

ENERGY EFFICIENT BUILDING :  
THE APPLICATION OF THERMAL ENERGY STORAGE  
(TES) FOR COOLING LOAD REDUCTION

TEE SWEE YIN

UNIVERSITI TUN HUSSEIN ONN MALAYSIA

PERPUSTAKAAN UTHM



\*30000002323066\*

CN 118914

UNIVERSITI TUN HUSSEIN ONN MALAYSIA

BORANG PENGESAHAN STATUS TESIS<sup>x</sup>

JUDUL: ENERGY EFFICIENT BUILDING : THE APPLICATION OF  
THERMAL ENERGY STORAGE (TES) FOR COOLING LOAD  
REDUCTION

SESI PENGAJIAN: 2008/2009

Saya TEE SWEE YIN (760313-01-6452)

(HURUF BESAR)

mengaku membenarkan tesis (PSM / Sarjana / Doktor Falsafah)\* ini disimpan di Perpustakaan Universiti Tun Hussein Onn Malaysia dengan syarat-syarat kegunaan seperti berikut:

1. Tesis adalah hakmilik Universiti Tun Hussein Onn Malaysia.
2. Perpustakaan dibenarkan membuat salinan untuk tujuan pengajian sahaja.
3. Perpustakaan dibenarkan membuat salinan tesis ini sebagai bahan pertukaran antara institusi pengajian tinggi.
4. \*\* Sila tandakan (✓).

SULIT

(Mengandungi maklumat yang berdarjah keselamatan atau kepentingan Malaysia seperti yang termaktub di dalam AKTA RAHSIA RASMI 1972.)

TERHAD

(Mengandungi maklumat TERHAD yang telah ditentukan oleh organisasi / badan di mana penyelidikan dijalankan)

TIDAK TERHAD

Disahkan oleh

  
(TANDATANGAN PENULIS)

  
(TANDATANGAN PENYELIA)

Alamat tetap:  
66, PARIT BILAL,  
83000 BATU PAHAT, JOHOR.


PROF. IR. MOHAMMAD ZAINAL  
BIN MD. YUSOF  
Nama Penyelia

Tarikh: 20 NOVEMBER 2008

Tarikh: 21 NOVEMBER 2008

- CATATAN \* Potong yang tidak berkenaan.  
\*\* Jika tesis ini SULIT atau TERHAD, sila lampirkan surat daripada pihak berkuasa / organisasi berkenaan dengan menyatakan sekali tempoh tesis ini perlu dikelaskan sebagai SULIT atau TERHAD.  
\* Tesis yang dimaksudkan sebagai tesis bagi Ijazah Doktor Falsafah dan Sarjana secara penyelidikan, atau disertai bagi pengajian secara kerja kursus dan penyelidikan, atau Laporan Projek Sarjana Muda (PSM).

“I declared that I had read this thesis and according to my opinion, this thesis is qualified in term of scope and quality for purpose of awarding the Master of Mechanical Engineering”

Signature : ..........  
Supervisor : Prof. Ir. Mohammad Zainal bin Md. Yusof  
Date : 21 NOVEMBER 2008

**ENERGY EFFICIENT BUILDING :  
THE APPLICATION OF THERMAL ENERGY STORAGE (TES)  
FOR COOLING LOAD REDUCTION**


**TEE SWEE YIN**

This thesis is submitted as a fulfillment of the requirements for the award of the  
degree of Master in Mechanical Engineering

Faculty of Mechanical and Manufacturing Engineering  
University Tun Hussein Onn Malaysia

NOVEMBER, 2008

“I declare that this thesis entitled “Energy Efficient Building : The Application Of Thermal Energy Storage (TES) For Cooling Load Reduction” is the result of my own research except as cited in references. This thesis has not been accepted for any degree and is not concurrently submitted in candidature of any degree”

Signature :  .....

Name of candidate : TEE SWEE YIN

Date : 21 NOVEMBER 2008

*To my loving parents, brothers and sister ...*

*“Thank you for your support”*

## **ACKNOWLEDGEMENT**

I would like to take this opportunity to forward my sincere appreciation to my supervisor, Professor Ir. Mohammad Zainal bin Md. Yusof for his thoughtful insights, helpful suggestions and supports in the form of knowledge and guidance during the course of this project.

Grateful thank to PPH members for their support and cooperation during this project.

My appreciation goes to the representative of Trane in providing the proposals of full storage and partial storage TES systems.

Special thank to Trane CDS Department for the use of TRACE 700 in calculating the cooling load.



## Abstract

A typical building zone designated as Zone PPU, in UTHM was selected for a detailed study of applying Thermal Energy Storage (TES) for cooling load reduction. Data of electricity bills from May 2005 to December 2007 were collected for analysis of usage trending. The energy consumption index for Zone PPU was also established and compared with MS1525 standard. The energy simulation program TRACE 700 was used to calculate the peak cooling loads for Zone PPU. Two storage systems using ice storage technology were being proposed in this study, which are full storage system and partial storage system. Two economical analysis tools, which are the Simple Payback Period method and Net Present Value method, were used to evaluate whether the proposals are economically viable to be considered. The energy consumption for buildings G1, G2 and G3 (of total floor areas 15,285 m<sup>2</sup>) for the year 2007 was 7,261,803kWh, giving an energy consumption index of 475kWh/m<sup>2</sup> per year which was far too much compared to the recommended value of 135kWh/m<sup>2</sup> per year as stated in MS1525 Standard. The analysis results indicated that the TES proposals for the existing cooling load of 1160RT has no attractive payback period and results negative net present value calculating up to the life span (of 15 years) of chillers with proper maintenance, indicating that the TES proposal is not economically viable. In view of the available market references, cooling load of 3000RT and above is required in order to achieve a more economically viable proposal. Therefore, several proposals with proposed capacity ranging from 2200RT, 2900RT, 3600RT and 4200RT have been made so that the most optimum load can be selected for future considerations.

## Abstrak

Zon tertentu di UTHM, Zon PPU, telah dipilih untuk kajian aplikasi *Thermal Energy Storage (TES)* dalam pengurangan beban penyejukan dan kesannya pengurangan pada penggunaan tenaga elektrik.. Data bil elektrik dari Mei 2005 ke Disember 2007 telah dikumpulkan untuk analisis trend penggunaan tenaga. Indeks tenaga untuk Zon PPU telah ditentukan dan dibandingkan dengan piawaian MS1525. Program simulasi tenaga TRACE 700 telah digunakan dalam mengirakan beban penyejukan puncak di Zon PPU. Dua sistem penyimpanan, iaitu sistem penyimpanan penuh dan sistem penyimpanan separa, dengan menggunakan teknologi penyimpanan ais telah dicadangkan dalam kajian ini. Dua kaedah analisis ekonomi, iaitu *Simple Payback Period* dan *Net Present Value* telah digunakan untuk menilai sama ada cadangan-cadangan ini adalah menguntungkan dari segi ekonomi. Pada tahun 2007, bangunan-bangunan G1, G2 dan G3 dengan keluasan 15,285m<sup>2</sup> telah menggunakan 7,261,803kWh, ini memberi nilai indeks penggunaan tenaga bernilai 475kWh/m<sup>2</sup>/tahun. Ini adalah jauh lebih besar berbanding nilai piawaian 135kWh/m<sup>2</sup>/tahun seperti yang dinyatakan dalam MS1525. Keputusan analisis menunjukkan bahawa cadangan *TES* untuk beban penyejukan 1160RT (Ton Penyejukan) yang sedia ada tidak memberi tempoh bayar balik yang menarik. Di samping itu, nilai negatif *net present value* yang dikira sehingga hayat guna chiller yang diselenggara dengan baik, selama 15 tahun, menunjukkan bahawa cadangan *TES* tidak menguntungkan dari segi ekonomi. Berpandukan rujukan pasaran sediada, beban penyejukan 3000RT dan ke atas adalah diperlukan bagi cadangan yang lebih ekonomik. Oleh itu, beberapa cadangan beban penyejukan daripada 2200RT, 2900RT, 3600RT dan 4200RT telah dibuat untuk mendapatkan cadangan beban yang paling optimum untuk pertimbangan masa akan datang.

**TABLE OF CONTENTS**

<b>CHAPTER</b>	<b>TOPIC</b>	<b>PAGE</b>
	<b>TITLE</b>	i
	<b>DECLARATION</b>	ii
	<b>DEDICATION</b>	iii
	<b>ACKNOWLEDGEMENT</b>	iv
	<b>ABSTRACT</b>	v
	<b>TABLE OF CONTENTS</b>	vii
	<b>LIST OF TABLES</b>	x
	<b>LIST OF FIGURES</b>	xi
	<b>LIST OF SYMBOLS</b>	xii
	<b>LIST OF APPENDICES</b>	xiii
<b>CHAPTER I :</b>	<b>INTRODUCTION</b>	
	1.1 Background	1
	1.2 Problem statement	3
	1.3 Objective	6
	1.4 Scope of study	6
	1.5 Significant of the project	7

**CHAPTER II : LITERATURE REVIEW AND THEORY**

2.1	Background	10
2.2	Introduction to thermal energy storage (TES)	11
2.3	Cooling load estimation method	15
2.3.1	Conduction through exterior walls, roof and glass	16
2.3.2	Conduction through interior partitions, ceilings and floors	17
2.3.3	Solar radiation through glass	17
2.3.4	Lighting	18
2.3.5	People	19
2.3.6	Equipment	19
2.3.7	Heat from infiltration of outside air through openings	20

**CHAPTER III : METHODOLOGY**

3.1	Introduction	21
3.2	The selected building	22
3.3	Building usage	28
3.4	Electric energy consumption pattern	28
3.5	Thermal storage technology	28
3.5.1	Introduction	28
3.5.2	Ice storage system	29
3.6	Economics analysis	34
3.6.1	Introduction	34
3.6.2	Simple payback period method (SPP)	34
3.6.3	Net present value method (NPV)	35

**CHAPTER IV : RESULT AND DISCUSSION**

4.1	Trend of electric energy consumption	37
4.2	Ice storage proposals	39
4.2.1	Load profile	39
4.2.2	Full storage system	41
4.2.3	Partial storage system	46
4.3	Economics analysis	51
4.3.1	Simple payback period	51
4.3.2	Net present value	52
4.4	Discussion	55

**CHAPTER V : CONCLUSION AND RECOMMENDATIONS**

5.1	Conclusion	57
5.2	Recommendations	58

<b>REFERENCES</b>	59
<b>APPENDIX A</b>	61
<b>APPENDIX B</b>	93
<b>APPENDIX C</b>	98
<b>APPENDIX D</b>	126

## LIST OF TABLES

TABLE NO.	TITLE	PAGE
Table 1.1:	Zoning other than PPU : Tariff B - Low Voltage Commercial Tariff	4
Table 1.2:	Zone PPU : Tariff C1 - Medium Voltage General Commercial Tariff	4
Table 2.1:	Commercial Tariff Category	13
Table 3.1:	Details of Blocks G1, G2 and G3	22
Table 3.2:	Physical and operational characteristics of Blocks G1, G2 and G3	25
Table 4.1:	Monthly Electricity Consumption for Zone PPU	38
Table 4.2:	Cooling load requirement for full storage system	41
Table 4.3:	Electrical load requirement for full storage system	43
Table 4.4:	Operation cost saving for full storage system	45
Table 4.5:	Cooling load requirement for partial storage system	46
Table 4.6:	Electrical load requirement for partial storage system	48
Table 4.7:	Operation cost saving for partial storage system	50
Table 4.8:	Results of payback period and net present value calculations	54
Table 4.9:	Comparison of investment priority between payback period method and net present value method	56

## LIST OF FIGURES

FIGURE NO.	TITLE	PAGE
Figure 1.1:	Commercial/Institutional Secondary Energy Use End-Use, 2002	3
Figure 1.2:	Yearly energy consumption in UTHM from 2002 to 2007	5
Figure 2.1:	Schematic representation of two building cooling TES systems: (a) with no storage and (b) with storage	11
Figure 2.2:	Heat gain components that contribute to the room cooling load	15
Figure 3.1:	Layout of Blocks G1, G2 and G3	25
Figure 3.2:	Glycol-based ice storage systems	30
Figure 3.3:	Design-day cooling load profile	31
Figure 3.4:	On peak and off peak periods	32
Figure 3.5:	Partial storage system	33
Figure 4.1:	Plot of monthly electricity consumption for Zone PPU in the year of 2006 and 2007	39
Figure 4.2:	Typical load profile for Blocks G1, G2 and G3	40
Figure 4.3:	Plot of Design Load Profile for Full Storage System	42
Figure 4.4:	Plot of Design Load Profile for Partial Storage System	48

### LIST OF SYMBOLS

SYMBOL	DESCRIPTION	UNIT
A	- area	ft <sup>2</sup>
BF	- ballast factor	--
CLF	- cooling load factor	--
CLTD	- modified temperature difference value that accounts for the heat storage/time lag effects	°F
CLTD <sub>c</sub>	- corrected value of CLTD	°F
DR	- daily temperature range	°F
LM	- correction for latitude and month	--
Q	- heat gain (cooling load)	BTU/hr
Q <sub>s</sub> , Q <sub>l</sub>	- sensible and latent heat gains (loads)	--
q <sub>s</sub> , q <sub>l</sub>	- sensible and latent heat gains per person	--
SC	- shading coefficient	--
SHGF	- maximum solar heat gain factor	BTU/hr/ft <sup>2</sup>
TD	- temperature difference between unconditioned and conditioned space	°F
T <sub>a</sub>	- average outside temperature on a design day	°F
T <sub>o</sub>	- outside design dry bulb temperature	°F
T <sub>R</sub>	- room temperature	°F
U	- overall heat transfer coefficient	BTU/hr-ft <sup>2</sup> -°F
W	- lighting capacity	watts



## LIST OF APPENDIX

FIGURE NO.	TITLE	PAGE
<b>APPENDIX A</b>	Energy Consumption In UTHM	61
Appendix A-1:	Data of Energy Consumption In UTHM From May 2002 To December 2007	62
Appendix A-2:	List Of Relevant Consuming Blocks	92
<b>APPENDIX B</b>	Cooling Load Calculations	93
Appendix B-1:	Zone Checksums – DK, EE & PM	94
Appendix B-2:	System Checksums	97
<b>APPENDIX C</b>	Proposal of Storage System for 3500RT	98
Appendix C-1:	Proposal of Full and Partial Storage TES System for 2200RT Cooling Load	99
Appendix C-2:	Proposal of Full and Partial Storage TES System for 2900RT Cooling Load	105
Appendix C-3:	Proposal of Full and Partial Storage TES System for 3600RT Cooling Load	111
Appendix C-4:	Proposal of Full and Partial Storage TES System for 4200RT Cooling Load	117
Appendix C-5:	Economical analysis of proposed plant sizes	123
Appendix C-4:	Comparison of investment priority between simple payback period method and net present value method for existing 1160RT capacity and proposed capacities	125

<b>APPENDIX D</b>	Company Information and Project References	126
Appendix D-1:	Company Information of Cristopia	127
Appendix D-2:	Project References	129

## **CHAPTER I**

### **INTRODUCTION**

#### **1.1 BACKGROUND**


Worldwide, people use about one third of the total energy consumption in buildings – for heating, cooling, cooking, lighting, and running appliances. Building-related energy demand is rising rapidly, particularly within our homes. But there are large differences in household energy use from one country to the next: for example, people in the United States and Canada consume 2.4 times much energy at home as those in Western Europe.

As homes become bigger, each individual house has more space to heat, cool, and light, as well as room for bigger and more appliances. Home appliances are the world's fastest-growing energy consumers after automobiles, accounting for 30 percent of industrial countries' electricity consumption and 12 percent of their greenhouse gas emissions (internet article: Making Better Energy Choices, <http://www.worldwatch.org>). In developing countries, meanwhile, the potential for appliance growth is enormous: sales of frost-free refrigerators in India alone are projected to grow nearly 14 percent annually.

Yet the same needs could be met with far less energy. Technologies available today could advance appliance efficiency by at least an additional 33 percent over the next decade, and further improvements in dryers, televisions, lighting, and standby power consumption could avoid more than half of projected consumption growth in the industrial world by 2030 (internet article: Making Better Energy Choices, <http://www.worldwatch.org>). In developing countries, people could save as much as 75 percent of their energy through improvements in building insulation, cooking, heating, lighting, and electrical appliances.

As shown in Figure 1.1, most of the energy consumed by commercial and institutional organizations is used to:

- i) Operate auxiliary equipment – devices that supply energy services to the major process technologies during their operation and that are common to most industries. Auxiliary equipment falls into five categories :
  - steam generation
  - permanent lighting
  - heating
  - ventilation and air conditioning
  - electric motors, including pumps, fans, compressors and conveyors
- ii) Supply plug load – the electricity demand from all equipment that is plugged into electrical outlets in buildings (principally office equipment, consumer electronics and portable lighting)



**Figure 1.1: Commercial/Institutional Secondary Energy Use End-Use, 2002**

(Source: *Energy Use Data Handbook*, Natural Resources Canada's Office of Energy Efficiency)

Improving energy efficiency, for instance in electricity use, will have two benefits: (World Energy Council, 2008)

- i) Supply more consumers with the same electricity production capacity, which is often the main constraint in many countries of Africa and Asia.
- ii) Slow down the electricity demand growth, and reduce the investment needed for the expansion of the electricity sector; this is especially important in countries with high growth of the electricity demand, such as China and many South East Asian countries.

## 1.2 PROBLEM STATEMENT

Data of the energy consumption in UTHM from 2002 to 2007 (Appendix A-1) has been collected and graph of yearly energy consumption was plotted (Figure 1.2). There were 14 zones in which monthly electricity bill were account for. The relevant

consuming blocks were listed as shown in Appendix A-2. From the data collected, the following considerations were to be taken into account for this project:

- i) Data from year 2002 to year 2004 were only indicated with electricity cost (RM), without total unit of kWh used. In addition, the data available for this period was not in complete set, which means some of the electricity bills were not available in the record. This is because the management of the electricity bills is taken over by Development and Property Management Office (Pejabat Pembangunan dan Pengurusan Hartabina) in year 2005 only.
- ii) Due to the reason stated in (i), the total unit of kWh for year 2002 to year 2004 was formulated from the total amount charged.
- iii) There was a tariff review effective from 1<sup>st</sup> June 2006. The tariff review is as follows (Table 1.1 and Table 1.2):

**Table 1.1: Zoning other than PPU : Tariff B - Low Voltage Commercial Tariff**

	Old Tariff (before June 2006)	New Tariff (effective from 1 <sup>st</sup> June 2006)
For all kWh	28.8 sen/kWh	32.3 sen/kWh

**Table 1.2: Zone PPU : Tariff C1 - Medium Voltage General Commercial Tariff**

	Old Tariff (before June 2006)	New Tariff (effective from 1 <sup>st</sup> June 2006)
For each kilowatt of maximum demand (MD) per month during the peak period	17.30 RM/kWh	19.50 RM/kWh
For all kWh	20.8 sen/kWh	23.4 sen/kWh




Figure 1.2: Yearly energy consumption in UTHM from 2002 to 2007

Zone PPU started its operation in May 2005 and was the main contributor to the energy consumption of UTHM despite its short length of service compared with other zones. Zone PPU covers areas for Block F2, G1 (FKEE), G2 (FKMP), G3 (lecture halls) and G4 (hostels). Why Zone PPU contributed the most to the total electricity bills of UTHM? What were the main factors contributing to this high electricity bills? Was there any possibility to reduce the consumption? These issues or questions had become the deriving force for undertaking the present project.

### **1.3 OBJECTIVE**

The objective of this project is to investigate the potential of applying Thermal Energy Storage (TES) technique in reducing the cooling load requirement for Technology Complex (Blocks G1 & G2) and Lecture Halls (Block G3) at UTHM.

### **1.4 SCOPE OF STUDY**

The scope of this project was to study energy efficiency in Universiti Tun Hussein Onn Malaysia. In this project, focus was given on the zone with the highest electricity energy consumption, which was Zone PPU (Technology Complex and Lecture Halls - Block G1, G2 and G3).

The scope of the study include:

- i) To identify the major area of energy consumption by studying the energy usage pattern.
- ii) To identify Building Energy Index (BEI) for Zone PPU and compare with MS1525 standard.