



THE UNIVERSITY *of* EDINBURGH

Edinburgh Research Explorer

Using Simple PID Controllers to Prevent and Mitigate Faults in Scientific Workflows

Citation for published version:

Ferreira da Silva, R, Filgueira Vicente, R, Deelman, E, Pairo-Castineira, E, Overton, I & Atkinson, M 2017, Using Simple PID Controllers to Prevent and Mitigate Faults in Scientific Workflows. in Proceedings of the 11th Workshop on Workflows in Support of Large-Scale Science co-located with The International Conference for High Performance Computing, Networking, Storage and Analysis (SC 2016). vol. 1800, CEUR Workshop Proceedings (CEUR-WS.org), Salt Lake City, Utah, USA, pp. 15-24, 11th Workshop on Workflows in Support of Large-Scale Science co-located with The International Conference for High Performance Computing, Networking, Storage and Analysis (SC 2016), Salt Lake City, United States, 14/11/16.

Link:

[Link to publication record in Edinburgh Research Explorer](#)

Document Version:

Peer reviewed version

Published In:

Proceedings of the 11th Workshop on Workflows in Support of Large-Scale Science co-located with The International Conference for High Performance Computing, Networking, Storage and Analysis (SC 2016)

General rights

Copyright for the publications made accessible via the Edinburgh Research Explorer is retained by the author(s) and / or other copyright owners and it is a condition of accessing these publications that users recognise and abide by the legal requirements associated with these rights.

Take down policy

The University of Edinburgh has made every reasonable effort to ensure that Edinburgh Research Explorer content complies with UK legislation. If you believe that the public display of this file breaches copyright please contact openaccess@ed.ac.uk providing details, and we will remove access to the work immediately and investigate your claim.



Using Simple PID Controllers to Prevent and Mitigate Faults in Scientific Workflows

Rafael Ferreira da Silva¹, Rosa Filgueira², Ewa Deelman¹
Erola Pairo-Castineira³, Ian Michael Overton⁴, Malcolm Atkinson⁵

¹University of Southern California, Information Sciences Institute, Marina Del Rey, CA, USA

²British Geological Survey, Lyell Centre, Edinburgh EH14 4AP

³MRC Institute of Genetics and Molecular Medicine, University of Edinburgh, Edinburgh, UK

⁴Usher Institute of Population Health Sciences and Informatics, University of Edinburgh, Edinburgh, UK

⁵School of Informatics, University of Edinburgh, Edinburgh EH8 9LE, UK

{rafsilva,deelman}@isi.edu, rosa@bgs.ac.uk, Erola.Pairo-Castineira@igmm.ed.ac.uk,
{ian.overton,malcolm.atkinson}@ed.ac.uk,

ABSTRACT

Scientific workflows have become mainstream for conducting large-scale scientific research. As a result, many workflow applications and Workflow Management Systems (WMSs) have been developed as part of the cyberinfrastructure to allow scientists to execute their applications seamlessly on a range of distributed platforms. In spite of many success stories, a key challenge for running workflows in distributed systems is failure prediction, detection, and recovery. In this paper, we propose an approach to use control theory developed as part of autonomic computing to predict failures before they happen, and mitigated them when possible. The proposed approach apply the *proportional-integral-derivative* controller (PID controller) control loop mechanism, which is widely used in industrial control systems, to mitigate faults by adjusting the inputs of the mechanism. The PID controller aims at detecting the possibility of a fault far enough in advance so that an action can be performed to prevent it from happening. To demonstrate the feasibility of the approach, we tackle two common execution faults of the Big Data era—data footprint and memory usage. We define, implement, and evaluate simple PID controllers to autonomously manage data and memory usage of a bioinformatics workflow that consumes/produces over 4.4TB of data, and requires over 24TB of memory to run all tasks concurrently. Experimental results indicate that workflow executions may significantly benefit from PID controllers, in particular under online and unknown conditions. Simulation results show that nearly-optimal executions (slowdown of 1.01) can be attained when using our proposed method, and faults are detected and mitigated far in advance.

Keywords

Scientific workflows, Fault detection and handling, Autonomic computing

1. INTRODUCTION

Scientific computing is the mainstream for scientists that want to extract the maximum information out of their data—which are often obtained from scientific instruments and processed in large-scale distributed systems. Scientific work-

flows have proven to process large-scale scientific computations in distributed systems, and have supported traditional and breakthrough researches across several domains [35]. In spite of impressive achievements today, failure prediction, detection, and recovery is still a major challenge in workload management in distributed system, both at the application and resource-level. Failures affect the turnaround time of the applications, and that of the greater analysis and therefore the productivity of the scientists that depend on the power of distributed computing to do their work.

In this work, we investigate how the *proportional-integral-derivative* controller (PID controller) control loop mechanism, which is widely used in industrial system, can be applied to predict and prevent failures on end-to-end workflow executions across distributed, heterogeneous computational environments. The basic idea behind a PID controller is to read data from a sensor, then compute the desired actuator output by calculating proportional (P), integral (I), and derivative (D) responses and summing those three components to compute the output. Each of the components can often be interpreted as the present error (P), the accumulation of past errors (I), and a prediction of future errors (D), based on current rate of change. The main advantage of using a PID controller is that the control loop mechanism progressively monitors the evolution of the workflow execution, detecting possible faults far in advance, and when needed performs actions to lead the execution to a steady-state.

The main contributions of this paper include:

1. The evaluation of PID controllers to prevent and mitigate two major problems of the Big Data era: data footprint and memory usage;
2. The characterization of a bioinformatics workflow, which consumes/produces over 4.4TB of data, and requires over 24TB of memory;
3. An experimental evaluation via simulation to demonstrate the feasibility of the proposed approach using simple PID controllers; and
4. A performance optimization study to tune the parameters of the control loop to provide nearly-optimal workflow executions, where faults are detected and handled far in advance.

2. RELATED WORK

Several offline strategies and techniques were developed to detect and handle failures during scientific workflow executions [3, 5, 24, 27, 28, 36]. Autonomic online methods were also proposed to cope with workflow failures at runtime, for example by providing checkpointing [20, 25, 30], provenance [13, 25], task resubmission [10, 31], and task replication [5, 8], among others. However, these systems do not aim to prevent faults, but mitigate them, and although task replication may increase the probability of having a successful execution in another computing resource, it should be used sparingly to avoid overloading the execution platform [7]. These systems also make strong assumptions about resource and application characteristics. Although several works address task requirement estimations based on provenance data [11, 18, 22, 29], accurate estimations are still challenging, and may be specific to a certain type of application. In [4], a prediction algorithm based on machine learning (Naïve Bayes classifier) is proposed to identify faults far in advance, and to apply preventive actions to mitigate the faults. Experimental results show that faults can be predicted up to 94% of accuracy, however the approach is tied to a small set of applications, and it is assumed that the application requirements do not change over time. In previous works, we proposed an autonomic method described as a MAPE-K loop to cope with online non-clairvoyant workflow executions faults on grids [15, 17], where unpredictability is addressed by using a-priori knowledge extracted from execution traces to identify severity levels of faults, and apply a specific set of actions. Although this is the first work on self-healing of workflow executions in online and unknown conditions, experimental results on a real platform show an important improvement of the QoS delivered by the system. However, the method does not prevent faults from happening (actions are performed once faults are detected). In [19], a machine learning approach based on inductive logic programming is proposed for fault prediction and diagnosis in grids. This approach is limited to small scale applications and a few parameters—the number of rules may exponentially increase as the number of tasks in a workflow or the accounted parameters increase.

To the best of our knowledge, this is the first work that uses PID controllers to mitigate faults in scientific workflow executions under online and unknown conditions.

3. PID CONTROLLERS

The keystone component of the proposed process is the *proportional-integral-derivative* controller (PID controller) [34] control loop mechanism, which is widely used in industrial control systems, to mitigate faults by adjusting the process control inputs. Examples of such systems are the ones where the temperature, pressure, or the flow rate, need to be controlled. In such scenarios, the PID controller aims at detecting the possibility of a fault far enough in advance so that an action can be performed to prevent it from happening. Figure 1 shows the general PID control system loop. The *setpoint* is the desired or command value for the process variable. The control system algorithm uses the difference between the output (process variable) and the *setpoint* to determine the desired actuator input to drive the system.

The control system performance is measured through a step function as a *setpoint* command variable, and the re-




Figure 1: General PID control system loop.




Figure 2: Response of a typical PID closed loop system.

sponse of the process variable. The response is quantified by measuring defined waveform characteristics as shown in Figure 2. Raise time is the amount of time the system takes to go from about 10% to 90% of the *steady-state*, or final, value. Percent overshoot is the amount that the process variable surpasses the final value, expressed as a percentage of the final value. Settling time is the time required for the process variable to settle to within a certain percentage (commonly 5%) of the final value. Steady-state error is the final difference between the process variable and the *setpoint*. Dead time is a delay between when a process variable changes, and when that change can be observed.

Process variables (output) are determined by fault-specific metrics quantified online. The *setpoint* is constant and defined as 1. The output of the PID controller is an input value for a *Curative Agent*, which determines whether an action should be performed (Figure 3). Negative input values mean the control system is raising too fast and may tend to the overshoot state (i.e., a faulty state), therefore preventive or corrective actions should be performed. Actions may include task pre-emption, task resubmission, task clustering, task cleanup, storage management, etc. In contrast, positive input values mean that the control system is smoothly rising to the steady state. The control signal $u(t)$ (output) is defined as follows:

$$u(t) = K_p e(t) + K_i \int_0^t e(t) dt + K_d \frac{de(t)}{dt}, \quad (1)$$

where K_p is the proportional gain constant, K_i is the integral gain constant, K_d is the derivative gain constant, and e is the error defined as the difference between the *setpoint* and the process variable value.

Tuning the proportional (K_p), integral (K_i), and derivative (K_d) gain constants is challenging and a research topic




Figure 3: General PID control system loop.

by itself. Therefore, in this paper we initially assume $K_p = K_i = K_d = 1$ for the sake of simplicity and to demonstrate the feasibility of the process, and then we use the Ziegler-Nichols closed loop method [37] for tuning the PID controllers (see Section 6).

4. DEFINING PID CONTROLLERS

In our proposed approach, a PID controller is defined and used for each possible-future fault identified from workload traces (historical data). In some cases, particular type of faults cannot be modeled as a full PID controller. For example, there are faults that cannot be predicted far in advance (e.g., unavailability of resources due to a power cut). In this case, a PI (*proportional-integral*) controller can be defined and deployed. In production systems, a large number of controllers may be defined and used to control, for example, CPU utilization, network bandwidth, etc. In this paper, we demonstrate the feasibility of the use of PID controllers by tackling two common issues of workflow executions: data and memory footprint.

4.1 Workflow Data Footprint and Management

In the era of Big Data Science, applications are producing and consuming ever-growing data sets. A run of scientific workflows that manipulate these data sets may lead the system to an out of disk space fault if no mechanisms are in place to control how the available storage is used. To prevent this, data cleanup tasks are often automatically inserted into the workflow by the workflow management system [33], or the number of concurrent task executions is limited to prevent data usage overflow. Cleanup tasks remove data sets that are no longer needed by downstream tasks, but nevertheless they add an important overhead to the workflow execution [9].

PID Controller. The controller process variable (output) is defined as the ratio of the estimated disk space required by current tasks in execution, and the actual available disk space. The system is in a *non-steady* state if the total amount of disk space consumed is above (overshoot) a predefine threshold (*setpoint*), or the amount of used disk space is below the *setpoint*. The proportional (P) response is computed as the error between the *setpoint*, and the actual used disk space; the integral (I) response is computed from the sum of the disk usage errors (cumulative value of the proportional responses); and the derivative (D) response is computed as the difference between the current and the previous disk overflow (or underutilization) error values.

Corrective Actions. The output of the PID controller (control signal $u(t)$, Equation 1) indicates whether the system is in a non-steady state. Negative values indicate that the current disk usage trespass the threshold of the minimum required available disk space (a safety measure to avoid an unrecoverable state). In contrast, positive values indicate that the current running tasks do not maximize disk usage. For values of $u(t) < 0$, (1) data cleanup tasks can be triggered to remove unused intermediate data (adding cleanup tasks may imply rearranging the priority of all tasks in the queue), or (2) tasks can be preempted due to the inability to remove data—the inability of cleaning up data may lead the execution to an unrecoverable state, and thereby to a failed execution. Otherwise (for $u(t) > 0$), the number of concurrent task executions may be increased.

4.2 Workflow Memory Usage and Management

Large scientific computing applications rely on complex workflows to analyze large volume of data. These tasks are often running in HPC resources over thousands of CPU cores and simultaneously performing data accesses, data movements, and computation, dominated by memory-intensive operations (e.g., reading a large volume of data from disk, decompressing in memory massive amount of data or performing a complex calculation which generates large datasets, etc.). The performance of those memory-intensive operations are quite often limited to the memory capacity of the resource where the application is being executed. Therefore, if those operations overflow the physical memory limit it can result to application’s performance degradation or application’s failure. Typically, the application end-user is responsible for optimizing the application, modifying the code if it is needed for complying the amount of memory that can be used on that resource. This work addresses the memory challenge proposing an *in-situ* analysis of memory, to adapt the number of concurrent tasks executions according to the memory usage required by an application at runtime.

PID Controller. The controller process variable (output) is defined as the ratio of the estimated total peak memory usage required by current tasks in execution, and the actual available memory. The system is in a *non-steady* state if the amount of memory available is below the *setpoint*, or if the current available memory is above it. The proportional (P) response is computed as the error between the memory consumption *setpoint* value, and the actual memory usage; the integral (I) response is computed from cumulative proportional responses (previous memory usage errors); and the derivative (D) response is computed as the difference between the current and the previous memory overflow (or underutilization) error values.

Corrective Actions. Negative values for the control signal $u(t)$ indicate that the ensemble of running tasks are leading the system to an overflow state, thus some tasks should be preempted to prevent the system to run out of memory. For positive $u(t)$ values, the memory consumption of current running tasks is below a predefined memory consumption *setpoint*. Therefore, the workflow management system may spawn additional tasks for concurrent execution.

5. EXPERIMENTAL EVALUATION

5.1 Scientific Workflow Application

The 1000 genomes project provides a reference for human variation, having reconstructed the genomes of 2,504 individuals across 26 different populations to energize these approaches [12]. The test case used in this work identifies mutational overlaps using data from the 1000 genomes project in order to provide a null distribution for rigorous statistical evaluation of potential disease-related mutations. This test case (Figure 4) has been implemented as a Pegasus [2, 14] workflow, and is composed of five different tasks:

Individuals. This task fetches and parses the Phase 3 data [12] from the 1000 genomes project per chromosome. These files list all of Single nucleotide polymorphisms (*SNPs*) variants in that chromosome and which individuals have each one. An *individual* task creates output files for each individual of *rs numbers*, where individuals have mutations on both alleles.




Figure 4: Overview of the 1000 genome sequencing analysis workflow.

Populations. The 1000 genome project has 26 different populations from many different locations worldwide [1]. The `populations` task fetches and parses five super populations (African, Mixed American, East Asian, European, and South Asian), and a set of all individuals.

Sifting. This task computes the *SIFT* scores of all of the *SNPs* variants, as computed by the Variant Effect Predictor (*VEP*). *SIFT* is a sequence homology-based tool that Sorts Intolerant From Tolerant amino acid substitutions, and predicts whether an amino acid substitution in a protein will have a phenotypic effect. *VEP* determines the effect of an individual variants on genes, transcripts, and protein sequence, as well as regulatory regions. For each chromosome, the `sifting` task processes the corresponding *VEP*, and selects only the *SNPs* variants that has a *SIFT* score.

Pair_Overlap_Mutations. This task measures the overlap in mutations (*SNPs*) among pairs of individuals. Considering two individuals, if both individuals have a given *SNP* then they have a mutation overlap. It performs several correlations including different number of pair of individuals, and different number of *SNPs* variants (only the *SNPs* variants with a score less than 0.05, and all the *SNPs* variants); and computes an array (per chromosome, population, and *SIFT* level selected) which has as many entries as individuals—each entry contains the list of *SNPs* variants per individual according to the *SIFT* score.

Frequency_Overlap_Mutations. This task calculates the frequency of overlapping mutations across n subsamples of j individuals. For each run, the task randomly selects a group of 26 individuals from this array and computes the number of overlapping in mutations among the group. Then, the task computes the frequency of mutations that has the same number of overlapping in mutations.

5.2 Workflow Characterization

We profiled the 1000 genome sequencing analysis workflow using the Kickstart [23] profiling tool. Kickstart monitors and records task execution in scientific workflows (e.g., process I/O, runtime, memory usage, and CPU utilization).

Runs were conducted on the *Eddie Mark 3*, which is the third iteration of the University of Edinburgh’s compute cluster. The cluster is composed of 4,000+ cores with up to 2 TB of memory. For running the characterization experiments, we have used three types of nodes, depending of the size of memory required for each task:

- 1 Large node with 2 TB RAM, 32 cores, Intel® Xeon® Processor E5-2630 v3 (2.4 GHz), for running the **individual** tasks;
- 1 Intermediate node with 192GB RAM, 16 cores, Intel® Xeon® Processor E5-2630 v3 (2.4 GHz), for running the **sifting** tasks;
- 2 Standards nodes with 64 GB RAM, 32 cores, Intel® Xeon® Processor E5-2630 v3 (2.4 GHz), for running the remaining tasks.

Table 1 shows the execution profile of the workflow. Most of the workflow execution time is allocated to the **individual** tasks. These tasks are in the critical path of the workflow due to their high demand of disk (174GB in average per task) and memory (411GB in average per task). The total workflow data footprint is about 4.4TB. Although the large node provides 2 TB of RAM and 32 cores, we would only be able to run up to 4 concurrent tasks per node. In *Eddie Mark 3*, the standard disk quota is 2GB per user, and 200GB per group. Since this quota would not suffice to run all tasks of the 1000 genome sequencing analysis workflow (even if all tasks run sequentially), we had a special arrangement to increase our quota to 500GB. Note that this increased quota allow us to barely run up to 3 concurrent **individual** tasks in the large node, and some of the remaining tasks in smaller nodes. Therefore, data and memory management is crucial to perform a successful run of the workflow execution, while increasing user satisfaction.

5.3 Experiment Conditions

The experiments use trace-based simulation. Since most workflow simulators are event-based [6,16], we developed an activity-based simulator to simulate every time slice of the PID controllers behaviors (which is available online [32]). The simulator provides support for task scheduling and resource provisioning at the workflow level. The simulated computing environment represents the three nodes from the *Eddie Mark 3* cluster described in Section 5.2 (total 80 CPU cores). Additionally, we assume a shared network file system among the nodes with total capacity of 500GB.

We use an FCFS policy with task preemption and backfill for task scheduling—tasks submitted at the same time are randomly chosen, and preempted tasks return to the top of the queue. To avoid unrecoverable faults due to run out of disk space, we implemented a data cleanup mechanism to remove data that are no longer required by downstream tasks [33]. Data cleanup tasks are only triggered if the maximum storage capacity is reached. In this case, all running tasks are preempted, the data cleanup task is executed, and the workflow resumes its execution. Note that this mechanism may add an important overhead to the workflow execution.

The goal of this experiment is to ensure that correctly defined executions complete, that performance is acceptable, and that possible-future faults are quickly detected and automatically handled before they lead the workflow execution to an unrecoverable state (measured by the number of data cleanup tasks used). Therefore, we do not attempt to op-

Task	Count	Runtime		Data Footprint		Memory Peak	
		Mean (s)	Std. Dev.	Mean (GB)	Std. Dev.	Mean (GB)	Std. Dev.
Individual	22	31593.7	17642.3	173.79	82.34	411.08	17.91
Population	7	1.14	0.01	0.02	0.01	0.01	0.01
Sifting	22	519.9	612.4	0.94	0.43	7.95	2.47
Pair_Overlap_Mutations	154	160.3	318.7	1.85	0.85	17.81	20.47
Frequency_Overlap_Mutations	154	98.8	47.1	1.83	0.86	8.18	1.42
Total (cumulative)	359	590993.8	–	4410.21	–	24921.58	–

Table 1: Execution profile of the 1000 genome sequencing analysis workflow.

timize task preemption (which criteria should be used to select tasks for removal, or perform checkpointing) since our goal is to demonstrate the feasibility of the approach with simple use case scenarios.

PID Controllers. The response variable of the control loop that leads the system to a *setpoint* (or within a steady-state error) is defined as waveforms, which can be composed of overshoots or underutilization of the system. In order to accommodate overshoots, we arbitrarily define our *setpoint* as 80% of the maximum total capacity (for both storage and memory usage), and a steady-state error of 5%. For this experiment we assume $K_p = K_i = K_d = 1$ to demonstrate the feasibility of the approach regardless the use of tuning methods. A single PID controller u_d is used to manage disk usage (shared network file system), while an independent memory controller u_m^n is deployed for each computing node n . The controller input value indicates the amount of disk space or memory that should be consumed by tasks. If the input value is positive, more tasks are scheduled (resp. tasks are preempted). When managing a set of controllers, it is important to ensure that an action performed by a controller does not counteract an action performed by another one. In this paper, the decision on the number of tasks to be scheduled/preempted is computed as the *min* between the response value of the unique disk usage PID controller, and the memory PID controller per resource, i.e., $\min(u_d, u_m^n)$. The control loop process uses then the mean values presented in Table 1 to estimate the number of tasks to be scheduled/preempted. Note that due to the high values of standard deviation, estimations may not be accurate. Task characteristics estimation is beyond the scope of this work, and sophisticated methods to provide accurate estimates can be found in [11, 18, 22, 29]. However, this work intend to demonstrate that even using inaccurate estimation methods, PID controllers can cope with the estimation error.

Reference Workflow Execution. In order to measure the efficiency of our online method under online and unknown conditions, we compare the workflow execution performance (in terms of the turnaround time to execute all tasks) to a reference workflow—computed offline under known conditions, i.e., all requirements (e.g., runtime, disk, memory) are accurate and known in advance. We performed several runs for the reference workflow, which yields an averaged makespan of 382,887.7s (~ 106 h, standard deviation $\leq 5\%$).

5.4 Experimental Results and Discussion

We have conducted workflow runs with three different types of controllers: (P) only the proportional component is evaluated: $k_p = 1$, and $K_i = K_d = 0$; (PI) the proportional and integral components are enabled: $k_p = k_i = 1$, and $k_d = 0$; and (PID) all components are activated: $k_p =$

Configuration	Avg. Makespan (h)	Slowdown
Reference	106.36	–
P	138.76	1.30
PI	126.69	1.19
PID	114.96	1.08

Table 2: Average workflow makespan for different configurations of the controllers: (P) proportional, (PI) proportional-integral, and (PID) proportional-integral-derivative. Reference denotes the makespan of a reference workflow execution computed offline and under known conditions.

$k_i = k_d = 1$. The reference workflow execution is reported as **Reference**. We have performed several runs of each configuration to produce results with statistical significance (errors below 5%).

Overall makespan evaluation. Table 2 shows the average makespan (in hours) for the three configurations of the controller and the reference workflow execution. The degradation of the makespan is expected due to the online and unknown conditions (no information about the tasks is known in advance). In spite of the mean does not provide accurate estimates, the use of a control loop mechanism diminishes this effect. The use of controllers may also degrade the makespan due to task preemption. However, if tasks were scheduled only using the estimates from the mean, the workflow would not complete its execution due to lack of disk space or memory overflows.

Executions using PID controllers outperforms executions using only the proportional (P) or the PI controller. The PID controller slows down the application of 1.08, while the application slowdown is 1.19 and 1.30 for the PI and P controllers, respectively. This result suggests that the derivative component (prediction of future errors) has significant impact on the workflow executions, and that the accumulation of past errors (integral component) also has important contribution to prevent and mitigate faults. Therefore, below we analyze how each of these components influence the number of tasks scheduled, and the peaks and troughs of the controller response function. We did not perform runs where mixed PID, PI, and P controllers were part of the same simulation, since it would be very difficult to determine the influence of each controller.

Data footprint. Figure 5 shows the time series of the number of tasks scheduled or preempted during the workflow executions. For each controller configuration, we present a single execution which the makespan is the closest to the average makespan value shown in Table 2. Task preemption is represented as negative values (red bars), while positive values (blue bars) indicate the number of tasks scheduled




Figure 5: Data Footprint: Number of tasks scheduled (blue bars for positive values) and preempted (red bars for negative values) during the lifespan of a workflow execution (left y -axis). The right y -axis represents the step response of the controller input value (black line) during the workflow execution.

at an instant of time. Additionally, the right y -axis shows the step response of the controller input value (black line) for disk usage during the workflow execution. Recall that *positive* input values ($u(t) > 0$, Equation 1) trigger task scheduling, while *negative* input values ($u(t) < 0$) trigger task preemption.

The proportional controller (P, Figure 5a) is limited to the current error, i.e., the amount of disk space that is over/underutilized. Since the controller input value is strictly proportional to the error, there is a burst on the number of tasks to be schedule at the beginning of the execution. This bursty pattern and the nearly constant variation of the input value lead the system to an inconsistent state, where the remaining tasks to be scheduled cannot lead the controller within the steady-state. Consequently, tasks are constantly scheduled and then preempted. In the example scenario shown in Figure 5a, this process occurs during about 4h, and performs more than 6,000 preemptions. Table 3 shows the average number of preemptions and cleanup tasks occurrences per workflow execution. In average, proportional controllers produced more than 7,000 preemptions, but no cleanup tasks. The lack of cleanup tasks indicate that the number of concurrent executions is very low (mostly influenced by the number of task preemptions), which is observed from the high average application slowdown of 1.30.

Controller	# Tasks Preempted	# Cleanup Tasks
P	7225	0
PI	168	48
PID	73	4

Table 3: Average actual number of tasks preempted and cleanup tasks executed per workflow run for the P, PI, and PID controllers.

The proportional-integral controller (PI, Figure 5b) aggregates the cumulative error when computing the response of the controller. As a result, the bursty pattern is smoothed along the execution, and task concurrency is increased. The cumulative error tend to increase the response of the PI controller at each iteration (both positively or negatively). Thus, task preemption occurs earlier during execution. On the other hand, this behavior mitigates the *vicious circle* present in the P controllers, and consequently the average number of preempted tasks is substantially reduced to 168 (Table 3). A drawback of using a PI controller, is the presence of cleanup tasks, which is due to the higher level of concurrency among task executions.

The proportional-integral-derivative controller (PID, Figure 5c) gives significant importance to the previous response produced by the controller (the last computed error). The

derivative component drives the controller to trigger actions once the current error follows (or increase) the previous error trend. In this case, the control loop only performs actions when disk usage is moving towards an overflow or under-utilization state. Note that the number of actions (scheduling/preemption) triggered in Figure 5c is much less than the number triggered by the PI controller: the average number of preempted tasks is 73, and only 4 cleanup tasks in average are spawned (Table 3).

Memory Usage. Figure 6 shows the time series of the number of tasks scheduled or preempted during the workflow executions for the memory controllers. The right y -axis shows the step response of the controller input value (black line) for memory usage during the workflow execution. We present the response function of a controller attached to a standard cluster (32 cores, 64GB RAM, Section 5.2), which runs the `population`, `pair_overlap_mutations`, and `frequency_overlap_mutations` tasks. The total memory allocation required to run all these tasks is over 4TB, which might lead the system to memory overflow states.

When using the proportional controller (P, Figure 6a), most of the actions are triggered by the data footprint controller (Figure 5a). As aforementioned, memory does not become an issue when only the proportional error is accounted, since task execution is nearly sequential (low level of concurrency). As a result, only a few tasks (in average less than 5) are preempted due to memory overflow. Note that the process of constant task scheduling (~ 50 h of execution) is strongly influenced by the memory controller. Also, the step response shown in Figure 6a highlights that most of the task preemptions occur in the standard cluster. This result suggests that actions performed by the global data footprint controller is affected by actions triggered by the local memory controller. The analysis of the influence of multiple concurrent controllers is out of the scope of this paper, however this result demonstrates that controllers should be used sparingly, and actions triggered by controllers should be performed by priority or the controller hierarchical level.

The PI controller (Figure 6b) mitigates this effect, since the cumulative error prevents the controller to trigger repeatedly actions. Observing the step response of the PI memory controller and the PI data footprint controller (Figure 5b), we notice that most of the task preemptions are triggered by the memory controller, particularly in the first quarter of the execution. The average data footprint per task of the `population`, `pair_overlap_mutations`, and `frequency_overlap_mutations` tasks is 0.02GB, 1.85GB, and 1.83GB (Table 3), respectively. Thus, the data footprint controller tends to increase the number of concurrent tasks. In the absence of memory controllers, the workflow execution would tend to memory overflow, and thereby into a failed state.

The derivative component of the PID controller (Figure 6c) acts as a catalyzer to improve memory usage: it decreases the overshoot and the settling time without affecting the steady-state error. As a result, the number of actions triggered by the PID memory controller is significantly reduced when compared to the PI or P controllers.

Although the experiments conducted in this feasibility study considered equal weights for each of the components in a PID controller (i.e., $k_p = k_i = k_d = 1$), we have demonstrated that correctly defined executions complete with acceptable performance, and that faults were detected far in

Control Type	K_p	K_i	K_d
P	$0.50 \cdot K_u$	–	–
PI	$0.45 \cdot K_u$	$1.2 \cdot K_p/T_u$	–
PID	$0.60 \cdot K_u$	$2 \cdot K_p/T_u$	$K_p \cdot T_u/8$

Table 4: Ziegler-Nichols tuning, using the oscillation method. These gain values are applied to the parallel form of the PID controller, which is the object of study in this paper. When applied to a standard PID form, the integral and derivative parameters are only dependent on the oscillation period T_u .

advance, and automatically handled before they lead the workflow execution to an unrecoverable state. In the next section, we explore the use of a simple and commonly used tuning method to calibrate the three PID gain parameters.

6. TUNING PID CONTROLLERS

The goal of tuning a PID loop is to make it stable, responsive, and to minimize overshooting. However, there is no optimal way to achieve responsiveness without compromising overshooting, or vice-versa. Therefore, a plethora of methods have been developed for tuning PID control loops. In this paper, we use the *Ziegler-Nichols* method to tune the gain parameters of the data footprint and memory controllers. This is one of the most common heuristics that attempts to produce tuned values for the three PID gain parameters (K_p , K_i , and K_d) given two measured feedback loop parameters derived from the following measurements: (1) the period T_u of the oscillation frequency at the stability limit, and (2) the gain margin K_u for loop stability. In this method, the K_i and K_d gains are first set to zero. Then, the proportional gain K_p is increased until it reaches the ultimate gain K_u , at which the output of the loop starts to oscillate. K_u and the oscillation period T_u are then used to set the gains according to the values described in Table 4 [26]. A detailed explanation of the method can be found in [37]. In this section, we will present how we determine the period T_u , and the gain margin K_u for loop stability.

6.1 Determining T_u and K_u

The Ziegler-Nichols oscillation method is based on experiments executed on an established closed loop. The overview of the tuning procedure is as follows [21]:

1. Turn the PID controller into a P controller by setting $K_i = K_d = 0$. Initially, K_p is also set to zero;
2. Increase K_p until there are sustained oscillations in the signal in the control system. This K_p value is denoted the ultimate (or critical) gain, K_u ;
3. Measure the ultimate (or critical) period T_u of the sustained oscillations; and
4. Calculate the controller parameter values according to Table 4, and use these parameter values in the controller.

Since workflow executions are intrinsically dynamic (due to the arrival of new tasks at runtime), it is difficult to establish a sustained oscillation in the signal. Therefore, in this paper we measured sustained oscillation in the signal within the execution of long running tasks—in this case the `individual` tasks (Table 1). We conducted several runs ($O(100)$) with the proportional (P) controller to compute the period T_u and the gain margin K_u . Table 5 shows the values for K_u and




Figure 6: Memory Usage: Number of tasks scheduled (blue bars for positive values) and preempted (red bars for negative values) during the lifespan of a workflow execution (left y -axis). The right y -axis represents the step response of the controller input value (black line) during the workflow execution. This figure shows the step response function of a controller attached to a standard cluster (32 cores, 64GB RAM), which has more potential to arise memory overflows.

Controller	K_u	T_u	K_p	K_i	K_d
Data Footprint	0.58	3.18	0.35	0.22	0.14
Memory Usage	0.53	12.8	0.32	0.05	0.51

Table 5: Tuned gain parameters (K_p , K_i , and K_d) for both the data footprint and memory usage PID controllers. K_u and T_u are computed using the Ziegler-Nichols method, and represent the ultimate period and critical gain, respectively.

T_u for each controller used in the paper, as well as the tuned gain values for K_p , K_i , and K_d for the PID controller.

6.2 Experimental Evaluation and Discussion

We have conducted runs with the tuned PID controllers for both the data footprint and memory usage. Figure 7 shows the time series of the number of tasks scheduled or preempted during the workflow executions, and the step response of the controller input value (right y -axis). The average workflow execution makespan is 386,561s, which yields a slowdown of 1.01. The average number of preempted tasks is around 18, and only a single cleanup task was used in each workflow execution. The controller step responses, for

both the data footprint (Figure 7a) and the memory usage (Figure 7b), show lower peaks and troughs values during the workflow execution when compared to the PID controllers using equal weights for the gain parameters (Figures 5c and 6c, respectively). More specifically, the controller input value is reduced of about 30% for the memory controller attached to a standard cluster. This behavior is attained through the ponderations provided by the tuned parameters. However, tuning the gain parameters cannot ensure that an optimal scheduling will be produced for workflow runs (mostly due to the dynamism inherent to workflow executions) as few preemptions are still triggered.

Although the Ziegler-Nichols method provides quasi-optimal workflow executions (for the workflow studied in this paper), the key factor of its success is due to the specialization of the controllers to a single application. In production systems, such methodology may not be realistic because of the variety of applications running by different users—deploying a PID controller per application and per component (e.g., disk, memory, network, etc.) may significantly increase the complexity of the system and the system’s requirements. On the other hand, controllers may be deployed on the user’s space (or per workflow engine) to manage a small number of workflow executions. In addition, the time required to pro-




Figure 7: Tuning PID Controllers: Number of tasks scheduled (blue bars for positive values) and preempted (red bars for negative values) during the lifespan of a workflow execution (left y -axis). The right y -axis represents the step response of the controller input value (black line) during the workflow execution. The bottom of the figure shows the step response function of a memory controller attached to a standard cluster (32 cores, 64GB RAM), which has more potential to arise memory overflows. The average workflow makespan is 386,561s, i.e. an average application slowdown of 1.01.

cess the current state of the system and decide whether to trigger an action is nearly instantaneous, what favors the use of PID controllers on online and real-time workflow systems. More sophisticated methods (e.g., using machine learning) may provide better approaches to tune the gain parameters. However, they may also add an important overhead.

7. CONCLUSION

In this paper, we have described, evaluated, and discussed the feasibility of using simple PID (proportional-integral-derivative) controllers to prevent and mitigate faults online and under unknown conditions in workflow executions. We have addressed two common faults of today’s science applications, data footprint and memory usage (main issues in data-intensive workflows), as use cases to demonstrate the feasibility of the proposed approach.

Experimental results using simple defined control loops (no tuning) show that faults are detected and prevented far in advance, leading workflow execution to its completion with acceptable performance (slowdown of 1.08). The experiments also demonstrated the importance of each component in a PID controller. We then used the Ziegler-Nichols method to tune the gain parameters of the controllers (both data footprint and memory usage). Experimental results show that the control loop system produced nearly optimal scheduling—slowdown of 1.01. Therefore, we claim that the preliminary results of this work open a new venue of research in workflow management systems.

We acknowledge that PID controllers should be used sparingly, and metrics (and actions) should be defined in a way that they do not lead the system to an inconsistent state—as observed in this paper when only the proportional component was used. Therefore, we plan to investigate the si-

multaneous use of multiple control loops at the application and infrastructure levels, to determine to which extent this approach may negatively impact the system. We also plan to extend our synthetic workflow generator [16] (that can produce realistic synthetic workflows based on profiles extracted from execution traces) to generate estimates of data and memory usages based on the gathered measurements.

Acknowledgments. This work was funded by DOE contract number #DESC0012636, “Panorama—Predictive Modeling and Diagnostic Monitoring of Extreme Science Workflows”. This work was carried out when Rosa Filgueira worked for the University of Edinburgh, and was funded by the Postdoctoral and Early Career Researcher Exchanges (PECE) fellowship funded by the Scottish Informatics and Computer Science Alliance (SICSA) in 2016, and the Wellcome Trust-University of Edinburgh Institutional Strategic Support Fund.

8. REFERENCES

- [1] Populations - 1000 genome. <http://1000genomes.org/category/population>.
- [2] 1000genome workflow. <https://github.com/pegasus-isi/1000genome-workflow>.
- [3] H. Arabnejad et al. Fairness resource sharing for dynamic workflow scheduling on heterogeneous systems. In *2012 IEEE 10th International Symposium on Parallel and Distributed Processing with Applications (ISPA)*, pages 633–639. IEEE, 2012.
- [4] A. Bala et al. Intelligent failure prediction models for scientific workflows. *Expert Systems with Applications*, 42(3):980–989, 2012.
- [5] O. A. Ben-Yehuda et al. Expert: Pareto-efficient task replication on grids and a cloud. In *2012 IEEE 26th*

- International Parallel & Distributed Processing Symposium (IPDPS)*, pages 167–178. IEEE, 2007.
- [6] R. N. Calheiros et al. Cloudsim: a toolkit for modeling and simulation of cloud computing environments and evaluation of resource provisioning algorithms. *Software: Practice and Experience*, 41(1):23–50, 2011.
- [7] H. Casanova. On the harmfulness of redundant batch requests. In *15th IEEE International Conference on High Performance Distributed Computing*, pages 255–266. IEEE, 2006.
- [8] I. Casas et al. A balanced scheduler with data reuse and replication for scientific workflows in cloud computing systems. *Future Generation Computer Systems*, 2016.
- [9] W. Chen et al. Workflow overhead analysis and optimizations. In *Proceedings of the 6th workshop on Workflows in support of large-scale science*, pages 11–20. ACM, 2011.
- [10] W. Chen et al. Dynamic and fault-tolerant clustering for scientific workflows. *IEEE Transactions on Cloud Computing*, 4(1):49–62, 2016.
- [11] A. M. Chirkin et al. Execution time estimation for workflow scheduling. In *9th Workshop on Workflows in Support of Large-Scale Science (WORKS)*, pages 1–10, 2014.
- [12] . G. P. Consortium et al. A global reference for human genetic variation. *Nature*, 526(7571):68–74, 2012.
- [13] F. Costa et al. Handling failures in parallel scientific workflows using clouds. In *High Performance Computing, Networking, Storage and Analysis (SCC)*, pages 129–139, 2012.
- [14] E. Deelman et al. Pegasus, a workflow management system for science automation. *Future Generation Computer Systems*, 46(0):17–35, 2015.
- [15] R. Ferreira da Silva et al. Self-healing of workflow activity incidents on distributed computing infrastructures. *Future Generation Computer Systems*, 29(8):2284–2294, 2013.
- [16] R. Ferreira da Silva et al. Community resources for enabling and evaluating research on scientific workflows. In *10th IEEE International Conference on e-Science, eScience’14*, pages 177–184, 2014.
- [17] R. Ferreira da Silva et al. Controlling fairness and task granularity in distributed, online, non-clairvoyant workflow executions. *Concurrency and Computation: Practice and Experience*, 26(14):2347–2366, 2014.
- [18] R. Ferreira da Silva et al. Online task resource consumption prediction for scientific workflows. *Parallel Processing Letters*, 25(3), 2015.
- [19] M. Ferro et al. A proposal to apply inductive logic programming to self-healing problem in grid computing: How will it work? *Concurrency and Computation: Practice and Experience*, 23(17):2118–2135, 2011.
- [20] A. Hary et al. Design and evaluation of a self-healing kepler for scientific workflows. In *19th ACM International Symposium on High Performance Distributed Computing (HPDC)*, pages 340–343, 2010.
- [21] F. Haugen. Ziegler-nichols’ closed-loop method. Technical report, TechTeach, 2010.
- [22] H. Hiden et al. A framework for dynamically generating predictive models of workflow execution. In *8th Workshop on Workflows in Support of Large-Scale Science (WORKS)*, pages 77–87, 2013.
- [23] G. Juve et al. Practical resource monitoring for robust high throughput computing. In *2nd Workshop on Monitoring and Analysis for High Performance Computing Systems Plus Applications, HPCMASPA’15*, pages 650–657, 2015.
- [24] G. Kandaswamy et al. Fault tolerance and recovery of scientific workflows on computational grids. In *2008. CCGRID’08. 8th IEEE International Symposium on Cluster Computing and the Grid*, pages 777–782. IEEE, 2013.
- [25] S. Köhler et al. Improving workflow fault tolerance through provenance-based recovery. In *International Conference on Scientific and Statistical Database Management*, pages 207–224, 2011.
- [26] A. S. McCormack et al. Rule-based autotuning based on frequency domain identification. *Control Systems Technology, IEEE Transactions on*, 6(1):43–61, 1992.
- [27] J. Montagnat et al. Workflow-based comparison of two distributed computing infrastructures. In *2010 5th Workshop on Workflows in Support of Large-Scale Science (WORKS)*, pages 1–10. IEEE, 2009.
- [28] N. Muthuvelu et al. Task granularity policies for deploying bag-of-task applications on global grids. *Future Generation Computer Systems*, 29(1):170–181.
- [29] I. Pietri et al. A performance model to estimate execution time of scientific workflows on the cloud. In *2014 9th Workshop on Workflows in Support of Large-Scale Science (WORKS)*, pages 11–19. IEEE, 2014.
- [30] D. Poola et al. Fault-tolerant workflow scheduling using spot instances on clouds. *Procedia Computer Science*, 29:523–533, 2014.
- [31] D. Poola et al. Enhancing reliability of workflow execution using task replication and spot instances. *ACM Transactions on Autonomous and Adaptive Systems (TAAS)*, 10(4):30, 2015.
- [32] Pid simulator.
<https://github.com/rafaelfsilva/pid-simulator>.
- [33] S. Srinivasan et al. A cleanup algorithm for implementing storage constraints in scientific workflow executions. In *9th Workshop on Workflows in Support of Large-Scale Science, WORKS’14*, pages 41–49, 2014.
- [34] S. W. Sung et al. Proportional–integral–derivative control. *Process Identification and PID Control*, pages 111–149, 2003.
- [35] I. J. Taylor et al. *Workflows for e-Science: scientific workflows for grids*. 2014.
- [36] Y. Zhang et al. Combined fault tolerance and scheduling techniques for workflow applications on computational grids. In *9th IEEE/ACM International Symposium on Cluster Computing and the Grid*, pages 244–251. IEEE Computer Society, 2008.
- [37] J. G. Ziegler et al. Optimum settings for automatic controllers. *trans. ASME*, 64(11), 2010.