## **CYBER SWITCHING ATTACKS ON SMART GRIDS**

HAZEM KARBOUJ



Department of Electrical Engineering National Institute of Technology, Rourkela Rourkela – 769008, India

#### **CYBER SWITCHING ATTACKS ON SMART GRIDS**

Thesis submitted in June 2016 to the department of **Electrical Engineering** in partial fulfillment of the requirements for the degree of **Master of Technology** by **Hazem Karbouj** 

> (Roll Number 214EE4007) under the supervision of Dr. Somnath Maity



Department of Electrical Engineering National Institute of Technology, Rourkela Rourkela – 769008, India



Electrical Engineering National Institute of Technology Rourkela

Rourkela-769008, India. www.nitrkl.ac.in

#### Certificate

This is to certify that the thesis entitled "Cyber Switching Attacks on Smart Grids" submitted by Hazem Karbouj, in partial fulfillment of the requirements for the award of Master of Technology in Electrical Engineering, in the Department of Electrical Engineering, with specialization in Power Electronics and Drives at National Institute of Technology - Rourkela is a genuine thesis carried out by him under my guidance and supervision. To the best of my knowledge, the material personified in the thesis has not been submitted to any other University, College or Institute for the award of any Degree or Diploma.

Date:

Dr. Somnath Maity Assistant Professor Department of Electrical Engineering *Thesis Supervisor* 

#### **Declaration of Originality**

I, Hazem Karbouj, Roll Number 214EE4007 hereby declare that this dissertation entitled *Cyber Switching Attacks on Smart Grids* presents my original work carried out as a doctoral student of NIT Rourkela and, to the best of my knowledge, contains no material previously published or written by another person, nor any material presented by me for the award of any degree or diploma of NIT Rourkela or any other institution. Any contribution made to this research by others, with whom I have worked at NIT Rourkela or elsewhere, is explicitly acknowledged in the dissertation. Works of other authors cited in this dissertation have been duly acknowledged under the sections Reference or Bibliography. I have also submitted my original research records to the scrutiny committee for evaluation of my dissertation. I am fully aware that in a case of any non-compliance detected in future, the Senate of NIT Rourkela may withdraw the degree awarded to me on the basis of the present dissertation.

May 31, 2016 NIT Rourkela Hazem Karbouj 214EE4007 Dedicated to my parents, brothers and sisters.

#### Acknowledgment

I would like to express my sincere gratitude and thanks to my supervisor Dr. Somnath Maity, Asst. Professor, Department of Electrical Engineering for his continuous inspiration and support. I am grateful to him for helping me to understand the problem deeply and providing visions towards the solution.

I extend my gratitude to the Prof. Anup Kumar Panda for his continuous encouraging and support. I would like also to thank all professors and administrative staff of electrical engineering department for their help.

As I did this project far away from my country there is a person who stood with me in all circumstances, who inspired me a lot and was the big brother, he is Abdullahi Alkhalifa, I would like to thank him for all incorporeal support and inspiration.

Finally this thesis would have been difficult to complete without the continuous moral support from my family members and my best friends, I would like to thank them all.

#### Hazem Karbouj

#### Abstract

As we live in smart grid revolution, the conventional power systems turn into a fast pace toward smart grids, this transition creates new and significant challenges on the electrical network security level; In addition to the important features of the smart grids, cyber security transpire to be a serious issue due to connecting all the loads, generation units, renewable resources, substations and switches via communication network. Cyber-physical attacks are classified as the major threatening of smart grids security, this attacks may lead to a many severe repercussions in the smart grid such as large blackout and destruction of infrastructures. Switching attack is one of the most serious cyber-physical attacks on smart grids because it is direct, fast, and effective in destabilizing the grids.

We start the thesis by introducing a state-of-the-art on cyber attacks from the power layer point of view i.e. the cyber attacks that affect the smart grid stability, and what are the power system based solutions have been done so far to prevent or reduce the cyber attack severity.

As we focus on cyber switching attack and the method of preventing it, firstly a study on the attack principles and effects is introduced, we construct the attack on a single machine connected to an infinite bus through a transmission line. The attack on the target generator implemented by modeling the system using swing equation on Matlab platform, then we verified the result by implementing the same attack on Simulink Platform. Finally we present a novel solution to mitigate such type of attacks by using Thyristor-Controlled Braking Resistor (TCBR). The suggested solution is able to recapture the machine stability directly after the attack.

**Keywords:** Cyber Switching attacks, Cyber-physical attacks, Smart grid security, Thyristor-controlled Braking resistor, Power system stability.

## Contents

Ce	rtific	ate		ii
De	Declaration of Originality iii			
De	Dedication			
Ac	Acknowledgement			
Ab	ostrac	t		vi
Lis	st of H	igures		ix
Lis	st of 7	<b>Fables</b>		xi
1	Intro	oductio	n	1
		1.0.1	Overview: Cyber Threats on Smart Grids	1
		1.0.2	Objective	3
		1.0.3	Structure of Thesis	3
2	Lite	terature Review		
	2.1	A class	sification of Cyber-Physical attacks on smart grids	5
		2.1.1	Congestion Attacks	7
		2.1.2	Cyber Switching Attacks	9
	2.2	Detect	on of Cyber-Physical Attacks on Smart Grids	10
3	Cyb	er Swite	ching Attacks on SMIB system	12
	3.1	Hybrid	Systems Stability	12
		3.1.1	Sliding Mode in Hybrid Systems	12
		3.1.2	Switching Attacks	14
	3.2	Cyber	Switching Attack Construction	16

	3.3 Simulation results	21		
4	Cyber Switching Attack Mitigation Using TCBR	25		
5	Conclusion And Future Work			
	5.1 Conclusion	30		
	5.2 Future Work	30		
Bi	Bibliography			

## **List of Figures**

1.1	Smart Grid Architecture	2
3.1	Hybrid system architecture	13
3.2	System Dynamic. (a) System's trajectory in State $\Psi_1$ . (b) System's	
	trajectory in State $\Psi_2$ . (c) System trajectory with sliding surface $S(x) =$	
	$x_1 + x_2$ .(d) System trajectory with sliding surface $S(x) = x_1 - x_2$	15
3.3	Single machine infinite bus model	16
3.4	Cyber switching attack steps on SMIB system	17
3.5	The dynamics of target generator for different initial conditions. (a)	
	trajectories of system $A_1$ (switch is opened). (b) trajectories of system	
	$A_2$ (switch is closed). (c) overlapped trajectories	18
3.6	Successful cyber switching attack. (a) System trajectory under cyber	
	switching attack. (b) Load switch status	20
3.7	Unconstrained cyber switching attack. (a) System trajectory under	
	unconstrained cyber switching attack. (b) Load switch status	20
3.8	Unsuccessful cyber switching attack. (a) System trajectory under	
	unsuccessful cyber switching attack. (b) Load switch status	21
3.9	Simulink model of cyber switching attack on SMIB system	22
3.10	CSA on generator $G_t$ , (a) phase plan, (b) switching signal, (c) rotor angle	
	of $G_t$ , (d) frequency of $G_t$ , (e) Terminal voltage of $G_t$	23
4.1	Single line diagram of one leg TCBR	26
4.2	Using TCBR to mitigate CSA (a) closed loop control of TCBR, (b) the	
	controller structure.	27

## **List of Tables**

2.1	Classification of cyber attacks in smart grid [8]	6
3.1	Target generator parameters $G_t$ . $P_{\text{base}} = 100 \text{ MVA} [30] \dots \dots \dots$	22

## Chapter 1

## Introduction

#### **1.0.1** Overview: Cyber Threats on Smart Grids

Due to new power and energy context such as greenhouse effect and other environmental issues, fuel depletion and electricity cost increase, new regulation and standards [1], the electrical power systems operators as well as the governments around the world urge the pace to upgrade their conventional power systems toward the smart grids. The smart grid is nothing but the assemblage of the conventional power system and information technology in five fields: smart places, smart renewable resources, smart electricity services, smart transportation and smart power grid [2]. The implementation of smart grids achieves more effective management and control of the grid and the integration of renewable energy resources. Information and Communication Technologies (ICTs) have an important role to play in improving the efficiency, and controlling the smart grid. This combination of the power grids and ICTs create a new type of systems which is called Cyber-Physical Systems (CPSs). Figure 1.1 shows the basic architecture of smart grid, it is clear that all physical components of power system are linked with each other by cyber network.

Although the Integration of CPSs in the power systems achieves the implementation of more complicated controls, the ability of connecting a different energy resources, cooperative loads, smart homes and manufactories, more ability to observe and control the system due to sensor networks and analytics, and many other aspects [3], it carries the risk of increasing security vulnerabilities of the grid, and allows the hackers to access the power system to either apply undesirable operation or steal state of the system.



Figure 1.1: Smart Grid Architecture

Because of the strong linkage between the electrical power layer and the internet layer in the smart grid at all levels (Generation-Transmission-Distribution and Consumption) and the widespread of them, the cyber attacks on smart grids have different goals, effects and vulnerable points of access. Despite the high level of communication security system of smart grid, the possibility of hacking the internet layer still exists, the impact of this attacks heads a dangerous turn when the target of attacks is such a vital infrastructure facility like electrical grid especially that type of attacks which may lead to partial or complete blackout i.e. Cyber attacks which affect the power system stability. In addition to the massive economic losses that could be caused by this blackout for the electrical power production companies as well as the electric power consumers, the causalities became possible with increasing the dependence on electrical power in sensitive facilities like metros and Desalination plants. According to the recent risk study [4] which proposed by Cambridge University and others, the expected direct and indirect economic losses due to blackout in 15 states caused by hypothetical cyber attack might rise to more than 1 trillion USD and the duration of this blackout could be reach to a number of weeks in some parts of attacked network. The main vulnerable points of smart grid where the attacks may take place are identified in [5] and [6] as follow:

- Advanced metering infrastructure (AMI).
- Electric transportation infrastructure (e.g., plug-in hybrid electric vehicle, charging stations).
- Energy storage system.
- Supervisory control and data acquisition (SCADA) network.
- Power Station.
- Indoor Net Users.

The threat of cyber attacks on CPS is not hypothetical, there are several cyber-attacks have been reported against CPS even before the implementation of the smart grid. The impact, coverage, and frequency of this type of attacks are expected to increase in the smart grids [5]. There are different types of cyber-physical attacks on the smart grid which are different in aims and effects, the most dangerous attacks are those attacks which affect power grid stability. This thesis introduce a novel solution for one type of those cyber-physical attack on smart grid, it is cyber switching attacks, this attack is very effective, stealthy and direct in destabilizing the target machines.

#### 1.0.2 Objective

The objectives of this project are to study the properties of cyber switching attacks, to construct this type of attack and implement it on a single machine infinite bus system, and then to find a technical solution so that the generator targeted by the attack does not disconnect from the network due losing its stability.

#### **1.0.3** Structure of Thesis

This Thesis is organized as follow, in chapter 2 a survey on cyber-physical attacks which affect the power layer stability and the new methods of attacks detection and identification is presented. Chapter 3 presents the principles of constructing the cyber switching attacks on the single machine infinite bus. We present in chapter 4 a new dynamic solution to mitigate the cyber switching attack on SMIB system by using Thyristor-Controlled Braking Resistor TCBR . Finally, The conclusion and future work are presented in chapter 5.

## Chapter 2

## **Literature Review**

In this chapter, we survey the research works have been done on cyber-physical attacks on a smart grid which affect the power layer stability. Moreover, a review of the researches that have been done on cyber-physical attacks detection presented in the last part of this chapter.

## 2.1 A classification of Cyber-Physical attacks on smart grids

The underlying objectives of cyber attacks on smart grids vary depending on the vulnerable points that the hacker can access whether those points are information points or control points and in complex attacks it may depend on the hackers knowledge about power network connections diagram and its control process. Generally, cyber attacks on smart grids can be divided into two categories:

- a cyber attack without causing power interruption i.e. the attack has no impact on continuity of the power supply: as the attacks which aim to breach a power consumers privacy like stealing the smart meters readings in order to detect the physical activities inside the home, another type of this attacks is that kind where the hackers aim is to collect the power consumption data in order to use this information in another attack.
- a cyber attack which may cause power interruption: in this type of attacks the

power grid and its control operations are the target rather than the consumers privacy. This attacks might be directed to implement power outage on a specific consumer or an area of consumers; in distribution level the hacker can subject the supplier circuit breaker by fake load shed command or open specific breaker which feed an area of consumers [8], [9] and [10], in generation and transmission levels this type of attack (False Data Injection (FDI)) could take more dangerous forms by giving wrong commands to the generation and grid control equipment such as facts, AVR, governor etc [11] [12], [13] and [14]. Furthermore hackers might attack the power layer in an indirect way by subjecting the cyber layer of smart grid by heavy data traffic to create failure or delay in communication layer i.e. deny of service (DoS) attack, consequently the control centers would be busy in processing fake data which cause a delay in control decisions, such a delay is very critical in smart grid control.

Name	Description		
Drive eventte els	It aims to learn/infer users private information by		
Privacy attack	analyzing electricity usage data.		
Device etteck	It aims to compromise (control) a grid device. It is		
Device attack	often the initial step of a sophisticated attack.		
	It attempts to adversarially insert, alter or delete data		
Data attack	in the network traffic so as to mislead smart grid to		
	take wrong decisions.		
Network	It aims to use up or overwhelm the communication		
availability	and computational resources of smart grid and to		
attack	result in delay or failure of communication.		

Table 2.1: Classification of cyber attacks in smart grid [8].

In this chapter, we interested in surveying only the cyber attacks which affect the power layer stability of the smart grid. Congestion attacks and cyber switching attacks are considered as the most effective attacks can destabilize or reduce the stability margin of the power layer.

#### 2.1.1 Congestion Attacks

Congestion attacks considered effective are as an cyber-attack on cyber-physical-systems (CPSs), which is based on undermining the communication between the physical parts of the CPS in order to disturb the system or destabilize it. This type of attacks attracted many researchers due to its wide impact and its ease of application by the opponents with less knowledge about the exact details of the physical layer of CPS (i.e. in this case the physical layer dynamics or measurements are not required as they are in switching attacks). Congestion attacks might take other names in researches (Jamming Attacks, Denial-of-Service (DoS) and Network Availability Attacks). Its principle relies on flooding the communication layer of CPS by transmitting fake data in order to delay the effective data arrival to its destination or by overwhelming the servers by false information to delay the decision-making which will reflect negatively on the physical layer performance and may lead to serious damage.

The required time to transfer the network measurements (phase measurement units PMU and wide area measurement system WAMS) to control center/s or to transfer the control commands from control center/s to the deferent devices around the power system significantly affect the power system stability, it decreases the area of stability, make the stability margin smaller [15] and it may lead the whole system to be unstable if this time delay cross a certain value [16]. This point of weakness is utilized in congestion attack which is primarily based on obstructing the control process of power layer in smart grid by creating time delay in control/communication processes in order to destabilize the smart grid or at least decrease the stability margin.

The existing studies on this type of attacks on smart grids can be broadly divided into two groups. The papers in the first category investigate the impact of congestion attacks on different parts of power layer [17]- [19]. The work in the second category applies different types **of control algorithms of** smart grid in order to decrease the effect of congestion attacks [21]- [27].

The impact of congestion attacks on the electrical grid differs depending on the target communication node/link, what the criticalness of this node/link and at which

time the attacker is going to apply this attack. Congestion attack may attack critical communication node and leads to blackout [17], an attacker can apply this type of attack on Advanced Metering Infrastructure AMI during critical peak hours and causes power interruptions [18]. Moreover reference [19] has shown that congestion attack on the communication link between the voltage support devices (SVC) sensor and its controller can decrease the stability margin of all power system and might lead the system to be unstable On the other hand by moving to discuss the prevention methods, as we have mentioned previously, we are not going to refer to the methods of protecting the communications layer, but instead we will survey the solutions on physical layer i.e. power system solutions and the control algorithms of power network which aim to increase the smart grid immunity against this kind of attack.

Most of the proposed solutions to improve smart grid stability in light of congestion attacks are focused on smart grid management and control mechanism of fast-acting energy storage devices (flywheels, batteries, ultra-capacitors . . . etc.) in the event of the disturbance. One of those control strategies of smart grid control is flocking-based control paradigm " [21] and [22], It is an algorithm designed to minimize the exchange of data and control commands via the communication network which is based in its essence on the theory flocking theory [20] where each generator is considered as a bird and those birds are clustered based upon their physical coherency with each other and consider this cluster as a flock of birds (generators) which has a leader, the highest inertia generator in the cluster. In conventional control algorithm all generators are fitted with fast-acting power source and are connected through communication layer in order to take an action if any disturbance occurred, however by applying flocking-based control paradigm only the lead generator of each cluster are equipped with fast-acting power source and the communications are confined to those lead generators which reduces the reliance on the communications network as it is in conventional methods and mitigate the impact of congestion attack associated with physical disturbance in the electrical network. Jin Wei and Deepa Kundur in [23] proposed a fast clustering algorithm based on generators coherency. The main disadvantage of this method is the large computational energy required and the slow performance of this algorithm to restore the system stability, especially when time delay in communication layer is large [24].

References [25] and [26] have proposed a new method to stabilize the smart grid

after being subjected to a disturbance and have taken the communication delay which may be caused by congestion attack into account. The proposed method developed a combined centralized-decentralized parametric feedback linearization controller which has two modes, in destabilized mode where the controller is designed to control the fast-acting energy storage devices to take the required actions based on parametric feedback linearization control scheme without relying on communication network, on the other hand, the controller is designed by using same scheme with considering the communications between all generators. Depending on the communication availability in the smart grid the control mode is switched between centralized mode (in normal cases) and decentralized mode (in the case of congestion attack). Finally Nasirian et al. have proposed a new control strategy to improve the stability of dc microgrids by decreasing the number of communication links i.e. connecting each dc-dc converter to its neighbors only and using cooperative distributed algorithm to control the microgrid [27].

#### 2.1.2 Cyber Switching Attacks

Cyber switching attacks can be classified as False Data Injection (FDI) attacks which combine two types of attacks device and data attacks, FDI is considered as one of the most dangerous cyber-attacks in smart grids, as it may lead on small scale to energy steal from end users, false dispatch in the distribution process, and device breakdown during power generation [42]. In cyber switching attacks, the opponent aims to get the accurate information and measurement from the transferred data through the communication network (data attack) to detect the current and exact situation of the system and then apply the attack on the system based on the system conditions (device attack). The corrupted device in such kind of attacks the circuit breakers, the main target of cyber switching attacks is to destabilize specific generator or the whole system as we will discuss in details in chapter 3.

Researches [28–34] present and analyze the methodology of construction single CSA , in [28–30] the principles of constructing single-switch CSA based on sliding mode control has been presented, the target generator has been simulated as single machine infinite bus (SMIB) model and the corrupted breaker was load breaker connected to the target generator. [29, 31] studied the possibility of constructing CSAs when

the opponent (hacker) has a limited knowledge of target generator state or model parameter error. In [32] same authors investigated the method of constructing single switch CSA on a multi-machine system, the corrupted switch was line switch whereas in previous studies it was load switch. A developed version of CSA has been developed in [33] where the fast-acting energy storage system (ESS) has been used in the attack. Abdullah A et.al.in [34] presented an investigation of practical limitation of constructing CSA. The CSAs has been developed in [35, 36] where destabilizing a generator was not the main aim but destabilizing the whole network instead, many techniques for constructing a stealthy multi-switch CSA has been presented in these papers, a complete blackout in studied network has been accomplished.

On the other hand, at the level of finding technical solutions and detection methods of CSAs, and here we are talking about the power layer based solutions. [40] presents a switching based solution of CSAs, where the smart grid operator implements a switching signal on a specific power switch in order to oppose the attack signal and drag the system trajectory to stable operating point through specifying a stable sliding surface. Practically it is difficult to implement such kind of solution because CSAs are very fast in leading the system to instability (less than 1 sec in some cases), which will not give the operator sufficient time to take action. The distributed control strategy of fast-acting ESS has been used in [37] to stabilize the smart grid under CSAs. A game theory based analysis of CSA has been presented in [38], this analysis provided a platform for developing a strategy based on game theory to control the fast-acting ESS in order to mitigate CSAs. It is possible to apply these two solutions technically, but the high cost of ESS is an important obstacle of applying such kind of solutions. [39] presented a CSA detection method based on hidden mode stochastic switched linear systems with unknown inputs, the method success in detecting the switching attack signal during the attack process.

#### 2.2 Detection of Cyber-Physical Attacks on Smart Grids

In order to detect and identify the cyber attacks on smart grids, different methods are proposed. In [41] Fabio Pasqualetti et al. proposed a distributed method for smart grid control centers to estimate the operating conditions of the power plant, and to determine the occurrence of false data injection (FDI), this mission has been done by adopting the static state network estimation model, and then applying a finite-time algorithm to detect if the measurements have been corrupted by a malignant agent. Within the same context, Dai Wang et al. [42] proposed a method to detect Tolerable false data injection (TFDI) based on extended distributed state estimation. In [43] Amir-Hamed Mohsenian-Rad et al. presented multiple defense mechanisms which may be used against Internet-based load-altering attacks, this has been achieved by identifying a set of loads which can be vulnerable targets for Internet-based load-altering attacks and the scenarios where the attacks can be effective and able to cause large damage to the smart grid. Based on graph theory Florian Dorfler, Fabio Pasqualetti, and Francesco Bullo in [44–47] proposed a unified framework and multiple methods to detect and identify the cyber attacks as well as to analyze the resilience of cyber-physical systems (smart grids in our case) against attacks. In [44] and [45] the researchers describe a unified modeling framework for cyber-physical systems and attacks, they modeled the cyber-physical system under the attack as a descriptor system subject to unknown inputs affecting the state and the measurements, then they have shown the fundamental limitations of static, dynamic, and active detection and identification procedures and they provide a graph theoretic characterization of undetectable attacks. In addition, they propose attack detection and identification filters that are effective against both state and output attacks against linear continuous time differential-algebraic cyber-physical systems. In [46] the researchers proposed a new approach which called Waveform Relaxation Approach where a distributed estimation and detection of cyber attacks in large-scale interconnected power networks is proposed. Last but not least they define in [47] the concept of network vulnerability, which identifies the possibility for an opponent to affect the network dynamics without being detected through the monitoring measurements based on graph theoretic techniques.

## Chapter 3

# Cyber Switching Attacks on SMIB system

In this chapter we introduce the principles of constructing cyber switching attacks, as the smart grid under cyber switching attacks is considered as hybrid system, we discuss hybrid system stability in first section, an example of using sliding mode control to get a stable and unstable hybrid system from multi-structure stable states system is introduced in this section. The requirements of constructing such type of attack on the single machine infinite bus SMIB system is introduced in the second section of this chapter, we use Matlab to study the system dynamic under the cyber switching attack. Finally, in the third section, we verify the attack's ability in destabilizing the target generator using Simulink.

#### 3.1 Hybrid Systems Stability

#### **3.1.1** Sliding Mode in Hybrid Systems

As the smart grid under CSA is considered as a hybrid system we introduce a brief discussion on its stability criteria. The system which contains both continuous and discrete states that influence the dynamic behavior is called Hybrid system or switched system [49], such type of system has its own stability rules, where the stability of all system continuous states is necessary condition but not sufficient to ensure that this system is stable Let us take the hybrid system shown in figure 3.1, the system has *N* 



Figure 3.1: Hybrid system architecture

continuous states, where  $A_1, ..., A_k \in \mathbb{R}^{n \times n}$  are the states matrices,  $B_1, ..., B_k \in \mathbb{R}^{n \times m}$  are the input matrices,  $C \in \mathbb{R}^{p \times n}$  is the output matrix,  $D \in \mathbb{R}^{p \times m}$  is the feedforward matrix, and  $u \in \mathbb{R}^m$ ,  $x \in \mathbb{R}^n$  and  $y \in \mathbb{R}^p$  are the input, state and output vectors respectively. The switching decision is taken by switching rule block to switch to state  $\Psi_i$ , where *i* is an integer  $i \in [1-N]$ , based on the state vector and it might be based on output vector. Here we have many methods of controlling the hybrid system such as finite time switched control, time average control and sliding mode control (SMC). In this chapter we are more interested in studying SMC because it is the control scheme which is used to control corrupted switch in CSA. SMC is based on designing a sliding surface S(x) force the controlled system trajectory to follow its direction reaching to the desired operating point. To make the mission of designing S(x) easier, we choose S(x) as a linear combination of weighted state variables which is given by:

$$S(x) = \sum_{i=1}^{N} a_i x_i \tag{3.1}$$

Where  $a_i$  represent sliding coefficients. SMC problem is summed up by designing these coefficients in such that three conditions are fulfilled, the three conditions are [50], hitting, existence and stability conditions. Hitting condition ensures that the control action will drive the system trajectory toward sliding surface or it's vicinity  $\varepsilon$  regardless it's initial condition, where  $\varepsilon$  represents the hysteresis band. the following inequality guarantees this condition:

$$S\frac{dS}{dt} < 0 \tag{3.2}$$

Existence condition ensures that the system trajectory after hitting the sliding surface it will keep tracking its manifold. Mathematically this condition is represented by:

$$\lim_{S \to 0^+} \frac{dS}{dt} < 0 \ and \ \lim_{S \to 0^-} \frac{dS}{dt} > 0.$$
(3.3)

Last but not least stability condition ensures that sliding surface not only drives system trajectory toward the equilibrium point, but also it stop this trajectory at the vicinity of this equilibrium point.

#### 3.1.2 Switching Attacks

In order to explain the principles of constructing the switching attacks on smart grid, let us take the following numerical example, suppose we have a system with two state

variables  $x = \begin{bmatrix} x_1 \\ x_2 \end{bmatrix}$  this system has two stable states  $\Psi_1$  and  $\Psi_2$  as follow

$$\begin{cases} \Psi_1 : \dot{x} = A_1 x, \\ \Psi_2 : \dot{x} = A_2 x \end{cases}$$
(3.4)

where 
$$A_1 = \begin{pmatrix} -0.3 & 2.3 \\ -1 & -0.4 \end{pmatrix}$$
 and  $A_2 = \begin{pmatrix} -2 & -2.5 \\ 3 & 1 \end{pmatrix}$  are the states matrices and

 $\dot{x} = \frac{dx}{dt}$ . As both states have negative real part eigenvalues then the system in its states is stable, and the equilibrium point for both states is (0,0). Figures 3.2a and 3.2b show the system trajectory for both states  $\Psi_1$  and  $\Psi_2$  respectively.

In order to show that the stability of each state of hybrid system is a necessary condition but not enough to ensure the stability of the system [48], let us apply two different sliding surfaces as switching rules to switch between  $\Psi_1$  and  $\Psi_2$ . Both surfaces are designed to satisfy hitting 3.2 and existence 3.3 conditions, however the stability condition is satisfied in the first example and not satisfied in the other, the control signal will be given to the switch or the system to move from one to another state as follow:

Switch to 
$$\Psi_1$$
 when  $S(x) > \varepsilon$ ,  
Switch to  $\Psi_2$  when  $S(x) < -\varepsilon$ . (3.5)

The system dynamic under first sliding surface applied on the system  $S(x) = x_1 + x_2 = 0$  is shown in figure 3.2c, we can notice that the whole system is stable due to its



Figure 3.2: System Dynamic. (a) System's trajectory in State  $\Psi_1$ . (b) System's trajectory in State  $\Psi_2$ . (c) System trajectory with sliding surface  $S(x) = x_1 + x_2$ .(d) System trajectory with sliding surface  $S(x) = x_1 - x_2$ .

convergence to the common equilibrium point (0,0), moreover, all stability conditions mentioned previously are satisfied where the system is hitting the sliding surface regardless its initial positions and then keeps tracking the vicinity of sliding surface  $\varepsilon = 0.5$  and finally stops at the equilibrium point. On the other hand applying another sliding surface may leads to unstable system like the applied one on the system shown in figure 3.2d, here we can see the system trajectory diverges from the equilibrium point and going to the infinite space with the passage of time, the sliding surface applied is  $S(x) = -x_1 + x_2 = 0$ .

From the previous example we can conclude that the possibility of destabilizing multistructure system is exist even if all its states are stable. The destabilization

process can be achieved by proper designing of switching rule (in our case sliding surface) which controls the hybrid system.

#### **3.2** Cyber Switching Attack Construction

In this section we will try to destabilize a generator (the target generator) which is connected to infinite bus through transmission line, an ohmic load is connected to the target generator bus through breaker (corrupted breaker), figure 3.3 shows the SMIB case. In this study we will assume that the hacker has a full online access to the generator measurements, in other words rotor angle  $\delta$  and angular speed  $\omega$  or at least has the online access to the generator measurements which enables him to estimate  $\delta$  and  $\omega$ , moreover we assume that hacker gets the authority to control the corrupted load breaker, these assumptions are to simplify the study and to not go toward the data and communication security of the smart grid. It is important to mention that this section is a reproduction of the researches [28–30] have been done by S.Liu et.al.

Let  $\delta_t$  and  $\Delta \omega_t$  are the deviation of the rotor angle and angular speed of the target generator  $G_t$  respectively,  $B_{t\infty}$  is the susceptance of the transmission line between the generator and the infinite bus,  $D_t$  represents the damping factor of  $G_t$ ,  $M_t$  is the moment of inertia of  $G_t$ ,  $P_L$  and  $P_M$  are the load power at generator bus and the mechanical power of the target generator respectively ,  $E_t$  and  $E_{\infty}$  are the internal voltage of the generator and the voltage of infinite bus respectively.

To represent the dynamics of the target generator we can write the swing equation in



Figure 3.3: Single machine infinite bus model

form of differential equation as follow:

$$\begin{cases} \dot{\delta_t} = \Delta \omega_t \\ \dot{\Delta \omega_t} = \frac{1}{M_t} [P_M - E_t^2 G_{tt} - \sigma P_L - E_t E_\infty B_{t\infty} \sin(\delta_t) - D_t \Delta \omega_t] \end{cases}$$
(3.6)

where  $\sigma$  represents the situation of the breaker,  $\sigma = 1$  for closed breaker and  $\sigma = 0$  for opened breaker. Assuming  $M_t = 0.1$ ,  $D_t = 0.1$ ,  $P_L = 0.9$ ,  $P_M - E_t^2 G_t t = 0.9$ ,  $E_t E_{\infty} B_{t\infty} = 1$  [29]. the overall system can be represented as switched system:

$$A_{1}: \begin{cases} \dot{\delta}_{t} = \Delta \omega_{t} & \text{if } P_{L} \text{ is connected} \\ \dot{\Delta \omega}_{t} = -10 \sin(\delta_{t}) - \Delta \omega_{t} & \\ \dot{\delta}_{t} = \Delta \omega_{t} & \\ \dot{\Delta \omega}_{t} = 9 - 10 \sin(\delta_{t}) - \Delta \omega_{t} & \text{if } P_{L} \text{ is NOT connected} \end{cases}$$
(3.7)

The first step of implementing cyber switching attack is to steal the present situation of the target generator (data attack), or in some cases steal the data which enables the opponent to estimate the required data, in other words to get the initial condition of the system where  $x = [\delta \Delta \omega]^T$  is the state variable vector of the studied system. Secondly to construct the system dynamics, specify the equilibrium points and draw the phase plan of the target generator as well as the stability boundaries (i.e. the separatrices). The third step of the attack is to specify the sliding surface and the attack period,



Figure 3.4: Cyber switching attack steps on SMIB system

finally to generate the switching signal and apply this signal on the corrupted breaker. Figure 3.4 presents the diagram of single machine infinite bus with the algorithm of switching attack.

Now we let us analyze each dynamic separately for both breaker positions (opened and closed). When the switch is opened the dynamic of the system is  $A_1$ , and the system has two types of equilibrium points:

- stable focus @  $(2k\pi, 0)$
- saddle points @  $(2k\pi + \pi, 0)$





Figure 3.5: The dynamics of target generator for different initial conditions. (a) trajectories of system  $A_1$  (switch is opened). (b) trajectories of system  $A_2$ (switch is closed). (c) overlapped trajectories.

On the other hand when the switch is closed  $A_2$ , then the system also has two types of equilibrium points:

- stable focus @  $(2k\pi + 1.1198,0)$
- saddle points @  $(2k\pi + 2.0218,0)$  ,where k is any integer.

Figure 3.5a and 3.5b show the trajectories of the system and the separatrices (boundary of stability) in both cases ( $A_1 \& A_2$ ) for different initial conditions, both dynamic's trajectories are overlapped in figure 3.5c.

Moving to construct cyber switching attack on the target generator, after we assumed that the cyber access to the target generator measurements and the corrupted breaker control is gained by the hacker, then the remain mission is to design the switching signal which will be applied on the corrupted breaker so that the target generator goes out of stability. The main parameters which the switching attack is based on are sliding surface and the period of applying the attack. Sliding surface parameters  $s(x) = a_1 \delta_t + a_2 \Delta \omega_t = 0$  can be chosen such that it satisfies the hitting and existence conditions mentioned in previous section, and ensures that this sliding surface drives the system trajectory away from the the equilibrium point, [30] detects the sliding surface space, we will pick out sliding space parameters from this space as follow:  $s(x) = 1.25\delta_t + \Delta \omega_t = 0$ , the switching rule will be:

$$\dot{\delta}_{t} = \Delta \omega_{t}$$

$$\dot{\Delta \omega}_{t} = \begin{cases} -10\sin(\delta_{t}) - \Delta \omega_{t}, & s(x) > \varepsilon, \\ 9 - 10\sin(\delta_{t}) - \Delta \omega_{t}, & s(x) < -\varepsilon, \end{cases}$$
(3.8)

The corrupted switch status varies under the attack based on s(x) value, where it is closed when s > 0 and opened when s < 0. The period of the switching attack can be chosen so that the attack stops switching at the moment when the system trajectory cross the stability boundary for a specific state and to keep the switch on the position of the correspond boundary's state. To include the breaker delay we will take the hysteresis band  $\varepsilon = 0.2$ .

Figure 3.6a presents a success switching attack on the target generator  $G_t$ , the system trajectory starts from initial point (where it is assumed that the switch was opened for long period before initiating the attack) and goes away from the origin and going to infinity with the passage of time, which means that the generator is destabilized and the



Figure 3.6: Successful cyber switching attack. (a) System trajectory under cyber switching attack. (b) Load switch status.

attack achieve its goal, practically the protection relays switch off the generator after crossing the frequency limit. The switching signal applied on the corrupted switch is shown in 3.6b, the switching signal is applied for 1.7 seconds and then when the system trajectory crosses the boundary of opened switch case, the switch is opened so that the system follows the opened switch dynamic which is out of stability due to cross its boundary.

Applying same sliding surface and hysteresis band i.e. same switching rule, does not necessarily lead to success attack, Figure 3.7 and 3.8 present an unsuccessful



Figure 3.7: Unconstrained cyber switching attack. (a) System trajectory under unconstrained cyber switching attack. (b) Load switch status.



Figure 3.8: Unsuccessful cyber switching attack. (a) System trajectory under unsuccessful cyber switching attack. (b) Load switch status.

switching attacks with same sliding surface applied in previous success attack. In figure 3.7 an unconstrained switching attack with same sliding surface  $s(x) = 1.25\delta_t + \Delta\omega_t = 0$  is applied on the system, the corrupted switch is left to keep switching without time limit, this results in shifting the system equilibrium point from initial stable point (1.1198,0) to the other one (0,0) which is corresponded to closed switch state. As result the system still stable after the attack and the attack is does not succeed.

Finally if the attack stops switching before the system trajectory crosses the stability boundary, then the system operating point returns back to the initial condition (1.1198,0) as the system is asymptotically stable inside this region, figure 3.8 shows the system trajectory as well as the corresponding switching signal applied on the corrupted switch.

#### **3.3** Simulation results

In order to verify the results obtained in previous section we use Matlab-Simulink software, same SMIB system shown in figure 3.3 is implemented on Simulink platform, the generator data has been taken from [30], and shown in table 3.1, the target generator is connected to infinite bus through transmission line has been modeled by inductor with 0.014 H, The generator is loaded by ohmic load,  $P_L = 32.4MW$ . Figure 3.9 presents the Simulink model used to implement this attack, the

Parameter	Rated voltage	Rated power	Power factor	Frequency
Value	13.8 kV	36 MW	0.8	60 Hz
x <sub>d</sub>	<i>x</i> <sub>d</sub>	$x_q$	Inertia constant	$T_{do}$
1.55 p.u	0.22 p.u	0.76 p.u.	0.5 sec	8.95 sec

Table 3.1: Target generator parameters  $G_t$ .  $P_{\text{base}} = 100 \text{ MVA}$  [30]

simulation time is 6 seconds.

The simulation results of implementing cyber switching attack on target generator  $G_t$  are shown in figure 3.10. A phase plan of target generator rotor angle  $\delta$  and rotor speed deviation  $\Delta \omega$  is shown in figure 3.10a. Assuming that the system was working for long period while the switch was opened, consequently the initial conditions  $[1.098 \ 0]^T$  as it is calculated in previous section.

We can notice how the system trajectory in fig. 4.a starts from the initial condition  $[1.098 \ 0]^T$  following the sliding surface until it crosses the stability boundary of the opened switch state and then going to infinity with the passage of time which means the system becomes unstable and the protection relays will disconnect it from the network due to crossing the frequency limit as well as the rotor angle limit. The



Figure 3.9: Simulink model of cyber switching attack on SMIB system



stability boundary is drawn in fig. 4.a is for an opened switch position, the boundary for the closed position is not shown. Driving the operation point of target generator

Figure 3.10: CSA on generator  $G_t$ , (a) phase plan, (b) switching signal, (c) rotor angle of  $G_t$ , (d) frequency of  $G_t$ , (e) Terminal voltage of  $G_t$ .

in very fast manner to make big difference between the input mechanical power and the output electrical power is the main reason behind destabilizing the target generator under CSA.

The sliding surface  $S = \delta_t + 0.45\Delta\omega_t$  is used to generate the switching signal shown in figure 3.10b, with noticing that the switching process stops at t = 0.9sec due to cross the boundary of stability. Figures 3.10c and 3.10d show the target generator rotor angle and frequency respectively, it is clear from both figures that the target generator is destabilized due to the attack applied on the corrupted switch and the protection relays have to take action such as disconnecting the target generator from the system where the hacker aim is achieved. The terminal voltage of target generator is shown in figure 3.10e

## Chapter 4

## Cyber Switching Attack Mitigation Using TCBR

Thyristor-Controlled Braking Resistor (TCBR) is a member of FACTS controllers family, this controller is usually used to stabilize the power system by absorbing the excess acceleration electrical energy in power network. Due to its resistive nature, TCBR is able only to consume the active power rather than supply it, this characteristic along with TCBRs ability to take a fast action present using TCBR as a cheap, reliable, and dynamical solution for many stability issues. TCBR is widely used to enhance the transient stability, damp low frequency oscillations, damp subsynchronous resonance and solve many other stability problems [54].

A single line diagram of single leg TCBR is shown in figure 4.1, a three phase TCBR consists of three legs each one is connected to phase, and these legs are connected to each other either in wye or delta. Each leg is formed by connecting in series a back-to-back connected thyristor and a resistant  $R_{TCBR}$ , practically a transformer is used to connect TCBR to the power grid.

Controlling the consumed power from TCBR can be done by controlling the firing angle of thyristors, the realtion between the average active power consumed by TCBR  $P_{TCBR}$  and firing angle  $\alpha$  is given by:

$$P_{TCBR} = \frac{V^2 G_{TCBR}}{\pi} (\pi - \alpha + \frac{1}{2}\sin(2\alpha))$$

$$(4.1)$$

Where V is the rms voltage at the point of TCBR connection,  $G_{TCBR}$  is the conductance of braking resistor i.e.  $G_{TCBR} = \frac{1}{R_{TCBR}}$ , and  $\alpha$  has a range of variation  $[0, \pi]$ . The power consumed by TCBR is at maximum value when  $\alpha = 0$  and then decreases with



Figure 4.1: Single line diagram of one leg TCBR

increasing  $\alpha$  till reaching zero at  $\alpha = \pi$ .

Our proposed method of mitigating CSA is based on fixing TCBR at the target generator terminals, the objectives of TCBR is to absorb the accelerating active power that produced after CSA which is the main reason of destabilizing the target generator as it is mentioned in previous chapter.

Figure 4.2a shows the proposed method, the generator frequency, mechanical input power and electric output power are fed to the controller, the controller specifies the appropriate firing angle based on the required energy to be absorbed by TCBR. Firing angle  $\alpha$  is fed to pulses generator which in turn trigger TCBR thyristors. After adding TCBR to the system the system dynamic can be represented by:

$$\begin{cases} \frac{d\delta}{dt} = \Delta\omega \\ M\frac{d^2\delta}{dt^2} = P_m - P_e - P_d - P_{TCBR} \end{cases}$$
(4.2)

The controller structure is shown in figure 4.2b the difference between the input mechanical power  $P_m$  and the output electrical power is calculated and fed to PID controller, which in turn produce the required conductance of TCBR  $G_{out}$  to absorb the acceleration active power. where  $G_{out}$  is calculated as follow:

$$G_{out} = \frac{G_{TCBR}}{\pi} (\pi - \alpha + \frac{1}{2}\sin(2\alpha))$$
(4.3)

The required conductance is limited between zero and nominal conductance value  $G_{TCBR}$ . Equation 4.2 then is used to calculate the required firing angle which is limited

in the range of  $[0, \pi]$ . TCBR controller works only when the generator accelerate and its speed deviation cross 2% of the nominal speed, otherwise TCBR does not consume any power i.e.  $\alpha = \pi$ .

We use Matlab/Simulink to check the efficiency of proposed method in mitigating CSA, the attack implemented in previous section is applied on the system with simulation time 15 sec with same sliding surface  $S = \delta_t + 0.45\Delta\omega_t$  and switching time t = 0.9sec. The rated conductance of TCBR is  $G_{TCBR} = 0.15pu$  with  $P_{\text{base}} = 100$ MVA and  $V_{\text{base}} = 13.8$ kV. The conduction and switching losses in TCBR's thyristors are neglected compared with the power consumed by the braking resistor. The simulation results are presented in Figure 4.3







(b)

Figure 4.2: Using TCBR to mitigate CSA (a) closed loop control of TCBR, (b) the controller structure.



Figure 4.3: Simulation results of SMIB system under CSA in the presence of TCBR. (a) System phase plan. (b) The terminal voltage of target Generator. (c) The frequency of target Generator. (d) Rotor angle of target Generator. (e) Active power consumed by TCBR  $P_{TCBR}$ .

Figure 4.3a shows the phase portrait of target generator dynamic, the generator was attacked by CSA and trajectory started to diverge away from the equilibrium point. When the rotor speed deviation crosses the specified limit i.e.  $\Delta \omega = 2\% * 120\pi = 7.54 \ rad/sec$ , TCBR intervenes and starts to consume the excess acceleration power specified from the difference between  $P_m$  and  $P_e$ , the consumed power by TCBR is shown in figure 4.3e. We can notice from the phase plan that the intervention of TCBR restore the system stability and draw the system trajectory to new equilibrium point, the location of this equilibrium point can be specified from equation 4.2 and can be controlled by changing the consumed power from TCBR  $P_{TCBR}$  which can be done by tuning the PID controller parameters.

The rotor angle ,terminal voltage, and frequency of the target generator are shown in figures 4.3b, 4.3c, 4.3d respectively, we can notice from both rotor angle and frequency curves that the system recaptures the stability in less than 10 seconds after the CSA. The time of stability can be minimized by increasing the rated power of TCBR, but practically it is not efficient action due to the increase of TCBR cost.

## Chapter 5

## **Conclusion And Future Work**

#### 5.1 Conclusion

A literature survey on cyber attacks on smart grids has been presented, a preface about the importance of smart grids and the probable risks of the interconnection between the communication layer and power network in smart grids has been introduced in the first chapter. A literature survey on the cyber attacks which are directed to destabilize the power layer of smart grid has been introduced in the second chapter, this chapter surveyed also the works have been done on cyber attack detection and identification. In third chapter a full description of cyber switching attacks on smart grids has been presented, single-switch attacks has been discussed in details in this part, we have simulated and discussed a case study of single machine infinite bus, a detailed description of implementing cyber switching attack can destabilize the target machine in less than one second. In chapter four of the study, a new solution to save the stability of target generator has been introduced, the suggested solution is based on using TCBR to prevent the attack from destabilizing the target generator. Finally, in this chapter, the thesis is concluded and future work is presented.

#### 5.2 Future Work

• To include the turbine action of target generator in calculating the rated power of TCBR.

- To develop a controller that cooperate between the turbine and TCBR, so that the rated power of TCBR can be reduced.
- To study cyber switching attack on multi-machine system, and specify the optimal location and number of TCBR controllers to mitigate the most savior scenario.
- To develop a new type of coordinated cyber attack which combines congestion and switching attack.

## **Bibliography**

- [1] Environmental Engineering (EE) The use of alternative energy solutions in telecommunications installations ETSI, V1.2.1 (2012-11), European Telecommunications Standards Institute 2012.
- [2] Smart Grid Insights. South Korea: Smart Grid Revolution, Zpryme Research and Consulting, July 2011.
- [3] E. Widl, P. Palensky, P. Siano, and C. Rehtanz, Guest Editorial: Modeling, Simulation, and Application of Cyber-Physical Energy Systems. IEEE Trans. Industrial Informatics, vol. 10, no. 4, pp. 2244-2246, (2014).
- [4] Lloyds of London and University of Cambridge, Business Blackout: The insurance implications of a cyber attack on the US power grid, May 2015. Avilable at:www.cambridgeriskframework.com/getdocument/29.
- [5] M. E. Kantarci and H. T. Mouftah, Smart grid forensic science: Applications, challenges, and open issues, IEEE Commun. Mag., vol. 51, no. 1, pp. 68-74, Jan. 2013.
- [6] Z. Zhang, L. Hao, N. Shuangxia, and Mo Jiansong. Information security requirements and challenges in smart grid. In 6th IEEE Joint International Information Technology and Artificial Intelligence Conference (ITAIC), vol. 1, pp. 90-92. 2011.
- [7] W. Wang and Z. Lu, Cyber security in the smart grid: Survey and challenges, Comput. Netw., vol. 57, no. 5, pp. 1344-1371, 2013.
- [8] X. Li, X. Liang, R. Lu, X. Lin, H. Zhu, and X. Shen, Securing smart grid: Cyber attacks, countermeasures and challenges, IEEE Communications Magazine, vol. 50, no. 8, pp. 38-45, 2012
- [9] I. H. Lim, S. Hong, M. S. Choi, S. J. Lee, T. W. Kim, S. W. Lee, and B. N. Ha, Security protocols against cyber attacks in the distribution automation system, IEEE Trans. Power Del., vol. 25, no. 1, pp. 448-455, Jan. 2010.
- [10] C.-W. Ten, J. Hong, and C.-C. Liu, Anomaly detection for cybersecurity of the substations, IEEE Trans. Smart Grid, vol. 2, no. 4, pp. 865-873, Dec. 2011.
- [11] S. Sridhar, A. Hahn, and M. Govindarasu, Cyber-physical system security for the electric power grid, Proc. IEEE, vol. 100, no. 1, pp. 210-224, Jan. 2012
- [12] P. Mohajerin Esfahani, M. Vrakopoulou, K. Margellos, J. Lygeros, and G. Andersson, Cyber attack in a two-area power system: Impact identification using reachability, in Proc. Amer. Control Conf. (ACC), 2010.
- [13] S. Liu, X. Liu, and A. El Saddik, Denial-of-Service (DoS) attacks on load frequency control in smart grids, in IEEE PES Innovative Smart Grid Technologies (ISGT), pp. 1-6, 2013.

- [14] S. Sridhar and G. Manimaran, Data integrity attacks and their impacts on SCADA control system, in Proc. Power Energy Soc. Gen. Meet., 2010
- [15] Jia, Hongjie, Xiaodan Yu, Yixin Yu, and Chengshan Wang. Power system small signal stability region with time delay. International Journal of Electrical Power & Energy Systems 30, no.1 (2008): 16-22.
- [16] H. Wu, H. Ni, and G. T. Heydt, The impact of time delay on robust control design in power systems, in Proc. IEEE PES Winter Meeting, vol. 2, pp. 27-31, 2002.
- [17] R. Liu, C. Vellaithurai, S. S. Biswas, T. T. Gamage, and A. K. Srivastava, Analyzing the Cyber-Physical Impact of Cyber Events on the Power Grid, IEEE Trans. on Smart Grid, vol. 6, no. 5, pp. 2444-2453, Sep. 2015.
- [18] S K. Sgouras, A. Birda, and D. Labridis, Cyber attack impact on critical smart grid infrastructures, in IEEE PES Innovative Smart Grid Technologies Conference (ISGT), pp. 1-5, Feb. 2014.
- [19] B. Chen, K. L. Butler-Purry, S. Nuthalapati, and D. Kundur, Network Delay Caused by Cyber Attacks on SVC and its Impact on Transient Stability of Smart Grids, in Proc. IEEE Power and Energy Society General Meeting (PES), pp. 1-5, 2014.
- [20] R. Olfati-Saber, Flocking for multi-agent dynamic systems: Algorithms and theory, IEEE Trans. Autom. Control, vol.51, no. 3, pp. 401-420, Mar. 2006.
- [21] J. Wei, D. Kundur, T. Zourntos, and K. Butler-Purry, A flocking based paradigm for hierarchical cyber-physical smart grid modeling and control, IEEE Trans. Smart Grid, vol. 5, no. 6, pp. 2687-2700, Nov. 2014.
- [22] J. Wei and D. Kundur, Two-tier hierarchical cyber-physical security analysis framework for smart grid, in Proc. IEEE Power Energy Soc. Gen. Meeting (PESGM), San Diego, CA, USA, Jul. 2012, pp. 1-5.
- [23] J. Wei and D. Kundur, A multi-flock approach to rapid dynamic generator coherency identification, in Proc. IEEE Power Energy Soc. Gen. Meeting, Vancouver, BC, Canada,pp. 1-5, Jul. 2013.
- [24] A. K. Farraj, E. Hammad, J. Wei, D. Kundur, and K. Butler-Purry, Performance of Flocking-Based Control Schemes in Smart Grid Applications, in IEEE Global Conference on Signal and Information Processing (GlobalSIP), pp. 1-5, December 2014.
- [25] A. Farraj, E. Hammad, and D. Kundur, A Cyber-Enabled Stabilizing Control Scheme for Resilient Smart Grid Systems, IEEE Trans. on Smart Grid, no. 99, pp. 1-10, 2015.
- [26] E. Hammad, A. Farraj, and D. Kundur, A Resilient Feedback Linearization Control Scheme for Smart Grids under Cyber-Physical Disturbances, in IEEE PES Conference on Innovative Smart Grid Technologies (ISGT), pp. 1-5, February 2015.
- [27] V. Nasirian, S. Moayedi, A. Davoudi, and F. Lewis, Distributed Cooperative Control of DC Microgrids, IEEE Trans. Power Electron., vol. 30, no. 4, pp. 2288-2303, 2015.
- [28] S. Liu, X. Feng, D. Kundur, T. Zourntos, and K. Butler-Purry, Switched system models for coordinated cyber-physical attack construction and simulation, In First IEEE International Workshop on Smart Grid Modeling and Simulation, Brussels, Belgium, October 2011, pp. 4954.

- [29] S. Liu, X. Feng, D. Kundur, T. Zourntos, and K. L. Butler-Purry, A Class of Cyber-Physical Switching Attacks for Power System Disruption, in Cyber Security and Information Intelligence Research Workshop (CSIIRW), pp. 14, 2011.
- [30] S. Liu, S. Mashayekh, D. Kundur, T. Zourntos, and K. Butler-Purry, A framework for modeling cyber-physical switching attacks in smart grid, IEEE Trans. Emerging Topics Comput., vol. 1, no. 2, pp. 273285, 2013.
- [31] S. Liu, D. Kundur, T. Zourntos, and K. L. Butler-Purry, Coordinated Variable Structure Switching Attack in the Presence of Model Error and State Estimation, in IEEE International Conference on Smart Grid Communications (SmartGridComm), pp. 318323, 2012.
- [32] S. Liu, S. Mashayekh, D. Kundur, T. Zourntos, and K. L. Butler-Purry, A Smart Grid Vulnerability Analysis Framework for Coordinated Variable Structure Switching Attacks, in IEEE Power and Energy Society General Meeting, pp. 16, 2012.
- [33] A. Farraj and D. Kundur, On Using Energy Storage Systems in Switching Attacks That Destabilize Smart Grid Systems, in IEEE PES Conference on Innovative Smart Grid Technologies (ISGT), pp. 1-5, February 2015.
- [34] A. Farraj, E. Hammad, D. Kundur, and K. Bulter-Purry, Practical Limitations of Sliding-Mode Switching Attacks on Smart Grid Systems, in IEEE Power and Energy Society General Meeting (PESGM), pp. 1-5, July 2014.
- [35] S. Liu, B. Chen, T. Zourntos, D. Kundur, and K. Butler-Purry, Progressive switching attacks for instigating cascading failures in smart grid. in IEEE Power and Energy Society General Meeting, pp. 15, 2013.
- [36] S. Liu, B. Chen, T. Zourntos, D. Kundur, and K. Butler-Purry, A coordinated multi-switch attack for cascading failures in smart grid, IEEE Trans. Smart Grid, vol. 5, no. 3, pp. 11831195, May 2014.
- [37] A. Farraj, E. Hammad, and D. Kundur, On Using Distributed Control Schemes to Mitigate Switching Attacks in Smart Grids. in IEEE 28th Canadian Conference on Electrical and Computer Engineering (CCECE), pp. 1578-1582, May 2015.
- [38] A. Farraj, E. Hammad, A. Al Daoud, and D. Kundur, A game theoretic analysis of cyber switching attacks and mitigation in smart grid systems, IEEE Trans. Smart Grid, 2015.
- [39] S.Z. Yong, M. Zhu, and E. Frazzoli, Resilient state estimation against switching attacks on stochastic cyber-physical systems. in IEEE International Conference on Decision and Control. 2015.
- [40] S. Liu, D. Kundur, T. Zourntos, and K. Butler-Purry, Coordinated variable structure switching in smart power systems: Attacks and mitigation, in 1st International Conference on High Confidence Networked Systems, China, April 2012.
- [41] F. Pasqualetti, R. Carli, and F. Bullo. **Distributed estimation and false data detection with application to power networks,** Automatica, March 2011,
- [42] D. Wang, X. Guan, T. Liu, Y. Gu, C. Shen, and Z. Xu, Extended distributed state estimation: A detection method against tolerable false data injection attacks in smart grids, Energies, vol. 7, no. 3, pp.1517-1538, 2014.

- [43] A. Mohsenian-Rad and A. Leon-Garcia, Distributed internet-based load altering attacks against smart power grids, IEEE Transactions on Smart Grid, vol. 2, no. 4, pp. 667-674, 2011.
- [44] F. Pasqualetti, F. Dorfler, and F. Bullo, Attack detection and identification in cyber-physical systems Part I: Models and fundamental limitations, arXiv:1202.6144v2, 2012.
- [45] F. Pasqualetti, F. Dorfler, and F. Bullo, Attack detection and identification in cyberphysical systems part ii: Centralized and distributed monitor design, arXiv:1202.6049, 2012.
- [46] F. Dorfler, F. Pasqualetti, and F. Bullo, Distributed detection of cyber-physical attacks in power networks: A waveform relaxation approach, in Proc. 49th Annual Allerton Conference on Communication, Control, and Computing, pp. 1486-1491, 2011.
- [47] F. Pasqualetti, A. Bicchi, and F. Bullo, A graph-theoretical characterization of power network vulnerabilities, in American Control Conference, San Francisco, CA, USA, pp. 3918-3923, 2011.
- [48] D. Liberzon, Switching in Systems and Control. Boston: Birkhauser, 2003.
- [49] S. Pettersson and B. Lennartson, Hybrid system stability and robustness verification using linear matrix inequalities, Inter.J. Control, vol. 75, no. 16-17, pp. 1335-1355, 2002.
- [50] S.-C. Tan, Y.-M. Lai, and C. K. Tse, Sliding Mode Control of Switching Power Converters. Boca Raton, FL, USA: CRC Press, 2011.
- [51] P. W. Sauer and M. A. Pai, Power System Dynamics and Stability. Upper Saddle River, NJ: Prentice-Hall, 1998.
- [52] P. Kundur, Power System Stability and Control. New York: McGrawHill, 1994.
- [53] J. Machowski, J. Bialek, and J. Bumby, Power System Dynamics: Stability and Control, 2nd ed. NJ, US: John Wiley & Sons, Inc. 2008
- [54] N. G. Hingorani and L. Gyugyi, Understanding FACTS: Concepts and Technology of Flexible AC Transmission Systems, New York: IEEE Press, 2000.
- [55] A. H. M. A. Rahim and D. A. H. Alamgir, A closed-loop quasi-optimal dynamic braking resistor and shunt reactor control strategy for transient stability, IEEE Trans. Power Syst., vol. 3, no. 3, pp. 879-886, Aug. 1988.
- [56] M. H. Ali, T. Murata, and J. Tamura, Effect of coordination of optimal reclosing and fuzzy controlled braking resistor on transient stability during unsuccessful reclosing, IEEE Trans. Power Syst., vol. 21, no. 3, pp. 1321-1330, Aug. 2006.