

Technical University of Denmark



Gas cleaning for staged gasifiers

Hindsgaul, Claus; Gøbel, Benny

Publication date:
2002

Document Version
Publisher's PDF, also known as Version of record

[Link back to DTU Orbit](#)

Citation (APA):
Hindsgaul, C., & Gøbel, B. (2002). Gas cleaning for staged gasifiers [Sound/Visual production (digital)]. GasNET meeting, Strasbourg, 01/01/2002

DTU Library

Technical Information Center of Denmark

General rights

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain
- You may freely distribute the URL identifying the publication in the public portal

If you believe that this document breaches copyright please contact us providing details, and we will remove access to the work immediately and investigate your claim.

Gas cleaning for staged gasifiers

GasNET meeting October 2. 2002

Claus Hindsgaul



Benny Gøbel

Biomass Gasification Group

Energy Section of Dept. Mechanical Engineering

Technical University of Denmark (DTU)

M. Sc. Claus Hindsgaul

Biomass Gasification Group, DTU


<http://www.et.dtu.dk/Halmfortet>

Outline

- Two stage gasification
- Scrubber performance
- Particle properties
- Relevant particle removal technologies
- Viking gasifier
- Baghouse filter in Viking
 - Performance
 - Waste quality
- Conclusions


Two-stage gasification

- x Separated pyrolysis and gasification
- x Tar conversion zone for pyrolysis gases
 - No tar in gas
 - nor in waste**
 - High efficiency




Experience with venturi scrubber system

- Reliable
- Particles in waste water
 - Recycling system




Experience with venturi scrubber system

- Reliable
- Particles in waste water
 - Recycling system
- Particle removal 65-85%
- High pressure drop



Characterisation of two-stage particles


- 6% volatiles (tar)
- Ash 20-30%
- **Submicron**
(**>85% mass**)



Removing submicron particles

Inertial methods inefficient
(e.g. cyclones and scrubbers)

Electrostatic precipitators
efficient but expensive.




Removing submicron particles

Inertial methods inefficient
(e.g. cyclones and scrubbers)

Electrostatic precipitators
efficient but expensive.


Fibre filtration efficient
due to Brownian motions.



*Fibre filtration with
Brownian motions*

Baghouse filter system

- x Particle removal just above water dew point.
- x Filter cleaning by N₂ backflush.
 - Bulk particles and condensate recovered separately.
 - Pressure <100 mmWG
 - Low energy consumption



Viking gasifier at DTU

Commissioned August 2002

Small scale ($80\text{kW}_{\text{fuel}}$)

Unattended operation

Engine woodgas operation for
400 hours

Using baghouse filtering
(no cyclone)



Gas cleaning performance

- Reliable for >400 hours with no filter change.

- Dust removal >99.5%

- Tar condenses on particles, removed with these

- Tar levels in gas drop from 25 to "no tar" (<5 mg/Nm³)



Police filter after 450 hours

Viking condensate quality

Amounts:	2-6 l/h
NH ₃ :	1 g/l
Naphtalene:	<20 µg/l
Other PAH:	<2 µg/l
Smell:	NH ₃
⇒ OK for standard biological surridge plant!	



Viking dust quality

Amounts: 600 mg/Nm^3
= 30 g/h

Ash: 30-50%

Tar: <5% mass

Bulk particles

→ Low temperature reburning
in boiler should be possible.



Intake Manifold 400 hours Wood Gas



Conclusions

- Dust removal efficiency $>99.5\%$
- Tar removed with particles
 $<5 \text{ mg/Nm}^3$ tar after filter
- Condensate not a waste problem
- Dust can be treated separately
- Absence of tars \Rightarrow simple, cheap gas cleaning for woodgas.

Questions?

