



ROBUST CONTROLLER DESIGN FOR POSITION TRACKING OF NONLINEAR SYSTEM USING BACKSTEPPING-GSA APPROACH

Sahazati Md Rozali¹, Mohd Fua'ad Rahmat², Abd Rashid Husain³ and Muhammad Nizam Kamarudin⁴

¹Department of Control System and Automation, Faculty of Electrical Engineering, Universiti Teknikal Malaysia Melaka, Durian Tunggal, Melaka, Malaysia

²Department of Control and Mechatronics Engineering, Faculty of Electrical Engineering, Universiti Teknologi Malaysia, Skudai, Johor, Malaysia

³Centre of Student Innovation, Universiti Teknologi Malaysia, Skudai, Johor, Malaysia

⁴Department of Power Electronic and Drives, Faculty of Electrical Engineering, Universiti Teknikal Malaysia Melaka, Durian Tunggal, Melaka, Malaysia

E-Mail: sahazati@utem.edu.my

ABSTRACT

Electro-hydraulic actuator (EHA) system is highly non-linear system with uncertain dynamics in which the mathematical representation of the system cannot sufficiently represent the practical system. Nonlinearities of the system come from either the system itself or external disturbance signals. These dynamic characteristics are the reasons that cause the controller design for the system to be quite challenging. In this paper, back-stepping controller design for tracking purpose of this system is presented based on Lyapunov stability condition. Gravitational Search Algorithm (GSA) technique is then used to optimize the control parameters in order to achieve a predefined system performance. The performance is evaluated based on the tracking output and the tracking error between reference input and the system output. The results show that the system's output follow the reference input given but the tracking performance is influenced by the condition of the system and number of agents and iteration in the algorithm.

Keywords: backstepping, lyapunov function, disturbance, gravitational search algorithm, sum of squared error.

INTRODUCTION

Back-stepping control method permits to obtain global stability in the cases when the feedback linearization method only secures local stability (Anna, *et al*, 2007). The fundamental concept of back-stepping method is introduced in (Krstic M, *et al*, 1995, Khalil, 2002). It is used as an observer (Nakkarat, *et al*, 2009, Payam, 2006), controller for electro-hydraulic system (Kaddissi, *et al*, 2006, Sirouspour, *et al*, 2000, Ursu, *et al*, 2006), enhance the stability of power system (Karimi, 2005), as an adaptive method (Ji Min Le, *et al*, 2009, Qingwei Wang, *et al*, 2006) and controller for electro-pneumatic system (M.Smaoui, *et al*, 2006). The control parameter of back-stepping is important in order to achieve performance target. The value can be determined by several methods such as heuristic approach, artificial intelligent technique (Younes Al-Younes, *et al*, 2006) and optimization algorithm (Chao-Kuang Chen, *et al*, 2010, Anna, *et al*, 2007, Chao-Yong Li, *et al*, 2009, Ali Karimi, *et al*, 2005, Yu Hong, *et al*, 2004, R.J. Wai, *et al*, 2010, Faa-Jeng Lin, *et al*, 2010).

This research work focused on designing back-stepping controller for position tracking of electro hydraulic actuator system (EHA). The control parameters of back-stepping controller are then tuned by using Gravitational Search Algorithm (GSA) technique in order to acquire the suitable values for accurate tracking response. The performance of the designed controller with this technique is evaluated in terms of tracking output and tracking error. Sum of Squared Error (SSE) is used as an

objective function for this algorithm. The pattern of SSE value is observed by increasing number of agent and iteration in the simulation process such that the information on the optimum parameters of the controller algorithm which generates optimum output can be attained. The effectiveness of the back-stepping controller is verified in simulation environment under various system set-up subjected to different type of external disturbance given to its actuator.

PROBLEM FORMULATION

Consider a state-space model of EHA system is given as follow [10]:

$$\begin{aligned}\dot{x}_1 &= x_2 \\ \dot{x}_2 &= -\frac{k}{m}x_1 - \frac{f}{m}x_2 + \frac{S}{m}x_3 - \frac{F_L}{m} \\ \dot{x}_3 &= -\frac{S}{k_c}x_2 - \frac{k_l}{k_c}x_3 + \frac{c}{k_c}\sqrt{\frac{p_a - x_3}{2}}k_v u\end{aligned}\quad (1)$$

x_1 is displacement of the load, x_2 is load velocity and x_3 is the pressure difference between the cylinder chambers caused by load. F_L is an external disturbance given to the system and it can be constant or time varying. The control signal for the system based on Lyapunov stability is given as

$$u = \frac{k_c}{\rho_3 c k_v} \sqrt{\frac{2}{p_a - x_3}} \left[-\frac{\rho_2}{m} S e_2 + \frac{\rho_3}{k_c} S x_2 + \frac{\rho_3}{k_c} k_1 x_3 + \rho_3 \dot{x}_3 d - k_3 e_3 \right] \quad (2)$$



$$x_{3d} = \frac{1}{s} [kx_1 + fx_2 - \frac{\rho_1}{\rho_2} me_1 + mx_{2d} - \frac{k_2}{\rho_2} me_2 + F_0] \quad (3)$$

$$x_{2d} = x_{1d} - k_1 e_1 \quad (4)$$

30 iterations and 25 agents within 50 iterations are chosen for GSA in order to observe the performance of the designed controller with small, medium and bigger number of agents and iterations. Two dissimilar type of signal is given as an external perturbation to the system.

SIMULATION RESULTS AND DISCUSSION

The parameter of the testing system is given as $m = 0.33Ns^2/cm$, $S = 10cm^2$, $f = 27.5Ns/cm$, $k = 1000N/cm$, $w = 0.05cm$, $P_a = 2100N/cm^2$, $c_d = 0.63$, $k_l = 2.38 \times 10^{-3}cm^5/Ns$, $k_v = 0.017cm/V$, $k_c = 2.5 \times 10^{-4}cm^5/N$ and $\rho = 8.87 \times 10^{-7}Ns^2/cm^4$. For presentation of results in this chapter, the output plot yielded by 10 agents within 20 iterations, 15 agents within

Case 1

In this case, constant value of signal $F_L = 10000$ is added as perturbation to system's actuator. Figure 1, 2 and 3 show the system's output, tracking error and SSE obtained from back-stepping-GSA with 10 agents within 20 iterations, 15 agents within 30 iterations and 25 agents within 50 iterations respectively.




Figure-1. Position output, tracking error and SSE obtained from backstepping-GSA with 10 agents within 20 iterations.



www.arpnjournals.com




Figure-2. Position output, tracking error and SSE obtained from backstepping-GSA with 15 agents within 30 iterations.




Figure-3. Position output, tracking error and SSE obtained from back-stepping-GSA with 25 agents within 50 iterations.

Referring to these Figures, the top plot illustrates the output yielded by back-stepping-GSA, the middle plot shows its tracking error while the SSE is presented by the bottom plot. Based on these three figures, the tracking output and error of the system is bigger when the system is operated with smaller agents and iterations. However, the

values of these parameters are improved with the increment of agents and iterations. Better output performance is produced when the system simulates with more agents within long iterations.



Case 2

In this case, time-varying signal is given to replace the signal disturbance to the system's actuator. Figure 4, 5 and 6 respectively show system output, tracking error and SSE for incorporation of back-stepping with GSA with 10 agents within 20 iterations, 15 agents within 30 iterations and 25 agents within 50 iterations. By

looking at these figures, similar as previous case, the system's output and its tracking error is bigger when smaller agents within short iterations are given to the system. On the other hand, the output and tracking error is improved when the system operates with bigger number of agents within longer iterations.




Figure-4. Position output, tracking error and SSE obtained from backstepping-GSA with 10 agents within 20 iterations.




Figure-5. Position output, tracking error and SSE obtained from backstepping-GSA with 15 agents within 30 iterations.



www.arpnjournals.com




Figure-6. Position output, tracking error and SSE obtained from backstepping-GSA with 25 agents within 50 iterations.

CONCLUSIONS

Generally, the proposed back-stepping controller has mathematically fulfilled the requirement of stability of control system. External perturbation injected to the system's actuator is considered as nonlinearities in the chosen system. Since the performance of the designed controller relies on its control parameters, specific method should be determined in order to obtain the suitable value of these parameters such that good tracking performance is achieved. Although the trial and error method is good enough to set the value of control parameters such that the system's output tracked the reference input given, this manual method consumes a lot of time and require good experience and knowledge of the user to fix it on certain value and condition. Thus, Gravitational Search Algorithm (GSA) technique is integrated with back-stepping controller so that the controller has the own capability to tune its control parameters automatically in any condition of the system. Although back-stepping-GSA applied on the chosen system cannot completely tracked the reference input given smoothly, the performance of this integration of controller still can be improved by providing bigger number of agents and iterations for optimization algorithm. It can be concluded in each case, additional number of agents and iterations of GSA produced better tracking performance with smaller tracking output and oscillation of the system. SSE value generated by the similar algorithm with more number of agent and iteration is also reduced.

REFERENCES

Anna Witkowska, Miroslaw Tomera and Roman Smierzchalski. 2007. Backstepping Approach to Ship Course Control. *International Journal of Applied Mathematics Computer Science*. Vol 17(1), pp. 73-85.

Ali Karimi, Amer Al-Hinai, Karl Schoder and Ali Feliachi. 2005. Power System Stability Enhancement Using Backstepping Controller Tuned by Particle Swarm Optimization Technique. *Proc. of IEEE Power Engineering Society General Meeting*. Vol 2, pp. 1388-1395.

Ali Karimi and Ali Feliachi. 2006. PSO-Tuned Adaptive Backstepping Control of Power Systems. *Proc of 2006 Power Systems Conference and Exposition*, pp. 1315-1320.

B.M.B.A. Farrokh Payam. 2006. Nonlinear Sliding Mode Controller for Sensorless Speed Control of DC Servo Motor Using Adaptive Backstepping Observer. *Proc. of International Conference on Power Electronics, Drives and Energy Systems*.

Chao-Kuang Chen and Wei-Yen Wang. 2010. Compact Ant Colony Optimization Algorithm Based Fuzzy Neural Network Backstepping Controller for MIMO Nonlinear Systems. *Proc of International Conference on System Science and Engineering*, pp. 146-149.

Chao-Yong Li, Wu-Xing Jing and Chang-Sheng Gao. 2009. Adaptive Backstepping-Based Flight Control System Using Integral Filters. *Aerospace Science and Technology*. 13, pp. 105-113.

Faa-Jeng Lin and Syuan-Yi Chen. 2010. Intelligent Integral Backstepping Sliding Mode Control Using Recurrent Neural Network for Magnetic Levitation System. *Proc. of International Joint Conference on Neural Network*, pp. 1-7.



H. K.Khalil. 2002. Nonlinear Systems, 3rd ed. Prentice Hall.

Ioan Ursu, Felicia Ursu and Florica Popescu. 2006. Backstepping Design for Controlling Electro hydraulic Servos. Journal of Franklin Institute. 343, pp. 94-110.

Ji Min Le, Han Me Kim, Sung Hwan Park and Jong Shik Kim. A Position Control of Electro-Hydraulic Actuator Systems Using the Adaptive Control Scheme. 2009. Proc of the 7th Asian Control Conference. pp. 21-26.

J.P.L. Claude Kaddissi, Maarouf Saad. 2005. Draw by Wire Control of an Electro-Hydraulic Active Suspension: A Backstepping Approach. Proc of IEEE Conference on Control Applications.

K. I. Kristic M, Kokotovic P.V. 1995. Nonlinear and Adaptive Control Design, John Wiley and Sons.

Mohammad R. Sirouspour, S.E. Salcudean. 2000. On the Nonlinear Control of Hydraulic Servo Systems. Proc. of the 2000 IEEE International Conference on Robotics and Automation, pp.1276-1282.

M. Smaouix. Brun, D. Thomasset. 2006. A Study on Tracking Position Control of An Electro pneumatic System Using Backstepping Design. Control Engineering Practice. 14, pp. 923-933.

Prut Nakkaratand Suwat Kuntanapreda. 2009. Observer Based Backstepping Force Control of An Electro hydraulic Actuator. Control Engineering Practice 17, pp. 895-902.

Qingwei Wang, Zhenghua Liu and Lianjie Er. 2006. Disturbance Observer Based Backstepping Control for Flight Simulator. Proc of the First International Conference on Innovative Computing, Information and Control. 1, pp. 1366-1370.

R.J. Wai and K.L. Chuang. 2010. Design of Backstepping Particle-Swarm Optimisation Control for Maglev Transportation System. IET Control Theory and Applications. Vol. 4(4), pp. 625-645.

Yu Hong, Feng Zheng-Jin, Wang Xu-Yong. (2004). Nonlinear Control for a Class of Hydraulic Servo System. Journal of Zhejiang University Science, pp.1413-1417.

Younes Al-Younes and M.A. Jarrah. 2008. Attitude Stabilization of Quadrotor UAV Using Backstepping Fuzzy Logic and Backstepping Least-Mean-Square Controller. Proc of the 5th International Symposium on Mechatronics and Its Applications, pp. 1-11.