





first, the natural gas is fed through line (1) to the burner and the reformer sections. In the burner, natural gas is reacted with the air and burns. This generated heat is used to provide energy needs for the reformer section. In the reformer unite; the natural gas is reacted with the produced steam in the heater. In this stage, the produced hydrogen gas ( $H_2$ ) by reformer, is fed to PEM fuel cell (line 11). This hydrogen is reacted with air (line 7), to produce electrical power and hot water. Remaining part of air is discharged to atmosphere. For cooling of fuel cell, water is pumped to fuel cell (line 16), which is warmed up and fed to heat exchanger. In heat exchanger, this water is mixed with a part of hot water which produced in PEM (line 19) and is fed to storage tank through. Remaining part of produced water by PEM fuel cell, change to steam in heater, and is used in reformer.

In previous research, the fuel cell stack with a nominal power of 8.4 kW is considered here, employing natural gas as fuel. Based on previous findings (Pourmahmoud *et al.*, 2014), we understand that the maximum electrical power requirement is 32.96 kW, occurring between the hours of 7 and 8 p.m. in July. It is found that the maximum heating load is 1590 kW, occurring at 5 a.m. in January (Pourmahmoud *et al.*, 2014). However, the maximum cooling load is 2028 kW, occurring at 3 p.m. in July (Pourmahmoud *et al.*, 2014). Furthermore, the maximum domestic hot water energy requirement is 0.926 kW, occurring between 5 a.m. and 11 p.m. in January (Pourmahmoud *et al.*, 2014).

A method to meet the energy needs of the residential building under consideration is to employ a number of fuel cell stacks to produce electricity to meet the electrical energy needs of the building, and to provide some part of the heating and cooling energy needs through a heat pump (Pourmahmoud *et al.*, 2014). Results show that all the energy needs of the building can be met with 12 fuel cell stacks at a nominal capacity of 8.4 kW (Pourmahmoud *et al.*, 2014).

## RESULTS AND DISCUSSIONS

The variation of carbon monoxide and nitrogen monoxide mass production of the proposed CHP fuel cell system with respect to the variation of the ambient air temperature is illustrated in Figure-2.

From this figure, it can be observed that when the ambient temperature increases from  $1^\circ C$  to  $40^\circ C$ , the carbon monoxide mass production by each fuel cell stack increases from 0.0277(kg/sec) to 0.0316(kg/sec). In addition mass production of monoxide nitrogen increases from 0.0518(kg/sec) to 0.0557(kg/sec). Monoxide carbon and monoxide nitrogen mass production due to number of fuel cell stacks to meet the energy loads during the hours is shown in Tables 5-6 and 7-8, respectively. Maximum monoxide carbon and maximum monoxide nitrogen mass production occurs at 15 hour in 15 July and is equal to 0.378 (kg/sec) and 0.6672 (kg/sec), respectively.




Figure-2. variation of mass production with respect air temperature in one unit of CHP fuel cell stack.

Table-1. Carbon monoxide mass production from fuel cell stacks which operate in the residential building in kg/sec (January-June).

Hour	Jan	Feb	Mar	Apr	May	Jun
2	0.196	0.168	0.1132	0.0584	0.0294	0.0596
4	0.196	0.196	0.1132	0.0582	0.0293	0.0594
6	0.196	0.196	0.1132	0.0582	0.0293	0.0594
8	0.1686	0.168	0.0849	0.0292	0.0295	0.0598
10	0.1128	0.1128	0.0286	0.0297	0.0891	0.1208
12	0.0852	0.0566	0.0287	0.0604	0.151	0.1836
14	0.0286	0.0285	0.0582	0.0912	0.2128	0.2772
15	0.0286	0.0286	0.0582	0.122	0.2121	0.31
16	0.0286	0.0285	0.0582	0.0912	0.1812	0.2772
18	0.0852	0.0568	0.0288	0.0912	0.15	0.1842
20	0.1132	0.1132	0.0287	0.0596	0.0894	0.152
22	0.1686	0.1405	0.0568	0.0295	0.0592	0.09
24	0.168	0.168	0.0849	0.0292	0.0294	0.0596



**Table-2.** Carbon monoxide mass production from fuel cell stacks which operate in the residential building in kg/sec (July-December).

Hour	July	Aug	Sep	Oct	Nov	Dec
2	0.0602	0.0598	0.0594	0.0287	0.0849	0.168
4	0.06	0.0596	0.0295	0.0287	0.1132	0.168
6	0.06	0.0594	0.0295	0.0287	0.1132	0.1674
8	0.0909	0.09	0.0594	0.0287	0.0852	0.1405
10	0.153	0.1515	0.09	0.0582	0.0286	0.1128
12	0.2799	0.2763	0.1824	0.0885	0.0287	0.0283
14	0.3454	0.3421	0.2456	0.12	0.0584	0.0287
15	0.378	0.3732	0.2456	0.09	0.0584	0.0287
16	0.3454	0.3421	0.2448	0.12	0.0584	0.0286
18	0.2808	0.2772	0.183	0.0885	0.058	0.0568
20	0.1848	0.183	0.1204	0.0586	0.0287	0.0846
22	0.1216	0.1204	0.0894	0.0576	0.057	0.112
24	0.0906	0.06	0.0594	0.0287	0.0568	0.1395

Figure-3 shows that unlike monoxide nitrogen and monoxide carbon, mass production of dioxide carbon decreases when the inlet air temperature increases from 1°C to 40°C, it decreases from 0.802 (kg/sec) to 0.79843 (kg/sec). As we know, increasing ambient air temperature led to reduction heat rate burner and increasing mass flow rate of fuel. So mass production of dioxide carbon by burner increases. In the other hand, with increasing ambient air temperature, outlet pressure of compressor and power of compressor increase. So, net power of the system

and outlet dioxide carbon of the reformer decrease. Increasing of mass production of dioxide carbon by burner is less than decreasing mass production of dioxide carbon by reformer. Therefore, total mass production of dioxide carbon by system decreases with increasing ambient air temperature. This variation is shown in Figure-3.

Furthermore, it should be noted that dioxide carbon mass production from fuel cell stacks which operate in the residential building is shown in Tables 1-5.


**Table-3.** Monoxide nitrogen mass production from fuel cell stacks which operate in the residential building in kg/sec (January-June).

Hour	Jan	Feb	Mar	Apr	May	Jun
2	0.3654	0.3132	0.2096	0.1066	0.0535	0.1076
4	0.3654	0.3605	0.2096	0.1064	0.0534	0.1074
6	0.3654	0.3647	0.2096	0.1064	0.0534	0.1074
8	0.2096	0.21	0.0527	0.0537	0.1611	0.2172
10	0.3132	0.3132	0.1572	0.0534	0.0536	0.108
12	0.1578	0.1052	0.0529	0.1086	0.2715	0.3282
14	0.1575	0.105	0.0529	0.1635	0.271	0.3282
15	0.0527	0.0527	0.1064	0.1635	0.3815	0.4923
16	0.0527	0.0527	0.1064	0.2184	0.3808	0.548
18	0.0527	0.0527	0.1064	0.1635	0.3258	0.4932
20	0.2096	0.2096	0.0528	0.108	0.1614	0.2725
22	0.3132	0.3132	0.1575	0.0533	0.0536	0.108
24	0.3132	0.261	0.105	0.0536	0.1072	0.1626



**Table-4.** Monoxide nitrogen mass production from fuel cell stacks which operate in the residential building in kg/sec (July-December).

Hour	July	Aug	Sep	Oct	Nov	Dec
2	0.1086	0.108	0.1074	0.0528	0.1575	0.3132
4	0.1084	0.1076	0.0536	0.0528	0.21	0.3132
6	0.1084	0.1074	0.0536	0.0528	0.21	0.3132
8	0.1632	0.1626	0.1074	0.0529	0.1575	0.2615
10	0.2735	0.273	0.1626	0.1064	0.0528	0.2096
12	0.4968	0.4941	0.3264	0.1605	0.0529	0.0525
14	0.6116	0.6028	0.4352	0.2164	0.1066	0.0528
15	0.6672	0.6576	0.436	0.1626	0.1066	0.0528
16	0.6105	0.6028	0.436	0.2168	0.1066	0.0528
18	0.4959	0.4941	0.3276	0.1608	0.1062	0.1052
20	0.3288	0.3276	0.2172	0.1068	0.0527	0.1572
22	0.1629	0.1084	0.1074	0.0529	0.105	0.261
24	0.218	0.2172	0.162	0.1058	0.1052	0.2092



**Figure-3.** Variation of mass production of dioxide carbon with respect air temperature in one unit of CHP fuel cell stack.



**Table-5.** Dioxide carbon mass production from fuel cell stacks which operate in the residential building in kg/sec (January-June).

Hour	Jan	Feb	Mar	Apr	May	Jun
2	5.6119	4.8102	3.2056	1.601	0.8003	1.5998
4	5.6119	5.6119	3.2056	1.6012	0.8004	1.6
6	5.6119	5.6119	3.2056	1.6012	0.8004	1.6
8	4.8096	4.8102	2.4042	0.8005	0.8002	1.5996
10	3.206	3.206	0.8011	0.8	2.4	3.198
12	2.4039	1.6028	0.801	1.599	3.9975	4.7946
14	0.8011	0.8012	1.6012	2.3979	5.5951	7.1892
15	0.8011	0.8011	1.6012	3.1968	5.5958	7.987
16	0.8011	0.8012	1.6012	2.3979	4.797	7.1892
18	2.4039	1.6026	0.8008	2.3979	3.9985	4.794
20	3.2056	3.2056	0.801	1.5998	2.3997	3.9965
22	4.8096	4.008	1.6026	0.8002	1.6002	2.3991
24	4.8096	4.8102	2.4042	0.8005	0.8003	1.5998

**Table-6.** Dioxide carbon mass production from fuel cell stacks which operate in the residential building in kg/sec (July-December).

Hour	July	Aug	Sep	Oct	Nov	Dec
2	1.5992	1.5996	1.6	0.801	2.4042	4.8102
4	1.5994	1.5998	0.8002	0.801	3.2056	4.8102
6	1.5994	1.6	0.8002	0.801	3.2056	4.8102
8	2.3982	2.3991	1.6	0.8009	2.4039	4.008
10	3.9955	3.997	2.3991	1.6012	0.8011	3.206
12	7.1874	7.1901	4.7958	2.4009	0.801	0.8014
14	8.7813	8.7846	6.392	3.1988	1.601	0.8009
15	9.5784	9.5832	6.3912	2.3991	1.601	0.8009
16	8.7813	8.7846	6.3928	3.1988	1.601	0.8011
18	7.1865	7.1892	4.7952	2.4006	1.6014	1.6026
20	4.7934	4.7952	3.1984	1.6008	0.801	2.4045
22	3.1972	3.1984	2.3997	1.6018	1.6024	3.2068
24	2.3985	1.5994	1.6	0.801	1.6026	4.009

## CONCLUSIONS

Herein, the environmental consideration of a polymer electrolyte membrane (PEM) fuel cell power system, which is proposed for domestic application, has been investigated. The system was proposed to meet the energy requirements of the building in Ahvaz. Environmental analysis of this CHP system shows that by increasing of ambient air temperature from 1°C to 40°C, production of nitrogen monoxide and carbon monoxide increases by 7.5% and 14.06%, respectively and production of carbon dioxide decreases by 0.48%. It has been found that mass production of monoxide carbon,

nitrogen monoxide and carbon dioxide are equal to 1272.621 (kg/year), 1609.056 (kg/year) and 26107.23 (kg/year), respectively. This data is useful for design reliable systems that pass the environmental protocol limitations.

## REFERENCES

Rosen M.A., Lee N.M. and Dincer I. 2005. Efficiency analysis of a cogeneration and district energy system. Applied Thermal Engineering, 25: 147-159.



- Silveira J.L., Walter A.C.S. and Luengo C.A. 1997. A case study of compact cogeneration using various fuels. *Fuel*. 76: 447-451.
- Ehyaiei M.A. and Bahadori M.N. 2006. Selection of micro turbines to meet electrical and thermal energy needs of residential buildings in Iran. *Energy and Buildings*. 39: 1227-1234.
- Ehyaiei M.A. and Mozafari A. 2010. Energy, economic and environmental (3E) analysis of a micro gas turbine employed for on-site combined heat and power production. *Energy and Buildings*. 42: 259-264.
- Saidi M.H., Ehyaiei M.A. and Abbasi A. 2005a. Optimization of a combined heat and power PEFC by exergy analysis. *Journal of Power Sources*. 143: 179-184.
- Saidi M.H., Ehyaiei M.A., and Abbasi A. 2005b. Exergetic optimization of a PEM fuel cell for domestic hot water heater. *ASME journal of fuel cell technology*. 2: 284-289.
- Renedo C.J., Ortiz A., Monana M., Silio D. and Perez S. 2006. Study of different cogeneration alternatives for Spanish hospital center. *Energy and Buildings*. 38: 484-490.
- Khan K.H., Rasul M.G. and Khan M.M.K. 2004. Energy conservation in buildings: cogeneration and cogeneration coupled with thermal energy storage. *Applied Energy*. 7: 15-34.
- Dentice M., Accadia D. and Sasso M. 2003. Micro-combined heat and power in residential and light commercial applications. *Applied Thermal Engineering*. 23: 1247-1259.
- Miguez J.L., Murillo S. and Porteiro J. 2004a. Feasibility of a new domestic CHP tri generation with heat pump: I. Design development. *Applied Thermal Engineering*. 24: 1409-1419.
- Miguez J.L., Murillo S. and Porteiro J. 2004b. Feasibility of a new domestic CHP tri generation with heat pump: II. Availability analysis. *Applied Thermal Engineering*. 24: 1421-1429.
- Gigliucci G., Petruzzi L. and Cerelli E. 2004. Demonstration of a residential CHP system based on PEM fuel cells. *Journal of Power Sources*. 131: 62-68.
- Kong X.Q., Wang R.Z. and Huang X.H. 2004. Energy efficiency and economic feasibility of CCHP driven by sterling engine. *Energy Conversion and Management*. 45: 1433-1442.
- Maribu K.M., Firestone R., Mamay C. and Siddiqui A.S. 2007. Distributed energy resources market diffusion model. *Energy Policy*. 35: 4471-4484.
- Maidment G.G. and Tozer R.M. 2002. Combined cooling heat and power in supermarkets. *Applied Thermal Engineering*. 22: 653-665.
- Ziher D. and Poredos A. 2006. Economics of a three-generation system in a hospital. *Applied Thermal Engineering*. 26: 680-687.
- Cardona E., P. Sannino, A. Piacentino and F. Cardona. 2006. Energy saving in airports by three-generation. Part II: Short and long term planning for the Malpensa 2000 CHCP plant. *Applied Thermal Engineering*. 26: 1437-1447.
- Bejan A. 1988. *Advanced Engineering Thermodynamics*. John Wiley and Sons, New York, USA.
- Mozafari A., A. Ahmadi and M.A. Ehyaiei. 2010. Optimization of micro gas turbine by exergy, economic and environmental (3E) analysis. *IJ Exergy*. 7: 1-19.