

Geophysical Research Abstracts
Vol. 16, EGU2014-15543, 2014
EGU General Assembly 2014
© Author(s) 2014. CC Attribution 3.0 License.



Operational water balance in irrigation districts

Raúl Sánchez, Leonor Rodríguez-Sinobas, Luis Juana, and Francisco V. Laguna

Technical University of Madrid (UPM) Q2818015F, Grupo de investigación Hidráulica del Riego, Ingeniería Rural Dept., Madrid, Spain (raul.sanchez@upm.es, (34)913365845)

RAÚL SÁNCHEZ¹, LEONOR RODRÍGUEZ-SINOBAS¹, LUIS JUANA¹, FRANCISCO V. LAGUNA²
¹ TECHNICAL UNIVERSITY OF MADRID (UPM), IRRIGATION HYDRAULICS RESEARCH GROUP, RURAL ENGINEERING DEPARTMENT.

² TECHNICAL UNIVERSITY OF MADRID (UPM), IRRIGATION HYDRAULICS RESEARCH GROUP, DEPARTMENT OF CIVIL ENGINEERING: HYDRAULICS AND ENERGY.

Corresponding author: Raúl Sánchez, Email: raul.sanchez@upm.es, <http://hideriego.upm.es>, Address: Escuela Técnica Superior de Ingenieros Agrónomos (edif. principal), Avda. Complutense s/n, 28040 Madrid, Spain.

Abstract

In pressure irrigation-water distribution networks, applied water volume is usually controlled opening a valve during a calculated time interval, and assuming constant flow rate. In general, pressure regulating devices for controlling the discharged flow rate by irrigation units are needed due to the variability of pressure conditions. A pressure regulating valve PRV is the commonly used pressure regulating device in a hydrant, which, also, executes the open and close function. A hydrant feeds several irrigation units, requiring a wide range in flow rate. In addition, some flow meters are also available, one as a component of the hydrant and the rest are placed downstream. Every land owner has one flow meter for each group of field plots downstream the hydrant. Ideal PRV performance would maintain a constant downstream pressure. However, the true performance depends on both upstream pressure and the discharged flow rate.

Theoretical flow rates values have been introduced into a validated in laboratory PRV performance model coupled with an irrigation district waterworks. Variations on flow rate are simulated by taking into account the consequences of variations on climate conditions and also decisions in irrigation operation, such as duration and frequency application. The model comprises continuity, dynamic and energy equations of the components of both the PRV and the water distribution network.

In this work the estimation of water balance terms during the irrigation events in an irrigation campaign has been carried on. The effect of demand concentration peaks has been assessed.