

International Journal of Emerging Electric Power Systems

Volume 2, Issue 1

2005

Article 1021

Optimization Methods for Electric Power Systems: An Overview

R. C. Bansal Dr., *Birla Institute of Technology & Science,
Pilani*

Recommended Citation:

Bansal, R. C. Dr. (2005) "Optimization Methods for Electric Power Systems: An Overview,"
International Journal of Emerging Electric Power Systems: Vol. 2: Iss. 1, Article 1021.

DOI: 10.2202/1553-779X.1021

©2005 by the authors. All rights reserved.

Optimization Methods for Electric Power Systems: An Overview

R. C. Bansal Dr.

Abstract

Power systems optimization problems are very difficult to solve because power systems are very large, complex, geographically widely distributed and are influenced by many unexpected events. It is therefore necessary to employ most efficient optimization methods to take full advantages in simplifying the formulation and implementation of the problem. This article presents an overview of important mathematical optimization and artificial intelligence (AI) techniques used in power optimization problems. Applications of hybrid AI techniques have also been discussed in this article.

KEYWORDS: Power systems optimization, linear programming, expert systems, fuzzy systems, artificial neural network

1 Introduction

Mathematical optimization (algorithmic) methods have been used over the years for many power systems planning, operation, and control problems. Mathematical formulations of real-world problems are derived under certain assumptions and even with these assumptions, the solution of large-scale power systems is not simple. On the other hand, there are many uncertainties in power system problems because power systems are large, complex, and geographically widely distributed. More recently deregulation of power utilities has introduced new issues into the existing problems. It is desirable that solution of power system problems should be optimum globally, but solution searched by mathematical optimization is normally optimum locally. These facts make it difficult to deal effectively with many power system problems through strict mathematical formulation alone.

Therefore, artificial intelligence (AI) techniques which promise a global optimum or nearly so, such as expert systems (ES), artificial neural network (ANN), genetic algorithm (GA), fuzzy logic have emerged in recent years in power systems as a complement tool to mathematical approaches. The real beginning of AI is often quoted as 1958 [1]. Various optimization techniques have been applied to solve the power systems problem and large number of papers has been published in this area since 1950. Review on various power systems problems has been presented by Kothari et al. [2-4], Momoh et al. [5,6], Sachdev et al. [7], Happ [8], Quintanna et al. [9], Gonen et al. [10], Rahman [11], Huneault [12] and IEEE Committee [13,14]. This article presents an overview of important mathematical optimization and AI (e.g. ES, fuzzy logic, ANN, GA, ant colony search (ACS), tabu search (TS)) techniques used in power optimization problems. Applications of hybrid AI techniques in power systems have also been discussed in this article.

2 Mathematical Optimization Methods

An optimization problem is a mathematical model where main objective is to minimize undesirable things (e.g. cost, energy loss, errors, etc.) or maximize desirable things (e.g. profit, quality, efficiency, etc.), subject to some constraints. The main advantages of algorithmic methods include:

- Optimality is mathematically rigorous in some algorithms.
- Problems can be formulated to take advantage of the existing sparsity techniques applicable to large-scale power systems.
- There are a wide range of mature mathematical programming technologies, such as linear programming (LP)/interior point (IP) method and quadratic programming (QP), nonlinear programming (NLP), decomposition technique, integer and mixed integer programming, dynamic programming (DP), etc.

Following Section briefly discusses about the important mathematical optimization techniques used in power systems problems:

2.1 Linear and Quadratic Programming

When the objective function and constraints are linear, this gives the LP [15-17]. LP methods basically fall into two categories: simplex and IP methods [18-25]. These methods can handle problems with thousands of variables and constraints even using inexpensive computers. Main advantage of simplex method is its high computational efficiency. Main disadvantage is that number of iterations grows exponentially with problem size. This disadvantage can be overcome by IP methods. IP methods do not step from one corner point to the next in the manner of simplex algorithm, but rather stay within the interior of the constrained region and progressively move to the optimal point. A variety of IP algorithms have been applied to a number of power system problems, e.g. economic dispatch, reactive power optimization, power system optimization, etc. Both the simplex and IP methods can be extended to a linear and quadratic objective function when constraints are linear. Such methods are called QP [26-27]. LP has been used in various power systems applications, including power systems optimal power flow [16], load flow [17], reactive power planning [28], active and reactive power dispatch [29, 30].

2.2 Nonlinear Programming

When the objective function or the constraints are nonlinear, it forms NLP. The difference between the NLP and LP is analogous to the difference between a set of solving nonlinear equations and a set of solving linear equations. In most of the NLP methods, the approach is to start from an initial guess and to determine a 'descent direction' in which objective function decreases in case of minimization problem. A large number of NLP methods are available, distinguishable by their definition and step length. Quasi-Newton [31], which attempts to build up an approximation to Hessian matrix, can exhibit powerful convergence. Drawback of this method is that matrix processing is required. If the coefficients of Hessian matrix are available analytically, Newton method [32] can be applied. Some of the most successful mathematical methods in use today are based on applying QP to solve a local approximation to a non-linear problem. IP methods originally developed for LP can be applicable to QP and NLP problem. NLP has been applied to various areas of power systems [5] e.g. optimal power flow [33], hydrothermal scheduling [34], etc.

2.3 Integer and Mixed-Integer Programming

For many optimization problems (e.g. ON status =1, and OFF status =0), some of the independent variables can take only integer values; such problem is called integer programming. When some of the variables are continuous, the problem is called mixed integer programming. Mainly two approaches i.e. 'branch and

bound', and 'cutting plane methods', have been used to solve integer problems using mathematical programming techniques [31]. It is possible to solve problem of hundreds of variables using integer and mixed integer programming. The size and complexity of integer and mixed-integer programmes that can be solved in practice depends upon the structure of the problem. Decomposition technique to decompose continuous problem into integer/mixed integer programming has been used in [35-40]. Integer/mixed integer programming has been applied to various areas of power systems e.g. optimal reactive power planning [41], power systems planning [42, 43], unit commitment [44], generation scheduling [45], etc.

2.4 Dynamic Programming

DP based on the principle of optimality states that a sub-policy of an optimal policy must in itself be an optimal sub-policy. For example, for a problem of n generators with possible s output level each, exhaustive enumeration would require s^n possible combinations to be examined, where as DP would examine fewer than $n^2 s^2$ combinations. DP is a very powerful technique, where it is applicable, but suffers from the curse of dimensionality [46], (In the above example for $n=100$, $s=200$, $n^2 s^2 = 4 \times 10^8$). DP has been applied to various areas of power systems e.g. reactive power control [47], transmission planning [48], unit commitment [49], etc.

3 Artificial Intelligence Techniques

Despite the successes of the algorithmic approaches described in the previous section, there remains a large class of problems that elude complete solution in a conventional setting. These problems require:

- Use of knowledge bases to store human knowledge.
- Operator judgment particularly in practical solutions.
- Experience gained over a period of time.
- Characterization by network uncertainty, load variations, etc.

This section presents the overview of AI techniques (ES, ANN, fuzzy systems, EC, ant colony search, tabu search, etc.) for power systems problems.

3.1 Expert System

ES was first broadly researched by Feigenbaum et al. in the early 1970s [50, 51]. ES is a knowledge-based or rule based system, which uses the knowledge and interface procedure to solve problems that are difficult enough to require human expertise for their solution. Main advantages of ES [52] are: (i) It is permanent and consistent; (ii) Can be easily transferred or reproduced; (iii) Can be easily documented. Main disadvantage of ES is that it suffers from a knowledge bottleneck by having inability to learn or adapt to new situations. The level of maturity of applications varies from software prototype to practical systems in use

in the power industry environment. The knowledge engineering techniques started with simplistic rule based techniques and extended to more advanced techniques such as object-oriented design, qualitative reasoning, verification and validation methods, natural languages, multi-agent systems.

For the past twenty years, a great deal of ES applications have been developed to help plan, analyze, manage, control and operate various aspects of power generation, transmission and distributions systems. A survey of ES applications in power system is presented in [53-56]. Lu et al. [57, 58] have done considerable work on the applications of ES in power systems. A recent survey presented in [59] indicates that ES has been applied to various areas of power systems, including: power system planning, alarm processing, fault diagnosis, power system protection, power system restoration and reactive power/voltage control.

3.2 Artificial Neural Network

The starting point of ANN was the training algorithm proposed by Hebb in 1949, which demonstrated how a network of neurons could exhibit learning behaviour [60]. ANN are mainly categorized by their architecture (number of layers), topology (connectivity pattern, feed forward or recurrent etc.), and learning regime. Most of the applications of ANN in the power systems use multi-layer feed forward network. The main advantages of ANN are [61-64]: (i) It is fast; (ii) Possesses learning ability; (iii) Adapts to the data; (iv) Robust; (v) Appropriate for non-linear modelling. These advantages suggest the use of ANN for voltage security monitoring and control. Though the neural network training is generally computationally expensive, it takes negligible time to evaluate voltage stability once the network has been trained. Despite the advantages, some disadvantages of the ANN are: (i) Large dimensionality; (ii) Selection of the optimum configuration; (iii) The choice of training methodology; (iv) The 'black-box' representation of ANN – they lack explanation capabilities and so decisions are not audible; (v) The fact that results are always generated even if the input data are unreasonable.

Vankayala et al. [65] have presented a bibliographical survey of neural network and their applications to power systems. Neural network has been mainly used in following areas of power systems:

- Planning (long term load forecasting [66, 67], capacitor placement/voltage control [68-72])
- Operation (economic dispatch/unit commitment [73-79], short-term load forecasting [80-90], fault diagnosis [91-95], load flow [96], static and dynamic security assessment [97-100], hydro scheduling [101-104], transient stability [105-114])
- Analysis (power system stabilizer [115-117]).

3.3 Fuzzy Logic

Fuzzy logic was developed by Zadeh in 1964 to address uncertainty and imprecision which widely exist in the engineering problems and it was first introduced in 1979 for solving power system problems. Fuzzy set theory can be considered as a generalization of the classical set theory. In classical set theory an element of the universe either belongs to or does not belong to the set. Thus the degree of association of an element is crisp. In a fuzzy set theory the association of an element can be continuously varying. Mathematically, a fuzzy set is a mapping (known as membership function) from the universe of discourse to the closed interval $[0,1]$. The membership function is usually designed by taking into consideration the requirement and constraints of the problem. Fuzzy logic implements human experiences and preferences via membership functions and fuzzy rules. Due to the use of fuzzy variables, the system can be made understandable to a non-expert operator. In this way, fuzzy logic can be used as a general methodology to incorporate knowledge, heuristics or theory into controllers and decision makers.

The advantages of fuzzy theory are (i) More accurately represents the operational constraints of power systems; (ii) Fuzzified constraints are softer than traditional constraints [118, 119]. A detailed introduction to fuzzy logic and their applications in power systems has been presented in [120-122]. Momoh et al. [123] have presented the overview and literature survey of fuzzy set theory application in power systems. A recent survey presented in [124] shows that fuzzy set theory has been applied mainly in voltage and reactive power control, load forecasting, fault diagnosis, power system protection/relaying, stability, and power system control, etc.

3.4 Evolutionary Computation

EC is based on the Darwin's principle of 'survival of the fittest strategy'. An evolutionary algorithm begins by initializing a population of candidate solutions to a problem [132]. New solutions are then created by randomly varying those of the initial population. All solutions are measured with respect to how well they address the task. Finally, a selection criterion is applied to weed out those solutions, which are below par. The process is iterated using the selected set of solutions until a specific criterion is met. The advantages of EC are adaptability to change and ability to generate good enough solutions but it needs to be understood in relation to computing requirements and convergence properties. EC can be subdivided into GA, evolution strategies, evolutionary programming (EP), genetic programming, classified systems and simulated annealing (SA).

The first work in the field of Evolutionary Computation (EC) was reported by Fraser in 1957 [125] to study the aspects of genetic system using a computer. After some time a number of evolutionary inspired optimization techniques were

developed, i.e. by Friedman in 1959 [126], Blendsoe in 1961 [127] and Bremermann in 1962 [128]. EC was presented by Fogel et al. in 1966 [129]. The rejection of EC work by AI community was responsible for widespread skepticism faced by more schema-friendly GA of late 1960s and mid 1970s. GA was later popularized by Holland in 1975 [130], and Goldberg in 1989 [131].

Over 95% of all the papers published in power systems are based on GA [52]. Other popular technique for power system applications is SA. GA and SA have been receiving increasing amounts of attention due to their versatile optimization capabilities for both continuous and discrete optimization problems. Both are motivated by so-called nature's wisdom: GA are loosely based on the concept of natural selection and evolution; while SA originated in the annealing process found in the thermodynamics and metallurgies. A recent extensive literature survey on EC applications in power systems presented in [133].

3.4.1 Genetic Algorithm

GA is a global search technique based on mechanics of natural selection and genetics. It is a general-purpose optimization algorithm that is distinguished from conventional optimization techniques by the use of concepts of population genetics to guide the optimization search. Instead of point-to-point search, GA searches from population to population. The advantages of GA over traditional techniques are:

- i) It needs only rough information of the objective function and places no restriction such as differentiability and convexity on the objective function.
- ii) The method works with a set of solutions from one generation to the next, and not a single solution, thus making it less likely to converge on local minima.
- iii) The solutions developed are randomly based on the probability rate of the genetic operators such as mutation and crossover; the initial solutions thus would not dictate the search direction of GA.

Major disadvantage of GA method is that it requires tremendously high time. Alander [134] has presented a bibliography of genetic algorithm in power systems. Following are the major applications of GA in power systems:

- Planning (transmission expansion planning [135-140], capacitor placement [141-142])
- Operation (voltage/reactive power control [143-145], unit commitment/economic dispatch [146-154], hydrothermal scheduling [155-157]).

3.4.2 Simulated Annealing

SA technique based on thermodynamics were originally inspired by the formation of crystals in solids during cooling. The advantages of SA are its general applicability to deal with arbitrary systems and cost functions, its ability to refine

optimal solution, and its simplicity of implementation even for complex problems. The major drawback of SA is repeated annealing. This method cannot tell whether it has found optimal solution. Some other method (e.g. branch and bound) is required to do this. SA has been used in various power system applications e.g. transmission expansion planning [158, 159], unit commitment [160-162], maintenance scheduling [163], etc.

3.5 Ant Colony Search

Dorigo introduced the ACS system first time in 1992 [164]. ACS techniques take inspiration from the behavior of real ant colonies and are used to solve function or combinatorial problems. ACS algorithms to some extent mimic the behavior of real ants. The main characteristics of ACS are positive feedback for recovery of good solutions, distributed computation, which avoids premature convergence, and the use of a constructive greedy heuristic to find acceptable solutions in the early stages of the search process. Poor computational of the ACS is the main drawback of this technique. ACS technique has been mainly used in finding the shortest route for transmission network [165, 166].

3.6 Tabu Search

TS is an iterative improvement procedure that starts from some initial solution and attempts to determine a better solution in the manner of a ‘greatest descent neighborhood’ search algorithm. Basic components of TS are the moves, tabu list and aspiration level. TS is a metaheuristic search to solve global optimization problem, based on multi-level memory management and response exploration [167-170]. TS has been used in various power system applications, e.g. transmission planning [171], optimal capacitor placement [172-174], unit commitment [175], hydrothermal scheduling [176], fault diagnosis/alarm processing [177, 178], reactive power planning [179], etc.

4 Hybrid AI Techniques

The real life power system problems may neither fit the assumptions of a single AI technique nor be effectively solved by the strengths and capabilities of single technique. One approach to deal with these complex real world problems is to integrate the two or more techniques in order to combine their strengths and overcome each other’s weaknesses to generate hybrid solutions [52]. With the benefits offered by hybrid AI techniques, their applications to power systems have been increasing rapidly. Table 1 lists the different hybrid AI techniques, which have been applied to various power systems problems.

Table 1: Applications of hybrid AI techniques in power systems problems

Hybrid AI techniques	Application area/power system problems
Fuzzy neural network systems	Generation and distribution [180], relaying [181], fault diagnosis [182], load forecasting [183, 184], reactive power control [185, 186], generator maintenance scheduling [187]
Fuzzy genetic systems	Stability [188], Power systems control [189, 190], economic dispatch [191]
Fuzzy expert systems	Power system planning [192]
Fuzzy/neural/expert/genetic systems	Load forecasting [193, 194], generation expansion planning [195], power system stabilizer [196]
Simulated annealing with fuzzy/genetic/expert systems	Reactive power planning [197], generator maintenance scheduling [198-200]

5 Conclusions

This article has shed some light on the important mathematical optimization and AI techniques used in power system applications. Various hybrid AI techniques used in power systems have also been discussed. In the light of the overview presented in this article, the following are the significant points of conclusions.

Despite remarkable advances in mathematical optimization techniques, conventional mathematical methods have yet to achieve fast and reliable real time applications in power system applications. Considerable efforts are required to avoid mathematical traps such as ill-conditioning and convergence difficulties.

AI relies heavily on good problem description and extensive domain knowledge. ES, which is a knowledge-based system, suffers from a knowledge bottleneck by having an inability to learn or to adapt to new situations. Knowledge-based system can enhance the capabilities of a power system, whereas ANN can acquire knowledge through adaptive training and generalization. ANN, fuzzy, and ES suffer from the same requirement of expert user in their design and implementation. They also suffer from a lack of the formal model theory and mathematical rigors and so are vulnerable to the experts' depth of knowledge in problem definition. Fuzzy theory with its of realistic description of power system problems and ANN with its promise of adaptive training and generalization deserves scope for further study. GA, by contrast, access deep knowledge of systems problem by well-established models. GA has much more potential in power systems analysis and are also latest entry into the

AI fields and are getting most of the current attention. GA needs to be understood in relation to the computation requirements and convergence properties. The application of hybrid systems in power system problems is a novel development, which represents a definite future trend in power systems research.

References

- [1] J. McCarthy. Programs with Common Sense. *Proc. National Physics Lab., HMSO*, London, 1958.
- [2] D.P. Kothari. Optimal Hydrothermal Scheduling: A Review. *Journal of Scientific and Industrial Research*, Vol. 47: 98-101, Feb. 1988.
- [3] A. Ahmad and D.P. Kothari. A Review of Recent Advances in Generator Maintenance Scheduling. *Electric Machines and Power Systems*, 26(4):373-387, 1998.
- [4] S. Sen and D.P. Kothari. Optimal Thermal Generating Unit Commitment- A Review. *Int. Journal of Electrical Power and Energy Systems*, 20(7): 443-451, 1998.
- [5] J.A. Mamoh, M.E. El Hawary, and R. Adapa. A Review of Selected Optimal Power Flow Literature to 1993, Part-I: Non-Linear and Quadratic Programming Approach. *IEEE Trans. Power Systems*, 14(1):96-104, 1999.
- [6] J.A. Mamoh, M.E. El Hawary, and R. Adapa. A Review of Selected Optimal Power Flow Literature to 1993, Part-II: Newton, Linear Programming and Interior Point Methods. *IEEE Trans. Power Systems*, 14(1):105-111, 1999.
- [7] M.S. Sachdev, R. Billinton, and C.A. Peterson. Representative Bibliography on Load Forecasting. *IEEE Trans. Power Apparatus and Systems*, PAS-96(2): 697-700, 1977.
- [8] H.H. Happ. Optimization Power Dispatch – A Comprehensive Survey. *IEEE Trans. Power Apparatus and Systems*, PAS-96(2):841-854, 1977.
- [9] V.H. Quintana, G.L. Torres, and J.M. Palomo. Interior-Point Methods and Their Applications to Power Systems: A Classifications of Publications and Software. *IEEE Trans. Power Systems*, 15(1): 170-176, 2000.
- [10] T. Gonen and A.A. Mahmoud. Bibliography of Power Distribution System Planning. *IEEE Trans. Power Apparatus and Systems*, PAS-102(6):1778-1787, 1983.
- [11] R. Rahman. Artificial Intelligence in Electric Power System's Survey in Japanese Industry. *IEEE Trans. Power Systems*, 8(3):1211-1218, 1993.
- [12] M. Huneault and F.D. Galiana. A Survey of the Optimal Power Flow Literature. *IEEE Trans. Power Systems*, 6(2): 762-770, 1991.
- [13] IEEE Committee Report. Load Forecasting, Bibliography, Phase-1. *IEEE Trans. Power Apparatus and Systems*, PAS-99(1): 53-58, 1980.

- [14] IEEE Committee Report. Load Forecasting, Bibliography, Phase-2. *IEEE Trans. Power Apparatus and Systems*, PAS-100(7):3217-3220,1981.
- [15] B. Scott and J.L. Marinho. Linear Programming for Power System Network Security Applications. *IEEE Trans. Power Apparatus and Systems*, PAS-98:837-845, May/June 1979.
- [16] O. Alsac, J. Bright, M. Prais, and B. Scott. Further Developments in LP Based Optimal Power Flow. *IEEE Trans. Power Systems*, 5(3):697-711, 1990.
- [17] G.T. Hegdt and W.M. Grady. Optimal Var Siting Using Linear Load Flow Formulation. *IEEE Trans. Power Apparatus and Systems*, PAS-102 (5):1214-1222, 1983.
- [18] G.D. Irisari, L.M. Kimball, K.A. Clements, A. Bagchi and P.W. Davis. Economic Dispatch with Network and Ramping Constraints via Interior Point Methods. *IEEE Trans. Power Systems*, 13(1):236-242, 1998.
- [19] L.S. Vargas, V.H. Quintana, and V. Vannelli. A Tutorial Description of an Interior Point Method and its Applications to Security Constrained Economic Dispatch. *IEEE Trans. Power Systems*, 8(3):1315-1324, 1993.
- [20] S. Granville. Optimal Reactive Dispatch Through Interior Point Methods. *IEEE Trans. Power Systems*, 9(1):136-144, 1994.
- [21] J.L. M. Ramos, A.G. Exposito, and V.H. Quintana. Reactive Power Optimization by Quadratic Interior Point Method: Implementation Issues. *Proc. 12th Power System Computation Conf.*, Dredson, Germany, 1996.
- [22] M. Christoforidis, M. Aganagic, B. Awobamise, S. Tong, and A.F. Rahimi. Long-Term/Mid-Term Resource Optimization of a Hydro-Dominant Power System using Interior Point Methods. *IEEE Trans. Power Systems*, 11(1):287-294, 1996.
- [23] J.C.O. Mello, A.C.G. Melo, and S. Granville. Simultaneous Capability Assessment by Combining Interior Point Method and Monte Carlo Simulation. *IEEE Trans. Power Systems*, 12(2):736-742, 1997.
- [24] K. Pannambalam, V.H. Quintana, and A. Vannelli. A Fast Algorithm for Power System Optimization using Interior Point Method. *IEEE Trans. Power Systems*, 7(2):892-899, 1992.
- [25] V.R. Sherkat and Y. Ikura. Experience With Interior Point Optimization Software for a Fuel Planning Application. *IEEE Trans. Power Systems*, 9(2):833-840, 1994.
- [26] J.A. Momoh, S.X. Guo, E.C. Ogbuoriri, and R. Adapa. The Quadratic Interior Point Method Solving Power System Optimization Problems. *IEEE Trans. Power Systems*, 9 (3):1327-1336, 1994.
- [27] J. Nanda, D.P. Kothari, and S.C. Srivastava. A New Optimal Power Dispatch Algorithm using Fletcher's QP Method. *IEE Proceedings, Generation Transmission and Distribution*, 136(3):153-161, 1989.

- [28] G. Opoku. Optimal Power System VAR Planning. *IEEE Trans. Power Systems*, 5(1):53-59, 1990,.
- [29] A.M. Chebbo and M.R. Irving. Combined Active and Reactive Power Dispatch Part 1: Problem Formulation and Solution Algorithm. *IEE Proceedings- Generation Transmission and Distribution*, 142(4):393-400, 1995.
- [30] A.M. Chebbo, M.R. Irving, and N.H. Dandachi. Combined Active and Reactive Power Dispatch Part 2: Test Results. *IEE Proceedings- Generation Transmission and Distribution*, 142(4):401-405, 1995.
- [31] M.R. Irving and Y.H. Song. Optimization Methods for Electric Power Systems, Part 1, Mathematical Optimization Methods. *IEE Power Engineering Journal*, 14 (5):245-254, 2000.
- [32] W.F. Tinney and C.S. Hart. Power Flow Solution by Newton's Method. *IEEE Trans. Power Apparatus and Systems*, PAS-86(11):1449-1460, 1967.
- [33] D.I. Sun, B. Ashley, B. Brewer, A. Hughes, and W.F. Tinney. Optimal Power Flow by Newton Approach. *IEEE Trans. Power Apparatus and Systems*, PAS-103(2):2864 – 2878, 1984.
- [34] D.P. Kothari. Optimal Stochastic Hydrothermal Scheduling using Nonlinear Programming Technique. Presented Australian Society, Melbourne (Australia), 335-344, 1989.
- [35] N. Alguacil and A.J. Conejo. Multi-Period Optimal Power Flow using Benders Decomposition. *IEEE Trans. Power Systems*, 15(1):196-201, 2000.
- [36] N. Deeb and S.M. Shahidehpour. Linear Reactive Power Optimization in a Large Power Network Using the Decomposition Approach. *IEEE Trans. Power Systems*, 5(2):428 – 438, 1990.
- [37] A.M. Geoffrion. Generalized Benders Decomposition. *Journal of Optimization Theory Applications*, 10(4) 237-261, 1972.
- [38] M.V.F Pereira, L.M.V.G. Pinto, S.H.F. Cunha, and C.G. Oliveira. Decomposition Approach to Automated Generation/Transmission Expansion Planning. *IEEE Trans. Power Apparatus and Systems*, PAS-104 (11):3074-3083, 1985.
- [39] S. Granville, M.V.F. Pereira, and A. Monticelli. An Integrated Methodology for VAR Source Planning. *IEEE Trans. Power Systems*, 3(2):549-557, 1988.
- [40] J. Madina, A.J. Conejo, N.R. Jimenez, F.P. Thoden, and J. Gonzalez. A LP Based Decomposition Approach to Solve The Medium Term Hydrothermal Coordination Problem. *Proc. 12th Power System Computation Conf.*, Dredson, Germany, 1397-1405, 1996.

- [41] K. Aoki, M. Fan, and A. Nishikori. Optimal VAR Planning by Approximation Method for Recursive Mixed – Integer Linear Programming. *IEEE Trans. Power Systems*, 3(4): 1741 – 1747, 1988.
- [42] R. Adams and M.A. Laughton. Optimal Planning of Power Networks using Mixed Integer Programming. *Proceedings IEE*, 121(2):139-145, 1974.
- [43] T. Gonen and B.L. Foote. Distribution System Planning using Mixed Integer Programming. *IEE Proceedings-Generation, Transmission and Distribution*, 128(2):70-79, 1981.
- [44] T.S. Dillon, K.W. Edwin, H.D. Kochs, and R.D. Tand. Integer Programming Approach to the Problem of Unit Commitment with Probabilistic Reserve Determination. *IEEE Trans. Power Apparatus and Systems*, PAS-97(6): 2154-2166, 1978.
- [45] J.F. Dapezo and H.M. Merrill. Optimal Generator Scheduling with Integer Programming. *IEEE Trans. Power Apparatus and Systems*, PAS-94 (3):1537-1545, 1975.
- [46] Y.H. Song. Modern Optimization Techniques in Power Systems. *Kluwer Academic Publishers*, London, UK, 1999.
- [47] F.C. Lu and Y.Y. Hsu. Reactive Power/Voltage Control in a Distribution Substation using Dynamic Programming. *IEE Proceedings- Generation Transmission and Distribution*, 142(6):639-645, 1995.
- [48] J. Parten. A Simplified Modified Dynamic Programming Algorithm for Sizing Location and Feeder Reinforcements. *IEEE Trans. Power Delivery*, 5(1): 277-283, 1990.
- [49] W.J. Hobbs, G. Hermon, S. Warner, and G.B. Sheble. An Enhanced Dynamic Approach for Unit Commitment. *IEEE Trans. Power Systems*, 3(3):1201-1205, 1988.
- [50] B.G. Buchanan and E.A. Feigenbaum. Dendral and Metadendral: Their Applications Dimension. *Artificial Intelligence*, 5-24, Nov.1978.
- [51] T.J. Dillon and M.A. Laughton. Expert System Application in Power Systems. *Prentice Hall*, London, 1990.
- [52] K. Wardwick, A. Ekwue, and R. Aggarwal. Artificial Intelligence Techniques in Power Systems. *IEE, London*, UK, 1997.
- [53] Z.Z. Zhang, G.S. Hope, and O.P. Malik. Expert Systems in Electric Power Systems – A Bibliographic Survey. *IEEE Trans. Power Systems*, 4(4): 1355-1362, 1989.
- [54] N.J. Balu, R.A. Adapa, G. Cauley, M. Lauby, and D.J. Maratukulam, Review of Expert Systems Planning And Operations, *Proceedings of IEEE*, 80(5): 727-731, 1992.
- [55] CIGRE Task Force 38-06-02, Survey on Expert System in Alarm Handling, *Electra*, Vol. 139:133-151, 1991.

- [56] A.J. Germond and D. Niebur. Survey of Knowledge-Based Systems in Power Systems: Europe. *Proceedings of IEEE*, 80(5): 732-744, 1992.
- [57] C.C. Liu, T.K. Ma, K.L. Liou, and M.S. Tsai. Practical Use of Expert Systems in Power Systems. *Int. Journal on Engineering Intelligent Systems*, 2(1): 11-22, 1994.
- [58] C.C. Liu, Practical Use of Expert Systems in Planning and Operation of Power Systems. *Electra*, 141:31-67, Feb. 1993.
- [59] R.C. Bansal. Literature Survey on Expert System Applications to Power Systems (1990-2001). *Int. Journal Engineering Intelligent Systems*, 11(3):103-112, 2003.
- [60] P.D. Wasserman. Neural Computing: Theory and Practice. *Van Nostrand Reinhold*, New York, 1989.
- [61] D. Niebur and T.S. Dillon, Neural Network Applications in Power Systems, *CRL Publishing Ltd.* U.K. 1996.
- [62] R. Aggarwal and Y.H. Song. Artificial Neural Networks in Power Systems: Part 1 General Introduction to Neural Computing. *IEE Power Engineering Journal*, 11(3): 129-134, 1997.
- [63] R. Aggarwal and Y.H. Song. Artificial Neural Networks in Power Systems: Part 2 Types of Artificial Neural Networks. *IEE Power Engineering Journal*, 12(1):41-47, 1998.
- [64] R. Aggarwal and Y.H. Song. Artificial Neural Networks in Power Systems: Part 3 Examples of Applications in Power Systems. *IEE Power Engineering Journal*, 12(6):279-287, 1998.
- [65] V.S.S. Vankayala and N.D. Rao. Artificial Neural Networks and Their Applications to Power Systems – A Bibliographical Survey. *Electric Power Systems Research*, 28(1):67-79,1993.
- [66] D.D. Highly and T.J. Hilmes. Load Forecasting by ANN. *IEEE Computer Applications in Power*, 6(3) 10-15, 1993.
- [67] D. Park. Electric Load Forecasting Using an Artificial Neural Network. *IEEE Trans. Power Systems*, 6(2): 442-449, 1991.
- [68] N.I. Santoso and O.T. Tan. Neural-Net Based Real-Time Control of Capacitors Installed on Distribution Systems. *IEEE Trans. Power Delivery*, 5(1): 266-272, 1990.
- [69] M.J. Short, C.K. Hui, J.F. Macqeen, and A.O. Ekwue, Application of Artificial Neural Network for NGC Voltage Collapse Monitoring. CIGRE Symposium, Paris, Paper 28-205,1994.
- [70] Y.H. Song, H.B. Wan, and A.T. Johns. Kohonen Neural Network Based Approach to Voltage Weak Buses Areas Identification. *IEE Proceedings-Generation Transmission Distribution*, 144(3):340-344, 1997.

- [71] A.D. Roy and S.K. Goswami. Development of Artificial Neural Networks for Solving Capacitor Control Problem in Distribution Network. *Proc. 9th National Power Systems Conference*, IIT Kanpur (India), 413-416, 1996.
- [72] Z. Gu and D.T. Rizy. Neural Network for Combined Control of Capacitance Banks and Voltage Regulators in Distribution Systems. *IEEE Trans. Power Systems*, 11(4): 1921-1928, 1996.
- [73] J. Kumar and G. Sheble. Clamped State Solution of Artificial Neural Network for Real Time Economic Dispatch. *IEEE Trans. Power Systems*, 10(2): 925-931, 1995.
- [74] M. Djukanovi, M. Alovi, B. Miloevi, and D.J. Sobajic. Neural-Net Based Real-Time Dispatch for Thermal Power Plants. *IEEE Trans. Energy Conversion*, 11(4): 755-761, 1996.
- [75] Y. Fukuyama and Y. Ueki. An Application of Neural Network to Dynamic Dispatch using Multi Processors. *IEEE Trans. Power Systems*, 9(4): 1759-1765, 1994.
- [76] C. Su and G. Chiou. A Fast Computation Hopfield Method to Economic Dispatch of Power Systems. *IEEE Trans. Power Systems*, 12(4): 1759-1764, 1997.
- [77] M.P. Walsh, M.E. Flynn and M.J. O'Malley. Augmented Hopfield Network for Unit Commitment and Economic Dispatch. *IEEE Trans. Power Systems*, 12(4): 1765-1774, 1997.
- [78] P.S. Kulkarni, A.G. Kothari, and D.P. Kothari. Combined Economic Dispatch Unit using Economic Improved Back Propagation Neural Network. *Electric Machines and Power Systems*, 28(8): 31-44, 2000.
- [79] P.S. Kulkarni, A.G. Kothari, and D.P. Kothari. Adaptive BP NN Approach to Emission Constrained Economic Dispatch. *Proc. CBIP Int. Conf.*, New Delhi (India), pp. viii-1-10, 1999.
- [80] D. Singh and S.P. Singh. ANN Based Short Term Load Forecasting. *Institution of Engineers (India)*, 82(3): 155-160, 2001.
- [81] H. Mori and A. Yuithara. Deterministic Annealing for ANN-Based Short-Term Load Forecasting. *IEEE Trans. Power Systems*, 16(3): 545-551, 2001.
- [82] H.S. Hippert, C.E. Pedreira, and H. Hamadanizadeh. Neural Network for Short-Term Load Forecasting. *IEEE Trans. Power Systems*, 16(1): 44-55, 2001.
- [83] S. Krunic, I. Krcmar, and N. Rajakovic. An Improved Neural Network Approach for Short-Term Load Forecasting. *Electric Machines and Power Systems*, 28(8): 703-722, 2000.
- [84] Y.Y. Hsu and C.C. Yang. Design of Artificial Neural Networks for Short Term Load Forecasting. Part I and II. *IEE Proceedings- Generation, Transmission and Distribution*, 138(5): 407-418, 1991.

- [85] R. Lamedica, A. Prudenzi, M. Sofrna, M. Caciottas, and V.O. Cencelli. A Neural Network Based Technique for Short Term Load Forecasting. *IEEE Trans. Power Systems*, 11(4): 1749-1756, 1996.
- [86] K.L. Ho, Y.Y. Hsu, and C.C. Yang. Short Term Load Forecasting using a Multilayer Neural Network with an Adaptive Learning Algorithm. *IEEE Trans. Power Systems*, 7(1): 141-149, 1992.
- [87] T.M. Peng, N.F. Hubele, and G.G. Karady, Advancement in the Application of Neural Network for Short Term Load Forecast. *IEEE Trans. Power Systems*, 7(1), 1992, 250-257.
- [88] W. Charytoniuk and M.S. Chen. Very Short Term Load Forecasting using Artificial Neural Network. *IEEE Trans. Power Systems*, 15(1): 263-268, 2000.
- [89] D.K. Ranaweera, N.F. Hubele, and A.D. Papalexopoulos. Application of Radial Basis Function Neural Network Model to Short Term Load Forecast. *IEE Proceedings - Generation Transmission and Distribution*, 142(1): 45-50, 1995.
- [90] M. Safora and F. Proverbio, A Neural Network Operator Oriented Short-Term and On-Line Load Forecasting Environment. *Electric Power Systems Research*, 33(2):139-149,1995.
- [91] M.M. Tawfik and M.M. Morcos. ANN-Based Technique for Estimating Fault Location on Transmission Lines Using Prony Method. *IEEE Trans. Power Delivery*, 16(2): 219-224, 2001.
- [92] H.A. Darwish and A.M.I. Taalab. Development to Implementation of ANN-Based Fault Diagnosis Scheme for Generator Winding Protection. *IEEE Trans. Power Delivery*, 16(2): 200-207, 2001.
- [93] Z. Chen and J.C. Mann. Artificial Neural Network Approach to Single Ended Fault Locator for Transmission Lines. *IEEE Trans. Power Systems*, 15(1): 370-375, 2000.
- [94] Y.H. Song, A.T. Johns and R. Aggarwal. Neural Network Based Adaptive Autoreclosure Technique For Long-Distance Compensated Transmission Systems. *Electric Machines and Power Systems*, 25(3): 281-294, 1997.
- [95] S. Ebrom, D.L. Lubkeman and M. White. A Neural Network Approach to the Detection of the Incipient Faults on Power Distribution Feeders. *IEEE Trans. Power Delivery*, 5(2):505-514, 1990.
- [96] W.L. Chan, A.T.P. So and L.L. Lia. Initial Application of Artificial Neural Network to Load Flow Analysis. *IEE Proceedings- Generation Transmission and Distribution*, 147(6): 361-366, 2000.
- [97] D.J. Sobajic and Y.H. Pao. ANN Based Dynamic Security Assessment for Electric Power Systems. *IEEE Trans. Power Systems*, 4(1): 220-226, 1989.

- [98] S. Ghosh and B.H. Chowdhury, Security Constrained Optimal Rescheduling of Real Power using Hopfield Neural Network. *IEEE Trans. Power Systems*, 11(4): 1743-1748, 1996.
- [99] D.J. Sobojic and Y. Pao. Artificial Neural Network Based Dynamic Security Assessment for Electric Power Systems. *IEEE Trans. Power Systems*, 4(1):220-228, 1989.
- [100] D. Nibur and A.J. Germond. Power System Static Security Assessment using the Kohonen Neural Network Classifier. *IEEE Trans. Power Systems*, 7(2):865-872,1992.
- [101] R. Naresh and J. Sharma. Hydro System Scheduling Using ANN Approach. *IEEE Trans. Power Systems*, 15(1): 388-395, 2000.
- [102] J.T. Ma, L.L. Lai, R.H. Liang, and Y.Y. Hsu. Short-Term Hydro-Scheduling using Hopfield Neural Network Evolutionary Programming Approach to Reactive Power Planning. *IEE Proceedings- Generation Transmission and Distribution*, 143(3): 269-275, 1996.
- [103] L.R. Hsu and H.Y Yih. A Hybrid Artificial Neural Network-Differential Dynamic Programming Approach for Short-Term Hydro Scheduling. *Electric Power System Research*, 33(2): 77-86, 1995.
- [104] R.H. Liang and Y.Y. Hsu. Scheduling of Hydroelectric Generations using Artificial Neural Networks. *IEE Proceedings- Generation Transmission and Distribution*, 141(5): 452-458, 1994.
- [105] X.Z. Dai, D. He, L.L. Fan, N.H. Li, and H. Chen. Improved ANN Alpha Th-Order Inverse TCSC Controller for Enhancing Power System Transient Stability. *IEE Proceedings- Generation Transmission and Distribution*, 146(6): 550-556, 1999.
- [106] C.W. Liu, M.C. Su, S.S. Tsay, and Y.J. Wang. Application of a Novel Fuzzy Neural Network to Real-Time Transient Stability Swings Prediction Based on Synchronized Phasor Measurements. *IEEE Trans. Power Systems*, 14(2): 685 –692, 1999.
- [107] C.W. Liu, S.S. Tsay, Y.J. Wang, and M.C. Su. Neuro-Fuzzy Approach to Real-Time Transient Stability Prediction Based on Synchronized Phasor Measurements. *Electric Power System Research*, 49(2): 123-127, 1999.
- [108] T. Hiyama, Y. Ueki, H. Andou. Integrated Fuzzy Logic Generator Controller for Stability Enhancement. *IEEE Trans. Energy Conversion*, 12(4): 400 –406, 1997.
- [109] S.H. Karaki, A.S. Deba, and Y.E. Saliva. Multi-Machine Classical Transient Stability using ANN. *Int. Journal of Power and Energy Systems*, 19(1): 49-55, 1997.
- [110] F. Aboytes and R. Ramirez, Transient Stability Assessment in Longitudinal Power Systems using Artificial Neural Networks. *IEEE Tran. Power Systems*, 11(4): 2003 –2010, 1997.

- [111] H.C. Chang and M.H. Wang. Neural Network-Based Self-Organizing Fuzzy Controller for Transient Stability of Multimachine Power Systems. *IEEE Trans. Energy Conversion*, 10(2): 339-347, 1995.
- [112] V. Miranda, J.N. Fidalgo, J.A.P. Lopes, and L.B. Almeida. Real Time Preventive Actions for Transient Stability Enhancement with a Hybrid Neural Network-Optimization Approach. *IEEE Trans. Power Systems*, 10(2): 1029 –1035, 1995.
- [113] D.R. Marpaka, M. Bodruzzaman, S.S. Devagan, S.M. Aghili, and S. Kari. Neural Network Based Transient Stability Assessment of Electric Power Systems. *Electric Power System Research*, 30(1): 251-256, 1994.
- [114] A.M. Sharaf and T.T. Lie. Artificial Neural Network Pattern Classification of Transient Stability and Loss of Excitation for Synchronous Generation. *Electric Power Systems Research*, 30(1): 9-16, 1994.
- [115] A. Sharma and M.L. Kothari. Adaptive Network Fuzzy Interference System Based Dual Input Power System Stabilizer. *Proc. National Seminar on Sustainable Energy Options for the New Millennium*, Jaipur (India), 240 – 249, 2000.
- [116] S. Madnani. Radial Basis Function (RBF) Network Adaptive Power System Stabilizer. *IEEE Trans. on Power Systems*, 15(2):722-727, 2000.
- [117] M. Moghivvemi and S.S. Yang. ANN Application Techniques for Power System Stabilizer. *Electric Machines and Power Systems*, 28(2): 167-178, 2000.
- [118] L.A. Zadeh. Fuzzy Sets. *Information and Control*, Vol. 8:338-353, 1965.
- [119] S.K. Pal and D.P. Mandal. Fuzzy Logic and Approximate Reasoning: An Overview. *Journal of Institution of Electronics and Telecommunication Engineers*, Paper No. 186-C, 548-559, 1991.
- [120] Y.H. Song and A.T. Johns. Applications of Fuzzy Logic in Power Systems. I. General Introduction to Fuzzy Logic. *IEE Power Engineering Journal*, 11(5): 219-222, 1997.
- [121] Y.H. Song and A.T. Johns. Applications of Fuzzy Logic in Power Systems. II. Comparison and Integration with Expert Systems Neural Networks and Genetic Algorithms. *IEE Power Engineering Journal*, 12(4):185-190, 1998.
- [122] Y.H. Song and A.T. Johns. Applications of Fuzzy Logic in Power Systems. III. Example Applications. *IEE Power Engineering Journal*, 13(2):97-103, 1999.
- [123] J.A. Momoh, X.W. Ma, and K. Tomsovic. Overview and Literature Survey of Fuzzy Set Theory in Power Systems. *IEEE Trans. Power Systems*, 10(3): 1676-1690, 1995.
- [124] R.C. Bansal. Bibliography on the Fuzzy Set Theory Applications to Power Systems (1994-2001). *IEEE Trans. Power Systems*, 18(4):1291-1299, 2003.

- [125] A.S. Fraser. Simulation of Genetic Systems by Automatic Digital Computers. *Australian Journal of Biological Sciences*, Vol. 10: 484-491 1957.
- [126] G.D. Friedman. Digital Simulation of an Evolutionary Process. *General Systems Yearbook*, 4, 1959.
- [127] W.W. Blendsoe. The Use of Biological Concepts in the Analytical Study of Systems. *Paper presented at the ORSA-TIMS National Meeting, San Francisco, CA, Nov. 1961.*
- [128] H.J. Bremermann. Optimization Through Evolution and Recombination. in M.C. Yovits, G.T. Jacobi, and G.D. Goldstein (editors), *Self Organization Systems*, *Spartan Books*, Wasington, D.C., pp. 93-106, 1962.
- [129] L.J. Fogel, A.J. Owens, and M.J. Walsh. *Artificial Intelligence Through Simulated Evolution*. *John Wiley*, New York, 1966.
- [130] J.H. Holland. *Adaption in Natural and Artificial Systems*. *University of Michigan Press*, Ann Arbor, MI, 1975.
- [131] D.E. Goldberg. *Genetic Algorithms in Search, Optimization and Machine Learning*. *Addison-Wesley*, New York, 1989.
- [132] D. B. Fogel. What is Evolutionary Computation? *IEEE Spectrum*, 37(2):26-32, 2000.
- [133] R.C. Bansal. A Bibliographical Survey of Evolutionary Computation Applications in Power Systems (1994-2003). To appear in *Int. Journal of Power and Energy Systems*, Vol. 25, 2005.
- [134] J.T. Alander. An Indexed Bibliography of Genetic Algorithm in Power Engineering. *Report Series 94-1, Power*, Feb. 1996, <ftp://ftp.uwasa.fi/cs/report94-1/gaPOWERbib.ps.Z>.
- [135] E.L. da Silva, H.A. Gill, and J.M. Areiza. Transmission Network Expansion Planning Under an Improved Genetic Algorithm. *IEEE Trans. Power Systems*, 15(3): 1168-1175, 2000.
- [136] R. Hugh, R. Palma, E. Cura, and C. Silva. Economically Adapted Transmission System in Open Access Schemes - Application of Genetic Algorithm. *IEEE Trans. Power Systems*, 11(3): 1427-1440, 1996.
- [137] EC. Yeh, S.S. Venkata and Z. Sumic. Improved Distribution System Planning using Computational Evolution. *IEEE Trans. Power Systems*, 11(2): 668-674, 1996.
- [138] J.B. Park, Y.M. Park, and K.Y. Lee. An Improved Genetic Algorithm for Transmission Network Expansion Planning. *IEEE Trans. Power Systems*, 15(3): 916-922, 2000.
- [139] K. Nara, T. Satoh, K. Aoki, and M. Kitagawa. Multilayer Expansion Planning for Distribution Systems Distribution Network Planning. *IEEE Trans. Power Systems*, 6(3): 952-958, 1991.

- [140] V. Miranda, J. V. Ranito, and L.M. Proenca. Genetic Algorithms in Optimal Multistage Distribution Network Planning. *IEEE Trans. Power Systems*, 9(4): 1927-1933, 1994.
- [141] M. Delfanti, G.P. Granelli, P. Marannino, and M. Montagna. Optimal Capacitor Placement using Deterministic and Genetic Algorithms. *IEEE Trans. on Energy Conversion*, 15(3): 1041-1046, 2000.
- [142] S. Sundhararajan and A. Pahwa. Optimal Selection of Capacitor for Radial Distribution Systems using Genetic Algorithms. *IEEE Trans. Power Systems*, 9(3), 1994, 1499-1507.
- [143] T. Haida and Y. Akimoto. Voltage Optimization using Genetic Algorithm. *Proc. 3rd Symposium on Expert System Applications to Power Systems*, Tokyo, Japan, 375-380, 1991.
- [144] R. Yokoyama, T. Niimura, and Y. Nakanishi. A Coordinated Control of Voltage and Reactive Power By Heuristic Modeling and Approximate Reasoning. *IEEE Trans. Power Systems*, 8(2): 636 – 645, 1993.
- [145] K. Iba. Reactive Power Optimization by Genetic Algorithm. *IEEE Trans. Power Systems*, 9(2): 685- 692, 1994.
- [146] S.A. Kazarlis, A.G. Bakirtzis, and V. Petridis. A Genetic Algorithm Solution to Unit Commitment Problem. *IEEE Trans. Power Systems*, 11(1): 83-92, 1996.
- [147] C.P. Cheng, C.W. Liu, and C.C. Lin. Unit Commitment by Lagrangian Relaxation and Genetic Algorithms. *IEEE Trans. Power Systems*, 15(2): 707-714, 2000.
- [148] C.W. Richter Jr. and G.B. Sheble. A Profit Based Unit Commitment GA for Competitive Environment. *IEEE Trans. Power Systems*, 15(2): 715-721, 2000.
- [149] C.J. Aldridge, S. Mekee, J.R. Mc Denel, S.J. Gallowak, K.P. Dahal, M.C. Bradley, and J.F. Macqueen. Knowledge-Based Genetic Algorithm for Unit Commitment Problem. *IEE Proceedings- Generation Transmission and Distribution*, 146(2): 146-152, 2001.
- [150] P.C. Yang, H.T. Yang, and C.L. Huang. Solving the Unit Commitment Problem Through a Constraint Satisfaction Technique. *Electric Power Systems Research*, 37(1): 55-65, 1996.
- [151] T.T. Maifield, and G.B. Sheble. Genetic Based Unit Commitment Algorithm. *IEEE Trans. Power Systems*, 11(3): 1359-1376, 1996.
- [152] S.A. Kazarils, A.G. Bakirtzis, and V. Petridis. A Genetic Algorithm Solution to Unit Commitment Problem. *IEEE Trans. Power Systems*, 11(1): 83-92, 1992.
- [153] P. Venkatesh, P.S. Kanan, and S. Anudevi. Application of Micro Genetic Algorithm to Economic Load Dispatch. *Institution of Engineers (India)*, 82(3): 161-166, 2001.

- [154] Y.H. Song and C.S. Chou. Advanced Engineered Conditioning Genetic Approach to Power Economic Dispatch. *Proc. IEE – Generation Transmission Distribution*, 144(3): 285-292, 1997.
- [155] P.H. Chan and H.C. Chang. Genetic Aided Scheduling of Hydraulically Coupled Plants in Hydrothermal Coordination. *IEEE Trans. Power Systems*, 11(2): 975-981, 1996.
- [156] O.S. Orero and M.R. Irving. A Genetic Algorithm Modeling Framework and Solution Technique for Short Term Optimal Hydrothermal Scheduling. *IEEE Trans. Power Systems*, 13(2): 501-518, 1998.
- [157] O.S. Orero and M.R. Irving. A Genetic Algorithm for Generator Scheduling in Power System. *Int. Journal of Electrical Power and Energy Systems*, 18(1): 19-26, 1996.
- [158] R.A. Gallego, A.B. Alves, A. Monticelli, and R. Romero. Parallel Simulated Annealing Applied to Long Term Transmission Network Expansion Planning. *IEEE Trans. Power Systems*, 12(1): 181-188, 1997.
- [159] R. Romero, R.A. Gallego, and A. Monticelli. Transmission System Expansion Planning by Simulated Annealing. *IEEE Trans. Power Systems*, 11(1): 364-369, 1996.
- [160] U.D. Annakkage, T. Numnonda, and N.C. Pahalawaththa. Unit Commitment by Parallel Simulated Annealing. *IEE Proceedings-Generation Transmission and Distribution*, 142(6): 595-600, 1995.
- [161] A.H. Mentaway, Y.L. Abdel-Magid, and S.Z. Selim. A Simulated Annealing Algorithm for Unit Commitment. *IEEE Trans. Power Systems*, 13(1): 197-204, 1998.
- [162] H.T. Yang, P.C. Yang, and C.L. Huang. A Parallel Algorithm Approach to Solving the Unit Commitment Problem: Implementation on the Transputer Networks. *IEEE Trans. Power Systems*, 12(2): 661-668, 1997.
- [163] T. Satoh and K. Nara. Maintenance Scheduling by Using Simulated Annealing Method. *IEEE Trans. Power Systems*, 6(2) 850-857, 1991.
- [164] Y.H. Song and M.R. Irving. Optimization Methods for Electric Power Systems, Part 2, Heuristic Optimization Methods. *IEE Power Engineering Journal*, 15(3): 151-160, 2001.
- [165] M. Dorigo, V. Maniezzo, and A. Coloni. The Ant System: Optimization by a Colony of Co-Operating Agents. *IEEE Trans. Systems, Man and Cybernetics*, 26(1): 29-41, 1996.
- [166] Y.H. Song and C.S. Chou. Application of Ant Colony Search Algorithms in Power System Optimization. *IEEE Power Engineering Review*, 18(12): 63-64, 1998.
- [167] F. Glover and M. Laguna. Tabu Search. *Kluwer Academic Publishers*, Boston, USA, 1997.

- [168] F. Glover, M. Laguna, E. Tallard and D.de Werra. Tabu Search. *Science Publishers*, Basel, Switzerland, 1993.
- [169] F. Glover. Tabu Search – Part 1. *ORSA Journal on Computing*, 1(3): 190-206, 1989.
- [170] F. Glover, Tabu Search – Part 1. *ORSA Journal on Computing*, 2(1): 4-32, 1990.
- [171] F. Wen and C.S. Chang. Transmission Network Optimal Planning using Tabu Search Method. *Electric Power System Research*, 42(2): 153-163, 1997.
- [172] Y.C. Huang, H.T. Yang, and C.L. Haung. Solving the Capacitor Placement Problem in a Radial Distribution System using Tabu Search Approach. *IEEE Trans. Power Systems*, 11(4): 1868-1873, 1996.
- [173] H.T. Yang, Y.C. Huang, and C.L. Haung. Solution to Capacitor Placement Problem in a Radial Distribution System Using Tabu Search Method. *Proc. Int. Conf. on Energy Management and Power Delivery*, Singapore, 388-393, 1995.
- [174] D. Gan, Y. Hayashi, and K. Nara. Multi-Level Reactive Resource Planning by Tabu Search. *Proc. of IEE of Japan Power and Energy*, Nagoya, Japan, 137-142, 1995.
- [175] H. Mori and T. Usami. Unit Commitment using Tabu Search with Restricted Neighborhood. *Proc. of Int. Conf. on Intelligent Systems Applications to Power Systems*, Orlando, USA, 422-427, 1996.
- [176] X. Bai and S. Shahidehpour. Hydro-Thermal Scheduling by Tabu Search and by Decomposition Method. *IEEE Trans. Power Systems*, 11(2): 968-974, 1996.
- [177] F. Wen and C.S. Chang. A Tabu Search Approach to Fault Section Estimation in Power Systems. *Electric Power System Research*, 40(1): 63-73, 1997.
- [178] F. Wen and C.S. Chang. Tabu Search Approach to Alarm Processing in Power Systems. *IEE Proceedings- Generation Transmission and Distribution*, 144(1): 31-38, 1997.
- [179] D. Gan, Z. Qu, and H. Cai. Large Scale VAR Optimization by Tabu Search. *Electric Power System Research*, 39(3): 195-204, 1995.
- [180] R. Aggarwal and Y.H. Song. Fuzzy Logic and Neural Networks in Generation and Distribution. *Power Technology International*, Spring Issue, 39-45, 1997.
- [181] P.K. Dash, T.S. Sidhu, and H.S. Gill. A Novel Fuzzy Neural Based Distance-Relaying Scheme. *IEEE Trans. Power Delivery*, 15(3): 895-901, 2000.

- [182] R. Aggarwal, M. Joorabian, and Y.H. Song. Fuzzy Neural Network Approach to Accurate Transmission Line Fault Location. *Int. Journal of Engineering Intelligent Systems*, 5(4), 1997.
- [183] D. Srinivasan, A. Liew, and C. Chang. Forecasting Daily Load Curve using a Hybrid Fuzzy-Neural Approach. *IEE Proceedings- Generation Transmission and Distribution*, 141(6): 561-567, 1994.
- [184] A.C. Bakirtzis, J.B. Theocharis, S.J. Kiartzis, and K.J. Satsios. Short Term Load Forecasting Fuzzy Neural Networks. *IEEE Trans. Power Systems*, 10(3): 1518-1524, 1995.
- [185] C.W. Liu, C.S. Chang, and M.C. Su. Neuro-Fuzzy Networks for Voltage Security Monitoring Based on Synchronized Phasor Measurements. *IEEE Trans. Power Systems*, 13(2):326-332, 1998.
- [186] K. Elithy and A. Al-Naamany, A Hybrid Neuro Fuzzy Network (ANN) and Static VAR Compensator for Stabilizer System Damping Improvement in the Presence of Load Parameters Uncertainty. *Electric Power Systems Research*, 56(3): 211-223, 2000.
- [187] C. Wang and M. Shalidehpour. A Fuzzy Artificial Neural Network for Multi-Area Optimal Power Generation Scheduling with Transmission Losses. *Proc. of the American Power Conf.*, Chicago, IL, 1992.
- [188] P. Lakshmi and M.A. Khan. Stability Enhancement of a Multi-Machine Power System using Fuzzy Logic Based Power System Stabilizer Tuned Through Genetic Algorithm. *Int. Journal of Electrical Power and Energy Systems*, 22(2): 137-145, 2000.
- [189] J. Wen, S. Cheng, and O.P. Malik. A Synchronous Generator Fuzzy Excitation Controller Optimally Designed with Genetic Algorithm. *IEEE Trans. Power Systems*, 13(3): 884-889, 1997.
- [190] C.S. Chang, W. Fu, and F. Wen. Load Frequency Control using Genetic Algorithm Based Fuzzy Gain Scheduling of PI Controller. *Electrical Machines and Power Systems*, 26(1): 39-52, 1998.
- [191] Y.H. Song, G.S. Wang, P.Y. Wang, and A.T. Johns. Environmental/Economic Dispatch using Fuzzy Controlled Genetic Algorithms. *Proc IEE - Generation Transmission Distribution*, 144(4): 377-382, 1997.
- [192] A.K. David and R. Zhao. An Expert Systems With Fuzzy Sets for Optimal Long Range Operation Planning. *IEEE Trans. Power Systems*, 6(1):59-65, 1991.
- [193] P.K. Dash, A.C. Liew, and S. Rahman. Fuzzy Neural Network and Fuzzy Expert Systems for Load Forecasting. *IEE Proceedings - Generation Transmission and Distribution*, 143(1): 106-114, 1996.
- [194] K.H. Kim, K. J. Park, K. J. Hwang, and S.H. Kim. Implementation of Hybrid Short Term Load Forecasting using Artificial Neural Networks and

- Fuzzy Expert Networks. *IEEE Trans. Power Systems*, 10(3): 1534-1539, 1995.
- [195] Y. M. Park, J. B. Park, and J. R. Won, A Hybrid Genetic Algorithm/Dynamic Programming Approach To Optimal Long-Term Generation Expansion Planning, *Int. Journal of Electrical Power and Energy Systems*, 20(4): 295-303, 1997.
- [196] A. Afzalin and D.A. Linkens. Training of Neuro Fuzzy Power System Stabilizer using Genetic Algorithms. *Int. Journal of Electrical Power and Energy Systems*, 22(2): 93-102, 2000.
- [197] W.S. Jwo, C.W. Liu, C.C. Liu, and Y.T. Hsiao. Hybrid Expert System and Simulated Annealing Approach to Optimal Reactive Power Planning. *IEE Proceedings- Generation Transmission and Distribution*, 142(4): 381-385, 1995.
- [198] K.P. Wong and Y.W. Wong. Combined Genetic Algorithm/ Simulated Annealing /Fuzzy Set to Short Term Generation Scheduling with Take-or Pay Fuel Contract. *IEEE Trans. Power Systems*, 11(1): 128-136, 1996.
- [199] K.P. Wong and S.Y.W. Wong. Hybrid Genetic/Simulated Annealing to Short Term Multiple Fuel-Constrained Generation Scheduling. *IEEE Trans. Power Systems*, 12(2):776-784, 1997.
- [200] H. Kim, K. Nara, and M. Gen. A Method for Maintenance Scheduling using GA Combined with SA. *Computers and Industrial Engineering*, 27(4): 477-480, 1994.