

Techno-economic Analysis of Chemical Looping Combustion with Humid Air Turbine Power Cycle

Akeem K Olaleye^{1,2}, Meihong Wang^{1,2}

¹ *Process and Energy Systems Engineering Group, School of Engineering, University of Hull, Cottingham Road, Hull, United Kingdom, HU6 7RX*

² *Process Systems Engineering Group, School of Engineering, Cranfield University, United Kingdom, MK43 0AL*

Emails: A.K.Olaleye@2012.hull.ac.uk; Meihong.Wang@hull.ac.uk

Abstract

Power generation from fossil fuel-fired power plant is the largest single source of CO₂ emission. CO₂ emission contributes to climate change. On the other hand, renewable energy is hindered by complex constraints in dealing with large scale application and high price. Power generation from fossil fuels with CO₂ capture is therefore necessary to meet the increasing energy demand, and reduce the emission of CO₂. This paper presents a process simulation and economic analysis of the chemical looping combustion (CLC) integrated with humid air turbine (HAT) cycle for natural gas-fired power plant with CO₂ capture. The study shows that the CLC-HAT including CO₂ capture has a thermal efficiency of 57% at oxidizing temperature of 1200°C and reducer inlet temperature of 530°C. The economic evaluation shows that the 50 MW_{th} plant with a projected lifetime of 30 years will have a payback period of 7 years and 6 years for conventional HAT and CLC-HAT cycles respectively. The analysis indicates that CLC-HAT process has a high potential to be commercialised.

Keywords: Chemical Looping Combustion, Humid Air Turbine, Economic Analysis, Process simulation, CO₂ capture, Circulating Fluidized Bed (CFB)

© 2014, Elsevier. Licensed under the Creative Commons Attribution-NonCommercial-NoDerivatives 4.0 International <http://creativecommons.org/licenses/by-nc-nd/4.0/>

Nomenclature

NCV	net calorific value (J/kg)
P	power output (MW)
NPV	Net Present Value (£)
IRR	Internal Rate of Return (%)
η_{ref}	efficiency of Conventional HAT cycle (%)
η_{ccs}	efficiency of HAT cycle with Carbon capture (%)
W_{comp}	Compressor Work (MW)
Q	energy (MW)

Greek Symbols

Υ	yield
η	efficiency

Subscripts

comp	compressor
ccs	carbon capture and storage
ref	reference
GT	gas turbine
th	thermal

Acronyms

ASU	air separation unit
CFB	circulating fluidized bed
CLC	chemical looping combustion
CLC-HAT	chemical Looping Combustion with humid air turbine cycle
HAT	humid air turbine
PI	profitability index

1 Introduction

1.1 Background

Fossil fuels are burned in power plants in a variety of ways. The combustion of fossil fuels produces flue gas stream (i.e. NO_x, CO₂, SO_x, CO, CH₄, water vapour etc.) with a CO₂ content of up to 14 vol% [1]. CO₂ is the largest and most important anthropogenic greenhouse gas (GHG) [2]. However, fossil fuel fired power plants play a key role in meeting energy demands. With growing concerns over the increasing atmospheric concentration of anthropogenic greenhouse gases, effective CO₂ emission abatement strategies are required to combat this trend [3]. In a fossil fuel-based power plant, CO₂ management is made up of three steps namely CO₂ capture (including separation and compression); transportation and storage [4]. There are three approaches for capturing CO₂ from use of fossil fuels and/or biomass for heat and power generation: pre-combustion, post-combustion and oxy-fuel process [5]. CLC is a relatively new CO₂ capture mechanism. The fuel is converted by its reaction with oxygen from an oxygen carrier rather than air (as in oxy-fuel and pre-combustion). CLC also enables the production of a concentrated CO₂ stream without the need for an expensive air separation unit [6]. The inherent CO₂ separation without severe energy penalties in the CLC process has drawn increased attention in light of power plant efficiency improvement and global warming potential due to fossil fuel combustion [4].

1.2 Chemical Looping Combustion (CLC)

1.2.1 CLC Concept

CLC is a method characterized by indirect fuel combustion because the air and fuel are never in direct contact. CLC differs from the oxy-fuel combustion strategy because of the concept of oxygen separation from air and the direct contact of pure oxygen & fuel in the latter [4]. In oxy-fuel combustion, the operation of air separation unit (ASU) accounts for nearly three quarters of overall efficiency loss [7].

Figure 1 shows a schematic diagram of the CLC concept. The fossil fuel conversion is achieved in two sub-reactions (oxidation and reduction) and with oxygen carrier particle as the chemical intermediates. In the reduction stage, the oxygen carrier particle is reduced by the fuel, yielding CO₂ and H₂O. This is depicted in reaction (1) for a gaseous fuel [4]





Figure 1: Schematic of the CLC Concept [4]

This fuel conversion step could either be exothermic or endothermic depending upon the type of oxygen carrier and fuel used. The reduced metal is then sent to the oxidizer where combustion occurs with air. The reduced metal is regenerated to its initial oxidation state as shown in reaction (2) [4].



The oxidation step being exothermic produces an enormous amount of heat which is used to generate electricity; also the fact that both the fuel and the air conversion process occur in different reactors leads to the production of a CO₂ stream from the reducer that has only H₂O as the other component, hence it is easily separated from the mixture. CLC can be applied to both gaseous (natural gas) and solid fuels (coal) [4].

1.2.2 Review on CLC Study

The most common metals used as oxygen carrier include Fe, Ni, and Cu. A number of promising oxygen carriers have been found, of which NiO/NiAl₂O₄ is perhaps the most promising [8] [9]. NiO/Ni oxygen carrier particle with NiAl₂O₄ as inert support material will be used as the oxygen carrier particle in this study. A brief outline of some of the published work on oxygen carrier development is summarized in Table 1.

Table 1: Oxygen Carrier Development

Authors	Carriers/ Stabilizers	Fuel/Reactant gases	Issues/ results
Johansson et al [10]	NiO-Fe ₂ O ₃	CH ₄	Using mixed Fe & Ni oxides for CH ₄ combustion. Less bed material used with mixed oxides as against Fe only.
Jerndal et al [11]	Metal oxides based on Ni, Cu, Fe, Mn	CH ₄ , CO and H ₂	Thermal analysis of the CLC process using different O ₂ carrier
Abad et al [12]	Fe ₂ O ₃ / Al ₂ O ₃	CH ₄ / Syngas	Low attrition, and particles have high durability, but better suited for syngas than CH ₄
Zhao et al [13]	NiO/ NiAl ₂ O ₄	Coal char/H ₂	NiO/NiAl ₂ O ₄ reacts rapidly with coal char at temperature higher than 850°C with NiO mass content of 60% and sintering temperature of 1300°C
Abad et al [14]	FeTiO ₃ / TiO ₂	CH ₄ , CO/H ₂	Kinetics of the REDOX reaction were obtained
Mendiara et al [15]	Bauxite Waste (BW)	Coal	Investigates influence of temperature on coal conversion
Mattison et al [16]	NiO/NiAl ₂ O ₄	CH ₄	The particles show high rate of reduction with CH ₄ in the temperature range 750-950°C

Reactor design is another important area in CLC development that has witnessed rapid growth. Optimized reactor design is required in order to render the CLC operation economically feasible. Two key factors that dictate the selection of gas–solid reactor are the type of metal oxide carriers employed for the looping operation and the type of products to be produced [4]. Fluidized beds systems have been widely applied for CLC reactor systems modelling, design and experimentation. From the pioneering work of Lyngfelt [17], a number of study are available e.g. [18], [19], and [20] etc. on the modelling, design and scale-up of fluidized bed reactor system for a successful operation of CLC systems.

1.2.3 CLC Power Cycles

In order to fully appreciate the gains of a relatively new technology such as CLC, it is imperative to carry out detailed study of its power generation potential. The CLC system can be integrated into different power cycles, and analysed at different operating conditions. These studies are done by modelling and simulation of the power plants with CLC, performing sensitivity analysis for various plant configurations in order to estimate the plant efficiency.

A number of articles have been published on the integration of CLC into power cycles. Different approaches have been adopted at different periods by different researchers to evaluate the potentials of CLC power generation scheme. Two important aspects, however dominates the researches carried out so far, these are;

- Power cycle analysis which focuses mainly on the comparative studies of different power cycles, and
- Exergy analysis of CLC power cycle and its comparison with that of conventional power cycle.

Articles focusing on the first aspect include [21], [22] and [23] etc. [21], [22] and [23] made use of a common fuel (CH_4) and similar oxygen carrier with different power cycles for comparison. It was found that the cycles integrated with CLC have minute energy losses and CO_2 was separated at a higher capture level. Articles that focus on the exergy analysis include [24], [9]. It was reported that the exergy losses in the CLC power cycle were lower compared to conventional cycles.

Authors of [24] and [9] used the Humid Air Turbine (HAT) power cycle. The HAT cycle is adopted in this research due to its advantages and high thermal efficiency [25]. In this principle, a humidifying tower is used to saturate the incoming air, before combustion [9].

1.3 Aim of this paper and its Novel Contribution

In this paper, the CLC system is integrated into a HAT cycle. The paper presents a process simulation and economic analysis of CLC in the HAT cycle. The differences between this paper and previous CLC with HAT power cycle reports such as [24] and [9] are: (a) this paper uses a modular-based simulation tool (Aspen Plus[®]) with well-defined physical and thermodynamic properties of the reacting species and inert in its database; (b) this paper use a promising oxygen carrier, NiO and NiAl_2O_4 as the looping media in modelling and simulation of the CLC process; (c) this paper presents the simulation and process analysis of both the conventional HAT power cycle and CLC-HAT cycle, (d) this paper carried out economic analysis of the CLC-HAT cycle in order to determine its feasibility, and compare it with equivalent conventional HAT cycle.

2 Simulation of CLC

This section describes the development of CLC simulation in Aspen Plus[®]. It requires specific skills such as accurate description of property packages of pure components and complex mixtures, models for different types of reactors and unit operations etc.

2.1 Simulation Data for CLC

There exists no full-scale commercial CLC plant (e.g. above 50 MW_{th}). Hence, it is difficult to get a single source with all the necessary information required for the simulation of the CLC based HAT power cycle. The simulation data used in this study were obtained from two different sources, [24] and [9]. The oxygen carrier used in this study; however is NiO/NiAl₂O₄ as against NiO with yttrium stabilized zirconium (NiO/YSZ) used by both [24] and [9].

2.2 Simulation of CLC in Aspen Plus[®]

The circulating fluidized bed (CFB) reactor is simulated in this paper as a combination of simple RGIBBS and RSTOIC reactor models in Aspen Plus[®] because most commercial tools do not yet offer a possibility for treatment of gas-solid reactions as needed for CLC (i.e. CFB). This approach is similar to that adopted by [4] for simulating syngas chemical looping process for production of electricity, hydrogen and CO₂ capture [4].

2.2.1 Assumptions

- The simulation considers that the CFB is divided into two regions; (a) a dense lower region, and (b) a more dilute upper region (Figure 2(a))
- **Equilibrium based thermodynamic reactions** are assumed in the dense region. Products discharged from the reactors are **based on minimization of Gibbs free energy principle**, hence the use of RGIBBS module in Aspen Plus[®].
- The dilute region is assumed to be in a completely well mixed condition. A stoichiometric reactor module RSTOIC is used.
- The hydrodynamic parameters of the bed and physical properties of the components are considered to be constant throughout the bed.
- **The oxidation reaction temperature within the catalytic bed is assumed constant by continuously removing heat at a rate proportional to the temperature difference.**
- The reduction (endothermic) depends on the exothermic heat energy from the oxidizer to operate.

There are different types of fuels that can be used as feedstock for the CLC operation. This study considers natural gas as feedstock (with 100% CH₄ assumption). The CH₄ in the reducer was converted to CO₂ and H₂O using NiO as oxygen carrier. The NiO is reduced to Ni. NiAl₂O₄ plays the role of keeping the mechanical strength of the particle [26]. The reactions considered in this simulation are summarized in Table 2.

Table 2 Reactions considered in the simulation [27]

Reaction	Reactor
$\text{CH}_4 + 2\text{NiO} \rightleftharpoons \text{CO}_2 + 2\text{H}_2 + 2\text{Ni}$ (3)	Reducer
$\text{CH}_4 + \text{NiO} \rightleftharpoons \text{CO} + 2\text{H}_2 + \text{Ni}$ (4)	Reducer
$\text{CO} + \text{NiO} \rightleftharpoons \text{CO}_2 + \text{Ni}$ (5)	Reducer
$\text{H}_2 + \text{NiO} \rightleftharpoons \text{H}_2\text{O} + \text{Ni}$ (6)	Reducer
$4\text{Ni} + 2\text{O}_2 \rightleftharpoons 4\text{NiO} + \text{Heat}$ (7)	Oxidizer




Figure 2: Typical structure of fluidized bed reactor

2.2.2 Operating Conditions of the CLC Reactors

The operating parameters and components (mainly reactants) of the CLC reactors are given in Table 3. Figure 3 is the flowsheet in Aspen plus[®] of the dual CFB for the CLC system. When the reducer is operated at 700 °C, the CLC simulation results are presented in Table 4. The results show that with NiO-based carrier particle, a conversion of CH₄ of over 99% can be achieved in the reducer.

Table 3: Input streams of the CLC Reactors

Oxidizer		Air		Oxygen Carrier	
Species	O ₂	N ₂	Ni	NiAl ₂ O ₄	
Flow Rates (kg/s)	49.8		37.05		
Concentration	21 vol%	79 vol%	40wt%	60wt%	
Temperature (°C)	530		530		
Pressure (bar)	20	20	20		
Reducer		Fuel	Oxygen Carrier		
Species	CH ₄	NiO	NiAl ₂ O ₄		
Flow Rates (kg/s)	1.0	32.6			
Mass Fraction	100wt%	45.9wt%	54.1wt%		
Temperature (°C)	700	1200			
Pressure (bar)	20	20			




Figure 3: Simulation of dual CFB for CLC system in Aspen plus®

Table 4 Simulation Results with the inputs in Table 3

Oxidizer (exhaust)			
Components	Mass flow (kg/s)	vol% (gas)	wt.% (solids)
N ₂	38.32	99.87	-
O ₂	0.023	0.13	-
Ni	1.49	-	4.58
NiO	11.33	-	34.81
NiAl ₂ O ₄	19.73	-	60.61
Reducer (exhaust)			
Components	Mass flow (kg/s)	vol % (gas)	wt.% (solids)
CH ₄	0.0004	0.01	-
CO ₂	2.0728	90.97	-
CO	0.0288	2.19	-
H ₂	0.0063	6.83	-
Ni	15.83	-	42.73
NiO	1.49	-	4.02
NiAl ₂ O ₄	19.73	-	53.25

2.3 Validation of the CLC Simulation

The works of [24] and [9] do not include analysis of the thermodynamic gas yield and conversions of the gas and solid species in the CLC reactors. The thermodynamic gas yield and, H₂ and CO concentrations for the CH₄ over the Ni/NiAl₂O₄ was validated from the experimental results of [29]. This is necessary to analyse and mitigate the thermodynamic limitation of NiO to convert all the CH₄ to CO₂ and H₂O at different operating temperatures. The CH₄ conversion and CO₂ yield from the reducer are evaluated from the simulation results thus;

$$\gamma_{CO_2} = \frac{x_{CO_2}}{x_{CH_4} + x_{CO_2} + x_{CO}} \quad (3)$$

$$(1 - X_{CH_4}) = \frac{x_{CH_4}}{x_{CH_4} + x_{CO_2} + x_{CO}} \quad (4)$$

γ_{CO_2} = Yield of CO₂, x_i = volume fraction of species i, and $(1 - X_{CH_4})$ = conversion of CH₄. The CH₄ conversion and CO₂ yield from the reducer were estimated from equation (3) and (4) as 98.93% and 96.23% respectively. The results in Table 5 show reasonable agreement with experimental results presented in [29]. A further analysis of the CLC system is explained in Section 2.4.

Table 5: Results to validate CLC simulation in Aspen Plus

Temperature (°C)	Parameter	Experimental [29]	Simulation	Relative Error (%)
700	CO ₂ yield (%)	97.88	96.23	1.69
	CO concentration (vol %)	2.0	2.19	9.5
	H ₂ concentration (vol %)	6.2	6.83	10.16
800	CO ₂ yield (vol %)	96.68	94.92	1.82
	CO concentration (vol %)	3.1	3.41	10.0
	H ₂ concentration (vol %)	6.6	7.22	9.39
900	CO ₂ yield (vol %)	95.16	91.46	3.89
	CO concentration (vol %)	4.5	4.87	8.22
	H ₂ concentration (vol %)	7.0	7.61	8.71
1000	CO ₂ yield (vol %)	93.43	89.87	3.81
	CO concentration (vol %)	6.1	6.49	6.39
	H ₂ concentration (vol %)	7.4	8.12	9.72
1100	CO ₂ yield (vol %)	91.46	88.49	3.25
	CO concentration (vol %)	7.9	8.72	10.38
	H ₂ concentration (vol %)	7.8	8.51	9.10
1200	CO ₂ yield (vol %)	89.40	87.23	2.43
	CO concentration (vol %)	9.7	10.26	5.77
	H ₂ concentration (vol %)	8.2	9.03	10.12

2.4 Process Analysis for the CLC System

2.4.1 Effect of fuel flow on oxidizer and reducer outlet temperature

Figure 4 shows the effect of fuel flowrate (kg/s) on the outlet temperatures of the oxidizer and reducer. Due to the reactions in the reducer being endothermic, increasing the flow rate of the fuel (CH₄) decreases the reactor temperature (Figure 4). This increase in fuel flow in the reducer aids the conversion of NiO to Ni, and increases the availability of Ni for the oxidation reaction in the oxidizer. This increases the rate of oxidation (exothermic) reaction and thus the temperature in the oxidizer. Increasing the fuel flow rate above the stoichiometric amount has no effect on the production of Ni metal. Therefore, after reaching the maximum value (approximately 1200°C), further increase in fuel flow has no impact on the oxidation reactor temperature.




Figure 4: Effect of Fuel flow on Temperature change

2.4.2 Effect of Humid Air/Fuel Ratio on Gas product yield

The effect of the humid air/fuel molar ratio on the product distribution in the fuel reactor was considered in this case study. Figure 5 shows the gas products CO₂, H₂ and CO concentrations at the reducer outlet. It is observed that increasing the humid air/fuel ratio between 0.8 – 1.2 and reactor temperature of 900°C has effect on the amount of CO and H₂ that are produced alongside the main product, CO₂ (obtained after H₂O condensation). Increasing the air/fuel ratio leads to an increase in CO₂ concentration. However, H₂ and CO reduces as the air/fuel ratio increases; thereby leading to the production of more CO₂ and H₂O vapour which is condensed to obtain a dry gas composition (Figure 5). A humid air/fuel ratio of 1.1 was used in the simulation of the CLC-HAT cycle power plant. **The trends are consistent with the results reported by Kolbitsch et al [18].**




Figure 5: Effect of Humid Air/Fuel Ratio on the Gas Product Distribution

2.4.3 Effect of fuel reactor temperature on gas composition

The temperature is an important parameter in the successful operation of the CLC system. The fuel reactor temperature can be varied at a given air/fuel ratio to investigate the response of CH₄ and CO composition in the reactor. The fuel reactor temperature is varied between 800°C and 1000°C. It was observed that CO concentration decreases rapidly with increasing temperature. CH₄ concentration also decreases slightly at increasing temperature. However, it is observed (Figure 6) that beyond 900°C the change in CH₄ concentration is insignificant or fairly constant. This is probably due to weakening of the reactivity of the oxygen carrier particle at a higher temperature.




Figure 6: Effect of fuel reactor inlet temperature on gas composition

The results show reasonable accuracy with the results reported by Kolbitsch et al [18]. Hence, operating the CLC reactors at appropriate temperature (i.e. 850°C) is essential to improving its rate of reaction and also maintains the carrier particle reactivity.

2.4.4 Effect of fuel flow on Ni solid Product

The effect of the fuel flow rate on the solids product is shown in Figure 7. Increasing the fuel flow rate in the reducer, results in a corresponding increase in the flow rate of Ni to be used in the oxidation reaction. However, Figure 7 shows that NiO conversion in the fuel reactor is limited by the stoichiometric fuel flow (1 kg/s) available for reduction process. Increasing the flow rate of the fuel after this point does not influence the NiO conversion.




Figure 7: Effect of fuel flow rate on Solids Ni Production

2.4.5 Effect of reducer inlet temperature on gas product yield

Increasing the reducer inlet temperature leads to an increase in the fraction of the CO and H₂, and reduction in the yield of CO₂ in the fuel reactor outlet. It is clear from Figure 8 that the NiO/Ni carrier particle can convert as much as 99% of the available CH₄ to CO₂ below 900°C. However, less CH₄ is converted to CO₂ at higher temperatures (e.g. 87.3% at 1200°C). Hence, the fuel reactor temperature is operated at a desirable value within 500°C - 850°C. The simulation results agree reasonably well (within 10 % relative error) with the experimental results reported in Mattisson et al [29].




Figure 8: Effect of reducer Temperature on product yield (in comparison with experimental study by Mattisson et al [29])

3 Simulation of the HAT Cycles

3.1 Simulation of Conventional HAT Cycle in Aspen Plus®

The conventional HAT cycle is an improvement to the combined cycles for its high thermal efficiency. In this cycle, air is compressed in a multistage compressor and intercooled with water, it is then admitted into the saturator where hot water is allowed to evaporate and mix with air. The humidified air is then pre-heated in the recuperator by the exhaust gas from the turbine before it is sent into the combustion unit. The heat recovery is completed with the economizer used to heat water, using the hot exhaust gas from the turbine before being purged in the stack stream [30].




Figure 9: The Conventional HAT cycle flowsheet (Adapted from [30])

The conventional HAT process simulation is largely based on the parameters from the final reports on advanced fossil fuel power system comparative study by NETL [31]. The HAT cycle power plant used in this study is a simplified model as shown in Figure 9 [30]. The Aspen plus[®] simulation of the plant is shown in Figure 10. Air is compressed in a multistage compressor with inbuilt intercooler before it enters into the saturator (SEP) where hot water is allowed to evaporate and mix with the air. The humidified air is pre-heated in the recuperator (HEATX) by the exhaust gas from the turbine (EXPANDER) before it is sent into the combustor (RGIBBS), where the fuel reacts with the humidified air to produce the combustion products (i.e. CO, CO₂, H₂O, NO_x, N₂ etc.). The heat recovery is completed with the economizer (HEATX) used to heat water, using the hot exhaust gas from the turbine before being purged. This approach results in elimination of the HRSG/steam cycle of the NGCC and replaces it with the heat exchangers.




Figure 10: Simulation of conventional HAT Cycle in Aspen Plus[®]

3.2 Simulation of CLC-HAT Power Cycle in Aspen Plus[®]

The process flow diagram of the CLC-HAT process is shown in Figure 11. In this process, methane (CH₄) at 25°C and 20 bar is pre-heated by the exhaust gas from gas turbine, GT-2 to increase its temperature to 530°C at 19 bar before it is then admitted into the reducer.

In the reducer, NiO particles are passed by gravity (through the top) into the reducer from the oxidizer. NiO is reduced by the endothermic reaction of CH₄ and NiO to produce Ni, CO₂, and H₂O vapour. The Ni produced serves as the feed into the oxidizer. The product gas discharged from the reducer (stream G-RED) is mainly CO₂ and H₂O vapour. This exhaust gas is used to drive the gas turbine, GT-2 to generate electricity. It is subsequently cooled by releasing heat to

methane (CH₄ stream) and process water. CO₂ and water vapour is condensed, CO₂ at 70°C and 1.1 bar is captured, compressed to a pressure of 150 bar for sequestration.

Furthermore, air at 25°C and 1 bar is compressed in a multistage compressor with intercoolers (COMPR-1) to 20 bar. The compressors are cooled by process water, leading to a temperature increase of 186°C, required in the saturator. The compressed air is saturated with the heated water to produce a humidified air at 142°C and 19 bar (with H₂O vapour as a 25 wt. % fraction). The humidified air is then further heated to a temperature of 530°C by the exhaust gas from GT-1 before it enters into the oxidation reactor.

In the oxidizer, Ni is sent from the reducer to be oxidized by the humidified air to form NiO. The oxidation reaction is exothermic, producing an exhaust gas stream (G-OX) at 1200°C which is passed into turbine GT-1 to generate electricity, pre-heat the humidified air in the HEX-3, and further cooled in HEX-4 and HEX-5 by releasing heat to the process water. The H₂O vapour is then condensed in condenser (GT1-COND) and recovered for re-use. The exhaust gas stream mainly N₂ and water vapour is also condensed in GT2-COND.




Figure 11: Simulation of CLC-HAT Power Cycle in Aspen Plus®

3.3 Comparison of the CLC-HAT Cycle Simulation

The model for the conventional HAT and the CLC-HAT cycles were compared using the simulation results from [9]. The simulation results were compared with this reference case (50 MW_{th} Plant) as shown in Table 5 based on key process performance variables. An inspection of the results presented in Table 5 shows that the model is a good representation of the reference case. Thermal Efficiency of the power plant is computed as follows and compared with the reference case.

Thermal Efficiency (neglecting pump work)

$$\eta_{th} = \frac{P_{GT} - W_{comp}}{Q_{fuel}} \quad (5)$$

$$Q_{fuel} = \text{fuel burn rate} \left(\frac{\text{kg}}{\text{s}}\right) \times \text{NCV} \left(\frac{\text{MJ}}{\text{kg}}\right) \quad (6)$$

Where P_{GT} = Gas turbine power output from GT-1 and GT-2
 Q_{fuel} = Chemical energy of fuel (CH_4) = 50 MW_{th} (LHV)
 W_{comp} = compressor work
 NCV = net calorific value

The Energy penalty (fractional reduction in power output per unit of fuel), expressed in fractions or percentage and Efficiency penalty (absolute difference between the two process, expressed in % point) as a result of the CO_2 capture and compression is evaluated as shown in equations (7) and (8) [32] and compared with the reference case. In general, the validation results (Table 5) show that the simulation gives a good prediction of the performance of the CLC-HAT cycle when compared to that obtained by [9].

$$\text{Efficiency Penalty} = \eta_{conv} - \eta_{ccs} \text{ (\% point)} \dots (7)$$

$$\text{Energy Penalty} = \frac{\eta_{conv} - \eta_{ccs}}{\eta_{conv}} \dots \dots \dots (8)$$

η_{conv} = efficiency of the HAT cycle, η_{ccs} = efficiency of the CLC-HAT cycle

The results in **Table 6** show that the energy penalty and the efficiency penalty of incorporating a CLC CO_2 capture into the system only led to a small parasitic loss of about 3% and 2% respectively. This is a very low penalty level compared to other CO_2 capture approaches.

Table 6 Comparison of Simulation Results of HAT cycle and the CLC-HAT cycle

Parameters	Reference Case [9]	Conventional HAT	CLC-HAT
Gas Turbine (MW_{th})	50.0	43.64	49.02
Compressor Work (MW_{th})	22.0	14.14	20.47
Net Power (MW_{th})	28.0	29.50	28.55
Net Plant Efficiency (%LHV)	55.9	59.0	57.1
Energy penalty	3.62	-	3.39
Efficiency penalty (%)	2.1	-	1.9

3.4 Process Analysis of the CLC-HAT cycle

The Aspen plus model was employed to investigate the effect of some key process parameters on the power produced and overall thermal efficiency. The parameters include oxidation (air reactor) and reduction (fuel reactor) inlet and outlet temperatures, mass ratio of humid air to the oxygen carrier (Air/Ni-NiAl₂O₄ in kg/kg) in the oxidizer, and turbines GT-1 and GT-2 inlet temperatures. Four different cases were considered at varying conditions for the identified process parameters.

3.4.1 Effects of Fuel Inlet Temperature on Thermal Efficiency

At the given fuel flow and outlet conditions, reducing the fuel inlet temperature means more of the heat from the fuel pre-heat exchanger (HEX-1 in Figure 11) can be available to the air pre-heat exchanger, thereby increasing the inlet temperature of the oxidizer. In terms of mass flows, the amount of fuel intake in the process is much lower than the air flow requirement in the system. Consequently, little effect is observed on the overall plant efficiency, for example in Figure 12, an efficiency increase of 0.2% is observed over a temperature range of (250-600°C). Hence, maximum temperature allowable by ΔT_{\min} required in the heat exchanger HEX-1 was used in the simulation to avoid temperature crossing (which indicates a negative driving force for heat transfer between the hot and cold fluids) due to the hot stream outlet temperature lower than the desired cold stream outlet temperature in a counter-current flow arrangement. The trends are consistent with the results reported by Brandvoll and Bolland [9].




Figure 12: Effect of Fuel Inlet Temperature

3.4.2 Effects of Inlet & Outlet Temperature of Oxidizer on Efficiency

Assuming constant fuel input, increasing the humid-air temperature at oxidizer inlet influences the power output of the gas turbine GT-1. An increase in the overall efficiency is observed due to a relatively larger increment in the gas turbine output as the oxidizer inlet temperature is increased. The impact of the oxidizer inlet temperature on efficiency is more significant than the fuel reactor inlet temperature – about 7% over the temperature range 400°C – 600°C. The temperature is set as high as possible limited by the (ΔT_{\min}) minimum temperature difference required in the preheat exchanger HEX-3.




Figure 13: Effect of (a) oxidizer inlet temperature (b) oxidizer outlet temperature on efficiency

From Figure 13 (b), increasing the oxidizer outlet temperature, instantly results in a proportional increase in the power output from GT-1 and the thermal efficiency. The turbine GT-1 outlet temperature also increases and more energy is available for air preheating in HEX-3. These results are consistent with the results reported by Brandvoll and Bolland [9] as shown in Figure 13(a) and Figure 13(b).

3.4.3 Effect of Humid Air and Ni Flow rate on Overall Thermal Efficiency

Figure 14 (a) shows the effect of humid air mass flow rate on the thermal efficiency of the CLC-HAT cycle. In this present study, 35.6 kg/s of incoming Ni are completely oxidized by 49.8 kg/s of the air. Based on the stoichiometry of the reaction (reaction 7 in Table 2), the air to incoming Ni mass ratio is 1.4. At this point, the oxidation reaction temperature is at maximum value (about 1200°C, Figure 15). The thermal efficiency of the plant increases with an increase in the air flow rate due to increase in high temperature working fluid (mainly N₂) at the exit of the oxidation reactor for the gas turbine GT-1. Further increase in air flow rate beyond the stoichiometric amount, the thermal efficiency begins to decrease (Figure 14(a)). This is due to significant drop in the turbine GT-1 inlet temperature at higher air flow rate.




Figure 14: Effect of (a) Humid air flow rate

(b) oxygen carrier on Efficiency

Figure 14(b) shows the effect of oxygen carrier (Ni) mass flow rate on the thermal efficiency of the plant. The result shows that the thermal efficiency of the CLC-HAT cycle increases with an increase in the oxygen carrier mass flow rate due to the increase rate of reactions in the reactor and exothermic heat. However, the increase is only up to the stoichiometric amount of Ni required in the reactor. Further increase in the Ni mass flow has no significant impact on the efficiency (Figure 14(b)). Though, more Ni can still be oxidized by the presence of excess air, this reaction is however limited by the reduction process and its ability to reduce the NiO to Ni.

3.4.4 Effect of Air/Oxygen Carrier Ratio on Efficiency and Oxidizer outlet Temperature

The ratio of air to Ni in the oxidizer affects the oxidizer outlet temperature and the overall thermal efficiency of the plant. As described separately in cases 3(a) and 3(b), increasing the air flow and the oxygen carrier flow rate independently influences the efficiency of the plant (Figure 3). Increase in the air/Ni mass ratio results in corresponding increase in the thermal efficiency and the oxidizer outlet temperature (Figure 15), up until the stoichiometric amount. Further increase beyond this point results in no significant change in the temperature and the overall thermal efficiency of the plant.




Figure 15: Effect of Air/Ni ratio on Temperature and Efficiency

4 Economic analysis of Conventional and CLC-HAT Cycles

The main aim of embarking on the CLC-HAT Power generation system is to comply with growing demands for CO₂ emission reduction to safeguard the environment from the threat of greenhouse gases and climate change; as well as generate electricity at a high efficiency, as well as reasonably low cost. This section presents economic analysis of CLC power generation system, with CO₂ capture and compression.

It is not intended to obtain absolute power generation costs from this evaluation as the results of this work may not accurately reflect the final cost of constructing the plants, but it is a useful method for establishing economic viability of a process and comparing competing processes and for identifying possible bottlenecks.

The following assumptions were used to develop the economic model in the Aspen Economic Analyser[®]:

- The proposed plant location for both cases is the United Kingdom (UK)
- The plant is designed to have the capacity to process 1.0 kg/s (50MW_{th}) of fuel.
- 8000 working hours per year was used.
- All the cost estimations are carried out in British pounds (£).
- The lifetime of the power plants were set at 30 years.

Table 7 shows the costs of the raw materials and utilities associated with the power cycles. The raw material prices are the general market prices as at June 2011. The amounts of oxygen carriers used were not calculated based on an hourly basis since they are either fixed in the reactors or recycled, and hence it is assumed that the catalysts are changed based on their average lifetimes [4]. Equipment sizes are estimated based on the Aspen Plus[®] simulations.

Table 7: Basic Parameters for economic analysis [33]

Item	Specification	Price/unit
<i>Raw materials</i>		
Methane		2p/kWh
Nickel oxide		11.01 (£/kg)
Process water		£0.37/m. tonne
<i>Utilities</i>		
Cooling water	1 bar, 25°C	£0.0012/L
Electricity		£0.0775/kWh
Plant type	Grass roots/clear field	
Depreciation model	5% per period	
Taxes	20% per period	
Rate of return	15% per period	
General & Administrative (G&A) expenses	8% per period	

Table 8: Aspen Icarus[®] Estimate of Process Equipment Cost

ITEM		HAT (£)	CLC-HAT (£)
Plant capacity	(MW _{th})	50	50
Heaters/Heat HEXs	(total)	141,200	152,500
Pumps	(total)	30,700	85,100
Reactor 1	(Oxidizer)	-	142,700
Reactor 2	(Reducer)	-	142,700
Saturator (sep)		59,600	59,600
Compressors		2,332,000	11,467,300
Gas Turbines	(total)	8,724,800	12,312,000
Combustor		191,100	-
Total equipment cost		11,479,400	24,361,900
Total direct cost		12,687,300	26,785,600
Fixed capital cost		25,377,700	45,211,800
Working capital		1,332,330	2,260,590
Start up and validation cost		2,537,770	4,521,180
Total capital investment		29,271,400	51,999,270

The two HAT power cycles were evaluated based on the total capital investment, total manufacturing costs, pay-out period, profitability, internal rate of return and the net present value. A breakdown of the cost of the process equipment for the two options and their associated costs is presented in Table 8. The total operating costs for the conventional and CLC-HAT cycles are presented in Table 10.

The profitability index (PI) shows the relative profitability of any project. For each period, this number is computed by dividing the Present Value of the Cumulative Cash Inflows by the Present Value of the Cumulative Cash Outflows. If the profitability index is greater than one, then the project appears to be profitable. If this index is less than one, then the project appears not to be profitable. If this number equals zero then the project incurs no losses or gains (break-even point) [33]. It shows the present value of the benefits relative to the present value of the costs. Table 8 shows the PI of the conventional HAT and CLC-HAT power plant. It can be seen that for every £1 invested in this technology, the total value created by the CLC-HAT cycle is £1.6 as against £1.42 for the conventional cycle.

Mathematically,

$$\text{Profitability Index (PI)} = \frac{\text{Net Present Value (NPV) of future cash flow}}{\text{Initial Investment required}}$$

4.1 Economic Indicators for the Conventional and CLC-HAT cycles

Table 10 is a summary of the important economic indicators showing the feasibility of the CLC-HAT technology in comparison to the conventional HAT approach. From the table, it can be seen that the two HAT cycle processes have total capital requirement of power generation of £584/kW_{th} and £1040/kW_{th} with the conventional HAT cycle having the lower value. Nevertheless, the CO₂ emitted in the conventional cycle when quantified and charged at appropriate tax rate (£30 /t CO₂ as presented in **Table 9**) makes the CLC-HAT cycle a more viable option over the life cycle of the plants. **The uncertainties in the tax rate due to government policies [34] also means that the cost of operating the conventional plant will increase if the government implements its plan to increase the carbon tax in order to meet the carbon emission reduction target (CERT) of reducing emission to 80% below the 1990 level by 2050 [35]. In the present analysis, an average value of £30/t CO₂ emitted (which covers the rate between Jan 2006 to Jan 2013 [34]) was used to estimate the annual CO₂ emission tax for the conventional HAT cycle.**

Table 9: Estimation of CO₂ emission Tax for the Conventional HAT Cycle

Parameters	Conventional HAT Cycle
Plant generation capacity (MW _{th})	29.50
Carbon Price (£/tCO ₂)	30.00
CO ₂ emission (kg/MW-hr)	394.77
CO₂ Emission cost (£/yr.)	3,018,569.33
Plant Operating Cost (£/yr.)	4,915,990.00
Total Operating Cost (£/yr.)*	7,934,559.33

*including annual cost of CO₂ emission tax

Table 10 Economic indicators for the Conventional HAT and CLC-HAT cycles

	HAT	CLC-HAT
Plant generation capacity (MW _{th})	29.50	28.55
Total capital investment (£)	29,271,400	51,999,270
Raw material cost (£/yr.)	8,000,000	11,062,634
Total operating cost (£/yr.)	7,934,559.33	9,104,170.00
Payback period (years)	7.03	6.14
Profitability Index (PI)	1.42	1.60
Net Present Value (NPV) (£)	94,162,100	104,240,000
Internal Rate of Return (IRR) (%)	26.83	37.87
Capital Requirement (£/kW)	584.43	1039.99

5 Conclusions

The CLC system with HAT principle shows an efficiency of 57% at oxidizing temperature of 1200°C and reducer inlet temperature of 530°C, and a very low penalty point when compared with other CCS options integrated into the power cycles. The sensitivity analysis showed that the overall efficiency of the plant is greatly influenced by the air inlet temperature to the oxidation reactor and its exhaust temperature. The thermal efficiency penalty and thermal energy penalty were found to be very low at a value of 2.0% point and 3.4 % point respectively.

The economic evaluation performed shows that the 50 MW_{th} plant with a projected lifetime of 30 years will have a payback period of 7 and 6 years, a net present value of **£94.2** million and **£104.2** million, and a total capital investment of £29.2 million and £52 million for conventional HAT and CLC-HAT cycles respectively. The profitability index of 1.6 for the CLC as against 1.3 for conventional HAT also affirms the long term superiority of the CLC-HAT cycle in combating CO₂ emission over conventional combustion.

Acknowledgement

This work is financially supported by the Petroleum Technology Development Fund (PTDF), Nigeria.

REFERENCES

- [1]. IEA Greenhouse Gas R&D Programme (IEA GHG), 2002a: Building the Cost Curves for CO₂ Storage, Part 1: Sources of CO₂, Program report no. PH4/9, July, pp. 48.
- [2]. Freund, P, 2003. Making deep reductions in CO₂ emissions from coal-fired power plant using capture and storage of CO₂, *Proceedings of Institution of Mechanical Engineers Part A: Journal of Power and Energy*, pp. 217, 1–8.
- [3]. Wang M, Lawal A, Stephenson P, Sidders J and Ramshaw C. (2011), Post-combustion CO₂ capture with chemical absorption: A state-of-the-art review, *Chemical Engineering Research and Design*, vol. 89, pp.1609–1624.
- [4]. Fan, L-S. (2010), *Chemical Looping Systems for Fossil Energy Conversions*, John Wiley and Sons, New Jersey, USA.
- [5]. Intergovernmental panel on climate change (IPCC). (2005), *IPCC Special Report on Carbon Dioxide Capture and Storage*, Cambridge University Press, Cambridge, United Kingdom and New York, USA.
- [6]. Figueroa, J.D., Fout, T., Plasynski, S., McIlvried, H., Srivastava, R.D. (2008), Advances in CO₂ capture technology—The U.S. Department of Energy’s Carbon Sequestration Program, *International Journal of Greenhouse Gas Control*, vol. 2, pp. 9-20
- [7]. Lu, Y., S. Chen, M., Rostam-Abadi, R., Varagani, F., Chatel-Pelage, and A.C., Bose, Techno-Economic Study of the Oxy-Combustion Process for CO₂ Capture from Coal-fired Power Plants, Paper presented at the Annual International Pittsburgh Coal Conference (2005).
- [8]. Jin H., Okamoto T., Ishida M. (1999), Development of a novel chemical-looping combustion: Synthesis of a Solid looping material NiO/NiAl₂O₄, *Industrial and Engineering Chemistry Research*, vol. 38, pp. 126-132.
- [9]. Brandvoll, O. and Bolland, O. (2004), Inherent CO₂ Capture using Chemical Looping Combustion in a Natural Gas Fired Power Cycle, *ASME Journal for Engineering for Gas Turbines and Power*, vol. 126, no. 2002-GT-30129, pp. 316-321.
- [10]. Johansson, E., Mattisson, T., Lyngfelt, A. and Thunman, H. (2006), Combustion of Syngas and Natural Gas in a 300 W Chemical-Looping Combustor, *Chemical Engineering Research and Design*, vol. 84, no. A9, pp. 819-827.
- [11]. Jerndal, E., Mattisson, T. and Lyngfelt, A. (2006), "Thermal Analysis of Chemical-Looping Combustion", *Chemical Engineering Research and Design*, vol. 84, no. A9, pp. 795-806.
- [12]. Abad, A., Mattison, T., Lyngfelt, A. and Johansson, M. (2007), The use of Iron Oxide as Oxygen Carrier in a Chemical Looping Reactor, *Fuel*, vol. 86, pp. 1021-1035.
- [13]. Zhao, H., Liu, L., Wang, B., Xu, D., Jiang, L. and Zheng, C. (2008), Sol-Gel-Derived NiO/NiAl₂O₄ Oxygen Carriers for Chemical-Looping Combustion by Coal Char, *Energy and Fuels*, vol. 22, pp. 898-905.
- [14]. Abad, A., Adanez, J., Cuadrat, A., Garcia-Labiano, F., Gayan, P. and de Diego, L. F. (2011), Kinetics of Redox Reactions of Ilmenite for Chemical-Looping Combustion, *Chemical Engineering Science*, vol. 66, pp. 689-702.
- [15]. Mendiara, T., Garcia-Labiano, F., Gayan, P., Abad, A., de Diego, L.F., Adanez, J. (2013). Evaluation of the use of different coals in Chemical Looping Combustion using a bauxite waste as oxygen-carrier. *Fuel*, vol.106, pp. 57-69.

- [16]. Mattisson, T., Jerndal, E., Linderholm, C., Lyngfelt, A., (2011). Reactivity of a spray-dried NiO/NiAl₂O₄ oxygen carrier for chemical-looping combustion. *Chemical Engineering Science*, vol. 66(20), pp. 4636-4644.
- [17]. Lyngfelt, A., Leckner, B. and Mattisson, T. (2001). A Fluidized-Bed Combustion Process with Inherent CO₂ Separation; Application of Chemical-Looping Combustion. *Chemical Engineering Science*, vol. 56, pp. 3101-3113.
- [18]. Kolbitsch, P., Proll, T. and Hofbauer, H. (2009). Modelling of a 120 kW Chemical looping Combustion Reactor System Using Ni-Based Oxygen Carrier, *Chemical Engineering Science*, vol. 64, pp. 99-108.
- [19]. Marx, K., Bolhar-Nordenkamp, J., Proll, T., Hofbauer, H. (2011). Chemical looping combustion for power generation-Concept study for a 10 MW_{th} demonstration plant. *International Journal of Greenhouse Gas Control*, vol. 5(5), pp. 1199-1205.
- [20]. Cuadrat, A., Abad, A., Gayan, P., de Diego, L., Garcia-Labiano, F, Adanez, J. (2012). Theoretical approach to CLC performance with solid Fuels: optimizing the solids inventory. *Fuel*, vol.97, pp.536-551.
- [21]. Anheden M., Näsholm A. S., Svedberg G., (1995). Chemical-looping combustion – Efficient conversion of chemical energy in fuels into work, *Intersociety Energy Conversion Engineering Conference*, vol. 30, pp. 75-81
- [22]. Wolf J., Anheden M., Yan J., (2001). Performance of Power Generation Processes with Chemical Looping Combustion for CO₂ Removal – Requirements for the Oxidation and Reduction Reactors, *Proceedings of International Pittsburgh Coal Conference*, Newcastle, New South Wales, Australia.
- [23]. Naqvi R., Bolland O., Brandvoll O., Helle K., 2004, Chemical Looping Combustion, Analysis of natural gas fired power cycle with inherent CO₂ capture, *Proceedings of ASME Turbo Expo 2004*, GT2004-53359, pp. 14-17 June, Vienna, Austria.
- [24]. Ishida, M. and Jin, H. (1994), A New Advanced Power-Generation System using Chemical-Looping Combustion, *Energy*, vol. 19, no. 4, pp. 415-422.
- [25]. Gallo, W. L. R. (1997), A Comparison between the Hat Cycle and other Gas-Turbine Based Cycles: Efficiency, Specific Power and Water Consumption, *Energy Conversion and Management*, vol. 38, no. 15-17, pp. 1595-1604.
- [26]. Ishida, M., Yamamoto, M. and Ohba, T. (2002), Experimental Results of Chemical-Looping Combustion with NiO/NiAl₂O₄ Particle Circulation at 1200°C, *Energy Conversion and Management*, vol. 43, pp. 1469-1478.
- [27]. Iluita, I., Tahoces, R., Patience, G.S.,(2010) Chemical Looping Combustion Process: Kinetics and Mathematical Modelling, American Institute of Chemical Engineers, *AIChE Journal*, Vol 56, No. 4, pp 1063-1079.
- [28]. Gharebaagh R.S., Legros R., Chaouki J., Paris J. (1998), Simulation of circulating fluidized bed reactors using Aspen Plus, *Fuel*, vol. 77, pp. 327-337.
- [29]. Mattisson, T., Johansson, M. and Lyngfelt, A. (2006), The Use of NiO as an Oxygen carrier in Chemical looping-Combustion, *Fuel*, vol. 85, pp. 736-747.
- [30]. Korobitsyn M.A., (1998), New and Advanced Energy Conversion Technologies: Analysis of cogeneration, combined and integrated cycles, PhD Thesis, Thermal Engineering Department, University of Twente, Netherlands.
- [31]. Parsons, E.L., Shelton, W.W., Advanced Fossil Power Systems Comparison Study, National Energy Technology Laboratory, Pittsburgh, PA.
- [32]. Maurstad, O. (2005), An Overview of Coal based Integrated Gasification Combined Cycle (IGCC) Technology, Massachusetts Institute of Technology, Laboratory for Energy and the Environment, Cambridge, MA. Publication No LFEE 2005-002 WP.

- [33]. Aspen Technology (2010b), Aspen Icarus V7.2 Reference Guide, Icarus Evaluation Engine (IEE) V7.2, Aspen Technology, Inc. Burlington, MA
- [34]. Ares, E., (2013), Carbon Price Floor: House of Commons Library Standard Note, Energy and Environment Section. House of Commons Library, SN05927 pp. 1-10. <<http://www.parliament.uk/briefing-papers/SN05927/carbon-price-floor>>.
- [35]. Watson, C., Bolton, P. (2013), Carbon Emission Reduction Target (CERT): House of Commons Library Standard Note, Science and Environment, Social and General Statistics Section. House of Commons Library, SN/SC/06196 pp. 1-9. <<http://www.parliament.uk/briefing-papers/SN06196/carbon-emissions-reduction-target-cert>>