



Amankwah, Emmanuel and Costabeber, Alessandro and Jasim, Omar and Trainer, David and Clare, Jon C. (2017) ESBC: an enhanced modular multilevel converter with H-bridge front end. In: 2017 IEEE Energy Conversion Congress and Exposition (ECCE), 1-5 October 2017, Cincinnati, Ohio, USA.

Access from the University of Nottingham repository:

<http://eprints.nottingham.ac.uk/51078/1/ESBC%20An%20enhanced%20modular%20multilevel%20converter%20with%20H-bridge%20front%20end.pdf>

Copyright and reuse:

The Nottingham ePrints service makes this work by researchers of the University of Nottingham available open access under the following conditions.

This article is made available under the University of Nottingham End User licence and may be reused according to the conditions of the licence. For more details see: http://eprints.nottingham.ac.uk/end_user_agreement.pdf

A note on versions:

The version presented here may differ from the published version or from the version of record. If you wish to cite this item you are advised to consult the publisher's version. Please see the repository url above for details on accessing the published version and note that access may require a subscription.

For more information, please contact eprints@nottingham.ac.uk

ESBC: an Enhanced Modular Multilevel Converter with H-Bridge Front End

Emmanuel Amankwah
The University of
Nottingham
Nottingham, UK
emmanuel.amankwah@nottingham.ac.uk

Alessandro Costabeber
The University of
Nottingham
Nottingham, UK
alessandro.costabeber@nottingham.ac.uk

Omar Jasim
GE Energy Connections
GE
Stafford, UK
Omar.Jasim@GE.com

David Trainer
GE Energy Connections
GE
Stafford, UK
David.Trainer@GE.com

Jon Clare
The University of
Nottingham
Nottingham, UK
jon.clare@nottingham.ac.uk

Abstract—This paper presents the Enhanced Series Bridge Converter (ESBC), a hybrid modular multilevel converter with H-bridge front end suitable for high power grid applications. It retains the advantages of other modular multilevel topologies while offering compact structure, making it attractive for offshore stations, back-back HVDC stations, and city centre infeeds. The structure, operating principles and energy management of the converter are discussed. Simulation results from a scaled down medium voltage demonstrator are presented to validate the concept.

Keywords—Modular Multilevel Converters, HVDC Transmission, Offshore, H-bridge.

I. INTRODUCTION

Modular Multilevel Voltage Source Converters (MM-VSCs) have the inherent advantage of generating high quality voltage and current waveforms. These converters are also scalable making them more attractive for high voltage/power grid applications such as HVDC and FACTS. The efficiencies of HVDC installations using the MM-VSCs are comparable to that of more established HVDC technologies based on Line Commutated Converters (LCC) [1-4]. In recent times, many MM-VSC HVDC installations have been implemented [5-7]. However, there is significant research interest among academics and industry to develop an optimum HVDC VSC with high efficiency, high robustness to system faults and compact size while maintaining the other advantages of the modular VSC in power systems.

In [1, 8, 9] different variants of the MM-VSCs exploiting an H-bridge front end are investigated. This paper presents the Enhanced Series Bridge Converter (ESBC), which is the further development of the recently presented Series Bridge Converter (SBC) [8]. The topology is composed by the series connection on the DC side of three single phase units, each of them including a multilevel half-bridge arm (Chain-Link), two sets of multilevel full-bridge arms being deployed as series full bridge (SFB) arm and T-branch, H-bridge front end, and interface transformer. Ideally, on the DC side the three phases generate a set of phase shifted rectified sinewaves, adding to the DC voltage plus a 6n harmonics voltage ripple. The T-branch provides the harmonic filtering required to generate smooth DC

voltage at the DC terminals. In the topology in [8], the voltage filtering is embedded in CLs and SFBs, thus influencing the inter-arm energy dynamics and therefore the amount of second harmonic required for the inter-arm energy management [8]. In the ESBC, the T-branch is independent from CLs and SFBs and it does not influence the energy management. Therefore, the second harmonic voltage needed for energy management can be reduced. This reduction helps to reduce the size of the SFB arms. In this paper, the general operation of the ESBC is presented. Control algorithm and energy management concepts are discussed and simulation results from a scaled down medium voltage demonstrator are presented.

II. CONVERTER TOPOLOGY

Figure 1 shows the two basic configurations of the ESBC. In these configurations, the T-branch is introduced to extract the 6n harmonic voltages across the DC bus. In Figure 1a, the T-branch submodules are lumped together at the DC rail of the converter while in Figure 1b, the submodules are represented on a per phase basis. As can be observed from Figure 1a and Figure 1b, there is no significant difference in the performance of the T-branch during symmetrical network operating conditions, therefore in this paper all studies will be undertaken considering Figure 1a. Nevertheless, the studies and observations can easily be applied to Figure 1b with the appropriate scaling. The converter now consists of two wave shaping arms, an H-bridge front end and a T-branch arm for harmonic voltage filtering. The shunt connected arm with half-bridge submodules is named Chain-Link (CL), while the series connected arm with full-bridge submodules is called Series Full Bridges arm (SFB). The newly introduced T-branch is a full bridge arm, which is in the main DC path. The CL and SFB arms are responsible for synthesising a variable amplitude full wave rectified sinusoidal voltage on the DC input of each H-bridge, that ‘unfolds’ the waveform at the zero crossings of the voltage to generate the AC voltages across the primary side of three single phase open winding transformers as shown in Figure 1. An open winding transformer configuration is adopted to decouple the converter phase connection on the AC side. The three series connected CL units support the DC bus




Figure 1a: Lumped T-branch




Figure 1b: Distributed T- Branch

voltage while the three SFB units operate to decouple the AC network from the DC network and achieve full control of the AC side current and voltage. The configuration of the topology inherently improves the performance and size of the converter as:

- The converter consists of an optimal number of full and half bridge submodules which are less than that in the standard MMC either with half OR full bridge submodules.
- The DC current component in the half-bridge CLs is less than 20% of the rated DC current [1] and therefore the CL arms are less lossy.
- The power pulsation in the SFB arms has a fundamental frequency which is twice the line frequency and therefore the size of submodule capacitors can be reduced.
- The T-branch submodules capacitance is small as the lowest harmonic component synthesised by the branch is the 6th order.
- The use of the T-branch means that the amount of second harmonic voltage required for inter-arm energy management as discussed in [8] is reduced and therefore the size of the SFB branch is also reduced.

Therefore, the converter can be made more compact and efficient compared to other similar MM-VSCs such as the standard MMC, the AAC and similar topologies. Although the H-bridge based SFB arms and the H-bridge front ends are placed in the full current path, the number of submodules in the CL and the SFB arms can be optimally selected to achieve the required PQ operation while maintaining low conduction loss and compact size.

III. OPERATING PRINCIPLE

The operation of the ESBC can be discussed focusing on three main functions: (1) Support the DC bus voltage by the series connected CLs, (2) Formulation and “unfolding” of the full wave rectified voltages into AC voltages and currents, (3) Filtering of the resultant DC side harmonics caused by the operation of the CLs. As presented in Figure 1, the ESBC is composed of four elements in each phase: front-end H-bridge, SFB, CL and the T-branch. The H-bridge front end has the same task as in the SBC [8] of “unfolding” the full wave voltages imposed at the DC rail into AC waveforms at the converter AC terminals. The CLs synthesise full wave rectified sinusoidal voltages with a DC component matching the required DC bus voltage. The SFB branch then provides attenuation between the voltages synthesised by the CL and that required at the converter AC terminal to be able to achieve variable active power (P) and reactive power (Q) control. As shown in earlier

publications of other embodiments of the SBC, the full wave rectified operation of the CL arms of the SBC results in 6n voltage harmonics in the DC network. In the work presented in this paper, the T-branch is used to remove these harmonic components from the DC network.

In its basic form, the operation of the ESBC can be illustrated considering a balanced and stiff three phase AC network, with the impedances dominated by the leakage inductances of the transformers, and consider first an operation where the AC voltage can be matched with the CL. In this case, ideally, the SFB arms can be bypassed. In this condition, the three CLs generate three full wave rectified sinusoids displaced 120 electrical degrees. The turns ratio $r:1$ of the transformer can be selected to match the amplitude of the converter voltage and grid voltage in this ideal condition. In this example, the voltage imposed by the grid, that to be synthesised by the converter, and that synthesised by the CL can be described for phase ‘a’ in (1), where δ is the phase shift between the grid voltage and the converter voltage and a corresponding phase shift ϕ of the grid current.

$$\begin{aligned} V_{Ga}(t) &= V_G \sin(\omega t), & V_{Ca}(t) &= V_C \sin(\omega t + \delta), \\ I_a(t) &= I \sin(\omega t + \phi), & V_{INa} &= |V_{Ca}(t)|, \\ V_{SFBa}(t) &= 0, & V_{CLa}(t) &= V_{INa} \end{aligned} \quad (1)$$

Clearly, the average of the voltages in the three CLs can be shown to be (2):

$$\bar{V}_{DCC} = \sum_{x=a,b,c} \bar{V}_{CLx} = 3 \left(V_C \frac{2}{\pi} \right) = V_C \frac{6}{\pi} \rightarrow V_C = \bar{V}_{DCC} \frac{\pi}{6} \quad (2)$$

As stated earlier, in (1) and (2) the performance of the SFB arm and T-branch are not considered in the waveform formulation and therefore the amplitude of the converter AC voltages is directly related to the DC voltage and influences the selection of the turn ratio of the transformer. To decouple the peak converter voltage, V_C , from the composite DC voltage in the CLs, the SFB arms would be required to synthesise the residual voltage between the voltage required at the DC input of the H-bridge front-end, $V_{INa}(t)$ and that synthesised by the corresponding CL arm and allow for a system operation with a fixed transformer turns ratio. Consider now a more general case where the SFBs are inserted into the circuit. For a given (P, Q) operating point on the AC side, the amplitude V_C and the phase shift δ of the converter voltages can be expressed as (3).

$$\begin{aligned} V_{Ga}(t) &= V_G \sin(\omega t) \rightarrow V_C, \delta \rightarrow V_{Ca}(t) = V_C \sin(\omega t + \delta), \\ I_a(t) &= I \sin(\omega t + \phi) \end{aligned} \quad (3)$$

For a given active power P, also the DC voltage demand of the converter V_{DCC} is defined. With V_{DCC} , the amplitude of the rectified sinusoids forming the CL voltages can be derived. To limit the SFB voltage requirements, the rectified CL waveforms can be made proportional to the rectified AC voltage on the converter side. Referring to phase ‘a’:

$$V_{CL} = \frac{\pi}{6} V_{DCC} \rightarrow V_{CLa}(t) = V_{CL} |\sin(\omega t + \delta)| \quad (4)$$

The difference required to generate V_C is managed by the SFBs, guaranteeing reactive power control:

$$V_{INa} = V_C |\sin(\omega t + \delta)| \rightarrow V_{SFBa}(t) = (V_C - V_{CL}) |\sin(\omega t + \delta)| \quad (5)$$

Fourier spectrum of the individual CL voltages contains even harmonics $2n$, that will cancel in the sum across the three phases except for those harmonics that are also multiples of 3 – i.e. the DC voltage will contain $6n$ ripple components (6). In this mode of operation, the SFBs are used to control reactive power but voltage ripple will appear in the DC circuit.

$$V_{DLC} = \bar{V}_{DCC} + V_R(t)$$

$$V_R(t) = -\frac{12}{\pi} V_{CL} \sum_{n=1}^{\infty} \left(\frac{1}{(6n)^2 - 1} \cos(6n\omega t + 6n\delta) \right) \quad (6)$$

In contrast to the operation of the SBC as presented in [8], the voltage harmonics $V_R(t)$ in (6) are extracted from the DC circuit using the newly introduced T-branch in Figure 1. In summary, the CL voltage, the SFB voltage, the input voltage for the main H-bridge and the T-branch voltages that guarantees full power control and active DC filtering are:

$$V_{CLa}(t) = V_{CL} |\sin(\omega t + \delta)|$$

$$V_{SFBa}(t) = (V_C - V_{CL}) |\sin(\omega t + \delta)| = (V_C - V_{CL}) \sin(\omega t + \delta)$$

$$V_{INa}(t) = V_{CLa}(t) + V_{SFBa}(t) = V_C |\sin(\omega t + \delta)| \quad (7)$$

$$H \text{ bridge unfolding} \rightarrow V_{Ca}(t) = V_C \sin(\omega t + \delta)$$

$$V_T(t) = -V_R(t) = \frac{12}{\pi} V_{CL} \sum_{n=1}^{\infty} \left(\frac{1}{(6n)^2 - 1} \cos(6n\omega t + 6n\delta) \right)$$

The proposed methodology for voltage waveform formulation for CLs and SFBs minimises the impact of the SFBs on converter size and loss.

IV. ENERGY MANAGEMENT

In this section, the impact of the considered waveform formulation on the energy distribution of the converter arms is investigated. Referring to Figure 1, consider the scenario where $x=a$ and the rectified sinusoid V_{INa} is unfolded at the zero crossings we get:

$$I_{SFBa}(t) = I_a(t) \text{sign}(V_{Ca}(t)) \quad (8)$$

Considering again a generic operating point with $V_{Ca}(t) = V_C \sin(\omega t + \delta)$, $I_a(t) = I \sin(\omega t + \varphi)$, the current through the corresponding CL arm can be described as (9)

$$I_{CLa}(t) = I_{SFBa}(t) - I_{DC} \quad (9)$$

By combining the voltages (7) and the corresponding currents (8) and (9), the average powers sourced/sunk by a CL and SFB can be expressed as (10):

$$\begin{aligned} \bar{P}_{CLa} &= -\frac{V_{DCC} I_{DC}}{3} + \frac{V_{CL} I}{2} \cos(\delta - \varphi) \\ &= -\frac{V_{DCC} I_{DC}}{3} + \frac{\pi V_{DCC} I}{12} \cos(\delta - \varphi) = -\bar{P}_{SFBa} \end{aligned} \quad (10)$$

Equation (10) can be conveniently rewritten including equation (4) and defining the DC power $P_{DC} = V_{DCC} I_{DC}$:

$$\begin{aligned} \bar{P}_{CLa} &= -\frac{V_{DCC} I_{DC}}{3} + K_U \frac{V_C I}{2} \cos(\delta - \varphi) \\ &= -\frac{P_{DC}}{3} + \frac{V_{CL}}{V_C} P_{ACa} = -\bar{P}_{SFBa} \end{aligned} \quad (11)$$

Where P_{ACa} is the active power absorbed by phase a . Average power into the T-branch of the converter can similarly be derived from (7) and considering the DC flow through the T-branch as (12):

$$\bar{P}_T = -V_R(t) I_{DC} = 0 \quad (12)$$

Equation (11) shows that the average powers in the CL and SFB arms can be zero if $V_{CL} = V_C$ or if $\cos(\delta - \varphi) = 0$ and $I_{DC} = 0$, but generally $\bar{P}_{CLa} = -\bar{P}_{SFBa} \neq 0$. However, with the T-branch located in the DC circuit there is no net power exchange between the components of the arms other than the residual device losses that needs to be managed during converter operation. However, an active energy management is required to maintain the energy within the arms of the SFB and the CL. A method of using the 2nd harmonic voltage injection to achieve this energy management has been considered in other publications on the SBC and will be adopted also in this work. However, the amount of 2nd harmonic required is less compared to that used in the previous work as the filtering of the voltage harmonics using the T-branch does not affect the inter-arm energy as in [8]. This can be appreciated from the average power equation (10) where there is no effect of the $6n$ voltage harmonics in the average power in the CL and SFB arms. In the study of the SBC, however, the $6n$ harmonic voltage affect significantly the energy variation in the arms of the SFB and the CL.

V. DESIGN AND SIMULATION

In this section, plots illustrating the design of the converter and the simulation results demonstrating the performance of the converter are presented. The design of the CL, SFB and




Fig. 2: Maximum CL Voltage required




Fig. 3: Maximum and Minimum SFB voltages




Fig. 4: Maximum and Minimum T-branch voltages




Fig. 5: Factor of second harmonic voltage required for inter arm energy management, i.e. amplitude of the second harmonic normalised by the peak of the CL voltage before energy management in each operating point

T-branch arms are highly influenced by the voltages to be synthesised by these arms. Fig. 2 to Fig. 4 illustrate the voltage requirement for the various arms of the converter considering a 20MW/20kV DC/11kV AC system. The factor of 2nd harmonic voltage in the CL arm that will be required to manage power in the arms is presented in Fig. 5. The factor is defined as the ratio between the peak of the second harmonic voltage and the peak of the ideal CL voltage (i.e. without the need for second harmonic for energy management) in each operating point. Clearly, the rating of the T-branch voltages would have been extracted from the CL and be synthesised by the SFB, thereby increasing the size of the SFB and the amount of energy imbalance between the CL and SFB arms in the embodiments presented in [8]. Therefore, by using the T-branch, the amount

of 2nd harmonic voltage required for inter-arm energy management is reduced. In the T-branch, the predominant components are the 6th harmonic components. This reduces drastically the size of the capacitors that are required to meet the peak to peak voltage ripple for the submodules in the T-branch. From the plots in Fig. 2 to Fig. 4, a rating of 12kV for the CL arms, 3kV for the SFB arms and 3kV for the T-branch are considered for the 20MW/20kV DC/11kV AC demonstrator. A leakage inductance of 0.12PU typical of high power transformers is considered in this study. To maintain uniformity in the design of the submodules, local storage capacitors of 4mF operated at a nominal voltage of 1.5kV are used for all the arms.




Fig. 6: Converter AC terminal voltages and currents, V_G and I




Fig. 7: Converter voltages and currents at DC input of the H-Bridge front-ends




Fig. 8: CL voltages and currents




Fig. 9: SFB and T-branch voltages




Fig. 10: Converter DC side voltages (with and without filtering) and DC network current




Fig. 11: Instantaneous and average power in the SFB arms with and without 2nd harmonic inter arm energy control

The operation of the converter can be illustrated considering Fig. 6 to Fig. 11. Consider that the voltages in Fig. 6 are imposed at the AC terminal of the ESBC, which will be rectified into full wave rectified sinusoidal voltages with the attendant current shaping as shown in Fig. 7. To help synthesise the required full wave voltage V_{IN} and support the DC bus voltage, the CL arms synthesise the corresponding voltages as presented in Fig. 8. However, the voltages synthesised by the CL does not match that required at the DC input of the H-Bridge front-end, therefore the SFB arms synthesise the difference

between that synthesised by the CL and the corresponding V_{IN} as presented in Fig. 9. As shown earlier in (11) this results in residual powers in the SFB which will have to be managed by the use of the 2nd harmonic voltage injection. Also, the operation of the CL also results in the 6ⁿ harmonic voltages in V_{DCL} as shown in (6). The voltage synthesised by the SFB by supporting the V_{IN} formation and inter-arm energy management are shown in Fig. 9. The voltage harmonics that are extracted from V_{DCL} by the use of the T-branch is shown in lower plot of Fig. 9. Fig. 10 illustrates V_{DCL} with the 6ⁿ harmonic voltages




Fig. 12: Grid side voltages and Currents




Fig. 13: Voltages and currents at the DC input of the Converter




Fig. 14: Voltages formulated by the various arms of the ESBC




Fig. 15: Filtered and DC side voltages and the FFT of the filtered voltage




Fig. 16: Local submodule capacitor voltages in the various arms of the converter (top) T branch, (middle) SFB and (bottom) CL




Fig. 17: Power transferred between the ESBC and the DC and AC network

and V_{DC} when the 6ⁿ harmonic voltages have been extracted using the T-branch, showing that the voltage seen by the DC network is ripple free. The effect of the energy management on the SFB performance is illustrated with Fig. 11. Clearly, it can be observed that the energy in the arms can be managed with the use of the second harmonic voltage injection.

Fig. 12 to Fig. 17 present waveforms from a detailed switching model of 20kVDC 20MW system with 8, 2 and 2

submodules in the CL, SFB and T-branch arms respectively. It can be observed that the operation of the ESBC produces high quality current waveforms and can also produce good quality AC voltage waveforms with the appropriate number of submodules. In Fig. 13 the voltage imposed at the DC bus of the H-bridge front-end and the corresponding currents are presented. The voltage waveforms formulated by the various arms of the converter to ensure that the converter synthesises

the right voltages in Fig. 13 and ripple free DC voltage and current are presented in Fig. 14. In Fig. 15, the voltages across the three CLs and that across the DC bus after the T-branch the action are presented. The T-branch removes all the expected voltage harmonics from the DC bus voltage. Also, local capacitor voltages on the submodules in the arms of the various arms are presented in Fig. 16 during the power transients shown in Fig. 17. It is shown that the inter-arm energy management and the intra-arm controllers developed do support the operation of the converter and formulate high quality voltage and current waveforms at the AC and DC sides guarantee energy control.

VI. CONCLUSION

In this paper, an enhanced H-bridge front-end modular multilevel converter has been presented which has the advantage of using significantly fewer submodules and therefore less energy storage than other topologies with similar performances. The proposed converter uses an optimum number of half bridge and full bridge submodules to achieve active and reactive power control and DC voltage active filtering. The operating principle of the converter, the voltage waves shaping and internal energy management principle have been discussed. Results from a scaled down medium voltage demonstrator have been presented to validate the concept of converter operation and the capabilities of the converter.

VII. REFERENCES

- [1] R. Feldman, M. Tomasini, E. Amankwah, J. C. Clare, P. W. Wheeler, D. R. Trainer, *et al.*, "A Hybrid Modular Multilevel Voltage Source Converter for HVDC Power Transmission," *Industry Applications, IEEE Transactions on*, vol. 49, pp. 1577-1588, 2013.
- [2] S. Allebrod, R. Hamerski, and R. Marquardt, "New transformerless, scalable Modular Multilevel Converters for HVDC-transmission," in *Power Electronics Specialists Conference, 2008. PESC 2008. IEEE, 2008*, pp. 174-179.
- [3] M. M. C. Merlin, T. C. Green, P. D. Mitcheson, D. R. Trainer, R. Critchley, W. Crookes, *et al.*, "The Alternate Arm Converter: A New Hybrid Multilevel Converter With DC-Fault Blocking Capability," *Power Delivery, IEEE Transactions on*, vol. 29, pp. 310-317, 2014.
- [4] G. P. Adam, Finney, S. J., Williams, B. W., Trainer, D. R., Oates, C. D. M., Critchley, D. R., "Network fault tolerant voltage-source-converters for high-voltage applications," in *AC and DC Power Transmission, 2010. ACDC. 9th IET International Conference on*, 2010, pp. 1-5.
- [5] G. Bopparaju, "VSC based FACTS and HVDC: ABB's experience," in *Sustainable Energy and Intelligent Systems (SEISCON 2011), International Conference on*, 2011, pp. 1-2-1-2.
- [6] L. B. Feng Wang, Tuan Le, "An Overview of VSC-HVDC : State - of - art and potential applications in Electric Power Systems," *Cigre*, 2011.
- [7] J D Ainsworth, M Davies, P J Fitz, K E Owen, and D. R. Trainer, "A static var compensator (STATCOM) based on single phase chain circuit converters," *IEE Proceedings, Generation, Transmission and Distribution*, vol. 145, July 1998.
- [8] E. Amankwah, A. Costabeber, A. Watson, D. Trainer, O. Jasim, J. Chivite – Zabalza, *et al.*, "The Series Bridge Converter (SBC): A

Hybrid Modular Multilevel Converter for HVDC Applications," presented at the EPE 2013, Karlsruhe, 2016.

- [9] O. F. Jasim and D. R. Trainer, "Voltage Source Converter," EP2858231A1, 2015.