

# OHL Assessment and Risk Evaluation

## Based on Environmental and Inspection Data

Francisco Azevedo<sup>1</sup>, João Gomes-Mota<sup>2</sup>, Luís Campos-Pinto<sup>3</sup>, Nélio Machado<sup>4</sup>, and Susana de Almeida de Graaff<sup>5</sup>

<sup>1</sup> fa@albatroz-eng.com (corresponding author, +351-965149374), Assistant Professor - CENTRIA – Faculdade de Ciências e Tecnologia – Universidade Nova de Lisboa, Quinta da Torre, 2829-516 CAPARICA, Portugal

<sup>2</sup> gomes.mota@albatroz-eng.com (+351-213473079), MSc, Engineer - Albatroz Engenharia, , Portugal

<sup>3</sup> campospinto@ren.pt, Director, Engineer - REN – Rede Eléctrica Nacional, S.A., Portugal

<sup>4</sup> nelio.machado@ren.pt, MSc, Engineer - REN – Rede Eléctrica Nacional, S.A., Portugal

<sup>5</sup> Susana.de.Graaff@tennet.eu, PhD, Engineer - TenneT TSO B.V., The Netherlands

### Abstract

REN – Rede Eléctrica Nacional, S.A., Portuguese Transmission System Operator (TSO), has been using LiDAR technology in their aerial inspections. The acquired three-dimensional data in this Power Line Maintenance System are automatically processed, with support of the video inspections and geo-referenced systems. The national transmission grid was fully characterized at span level with urbanization and vegetation growth rate indices.

The collection of historical data, together with the knowledge of asset characteristics and system operation conditions, is structured in a generalized relational database, extended with a comprehensive set of different environmental, meteorological and geographic data over the years.

A methodology to evaluate operational risk was developed, taking into account the probabilistic nature of contingencies and their severity under specific operating conditions. Risk indices provide an insight to operators of the network state and of the constraints that operators face. Different optimization tools are also being developed.

**Keywords:** OHL; Risk; Data base; Environment; Inspection; Maintenance; Planning

# 1 Introduction

Nowadays, the difficulty to build new assets, the increasing demands for quality of service and system's operation closer to its security limits, are determining factors since in many countries, assets (such as towers to support power lines transmission) installed some decades ago are now reaching their end of life. In this context of cost reduction, higher efficiency and productivity, together with current environmental concerns and the desire to compare operation and maintenance efficiency with counterpart companies, REN – Rede Eléctrica Nacional, S.A., Portuguese Transmission System Operator (TSO), has been using LiDAR (Light Detection And Ranging) technology in their aerial inspections since 2007 (André and Gomes-Mota 2009). The acquired three-dimensional data in this Power Line Maintenance System (PLMI) (Gomes-Mota 2008) are automatically processed, followed by human supervision for confirmation and adjustments, with support of the video inspections and geo-referenced systems. The national grid was thus fully characterized at span level with urbanization and vegetation growth rate indexes, following the ITOMS methodology (ITOMS 2011), which were validated by a comparative analysis of inspections in subsequent years.

The collection of historical data, together with the knowledge of asset characteristics and system operation conditions, is now structured in a generalized relational database, allowing a multi-purpose, structured and complex data analysis. Information organization represents a big challenge and an extremely time-consuming task for a TSO, but it allows the development of methodologies that will improve the system performance in several domains. Data collection and organization become crucial to obtain better results and represent a major step for a TSO. This forces the TSO to maintain an updated and well structured asset database with all the required information. For example, a ‘number crunching’ analysis tools and statistical methods to infer valuable information, such as common cause failure and probability of failure under different conditions, which can be also combined with online operational and meteorological data. Real-time conditions play a very important role for system operation. Assets lifeline can then be more precisely estimated for several time frames. Additionally, this model is being extended with a comprehensive set of different environmental, meteorological and geographic data over the years, including hourly temperatures in Portugal’s main land, all detected lightning strikes, levels of relevant pollution levels, fire risk with about 600m<sup>2</sup> detail, and storks population. In fact, REN usually counts on

dedicated inspections (with all its associated costs) just to detect and count stork nests in its towers. The authors, also in the scope of the LIONS (Lines Inspection Optimization System) project, are currently working on a tool to automatically identify such nests based on the videos produced from regular inspections, together with our geo-referenced data on the respective towers.

With such a system, more precise risk indices can be calculated based on the probability of failure for each span and aggregated for a whole overhead line (OHL), taking also into account the operation conditions, the severity of failures, and its estimated exposition time. Such approach is similar to Condition Based Risk Management (Earp (2005) and Hughes (2005)), but favours a broader analysis of factors affecting the lines in a shorter time frame. Moreover, the criticality of each line depends on its risk index, as well as on the grid topology as a complex graph (Azevedo and Gomes-Mota 2010a), with its power sources, sinks, and available alternative power flow paths. Having such information reliably calculated allows to develop optimisation tools, as we are currently doing (Azevedo and Gomes-Mota 2010b), to reduce costs or to improve the quality of service by an appropriate use of resources, such as an intelligent maintenance policy or inspection planning. Equally important is the ability of more accurate asset life line estimation, to fully exploit its use with less risk, and better plan future maintenance and investments, reducing uncertainty.

A methodology to evaluate operational risk for a short-period of time was developed internally at REN, taking into account the probabilistic nature of contingencies and their severity under specific operating conditions. This new methodology aims to provide control room operators with risk-based security indices for the following period (such as 1 hour). Risk indices provide an insight to operators of the network state and of the constraints that operators face (Almeida *et al.* (2010, 2011) and Almeida (2010)). The presented database allows this methodology to survive and succeed.

This paper is organized as follows: in the next section, we start by describing the risk factors that we are considering. In section 3 we present the information structure used to represent and handle all relevant data, and then, in section 4, we discuss our risk model. We conclude in section 5.

## 2 Risk Factors

We are currently considering the following main risk factors for operation of OHLs:

- **Equipment:** in fact, one of the risk factors for electrical power transmission using OHLs comes from assets, the equipment itself, such as its own structure, i.e. the tower, and insulators, which may not perform its intended functions,

due to its physical conditions;

- **Vegetation:** vegetation (and other objects) in the right-of-way is a major concern for OHLs since its proximity to phase conductors may cause a line tripping, and it has a dynamic nature (vegetation grows, wind blows, sag increases with temperature, etc.) (Almeida 2010);
- **Storks:** birds (in particular, storks, in Portugal and other countries) may nidify in towers. Collisions with conductors represent danger both to the bird and to system's security, since bird's electrocution may cause an unexpected outage of the line. In a more time consuming but frequent way, birds droppings (which are highly corrosive) over insulators will lead to their malfunctioning (Almeida 2010);
- **Pollution and fog:** pollution, especially when associated with fog, also largely affect insulators, in particular non-composite ones (Almeida 2010);
- **Lightning:** one of the major causes of concern with respect to OHLs is lightning, due to its power and unpredictability. A single strike at a line (or nearby) may easily cause it severe damages (Almeida 2010);
- **Fires:** forest fires, also known as wildfires, occurring under a line also represent a risk to OHLs, as they cause forced outages and may require the operator to take the line out of service to allow fire extinction (Almeida 2010).

### 3 Information Structure


Our architecture (Azevedo and Gomes-Mota 2010b) consists of a server with connections to geographical information systems (GIS) and asset management systems, running modular applications, with access to relational databases implemented over PostgreSQL, and with http-based communication.

There are three databases involved: 1) a database containing the electrical grid topology, with all its relevant components and features; 2) a 'lower-level' database containing the raw data produced by line inspections, such as vegetation management, equipment faults, navigation systems data, and so on; 3) environmental database.

The 'topology' database contains information concerning four categories. Without intending to delve into the details, a general picture of a schema is shown in Fig. 1, where each of the categories corresponds to a different rectangle region. Some regions overlap and, of course, are related to others:

1. **Graph** (blue & zoom): the grid topology itself, which defines a graph with nodes such as substations, plants, or sectioning posts, and where arcs are the electrical circuits connecting two nodes.

2. **Lines** (yellow): aerial lines carrying the electrical circuits, with their towers and respective numbers. It includes also underground circuit segments, and electrical characteristics.
3. **Assets** (green): towers and wires as grid assets, with their characteristics, their use, and their relations.
4. **Inspections** (pink): general part of inspections already performed, containing identification, and processed data, such as identified towers, wires, environment, and anomalies. Historical data lie mainly in this category.



**Fig. 1.** Database schema [\(low resolution image, for confidentiality reasons\)](#)

On the left of Fig 1, the ‘Graph’ region is magnified, as an illustrative example. Electrical circuits are the graph arcs, connecting two nodes, with a given operation voltage. Each node has geographical data and can be either a substation, or a plant (if not part of a substation), or a sectioning post. It can also be a simple derivation from some circuit. Border nodes are also considered when lines reach a different country to allow for cross border energy trade. Notice that substations are also modelled with transformation capacities between different voltages, via the Transformer table. This part of the database allows performing global analyses of the grid (Azevedo and Gomes-Mota 2010a), calculating critical paths, for instance.

Regarding environmental data (Azevedo and Gomes-Mota 2012), for each tower we have registered its number of stork nests and whether it is located in a frequent thick fogs region, together with a rough estimate on the kind of pollution (industrial, salt, dust, birds, other) each tower was subject to. Maintenance information concerning washing of dirty insulators was also available and we registered its towers and dates, thus being able to determine critical areas, inferring pollution zones based on its effects, and their level based on the frequency.

More accurate and complete information was anticipated by referring to available national sensors (of several distinct pollutants), using historical data gathered since 1995. Unfortunately, the regional dispersion of sensors is very low, with many being located in the big cities, so it is not so important for transmission operators, since that is not where OHLs lie. Thus washing data appear to be more useful. Nevertheless, all available data were recorded in the database.

From the Portuguese meteorological institute, we have cloud-to-ground lightning data including date and time of striking, amplitude (negative or positive), and estimated (by different methods) localization, given by an ellipse. The location accuracy is given by its  $\chi^2$  value. Data are registered by a network of sensors covering the entire region since 2003. A statistical analysis of such historical data allows calculating lightning density throughout all lines for a better estimation of probability of incidence along the years.

For wildfires, from the same meteorological source, we have daily values (on a risk scale of 1 to 5) based on fires forecast, for each municipality, and updated active fire information from the fire-fighters coordination centre. Mainly for historical value, but also useful to verify, for instance, hotter regions where fires may more easily occur, we register air temperatures along the territory, thanks to the available data. In fact, the Portuguese meteorological institute provides us with daily temperatures (minimum, maximum, and average) for district capitals for the last 25 years. In addition, the grid operator has available temperature measurements registered in substations every 15 minutes, for the last 10 years. We recorded all these data in the environment database.

Additionally to the described databases, REN has since 2001 an application called GestInc, which has as main purpose to organize and manage incidents' data, recording all the relevant detailed information (Almeida and Lobo 2005).

## 4 Risk Evaluation

The total probability of fault in an OHL circuit is determined by the probability of occurrence of each individual cause, where the probability of  $cause_i$  (except lightning) per  $OHL_k$  is equal to

$$\text{prob}_{\text{cause}_i, \text{OHL}_k} = [\lambda_{\text{cause}_i}(m, p, u) \times LR_{\text{cause}_i, \text{OHL}_k}] \cdot t \quad (1)$$

Where  $m$  is the month,  $p$  is the day period,  $u$  is the voltage level and  $t$  is the analysis duration (for short term and online assessment this is typically 1 hour);  $\lambda_{\text{cause}_i}(m, p, u)$  is the average failure rate and  $LR$  is the length at risk of  $OHL_k$ , both per cause.

The failure rates are calculated every time through an application that gets the information from the databases (described in ‘Information Structure’ section) in order to take into account the last incidents and the recent updates of equipment on the Portuguese transmission network.

For online and short-time risk calculation, some processes were developed to gather and process the information of current and forecast conditions to calculate the probability of the causes that are time dependent:

- (a) Forecast Forest fires risk
- (b) Active fires
- (c) Forecast lighting
- (d) Current lighting conditions (using a lightning monitor application ‘JOBS’)
- (e) Temperature
- (f) Fog

The processes to retrieve this information were developed at REN (Machado 2011) and use different sources of information including some from the internet. As all of the mentioned forecast information is given for each municipality region, the correspondent LR term for probability calculation is weighted with the  $\alpha$  factor for each municipality depending on the forecast conditions:

$$LR_{cause, OHL_k, municipality_j} = length_{municipality_j, OHL_k} \cdot \alpha_{cause, municipality_j} \quad (2)$$

The other causes described in “Risk Conditions” that are not time dependent (as storks, vegetation, equipment, fog combined with pollution and forest fires) have a constant  $\alpha$  factor value for each analysis period that will affect the OHL. For these ones the LR term is calculated for each span.

For long term risk calculation several weather conditions are considered, namely dry, medium and wet seasons. For each of these 3 scenarios the  $\alpha$  factors are calculated for each cause except for storks which will be constant or can be assumed an increasing factor on some municipalities where it could be forecasted a significant increase of this bird population.

As lightning is the primary cause of faults in Portugal, the probability of fault is calculated using the backflash rate (BFR) methodology for each tower considering the lightning density on the region and the equipment database information for each tower, namely geometry, tower footing resistance, number of ground wires, tower footing resistance, insulation level

and the conductor's diameter. The critical current (the minimum current that causes flashover) and therefore the probability of flashover is calculated for each tower.

The risk of fault (contingency) can be evaluated by weighting its severity by its probability of occurrence as in equation 3:

$$Risk_k = probability_k \times severity_k \quad (3)$$

where  $k$  represents the  $k^{\text{th}}$  contingency under analysis.


Severity must reflect the consequences of a contingency (fault), namely the loading condition of the network branches and transformers, the voltage limits violations on busbars, instability index, loss of load, loss of generation, island processing and cascading analysis. The network is modelled in PSS/E application where the load, generation, equipment outage, voltage and phase-angle taps are adjusted to the forecast analysis. For online security calculation a snapshot model is created from the SCADA/EMS real-time system. For long term risk calculation, 3 scenarios of the network model are considered to be used with the corresponding 3 probability scenarios, dry, medium and wet seasons. For each scenario, the generation and load profile on the network model is adapted coherently to the weather conditions. These scenarios (network models) are the ones used by the long term planning department of REN.

The severity for each failure (contingency) is calculated in PSS/E using the Newton-Raphson method. The automation of severity calculation (Machado 2011) was implemented using python scripts running under PSS/E environment connected to a database performing the contingency analysis of the "must-run list" complemented with the analysis of loss of load, loss of generation, islanding, voltage instability and cascading evaluation. Additional severity values that not depend of loadflow calculations (as repair times and costs) are also considered.

The global severity value for each contingency is calculated by weighting all the severity independent results. The severity functions per type of impact are defined in such a way that their outcome is a normalized value.

At the end, a risk index will be computed for each contingency based on the probability and severity of each event. A visual interface was built (Fig. 2) to place this information available in the control room for a parallel run together with the deterministic information used on the day-a-ahead market validation and hourly-a-head security evaluation.





**Fig. 2.** Hourly Risk

To handle the large amount of results and information available on the risk evaluation, an automated filter was developed to show to control room operators only the critical situations to be taken into consideration.

Still under development is the challenging definition of “acceptable risk” to create a secure and risk zone on the visual interface of results, where several levels of risk can be defined. Local risk policies and management strategies play here a role. These concepts are expected to be more stable after few years of learning and trial, building up historical data of risk calculations. The acceptable risk threshold should correspond to the maximum risk value the operator is willing to accept, under which no additional measures will be taken. This means cost reductions but also possible reliability issues, potentially affecting quality of service. Thus, the acceptable risk must be defined by the management together with the national energy regulator.

## 5 Conclusions

A methodology to evaluate operational and maintenance risk for different time frames was developed, taking into account the probabilistic nature of contingencies and their severity under specific operating conditions. This methodology uses several types of information to calculate risk indices, including current conditions. The applicability of the methodology directly to the TSO needs is of great concern, because of continuous effort involving excellence in the operation, efficient planning, investment in new assets and in the renewal of existing ones, adequate maintenance strategies, strict coordination of outages and efficiency of technical and human resources.

The collection and data organization is a must for this methodology, which requires the TSO to maintain a common asset database properly organized and promptly updated, with all the required information, to be used as input, as described.

## References

- S.A.B. de Almeida, R. Pestana, F.P.M. Barbosa, and N. Machado (2010). "Operational Risk Assessment Methodology for the Portuguese Transmission System". *ELECTRA*, Invited paper.
- S.A.B. de Almeida, C.S. Engelbrecht, F.P.M. Barbosa, and R. Pestana (2011). "Prediction of faults caused by Lightning for Transmission System Operations". *ELECTRA*, Invited paper.
- S.A.B. de Almeida (2010). *Portuguese Transmission Grid Incidents Risk Assessment*. PhD thesis, FEUP.
- S.A.B. de Almeida, and J. Lobo (2005). "Gestic-The Incidents Data Base: Purposes, Contents, Management And Automatic Indicators Calculation Future Developments". In *1ere Conférence Internationale sur le Transport de l' Electricité en Algérie*.
- A.M. André, and J. Gomes-Mota (2009). "Multi-Challenges and Benefits of Integrated Over-Head Line Inspections". In *CIREDO9 - Session 20*, paper 0848.
- F. Azevedo, and J. Gomes-Mota (2010a). "Electrical grid modelling for overhead maintenance cycle optimisation". In T. Hadzic, R. Marinescu, eds., *1st Workshop on Constraint Reasoning and Graphical Structures (CRaGS 2010)*, pp. 75-82.
- F. Azevedo, and J. Gomes-Mota (2010b). "A time and space framework for overhead grid maintenance optimization". *Modern Energy Review*, 2(1): 95-99.
- F. Azevedo, and J. Gomes-Mota (2012). "Gathering Environmental Data Concerning Very High Voltage Lines. *Modern Energy Review*, 4(1): 71-73.
- G. Earp (2005). "Condition Based Risk Assessment of Electricity Towers using High Resolution Images from a Helicopter". In *CIREDO2005 - 18th International Conference on Electricity Distribution*.
- J. Gomes-Mota (2008). "Integrated, Flexible and Real Time Inspection of Overhead Lines". *Power Industry International*, 2(1): 67-69.
- D. Hughes (2005). "Condition Based Risk Management (CBRM) - Enabling Asset Condition Information to be Central to Corporate Decision Making". In *CIREDO, 18th International Conference on Electricity Distribution*.
- ITOMS (2011), available online at [http://www.umsgroup.com/ums\\_static/itoms.asp](http://www.umsgroup.com/ums_static/itoms.asp).
- N. Machado (2011). *Automatização da metodologia para análise de risco na Rede Nacional de Transporte*. MSc thesis, FEUP.