

KfK 4663
EUR 11395 EN
November 1989

HADA-2 (Modified Version of HADA)

**A FORTRAN-IV Program for the
Thermohydraulic Design of an Advanced
Pressurized Light Water Reactor with a
Tight Fuel Rod Lattice**

**T. Mori, M. Cigarini, M. Dalle Donne
Institut für Neutronenphysik und Reaktortechnik
Projektgruppe LWR-Sicherheit**

Kernforschungszentrum Karlsruhe

KERNFORSCHUNGSZENTRUM KARLSRUHE
Institut für Neutronenphysik und Reaktortechnik
Projektgruppe LWR-Sicherheit

KfK 4663
EUR 11395 EN

H A D A - 2 (MODIFIED VERSION OF HADA)

A FORTRAN-IV PROGRAM FOR THE THERMOHYDRAULIC DESIGN OF AN
ADVANCED PRESSURIZED LIGHT WATER REACTOR WITH A
TIGHT FUEL ROD LATTICE

T. Mori¹⁾

M. Cigarini²⁾

M. Dalle Donne³⁾

- 1) Visiting researcher from Japan Atomic Energy Research Institute,
Tokai-mura, Naka-gun, Ibaraki-ken, 319-11 Japan
- 2) Present address: c/o Mercedes Benz, Untertürkheim, Stuttgart
- 3) Delegated from Euratom to Kernforschungszentrum Karlsruhe,
Institut für Neutronenphysik und Reaktortechnik

Kernforschungszentrum Karlsruhe GmbH, Karlsruhe

Als Manuskript vervielfältigt
Für diesen Bericht behalten wir uns alle Rechte vor

Kernforschungszentrum Karlsruhe GmbH
Postfach 3640, 7500 Karlsruhe 1

ISSN 0303-4003

ABSTRACT

MORI, Takamasa, CIGARINI, Marco and DALLE DONNE, Mario :
HADA-2 (Modified Version of HADA): A FORTRAN-IV Program for the Thermohydraulic Design of an Advanced Pressurized Light Water Reactor with a Tight Fuel Rod Lattice

The FORTRAN-IV program HADA, which computes the thermohydraulic parameters for Advanced Pressurized Light Water Reactors with a tight fuel rod lattice, has been modified to extend its applicability. The new version can be applied to homogeneous reactors using grid spacers with an arbitrary linear heat rating or an arbitrary core height. This version is also applicable to an axially heterogeneous reactor (multiple stacked core) which has been designed in JAERI and is not based on the modern PWR plant of German design. For users of the program, the present report describes the modifications and the input data in detail. Three sample runs demonstrate the usage of the program and the output. The provided and used solution algorithms are explained, in addition to the description of the physical background given in KfK 3453 and KfK 4148. The utility programs are described and an installation guide for the program system is listed.

ZUSAMMENFASSUNG

MORI, Takamasa, CIGARINI, Marco and DALLE DONNE, Mario :
HADA-2 (eine geänderte Version von HADA): Ein FORTRAN-IV Programm zur thermohydraulischen Auslegung von fortgeschrittenen Druckwasserreaktoren mit enger Stabteilung

Das FORTRAN-IV Programm HADA zur Berechnung der thermohydraulischen Parameter von fortgeschrittenen Druckwasserreaktoren mit enger Stabteilung wurde modifiziert, um seine Anwendbarkeit zu erweitern. Die neue Version kann für homogene Reaktoren mit Gitterabstandshalter mit beliebiger Stableistung und mit beliebiger Kernhöhe angewendet werden. Diese Version ist anwendbar auf axial heterogene Reaktoren (geschichtete Kerne), die von JAERI entworfen worden sind und nicht den deutschen DWR-Entwürfen entsprechen. Der vorliegende Bericht beschreibt ausführlich die Änderungen und die Eingabe-Daten für die Programmbenutzer. Drei Beispielrechnungen zeigen die Verwendung des

Abstract

Programms und die Ausgabe. Die angegebenen und verwendeten Lösungsalgorithmen werden erklärt. Die Beschreibungen der physikalischen Hintergründe sind in den Berichten KfK 3453 und KfK 4148 angegeben. Die Dienstprogramme sind beschrieben und eine Anleitung zum Einbau des Programmsystems ist angegeben.

TABLE OF CONTENTS

1. Introduction	1
2. New Features of HADA-2 Code	2
2.1 Modification of Homogeneous Reactor Calculation	2
2.1.1 <i>Spacers</i>	2
2.1.2 <i>Linear Heat Rating and Core Height</i>	3
2.2 Computation of Multiple Stacked Core (JAERI Design)	4
2.3 Reactor Power Iteration	8
2.4 Axial Power Distribution	8
2.5 Various Additions	9
3. Mathematical Background	11
4. Input Data	13
4.1 Problem Identification (Unit 47)	14
4.2 Control Parameters and Options (Unit 05)	14
4.3 Common Physical Parameters (Unit INP)	17
4.4 Special Physical Parameters (Unit 05, JNP)	20
4.4.1 <i>Computation of the Power Ratio (IOP2=0, Unit 05)</i>	20
4.4.2 <i>Reactor with a Homogeneous Core (Unit JNP)</i>	21
4.4.3 <i>Reactor with a Heterogeneous Core (unit JNP)</i>	23
4.5 Physical Parameters for the CHF Computations (Unit 05)	24
5. Output	27
6. Examples	28
6.1 Sample 1, Homogeneous Core, Chopped Cosine Distribution (KfK Design)	29
6.2 Sample 2, Homogeneous Core, Arbitrary Axial Power Distribution (KfK Design)	57
6.3 Sample 3, Multiple Stacked Core (JAERI Design)	71
7. Utility Programs	95
7.1 Creating the Data Pool	95
7.2 Listing the Results	95
7.3 Deleting Entries	96
7.4 Listing a Specified Entry	96
7.5 Compressing the Data Pool	97
7.6 Plotting the Results	97

7.7 Listing the Contents	104
8. Installing the Programs	105
Reference	116

1. INTRODUCTION

The FORTRAN-IV program HADA has been developed to compute the thermohydraulic parameters for Advanced Pressurized Light Water Reactors (APWRs) with tight fuel rod lattices based on the data of a Pressurized Light Water Reactor. The first version of HADA was released for users' application in 1985/1/, and successfully used in the first parametric study for APWR design/2/. This version has the following functions:

- Power ratio - computation of the power fraction K for a given pressure drop Δp ,
- Computing the design parameters of a reactor with a homogeneous core with spacers formed by six spiral ribs,
- Computing the design parameters of a reactor with a radially heterogeneous core consisting of the seed (loose lattices, grid spacers) and the blanket (tight lattices, spiral rib spacers).

After the release of the first version, various improvements were made. The main modifications are as follows:

- The use of the water enthalpy, rather than the water temperature, for the equation giving the limitation due to the hot channel factor $F_{\Delta H}$.
- The introduction of the factor $C_{\Delta H}$, which ensures that the minimum value of the ratio between the critical heat flux and the hot channel heat flux (DNBR) is always equal to or greater than 1.3.

The details of the modifications are given in Reference /6/, where the modified version is temporarily called HADA-2. The recent parametric study in 1986 /6//7/ was carried out by using this version.

After the above modifications, the following new functions have been added to the program to the present:

- For the computation of the design parameters of a reactor with a homogeneous core, grid spacers, as well as spiral rib spacers, can be used with either fixed linear heat rating or fixed core height.
- Computing the design parameters of a reactor with a radially homogeneous but axially heterogeneous core (multiple stacked core) /4//5/.

- Introduction of the iteration scheme to ensure the same reactor thermal output as the reference one in case that the previous version gives a higher thermal output because of lower core pressure drop.
- An arbitrary axial power distribution in place of the chopped cosine one can be given by input in the form of numerical table.
- The total head of pump and/or the heat transfer characteristics of heat exchanger can be changed by input, if necessary.

In addition to the above modifications, some additions are made to the calculations of the pressure drop by spacer grids and the critical heat flux.

In this report, the modifications after 1986 and the usage of the present version are described for user's convenience. As for the physical background and the mathematical formulation of the problem, users should refer to the previous reports /2//6/.

2. NEW FEATURES OF HADA-2 CODE

2.1 MODIFICATION OF HOMOGENEOUS REACTOR CALCULATION

2.1.1 Spacers

In the original version of HADA, the fuel rod spacers are made of six spiral ribs integral with the rod cladding. In the present version of the code (HADA-2), in addition to this type of spacers, a user can make a computation of a homogeneous core with grid spacers as well. The core pressure drop is calculated in the same method as that in the seed of heterogeneous reactor. However, the solidity and the modified drag coefficient are calculated with different methods.

SOLIDITY: For defining the solidity ϵ , a user can select either of the following two ways:

- give the parameters shown in Figure 1 on page 117.

In this case, the solidity is calculated by

$$(1) \quad \varepsilon = \frac{AG}{\frac{\sqrt{3}}{4} p^2 - \frac{\pi d^2}{8}},$$

where

$$(2) \quad AG = 0.75 \times (p - d - SG - 0.0001) \times BG.$$

- give the parameters G1 and G2 in the following equation:

$$(3) \quad \varepsilon = G1 - G2 \times (p - d),$$

which is similar to Eq. (74) in Reference /2/.

MODIFIED DRAG COEFFICIENT: The modified drag coefficient is calculated by

$$(4) \quad C_V = 7.997 + \frac{167.12}{Re^{0.264}} + \frac{6.375 \times 10^{10}}{Re^{2.79}}.$$

When the product $\varepsilon^2 C_V$ is greater than 5.2, the relation

$$(5) \quad C_V = \frac{5.2}{\varepsilon^2}$$

replaces the above equation.

Instead of the above method, a user can define the product $\varepsilon^2 C_V$ as follows:

$$(6) \quad \frac{1}{2} \varepsilon^2 C_V = \frac{1}{2} \left(0.8189 + \frac{17.114}{Re^{0.264}} + \frac{0.6528 \times 10^{10}}{Re^{2.79}} \right).$$

The maximum value of the product is also 5.2.

2.1.2 Linear Heat Rating and Core Height

A user can specify the linear heat rating q_L and the core height L_C by one of the following three methods.

- use the original method /2/.

The linear heat rating is calculated by

$$(7) \quad q_L = \left[-372.27 + 744.11 \frac{p}{d} + 236.67 \left(\frac{p}{d} \right)^2 \right] \times 10^{10}.$$

The core height is determined by

$$(8) \quad L_C = \frac{Q}{n_T q_L},$$

where Q and n_T are the reactor thermal output and the total number of fuel rods, respectively.

- specify the absolute value of linear heat rating by input.

In this case, the core height is calculated by the above equation.

- specify the absolute value of core height by input.

In this case, the linear heat rating is calculated by

$$(9) \quad q_L = \frac{Q}{n_T L_C}.$$

2.2 COMPUTATION OF MULTIPLE STACKED CORE (JAERI DESIGN)

We consider a radially homogeneous reactor with an axial power distribution shown in Figure 2 on page 117. The definition of the parameters used in this section is summarized in Table 1 on page 7. The whole core is axially divided into three kinds of parts: inner core, inner blanket and outer blanket. We assume that the rod diameter and its pitch are the same in the whole core (both in the inner cores and the blankets). The power distribution in an inner core is represented by the chopped cosine distribution with the axial power form factor φ_{ax} . On the other hand, that in an outer blanket is assumed to be:

$$(10) \quad f_B(x) = A \cdot \exp(-R_{KB} \cdot x),$$

where x is a distance from the boundary between the inner core and the blanket. In the inner blanket, the power distribution is assumed to be:

$$(11) \quad f_{IB}(x) = f_B(x) + f_B(L_{IB} - x),$$

where x is again the distance from the boundary and L_{IB} is the thickness of inner blanket. The parameter R_{KB} is calculated from the input value φ_{ax2} as follows:

$$(12) \quad \varphi_{ax2} = \exp(-R_{KB} \cdot L_B),$$

where L_B is the thickness of outer blanket.

Since the rod diameter and its pitch are the same in the whole core, the thermohydraulic parameters of the system can be computed in the same way as

for the homogeneous reactor by using the whole core quantities L_C and q_L , which are the height of the whole core and the average linear heat rating over the whole core, respectively. In the calculation of local quantities such as the critical heat flux and the DNBR, the following relations are used:

$$(13) \quad L_C = (NAC - 1) \cdot L_{IB} + NAC \cdot L_{IC} + 2 \cdot L_B,$$

$$(14) \quad q_L \cdot L_C = q_{LB} \cdot 2 \cdot R \cdot (NAC - 1) \cdot L_{IB} + NAC \cdot q_{LIC} \cdot L_{IC} + 2 \cdot q_{LB} \cdot L_B,$$

where

$$(15) \quad R = \frac{q_{LIB}/2}{q_{LB}},$$

In the above equations, NAC is the number of inner cores, and L and q_L are the thickness and the average linear heat rating of each part, respectively. The subscripts IC, IB and B indicate the inner core, the inner blanket and the outer blanket, respectively.

From the above relations and the input values (R_1 , R_2 , R_3 and φ_{ax2}) the thickness and the average linear heat rating of each part are obtained as follows:

$$(16) \quad L_{IC} = \frac{L_C}{(NAC - 1) \cdot R_1 + NAC + 2 \cdot R_2},$$

$$(17) \quad L_{IB} = L_{IC} \cdot R_1,$$

$$(18) \quad L_B = L_{IC} \cdot R_2,$$

$$(19) \quad q_{LIC} = \frac{q_L \cdot L_C}{2 \cdot R_3 \cdot \{R \cdot (NAC - 1) \cdot L_{IB} + L_B\} + NAC \cdot L_{IC}},$$

$$(20) \quad q_{LB} = q_{LIC} \cdot R_3,$$

and

$$(21) \quad q_{LIB} = 2 \cdot q_{LB} \cdot R.$$

The parameter R can be written by using the input parameters as follows:

$$(22) \quad R = \frac{q_{LIB}/2}{q_{LB}} = \frac{R_2}{R_1} \frac{1 - (\varphi_{ax2}) R_2}{1 - \varphi_{ax2}} \cdot \frac{R_1}{R_2}.$$

The hot spot heat flux distribution at the surface of the fuel rod in the inner core is:

$$(23) \quad \phi_{HS,C}(x) = F_{qOP} \frac{q_{LIC}}{\pi d} \cos \frac{\pi x}{L_C},$$

of which the average value is

$$\frac{F_{qOP}}{\varphi_{ax}} \frac{q_{LIC}}{\pi d},$$

and the peak value is

$$\frac{F_{qOP} q_{LIC}}{\pi d}.$$

That in the outer blanket is:

$$(24) \quad \phi_{HS,B}(x) = \frac{F_{qOP}}{\varphi_{ax}} \frac{q_{LB}}{\pi d} \frac{\ln \varphi_{ax2}}{\varphi_{ax2} - 1} \exp(-R_{KB} \cdot x),$$

of which the average value is

$$\frac{F_{qOP}}{\varphi_{ax}} \frac{q_{LB}}{\pi d},$$

and the peak value is

$$\frac{F_{qOP}}{\varphi_{ax}} \frac{q_{LB}}{\pi d} \frac{\ln \varphi_{ax2}}{\varphi_{ax2} - 1}.$$

The nominal heat flux distribution at the surface of the fuel rods in the highest rated coolant channels is described by similar equations to Eqs. (23) and (24) with F_{qN} in place of F_q .

The critical heat flux is calculated by using the same correlations as in Reference /6/. These correlations are applied in the following two ways by user's choice:

- As the coolant channel inlet, the inlet of each part (each inner core, each blanket) is taken.
- The lowest part of the whole core is taken as the inlet in the CHF calculation.

The deformation of the axial heat flux distribution caused by the insertion of the control rods is taken into account in the inner core region. The same assumption for the deformation is used as in Reference /2/. The local quantities are calculated at all axial nodes (not only in the upper half). The position x in the print out shows the distance from the inlet of the whole core.

Parameter	Definition	Note
NAC	Number of inner cores	Input
φ_{ax}	Axial form factor in the inner core	Input
φ_{ax2}	Axial form factor in the outer blanket	Input (see Eq.(12))
F_q	Hot channel factor for heat flux in the inner core	Input (see Eqs.(22) and (23))
F_{qN}	Factor for the maximal heat flux in the inner core accounting the axial and radial power distribution	Input
O_p	Over power factor	Input
d	Diameter of fuel rod	Input
L_c	Total core height including inner cores, inner blankets and outer blankets	
L_{ic}	Thickness of the inner core	
L_{ib}	Thickness of the inner blanket	
L_b	Thickness of the outer blanket	
q_L	Average linear heat rating over the whole core	
q_{LIC}	Average linear heat rating in the inner core	
q_{LIB}	Average linear heat rating in the inner blanket	
q_{LB}	Average linear heat rating in the outer blanket	
R_1	L_{ib}/L_{ic}	Input
R_2	L_b/L_{ic}	Input
R_3	q_{LB}/q_{LIC}	Input
R	$(q_{LIB}/2)/q_{LB}$	

Table 1. Definition of parameters used in the computation of multiple stacked core

2.3 REACTOR POWER ITERATION

In the case of reactors with rather loose lattices using grid spacers, we sometimes obtain higher thermal output Q than that from the reference PWR plant Q_0 ($K=Q/Q_0>1.0$) because of lower core pressure drop. In order to get the results with the same thermal output for comparison, we have introduced a new power iteration scheme which is quite similar to the $C_{\Delta H}$ iteration in Reference /6/. For this purpose, Eq. (3) in Reference /6/ is modified as follows:

$$(25) \quad H_{2H} = H_1 + P_{R\Delta H} C_{\Delta H} \frac{F_{\Delta H}^{OP}}{K'} (H_2 - H_1).$$

The factor $P_{R\Delta H}$ is determined by iteration. For the first iteration, it is put equal to one. Then the ratio K is calculated. If this ratio is greater than one, the calculation is repeated with a higher values of $P_{R\Delta H}$ until K equals one. This iteration scheme is also applied to a heterogeneous reactor calculation.

2.4 AXIAL POWER DISTRIBUTION

In the previous version, the axial power distribution is assumed to be described by the chopped cosine distribution in both cases with and without the control rod insertion. On the other hand, the present version, if required, makes a computation with an arbitrary distribution given by a user in the form of numerical table. In this case, the local quantities such as the critical heat flux and the DNBR are calculated at the center of each axial segment.

Let f_i be a relative power in the i -th axial segment given by a user. The program normalizes them as follows:

$$(26) \quad \frac{\sum_{i=1}^{NC} f_i}{NC} = 1,$$

where NC is the number of axial segments. Note that all axial segments have the same length. Then, the axial form factor (peak/average) φ_{ax} is obtained by

$$(27) \quad \varphi_{ax} = \max f_i.$$

The hot spot heat flux at the surface of the i -th axial segment of the fuel rod is:

$$(28) \quad \phi_{HS}(i) = F_{qOP} \frac{q_L}{\pi d} \frac{f_i}{\phi_{ax}},$$

of which the average value is

$$\frac{F_{qOP}}{\phi_{ax}} \frac{q_L}{\pi d},$$

and the peak value is

$$\frac{F_{qOP} q_L}{\pi d}.$$

The hot channel water enthalpy corresponding to the i -th segment is:

$$(29) \quad H_{HS}(i) = H_1 + F_{\Delta HOP}(H_{2u} - H_1) \frac{\left\{ \sum_{j=1}^{i-1} f_j + \frac{f_i}{2} \right\}}{NC}.$$

On the other hand, the nominal heat flux distribution at the surface of the fuel rod in the highest rated coolant channels is:

$$(30) \quad \phi_N(i) = F_{qNOP} \frac{q_L}{\pi d} \frac{f_i}{\phi_{ax}},$$

The nominal water enthalpy distribution in these channels is:

$$(31) \quad H_N(i) = H_1 + \frac{F_{qN}}{\phi_{ax}} O_P(H_{2u} - H_1) \frac{\left\{ \sum_{j=1}^{i-1} f_j + \frac{f_i}{2} \right\}}{NC}.$$

In this case, the local quantities are calculated at all axial segments (not only in the upper half of the core). The position x in the print out shows the distance from the inlet of the core.

2.5 VARIOUS ADDITIONS

SYSTEM PARAMETERS: In the original version, the total pressure head of pump H_T and the average total heat transfer coefficient times the total surface of heat exchanger KF are assumed to be represented by Eqs. (21) and (10) in Reference /2/, respectively. They are written as follows:

$$(32) \quad H_T = PC0 + PC1 \times V - PC2 \times V^2,$$

with $PC0=111.678,$
 $PC1=22.244,$

$$PC3=4.0524,$$

and

$$(33) \quad KF = \frac{KF_0}{SG1 + SG2 \times (Q/Q_0)^{SG3} + SG4 \times (M_0/M)^{SG5}},$$

with

$$\begin{aligned} SG1 &= 0.58, \\ SG2 &= 0.18, \\ SG3 &= 0.24, \\ SG4 &= 0.24, \\ SG5 &= 0.8. \end{aligned}$$

The values of parameters in the above equations have been determined on the basis of the modern PWR plant of German design. In the present version, the values of these parameters can be replaced by input, if necessary.

CRITICAL HEAT FLUX CORRELATIONS: By the HADA code, the Dalle Donne-Hame correlation/3/ is mainly used as the critical heat flux correlation for both reactors with spiral rib spacers or grid spacers. In this correlation, the effect of spacer grids is taken into account by the V factor. Recently, a new correction factor for this effect has been proposed by D.C. Groenveld/8/ as follows:

$$(34) \quad K_3 = 1 + A \cdot \exp(B \cdot L_p/D_h),$$

where

$$A = 1.5 \times K_G^{0.5} (0.001 \times G)^{0.2},$$

$$B = 0.10,$$

$$K_G = \varepsilon^2 C_V,$$

L_p = distance from upstream spacer plane (m),

D_h = hydraulic equivalent diameter (m),

and

G = mass flux ($\text{kg/m}^2/\text{s}$).

A user can use this correction factor, if he likes.

3. MATHEMATICAL BACKGROUND

The program HADA computes the solution of a nonlinear algebraic system by iteration. This system is given by a set of equations:

$$(35) \quad F_j(x_i) = 0.$$

The elements of the solution vector $x_i (i=1, \dots, n)$ are the zeroes of the (n) relations F_j . For solving this equations, a simple Newton method is used as usually. In the first order Taylor approximation, one has:

$$(36) \quad F_j(x_i + \delta x_i) \approx F_j(x_i) + \frac{\partial F_j(x_i)}{\partial x_k} \delta x_k.$$

The condition $F_j(x_i + \delta x_i) \rightarrow 0$ is forced by setting the left hand side of the equations system equal to zero:

$$(37) \quad \frac{\partial F_j(x_i)}{\partial x_k} \delta x_k = -F_j(x_i).$$

Starting with an initial estimate x_i^0 , one obtains a series of approximations to the solution:

$$(38) \quad \frac{\partial F_j(x_i^v)}{\partial x_k} \delta x_k^{v+1} = -F_j(x_i^v),$$

and

$$(39) \quad x_k^{v+1} = x_k^v + \delta x_k^{v+1},$$

which is considered as adequate, if the related increment of all elements is less then a given positive number ε :

$$(40) \quad \max_k |\delta x_k^v / x_k^v| < \varepsilon.$$

The linear algebraic system (linear relative to δx) is solved by using a Gauß algorithm (with or without pivot search). The matrix of coefficients is:

$$(41.1) \quad a_j^k = \frac{\partial F_j(x_i^v)}{\partial x_k}$$

and the right hand sides are:

$$(41.2) \quad b_j = -F_j(x_i^v).$$

Five different methods based on the Gauß algorithm are available in the program:

- straightforward algorithm without any computational improvements,
- pivot method (only rows are exchanged),
- pivot method (rows and columns are exchanged),
- Gauß algorithm for a system with symmetrical coefficient matrix,
- Gauß algorithm for a symmetrical system using a reordered coefficient matrix.

The last two methods don't solve the original equations (41), but a derived system which is obtained by multiplication from the left with the transposed coefficient matrix. From

$$(42) \quad a_j^k \delta x_k = b_j,$$

we get the derived system:

$$(43) \quad a_j^1 a_1^k \delta x_k = a_j^1 b_1.$$

The new matrix of coefficients is symmetrical:

$$(44.1) \quad s_j = a_j^1 a_1^k.$$

The new right hand sides are:

$$(44.2) \quad c_j = a_j^1 b_1.$$

These two equations describe a new linear system replacing Eq. (42):

$$(45) \quad s_j^k \delta x_k = c_j.$$

To compute the elements of the coefficient matrix, we need the partial derivatives of the functions. They are approximated numerically by a first order Taylor expansion.

For $|x_k| \leq 10^{-6}$, we use:

$$f_1 = F_j(x_1, x_2, \dots, x_k - 0.001, \dots, x_n),$$

$$f_2 = F_j(x_1, x_2, \dots, x_k + 0.001, \dots, x_n),$$

$$\Delta x = 0.002,$$

and for $|x_k| > 10^{-6}$:

$$f_1 = F_j(x_1, x_2, \dots, 0.999 \times x_k, \dots, x_n),$$

$$f_2 = F_j(x_1, x_2, \dots, 1.001 \times x_k, \dots, x_n),$$

$$\Delta x = 0.002 \times x_k.$$

The derivatives are then calculated from

$$(46) \quad \frac{\partial F_j(x_i)}{\partial x_k} = \frac{(f_2 - f_1)}{\Delta x}.$$

In the testphase, the increment Δx and the accuracy of the calculation have been varied, but the presented values and double precision arithmetic proved to be optimal.

4. INPUT DATA

The input parameters are divided into five groups

1. problem identification
(unit 47)
2. control parameters for the input flow and programmable options
(unit 05)
3. common physical parameters
(unit INP)
4. special physical parameters
(unit JNP)
5. physical parameters for the computation of the critical heat flux
(unit 05).

All data except character strings and parts of third and fifth groups are read without format control (with the free format) as follows:

```
READ(...,*,...) ...
```

This means that, if there are more than one input datum per line required, successive data must be separated by at least one blank or a comma and may be entered in the same input line or, if necessary in continuation lines. It is not allowed to replace zeroes by blanks as in formatted read. Hence, as many data as required must be present. The input data set should **NOT** be

line numbered, to avoid misinterpreting in the case of continuation lines (the line numbers are treated as input data !).

4.1 PROBLEM IDENTIFICATION (UNIT 47)

A text of up to 55 characters can be entered as a problem identification. This text and the current date and time are used as header lines in all output data sets. If there are more characters than the allowed maximum, truncation occurs.

4.2 CONTROL PARAMETERS AND OPTIONS (UNIT 05)

The data of this group is read from the system input stream (unit 05) named SYSIN (IBM standards). The following values are required in particular:

1. line INP integer unit number associated to the data set containing the common physical parameters.

2. line IOP1 integer option controlling the computation of the pumping power in the primary circuit.
=1 constant pumping power: $H_T = H_{T0} \times M_0/M$,
=2 pumping power is computed using a given pump characteristic:
 $H_T = PC0 + (PC1 - PC2 \times V) \times V$.

Other values are not allowed.

IOP2 integer option selecting the reactor type.
=0 computation of the power fraction K for a given pressure drop Δp ,
=1 computing the design parameters of a reactor with a homogeneous core,
=2 computing the design parameters of a reactor with a heterogeneous core.

Other values are not allowed.

IOP3 integer option controlling the construction of the linear system.
<0 the coefficient matrix is constructed in

inverse order as the functional equations,
≥0 the coefficient matrix is constructed in
the same order as the functional equations
(use this method only).

IOP4 integer option selecting the solution method.
=1 Gauß algorithm without improvements
(use this method),
=2 Gauß algorithm with pivot search
(rows),
=3 Gauß algorithm with pivot search
(rows and columns),
=4 Gauß algorithm for a symmetrized
coefficient matrix,
=5 Gauß algorithm for a symmetrized
coefficient matrix with reordering of
the original matrix.

3. line IDR2 integer parameter controlling the output of the
results. This parameter is divided into two
subparameters:

$$\text{IDR2 and IMOD} = \text{IDR2}/10.$$

The subparameter IMOD denotes the number of
iteration steps between successive dumps of
the actual results. IDR2 controls the type
and the extent of this output in correspon-
dence to the following table :

IDR2	IMOD = 0
≤0	only the mean results are printed,
=1	the initial estimate is printed and after each iteration step the actual accuracy,
=2	as 1, and at the beginning of the iteration the coefficient matrix is printed before entering the elimination step,
=3	as 1,2, and at the beginning of the iteration the coefficient matrix is printed after leaving the elimination step,

IDR2 IMOD = IDR2/10

=10 as 1,2,3, and after solving the linear
=20 system the actual solutions are printed
=30 out every IMOD iteration step.
...

IDR3 integer parameter controlling the output of the
 heat flux calculations.
 <1 Only the most important results are
 printed,
 ≥1 additionally local data as a function of
 the axial position is printed into a
 separate data set.

The following input line is only necessary for IOP2 > 0. If IOP2 = 0, a special physical parameter must be present instead (see "Computation of the Power Ratio (IOP2=0, Unit 05)" on page 20).

4. line JNP integer unit number associated to the data set containing the special physical parameters

5. line GENAU real parameter denoting the required accuracy. The iteration is terminated, if the condition of Eq. (40) comes true (the boundary ϵ corresponds to GENAU).

DMAX real upper boundary for the increment of the solution vector. After each iteration step the condition of Eq. (40) is tested against DMAX. If any of the increments is greater than DMAX, the solution is divided by two, until Eq. (40) is met. In most cases a value of 0.5 will result in good convergence of the iteration. But in some cases a smaller value may be required to suppress problems of divergency.

ITMX integer maximum number of iteration steps. Non-convergent iterations are stopped after ITMX steps. Depending on the results, the computation may be repeated with a greater value of ITMX or with

updated parameters.

4.3 COMMON PHYSICAL PARAMETERS (UNIT INP)

The data of this group is read from unit INP, which must be assigned to the data set containing the input. At first, the program reads the following data by the read statement with the namelist "SYSTEM". The default values of parameters are shown in the parentheses, which correspond to those in the modern PWR plant of German design.

&SYSTEM

PC0 (111.678 m)
PC1 (22.244 m/(m/s))
PC2 (4.0524 m/(m/s)²)

These three parameters define the pump characteristics:

$$H_T = PC0 + (PC1 - PC2 \times V) \times V.$$

SG1 (0.58)
SG2 (0.18)
SG3 (0.24)
SG4 (0.24)
SG5 (0.80)

These five parameters (SG1-SG5) define the heat transfer coefficient times the total surface area of the heat exchangers in the whole system:

$$KF = \frac{KF_0}{SG1 + SG2 \times (Q/Q_0)^{SG3} + SG4 \times (M_0/M)^{SG5}}$$

NLP (4) number of primary coolant loop.

IOPTIN (0) option to read data with the free format,
=0 read the data with the free format and use them in the calculation,
=1 skip the following free formatted input.
(All free formatted data can be read in the present namelist input).

Meanings of the following parameters are given below.

QO (3.765D9 W)
OP (1.0)
FDHO (1.6)
CDHO (1.0)
AKS\$ (0.94)
ALC (0.0)
DN (1.707 W)
EAT\$ (0.774)
P20 (158.26 bar)
T20 (326.12 °C)
POS (64.5 bar)
DMO (1.88D4 kg/s)
DKO (1.55927D8 W/°C)
T10 (291.14 °C)
P10 (159.65 bar)
HR (70.6 m)
DNEl (5.4D7 W)
HTO (89.6 m)
QELO (1.3D9 W)

&END

When IOPTIN = 0, the following data, which are part of the above input, are read with the free format.

1. line QO real Q₀ [W]
thermal power of the reference Pressurized
Light Water Reactor.
2. line OP real O_p [-]
power plant overpower factor.
- FDHO real F_{ΔH} [-]
hot channel factor for the enthalpy rise in
the core.
- CDHO real C_{ΔH} [-]
initial value of parameter to force a DNB ratio
of at least 1.3. If CDHO < 0, the absolute value
of CDHO is taken as C_{ΔH}, and the iteration to
force a DNB ratio ≥ 1.3 is not carried out.
- AKS real K' [-]

part of the total mass flow rate cooling the core.

3. line ALC real L_p [m]
=0.0 use Eq. (35) in Reference /2/ for the fuel rod total length L_R ,
>0.0 total length of the axial reflectors:
 $L_R = L_C + L_p$.
4. line DN real N [W]
total pumping power for the primary circuit.
- ETA real η [-]
efficiency of the water pumps in the primary circuit.
5. line P20 real P_{20} [bar]
water pressure at the outlet of the reference PWR.
6. line T20 real T_{20} [°C]
average water temperature at the outlet of the reference PWR.
7. line POS real P_{0s} [bar]
saturation pressure at the turbine of the reference PWR.
8. line DMO real M_0 [kg/s]
total mass flow rate in the primary circuit of the reference PWR.
9. line DK0 real KF_0 [W/°C]
heat transfer coefficient times the average total surface of the heat exchangers in the reference PWR.
10. line T10 real T_0 [°C]
average water temperature at the inlet of the reference PWR.
11. line P10 real P_{10} [bar]
water pressure at the inlet of the reference

PWR.

12. line HR real H_{R0} [m]
pressure head available for the rest of the primary circuit (besides the core) in the case of the reference PWR.
13. line DNEl real N_{e1} [W]
total electrical power for internal use in the plant.
14. line HTO real H_{T0} [m]
total pressure head of the water pumps in the primary circuit of the reference PWR.
15. line QELO real Q_{e10} [W]
net electrical power of the reference PWR.

4.4 SPECIAL PHYSICAL PARAMETERS (UNIT 05, JNP)

The number of the required parameters and their meaning depend on the value of IOP2. For IOP2 = 0, the data is read from unit 05 (system input stream). For IOP2 > 0, the data of this group is read from unit JNP, which must be assigned to the data set containing the input.

4.4.1 Computation of the Power Ratio (IOP2=0, Unit 05)

In this case, the power ratio K for an Advanced Pressurized Light Water Reactor is computed from the data of the reference Pressurized Water Reactor (common physical parameters) and a fixed value for the pressure drop over the core.

4. line DPC real Δp_c [bar]
required pressure drop over the core of the Advanced Pressurized Water Reactor.
5. line GENAU real the same as the 5th line
DMAX real in "Control Parameters and Options (Unit 05)" on page 14.
ITMX integer

4.4.2 Reactor with a Homogeneous Core (Unit JNP)

For an Advanced Pressurized Water Reactor with a homogeneous core, the geometry and special factors are read from unit JNP, which must be assigned to the corresponding data set.

1. line P real p [m]
fuel rod pitch.

2. line D real d [m]
fuel rod diameter.

3. line AK0 real K_0 [-]
>0 spiral rib spacers are used. K_0 is a aspect ratio for the spiral spacer ribs.
<0 grid spacers are used. The solidity ϵ and the modified drag coefficient C_V are calculated in the following two ways:
=-1 As for ϵ , see the description of 7th line.

$$C_V = 7.997 + \frac{167.12}{Re^{0.264}} + \frac{6.375 \times 10^{10}}{Re^{2.79}},$$

When the product $\epsilon^2 C_V$ calculated is greater than 5.2, then the relation

$$C_V = \frac{5.2}{\epsilon^2}$$

replaces the above equation.

=-2 the product $\epsilon^2 C_V$ is calculated by

$$\frac{1}{2} \epsilon^2 C_V = \frac{1}{2} \left(0.8189 + \frac{17.114}{Re^{0.264}} + \frac{0.6528 \times 10^{10}}{Re^{2.79}} \right).$$

The maximum value of the product is also 5.2.

4. line AK1 real K_1 [-]
ratio denoting the part of the total core cross section which is occupied by fuel rods and the subchannels between them.

AKL\$ real K_{KL} [-]
>10 absolute value of linear heat rating [W/m],

<0 core height [m],
otherwise
correction factor for the relationship
between average fuel rod linear rating
and p/d ratio (Eq. (31) in Reference /2/).

5. line AK2 real K_2 [-]
fraction of the "non-useful" cross section
area (interface between fuel elements, control
and structure rods) occupied by flowing water.

6. line DEQ real D_{eq} [m]
equivalent diameter, diameter of a circle with
the same area as the cross section of the core.

When $AK0 > 0$ (spiral rib spacers),

7. line HZUD real H/d [-]
pitch to diameter ratio for the spiral rib
spacers.

When $AK0 < 0$ (grid spacers),

7. line NGI integer NGI
number of grids including top and bottom ones,
SG real see Figure 1 on page 117. [m],
BG real see Figure 1 on page 117. [m],
SCLAD real thickness of cladding [m].
The parameters SG and BG are used to calculate
solidity ϵ . When $BG > 1.0$, the solidity is
calculated by
$$\epsilon = SG - BG * (p - d),$$

which is similar to Eq. (74) in Reference /2/ .

8. line AKI real K_I [-]
inlet pressure drop coefficient.
RK real K_R [m]
average roughness height of the surface of fuel
rod.

4.4.3 Reactor with a Heterogeneous Core (unit JNP)

For an Advanced Pressurized Water Reactor with a heterogeneous core, the geometry and special factors are read from a data set assigned to unit JNP. In this case, the reactor core is divided into two zones (seed and blanket).

- | | | | |
|---------|--------|------|---|
| 1. line | RK1 | real | $K_1 [-]$
ratio of cross section area of seed to cross section area of blanket. |
| | AKLS\$ | real | $K_{KLs} [-]$
correction factor for the relationship between seed fuel rod linear rating and p/d ratio. |
| | AKLB\$ | real | $K_{KLb} [-]$
correction factor for the relationship between blanket fuel rod linear rating and p/d ratio. |
| 2. line | RK2S | real | $K_{2s} [-]$
ratio denoting the part of the seed cross section which is occupied by fuel rods and relative cooling water. |
| 3. line | RK2B | real | $K_{2b} [-]$
ratio denoting the part of the blanket cross section which is occupied by fuel rods and relative cooling water. |
| 4. line | RK3 | real | $K_3 [-]$
power ratio seed over blanket. |
| 5. line | QVS | real | $q_{vs} [W/m^3]$
average volume power density (seed). |
| 6. line | DS | real | $d_s [m]$
fuel rod diameter (seed). |
| 7. line | DEQ | real | $D_{eq} [m]$
equivalent diameter, diameter of a circle with the same area as the cross section of the core. |
| 8. line | ALSC | real | $L_{sC} [m]$ |

axial distance of spacer grids in the active core region (seed).

9. line ALSR real L_{sR} [m]
axial distance of spacer grids in the fission gas plenum region (seed).
10. line DKI real K_I [-]
inlet pressure drop coefficient.
11. line RKS real K_{Rs} [m]
average roughness height on the surface of seed fuel rod.
- RKB real K_{Rb} [m]
average roughness height on the surface of blanket fuel rod.
12. line RKO real K_0 [-]
aspect ratio for the spiral spacer ribs (blanket).
13. line HZUDB real H/d [-]
pitch to diameter ratio for the spiral rib spacers (blanket).

4.5 PHYSICAL PARAMETERS FOR THE CHF COMPUTATIONS (UNIT 05)

This group of data is read again from unit 05 (system input stream). The input stream contains options and parameters for the critical heat flux correlations. Four different correlations are available according to Reference /2/. The computation of the critical heat flux is done for a singular rod. At first, the program reads the following data by the read statement with the namelist "DNBR", which specify the values of parameters used in the case of computation of multiple stacked core.

&DNBR

- IBLT (0) =0 the same as in the previous version. The parameters in the namelist are read again by the program later with the free format.
- =1 multiple stacked core. The critical heat flux is calculated by setting the coolant inlet

at the bottom of each part (inner core,blanket).
=2 multiple stacked core. The critical heat flux
is calculated by setting the coolant inlet
at the lowest part of the whole core.

NAC	(1)	number of inner cores.
RR1	(1.0)	R_1 [-] (inner blanket height) / (inner core height)
RR2	(0.6)	R_2 [-] (outer blanket height) / (inner core height)
RR3	(0.2)	R_3 [-] (average linear heat rating in outer blanket) / (average linear heat rating in inner core).
FIAX2	(0.1)	φ_{ax2} [-] axial power form factor in the blanket.

Meanings of the following parameters are given
below.

FIAX	(1.48)
FQ	(2.1)
AK4	(0.1)
NC	(40)
OP	(1.12)
Q10	(0.0)
Q20	(9.157)
Q40	(6.507)
Q1N	(1.748)
Q2N	(7.540)
Q4N	(8.783)
FQN	(1.776)

&END

When IBLT = 0 (not multiple stacked core), the following data are read with
the free format.

6. line FIAX real φ_{ax} [-]
form factor accounting for the axial power
distribution. If $\varphi_{ax} \leq 0$, the axial power
distribution is given in the form of table in
the 15th and 16th lines.

7. line AK real K [W/m^2] 2.37×10^6
constant used in the Shippingport relation.

This parameter must be present as a dummy entry (its value has no importance), but it is not used in the latest version of the program.

8. line H0 real H_0 [J/kg] 1.588×10^6
enthalpy base (depending on pressure) for the Shippingport relation. As the previous parameter this datum must be present as a dummy entry.
9. line FQ real F_q [-]
hot channel factor for the heat flux at the fuel rod surface.
10. line AK4 real K_4 [-]
ratio between the shortening of the core active length due to insertion of the control rods and core active length without control rod insertion. This value has no meaning if $\varphi_{ax} \leq 0$.
11. line NC integer N_c [-]
number of axial nodes or axial segments for the computation of the local heat fluxes.
12. line OP real O_p [-]
overpower factor for the fuel rod under consideration.
13. line Q10 real option for Columbia-EPRI correlation.
>0.0 the same as in /6/,
=0.0 V factor is set to be one.
- Q20 real option for Dalle Donne-Hame correlation for grids.
>0.0 the same as in /3/,
=0.0 modified on the basis of /8/,
<0.0 the same as above, but the distance from the upstream grid is set to be the distance between two grids(more conservative assumption).
- Q40 real a dummy entry.
- Q1N real Q_1 1.748
- Q2N real Q_2 7.540

Q4N real Q4 8.783
parameters used in the latter version of
our CHF correlation /3/.

14.line FQN real F_{qN} [-]
factor for the maximal heat flux accounting
for the axial and radial power distribution.

The following two lines are required when $\varphi_{ax} \leq 0.0$ (an arbitrary axial power distribution is given by input).

15.line AXDISA real f_i [-]
axial power distribution (NC entries).

16.line AXDISB real f_i [-]
axial power distribution deformed by control
rod insertion (NC entries).

5. OUTPUT

The program uses four output data sets associated to units 06, 08, 09 and 10. The first one, assigned to the system output data set (named SYSPRINT on IBM-systems), is used for the printing of system error messages. The second data set (unit 08) must be assigned to an existing file (named PROJECT.APWRD.DATA in the examples) with the following (or corresponding) DCB attributes

```
record format RECFM=VBS
record length LRECL=2996
block size    BLKSIZE=3000.
```

This data set is used as a result pool and contains the main results of consecutive runs. Data may be retrieved from this file by using one of the existing utility programs (see " 7. Utility Programs" on page 95).

The input data, the main results, and, if required, the matrix, vector, and solution dumps are printed out to unit 09.

The local results of the critical heat flux calculation are printed out to unit 10.

The output in units 09 and 10 is self-explaining; the same variable names are used as in " 4. Input Data" on page 13 for the input parameters. The variable names of the output parameters are explained in References /2//6/, so that no more detailed description is necessary here. In " 6. Examples" on page 28, the output data of three sample runs are listed.

In the case of multiple stacked cores (JAERI design), the results of critical heat flux calculated by both method (IBLT = 1 and 2) are printed out to units 09 and 10, regardless of the input value of IBLT. The ordering of outputs is as follows: at first, the results by specified method by IBLT are printed out, and next those by the alternative method are printed. In this case and the case with the arbitrary axial power distribution given in the table form, the local quantities are calculated and printed out at all axial nodes or segments. The position x in the print out shows the distance from the inlet of the core.

6. EXAMPLES

To demonstrate the use of the program, three sample runs are presented. The first sample is for a homogeneous reactor with the water pumping power and steam generator heat transfer from the default characteristics. In this sample, the core height is specified by input, and the axial power distribution is described by the chopped cosine distribution with the axial form factor $\phi_{ax} = 1.45$. The input data and the control statements are shown at first. The used load module must be generated at first as described in " 8. Installing the Programs" on page 105. For this sample, the entire output is shown (units 09 and 10 in this order).

The second sample is similar to the first one except that the axial power distribution is given by input in the form of numerical table. In this case, the print out of the local result (unit 10) is omitted.

The third sample is for a reactor with a double stacked core. The water pumping power and steam generator heat transfer are specified by input. In this case, the print out of the local result (unit 10) is omitted.

The example of heterogeneous reactor is presented in /1/.

6.1 SAMPLE 1, HOMOGENEOUS CORE, CHOPPED COSINE DISTRIBUTION (KFK DESIGN)

CONTROL STATEMENTS AND INPUT:

```
Starting in column 1
↓
//PROJECT1 JOB (.....,.....,.....),.....,MSGCLASS=A,TIME=(1,00)
//*
// EXEC PGM=HADA
//STEPLIB DD DISP=SHR,DSN=PROJECT.HADA.LOAD
//*****
//*
//* ALLOCATE FILE 6 TO GET FORTRAN ERROR MESSAGES
//*
//FT06F001 DD DUMMY
//*T06F001 DD SYSOUT=*,
//*      DCB=(LRECL=133,BLKSIZE=3857,RECFM=FBA)
//*****
//*
//*      UNIT 8      DATA POOL FOR RESULT
//*
//FT08F001 DD DISP=(MOD,PASS),DSN=PROJECT.APWRD.DATA
//*****
//**
//**      UNIT 9      MAIN RESULT
//**
//FT09F001 DD SYSOUT=*,
//      DCB=(LRECL=133,BLKSIZE=3857,RECFM=FBA)
//FT10F001 DD SYSOUT=*,
//      DCB=(LRECL=133,BLKSIZE=3857,RECFM=FBA)
//*****
//**
//**      UNIT 47     PROBLEM IDENTIFICATION
//**
//FT47F001 DD *
HOMOGENEOUS REACTOR - 24 CONTROL ROD PER ELEMENT.
//*****
//**
//**      UNIT INP    COMMON PHYSICAL PARAMETERS
//**
//FT01F001 DD *
&SYSTEM
```

```

&END
3.765E9          QO IN W
1.00,1.65,-1.0000,0.97  OP,FDHO,CDH,K'
0.0              ALC FUER LR=1.1885*LC+0.02 OR LC + ALC
1.7E7,0.774     N IN W,          ETA (NEU 8.9.83)
158.26          P20 IN BAR
326.12          T20 IN GRD C
64.5            POS IN BAR
1.8800E4        MO IN KG/S
1.55927E8       KFO IN W/GRD C
291.14          T10 IN GRD C
159.65          P10 IN BAR
70.6            HR IN M
5.4D7           NEL IN W
89.6            HTO IN M
1.3E9           NEL IN W
//*****
//**
//**           UNIT JNP      SPECIAL PHYSICAL PARAMETERS
//**
//FT02F001 DD *
11.8000E-3      P IN M
9.5E-3          D IN M              2 REAL 9.9.83
-1.             K0
.875052,-3.5    K1,KL  LINEAR RATING
.904265         K2
3.88910         DEQ IN M              1 REAL 9.9.83
12,.4D-3,2.2D-3,.64D-3  NGI,SG,BG,SCLAD IN M
1.2,5.D-6       KI,RK
//*****
//**
//**           UNIT 05      SYSIN
//**
//FT05F001 DD *
1              INP
2,1,1,1       IOP1,IOP2,IOP3,IOP4 .,1,.. HOMOGEN  <===
1,2           IDR1,IDR2
2             JNP              2      HOMOGEN  <===
1.D-5,.5,20   EPS,DMAX,IMAX
&DNBR
&END
1.45           PHIAX              4 REAL 9.9.83
2.37D6        K

```

```
1588.D3          HO
2.3             FQ          7 REAL 9.9.83
.1             K4
40            NC
1.12          OP
1.000,1.000,6.507,1.748,7.540,8.783 (JMP$,JMP2$,Q4)ALT,(Q1,Q2,Q4)NEU
2.07930        FQN          5 REAL 12.9.83
//
```


Main results (unit 09)

TITEL :

HOMOGENEOUS REACTOR - 24 CONTROL ROD PER ELEMENT.

08.06.89 08.34.26

EINGABEPARAMETER

Q0 = 3.76500E+09 W
 POS = 64.500 BAR
 P20 = 158.26 BAR
 T20 = 326.12 GRD C
 KFO = 1.55927E+08 WATT/GRD
 N = 1.70000E+07 WATT
 P10 = 159.65 BAR
 MO = 18800. KG/S
 FDHO = 1.6500
 CDH = 1.0000
 OPF = 1.0000
 T10 = 291.14 GRD C
 HR = 70.600 M
 NEL = 5.40000E+07 W
 ALC = 0.00000E+00 M

CONSTANT PUMP CHARACTERISTICS

$$HT = 111.68 + (22.24 - 4.05 * V) * V$$

WHERE $V = M / RO / 4$

KF IS CALCULATED AS

$$KF = KFO / (0.580 + 0.180*(Q/Q0)**0.240 + 0.240*(M0/M)**0.800)$$

$$EPSI = 0.28399141750077277$$

P = 1.18000E-02 M
 D = 9.50000E-03 M
 DH = 6.66148E-03 M
 K0 = -1.0000
 K1 = 0.87505
 K2 = 0.90426
 DEQ = 3.8891 M
 H/D = 0.00000E+00
 KI = 1.2000
 RK = 5.00000E-06 M
 P/D = 1.2421
 B = 0.00000E+00 M
 KL = 1.0000 -

12.09.1983

RLC = 3.5000 M
RLR = 4.1798 M
AT = 10.395 QM
NT = 86203
VM/VROD = 0.92087 CORE, 0.70121 CELL
VM/VFUEL = 1.2300 CORE, 0.93659 CELL
NGI=12

HOMOGENEOUS REACTOR

EPS = 1.00000E-03 %
DELTA = 50.000 %

ANFANGSWERTE

NAME	NR	EINHEIT	WERT	ZUWACHS
*****	***	*****	*****	*****
K	1	-	1.0000	0.00000E+00
Q	2	W	2.45770E+09	0.00000E+00
T1	3	GRD C	291.14	0.00000E+00
RO1	4	KG/CBM	745.55	0.00000E+00
P1	5	BAR	159.65	0.00000E+00
H1	6	J/KG	1.28910E+06	0.00000E+00
T2	7	GRD C	326.12	0.00000E+00
RO2	8	KG/CBM	664.73	0.00000E+00
H2	9	J/KG	1.49004E+06	0.00000E+00
TS	10	GRD C	280.40	0.00000E+00
PS	11	BAR	64.500	0.00000E+00
TQ	12	GRD C	308.63	0.00000E+00
ROQ	13	KG/CBM	709.37	0.00000E+00
PQ	14	BAR	158.95	0.00000E+00
M	15	KG/S	18736.	0.00000E+00
KF	16	W/GRD	1.55825E+08	0.00000E+00
HT	17	M	91.473	0.00000E+00
HC	18	M	21.350	0.00000E+00
DP	19	BAR	1.3900	0.00000E+00
Y	20	-	1.4412	0.00000E+00
TSU	21	GRD C	336.49	0.00000E+00
RO2U	22	KG/CBM	631.28	0.00000E+00
H2U	23	J/KG	1.56116E+06	0.00000E+00
TQU	24	GRD C	308.63	0.00000E+00
ROQU	25	KG/CBM	709.37	0.00000E+00
NY	26	QM/S	1.26052E-07	0.00000E+00
U	27	M/S	4.5533	0.00000E+00
RE	28	-	2.40628E+05	0.00000E+00
LAM	29	-	1.97272E-02	0.00000E+00
ITER =	0 ABS :		1.31250E+09	2 *** REL : 0.50000 2
ITER =	1 ABS :		1.01615E+08	2 *** REL : 2.75636E-02 2
ITER =	2 ABS :		4.39442E+05	2 *** REL : 1.04442E-03 28
ITER =	3 ABS :		284.67	2 *** REL : 2.10145E-05 28

LOESUNGSVEKTOR UND ERREICHTE GENAUGIGKEIT

NAME	NR	EINHEIT	WERT	ZUWACHS
****	**	*****	*****	*****
K	1	-	1.0060	1.10907E-08
Q	2	W	3.78773E+09	41.756
T1	3	GRD C	291.65	1.24336E-06
RO1	4	KG/CBM	744.69	1.19477E-05
P1	5	BAR	160.28	-3.57297E-08
H1	6	J/KG	1.29175E+06	1.51336E-03
T2	7	GRD C	327.39	1.16058E-08
RO2	8	KG/CBM	660.99	-7.77667E-07
H2	9	J/KG	1.49833E+06	6.23687E-04
TS	10	GRD C	280.80	7.32912E-07
PS	11	BAR	64.889	7.15349E-07
TQ	12	GRD C	309.52	6.27483E-07
ROQ	13	KG/CBM	707.42	-7.04358E-07
PQ	14	BAR	159.27	-1.78648E-08
M	15	KG/S	18335.	2.81178E-04
KF	16	W/GRD	1.55134E+08	0.39003
HT	17	M	95.058	1.20574E-07
HC	18	M	27.640	-9.32642E-07
DP	19	BAR	2.0186	-3.57297E-08
Y	20	-	1.4571	-6.26527E-08
TSU	21	GRD C	337.88	-8.08796E-08
RO2U	22	KG/CBM	626.16	-7.71460E-07
H2U	23	J/KG	1.57143E+06	3.07569E-04
TQU	24	GRD C	314.76	5.81240E-07
ROQU	25	KG/CBM	695.08	-6.06774E-07
NY	26	QM/S	1.26141E-07	-1.25214E-16
U	27	M/S	4.5475	7.37065E-08
RE	28	-	2.40152E+05	4.27055E-03
LAM	29	-	2.07249E-02	-2.29895E-11
IPOW=1	PRDH=	1.0000000000000000		
ITER =	4 ABS :	9.22413E+06	2 *** REL :	2.43527E-03 2
ITER =	5 ABS :	1588.4	2 *** REL :	6.83857E-05 28

LOESUNGSVEKTOR UND ERREICHTE GENAUGIGKEIT

NAME	NR	EINHEIT	WERT	ZUWACHS
****	**	*****	*****	*****
K	1	-	1.0036	1.92751E-09
Q	2	W	3.77850E+09	7.2571
T1	3	GRD C	291.45	3.59058E-07
RO1	4	KG/CBM	745.07	1.09409E-05
P1	5	BAR	160.28	3.84785E-07
H1	6	J/KG	1.29069E+06	-2.16575E-03
T2	7	GRD C	327.14	-2.21443E-07
RO2	8	KG/CBM	661.75	-8.39807E-08
H2	9	J/KG	1.49665E+06	-9.00189E-04
TS	10	GRD C	280.64	1.27216E-07
PS	11	BAR	64.731	1.24324E-07
TQ	12	GRD C	309.29	6.88079E-08
ROQ	13	KG/CBM	707.94	9.46105E-07
PQ	14	BAR	159.27	1.92393E-07
M	15	KG/S	18346.	-7.70559E-05
KF	16	W/GRD	1.55167E+08	-0.13981
HT	17	M	95.047	3.21400E-06
HC	18	M	27.637	4.86024E-06
DP	19	BAR	2.0193	3.84785E-07
Y	20	-	1.4587	-2.80511E-08
TSU	21	GRD C	337.62	-1.82842E-07
RO2U	22	KG/CBM	627.11	-3.80031E-07
H2U	23	J/KG	1.56953E+06	-4.58865E-04
TQU	24	GRD C	314.54	8.81084E-08
ROQU	25	KG/CBM	695.63	-1.39299E-06
NY	26	QM/S	1.26132E-07	2.24004E-16
U	27	M/S	4.5465	-9.99164E-09
RE	28	-	2.40115E+05	-0.36833
LAM	29	-	2.07251E-02	2.03163E-09
IPOW=2	PRDH=	1.0060366786123589		
ITER =	6 ABS :	1.34089E+07	2 *** REL :	3.54874E-03 2
ITER =	7 ABS :	4191.0	2 *** REL :	9.49362E-05 28

LOESUNGSVEKTOR UND ERREICHTE GENAUGIGKEIT

NAME	NR	EINHEIT	WERT	ZUWACHS
*****	**	*****	*****	*****
K	1	-	1.0000	-1.21407E-10
Q	2	W	3.76509E+09	-0.45710
T1	3	GRD C	291.16	2.12178E-07
RO1	4	KG/CBM	745.63	1.39737E-05
P1	5	BAR	160.28	6.14319E-07
H1	6	J/KG	1.28915E+06	-3.85197E-03
T2	7	GRD C	326.76	-3.32714E-07
RO2	8	KG/CBM	662.86	2.45707E-07
H2	9	J/KG	1.49421E+06	-1.62066E-03
TS	10	GRD C	280.40	-9.42756E-09
PS	11	BAR	64.502	-7.83078E-09
TQ	12	GRD C	308.96	-6.02680E-08
ROQ	13	KG/CBM	708.69	9.67820E-07
PQ	14	BAR	159.27	3.07159E-07
M	15	KG/S	18361.	-2.00911E-04
KF	16	W/GRD	1.55216E+08	-0.32999
HT	17	M	95.032	5.05311E-06
HC	18	M	27.631	7.88330E-06
DP	19	BAR	2.0204	6.14319E-07
Y	20	-	1.4610	-2.56467E-08
TSU	21	GRD C	337.25	-2.35401E-07
RO2U	22	KG/CBM	628.49	-1.75679E-07
H2U	23	J/KG	1.56677E+06	-8.47667E-04
TQU	24	GRD C	314.20	-1.16118E-08
ROQU	25	KG/CBM	696.43	9.51324E-07
NY	26	QM/S	1.26121E-07	-1.56179E-16
U	27	M/S	4.5450	-5.59408E-08
RE	28	-	2.40061E+05	-0.78497
LAM	29	-	2.07254E-02	4.33034E-09

CONVERGENCE REACHED AFTER 3 ITERATIONS OVER THE REACTOR POWER: PRDH = 1.014872

ERGEBNISSE

Q = 3.76509E+09 W
K = 1.0000
PS = 64.502 BAR
TS = 280.40 GRD C
P1 = 160.28 BAR
T1 = 291.16 GRD C
T2 = 326.76 GRD C
M = 18361. KG/S
NP = 1.76098E+07 W
QNT = 1.30066E+09 W
QNT/QELO = 1.0005

***** ZUSATZ 08.09.1983 *****

KS = 0.97000 -
ETA = 0.77400 -
MS = 17810. KG/S
NPEL = 2.27517E+07 W

HOMOGENEOUS REACTOR WITH GRID SPACERS

LC = 3.5000 M
LR = 4.1798 M
T2U = 337.25 GRD C
U = 4.5450 M/S
RE = 2.40061E+05
LAMBDA = 2.07254E-02
DIST = 0.37998
\$K = 1.1569 (=CV*EPS*EPS)
DP = 2.0204 BAR
DPTOT = 2.3309 BAR

DPP = 6.9488 BAR

PRDH = 1.0149

CDH = 1.0000

CHF-CALCULATIONS

LC = 3.5000 M
T1 = 291.16 GRD C
RO1 = 745.63 KG/CBM
P1 = 160.28 BAR
H1 = 1.28915E+06 J/KG
T2 = 337.25 GRD
P2 = 158.26 BAR
ROQ = 696.43 KG/CBM
U = 4.5450 M/S
QL = 12479. W/M
D = 9.50000E-03 M
DH = 6.66148E-03 M
PZUD = 1.2421

EINGABEDATEN

FIAX = 1.4500
AK = 2.37000E+06
H0 = 1.58800E+06 J/KG
FQ = 2.3000
K4 = 0.10000
NC = 40
OP = 1.1200
Q10 = 1.0000
Q20 = 1.0000
Q40 = 6.5070
Q1N = 1.7480
Q2N = 7.5400
Q4N = 8.7830
FQN = 2.0793

ERGEBNISSE

X = 1.4371
PI/2X = 1.0931
LC' = 3.8257

RLCR = 3.150
RLCR' = 3.476
V1 = 0.70000E+00 WSC-2
CG' = 0.80219E+00 COLUMBIA-EPRI
V2 = 0.85680E+00 EIGENE,NEU

OVERPOWER FACTOR : 1.0000

POS X	T(X)	TW	COLUMBIA-EPRI			EDLUND			WSC-2			EIGENE,NEU			
			CHF	SM	SMLWR	CHF	SM	SMLWR	CHF	SM	SMLWR	CHF	SM	SMLWR	
0	0.00	325.87	348.92	1.973E+06	2.05	1.99	1.657E+06	1.72	1.56	2.352E+06	2.45	2.37	2.160E+06	2.25	2.18
1	0.09	328.09	348.89	1.869E+06	1.95	1.89	1.590E+06	1.66	1.50	2.233E+06	2.33	2.25	2.047E+06	2.13	2.06
2	0.17	330.24	348.87	1.769E+06	1.86	1.80	1.526E+06	1.60	1.45	2.117E+06	2.22	2.14	1.937E+06	2.04	1.96
3	0.26	332.32	348.84	1.672E+06	1.78	1.72	1.464E+06	1.56	1.40	2.004E+06	2.13	2.05	1.830E+06	1.95	1.88
4	0.35	334.31	348.80	1.577E+06	1.71	1.65	1.403E+06	1.52	1.37	1.894E+06	2.05	1.97	1.726E+06	1.87	1.80
5	0.44	336.21	348.77	1.484E+06	1.65	1.58	1.344E+06	1.49	1.34	1.785E+06	1.98	1.90	1.625E+06	1.80	1.73
6	0.52	338.01	348.73	1.393E+06	1.59	1.53	1.286E+06	1.47	1.33	1.679E+06	1.92	1.84	1.525E+06	1.75	1.68
7	0.61	339.70	348.69	1.303E+06	1.55	1.49	1.229E+06	1.46	1.32	1.574E+06	1.87	1.79	1.427E+06	1.69	1.63
8	0.70	341.27	348.65	1.215E+06	1.50	1.45	1.172E+06	1.45	1.32	1.469E+06	1.82	1.75	1.330E+06	1.65	1.59
9	0.79	342.72	348.60	1.127E+06	1.47	1.42	1.115E+06	1.45	1.32	1.366E+06	1.78	1.71	1.235E+06	1.61	1.55
10	0.87	344.04	348.55	1.041E+06	1.44	1.39	1.058E+06	1.46	1.34	1.263E+06	1.75	1.68	1.140E+06	1.58	1.52
11	0.96	345.25	348.50	9.545E+05	1.41	1.37	1.000E+06	1.48	1.37	1.161E+06	1.72	1.66	1.046E+06	1.55	1.50
12	1.05	346.32	348.44	8.688E+05	1.39	1.35	9.421E+05	1.51	1.41	1.059E+06	1.69	1.64	9.526E+05	1.52	1.48
13	1.14	346.73	348.38	7.833E+05	1.37	1.33	8.826E+05	1.54	1.47	9.565E+05	1.67	1.63	8.592E+05	1.50	1.46
14	1.22	346.71	348.31	6.977E+05	1.36	1.33	8.214E+05	1.60	1.54	8.537E+05	1.66	1.62	7.656E+05	1.49	1.45
15	1.31	346.68	348.24	6.119E+05	1.34	1.32	7.579E+05	1.67	1.65	7.503E+05	1.65	1.62	6.718E+05	1.48	1.45
16	1.40	346.66	348.16	5.257E+05	1.34	1.32	6.912E+05	1.76	1.80	6.459E+05	1.64	1.62	5.774E+05	1.47	1.45
17	1.49	346.63	348.07	4.388E+05	1.33	1.32	6.204E+05	1.89	2.04	5.403E+05	1.64	1.63	4.823E+05	1.47	1.46
18	1.57	346.61	347.96	3.511E+05	1.33	1.33	5.438E+05	2.06	2.44	4.332E+05	1.64	1.65	3.861E+05	1.47	1.47
19	1.66	346.58	347.84	2.622E+05	1.34	0.00	4.587E+05	2.34	0.00	3.244E+05	1.65	0.00	2.886E+05	1.47	0.00
20	1.75	346.55	347.69	1.721E+05	1.34	0.00	3.600E+05	2.81	0.00	2.134E+05	1.66	0.00	1.895E+05	1.48	0.00

MINIMALWERTE

CORRELATION	SMMIN	X	POS			
COLUMBIA-EPRI	1.3327	1.5750	18	1.3197	1.4000	16
EDLUND	1.4515	0.70000	8	1.3173	0.70000	8
WSC-2	1.6416	1.4875	17	1.6215	1.3125	15
EIGENE,NEU	1.4653	1.4875	17	1.4503	1.3125	15

X\$ = 9.72363E-02

X\$ = 9.45153E-02

OVERPOWER FACTOR : 1.1200

POS X	T(X)	TW	COLUMBIA-EPRI			EDLUND			WSC-2			EIGENE,NEU			
			CHF	SM	SMLWR	CHF	SM	SMLWR	CHF	SM	SMLWR	CHF	SM	SMLWR	
0	0.00	329.52	348.92	1.977E+06	1.84	1.78	1.657E+06	1.54	1.40	2.352E+06	2.18	2.11	2.160E+06	2.01	1.95
1	0.09	331.90	348.89	1.874E+06	1.74	1.69	1.590E+06	1.48	1.34	2.233E+06	2.08	2.01	2.047E+06	1.91	1.84
2	0.17	334.20	348.87	1.773E+06	1.66	1.61	1.526E+06	1.43	1.29	2.117E+06	1.99	1.91	1.937E+06	1.82	1.75
3	0.26	336.41	348.84	1.676E+06	1.59	1.53	1.464E+06	1.39	1.25	2.004E+06	1.90	1.83	1.830E+06	1.74	1.68
4	0.35	338.51	348.80	1.580E+06	1.53	1.47	1.403E+06	1.36	1.22	1.894E+06	1.83	1.76	1.726E+06	1.67	1.61
5	0.44	340.49	348.77	1.487E+06	1.48	1.42	1.344E+06	1.33	1.20	1.785E+06	1.77	1.70	1.625E+06	1.61	1.55
6	0.52	342.35	348.73	1.396E+06	1.43	1.37	1.286E+06	1.31	1.19	1.679E+06	1.72	1.65	1.525E+06	1.56	1.50
7	0.61	344.07	348.69	1.306E+06	1.38	1.33	1.229E+06	1.30	1.18	1.574E+06	1.67	1.60	1.427E+06	1.51	1.45
8	0.70	345.65	348.65	1.217E+06	1.35	1.30	1.172E+06	1.30	1.18	1.469E+06	1.63	1.56	1.330E+06	1.47	1.42
9	0.79	346.84	348.60	1.130E+06	1.31	1.27	1.115E+06	1.30	1.18	1.366E+06	1.59	1.53	1.235E+06	1.44	1.38
10	0.87	346.81	348.55	1.043E+06	1.29	1.24	1.058E+06	1.30	1.20	1.263E+06	1.56	1.50	1.140E+06	1.41	1.36
11	0.96	346.79	348.50	9.568E+05	1.26	1.22	1.000E+06	1.32	1.22	1.161E+06	1.53	1.48	1.046E+06	1.38	1.34
12	1.05	346.76	348.44	8.709E+05	1.24	1.21	9.421E+05	1.34	1.26	1.059E+06	1.51	1.47	9.526E+05	1.36	1.32
13	1.14	346.73	348.38	7.852E+05	1.23	1.19	8.826E+05	1.38	1.31	9.565E+05	1.49	1.46	8.592E+05	1.34	1.31
14	1.22	346.71	348.31	6.995E+05	1.21	1.19	8.214E+05	1.42	1.38	8.537E+05	1.48	1.45	7.656E+05	1.33	1.30
15	1.31	346.68	348.24	6.135E+05	1.20	1.18	7.579E+05	1.49	1.47	7.503E+05	1.47	1.45	6.718E+05	1.32	1.29
16	1.40	346.66	348.16	5.271E+05	1.20	1.18	6.912E+05	1.57	1.61	6.459E+05	1.47	1.45	5.774E+05	1.31	1.30
17	1.49	346.63	348.07	4.400E+05	1.19	1.18	6.204E+05	1.68	1.82	5.403E+05	1.47	1.46	4.823E+05	1.31	1.30
18	1.57	346.61	347.96	3.520E+05	1.19	1.19	5.438E+05	1.84	2.18	4.332E+05	1.47	1.47	3.861E+05	1.31	1.31
19	1.66	346.58	347.84	2.630E+05	1.20	0.00	4.587E+05	2.09	0.00	3.244E+05	1.48	0.00	2.886E+05	1.31	0.00
20	1.75	346.55	347.69	1.726E+05	1.20	0.00	3.600E+05	2.51	0.00	2.134E+05	1.49	0.00	1.895E+05	1.32	0.00

MINIMALWERTE

CORRELATION	SMMIN	X	POS			
COLUMBIA-EPRI :	1.1932	1.5750	18	1.1815	1.4000	16
EDLUND :	1.2960	0.70000	8	1.1761	0.70000	8
WSC-2 :	1.4657	1.4875	17	1.4478	1.3125	15
EIGENE,NEU :	1.3083	1.4875	17	1.2949	1.3125	15

X\$ = 0.15408

X\$ = 0.15105

Local results from CHF calculations (unit 10)

TITEL :

HOMOGENEOUS REACTOR - 24 CONTROL ROD PER ELEMENT.

08.06.89 08.34.26

OVERPOWER FACTOR : 1.0000

POS	X	T(X)	P(X)	H(X)	HFG(X)	ALFA(X)	RE(X)	PHIN(X)	TW(X)	TW1	TW2
		CORRELATION		PHICHF(X)	PHIHS(X)	PHIHSCR(X)	SM(X)	SMCR(X)	X\$X(X)	X\$XR(X)	

LOKALES SIEDEN :		0.000	M, TB =	348.92							
0	0.00	325.87	159.27	1.5182E+06	9.3581E+05	3.4402E+04	2.4912E+05	8.6942E+05	348.92	351.14	348.92
		COLUMBIA-EPRI :		1.97266E+06	9.61699E+05	1.06056E+06	2.051	1.994	-0.13782	-0.13782	
		EDLUND :		1.65704E+06			1.723	1.564			
		WSC-2 :		2.35161E+06			2.445	2.368			
		EIGENE,NEU :		2.15978E+06			2.246	2.181			
LOKALES SIEDEN :		0.087	M, TB =	348.89							
1	0.09	328.09	159.22	1.5365E+06	9.3621E+05	3.4569E+04	2.5087E+05	8.6717E+05	348.89	353.17	348.89
		COLUMBIA-EPRI :		1.86947E+06	9.59218E+05	1.05724E+06	1.949	1.888	-0.11983	-0.11798	
		EDLUND :		1.59033E+06			1.658	1.500			
		WSC-2 :		2.23285E+06			2.328	2.247			
		EIGENE,NEU :		2.04671E+06			2.134	2.065			
LOKALES SIEDEN :		0.175	M, TB =	348.87							
2	0.17	330.24	159.17	1.5547E+06	9.3661E+05	3.4752E+04	2.5258E+05	8.6046E+05	348.87	355.00	348.87
		COLUMBIA-EPRI :		1.76936E+06	9.51786E+05	1.04732E+06	1.859	1.795	-0.10194	-9.82817E-02	
		EDLUND :		1.52608E+06			1.603	1.446			
		WSC-2 :		2.11725E+06			2.224	2.142			
		EIGENE,NEU :		1.93707E+06			2.035	1.964			
LOKALES SIEDEN :		0.262	M, TB =	348.84							
3	0.26	332.32	159.12	1.5726E+06	9.3701E+05	3.4952E+04	2.5423E+05	8.4930E+05	348.84	356.62	348.84
		COLUMBIA-EPRI :		1.67196E+06	9.39443E+05	1.03085E+06	1.780	1.715	-8.42539E-02	-7.88444E-02	
		EDLUND :		1.46387E+06			1.558	1.403			
		WSC-2 :		2.00439E+06			2.134	2.051			
		EIGENE,NEU :		1.83046E+06			1.948	1.876			
LOKALES SIEDEN :		0.350	M, TB =	348.80							
4	0.35	334.31	159.07	1.5902E+06	9.3741E+05	3.5171E+04	2.5583E+05	8.3376E+05	348.80	358.02	348.80
		COLUMBIA-EPRI :		1.57693E+06	9.22251E+05	1.00793E+06	1.710	1.645	-6.68515E-02	-5.97867E-02	
		EDLUND :		1.40334E+06			1.522	1.370			
		WSC-2 :		1.89392E+06			2.054	1.971			
		EIGENE,NEU :		1.72648E+06			1.872	1.800			
LOKALES SIEDEN :		0.437	M, TB =	348.77							
5	0.44	336.21	159.02	1.6074E+06	9.3781E+05	3.5411E+04	2.5736E+05	8.1391E+05	348.77	359.20	348.77
		COLUMBIA-EPRI :		1.48395E+06	9.00301E+05	9.78712E+05	1.648	1.585	-4.98231E-02	-4.12253E-02	
		EDLUND :		1.34416E+06			1.493	1.344			
		WSC-2 :		1.78549E+06			1.983	1.903			

				EIGENE,NEU	:	1.62480E+06		1.805	1.734				
LOKALES	SIEDEN	:	0.525	M, TB =		348.73							
6	0.52	338.01	158.97	1.6240E+06		9.3820E+05	3.5674E+04	2.5881E+05	7.8987E+05	348.73	360.15	348.73	
				COLUMBIA-EPRI	:	1.39275E+06	8.73704E+05	9.43376E+05	1.594	1.532	-3.32547E-02	-2.32741E-02	
				EDLUND	:	1.28600E+06			1.472	1.327			
				WSC-2	:	1.67879E+06			1.921	1.844			
				EIGENE,NEU	:	1.52509E+06			1.746	1.677			
LOKALES	SIEDEN	:	0.612	M, TB =		348.69							
7	0.61	339.70	158.92	1.6399E+06		9.3860E+05	3.5963E+04	2.6019E+05	7.6175E+05	348.69	360.88	348.69	
				COLUMBIA-EPRI	:	1.30305E+06	8.42598E+05	9.02142E+05	1.546	1.487	-1.72301E-02	-6.04273E-03	
				EDLUND	:	1.22858E+06			1.458	1.318			
				WSC-2	:	1.57351E+06			1.867	1.793			
				EIGENE,NEU	:	1.42706E+06			1.694	1.628			
LOKALES	SIEDEN	:	0.700	M, TB =		348.65							
8	0.70	341.27	158.87	1.6551E+06		9.3900E+05	3.6277E+04	2.6147E+05	7.2969E+05	348.65	361.38	348.65	
				COLUMBIA-EPRI	:	1.21460E+06	8.07144E+05	8.55268E+05	1.505	1.448	-1.83015E-03	1.03635E-02	
				EDLUND	:	1.17160E+06			1.452	1.317			
				WSC-2	:	1.46937E+06			1.820	1.750			
				EIGENE,NEU	:	1.33041E+06			1.648	1.586			
LOKALES	SIEDEN	:	0.787	M, TB =		348.60							
9	0.79	342.72	158.82	1.6694E+06		9.3940E+05	3.6617E+04	2.6266E+05	6.9388E+05	348.60	361.67	348.60	
				COLUMBIA-EPRI	:	1.12717E+06	7.67525E+05	8.03047E+05	1.469	1.415	1.28675E-02	2.58447E-02	
				EDLUND	:	1.11478E+06			1.452	1.325			
				WSC-2	:	1.36610E+06			1.780	1.714			
				EIGENE,NEU	:	1.23490E+06			1.609	1.550			
LOKALES	SIEDEN	:	0.875	M, TB =		348.55							
10	0.87	344.04	158.77	1.6828E+06		9.3979E+05	3.6984E+04	2.6376E+05	6.5448E+05	348.55	361.74	348.55	
				COLUMBIA-EPRI	:	1.04054E+06	7.23945E+05	7.45806E+05	1.437	1.388	2.67891E-02	4.03066E-02	
				EDLUND	:	1.05781E+06			1.461	1.342			
				WSC-2	:	1.26344E+06			1.745	1.684			
				EIGENE,NEU	:	1.14026E+06			1.575	1.520			
LOKALES	SIEDEN	:	0.962	M, TB =		348.50							
11	0.96	345.25	158.71	1.6952E+06		9.4019E+05	3.7374E+04	2.6475E+05	6.1170E+05	348.50	361.61	348.50	
				COLUMBIA-EPRI	:	9.54486E+05	6.76629E+05	6.83903E+05	1.411	1.365	3.98646E-02	5.36618E-02	
				EDLUND	:	1.00036E+06			1.478	1.369			
				WSC-2	:	1.16112E+06			1.716	1.661			
				EIGENE,NEU	:	1.04625E+06			1.546	1.496			
LOKALES	SIEDEN	:	1.050	M, TB =		348.44							
12	1.05	346.32	158.66	1.7064E+06		9.4059E+05	3.7785E+04	2.6565E+05	5.6577E+05	348.44	361.30	348.44	
				COLUMBIA-EPRI	:	8.68802E+05	6.25821E+05	6.17724E+05	1.388	1.347	5.20287E-02	6.58294E-02	

	EDLUND	:	9.42097E+05			1.505	1.409			
	WSC-2	:	1.05890E+06			1.692	1.643			
	EIGENE,NEU	:	9.52636E+05			1.522	1.477			
LOKALES SIEDEN :	1.137 M,	TB =	348.38							
13	1.14 346.73 158.61		1.7165E+06	9.4098E+05	3.7962E+04	2.6600E+05	5.1692E+05	348.38	360.35	348.38
	COLUMBIA-EPRI :		7.83282E+05	5.71784E+05	5.47683E+05	1.370	1.334	6.32206E-02	7.67363E-02	
	EDLUND	:	8.82599E+05			1.544	1.465			
	WSC-2	:	9.56524E+05			1.673	1.630			
	EIGENE,NEU	:	8.59178E+05			1.503	1.464			
LOKALES SIEDEN :	1.225 M,	TB =	348.31							
14	1.22 346.71 158.56		1.7253E+06	9.4138E+05	3.7956E+04	2.6598E+05	4.6540E+05	348.31	358.97	348.31
	COLUMBIA-EPRI :		6.97726E+05	5.14796E+05	4.74218E+05	1.355	1.325	7.33848E-02	8.63172E-02	
	EDLUND	:	8.21388E+05			1.596	1.542			
	WSC-2	:	8.53737E+05			1.658	1.623			
	EIGENE,NEU	:	7.65647E+05			1.487	1.455			
LOKALES SIEDEN :	1.312 M,	TB =	348.24							
15	1.31 346.68 158.51		1.7328E+06	9.4178E+05	3.7949E+04	2.6596E+05	4.1148E+05	348.24	357.53	348.24
	COLUMBIA-EPRI :		6.11930E+05	4.55151E+05	3.97789E+05	1.344	1.320	8.24710E-02	9.45153E-02	
	EDLUND	:	7.57864E+05			1.665	1.649			
	WSC-2	:	7.50282E+05			1.648	1.622			
	EIGENE,NEU	:	6.71811E+05			1.476	1.450			
LOKALES SIEDEN :	1.400 M,	TB =	348.16							
16	1.40 346.66 158.46		1.7390E+06	9.4217E+05	3.7943E+04	2.6595E+05	3.5543E+05	348.16	356.03	348.16
	COLUMBIA-EPRI :		5.25691E+05	3.93158E+05	3.18872E+05	1.337	1.320	9.04344E-02	0.10128	
	EDLUND	:	6.91241E+05			1.758	1.803			
	WSC-2	:	6.45896E+05			1.643	1.625			
	EIGENE,NEU	:	5.77432E+05			1.469	1.451			
LOKALES SIEDEN :	1.487 M,	TB =	348.07							
17	1.49 346.63 158.41		1.7438E+06	9.4257E+05	3.7937E+04	2.6593E+05	2.9755E+05	348.07	354.48	348.07
	COLUMBIA-EPRI :		4.38803E+05	3.29135E+05	2.37963E+05	1.333	1.323	9.72363E-02	0.10658	
	EDLUND	:	6.20433E+05			1.885	2.037			
	WSC-2	:	5.40306E+05			1.642	1.633			
	EIGENE,NEU	:	4.82271E+05			1.465	1.455			
LOKALES SIEDEN :	1.575 M,	TB =	347.96							
18	1.57 346.61 158.36		1.7472E+06	9.4297E+05	3.7930E+04	2.6591E+05	2.3814E+05	347.96	352.88	347.96
	COLUMBIA-EPRI :		3.51055E+05	2.63414E+05	1.55565E+05	1.333	1.331	0.10284	0.11038	
	EDLUND	:	5.43822E+05			2.065	2.444			
	WSC-2	:	4.33228E+05			1.645	1.647			
	EIGENE,NEU	:	3.86078E+05			1.466	1.465			
LOKALES SIEDEN :	1.662 M,	TB =	347.84							

19	1.66	346.58	158.31	1.7444E+06	9.4261E+05	3.7924E+04	2.6590E+05	1.7749E+05	347.84	351.26	347.84
		COLUMBIA-EPRI	:	2.62228E+05	1.96334E+05	1.55565E+05	1.336	0.0000E+00	0.10723		0.11038
		EDLUND	:	4.58731E+05			2.336	0.0000E+00			
		WSC-2	:	3.24359E+05			1.652	0.0000E+00			
		EIGENE,NEU	:	2.88593E+05			1.470	0.0000E+00			
LOKALES SIEDEN	:	1.750	M,	TB =	347.69						
20	1.75	346.55	158.26	1.7472E+06	9.4297E+05	3.7917E+04	2.6588E+05	1.1593E+05	347.69	349.61	347.69
		COLUMBIA-EPRI	:	1.72092E+05	1.28240E+05	1.55565E+05	1.342	0.0000E+00	0.11038		0.11038
		EDLUND	:	3.59968E+05			2.807	0.0000E+00			
		WSC-2	:	2.13382E+05			1.664	0.0000E+00			
		EIGENE,NEU	:	1.89544E+05			1.478	0.0000E+00			
NKD =		107									

OVERPOWER FACTOR : 1.1200

POS	X	T(X)	P(X)	H(X)	HFG(X)	ALFA(X)	RE(X)	PHIN(X)	TW(X)	TW1	TW2
		CORRELATION		PHICHF(X)	PHIHS(X)	PHIHSR(X)	SM(X)	SMCR(X)	X\$X(X)	X\$XR(X)	

LOKALES SIEDEN :		0.000 M, TB =		348.92							
0	0.00	329.52	159.27	1.5457E+06	9.3581E+05	3.4687E+04	2.5200E+05	8.6942E+05	348.92	354.58	348.92
		COLUMBIA-EPRI :		1.97710E+06	1.07710E+06	1.18783E+06	1.836	1.784	-0.10845	-0.10845	
		EDLUND :		1.65704E+06			1.538	1.397			
		WSC-2 :		2.35161E+06			2.183	2.114			
		EIGENE,NEU :		2.15978E+06			2.005	1.947			
LOKALES SIEDEN :		0.087 M, TB =		348.89							
1	0.09	331.90	159.22	1.5662E+06	9.3621E+05	3.4908E+04	2.5389E+05	8.6717E+05	348.89	356.74	348.89
		COLUMBIA-EPRI :		1.87367E+06	1.07432E+06	1.18411E+06	1.744	1.689	-8.83411E-02	-8.62772E-02	
		EDLUND :		1.59033E+06			1.480	1.339			
		WSC-2 :		2.23285E+06			2.078	2.006			
		EIGENE,NEU :		2.04671E+06			1.905	1.844			
LOKALES SIEDEN :		0.175 M, TB =		348.87							
2	0.17	334.20	159.17	1.5865E+06	9.3661E+05	3.5155E+04	2.5573E+05	8.6046E+05	348.87	358.68	348.87
		COLUMBIA-EPRI :		1.77333E+06	1.06600E+06	1.17300E+06	1.664	1.607	-6.83542E-02	-6.42643E-02	
		EDLUND :		1.52608E+06			1.432	1.291			
		WSC-2 :		2.11725E+06			1.986	1.912			
		EIGENE,NEU :		1.93707E+06			1.817	1.754			
LOKALES SIEDEN :		0.262 M, TB =		348.84							
3	0.26	336.41	159.12	1.6066E+06	9.3701E+05	3.5435E+04	2.5751E+05	8.4930E+05	348.84	360.38	348.84
		COLUMBIA-EPRI :		1.67571E+06	1.05218E+06	1.15455E+06	1.593	1.535	-4.85868E-02	-4.25426E-02	
		EDLUND :		1.46387E+06			1.391	1.253			
		WSC-2 :		2.00439E+06			1.905	1.831			
		EIGENE,NEU :		1.83046E+06			1.740	1.675			
LOKALES SIEDEN :		0.350 M, TB =		348.80							
4	0.35	338.51	159.07	1.6263E+06	9.3741E+05	3.5751E+04	2.5921E+05	8.3376E+05	348.80	361.83	348.80
		COLUMBIA-EPRI :		1.58047E+06	1.03292E+06	1.12888E+06	1.530	1.472	-2.91394E-02	-2.12459E-02	
		EDLUND :		1.40334E+06			1.359	1.223			
		WSC-2 :		1.89392E+06			1.834	1.760			
		EIGENE,NEU :		1.72648E+06			1.671	1.607			
LOKALES SIEDEN :		0.437 M, TB =		348.77							
5	0.44	340.49	159.02	1.6456E+06	9.3781E+05	3.6111E+04	2.6083E+05	8.1391E+05	348.77	363.03	348.77
		COLUMBIA-EPRI :		1.48730E+06	1.00834E+06	1.09616E+06	1.475	1.418	-1.01107E-02	-5.05159E-04	
		EDLUND :		1.34416E+06			1.333	1.200			
		WSC-2 :		1.78549E+06			1.771	1.699			

- 53 -

				EIGENE,NEU	:	1.62480E+06			1.611	1.548				
LOKALES	SIEDEN	:	0.525	M,	TB =	348.73								
6	0.52	342.35	158.97	1.6642E+06		9.3820E+05	3.6518E+04	2.6235E+05	7.8987E+05	348.73	363.98	348.73		
				COLUMBIA-EPRI	:	1.39591E+06	9.78548E+05	1.05658E+06	1.427	1.371	8.40280E-03	1.95524E-02		
				EDLUND	:	1.28600E+06			1.314	1.185				
				WSC-2	:	1.67879E+06			1.716	1.646				
				EIGENE,NEU	:	1.52509E+06			1.559	1.497				
LOKALES	SIEDEN	:	0.612	M,	TB =	348.69								
7	0.61	344.07	158.92	1.6820E+06		9.3860E+05	3.6981E+04	2.6376E+05	7.6175E+05	348.69	364.67	348.69		
				COLUMBIA-EPRI	:	1.30602E+06	9.43710E+05	1.01040E+06	1.384	1.331	2.63073E-02	3.88036E-02		
				EDLUND	:	1.22858E+06			1.302	1.177				
				WSC-2	:	1.57351E+06			1.667	1.601				
				EIGENE,NEU	:	1.42706E+06			1.512	1.453				
LOKALES	SIEDEN	:	0.700	M,	TB =	348.65								
8	0.70	345.65	158.87	1.6990E+06		9.3900E+05	3.7505E+04	2.6507E+05	7.2969E+05	348.65	365.10	348.65		
				COLUMBIA-EPRI	:	1.21740E+06	9.04002E+05	9.57900E+05	1.347	1.296	4.35122E-02	5.71308E-02		
				EDLUND	:	1.17160E+06			1.296	1.176				
				WSC-2	:	1.46937E+06			1.625	1.562				
				EIGENE,NEU	:	1.33041E+06			1.472	1.416				
LOKALES	SIEDEN	:	0.787	M,	TB =	348.60								
9	0.79	346.84	158.82	1.7151E+06		9.3940E+05	3.7988E+04	2.6606E+05	6.9388E+05	348.60	365.10	348.60		
				COLUMBIA-EPRI	:	1.12980E+06	8.59628E+05	8.99413E+05	1.314	1.266	5.99306E-02	7.44220E-02		
				EDLUND	:	1.11478E+06			1.297	1.183				
				WSC-2	:	1.36610E+06			1.589	1.530				
				EIGENE,NEU	:	1.23490E+06			1.437	1.384				
LOKALES	SIEDEN	:	0.875	M,	TB =	348.55								
10	0.87	346.81	158.77	1.7300E+06		9.3979E+05	3.7981E+04	2.6605E+05	6.5448E+05	348.55	364.04	348.55		
				COLUMBIA-EPRI	:	1.04299E+06	8.10819E+05	8.35303E+05	1.286	1.242	7.54797E-02	9.05717E-02		
				EDLUND	:	1.05781E+06			1.305	1.198				
				WSC-2	:	1.26344E+06			1.558	1.504				
				EIGENE,NEU	:	1.14026E+06			1.406	1.357				
LOKALES	SIEDEN	:	0.962	M,	TB =	348.50								
11	0.96	346.79	158.71	1.7439E+06		9.4019E+05	3.7975E+04	2.6603E+05	6.1170E+05	348.50	362.89	348.50		
				COLUMBIA-EPRI	:	9.56764E+05	7.57825E+05	7.65971E+05	1.263	1.222	9.00813E-02	0.10548		
				EDLUND	:	1.00036E+06			1.320	1.222				
				WSC-2	:	1.16112E+06			1.532	1.483				
				EIGENE,NEU	:	1.04625E+06			1.381	1.336				
LOKALES	SIEDEN	:	1.050	M,	TB =	348.44								
12	1.05	346.76	158.66	1.7565E+06		9.4059E+05	3.7968E+04	2.6601E+05	5.6577E+05	348.44	361.66	348.44		
				COLUMBIA-EPRI	:	8.70907E+05	7.00920E+05	6.91850E+05	1.243	1.206	0.10366	0.11906		

	EDLUND	:	9.42097E+05				1.344	1.258			
	WSC-2	:	1.05890E+06				1.511	1.467			
	EIGENE,NEU	:	9.52636E+05				1.359	1.319			
LOKALES SIEDEN :	1.137 M,	TB =	348.38								
13	1.14 346.73 158.61	1.7677E+06	9.4098E+05	3.7962E+04		2.6600E+05	5.1692E+05	348.38	360.35	348.38	
	COLUMBIA-EPRI :	7.85214E+05	6.40398E+05	6.13405E+05		1.226	1.194	0.11615		0.13123	
	EDLUND	:	8.82599E+05			1.378	1.308				
	WSC-2	:	9.56524E+05			1.494	1.456				
	EIGENE,NEU	:	8.59178E+05			1.342	1.307				
LOKALES SIEDEN :	1.225 M,	TB =	348.31								
14	1.22 346.71 158.56	1.7776E+06	9.4138E+05	3.7956E+04		2.6598E+05	4.6540E+05	348.31	358.97	348.31	
	COLUMBIA-EPRI :	6.99478E+05	5.76571E+05	5.31124E+05		1.213	1.186	0.12750		0.14191	
	EDLUND	:	8.21388E+05			1.425	1.377				
	WSC-2	:	8.53737E+05			1.481	1.449				
	EIGENE,NEU	:	7.65647E+05			1.328	1.299				
LOKALES SIEDEN :	1.312 M,	TB =	348.24								
15	1.31 346.68 158.51	1.7861E+06	9.4178E+05	3.7949E+04		2.6596E+05	4.1148E+05	348.24	357.53	348.24	
	COLUMBIA-EPRI :	6.13499E+05	5.09769E+05	4.45523E+05		1.203	1.182	0.13763		0.15105	
	EDLUND	:	7.57864E+05			1.487	1.473				
	WSC-2	:	7.50282E+05			1.472	1.448				
	EIGENE,NEU	:	6.71811E+05			1.318	1.295				
LOKALES SIEDEN :	1.400 M,	TB =	348.16								
16	1.40 346.66 158.46	1.7930E+06	9.4217E+05	3.7943E+04		2.6595E+05	3.5543E+05	348.16	356.03	348.16	
	COLUMBIA-EPRI :	5.27069E+05	4.40336E+05	3.57137E+05		1.197	1.181	0.14651		0.15858	
	EDLUND	:	6.91241E+05			1.570	1.609				
	WSC-2	:	6.45896E+05			1.467	1.451				
	EIGENE,NEU	:	5.77432E+05			1.311	1.295				
LOKALES SIEDEN :	1.487 M,	TB =	348.07								
17	1.49 346.63 158.41	1.7984E+06	9.4257E+05	3.7937E+04		2.6593E+05	2.9755E+05	348.07	354.48	348.07	
	COLUMBIA-EPRI :	4.39982E+05	3.68631E+05	2.66518E+05		1.194	1.185	0.15408		0.16446	
	EDLUND	:	6.20433E+05			1.683	1.818				
	WSC-2	:	5.40306E+05			1.466	1.458				
	EIGENE,NEU	:	4.82271E+05			1.308	1.300				
LOKALES SIEDEN :	1.575 M,	TB =	347.96								
18	1.57 346.61 158.36	1.8022E+06	9.4297E+05	3.7930E+04		2.6591E+05	2.3814E+05	347.96	352.88	347.96	
	COLUMBIA-EPRI :	3.52023E+05	2.95024E+05	1.74233E+05		1.193	1.191	0.16032		0.16867	
	EDLUND	:	5.43822E+05			1.843	2.182				
	WSC-2	:	4.33228E+05			1.468	1.471				
	EIGENE,NEU	:	3.86078E+05			1.309	1.308				
LOKALES SIEDEN :	1.662 M,	TB =	347.84								

19	1.66	346.58	158.31	1.7991E+06	9.4261E+05	3.7924E+04	2.6590E+05	1.7749E+05	347.84	351.26	347.84
		COLUMBIA-EPRI :		2.62971E+05	2.19894E+05	1.74233E+05	1.196	0.0000E+00	0.16519		0.16867
		EDLUND :		4.58731E+05			2.086	0.0000E+00			
		WSC-2 :		3.24359E+05			1.475	0.0000E+00			
		EIGENE,NEU :		2.88593E+05			1.312	0.0000E+00			
LOKALES SIEDEN :		1.750 M, TB =	347.69								
20	1.75	346.55	158.26	1.8022E+06	9.4297E+05	3.7917E+04	2.6588E+05	1.1593E+05	347.69	349.61	347.69
		COLUMBIA-EPRI :		1.72595E+05	1.43629E+05	1.74233E+05	1.202	0.0000E+00	0.16867		0.16867
		EDLUND :		3.59968E+05			2.506	0.0000E+00			
		WSC-2 :		2.13382E+05			1.486	0.0000E+00			
		EIGENE,NEU :		1.89544E+05			1.320	0.0000E+00			

NKD = 133

RC001 1 DATENSATZ

NA = 72 ZEICHEN TITELZEILE:

HOMOGENEOUS REACTOR - 24 CONTROL ROD PER ELEMENT. 08.06.89 08.34.26

RC003 NR = 137 WOERTER REAL*4

RC004 NI = 8 WOERTER INTEGER*4

RC002 NEU GESCHRIEBEN

6.2 SAMPLE 2, HOMOGENEOUS CORE, ARBITRARY AXIAL POWER DISTRIBUTION (KFK DESIGN)

CONTROL STATEMENTS AND INPUT:

```
Starting in column 1
↓
//PROJECT2 JOB (.....,.....,.....),.....,MSGCLASS=A,TIME=(1,00)
//*
// EXEC PGM=HADA
//STEPLIB DD DISP=SHR,DSN=PROJECT.HADA.LOAD
//*****
//*
//* ALLOCATE FILE 6 TO GET FORTRAN ERROR MESSAGES
//*
//FT06F001 DD DUMMY
//*T06F001 DD SYSOUT=*,
//*          DCB=(LRECL=133,BLKSIZE=3857,RECFM=FBA)
//*****
//*
//*          UNIT 8          DATA POOL FOR RESULT
//*
//FT08F001 DD DISP=(MOD,PASS),DSN=PROJECT.APWRD.DATA
//*****
//**
//**          UNIT 9          MAIN RESULT
//**
//FT09F001 DD SYSOUT=*,
//          DCB=(LRECL=133,BLKSIZE=3857,RECFM=FBA)
//FT10F001 DD SYSOUT=*,
//          DCB=(LRECL=133,BLKSIZE=3857,RECFM=FBA)
//*****
//**
//**          UNIT 47         PROBLEM IDENTIFICATION
//**
//FT47F001 DD *
HOMOGENEOUS REACTOR - 24 CONTROL ROD PER ELEMENT.
//*****
//**
//**          UNIT INP        COMMON PHYSICAL PARAMETERS
//**
//FT01F001 DD *
```

```

&SYSTEM
&END
3.765E9          QO IN W
1.00,1.65,-1.0000,0.97  OP,FDHO,CDH,K'
0.0             ALC FUER LR=1.1885*LC+0.02 OR LC + ALC
1.7E7,0.774     N IN W,          ETA (NEU 8.9.83)
158.26          P20 IN BAR
326.12          T20 IN GRD C
64.5            POS IN BAR
1.8800E4        MO IN KG/S
1.55927E8       KFO IN W/GRD C
291.14          T10 IN GRD C
159.65          P10 IN BAR
70.6            HR IN M
5.4D7           NEL IN W
89.6            HTO IN M
1.3E9           NEL IN W
//*****
//**
//**          UNIT JNP          SPECIAL PHYSICAL PARAMETERS
//**
//FT02F001 DD *
11.8000E-3      P IN M
9.5E-3          D IN M          2 REAL 9.9.83
-1.             KO
.875052,-3.5    K1,KL  LINEAR RATING
.904265         K2
3.88910         DEQ IN M          1 REAL 9.9.83
12,.4D-3,2.2D-3,.64D-3  NGI,SG,BG,SCLAD IN M
1.2,5.D-6       KI,RK
//*****
//**
//**          UNIT 05          SYSIN
//**
//G.FT05F001 DD *
1              INP
2,1,1,1       IOP1,IOP2,IOP3,IOP4 .,1,.. HOMOGEN  <===
1,2           IDR1,IDR2
2              JNP              2          HOMOGEN  <===
1.D-5,.5,20   EPS,DMAX,IMAX
&DNBR
&END
-1.20         PHIAX          4 REAL 9.9.83

```

2.37D6 K
1588.D3 H0
2.3 FQ 7 REAL 9.9.83
.1 K4
40 NC
1.12 OP
1.000,9.000,6.507,1.748,7.540,8.783 (JMP\$,JMP2\$,Q4)ALT,(Q1,Q2,Q4)NEU
2.07930 FQN 5 REAL 12.9.83
0.3606,0.4790,0.5921,0.6986,0.7974,0.8872,0.9671,1.037,1.094,1.131,
1.164,1.193,1.199,1.200,1.200,1.200,1.200,1.200,1.200,1.200,
1.200,1.200,1.200,1.200,1.200,1.200,1.200,1.199,1.193,1.164,
1.131,1.094,1.037,0.9671,0.8872,0.7974,0.6986,0.5921,0.4790,0.3606
0.3606,0.4790,0.5921,0.6986,0.7974,0.8872,0.9671,1.037,1.094,1.131,
1.164,1.193,1.199,1.200,1.200,1.200,1.200,1.200,1.200,1.200,
1.200,1.200,1.200,1.200,1.200,1.200,1.200,1.199,1.193,1.164,
1.131,1.094,1.037,0.9671,0.8872,0.7974,0.6986,0.5921,0.4790,0.3606
//

Main results (unit 09)

TITEL :

HOMOGENEOUS REACTOR - 24 CONTROL ROD PER ELEMENT. 24.07.89 15.30.59

*Since the following six pages of outputs are the same as those of Sample 1,
they are omitted here.*

ERGEBNISSE

Q = 3.76509E+09 W
K = 1.0000
PS = 64.502 BAR
TS = 280.40 GRD C
P1 = 160.28 BAR
T1 = 291.16 GRD C
T2 = 326.76 GRD C
M = 18361. KG/S
NP = 1.76098E+07 W
QNT = 1.30066E+09 W
QNT/QELO = 1.0005

***** ZUSATZ 08.09.1983 *****

KS = 0.97000 -
ETA = 0.77400 -
MS = 17810. KG/S
NPEL = 2.27517E+07 W

HOMOGENEOUS REACTOR WITH GRID SPACERS

LC = 3.5000 M
LR = 4.1798 M
T2U = 337.25 GRD C
U = 4.5450 M/S
RE = 2.40061E+05
LAMBDA = 2.07254E-02
DIST = 0.37998
\$K = 1.1569 (=CV*EPS*EPS)
DP = 2.0204 BAR
DPTOT = 2.3309 BAR

DPP = 6.9488 BAR

PRDH = 1.0149

CDH = 1.0000

CHF-CALCULATIONS

LC = 3.5000 M
T1 = 291.16 GRD C
RO1 = 745.63 KG/CBM
P1 = 160.28 BAR
H1 = 1.28915E+06 J/KG
T2 = 337.25 GRD
P2 = 158.26 BAR
ROQ = 696.43 KG/CBM
U = 4.5450 M/S
QL = 12479. W/M
D = 9.50000E-03 M
DH = 6.66148E-03 M
PZUD = 1.2421

EINGABEDATEN

FIAX = -1.2000
AK = 2.37000E+06
HO = 1.58800E+06 J/KG
FQ = 2.3000
K4 = 0.10000
NC = 40
OP = 1.1200
Q10 = 1.0000
Q20 = 9.0000
Q40 = 6.5070
Q1N = 1.7480
Q2N = 7.5400
Q4N = 8.7830
FQN = 2.0793

AXIAL POWER DISTRIBUTION IS GIVEN BY INPUT AS FOLLOWS:

POS.	AXIAL DISTRIBUTION		DISTORTED BY CONTROL ROD	
		CUMULATIVE		CUMULATIVE
1	3.60600E-01	3.60600E-01	3.60600E-01	3.60600E-01
2	4.79000E-01	8.39600E-01	4.79000E-01	8.39600E-01

3	5.92100E-01	1.43170E+00	5.92100E-01	1.43170E+00
4	6.98600E-01	2.13030E+00	6.98600E-01	2.13030E+00
5	7.97400E-01	2.92770E+00	7.97400E-01	2.92770E+00
6	8.87200E-01	3.81490E+00	8.87200E-01	3.81490E+00
7	9.67100E-01	4.78200E+00	9.67100E-01	4.78200E+00
8	1.03700E+00	5.81900E+00	1.03700E+00	5.81900E+00
9	1.09400E+00	6.91300E+00	1.09400E+00	6.91300E+00
10	1.13100E+00	8.04400E+00	1.13100E+00	8.04400E+00
11	1.16400E+00	9.20800E+00	1.16400E+00	9.20800E+00
12	1.19300E+00	1.04010E+01	1.19300E+00	1.04010E+01
13	1.19900E+00	1.16000E+01	1.19900E+00	1.16000E+01
14	1.20000E+00	1.28000E+01	1.20000E+00	1.28000E+01
15	1.20000E+00	1.40000E+01	1.20000E+00	1.40000E+01
16	1.20000E+00	1.52000E+01	1.20000E+00	1.52000E+01
17	1.20000E+00	1.64000E+01	1.20000E+00	1.64000E+01
18	1.20000E+00	1.76000E+01	1.20000E+00	1.76000E+01
19	1.20000E+00	1.88000E+01	1.20000E+00	1.88000E+01
20	1.20000E+00	2.00000E+01	1.20000E+00	2.00000E+01
21	1.20000E+00	2.12000E+01	1.20000E+00	2.12000E+01
22	1.20000E+00	2.24000E+01	1.20000E+00	2.24000E+01
23	1.20000E+00	2.36000E+01	1.20000E+00	2.36000E+01
24	1.20000E+00	2.48000E+01	1.20000E+00	2.48000E+01
25	1.20000E+00	2.60000E+01	1.20000E+00	2.60000E+01
26	1.20000E+00	2.72000E+01	1.20000E+00	2.72000E+01
27	1.20000E+00	2.84000E+01	1.20000E+00	2.84000E+01
28	1.19900E+00	2.95990E+01	1.19900E+00	2.95990E+01
29	1.19300E+00	3.07920E+01	1.19300E+00	3.07920E+01
30	1.16400E+00	3.19560E+01	1.16400E+00	3.19560E+01
31	1.13100E+00	3.30870E+01	1.13100E+00	3.30870E+01
32	1.09400E+00	3.41810E+01	1.09400E+00	3.41810E+01
33	1.03700E+00	3.52180E+01	1.03700E+00	3.52180E+01
34	9.67100E-01	3.61851E+01	9.67100E-01	3.61851E+01
35	8.87200E-01	3.70723E+01	8.87200E-01	3.70723E+01
36	7.97400E-01	3.78697E+01	7.97400E-01	3.78697E+01
37	6.98600E-01	3.85683E+01	6.98600E-01	3.85683E+01
38	5.92100E-01	3.91604E+01	5.92100E-01	3.91604E+01
39	4.79000E-01	3.96394E+01	4.79000E-01	3.96394E+01
40	3.60600E-01	4.00000E+01	3.60600E-01	4.00000E+01

FIAXA =1.200000000000006 (AXIAL FORM FACTOR (PEAK/AVERAGE))

FIAXB =1.200000000000006 (AXIAL FORM FACTOR (PEAK/AVERAGE) WITH CONTROL RODS)

ERGEBNISSE

RLCR = 3.500
V1 = 0.70000E+00 WSC-2
CG' = 0.80219E+00 COLUMBIA-EPRI
V2 = 0.85680E+00 EIGENE,NEU

OVERPOWER FACTOR : 1.0000

POS X	T(X)	TW	COLUMBIA-EPRI			EDLUND			WSC-2			EIGENE,NEU			
			CHF	SM	SMLWR	CHF	SM	SMLWR	CHF	SM	SMLWR	CHF	SM	SMLWR	
*****	*****		*****			*****			*****			*****			
1	0.04	291.57	299.53	6.028E+06	20.86	20.86	1.114E+07	38.55	38.55	6.370E+06	22.04	22.04	6.373E+06	22.05	22.05
2	0.13	292.53	303.09	5.695E+06	14.83	14.83	6.539E+06	17.03	17.03	6.031E+06	15.71	15.71	5.955E+06	15.51	15.51
3	0.22	293.75	306.78	5.334E+06	11.24	11.24	5.114E+06	10.78	10.78	5.649E+06	11.90	11.90	5.524E+06	11.64	11.64
4	0.31	295.21	310.56	5.006E+06	8.94	8.94	4.342E+06	7.75	7.75	5.297E+06	9.46	9.46	5.140E+06	9.18	9.18
5	0.39	296.89	314.39	4.707E+06	7.37	7.37	3.830E+06	5.99	5.99	4.975E+06	7.79	7.79	4.795E+06	7.50	7.50
6	0.48	298.77	318.19	4.432E+06	6.23	6.23	3.453E+06	4.86	4.86	4.678E+06	6.58	6.58	4.483E+06	6.30	6.30
7	0.57	300.82	321.94	4.176E+06	5.39	5.39	3.156E+06	4.07	4.07	4.402E+06	5.68	5.68	4.197E+06	5.41	5.41
8	0.66	303.01	325.61	3.937E+06	4.74	4.74	2.914E+06	3.51	3.51	4.145E+06	4.99	4.99	3.933E+06	4.73	4.73
9	0.74	305.32	329.09	3.709E+06	4.23	4.23	2.706E+06	3.09	3.09	3.900E+06	4.45	4.45	3.684E+06	4.20	4.20
10	0.83	307.70	332.21	3.478E+06	3.84	3.84	2.516E+06	2.78	2.78	3.653E+06	4.03	4.03	3.436E+06	3.79	3.79
11	0.92	310.13	335.27	3.274E+06	3.51	3.51	2.357E+06	2.53	2.53	3.435E+06	3.68	3.68	3.219E+06	3.45	3.45
12	1.01	312.58	338.26	3.091E+06	3.23	3.23	2.222E+06	2.32	2.32	3.240E+06	3.39	3.39	3.026E+06	3.17	3.17
13	1.09	315.03	340.76	2.895E+06	3.01	3.01	2.087E+06	2.17	2.17	3.032E+06	3.16	3.16	2.823E+06	2.94	2.94
14	1.18	317.45	343.11	2.718E+06	2.83	2.83	1.969E+06	2.05	2.05	2.844E+06	2.96	2.96	2.639E+06	2.74	2.74
15	1.27	319.83	345.39	2.560E+06	2.66	2.66	1.867E+06	1.94	1.94	2.677E+06	2.78	2.78	2.477E+06	2.58	2.58
16	1.36	322.17	347.63	2.420E+06	2.52	2.52	1.778E+06	1.85	1.85	2.529E+06	2.63	2.63	2.335E+06	2.43	2.43
17	1.44	324.47	349.00	2.296E+06	2.39	2.39	1.700E+06	1.77	1.77	2.398E+06	2.49	2.49	2.208E+06	2.30	2.30
18	1.53	326.71	348.98	2.183E+06	2.27	2.27	1.631E+06	1.70	1.70	2.279E+06	2.37	2.37	2.095E+06	2.18	2.18
19	1.62	328.91	348.96	2.082E+06	2.17	2.17	1.569E+06	1.63	1.63	2.173E+06	2.26	2.26	1.993E+06	2.07	2.07
20	1.71	331.06	348.93	1.990E+06	2.07	2.07	1.514E+06	1.57	1.57	2.076E+06	2.16	2.16	1.901E+06	1.98	1.98
21	1.79	333.15	348.91	1.906E+06	1.98	1.98	1.463E+06	1.52	1.52	1.987E+06	2.07	2.07	1.817E+06	1.89	1.89
22	1.88	335.19	348.88	1.829E+06	1.90	1.90	1.417E+06	1.47	1.47	1.906E+06	1.98	1.98	1.740E+06	1.81	1.81
23	1.97	337.16	348.86	1.758E+06	1.83	1.83	1.375E+06	1.43	1.43	1.832E+06	1.90	1.90	1.670E+06	1.74	1.74
24	2.06	339.08	348.83	1.693E+06	1.76	1.76	1.336E+06	1.39	1.39	1.763E+06	1.83	1.83	1.605E+06	1.67	1.67
25	2.14	340.93	348.81	1.632E+06	1.70	1.70	1.300E+06	1.35	1.35	1.699E+06	1.77	1.77	1.545E+06	1.61	1.61
26	2.23	342.71	348.79	1.576E+06	1.64	1.64	1.267E+06	1.32	1.32	1.640E+06	1.71	1.71	1.489E+06	1.55	1.55
27	2.32	344.41	348.76	1.523E+06	1.58	1.58	1.235E+06	1.28	1.28	1.585E+06	1.65	1.65	1.438E+06	1.49	1.49
28	2.41	346.04	348.74	1.473E+06	1.53	1.53	1.206E+06	1.25	1.25	1.532E+06	1.59	1.59	1.389E+06	1.45	1.45
29	2.49	346.85	348.71	1.421E+06	1.49	1.49	1.175E+06	1.23	1.23	1.478E+06	1.55	1.55	1.338E+06	1.40	1.40
30	2.58	346.83	348.67	1.350E+06	1.45	1.45	1.134E+06	1.22	1.22	1.404E+06	1.51	1.51	1.269E+06	1.36	1.36
31	2.67	346.80	348.64	1.280E+06	1.41	1.41	1.094E+06	1.21	1.21	1.331E+06	1.47	1.47	1.202E+06	1.33	1.33
32	2.76	346.77	348.60	1.211E+06	1.38	1.38	1.053E+06	1.20	1.20	1.258E+06	1.44	1.44	1.135E+06	1.29	1.29
33	2.84	346.75	348.55	1.127E+06	1.36	1.36	1.004E+06	1.21	1.21	1.171E+06	1.41	1.41	1.055E+06	1.27	1.27
34	2.93	346.72	348.49	1.035E+06	1.34	1.34	9.499E+05	1.23	1.23	1.075E+06	1.39	1.39	9.671E+05	1.25	1.25
35	3.02	346.70	348.43	9.381E+05	1.32	1.32	8.918E+05	1.25	1.25	9.746E+05	1.37	1.37	8.752E+05	1.23	1.23

- 67 -

36	3.11	346.67	348.36	8.359E+05	1.31	1.31	8.289E+05	1.30	1.30	8.683E+05	1.36	1.36	7.784E+05	1.22	1.22
37	3.19	346.64	348.28	7.284E+05	1.30	1.30	7.608E+05	1.36	1.36	7.566E+05	1.35	1.35	6.772E+05	1.21	1.21
38	3.28	346.62	348.19	6.160E+05	1.30	1.30	6.865E+05	1.45	1.45	6.399E+05	1.35	1.35	5.717E+05	1.20	1.20
39	3.37	346.59	348.09	4.989E+05	1.30	1.30	6.045E+05	1.57	1.57	5.183E+05	1.35	1.35	4.623E+05	1.20	1.20
40	3.46	346.57	347.96	3.773E+05	1.31	1.31	5.122E+05	1.77	1.77	3.920E+05	1.36	1.36	3.490E+05	1.21	1.21

MINIMALWERTE

CORRELATION	SMMIN	X	POS			
*****	*****	*****	***			
COLUMBIA-EPRI :	1.2982	3.2812	38	1.2982	3.2812	38
EDLUND :	1.2013	2.7562	32	1.2013	2.7562	32
WSC-2 :	1.3485	3.2812	38	1.3485	3.2812	38
EIGENE,NEU :	1.2043	3.3687	39	1.2043	3.3687	39
	X \S =	0.10283		X \S =	0.10283	

OVERPOWER FACTOR : 1.1200

POS X	T(X)	TW	COLUMBIA-EPRI			EDLUND			WSC-2			EIGENE, NEU			
			CHF	SM	SMLWR	CHF	SM	SMLWR	CHF	SM	SMLWR	CHF	SM	SMLWR	
1	0.04	291.62	300.53	6.032E+06	18.64	18.64	1.114E+07	34.42	34.42	6.370E+06	19.68	19.68	6.373E+06	19.69	19.69
2	0.13	292.69	304.52	5.702E+06	13.26	13.26	6.539E+06	15.21	15.21	6.031E+06	14.03	14.03	5.955E+06	13.85	13.85
3	0.22	294.06	308.65	5.343E+06	10.05	10.05	5.114E+06	9.62	9.62	5.649E+06	10.63	10.63	5.524E+06	10.39	10.39
4	0.31	295.69	312.88	5.015E+06	8.00	8.00	4.342E+06	6.92	6.92	5.297E+06	8.45	8.45	5.140E+06	8.20	8.20
5	0.39	297.57	317.15	4.716E+06	6.59	6.59	3.830E+06	5.35	5.35	4.975E+06	6.95	6.95	4.795E+06	6.70	6.70
6	0.48	299.67	321.40	4.440E+06	5.58	5.58	3.453E+06	4.34	4.34	4.678E+06	5.87	5.87	4.483E+06	5.63	5.63
7	0.57	301.95	325.58	4.184E+06	4.82	4.82	3.156E+06	3.64	3.64	4.402E+06	5.07	5.07	4.197E+06	4.83	4.83
8	0.66	304.39	329.66	3.945E+06	4.24	4.24	2.914E+06	3.13	3.13	4.145E+06	4.45	4.45	3.933E+06	4.23	4.23
9	0.74	306.96	333.53	3.716E+06	3.78	3.78	2.706E+06	2.76	2.76	3.900E+06	3.97	3.97	3.684E+06	3.75	3.75
10	0.83	309.60	336.98	3.485E+06	3.43	3.43	2.516E+06	2.48	2.48	3.653E+06	3.60	3.60	3.436E+06	3.39	3.39
11	0.92	312.28	340.36	3.280E+06	3.14	3.14	2.357E+06	2.26	2.26	3.435E+06	3.29	3.29	3.219E+06	3.08	3.08
12	1.01	315.00	343.66	3.097E+06	2.89	2.89	2.222E+06	2.08	2.08	3.240E+06	3.03	3.03	3.026E+06	2.83	2.83
13	1.09	317.70	346.39	2.901E+06	2.70	2.70	2.087E+06	1.94	1.94	3.032E+06	2.82	2.82	2.823E+06	2.62	2.62
14	1.18	320.35	348.95	2.723E+06	2.53	2.53	1.969E+06	1.83	1.83	2.844E+06	2.64	2.64	2.639E+06	2.45	2.45
15	1.27	322.96	349.10	2.565E+06	2.38	2.38	1.867E+06	1.73	1.73	2.677E+06	2.49	2.49	2.477E+06	2.30	2.30
16	1.36	325.51	349.08	2.425E+06	2.25	2.25	1.778E+06	1.65	1.65	2.529E+06	2.35	2.35	2.335E+06	2.17	2.17
17	1.44	328.00	349.06	2.301E+06	2.14	2.14	1.700E+06	1.58	1.58	2.398E+06	2.23	2.23	2.208E+06	2.05	2.05
18	1.53	330.42	349.03	2.188E+06	2.03	2.03	1.631E+06	1.51	1.51	2.279E+06	2.12	2.12	2.095E+06	1.94	1.94
19	1.62	332.78	349.01	2.087E+06	1.94	1.94	1.569E+06	1.46	1.46	2.173E+06	2.02	2.02	1.993E+06	1.85	1.85
20	1.71	335.07	348.98	1.995E+06	1.85	1.85	1.514E+06	1.41	1.41	2.076E+06	1.93	1.93	1.901E+06	1.76	1.76
21	1.79	337.29	348.96	1.910E+06	1.77	1.77	1.463E+06	1.36	1.36	1.987E+06	1.84	1.84	1.817E+06	1.69	1.69
22	1.88	339.42	348.94	1.833E+06	1.70	1.70	1.417E+06	1.32	1.32	1.906E+06	1.77	1.77	1.740E+06	1.62	1.62
23	1.97	341.48	348.91	1.762E+06	1.64	1.64	1.375E+06	1.28	1.28	1.832E+06	1.70	1.70	1.670E+06	1.55	1.55
24	2.06	343.44	348.89	1.696E+06	1.57	1.57	1.336E+06	1.24	1.24	1.763E+06	1.64	1.64	1.605E+06	1.49	1.49
25	2.14	345.31	348.86	1.636E+06	1.52	1.52	1.300E+06	1.21	1.21	1.699E+06	1.58	1.58	1.545E+06	1.43	1.43
26	2.23	346.93	348.84	1.579E+06	1.47	1.47	1.267E+06	1.18	1.18	1.640E+06	1.52	1.52	1.489E+06	1.38	1.38
27	2.32	346.90	348.82	1.526E+06	1.42	1.42	1.235E+06	1.15	1.15	1.585E+06	1.47	1.47	1.438E+06	1.33	1.33
28	2.41	346.88	348.79	1.476E+06	1.37	1.37	1.206E+06	1.12	1.12	1.532E+06	1.42	1.42	1.389E+06	1.29	1.29
29	2.49	346.85	348.76	1.424E+06	1.33	1.33	1.175E+06	1.10	1.10	1.478E+06	1.38	1.38	1.338E+06	1.25	1.25
30	2.58	346.83	348.73	1.353E+06	1.30	1.30	1.134E+06	1.09	1.09	1.404E+06	1.34	1.34	1.269E+06	1.22	1.22
31	2.67	346.80	348.69	1.283E+06	1.26	1.26	1.094E+06	1.08	1.08	1.331E+06	1.31	1.31	1.202E+06	1.18	1.18
32	2.76	346.77	348.65	1.214E+06	1.24	1.24	1.053E+06	1.07	1.07	1.258E+06	1.28	1.28	1.135E+06	1.16	1.16
33	2.84	346.75	348.60	1.129E+06	1.21	1.21	1.004E+06	1.08	1.08	1.171E+06	1.26	1.26	1.055E+06	1.13	1.13
34	2.93	346.72	348.54	1.037E+06	1.20	1.20	9.499E+05	1.09	1.09	1.075E+06	1.24	1.24	9.671E+05	1.11	1.11
35	3.02	346.70	348.48	9.405E+05	1.18	1.18	8.918E+05	1.12	1.12	9.746E+05	1.22	1.22	8.752E+05	1.10	1.10

36	3.11	346.67	348.41	8.380E+05	1.17	1.17	8.289E+05	1.16	1.16	8.683E+05	1.21	1.21	7.784E+05	1.09	1.09
37	3.19	346.64	348.33	7.302E+05	1.16	1.16	7.608E+05	1.21	1.21	7.566E+05	1.21	1.21	6.772E+05	1.08	1.08
38	3.28	346.62	348.24	6.176E+05	1.16	1.16	6.865E+05	1.29	1.29	6.399E+05	1.20	1.20	5.717E+05	1.08	1.08
39	3.37	346.59	348.13	5.003E+05	1.16	1.16	6.045E+05	1.41	1.41	5.183E+05	1.21	1.21	4.623E+05	1.08	1.08
40	3.46	346.57	348.00	3.783E+05	1.17	1.17	5.122E+05	1.58	1.58	3.920E+05	1.21	1.21	3.490E+05	1.08	1.08

MINIMALWERTE

CORRELATION	SMMIN	X	POS			
*****	*****	*****	***			
COLUMBIA-EPRI :	1.1622	3.2812	38	1.1622	3.2812	38
EDLUND :	1.0726	2.7562	32	1.0726	2.7562	32
WSC-2 :	1.2040	3.2812	38	1.2040	3.2812	38
EIGENE,NEU :	1.0752	3.3687	39	1.0752	3.3687	39

X\$ = 0.16028

X\$ = 0.16028

6.3 SAMPLE 3, MULTIPLE STACKED CORE (JAERI DESIGN)

CONTROL STATEMENTS AND INPUT:

```
Starting in column 1
↓
//PROJECT3 JOB (.....,.....,.....),.....,MSGCLASS=A,TIME=2
// EXEC PGM=HADA
//STEPLIB DD DISP=SHR,DSN=PROJECT.HADA.LOAD
//*****
//FT06F001 DD DUMMY
//FT08F001 DD DSN=PROJECT.APWRD.DATA,DISP=(MOD,PASS)
//FT09F001 DD SYSOUT=*,
//          DCB=(LRECL=133,BLKSIZE=3857,RECFM=FBA)
//FT10F001 DD SYSOUT=*,
//          DCB=(LRECL=133,BLKSIZE=3857,RECFM=FBA)
//*****
//**
//**          UNIT 47          PROBLEM IDENTIFICATION
//**
//FT47F001 DD *
2-FLAT, HC=.5M,HIB=HOB=.3M,QLB:QLC=0.07,QLC=20,P=1.30
//*****
//**
//**          UNIT INP          COMMON PHYSICAL PARAMETERS
//**
//FT01F001 DD *   ( INP )
&SYSTEM
  PC0=210.88,PC1=-23.163,PC2=0.,
  SG1=0.7,SG2=0.1,SG3=0.23,SG4=0.2,SG5=0.8,
  NLP=3
&END
2.587E9          Q0 IN W
1.00,1.60,1.0000,0.95  OP,FDH0,CDH,K'
0.500          ALC FUER LR= LC+ALC
1.7E7,0.774          N IN W,          ETA (NEU 8.9.83)
155.00          P20 IN BAR
325.00          T20 IN GRD C
61.3           POS IN BAR
1.2525E4          M0 IN KG/S
0.98397E8          KFO IN W/GRD C
289.00          T10 IN GRD C
```

156.86 P10 IN BAR
56.0 HR IN M
5.4D7 NEL IN W
81.3 HTO IN M
1.3E9 NEL IN W

//*****

//**

//** UNIT JNP SPECIAL PHYSICAL PARAMETERS

//**

//FT02F001 DD * (JNP)

13.0-3 P IN M
9.5E-3 D IN M 2 REAL 9.9.83
-1. K0
.87103 , -1.9 K1, KL LIMITAZIONE DELLA POTENZA
.36700 K2
5.02420 DEQ IN M 1 REAL 9.9.83
7 0.6957 95.39 .655D-3 H/D OR NGI, SG, BG, SCLAD IN M
1.2, 5.D-6 KI, RK

//*****

//**

//** UNIT 05 SYSIN

//**

//FT05F001 DD *

1 INP
2, 1, 1, 1 IOP1, IOP2, IOP3, IOP4 ., 1, ., . HOMOGEN <===
1, 2 IDR1, IDR2
2 JNP 2 HOMOGEN <===
1.D-5, .5, 20 EPS, DMAX, IMAX

&DNBR

FIAX=1.2,
FQ=1.92,
AK4=0.0,
OP=1.12,
FQN=1.92,
RR1=0.6,
RR2=0.6,
RR3=0.07,
FIAX2=0.2,
NAC=2,
NC=10,
IBLT=1

&END

//

Main results (unit 09)

TITEL :

2-FLAT, HC=.5M, HIB=HOB=.3M, QLB:QLC=0.07, QLC=20, P=1.30 08.06.89 08.31.18

EINGABEPARAMETER

Q0 = 2.58700E+09 W
POS = 61.300 BAR
P20 = 155.00 BAR
T20 = 325.00 GRD C
KFO = 9.83970E+07 WATT/GRD
N = 1.70000E+07 WATT
P10 = 156.86 BAR
M0 = 12525. KG/S
FDHO = 1.6000
CDH = 1.0000
OPF = 1.0000
T10 = 289.00 GRD C
HR = 56.000 M
NEL = 5.40000E+07 W
ALC = 0.50000 M

CONSTANT PUMP CHARACTERISTICS

$$HT = 210.88 + (-23.16 - 0.00 * V) * V$$

WHERE $V = M / RO / 3$

KF IS CALCULATED AS

$$KF = KFO / (0.700 + 0.100*(Q/Q0)**0.230 + 0.200*(M0/M)**0.800$$

$$EPSI = 0.36183499999999996$$

P = 1.30000E-02 M
D = 9.50000E-03 M
DH = 1.01157E-02 M
K0 = -1.0000
K1 = 0.87103
K2 = 0.36700
DEQ = 5.0242 M
H/D = 0.00000E+00
KI = 1.2000
RK = 5.00000E-06 M
P/D = 1.3684
B = 0.00000E+00 M
KL = 1.0000 -

12.09.1983

RLC = 1.9000 M
RLR = 2.4000 M
AT = 17.269 QM
NT = 117988
VM/VROD = 1.1770 CORE, 1.0648 CELL
VM/VFUEL = 1.5837 CORE, 1.4327 CELL
NGI=7

HOMOGENEOUS REACTOR
EPS = 1.00000E-03 %
DELTA = 50.000 %

ANFANGSWERTE

NAME	NR	EINHEIT	WERT	ZUWACHS
*****	***	*****	*****	*****
K	1	-	1.0000	0.00000E+00
Q	2	W	6.14963E+10	0.00000E+00
T1	3	GRD C	289.00	0.00000E+00
RO1	4	KG/CBM	749.11	0.00000E+00
P1	5	BAR	156.86	0.00000E+00
H1	6	J/KG	1.27806E+06	0.00000E+00
T2	7	GRD C	325.00	0.00000E+00
RO2	8	KG/CBM	666.87	0.00000E+00
H2	9	J/KG	1.48361E+06	0.00000E+00
TS	10	GRD C	277.04	0.00000E+00
PS	11	BAR	61.300	0.00000E+00
TQ	12	GRD C	307.00	0.00000E+00
ROQ	13	KG/CBM	712.35	0.00000E+00
PQ	14	BAR	155.93	0.00000E+00
M	15	KG/S	12586.	0.00000E+00
KF	16	W/GRD	9.84737E+07	0.00000E+00
HT	17	M	81.155	0.00000E+00
HC	18	M	24.607	0.00000E+00
DP	19	BAR	1.8600	0.00000E+00
Y	20	-	1.3614	0.00000E+00
TSU	21	GRD C	330.10	0.00000E+00
RO2U	22	KG/CBM	651.53	0.00000E+00
H2U	23	J/KG	1.51722E+06	0.00000E+00
TQU	24	GRD C	307.00	0.00000E+00
ROQU	25	KG/CBM	712.35	0.00000E+00
NY	26	QM/S	1.26081E-07	0.00000E+00
U	27	M/S	1.7052	0.00000E+00
RE	28	-	1.36808E+05	0.00000E+00
LAM	29	-	1.86916E-02	0.00000E+00
ITER =	0	ABS :	5.88771E+10	2 *** REL : 0.50000 19
ITER =	1	ABS :	2.81220E+10	2 *** REL : 0.50000 19
ITER =	2	ABS :	1.27349E+10	2 *** REL : 0.50000 2
ITER =	3	ABS :	5.03089E+09	2 *** REL : 0.50000 2
ITER =	4	ABS :	1.17313E+09	2 *** REL : 0.30522 2
ITER =	5	ABS :	3.48161E+06	2 *** REL : 4.21872E-03 20
ITER =	6	ABS :	9447.4	2 *** REL : 2.74205E-05 28

- 77 -

LOESUNGSVEKTOR UND ERREICHTE GENAUGIGKEIT

NAME	NR	EINHEIT	WERT	ZUWACHS	
****	**	*****	*****	*****	
K	1	-	1.0336	-2.72589E-10	
Q	2	W	2.67387E+09	-0.70519	
T1	3	GRD C	292.69	-5.19827E-08	
RO1	4	KG/CBM	741.83	2.87409E-07	
P1	5	BAR	155.24	2.19501E-08	
H1	6	J/KG	1.29755E+06	-3.45383E-04	
T2	7	GRD C	326.77	-2.13613E-08	
RO2	8	KG/CBM	661.71	6.33334E-08	
H2	9	J/KG	1.49508E+06	-1.40312E-04	
TS	10	GRD C	279.22	-1.82042E-08	
PS	11	BAR	63.358	-1.67097E-08	
TQ	12	GRD C	309.73	-3.66720E-08	
ROQ	13	KG/CBM	705.98	-8.94607E-07	
PQ	14	BAR	155.12	1.09751E-08	
M	15	KG/S	13536.	-1.50404E-05	
KF	16	W/GRD	9.95201E+07	-1.61981E-02	
HT	17	M	69.992	2.11037E-07	
HC	18	M	3.3443	3.00433E-07	
DP	19	BAR	0.24329	2.19501E-08	
Y	20	-	1.2608	1.43975E-09	
TSU	21	GRD C	331.58	-2.15431E-08	
RO2U	22	KG/CBM	646.75	7.04383E-08	
H2U	23	J/KG	1.52739E+06	-1.49989E-04	
TQU	24	GRD C	312.14	-3.67629E-08	
ROQU	25	KG/CBM	700.36	1.37741E-06	
NY	26	QM/S	1.26098E-07	-2.32629E-16	
U	27	M/S	1.8653	-5.73822E-09	
RE	28	-	1.49638E+05	-8.09950E-02	
LAM	29	-	2.04335E-02	1.20459E-09	
IPOW=1		PRDH=	1.0000000000000000		
ITER =	7	ABS :	3.41277E+07	2 *** REL :	1.27634E-02 11
ITER =	8	ABS :	59273.	2 *** REL :	2.10048E-04 28
ITER =	9	ABS :	65.893	2 *** REL :	4.32998E-05 28

LOESUNGSVEKTOR UND ERREICHTE GENAUGIGKEIT

NAME	NR	EINHEIT	WERT	ZUWACHS
****	**	*****	*****	*****
K	1	-	1.0204	-7.02459E-10
Q	2	W	2.63968E+09	-1.8173
T1	3	GRD C	291.61	-7.92420E-08
RO1	4	KG/CBM	743.92	-6.56283E-07
P1	5	BAR	155.24	1.22440E-08
H1	6	J/KG	1.29182E+06	-1.29763E-04
T2	7	GRD C	325.41	-8.55853E-09
RO2	8	KG/CBM	665.70	2.47527E-08
H2	9	J/KG	1.48623E+06	-5.52195E-05
TS	10	GRD C	278.37	-4.53756E-08
PS	11	BAR	62.548	-4.30608E-08
TQ	12	GRD C	308.51	-4.39003E-08
ROQ	13	KG/CBM	708.78	6.41730E-07
PQ	14	BAR	155.12	6.12198E-09
M	15	KG/S	13578.	-1.45410E-05
KF	16	W/GRD	9.95969E+07	-1.45885E-02
HT	17	M	69.952	2.65906E-08
HC	18	M	3.3422	1.70797E-07
DP	19	BAR	0.24382	1.22440E-08
Y	20	-	1.2676	3.33805E-09
TSU	21	GRD C	330.21	-6.37262E-09
RO2U	22	KG/CBM	651.15	2.02275E-08
H2U	23	J/KG	1.51802E+06	-4.32661E-05
TQU	24	GRD C	310.91	-4.28073E-08
ROQU	25	KG/CBM	703.25	-1.59248E-06
NY	26	QM/S	1.26077E-07	3.03138E-16
U	27	M/S	1.8634	2.22415E-09
RE	28	-	1.49509E+05	2.08415E-04
LAM	29	-	2.04354E-02	2.26750E-13
IPOW=2 PRDH= 1.0335781062109666				
ITER =	10	ABS :	5.07065E+07	2 **** REL : 1.92093E-02 2
ITER =	11	ABS :	1.23400E+05	2 **** REL : 1.87030E-04 28
ITER =	12	ABS :	161.65	2 **** REL : 9.53559E-05 28

LOESUNGSVEKTOR UND ERREICHTE GENAUIGKEIT

NAME	NR	EINHEIT	WERT	ZUWACHS
*****	**	*****	*****	*****
K	1	-	1.0007	-2.24468E-11
Q	2	W	2.58885E+09	-5.80700E-02
T1	3	GRD C	289.99	-6.50301E-09
RO1	4	KG/CBM	746.99	-3.29096E-07
P1	5	BAR	155.24	-5.52303E-09
H1	6	J/KG	1.28331E+06	8.14782E-05
T2	7	GRD C	323.35	5.82203E-09
RO2	8	KG/CBM	671.54	-1.62522E-08
H2	9	J/KG	1.47310E+06	3.69036E-05
TS	10	GRD C	277.09	-1.47770E-09
PS	11	BAR	61.344	-1.37599E-09
TQ	12	GRD C	306.67	-3.40492E-10
ROQ	13	KG/CBM	712.91	8.18196E-07
PQ	14	BAR	155.12	-2.76152E-09
M	15	KG/S	13640.	2.92777E-06
KF	16	W/GRD	9.97109E+07	3.29413E-03
HT	17	M	69.893	-9.23769E-08
HC	18	M	3.3391	-7.38885E-08
DP	19	BAR	0.24461	-5.52303E-09
Y	20	-	1.2773	5.51097E-10
TSU	21	GRD C	328.15	4.37420E-09
RO2U	22	KG/CBM	657.58	-1.33137E-08
H2U	23	J/KG	1.50414E+06	2.91001E-05
TQU	24	GRD C	309.07	-1.06441E-09
ROQU	25	KG/CBM	707.51	-1.32215E-06
NY	26	QM/S	1.26067E-07	2.35920E-16
U	27	M/S	1.8606	3.87642E-09
RE	28	-	1.49298E+05	-5.01854E-04
LAM	29	-	2.04386E-02	2.38139E-11

CONVERGENCE REACHED AFTER 3 ITERATIONS OVER THE REACTOR POWER: PRDH = 1.085319

NZT = 5 : NUMBER OF ZONE
 RLIC = 0.50000 : INNER CORE HEIGHT (M)
 RLIB = 0.30000 : INNER BLANKET HEIGHT (M)
 RLB = 0.30000 : OUTER BLANKET HEIGHT (M)

QLC = 20241. : LINEAR HEAT IN CORE (W/M)
QLB = 1416.9 : LINEAR HEAT IN OUTER BLANKET (W/M)
RR = 1.0000 : QLIB/2 / QLB
RRR1 = 24290. : QLC * FIAX
RRR2 = 2850.5 : LOG(FIAX2) / (FIAX2-1) * QLB
RRR = 1.6765 : LOG(FIAX2) / (FIAX2-1) / FIAX
RPOWER 1.93726937269372715E-02 0.48062730627306277 0.51937269372693730 0.98062730627306280 1.0000000000000000

*** ICICL = 1: CDH =1.0000 DNBR =2.3218 AT X =1.6000 POS. 32

*** CONVERGENCE REACHED: NO MORE ITERATIONS NEEDED

ERGEBNISSE

Q = 2.58885E+09 W
K = 1.0007
PS = 61.344 BAR
TS = 277.09 GRD C
P1 = 155.24 BAR
T1 = 289.99 GRD C
T2 = 323.35 GRD C
M = 13640. KG/S
NP = 1.59161E+07 W
QNT = 8.68752E+08 W
QNT/QELO = 0.66827

***** ZUSATZ 08.09.1983 *****

KS = 0.95000 -
ETA = 0.77400 -
MS = 12958. KG/S
NPEL = 2.05634E+07 W

HOMOGENEOUS REACTOR WITH GRID SPACERS

LC = 1.9000 M
LR = 2.4000 M
T2U = 328.15 GRD C
U = 1.8606 M/S
RE = 1.49298E+05
LAMBDA = 2.04386E-02
DIST = 0.40000
\$K = 1.9891 (=CV*EPS*EPS)
DP = 0.24461 BAR
DPTOT = 0.41428 BAR

DPP = 5.1200 BAR

PRDH = 1.0853

CDH = 1.0000

CHF-CALCULATIONS

LC = 1.9000 M
T1 = 289.99 GRD C
RO1 = 746.99 KG/CBM
P1 = 155.24 BAR
H1 = 1.28331E+06 J/KG
T2 = 328.15 GRD
P2 = 155.00 BAR
ROQ = 707.51 KG/CBM
U = 1.8606 M/S
QL = 11548. W/M
D = 9.50000E-03 M
DH = 1.01157E-02 M
PZUD = 1.3684

EINGABEDATEN

FIAX = 1.2000
AK = 2.37000E+06
H0 = 1.58800E+06 J/KG
FQ = 1.9200
K4 = 0.00000E+00
NC = 10
OP = 1.1200
Q10 = 1.0000
Q20 = 9.1570
Q40 = 6.5070
Q1N = 1.7480
Q2N = 7.5400
Q4N = 8.7830
FQN = 1.9200

***** FLAT CORE (JAERI) *****

NAC = 2 : NUMBER OF CORE
IBLT = 1
RR1 = 0.60000 : RLIB / RLIC

RR2 = 0.60000 : RLB / RLIC
 RR3 = 7.00000E-02 : QLB / QLC
 FIAX2 = 0.20000 : PARAMETER FOR BLANKET POWER DISTRIBUTION

NZT = 5 : NUMBER OF ZONE
 RLIC = 0.50000 : INNER CORE HEIGHT (M)
 RLIB = 0.30000 : INNER BLANKET HEIGHT (M)
 RLB = 0.30000 : OUTER BLANKET HEIGHT (M)
 QLC = 20241. : LINEAR HEAT IN CORE (W/M)
 QLB = 1416.9 : LINEAR HEAT IN OUTER BLANKET (W/M)
 RR = 1.0000 : QLIB/2 / QLB
 RRR1 = 24290. : QLC * FIAX
 RRR2 = 2850.5 : LOG(FIAX2) / (FIAX2-1) * QLB
 RRR = 1.6765 : LOG(FIAX2) / (FIAX2-1) / FIAX

RPOWER 1.93726937269372715E-02 0.48062730627306277 0.51937269372693730 0.98062730627306280 1.0000000000000000

ERGEBNISSE

X = 1.0267
 PI/2X = 1.5299
 LC' = 0.76494
 RLCR = 0.500
 RLCR' = 0.765
 V1 = 0.70000E+00 WSC-2
 CG' = 0.48694E+00 COLUMBIA-EPRI
 V2 = 0.12090E+01 EIGENE,NEU

OVERPOWER FACTOR : 1.0000

POS X	T(X)	TW	COLUMBIA-EPRI			EDLUND			WSC-2			EIGENE,NEU			
			CHF	SM	SMLWR	CHF	SM	SMLWR	CHF	SM	SMLWR	CHF	SM	SMLWR	
1	0.05	290.09	292.75	5.464E+06	136.72	0.00	8.553E+06	214.00	0.00	8.168E+06	204.36	0.00	6.250E+06	156.38	0.00
2	0.10	290.22	293.71	5.369E+06	102.74	0.00	6.154E+06	117.76	0.00	7.795E+06	149.15	0.00	6.068E+06	116.10	0.00
3	0.15	290.39	294.95	5.326E+06	77.93	0.00	5.216E+06	76.33	0.00	7.559E+06	110.61	0.00	5.958E+06	87.18	0.00
4	0.20	290.61	296.57	5.316E+06	59.48	0.00	4.717E+06	52.79	0.00	7.411E+06	82.92	0.00	5.895E+06	65.97	0.00
5	0.25	290.91	298.70	5.328E+06	45.59	0.00	4.414E+06	37.77	0.00	7.321E+06	62.64	0.00	5.865E+06	50.19	0.00
6	0.30	291.29	301.47	5.355E+06	35.04	0.00	4.215E+06	27.58	0.00	7.271E+06	47.58	0.00	5.858E+06	38.33	0.00
7	0.35	293.52	346.96	8.673E+06	9.78	9.78	8.416E+06	9.49	9.49	1.255E+07	14.14	14.14	9.727E+06	10.97	10.97
8	0.40	296.27	347.05	7.325E+06	6.89	6.89	5.846E+06	5.50	5.50	1.018E+07	9.58	9.58	8.061E+06	7.58	7.58
9	0.45	299.42	347.11	6.416E+06	5.37	5.37	4.696E+06	3.93	3.93	8.662E+06	7.26	7.26	6.960E+06	5.83	5.83
10	0.50	302.81	347.14	5.699E+06	4.47	4.47	3.972E+06	3.12	3.12	7.508E+06	5.89	5.89	6.108E+06	4.79	4.79
11	0.55	306.29	347.15	5.077E+06	3.90	3.90	3.439E+06	2.64	2.64	6.544E+06	5.03	5.03	5.383E+06	4.13	4.13
12	0.60	309.71	347.14	4.501E+06	3.53	3.53	3.006E+06	2.36	2.36	5.684E+06	4.46	4.46	4.722E+06	3.70	3.70
13	0.65	312.92	347.10	3.941E+06	3.30	3.30	2.627E+06	2.20	2.20	4.878E+06	4.09	4.09	4.092E+06	3.43	3.43
14	0.70	315.79	347.03	3.373E+06	3.17	3.17	2.278E+06	2.14	2.14	4.094E+06	3.85	3.85	3.468E+06	3.26	3.26
15	0.75	318.24	346.94	2.780E+06	3.13	3.13	1.939E+06	2.19	2.19	3.306E+06	3.73	3.73	2.828E+06	3.19	3.19
16	0.80	320.16	346.80	2.140E+06	3.17	3.17	1.589E+06	2.36	2.36	2.491E+06	3.70	3.70	2.153E+06	3.19	3.19
17	0.85	320.57	330.63	7.116E+06	45.37	0.00	5.336E+06	34.03	0.00	1.015E+07	64.72	0.00	7.780E+06	49.61	0.00
18	0.90	320.93	330.01	5.762E+06	40.69	0.00	3.560E+06	25.13	0.00	7.779E+06	54.93	0.00	6.139E+06	43.35	0.00
19	0.95	321.27	330.02	4.905E+06	35.89	0.00	2.859E+06	20.92	0.00	6.398E+06	46.81	0.00	5.140E+06	37.61	0.00
20	1.00	321.60	330.67	4.404E+06	31.09	0.00	2.520E+06	17.79	0.00	5.628E+06	39.73	0.00	4.569E+06	32.26	0.00
21	1.05	321.96	331.99	4.150E+06	26.46	0.00	2.358E+06	15.03	0.00	5.244E+06	33.44	0.00	4.282E+06	27.30	0.00
22	1.10	322.36	334.09	4.060E+06	22.14	0.00	2.295E+06	12.52	0.00	5.104E+06	27.83	0.00	4.178E+06	22.78	0.00
23	1.15	324.22	346.91	7.360E+06	8.30	8.30	5.755E+06	6.49	6.49	1.060E+07	11.95	11.95	8.059E+06	9.09	9.09
24	1.20	326.50	347.00	6.372E+06	6.00	6.00	4.067E+06	3.83	3.83	8.774E+06	8.26	8.26	6.827E+06	6.42	6.42
25	1.25	329.07	347.06	5.634E+06	4.72	4.72	3.301E+06	2.76	2.76	7.505E+06	6.29	6.29	5.939E+06	4.97	4.97
26	1.30	331.80	347.09	5.021E+06	3.94	3.94	2.814E+06	2.21	2.21	6.508E+06	5.11	5.11	5.221E+06	4.10	4.10
27	1.35	334.56	347.10	4.474E+06	3.44	3.44	2.453E+06	1.88	1.88	5.663E+06	4.35	4.35	4.597E+06	3.53	3.53
28	1.40	337.20	347.09	3.962E+06	3.11	3.11	2.157E+06	1.69	1.69	4.905E+06	3.85	3.85	4.025E+06	3.16	3.16
29	1.45	339.63	347.05	3.463E+06	2.90	2.90	1.897E+06	1.59	1.59	4.197E+06	3.52	3.52	3.480E+06	2.91	2.91
30	1.50	341.74	346.98	2.960E+06	2.79	2.79	1.656E+06	1.56	1.56	3.512E+06	3.30	3.30	2.942E+06	2.77	2.77
31	1.55	343.49	346.89	2.436E+06	2.75	2.75	1.419E+06	1.60	1.60	2.829E+06	3.19	3.19	2.394E+06	2.70	2.70
32	1.60	344.83	346.75	1.874E+06	2.78	2.78	1.173E+06	1.74	1.74	2.127E+06	3.16	3.16	1.819E+06	2.70	2.70
33	1.65	344.89	346.09	5.326E+06	45.58	0.00	2.905E+06	24.86	0.00	7.565E+06	64.74	0.00	5.600E+06	47.92	0.00
34	1.70	344.89	346.01	4.168E+06	46.64	0.00	1.929E+06	21.58	0.00	5.527E+06	61.85	0.00	4.243E+06	47.48	0.00
35	1.75	344.88	345.93	3.247E+06	47.51	0.00	1.468E+06	21.48	0.00	4.092E+06	59.87	0.00	3.226E+06	47.20	0.00

185

36	1.80	344.88	345.86	2.521E+06	48.23	0.00	1.179E+06	22.57	0.00	3.057E+06	58.50	0.00	2.458E+06	47.03	0.00
37	1.85	344.88	345.80	1.951E+06	48.81	0.00	9.751E+05	24.40	0.00	2.299E+06	57.53	0.00	1.876E+06	46.95	0.00
38	1.90	344.87	345.73	1.506E+06	49.28	0.00	8.202E+05	26.84	0.00	1.737E+06	56.84	0.00	1.434E+06	46.91	0.00

MINIMALWERTE

CORRELATION	SMMIN	X	POS
*****	*****	*****	***
COLUMBIA-EPRI :	2.7466	1.5500	31
EDLUND :	1.5578	1.5000	30
WSC-2 :	3.1554	1.6000	32
EIGENE,NEU :	2.6989	1.6000	32
	X\$ =	-6.08375E-04	X\$ =
			-6.08375E-04

OVERPOWER FACTOR : 1.1200

POS X	T(X)	TW	COLUMBIA-EPRI			EDLUND			WSC-2			EIGENE,NEU			
			CHF	SM	SMLWR	CHF	SM	SMLWR	CHF	SM	SMLWR	CHF	SM	SMLWR	
1	0.05	290.10	293.09	5.468E+06	122.16	0.00	8.553E+06	191.07	0.00	8.168E+06	182.47	0.00	6.250E+06	139.63	0.00
2	0.10	290.25	294.15	5.375E+06	91.83	0.00	6.154E+06	105.14	0.00	7.795E+06	133.17	0.00	6.068E+06	103.66	0.00
3	0.15	290.44	295.54	5.332E+06	69.66	0.00	5.216E+06	68.15	0.00	7.559E+06	98.76	0.00	5.958E+06	77.84	0.00
4	0.20	290.69	297.36	5.322E+06	53.17	0.00	4.717E+06	47.13	0.00	7.411E+06	74.04	0.00	5.895E+06	58.90	0.00
5	0.25	291.02	299.74	5.334E+06	40.76	0.00	4.414E+06	33.72	0.00	7.321E+06	55.93	0.00	5.865E+06	44.81	0.00
6	0.30	291.45	302.85	5.361E+06	31.32	0.00	4.215E+06	24.63	0.00	7.271E+06	42.48	0.00	5.858E+06	34.22	0.00
7	0.35	293.94	347.02	8.665E+06	8.72	8.72	8.403E+06	8.46	8.46	1.253E+07	12.62	12.62	9.717E+06	9.78	9.78
8	0.40	297.01	347.11	7.319E+06	6.15	6.15	5.838E+06	4.90	4.90	1.017E+07	8.55	8.55	8.052E+06	6.76	6.76
9	0.45	300.52	347.17	6.410E+06	4.79	4.79	4.689E+06	3.51	3.51	8.653E+06	6.47	6.47	6.953E+06	5.20	5.20
10	0.50	304.30	347.21	5.694E+06	3.99	3.99	3.967E+06	2.78	2.78	7.501E+06	5.25	5.25	6.102E+06	4.27	4.27
11	0.55	308.16	347.21	5.073E+06	3.48	3.48	3.435E+06	2.35	2.35	6.538E+06	4.48	4.48	5.377E+06	3.69	3.69
12	0.60	311.94	347.20	4.497E+06	3.15	3.15	3.002E+06	2.10	2.10	5.678E+06	3.98	3.98	4.717E+06	3.30	3.30
13	0.65	315.49	347.16	3.937E+06	2.94	2.94	2.624E+06	1.96	1.96	4.873E+06	3.64	3.64	4.088E+06	3.06	3.06
14	0.70	318.65	347.09	3.370E+06	2.83	2.83	2.275E+06	1.91	1.91	4.090E+06	3.44	3.44	3.464E+06	2.91	2.91
15	0.75	321.32	347.00	2.778E+06	2.80	2.80	1.936E+06	1.95	1.95	3.303E+06	3.32	3.32	2.825E+06	2.84	2.84
16	0.80	323.42	346.86	2.138E+06	2.83	2.83	1.587E+06	2.10	2.10	2.489E+06	3.30	3.30	2.150E+06	2.85	2.85
17	0.85	323.87	335.07	6.904E+06	39.31	0.00	5.066E+06	28.84	0.00	9.847E+06	56.06	0.00	7.523E+06	42.83	0.00
18	0.90	324.26	334.37	5.592E+06	35.25	0.00	3.390E+06	21.37	0.00	7.547E+06	47.58	0.00	5.936E+06	37.42	0.00
19	0.95	324.63	334.37	4.761E+06	31.10	0.00	2.728E+06	17.82	0.00	6.207E+06	40.55	0.00	4.971E+06	32.47	0.00
20	1.00	324.99	335.08	4.275E+06	26.95	0.00	2.407E+06	15.17	0.00	5.459E+06	34.42	0.00	4.418E+06	27.85	0.00
21	1.05	325.38	336.54	4.029E+06	22.94	0.00	2.253E+06	12.83	0.00	5.087E+06	28.96	0.00	4.141E+06	23.57	0.00
22	1.10	325.82	338.86	3.942E+06	19.19	0.00	2.194E+06	10.68	0.00	4.951E+06	24.11	0.00	4.040E+06	19.67	0.00
23	1.15	327.83	346.97	7.117E+06	7.16	7.16	5.423E+06	5.46	5.46	1.025E+07	10.32	10.32	7.765E+06	7.82	7.82
24	1.20	330.28	347.06	6.162E+06	5.18	5.18	3.846E+06	3.23	3.23	8.485E+06	7.13	7.13	6.578E+06	5.53	5.53
25	1.25	333.04	347.12	5.448E+06	4.07	4.07	3.127E+06	2.34	2.34	7.258E+06	5.43	5.43	5.723E+06	4.28	4.28
26	1.30	335.94	347.16	4.855E+06	3.40	3.40	2.670E+06	1.87	1.87	6.294E+06	4.41	4.41	5.031E+06	3.52	3.52
27	1.35	338.83	347.16	4.326E+06	2.97	2.97	2.330E+06	1.60	1.60	5.476E+06	3.75	3.75	4.429E+06	3.04	3.04
28	1.40	341.56	347.15	3.831E+06	2.68	2.68	2.051E+06	1.44	1.44	4.743E+06	3.32	3.32	3.878E+06	2.72	2.72
29	1.45	344.03	347.11	3.349E+06	2.50	2.50	1.806E+06	1.35	1.35	4.059E+06	3.04	3.04	3.353E+06	2.51	2.51
30	1.50	344.90	347.04	2.863E+06	2.40	2.40	1.578E+06	1.33	1.33	3.397E+06	2.85	2.85	2.835E+06	2.38	2.38
31	1.55	344.90	346.95	2.356E+06	2.37	2.37	1.354E+06	1.36	1.36	2.736E+06	2.75	2.75	2.307E+06	2.32	2.32
32	1.60	344.89	346.81	1.812E+06	2.40	2.40	1.121E+06	1.49	1.49	2.057E+06	2.72	2.72	1.753E+06	2.32	2.32
33	1.65	344.89	346.13	4.886E+06	37.33	0.00	2.376E+06	18.15	0.00	6.943E+06	53.05	0.00	5.072E+06	38.75	0.00
34	1.70	344.89	346.04	3.825E+06	38.22	0.00	1.619E+06	16.17	0.00	5.073E+06	50.68	0.00	3.842E+06	38.39	0.00
35	1.75	344.88	345.96	2.982E+06	38.95	0.00	1.250E+06	16.33	0.00	3.756E+06	49.06	0.00	2.921E+06	38.16	0.00

36	1.80	344.88	345.89	2.315E+06	39.56	0.00	1.015E+06	17.35	0.00	2.806E+06	47.94	0.00	2.226E+06	38.03	0.00
37	1.85	344.88	345.82	1.793E+06	40.05	0.00	8.469E+05	18.92	0.00	2.110E+06	47.14	0.00	1.699E+06	37.96	0.00
38	1.90	344.87	345.76	1.385E+06	40.45	0.00	7.175E+05	20.96	0.00	1.594E+06	46.58	0.00	1.298E+06	37.93	0.00

MINIMALWERTE

CORRELATION	SMMIN	X	POS				
*****	*****	*****	***				
COLUMBIA-EPRI :	2.3715	1.5500	31	2.3715	1.5500	31	
EDLUND :	1.3257	1.5000	30	1.3257	1.5000	30	
WSC-2 :	2.7246	1.6000	32	2.7246	1.6000	32	
EIGENE,NEU :	2.3218	1.6000	32	2.3218	1.6000	32	
	X\$ =	4.24555E-02		X\$ =	4.24555E-02		

***** FLAT CORE (JAERI) *****

NAC = 2 : NUMBER OF CORE
 IBLT = 1
 RR1 = 0.60000 : RLIB / RLIC
 RR2 = 0.60000 : RLB / RLIC
 RR3 = 7.00000E-02 : QLB / QLC
 FIAX2 = 0.20000 : PARAMETER FOR BLANKET POWER DISTRIBUTION

NZT = 5 : NUMBER OF ZONE
 RLIC = 0.50000 : INNER CORE HEIGHT (M)
 RLIB = 0.30000 : INNER BLANKET HEIGHT (M)
 RLB = 0.30000 : OUTER BLANKET HEIGHT (M)
 QLC = 20241. : LINEAR HEAT IN CORE (W/M)
 QLB = 1416.9 : LINEAR HEAT IN OUTER BLANKET (W/M)
 RR = 1.0000 : QLIB/2 / QLB
 RRR1 = 24290. : QLC * FIAX
 RRR2 = 2850.5 : LOG(FIAX2) / (FIAX2-1) * QLB
 RRR = 1.6765 : LOG(FIAX2) / (FIAX2-1) / FIAX

RPOWER 1.93726937269372715E-02 0.48062730627306277 0.51937269372693730 0.98062730627306280 1.0000000000000000

ERGEBNISSE

X = 1.0267
 PI/2X = 1.5299

LC' = 0.76494
RLCR = 0.500
RLCR' = 0.765
V1 = 0.70000E+00 WSC-2
CG' = 0.48694E+00 COLUMBIA-EPRI
V2 = 0.12090E+01 EIGENE,NEU

OVERPOWER FACTOR : 1.0000

POS X	T(X)	TW	COLUMBIA-EPRI			EDLUND			WSC-2			EIGENE,NEU			
			CHF	SM	SMLWR	CHF	SM	SMLWR	CHF	SM	SMLWR	CHF	SM	SMLWR	
1	0.05	290.09	292.75	5.464E+06	136.72	0.00	8.553E+06	214.00	0.00	8.168E+06	204.36	0.00	6.250E+06	156.38	0.00
2	0.10	290.22	293.71	5.369E+06	102.74	0.00	6.154E+06	117.76	0.00	7.795E+06	149.15	0.00	6.068E+06	116.10	0.00
3	0.15	290.39	294.95	5.326E+06	77.93	0.00	5.216E+06	76.33	0.00	7.559E+06	110.61	0.00	5.958E+06	87.18	0.00
4	0.20	290.61	296.57	5.316E+06	59.48	0.00	4.717E+06	52.79	0.00	7.411E+06	82.92	0.00	5.895E+06	65.97	0.00
5	0.25	290.91	298.70	5.328E+06	45.59	0.00	4.414E+06	37.77	0.00	7.321E+06	62.64	0.00	5.865E+06	50.19	0.00
6	0.30	291.29	301.47	5.355E+06	35.04	0.00	4.215E+06	27.58	0.00	7.271E+06	47.58	0.00	5.858E+06	38.33	0.00
7	0.30	291.29	336.21	9.103E+06	13.51	13.51	9.950E+06	14.76	14.76	1.340E+07	19.88	19.88	1.032E+07	15.31	15.31
8	0.35	293.52	346.96	7.670E+06	8.65	8.65	6.532E+06	7.36	7.36	1.083E+07	12.21	12.21	8.519E+06	9.60	9.60
9	0.40	296.27	347.05	6.754E+06	6.35	6.35	5.180E+06	4.87	4.87	9.254E+06	8.71	8.71	7.391E+06	6.95	6.95
10	0.45	299.42	347.11	6.047E+06	5.06	5.06	4.367E+06	3.66	3.66	8.085E+06	6.77	6.77	6.537E+06	5.48	5.48
11	0.50	302.81	347.14	5.442E+06	4.27	4.27	3.783E+06	2.97	2.97	7.119E+06	5.58	5.58	5.819E+06	4.56	4.56
12	0.55	306.29	347.15	4.888E+06	3.75	3.75	3.321E+06	2.55	2.55	6.267E+06	4.81	4.81	5.174E+06	3.97	3.97
13	0.60	309.71	347.14	4.356E+06	3.42	3.42	2.927E+06	2.30	2.30	5.479E+06	4.30	4.30	4.566E+06	3.58	3.58
14	0.65	312.92	347.10	3.827E+06	3.21	3.21	2.573E+06	2.16	2.16	4.723E+06	3.96	3.96	3.972E+06	3.33	3.33
15	0.70	315.79	347.03	3.283E+06	3.09	3.09	2.239E+06	2.11	2.11	3.975E+06	3.74	3.74	3.374E+06	3.17	3.17
16	0.75	318.24	346.94	2.708E+06	3.05	3.05	1.910E+06	2.15	2.15	3.215E+06	3.62	3.62	2.755E+06	3.11	3.11
17	0.80	320.16	346.80	2.085E+06	3.09	3.09	1.568E+06	2.33	2.33	2.424E+06	3.60	3.60	2.098E+06	3.11	3.11
18	0.80	320.16	331.93	6.538E+05	3.57	0.00	7.491E+05	4.09	0.00	7.322E+05	3.99	0.00	6.450E+05	3.52	0.00
19	0.85	320.57	330.63	5.634E+05	3.59	0.00	6.801E+05	4.34	0.00	6.271E+05	4.00	0.00	5.540E+05	3.53	0.00
20	0.90	320.93	330.01	5.112E+05	3.61	0.00	6.374E+05	4.50	0.00	5.662E+05	4.00	0.00	5.014E+05	3.54	0.00
21	0.95	321.27	330.02	4.940E+05	3.61	0.00	6.207E+05	4.54	0.00	5.451E+05	3.99	0.00	4.835E+05	3.54	0.00
22	1.00	321.60	330.67	5.105E+05	3.60	0.00	6.291E+05	4.44	0.00	5.619E+05	3.97	0.00	4.990E+05	3.52	0.00
23	1.05	321.96	331.99	5.611E+05	3.58	0.00	6.617E+05	4.22	0.00	6.167E+05	3.93	0.00	5.481E+05	3.49	0.00
24	1.10	322.36	334.09	6.475E+05	3.53	0.00	7.171E+05	3.91	0.00	7.116E+05	3.88	0.00	6.325E+05	3.45	0.00
25	1.10	322.36	346.78	2.067E+06	3.07	3.07	1.500E+06	2.23	2.23	2.363E+06	3.51	3.51	2.062E+06	3.06	3.06
26	1.15	324.22	346.91	2.468E+06	2.78	2.78	1.694E+06	1.91	1.91	2.847E+06	3.21	3.21	2.474E+06	2.79	2.79
27	1.20	326.50	347.00	2.700E+06	2.54	2.54	1.801E+06	1.69	1.69	3.129E+06	2.94	2.94	2.713E+06	2.55	2.55
28	1.25	329.07	347.06	2.796E+06	2.34	2.34	1.841E+06	1.54	1.54	3.242E+06	2.72	2.72	2.809E+06	2.35	2.35
29	1.30	331.80	347.09	2.782E+06	2.18	2.18	1.828E+06	1.43	1.43	3.219E+06	2.53	2.53	2.792E+06	2.19	2.19
30	1.35	334.56	347.10	2.681E+06	2.06	2.06	1.771E+06	1.36	1.36	3.088E+06	2.37	2.37	2.684E+06	2.06	2.06
31	1.40	337.20	347.09	2.508E+06	1.97	1.97	1.681E+06	1.32	1.32	2.870E+06	2.25	2.25	2.502E+06	1.96	1.96
32	1.45	339.63	347.05	2.274E+06	1.90	1.90	1.562E+06	1.31	1.31	2.581E+06	2.16	2.16	2.259E+06	1.89	1.89
33	1.50	341.74	346.98	1.987E+06	1.87	1.87	1.417E+06	1.33	1.33	2.233E+06	2.10	2.10	1.963E+06	1.85	1.85
34	1.55	343.49	346.89	1.650E+06	1.86	1.86	1.246E+06	1.41	1.41	1.833E+06	2.07	2.07	1.620E+06	1.83	1.83
35	1.60	344.83	346.75	1.264E+06	1.88	1.88	1.046E+06	1.55	1.55	1.388E+06	2.06	2.06	1.233E+06	1.83	1.83

106

36	1.60	344.83	346.18	3.133E+05	2.05	0.00	4.525E+05	2.96	0.00	3.348E+05	2.19	0.00	3.012E+05	1.97	0.00
37	1.65	344.89	346.09	2.408E+05	2.06	0.00	3.880E+05	3.32	0.00	2.564E+05	2.19	0.00	2.311E+05	1.98	0.00
38	1.70	344.89	346.01	1.849E+05	2.07	0.00	3.330E+05	3.73	0.00	1.964E+05	2.20	0.00	1.772E+05	1.98	0.00
39	1.75	344.88	345.93	1.420E+05	2.08	0.00	2.860E+05	4.19	0.00	1.505E+05	2.20	0.00	1.359E+05	1.99	0.00
40	1.80	344.88	345.86	1.090E+05	2.09	0.00	2.459E+05	4.70	0.00	1.153E+05	2.21	0.00	1.042E+05	1.99	0.00
41	1.85	344.88	345.80	8.366E+04	2.09	0.00	2.115E+05	5.29	0.00	8.833E+04	2.21	0.00	7.992E+04	2.00	0.00
42	1.90	344.87	345.73	6.419E+04	2.10	0.00	1.820E+05	5.95	0.00	6.768E+04	2.21	0.00	6.128E+04	2.00	0.00

MINIMALWERTE

CORRELATION	SMMIN	X	POS			
*****	*****	*****	***			
COLUMBIA-EPRI :	1.8599	1.5500	34	1.8599	1.5500	34
EDLUND :	1.3082	1.4500	32	1.3082	1.4500	32
WSC-2 :	2.0587	1.6000	35	2.0587	1.6000	35
EIGENE,NEU :	1.8266	1.5500	34	1.8266	1.5500	34

X\$ = -1.28197E-02

X\$ = -1.28197E-02

OVERPOWER FACTOR : 1.1200

POS X	T(X)	TW	COLUMBIA-EPRI			EDLUND			WSC-2			EIGENE, NEU			
			CHF	SM	SMLWR	CHF	SM	SMLWR	CHF	SM	SMLWR	CHF	SM	SMLWR	
1	0.05	290.10	293.09	5.468E+06	122.16	0.00	8.553E+06	191.07	0.00	8.168E+06	182.47	0.00	6.250E+06	139.63	0.00
2	0.10	290.25	294.15	5.375E+06	91.83	0.00	6.154E+06	105.14	0.00	7.795E+06	133.17	0.00	6.068E+06	103.66	0.00
3	0.15	290.44	295.54	5.332E+06	69.66	0.00	5.216E+06	68.15	0.00	7.559E+06	98.76	0.00	5.958E+06	77.84	0.00
4	0.20	290.69	297.36	5.322E+06	53.17	0.00	4.717E+06	47.13	0.00	7.411E+06	74.04	0.00	5.895E+06	58.90	0.00
5	0.25	291.02	299.74	5.334E+06	40.76	0.00	4.414E+06	33.72	0.00	7.321E+06	55.93	0.00	5.865E+06	44.81	0.00
6	0.30	291.45	302.85	5.361E+06	31.32	0.00	4.215E+06	24.63	0.00	7.271E+06	42.48	0.00	5.858E+06	34.22	0.00
7	0.30	291.45	341.75	9.107E+06	12.06	12.06	9.950E+06	13.18	13.18	1.340E+07	17.75	17.75	1.032E+07	13.67	13.67
8	0.35	293.94	347.02	7.673E+06	7.72	7.72	6.532E+06	6.57	6.57	1.083E+07	10.90	10.90	8.519E+06	8.57	8.57
9	0.40	297.01	347.11	6.756E+06	5.68	5.68	5.180E+06	4.35	4.35	9.254E+06	7.77	7.77	7.391E+06	6.21	6.21
10	0.45	300.52	347.17	6.048E+06	4.52	4.52	4.367E+06	3.27	3.27	8.085E+06	6.05	6.05	6.537E+06	4.89	4.89
11	0.50	304.30	347.21	5.443E+06	3.81	3.81	3.783E+06	2.65	2.65	7.119E+06	4.99	4.99	5.819E+06	4.08	4.08
12	0.55	308.16	347.21	4.889E+06	3.35	3.35	3.321E+06	2.28	2.28	6.267E+06	4.30	4.30	5.174E+06	3.55	3.55
13	0.60	311.94	347.20	4.357E+06	3.05	3.05	2.927E+06	2.05	2.05	5.479E+06	3.84	3.84	4.566E+06	3.20	3.20
14	0.65	315.49	347.16	3.828E+06	2.86	2.86	2.573E+06	1.92	1.92	4.723E+06	3.53	3.53	3.972E+06	2.97	2.97
15	0.70	318.65	347.09	3.284E+06	2.76	2.76	2.239E+06	1.88	1.88	3.975E+06	3.34	3.34	3.374E+06	2.83	2.83
16	0.75	321.32	347.00	2.709E+06	2.73	2.73	1.910E+06	1.92	1.92	3.215E+06	3.24	3.24	2.755E+06	2.77	2.77
17	0.80	323.42	346.86	2.085E+06	2.76	2.76	1.568E+06	2.08	2.08	2.424E+06	3.21	3.21	2.098E+06	2.78	2.78
18	0.80	323.42	336.53	6.540E+05	3.18	0.00	7.491E+05	3.65	0.00	7.322E+05	3.56	0.00	6.450E+05	3.14	0.00
19	0.85	323.87	335.07	5.636E+05	3.21	0.00	6.801E+05	3.87	0.00	6.271E+05	3.57	0.00	5.540E+05	3.15	0.00
20	0.90	324.26	334.37	5.114E+05	3.22	0.00	6.374E+05	4.02	0.00	5.662E+05	3.57	0.00	5.014E+05	3.16	0.00
21	0.95	324.63	334.37	4.942E+05	3.23	0.00	6.207E+05	4.05	0.00	5.451E+05	3.56	0.00	4.835E+05	3.16	0.00
22	1.00	324.99	335.08	5.107E+05	3.22	0.00	6.291E+05	3.97	0.00	5.619E+05	3.54	0.00	4.990E+05	3.15	0.00
23	1.05	325.38	336.54	5.613E+05	3.20	0.00	6.617E+05	3.77	0.00	6.167E+05	3.51	0.00	5.481E+05	3.12	0.00
24	1.10	325.82	338.86	6.478E+05	3.15	0.00	7.171E+05	3.49	0.00	7.116E+05	3.46	0.00	6.325E+05	3.08	0.00
25	1.10	325.82	346.84	2.068E+06	2.74	2.74	1.500E+06	1.99	1.99	2.363E+06	3.13	3.13	2.062E+06	2.73	2.73
26	1.15	327.83	346.97	2.469E+06	2.49	2.49	1.694E+06	1.70	1.70	2.847E+06	2.87	2.87	2.474E+06	2.49	2.49
27	1.20	330.28	347.06	2.701E+06	2.27	2.27	1.801E+06	1.51	1.51	3.129E+06	2.63	2.63	2.713E+06	2.28	2.28
28	1.25	333.04	347.12	2.796E+06	2.09	2.09	1.841E+06	1.38	1.38	3.242E+06	2.42	2.42	2.809E+06	2.10	2.10
29	1.30	335.94	347.16	2.783E+06	1.95	1.95	1.828E+06	1.28	1.28	3.219E+06	2.25	2.25	2.792E+06	1.96	1.96
30	1.35	338.83	347.16	2.681E+06	1.84	1.84	1.771E+06	1.21	1.21	3.088E+06	2.12	2.12	2.684E+06	1.84	1.84
31	1.40	341.56	347.15	2.509E+06	1.76	1.76	1.681E+06	1.18	1.18	2.870E+06	2.01	2.01	2.502E+06	1.75	1.75
32	1.45	344.03	347.11	2.275E+06	1.70	1.70	1.562E+06	1.17	1.17	2.581E+06	1.93	1.93	2.259E+06	1.69	1.69
33	1.50	344.90	347.04	1.988E+06	1.67	1.67	1.417E+06	1.19	1.19	2.233E+06	1.88	1.88	1.963E+06	1.65	1.65
34	1.55	344.90	346.95	1.650E+06	1.66	1.66	1.246E+06	1.25	1.25	1.833E+06	1.85	1.85	1.620E+06	1.63	1.63
35	1.60	344.89	346.81	1.265E+06	1.68	1.68	1.046E+06	1.39	1.39	1.388E+06	1.84	1.84	1.233E+06	1.63	1.63

- 92 -

36	1.60	344.89	346.21	3.134E+05	1.83	0.00	4.525E+05	2.64	0.00	3.348E+05	1.96	0.00	3.012E+05	1.76	0.00
37	1.65	344.89	346.13	2.408E+05	1.84	0.00	3.880E+05	2.96	0.00	2.564E+05	1.96	0.00	2.311E+05	1.77	0.00
38	1.70	344.89	346.04	1.850E+05	1.85	0.00	3.330E+05	3.33	0.00	1.964E+05	1.96	0.00	1.772E+05	1.77	0.00
39	1.75	344.88	345.96	1.421E+05	1.86	0.00	2.860E+05	3.74	0.00	1.505E+05	1.97	0.00	1.359E+05	1.78	0.00
40	1.80	344.88	345.89	1.090E+05	1.86	0.00	2.459E+05	4.20	0.00	1.153E+05	1.97	0.00	1.042E+05	1.78	0.00
41	1.85	344.88	345.82	8.369E+04	1.87	0.00	2.115E+05	4.72	0.00	8.833E+04	1.97	0.00	7.992E+04	1.79	0.00
42	1.90	344.87	345.76	6.421E+04	1.88	0.00	1.820E+05	5.32	0.00	6.768E+04	1.98	0.00	6.128E+04	1.79	0.00

MINIMALWERTE

CORRELATION	SMMIN	X	POS			
*****	*****	*****	****			
COLUMBIA-EPRI :	1.6611	1.5500	34	1.6611	1.5500	34
EDLUND :	1.1680	1.4500	32	1.1680	1.4500	32
WSC-2 :	1.8381	1.6000	35	1.8381	1.6000	35
EIGENE,NEU :	1.6309	1.5500	34	1.6309	1.5500	34

X\$ = 2.87840E-02 X\$ = 2.87840E-02

7. UTILITY PROGRAMS

All main results of a run are appended to an existing data set, so that the results of many runs can be accumulated in this data pool. To retrieve and present these results, some utility programs are necessary.

7.1 CREATING THE DATA POOL

To create and initiate the data pool, the program INIT must be used as demonstrated in the following example:

```
//PROJECTL JOB (.....,.....,.....),.....,TIME=(,30),MSGCLASS=A
// EXEC PGM=IEFBR14
//DD1 DD DSN=PROJECT.APWRH.DATA,DISP=(OLD,DELETE)
// EXEC PGM=INIT
//STEPLIB DD DISP=SHR,DSN=PROJECT.HADA.LOAD
//FT08F001 DD DSN=PROJECT.APWRD.DATA,UNIT=DISK,VOL=SER=BAT00C,
// DCB=(LRECL=2996,RECFM=VBS,BLKSIZE=3000),
// DISP=(NEW,CATLG),SPACE=(CYL,(10,10))
```

7.2 LISTING THE RESULTS

With the program LISTP, accumulated results may be listed in a sorted manner as shown in Reference /6/. Another version of this code named LISTD lists the results of homogeneous reactors with the same rod diameter. These programs request, as input, first the unit number assigned to the data pool, and then one or more group indicators in successive lines as shown below.

```
//PROJECTL JOB (.....,.....,.....),.....,TIME=(,30),MSGCLASS=A
//LIST EXEC PGM=LISTP
//STEPLIB DD DISP=SHR,DSN=PROJECT.HADA.LOAD
//* LIST REACTORS WITH EQUAL ROD PITCH
//FT05F001 DD *
8 INPUT UNIT OF PROJECT.APWRS.DATA
2
3 DP-ITER.(1),HOMOGEN(2),HETEROGEN(3),JAERI(4)
//FT06F001 DD SYSOUT=*,DCB=(RECFM=FBA,LRECL=133,BLKSIZE=3857)
//FT08F001 DD DISP=SHR,DSN=PROJECT.APWRD.DATA
//FT09F001 DD SYSOUT=*,DCB=(RECFM=FBA,LRECL=133,BLKSIZE=3857)
```

```
//FT10F001 DD SYSOUT=*,DCB=(RECFM=FBA,LRECL=133,BLKSIZE=3857)
```

7.3 DELETING ENTRIES

With the program DELT the results of certain runs may be deleted from the data pool. To do this the original data set is copied to a new one by excluding the specified entries. As first input line, the unit numbers of the input and output data sets are required. Then in consecutive lines as many entry numbers as desired may be marked for exclusion. As the numbers of the entries (the record number in the data set) are changed during deletion, it is useful to start with the greatest number going down to the lowest one. In the following example, deleting is demonstrated.

```
//PROJECTD JOB (.....,.....,.....),.....,TIME=(,30),MSGCLASS=A
//DELT EXEC PGM=DELT
//STEPLIB DD DISP=SHR,DSN=PROJECT.HADA.LOAD
//FT05F001 DD *
8,18    EINGABEEINHEIT PROJECT.APWRD.DATA, AUSGABEEINHEIT
88
87
32
//FT06F001 DD SYSOUT=*,DCB=(RECFM=FBA,LRECL=133,BLKSIZE=3857)
//FT08F001 DD DISP=SHR,DSN=PROJECT.APWRD.DATA
//FT09F001 DD SYSOUT=*,DCB=(RECFM=FBA,LRECL=133,BLKSIZE=3857)
//FT18F001 DD DISP=SHR,DSN=PROJECT.APWRH.DATA
```

7.4 LISTING A SPECIFIED ENTRY

With the program OUT1, one or more entries may be listed as they are present in the data pool. The first input to this program is again the unit number. Then one or more entry numbers may be specified in consecutive lines. The following example demonstrates the usage of OUT1 :

```
//PROJECTD JOB (.....,.....,.....),.....,TIME=(,30),MSGCLASS=A
//OUT1 EXEC PGM=OUT1
//STEPLIB DD DISP=SHR,DSN=PROJECT.HADA.LOAD
//FT05F001 DD *
8      EINGABEEINHEIT PROJECT.APWRD.DATA,AUSGABEEINHEIT
31
75
```



```
//FT06F001 DD SYSOUT=*,DCB=(RECFM=FBA,LRECL=133,BLKSIZE=3857)
//FT08F001 DD DISP=SHR,DSN=PROJECT.APWRD.DATA
//FT09F001 DD SYSOUT=*,DCB=(RECFM=FBA,LRECL=133,BLKSIZE=3857)
```

7.5 COMPRESSING THE DATA POOL

The program COMP is used to omit entries with the same input data. Like the program DELT, this program uses two different data sets for input and output, so that the original data set remains unaffected. The program requires, as input, only the unit numbers assigned to the data pools.

```
//PROFECTC JOB (.....,.....,.....),.....,TIME=(,30),MSGCLASS=A
//COMP EXEC PGM=COMP
//STEPLIB DD DISP=SHR,DSN=PROJECT.HADA.LOAD
//FT05F001 DD *
8,18      EINGABEEINHEIT PROJECT.APWRD.DATA,AUSGABEEINHEIT
//FT06F001 DD SYSOUT=*,DCB=(RECFM=FBA,LRECL=133,BLKSIZE=3857)
//FT08F001 DD DISP=SHR,DSN=PROJECT.APWRD.DATA
//FT09F001 DD SYSOUT=*,DCB=(RECFM=FBA,LRECL=133,BLKSIZE=3857)
//FT18F001 DD DISP=SHR,DSN=PROJECT.APWRH.DATA
```

7.6 PLOTTING THE RESULTS

With the program PLOT, specified entries or group of entries may be selected as input for the plot routines. This program needs Calcomp/ Versatec plotter software and it is therefore restricted in usage. The following example shows the different commands and their meaning. The presented input stream was used to plot the figures in Reference /2/.

```
//PROJECTP JOB (.....,.....,.....),.....,TIME=(,30),MSGCLASS=A
//*MAIN LINES=50
//PLOT EXEC PGM=PLOT
//STEPLIB DD DISP=SHR,DSN=PROJECT.HADA.LOAD
//PLOTWK01 DD UNIT=SYSSQ,SPACE=(CYL,(10,5))
//PLOTWK02 DD UNIT=SYSSQ,SPACE=(CYL,(10,5))
//VECTR1 DD UNIT=SYSSQ,SPACE=(CYL,(10,5)),DISP=(MOD,PASS),
//      DSN=&&VECTR1
//VECTR2 DD UNIT=SYSSQ,SPACE=(CYL,(10,5)),DISP=(MOD,PASS),
//      DSN=&&VECTR2
//PLOTLOG DD SYSOUT=*
```

```
//COMM DD SYSOUT=*
//FT01F001 DD *
KOM
KOM
KOM          BESCHREIBUNG DER EINGABEDATEN
KOM
KOM  INI PLOTTERNUMMER, XMAX, YMAX, PLOTFAKTOR
KOM      0,1,2,3,4,... 0 = DUMMY-PLOT
KOM          1 = BILDSCHIRM GA
KOM          2 = BILDSCHIRM T4015
KOM          3 = SPEICHERBILDSCHIRM KSG
KOM          4 = CALCOMP, STATOS, XYNETICS, VERSATEC
KOM          >4 = PLOTAUSGABE ERFOLGT UEBER EINHEIT 9
KOM      XMAX          ZEICHNUNGSLAENGE IN CM (FUER FAKTOR 1)
KOM      YMAX          ZEICHNUNGSHOEHE  IN CM (FUER FAKTOR 1)
KOM      PLOTFAKTOR    1  PLOTTEREINHEIT = 1CM
KOM          <1       VERKLEINERUNG
KOM          >1       VERGROESSERUNG
KOM
KOM
KOM  NPL
KOM
KOM
KOM  GRP INDEX, TEXT1, TEXT2
KOM      INDEX          GRUPPENINDEX
KOM          1          HOMOGENE REAKTOREN
KOM          2          HETEROGENE REAKTOREN
KOM          3          1 UND 2
KOM
KOM
KOM  FIG NUMMER, TEXT1, TEXT2
KOM      NUMMER          ABBILDUNGSNUMMER
KOM
KOM
KOM  PAR NPAR, NAME=, EINHEIT, UMRECHNUNGSFAKTOR DARSTELLUNG/INTERN
KOM      NPAR            INDEX DES PARAMETERWERTS
KOM
KOM
KOM  XAX TEXT , EINHEIT, UMRECHNUNGSFAKTOR, STARTWERT, ENDWERT, ACHSENLAENGE
KOM      BEISPIEL      1.E2 CM/M WERT IN M WIRD IN CM DARGESTELLT.
KOM          DIE ACHSE BEGINNT BEI 0.7 CM
KOM          UND ENDET BEI 1.2 CM.
KOM          DIE GEZEICHNETE ACHSENLAENGE IST 10 CM.
```

KOM
KOM
KOM YAX TEXT ,EINHEIT,UMRECHNUNGSFAKTOR, STARTWERT,ENDWERT,ACHSENLAENGE
KOM
KOM
KOM TXT X-KOORD.,Y-KOORD.,HOEHE,TEXT,WINKEL
KOM
KOM
KOM PLT TYP,OPTION,NX,NY
KOM TYP : DPI DP-ITERATION
KOM HOM HOMOGENER KERN
KOM HET HETEROGENER KERN
KOM OPTION : POW KONSTANTE PUMPLEISUNG
KOM CHR KONSTANTE PUMPENCHARAKTERISTIK
KOM NX INDEX DES ABSZISSENWERTES
KOM NY INDEX DES ORDINATENWERTES
KOM
KOM
KOM SYM TYP,OPTION,NX,NY,NSYM
KOM
KOM
KOM ADI NN,NN WERTEPAARE IN INTERNEN EINHEITEN
KOM
KOM
KOM ADD NN,NN WERTEPAARE IN DARSTELLUNGSEINHEITEN
KOM
KOM
KOM ADZ NN,NN WERTEPAARE IN PLOTTEREINHEITEN
KOM
KOM
KOM MIT FIG WIRD EIN EINZELPLOT EROEFFNET, DIESES KOMMANDO
KOM MUSS DESHALB STETS ALS ERSTES ERSCHEINEN.
KOM DIE KOMMANDOS PAR,XAX,YAX KOENNEN IN BELIEBIGER REIHEN-
KOM FOLGE ANGESCHLOSSEN WERDEN, FEHLT DAS KOMMANDO PAR, SO
KOM WERDEN ALLE DATEN FUER DIE AUSGEWAEHLTE DATENGRUPPE DAR-
KOM GESTELLT (ALS EINE KURVE).
KOM DIE GRUPPE PLT,ADI,ADD,ADZ,SYM SCHLIESST IN BELIEBIGER
KOM REIHENFOLGE DIE KOMMANDOSEQUENZ AB. DAMIT EIN SINNVOLLER
KOM PLOT ERSTELLT WERDEN KANN, MUSS MINDESTENS EINES DAVON
KOM VORHANDEN SEIN.
KOM
KOM
KOM EIN NEUES EINZELBILD KANN DURCH FIG ODER DURCH INI
KOM EROEFFNET WERDEN, WOBEI INI NUR DANN ANZUGEBEN IST, WENN

KOM DIE GRUNDPARAMETER GEAENDERT WERDEN SOLLEN.

KOM

KOM DARSTELLUNG DER ERGEBNISSE

KOM

KOM

KOM 1. BILD QELNET VS. D MIT P ALS PARAMETER

KOM

KOM

PRT

GRP 1,HOMOGENEOUS CORE,CONSTANT PUMP CHARACTERISTICS

PAR 15, P=,CM,1.E2

XAX ROD DIAMETER D,CM,1.E2,0.7,1.2,10.

YAX NET PLANT ELECTRICAL POWER QELNET,MW,1.E-6,800.,1300.,10.

PLT HOM,CHR,16,42

NPL

YAX DNB RATIO,-,1.,1.2,1.7,10.

PLT HOM,CHR,16,101

TXT 8.,-2.5,.21,OVERPOWER FACTOR 1,0.

ADD 4,0.7,1.301,1.2,1.301,1.2,1.299,0.7,1.299

NPL

YAX DNB RATIO WITH CONTROL ROD,-,1.,1.2,1.7,10.

PLT HOM,CHR,16,104

TXT 8.,-2.5,.21,OVERPOWER FACTOR 1,0.

ADD 4,0.7,1.301,1.2,1.301,1.2,1.299,0.7,1.299

NPL

YAX DNB RATIO,-,1.,1.1,1.6,10.

PLT HOM,CHR,16,127

TXT 8.,-2.5,.21,OVERPOWER FACTOR 1.12,0.

ADD 4,0.7,1.301,1.2,1.301,1.2,1.299,0.7,1.299

NPL

YAX DNB RATIO WITH CONTROL ROD,-,1.,1.1,1.6,10.

PLT HOM,CHR,16,130

TXT 8.,-2.5,.21,OVERPOWER FACTOR 1.12,0.

ADD 4,0.7,1.301,1.2,1.301,1.2,1.299,0.7,1.299

NPL

YAX INLET TEMPERATURE T1,GRD C,1.,260.,310.,10.

PLT HOM,CHR,16,38

NPL

YAX OUTLET TEMPERATURE T2,GRD C,1.,316.,326.,10.

PLT HOM,CHR,16,39

NPL

YAX MASS FLOW RATE M,KG/S,1.,10000.,20000.,10.

PLT HOM,CHR,16,40

NPL

YAX PUMPING POWER NP,MW,1.E-6,15.,20.,10.

PLT HOM,CHR,16,41

NPL

YAX WATER TO FUEL ROD VOLUME RATIO VM/VF,-,1.,0.,1.,10.

PLT HOM,CHR,16,29

NPL

YAX CORE FRICTION PRESSURE DROP DP,BAR,1.,0.,10.,10.

PLT HOM,CHR,16,50

NPL

YAX ROD LINEAR POWER QL,W/CM,1.E-2,100.,200.,10.

PLT HOM,CHR,16,26

NPL

YAX CORE POWER DENSITY QV,W/CM**3,1.E-6,100.,300.,10.

PLT HOM,CHR,16,27

NPL

YAX VELOCITY U,M/S,1.,5.,10.,10.

PLT HOM,CHR,16,47

NPL

YAX POSITION OF INCIPIENT LOCAL BOILING,CM,1.E2,0.,200.,10.

PLT HOM,CHR,16,107

TXT 8.,-2.5,.21,OVERPOWER FACTOR 1,0.

NPL

YAX POSITION OF INCIPIENT LOCAL BOILING,CM,1.E2,0.,100.,10.

PLT HOM,CHR,16,133

TXT 8.,-2.5,.21,OVERPOWER FACTOR 1.12,0.

NPL

YAX CORE HEIGHT LC,CM,1.E2,120.,320.,10.

PLT HOM,CHR,16,44

GRP 2,HETEROGENEOUS CORE,CONSTANT PUMP CHARACTERISTICS

PAR 48, DS=,CM,1.E2

XAX SEED POWER DENSITY QVS,W/CM**3,1.E-6,100.,300.,10.

YAX NET PLANT ELECTRICAL POWER QELNET,MW,1.E-6,800.,1300.,10.

PLT HET,CHR,19,41

NPL

YAX DNB RATIO SEED,-,1.,1.5,2.0,10.

PLT HET,CHR,19,116

TXT 8.,-2.5,.21,OVERPOWER FACTOR 1,0.

NPL

YAX DNB RATIO SEED WITH CONTROL ROD,-,1.,1.5,2.0,10.

PLT HET,CHR,19,119

TXT 8.,-2.5,.21,OVERPOWER FACTOR 1,0.

NPL

YAX DNB RATIO SEED, -, 1., 1.3, 1.8, 10.
PLT HET, CHR, 19, 142
TXT 8., -2.5, .21, OVERPOWER FACTOR 1.12, 0.
NPL
YAX DNB RATIO SEED WITH CONTROL ROD, -, 1., 1.3, 1.8, 10.
PLT HET, CHR, 19, 145
TXT 8., -2.5, .21, OVERPOWER FACTOR 1.12, 0.
NPL
YAX DNB RATIO BLANKET, -, 1., 1.3, 1.8, 10.
PLT HET, CHR, 19, 198
TXT 8., -2.5, .21, OVERPOWER FACTOR 1, 0.
NPL
YAX DNB RATIO BLANKET WITH CONTROL ROD, -, 1., 1.3, 1.8, 10.
PLT HET, CHR, 19, 201
TXT 8., -2.5, .21, OVERPOWER FACTOR 1, 0.
NPL
YAX DNB RATIO BLANKET, -, 1., 1.1, 1.6, 10.
PLT HET, CHR, 19, 224
TXT 8., -2.5, .21, OVERPOWER FACTOR 1.12, 0.
ADD 4, 100., 1.301, 300., 1.301, 300., 1.299, 100., 1.299
NPL
YAX DNB RATIO BLANKET WITH CONTROL ROD, -, 1., 1.1, 1.6, 10.
PLT HET, CHR, 19, 227
TXT 8., -2.5, .21, OVERPOWER FACTOR 1.12, 0.
ADD 4, 100., 1.301, 300., 1.301, 300., 1.299, 100., 1.299
NPL
YAX INLET TEMPERATURE T1, GRD C, 1., 260., 310., 10.
PLT HET, CHR, 19, 37
NPL
YAX OUTLET TEMPERATURE T2, GRD C, 1., 316., 326., 10.
PLT HET, CHR, 19, 38
NPL
YAX MASS FLOW RATE M, KG/S, 1., 10000., 20000., 10.
PLT HET, CHR, 19, 39
NPL
YAX PUMPING POWER NP, MW, 1.E-6, 15., 20., 10.
PLT HET, CHR, 19, 40
NPL
YAX WATER TO FUEL ROD VOLUME RATIO VM/VF, -, 1., 0., 1.5, 10.
PLT HET, CHR, 19, 65
NPL
YAX CORE FRICTION PRESSURE DROP DP, BAR, 1., 0., 10., 10.
PLT HET, CHR, 19, 63

NPL

YAX POSITION OF INCIPIENT LOCAL BOILING SEED,CM,1.E2,0.,200.,10.

PLT HET,CHR,19,122

TXT 8.,-2.5,.21,OVERPOWER FACTOR 1,0.

NPL

YAX POSITION OF INCIPIENT LOCAL BOILING SEED,CM,1.E2,0.,100.,10.

PLT HET,CHR,19,148

TXT 8.,-2.5,.21,OVERPOWER FACTOR 1.12,0.

NPL

YAX POSITION OF INCIPIENT LOCAL BOILING BLANKET,CM,1.E2,0.,200.,10.

PLT HET,CHR,19,204,10

TXT 8.,-2.5,.21,OVERPOWER FACTOR 1,0.

NPL

YAX POSITION OF INCIPIENT LOCAL BOILING BLANKET,CM,1.E2,0.,100.,10.

PLT HET,CHR,19,230

TXT 8.,-2.5,.21,OVERPOWER FACTOR 1.12,0.

NPL

YAX CORE HEIGHT LC,CM,1.E2,100.,500.,10.

PLT HET,CHR,19,43

NPL

YAX PITCH BLANKET PB,CM,1.E2,.8,1.8,10.

PLT HET,CHR,19,55

NPL

YAX PITCH SEED PS,CM,1.E2,.6,1.6,10.

PLT HET,CHR,19,46

NPL

YAX ROD DIAMETER BALNKET DB,CM,1.E2,.8,1.8,10.

PLT HET,CHR,19,57

NPL

YAX PITCH TO DIAMETER RATIO SEED PS/DS,-,1.,1.,1.5,10.

PLT HET,CHR,19,49

NPL

YAX PITCH TO DIAMETER RATIO BLANKET PB/DB,-,1.,.9,1.4,10.

PLT HET,CHR,19,58

NPL

YAX ROD LINEAR POWER SEED QLS,W/CM,1.E-2,150.,250.,10.

PLT HET,CHR,19,28

NPL

YAX ROD LINEAR POWER BLANKET QLB,W/CM,1.E-2,100.,200.,10.

PLT HET,CHR,19,54

NPL

YAX VELOCITY BLANKET UB,M/S,1.,5.,10.,10.

PLT HET,CHR,19,60

```
NPL
YAX VELOCITY SEED US,M/S,1.,6.,8.5,10.
PLT HET,CHR,19,51
GRP 3
PAR
XAX NET PLANT ELECTRICAL POWER QELNET,MW,1.E-6,800.,1300.,10.
YAX WATER TO FUEL ROD VOLUME RATIO VM/VF,-,1.,0.,1.,10.
PLS HOM,CHR,42,29,2
PLS HET,CHR,41,65,10
SYM 8.,2.,.21,2,0.
TXT 8.5,1.9,.21,HOM.,0.
SYM 8.,1.5,.21,10,0.
TXT 8.5,1.4,.21,HET.,0.
//FT05F001 DD *
8,1,0
//FT06F001 DD SYSOUT=*,DCB=(RECFM=FBA,LRECL=133,BLKSIZE=3857)
//FT08F001 DD DISP=SHR,DSN=PROJECT.APWRS.DATA
//FT09F001 DD SYSOUT=*,DCB=(RECFM=FBA,LRECL=133,BLKSIZE=3857)
//FT20F001 DD DISP=(,DELETE),UNIT=SYSSQ,SPACE=(1,1),
//          DCB=(RECFM=FB,LRECL=80,BLKSIZE=3120)
//PLOT Parm DD *
&PLOT XMAX=300. &END
//VERS EXEC SVPLOT
```

7.7 LISTING THE CONTENTS

With the program SHOW, selected variables of a specified entry may be listed. The following example demonstrates the usage:

```
//PROJECTS JOB (.....,.....,.....),.....,TIME=(,30),MSGCLASS=A
//SHOW EXEC PGM=SHOW
//STEPLIB DD DISP=SHR,DSN=PROJECT.HADA.LOAD
//FT05F001 DD *
8          EINGABEEINHEIT PROJECT.APWRS.DATA
48         REAKTORNUMMER
XF 149,230
//FT06F001 DD SYSOUT=*,DCB=(RECFM=FBA,LRECL=133,BLKSIZE=3857)
//FT08F001 DD DISP=SHR,DSN=PROJECT.APWRS.DATA
//FT09F001 DD SYSOUT=*,DCB=(RECFM=FBA,LRECL=133,BLKSIZE=3857)
```


8. INSTALLING THE PROGRAMS

All programs, subroutines and functions are copied in a separate file. The following shows how the program library HADA.LOAD is to be generated.

```
//PROJECTG JOB (.....,.....,.....),.....,MSGCLASS=H,REGION=2000K
//*
//*MAIN LINES=20
//*****
//INPUTO EXEC F7CL,PARM.L='NCAL'
//C.SYSPRINT DD SYSOUT=N
//C.SYSIN DD DISP=SHR,DSN=PROJECT.HADA.FORT(INPUTO)
// DD DISP=SHR,DSN=PROJECT.HADA.FORT(INPUT1)
// DD DISP=SHR,DSN=PROJECT.HADA.FORT(INPUT2)
//L.SYSLMOD DD DISP=SHR,DSN=PROJECT.HADA.LOAD
//L.SYSPRINT DD SYSOUT=H
//L.SYSIN DD *
  ALIAS INPUT1,INPUT2
  NAME INPUTO(R)
//*****
//COMPRS EXEC F7CL,PARM.L='NCAL'
//C.SYSPRINT DD SYSOUT=N
//C.SYSIN DD DISP=SHR,DSN=PROJECT.HADA.FORT(COMPRS)
//L.SYSLMOD DD DISP=SHR,DSN=PROJECT.HADA.LOAD
//L.SYSPRINT DD SYSOUT=H
//L.SYSIN DD *
  NAME COMPRS(R)
//*****
//IVGL EXEC F7CL,PARM.L='NCAL'
//C.SYSPRINT DD SYSOUT=N
//C.SYSIN DD DISP=SHR,DSN=PROJECT.HADA.FORT(IVGL)
//L.SYSLMOD DD DISP=SHR,DSN=PROJECT.HADA.LOAD
//L.SYSPRINT DD SYSOUT=H
//L.SYSIN DD *
  NAME IVGL(R)
//*****
//OUTPUT EXEC F7CL,PARM.L='NCAL'
//C.SYSPRINT DD SYSOUT=N
//C.SYSIN DD DISP=SHR,DSN=PROJECT.HADA.FORT(OUTPUT)
//L.SYSLMOD DD DISP=SHR,DSN=PROJECT.HADA.LOAD
//L.SYSPRINT DD SYSOUT=H
```

```
//L.SYSIN DD *
NAME OUTPUT(R)
//*****
//DELETE EXEC F7CL, PARM.L='NCAL'
//C.SYSPRINT DD SYSOUT=N
//C.SYSIN DD DISP=SHR, DSN=PROJECT.HADA.FORT(DELETE)
//L.SYSLMOD DD DISP=SHR, DSN=PROJECT.HADA.LOAD
//L.SYSPRINT DD SYSOUT=H
//L.SYSIN DD *
NAME DELETE(R)
//*****
//OUTLST EXEC F7CL, PARM.L='NCAL'
//C.SYSPRINT DD SYSOUT=N
//C.SYSIN DD DISP=SHR, DSN=PROJECT.HADA.FORT(OUTLSTP)
//L.SYSLMOD DD DISP=SHR, DSN=PROJECT.HADA.LOAD
//L.SYSPRINT DD SYSOUT=H
//L.SYSIN DD *
NAME OUTLST(R)
//*****
//OUTHOM EXEC F7CL, PARM.L='NCAL'
//C.SYSPRINT DD SYSOUT=N
//C.SYSIN DD DISP=SHR, DSN=PROJECT.HADA.FORT(OUTHOMP)
// DD DISP=SHR, DSN=PROJECT.HADA.FORT(OUTHET)
//L.SYSLMOD DD DISP=SHR, DSN=PROJECT.HADA.LOAD
//L.SYSPRINT DD SYSOUT=H
//L.SYSIN DD *
ALIAS OUTHET
NAME OUTHOM(R)
//*****
//OUTLIN EXEC F7CL, PARM.L='NCAL'
//C.SYSPRINT DD SYSOUT=N
//C.SYSIN DD DISP=SHR, DSN=PROJECT.HADA.FORT(OUTLIN)
//L.SYSLMOD DD DISP=SHR, DSN=PROJECT.HADA.LOAD
//L.SYSPRINT DD SYSOUT=H
//L.SYSIN DD *
NAME OUTLIN(R)
//*****
//OUTPLT EXEC F7CL, PARM.L='NCAL'
//C.SYSPRINT DD SYSOUT=N
//C.SYSIN DD DISP=SHR, DSN=PROJECT.HADA.FORT(OUTPLT)
// DD DISP=SHR, DSN=PROJECT.HADA.FORT(BILDER)
// DD DISP=SHR, DSN=PROJECT.HADA.FORT(KOMGET)
// DD DISP=SHR, DSN=PROJECT.HADA.FORT(EXINT)
```

```
//          DD DISP=SHR,DSN=PROJECT.HADA.FORT(EXTXT)
//          DD DISP=SHR,DSN=PROJECT.HADA.FORT(EXREL)
//          DD DISP=SHR,DSN=PROJECT.HADA.FORT(EXTRC)
//L.SYSLMOD DD DISP=SHR,DSN=PROJECT.HADA.LOAD
//L.SYSPRINT DD SYSOUT=H
//L.SYSIN   DD *
  ALIAS BILDER,STORE,STORP,ZEICHN,KOMGET,EXINT,EXTXT,EXREL,EXTRC
  NAME OUTPLT(R)
//*****
//XACHSE EXEC F7CL,PARM.L='NCAL'
//C.SYSPRINT DD SYSOUT=N
//C.SYSIN   DD DISP=SHR,DSN=PROJECT.HADA.FORT(XACHSE)
//          DD DISP=SHR,DSN=PROJECT.HADA.FORT(ENCODE)
//          DD DISP=SHR,DSN=PROJECT.HADA.FORT(IENT)
//          DD DISP=SHR,DSN=PROJECT.HADA.FORT(PLTEXT)
//          DD DISP=SHR,DSN=PROJECT.HADA.FORT(LAENGE)
//          DD DISP=SHR,DSN=PROJECT.HADA.FORT(YACHSE)
//L.SYSLMOD DD DISP=SHR,DSN=PROJECT.HADA.LOAD
//L.SYSPRINT DD SYSOUT=H
//L.SYSIN   DD *
  ALIAS YACHSE,ENCODE,IENT,PLTEXT,LAENGE
  NAME XACHSE(R)
//*****
//PLTIN EXEC F7CL,PARM.L='NCAL'
//C.SYSPRINT DD SYSOUT=N
//C.SYSIN   DD DISP=SHR,DSN=PROJECT.HADA.FORT(PLTIN)
//L.SYSLMOD DD DISP=SHR,DSN=PROJECT.HADA.LOAD
//L.SYSPRINT DD SYSOUT=H
//L.SYSIN   DD *
  ALIAS PLTOF,NULLP
  NAME PLTIN(R)
//*****
//OUTSHW EXEC F7CL,PARM.L='NCAL'
//C.SYSPRINT DD SYSOUT=N
//C.SYSIN   DD DISP=SHR,DSN=PROJECT.HADA.FORT(OUTSHW)
//          DD DISP=SHR,DSN=PROJECT.HADA.FORT(GETIND)
//          DD DISP=SHR,DSN=PROJECT.HADA.FORT(IGET)
//          DD DISP=SHR,DSN=PROJECT.HADA.FORT(GET2)
//L.SYSLMOD DD DISP=SHR,DSN=PROJECT.HADA.LOAD
//L.SYSPRINT DD SYSOUT=H
//L.SYSIN   DD *
  ALIAS GETIND,IGET,GET2
  NAME OUTSHW(R)
```

```
//CHFCLC EXEC F7CL,PARM.L='NCAL'  
//C.SYSPRINT DD SYSOUT=N  
//*  
//* VKFF1 IS THE SAME AS VKNEW. ONLY THE FAKTOR FF (F IN THE SUBROUTINE)  
//* WAS SET = 1 ON THE BASIS OF THE EXPERIMENTAL RESULTS OF KWU-CHF TEST  
//*  
//C.SYSIN DD DISP=SHR,DSN=PROJECT.HADA.FORT(CHFCLC)  
// DD DISP=SHR,DSN=PROJECT.HADA.FORT(SHIP)  
// DD DISP=SHR,DSN=PROJECT.HADA.FORT(EDLD)  
// DD DISP=SHR,DSN=PROJECT.HADA.FORT(WSC2)  
// DD DISP=SHR,DSN=PROJECT.HADA.FORT(DDCR)  
// DD DISP=SHR,DSN=PROJECT.HADA.FORT(EPRI)  
// DD DISP=SHR,DSN=PROJECT.HADA.FORT(VKFF1)  
// DD DISP=SHR,DSN=PROJECT.HADA.FORT(VKOLD)  
// DD DISP=SHR,DSN=PROJECT.HADA.FORT(VKEPR)  
//L.SYSLMOD DD DISP=SHR,DSN=PROJECT.HADA.LOAD  
//L.SYSPRINT DD SYSOUT=H  
//L.SYSIN DD *  
ALIAS SHIP,EDLD,WSC2,DDCR,EPRI,VKNEW,VKOLD,VKEPR,$INV,NEWT,FRRK3  
NAME CHFCLC(R)  
//*  
//CHFCL2 EXEC F7CL,PARM.L='NCAL'  
//C.SYSPRINT DD SYSOUT=N  
//C.SYSIN DD DISP=SHR,DSN=PROJECT.HADA.FORT(CHFCL2)  
// DD DISP=SHR,DSN=PROJECT.HADA.FORT(CHFCL3)  
// DD DISP=SHR,DSN=PROJECT.HADA.FORT(CHFCL4)  
// DD DISP=SHR,DSN=PROJECT.HADA.FORT(SETDNB)  
// DD DISP=SHR,DSN=PROJECT.HADA.FORT(DNBR)  
//L.SYSLMOD DD DISP=SHR,DSN=PROJECT.HADA.LOAD  
//L.SYSPRINT DD SYSOUT=H  
//L.SYSIN DD *  
ALIAS CHFCL3,CHFCL4,SETDNB,DNBR,CICLI  
NAME CHFCL2(R)  
//*  
//GAUSS EXEC F7CL,PARM.L='NCAL'  
//C.SYSPRINT DD SYSOUT=N  
//C.SYSIN DD DISP=SHR,DSN=PROJECT.HADA.FORT(GAUSS)  
// DD DISP=SHR,DSN=PROJECT.HADA.FORT(ELIMS)  
// DD DISP=SHR,DSN=PROJECT.HADA.FORT(SOLVS)  
// DD DISP=SHR,DSN=PROJECT.HADA.FORT(GAUS0)  
// DD DISP=SHR,DSN=PROJECT.HADA.FORT(GAUS1)  
// DD DISP=SHR,DSN=PROJECT.HADA.FORT(GAUS2)  
// DD DISP=SHR,DSN=PROJECT.HADA.FORT(ELIMN)
```

```
//          DD DISP=SHR,DSN=PROJECT.HADA.FORT(SOLVN)
//          DD DISP=SHR,DSN=PROJECT.HADA.FORT(SETLIN)
//          DD DISP=SHR,DSN=PROJECT.HADA.FORT(SETIT)
//L.SYSLMOD DD DISP=SHR,DSN=PROJECT.HADA.LOAD
//L.SYSPRINT DD SYSOUT=H
//L.SYSIN   DD *
  ALIAS ELIMS,SOLVS,GAUS0,GAUS1,GAUS2,ELIMN,SOLVN,SETLIN,SETIT
  NAME GAUSS(R)
//*****
//DMPMAT EXEC F7CL,PARM.L='NCAL'
//C.SYSPRINT DD SYSOUT=N
//C.SYSIN   DD DISP=SHR,DSN=PROJECT.HADA.FORT(DMPMAT)
//          DD DISP=SHR,DSN=PROJECT.HADA.FORT(XNEU)
//          DD DISP=SHR,DSN=PROJECT.HADA.FORT(SETMAT)
//          DD DISP=SHR,DSN=PROJECT.HADA.FORT(SETVEK)
//          DD DISP=SHR,DSN=PROJECT.HADA.FORT(MAT)
//          DD DISP=SHR,DSN=PROJECT.HADA.FORT(VEK)
//          DD DISP=SHR,DSN=PROJECT.HADA.FORT(SORT)
//          DD DISP=SHR,DSN=PROJECT.HADA.FORT(TAUS)
//          DD DISP=SHR,DSN=PROJECT.HADA.FORT(EXCH)
//          DD DISP=SHR,DSN=PROJECT.HADA.FORT(SMAX)
//          DD DISP=SHR,DSN=PROJECT.HADA.FORT(IMAX)
//L.SYSLMOD DD DISP=SHR,DSN=PROJECT.HADA.LOAD
//L.SYSPRINT DD SYSOUT=H
//L.SYSIN   DD *
  ALIAS XNEU,SETMAT,SETVEK,MAT,VEK,SORT,TAUS,EXCH,SMAX,IMAX
  NAME DMPMAT(R)
//*****
//EFPW EXEC F7CL,PARM.L='NCAL'
//C.SYSPRINT DD SYSOUT=N
//C.SYSIN   DD DISP=SHR,DSN=PROJECT.HADA.FORT(EFPW)
//          DD DISP=SHR,DSN=PROJECT.HADA.FORT(EFPD)
//          DD DISP=SHR,DSN=PROJECT.HADA.FORT(EFS)
//          DD DISP=SHR,DSN=PROJECT.HADA.FORT(PSI0)
//          DD DISP=SHR,DSN=PROJECT.HADA.FORT(PSI)
//          DD DISP=SHR,DSN=PROJECT.HADA.FORT(Q)
//          DD DISP=SHR,DSN=PROJECT.HADA.FORT(B)
//          DD DISP=SHR,DSN=PROJECT.HADA.FORT(FI)
//          DD DISP=SHR,DSN=PROJECT.HADA.FORT(PR)
//          DD DISP=SHR,DSN=PROJECT.HADA.FORT(HR)
//          DD DISP=SHR,DSN=PROJECT.HADA.FORT(HS)
//          DD DISP=SHR,DSN=PROJECT.HADA.FORT(PS)
//L.SYSLMOD DD DISP=SHR,DSN=PROJECT.HADA.LOAD
```

```
//L.SYSPRINT DD SYSOUT=H
//L.SYSIN DD *
  ALIAS EFPD,EFS,PSIO,PSI,Q,B,FI,PR,HR,HS,PS
  NAME EFPW(R)
//*****
//ARG1 EXEC F7CL, PARM.L='NCAL'
//C.SYSPRINT DD SYSOUT=N
//C.SYSIN DD DISP=SHR,DSN=PROJECT.HADA.FORT(ARG1)
// DD DISP=SHR,DSN=PROJECT.HADA.FORT(SUCHEN)
// DD DISP=SHR,DSN=PROJECT.HADA.FORT(PINV)
// DD DISP=SHR,DSN=PROJECT.HADA.FORT(RP)
// DD DISP=SHR,DSN=PROJECT.HADA.FORT(SUMME)
// DD DISP=SHR,DSN=PROJECT.HADA.FORT(FE)
// DD DISP=SHR,DSN=PROJECT.HADA.FORT(FL)
// DD DISP=SHR,DSN=PROJECT.HADA.FORT(FC)
//L.SYSLMOD DD DISP=SHR,DSN=PROJECT.HADA.LOAD
//L.SYSPRINT DD SYSOUT=H
//L.SYSIN DD *
  ALIAS SUCHEN,PINV,RP,SUMME,FE,FL,FC
  NAME ARG1(R)
//*****
//DRUCK EXEC F7CL, PARM.L='NCAL'
//C.SYSPRINT DD SYSOUT=N
//C.SYSIN DD DISP=SHR,DSN=PROJECT.HADA.FORT(DRUCK)
// DD DISP=SHR,DSN=PROJECT.HADA.FORT(STOR8)
// DD DISP=SHR,DSN=PROJECT.HADA.FORT(OUTREC)
//L.SYSLMOD DD DISP=SHR,DSN=PROJECT.HADA.LOAD
//L.SYSPRINT DD SYSOUT=H
//L.SYSIN DD *
  ALIAS OUTREC,STOR8
  NAME DRUCK(R)
//F EXEC F7CL, PARM.L='NCAL'
//C.SYSPRINT DD SYSOUT=N
//C.SYSIN DD DISP=SHR,DSN=PROJECT.HADA.FORT(F)
// DD DISP=SHR,DSN=PROJECT.HADA.FORT(DF)
//L.SYSLMOD DD DISP=SHR,DSN=PROJECT.HADA.LOAD
//L.SYSPRINT DD SYSOUT=H
//L.SYSIN DD *
  ALIAS DF
  NAME F(R)
//*****
//**
//** COMP
```

```
/**
/**
/**
/**          INPUTO          COMPRS  OUTPUT
/**          |                |      |
/**          +-----+          IVGL
/**          |                |
/**          INPUT1  INPUT2
/**
/**COMP EXEC F7CL
/**C.SYSPRINT DD SYSOUT=N
/**C.SYSIN    DD DISP=SHR,DSN=PROJECT.HADA.FORT(COMP)
/**L.SYSLIB   DD
/**          DD DISP=SHR,DSN=PROJECT.HADA.LOAD
/**L.SYSLMOD  DD DISP=SHR,DSN=PROJECT.HADA.LOAD
/**L.SYSPRINT DD SYSOUT=H
/**L.SYSIN   DD *
ENTRY MAIN
NAME COMP(R)
/*******
/**
/**          DELT
/**          |
/**          +-----+-----+
/**          |                |      |
/**          INPUTO          DELETE  OUTPUT
/**          |                |
/**          +-----+          IVGL
/**          |                |
/**          INPUT1  INPUT2
/**
/**DELT EXEC F7CL
/**C.SYSPRINT DD SYSOUT=N
/**C.SYSIN    DD DISP=SHR,DSN=PROJECT.HADA.FORT(DELT)
/**L.SYSLIB   DD
/**          DD DISP=SHR,DSN=PROJECT.HADA.LOAD
/**L.SYSLMOD  DD DISP=SHR,DSN=PROJECT.HADA.LOAD
/**L.SYSPRINT DD SYSOUT=H
/**L.SYSIN   DD *
ENTRY MAIN
NAME DELT(R)
/*******
/**
```

```
//**                               INIT
//**
//INIT EXEC F7CL
//C.SYSPRINT DD SYSOUT=N
//C.SYSIN DD DISP=SHR,DSN=PROJECT.HADA.FORT(INIT)
//L.SYSLMOD DD DISP=SHR,DSN=PROJECT.HADA.LOAD
//L.SYSPRINT DD SYSOUT=H
//L.SYSIN DD *
ENTRY MAIN
NAME INIT(R)
/*****
//**
//**                               LIST
//**                               |
//**          +-----+-----+
//**          |               |   |
//**          INPUT0         OUTLST  DATUM
//**          |               |   |
//**          +-----+     +-----+
//**          |       |     |       |
//**          INPUT1  INPUT2  OUTHOM  OUTHET
//**
//LIST EXEC F7CL
//C.SYSPRINT DD SYSOUT=N
//C.SYSIN DD DISP=SHR,DSN=PROJECT.HADA.FORT(LIST)
//L.SYSLIB DD
// DD DISP=SHR,DSN=PROJECT.HADA.LOAD
//L.SYSLMOD DD DISP=SHR,DSN=PROJECT.HADA.LOAD
//L.SYSPRINT DD SYSOUT=H
//L.SYSIN DD *
ENTRY MAIN
NAME LISTP(R)
/*****
//**
//**                               OUT1
//**                               |
//**          +-----+-----+
//**          |               |   |
//**          INPUT0         OUTLIN
//**          |               |   |
//**          +-----+
//**          |       |
//**          INPUT1  INPUT2
```



```
/**
//OUT1 EXEC F7CL
//C.SYSPRINT DD SYSOUT=N
//C.SYSIN DD DISP=SHR,DSN=PROJECT.HADA.FORT(OUT1)
//L.SYSLIB DD
// DD DISP=SHR,DSN=PROJECT.HADA.LOAD
//L.SYSLMOD DD DISP=SHR,DSN=PROJECT.HADA.LOAD
//L.SYSPRINT DD SYSOUT=H
//L.SYSIN DD *
ENTRY MAIN
NAME OUT1(R)
/**
/**
/** PLOT
/** |
/** +-----+-----+-----+-----+
/** | | | | |
/** INPUT0 OUTPLT ZEICHN BILDER DATUM
/** | | | | |
/** +-----+ +-----+ +-----+ |
/** | | | | | | |
/** INPUT1 INPUT2 STORP STORE OUTHOM OUTHET |
/** | | | | | |
/** +-----+-----+-----+-----+-----+-----+
/** | | | | | | |
/** XACHSE YACHSE PLTIN KOMGET PLTEXT NULLP PLOTOF
/** | | | | |
/** +-----+-----+ | DATUM |
/** | | | | |
/** ENCODE PLTEXT LAENGE | +-----+-----+
/** | | | | |
/** IENT +-----+-----+ EXINT EXTXT EXREL
/** | | |
/** ENCODE PLTEXT LAENGE
/** |
/** IENT
/**
//PLOT EXEC F7CL
//C.SYSPRINT DD SYSOUT=N
//C.SYSIN DD DISP=SHR,DSN=PROJECT.HADA.FORT(PLOT)
//L.SYSLIB DD
// DD DISP=SHR,DSN=PROJECT.HADA.LOAD
//L.SYSLMOD DD DISP=SHR,DSN=PROJECT.HADA.LOAD
```

```
//L.SYSPRINT DD SYSOUT=H
//L.SYSIN DD *
ENTRY MAIN
NAME PLOT(R)
/*****
/**
/**          SHOW
/**          |
/**          +-----+-----+
/**          |          |          |
/**          INPUT0          OUTSHW  DATUM
/**          |          |
/**          +-----+          +-----+
/**          |          |          |          |
/**          INPUT1  INPUT2          GETIND  LAENGE
/**          |
/**          +-----+
/**          |          |
/**          GET2  IGET
/**
//SHOW EXEC F7CL
//C.SYSPRINT DD SYSOUT=N
//C.SYSIN DD DISP=SHR,DSN=PROJECT.HADA.FORT(SHOW)
//L.SYSLIB DD
// DD DISP=SHR,DSN=PROJECT.HADA.LOAD
//L.SYSLMOD DD DISP=SHR,DSN=PROJECT.HADA.LOAD
//L.SYSPRINT DD SYSOUT=H
//L.SYSIN DD *
ENTRY MAIN
NAME SHOW(R)
/*****
/**
//HADA EXEC F7CL
//C.SYSPRINT DD SYSOUT=N
//C.SYSIN DD DISP=SHR,DSN=PROJECT.HADA.FORT(HADA)
//L.SYSLIB DD
// DD DISP=SHR,DSN=PROJECT.HADA.LOAD
//L.SYSLMOD DD DISP=SHR,DSN=PROJECT.HADA.LOAD
//L.SYSPRINT DD SYSOUT=H
//L.SYSIN DD *
ENTRY MAIN
NAME HADA(R)
```

The different version of the LIST code named LISTD, which generates tables of the results with the same diameter, is produced in the following way:

```
//PROJECTL JOB (.....,.....,.....),.....,MSGCLASS=H
//*
//*
//*****
//LISTD EXEC F7CL
//C.SYSPRINT DD SYSOUT=N
//C.SYSIN DD DISP=SHR,DSN=PROJECT.HADA.FORT(LIST)
// DD DISP=SHR,DSN=PROJECT.HADA.FORT(INPUT0)
// DD DISP=SHR,DSN=PROJECT.HADA.FORT(INPUT1)
// DD DISP=SHR,DSN=PROJECT.HADA.FORT(INPUT2)
// DD DISP=SHR,DSN=PROJECT.HADA.FORT(OUTLSTD)
// DD DISP=SHR,DSN=PROJECT.HADA.FORT(OUTHOMD)
// DD DISP=SHR,DSN=PROJECT.HADA.FORT(OUTHET)
//L.SYSLIB DD
// DD DISP=SHR,DSN=PROJECT.HADA.LOAD
//L.SYSLMOD DD DISP=SHR,DSN=PROJECT.HADA.LOAD
//L.SYSPRINT DD SYSOUT=H
//L.SYSIN DD *
ENTRY MAIN
NAME LISTD(R)
```

REFERENCE

- /1/ M. Dalle Donne, W. Hame: "HADA; A FORTRAN-IV Program for the Thermohydraulic Design of An Advanced Pressurized Light Water Reactor with a Tight Fuel Rod Lattice," KfK 3904, EUR 7996e (1985).
- /2/ M. Dalle Donne, W. Hame: "A Parametric Thermohydraulic Study of an Advanced Pressurized Light Water Reactor with a Tight Fuel Rod Lattice," KfK 3453, EUR 7059e (1982).
- /3/ M. Dalle Donne, W. Hame: "A Critical Heat Flux Correlation for Triangular Array Rod Bundles with Tight Lattices, Including the Effect of Special Spacers," Nucl. Technol. 71, 111 (1985).
- /4/ Y. Ishiguro, K. Okumura: Nucl. Technol. 84, 331 (1989).
- /5/ T. Iwamura et al.: "Critical Heat Flux (CHF) Characteristics of High Conversion Pressurized Water Reactor with Double Flat Core," JAERI-M 89-004, Japan Atomic Energy Research Institute (1989) [in Japanese] .
- /6/ M. Cigarini, M. Dalle Donne: "Calculations for Advanced Pressurized Water Reactor with the Code HADA-2," KfK 4148, EUR 10532e (1986).
- /7/ M. Cigarini, M. Dalle Donne: "Thermhydraulic Optimization of Homogeneous and Heterogeneous Advanced Pressurized Water Reactor," Nucl. Technol., 80, 107 (1988).
- /8/ D. C. Groeneveld: "Recent Developments in Thermal Hydraulic Prediction Method," Preceedings of the Third International Topical Meeting on Nuclear Power Plant Termal Hydraulics and Operations (NUPTHO-3), Vol.1, p.A2-38, Seoul 14-17 Nov. 1988.




Figure 1. Geometry of grid.





Figure 2. Conceptual illustration of multiple stacked core.