

MITIGATION OF LOAD HARMONICS FROM GRID CONNECTED WIND  
TURBINE USING SHUNT ACTIVE POWER FILTER

SAJID HUSSAIN QAZI

A thesis submitted in fulfilment of the  
requirements for the award of the degree of  
Master of Engineering (Electrical)

Faculty of Electrical Engineering  
Universiti Teknologi Malaysia

FEBUARY 2016

This thesis work is dedicated to my parents, Mr and Mrs Hafiz Mukhtiar Ahmed Qazi who have always loved me unconditionally and whose good examples have taught me to work hard for the things that I aspire to achieve. This work is also dedicated to my wife who has been a constant source of support and encouragement during the challenges of study and life. I am truly thankful for having you in my life.

## ACKNOWLEDGEMENT

In the name of Allah almighty, the most Beneficent and the most Merciful. With gratitude to Allah for His mercy that has given me strength, patience, perseverance and health for timely completion of this imperative assignment. Guidance of our Holy Prophet Hazrat Muhammad (S.A.W), throughout my life and in this task in particular, is truly acknowledged. After that patronage, support and backing of my supervisor Prof. Ir. Dr. Mohd Mohd Wazir bin Mustafa is undeniable. Their encouragement and support not only enabled me pursue new ideas but also facilitated my self-confidence. Notably, their incisive feedback afforded me to progress in the precise direction. This task could not have been accomplished without their keen observations, incessant advices, and persistent suggestions in each and every part of this work.

I am greatly indebted to Universiti Teknologi Malaysia for providing me the platform. My sincerest thanks to all my colleagues and laboratory mates for their help and support. Finally, I truly endorse the warm backing and care of my family exclusively my wife whose endless support enhanced my agility to make her dream come to reality.

I would also acknowledge Mehran University of Engineering and Technology Shaheed Zulfiqar Ali Bhutto Campus, Khairpur Mir's, Pakistan for providing financial support under faculty development program (FDP) of campus.

## ABSTRACT

The increasing utilization of power electronics controlled devices in power system has increased distortion level in current and voltage waveforms in the form of harmonics. The increase in harmonic level also affects the performance of generator, thereby reducing its efficiency and lifespan. In this research, load harmonic mitigation method has been proposed for grid connected variable speed wind turbine generator using Shunt Active Power Filter (APF). The main advantage of this method is eliminating the effect of load harmonics from terminals of wind turbine generator and from the Point of Common Coupling (PCC). To evaluate the performance of shunt APF, two strategies have been utilized separately for extracting harmonic reference signal: the instantaneous reactive power method ( $pq$  method) and Synchronous Reference Frame (SRF) technique. To prove the effectiveness of the proposed system, MATLAB simulations have been carried out on 120 kV grid connected Permanent Magnet Synchronous Generator (PMSG) based wind turbine. Furthermore, nonlinear load is also attached to PCC under fixed and variable wind speed between 8 to 12 m/s separately. For proper operation of APF, switching pulses have been produced by hysteresis band current control. This technique decreases the magnitude of Total Harmonic Distortion (THD) to an acceptable limit set by IEEE-519 standard for harmonic control. Results have also shown that the shunt APF with SRF technique yields better performance under fixed and fluctuating wind speed compared to  $pq$  method.

## ABSTRAK

Peningkatan penggunaan peranti terkawal elektronik kuasa dalam sistem kuasa telah meningkatkan tahap herotan gelombang arus dan voltan dalam bentuk harmonik. Peningkatan tahap harmonik juga akan mempengaruhi prestasi penjana, justeru akan mengurangkan kecekapan dan jangka hayatnya. Dalam kajian ini, satu kaedah memangkas harmonik beban telah dicadangkan untuk penjana turbin angin kelajuan boleh ubah sambungan ke grid menggunakan Penapis Kuasa Aktif Pirau (APF). Kelebihan utama kaedah ini ialah menghapuskan kesan harmonik beban daripada terminal penjana turbin angin dan juga Titik Gandingan Sepunya (PCC). Untuk menilai prestasi pirau APF, dua strategi telah diguna secara berasingan untuk penyarian isyarat rujukan harmonic: kaedah kuasa regangan ketika (kaedah  $pq$ ) dan teknik Bingkai Rujukan Segerak (SRF). Bagi membuktikan keberkesanan sistem yang dicadangkan, penyelakuan MATLAB telah dijalankan ke atas Penjana Segerak Magnet Kekal (PMSG) turbin angin sambungan ke grid 120 kV. Selanjutnya beban tidak linear disambungkan ke PCC, dengan kelajuan angin tetap dan berubah secara berasingan di antara 8-12 m/s. Untuk penapis APF beroperasi dengan sewajarnya, denyutan pensuisan telah dihasilkan oleh kawalan semasa lingkaran histerisis. Teknik ini mengurangkan magnitud Jumlah Herotan Harmonik (THD) kepada had yang boleh diterima yang ditetapkan oleh piawaian IEEE-519 untuk kawalan harmonik. Keputusan juga menunjukkan bahawa APF pirau dengan teknik SRF mempunyai prestasi yang lebih baik di bawah kelajuan angin tetap dan angin membuai berbanding kaedah  $pq$ .

## TABLE OF CONTENTS

<b>CHAPTER</b>	<b>TITLE</b>	<b>PAGE</b>
	<b>DECLARATION</b>	ii
	<b>DEDICATION</b>	iii
	<b>ACKNOWLEDGEMENT</b>	iv
	<b>ABSTRACT</b>	v
	<b>ABSTRAK</b>	vi
	<b>TABLE OF CONTENTS</b>	vii
	<b>LIST OF TABLES</b>	xi
	<b>LIST OF FIGURES</b>	xii
	<b>LIST OF ABBREVIATIONS</b>	xvi
	<b>LIST OF SYMBOLS</b>	xvii
	<b>LIST OF APPENDICES</b>	xviii
<b>1</b>	<b>INTRODUCTION</b>	1
	1.1 Background	1
	1.2 Problem Statement	3
	1.3 Objectives	4
	1.4 Scopes	5
	1.5 Significances of Study	5
	1.6 Organization of Thesis	6
<b>2</b>	<b>LITERATURE REVIEW</b>	7
	2.1 Introduction	7
	2.2 Wind Turbine System	8
	2.2.1 Fixed Speed Wind Turbine System	9
	2.2.2 Variable-Speed Wind Turbine System	10
	2.3 Harmonics	12

2.3.1	Effect of Harmonics	12
2.3.2	Effect of Harmonics on the Wind	13
2.3.3	Turbine Generators	
	International Standard for Harmonics	14
	Control	
2.4	Methods for Mitigating Harmonics	16
2.4.1	Passive Power Filter	16
2.4.2	Active Power Filter	17
2.5	Classification of Active Power Filters	20
2.5.1	Classification based on Power Rating and Speed of Response	21
2.5.1.1	Low Power Applications	22
2.5.1.2	Medium Power Applications	23
2.5.1.3	High Power Application	23
2.5.2	Classification based on Power Circuit Connection	24
2.5.2.1	Shunt Active Power Filter	24
2.5.2.2	Series Active Power Filter	25
2.5.3	Classification based on Compensated Variable	27
2.5.3.1	Reactive Power Compensation	28
2.5.3.2	Compensation of Harmonic	28
2.5.3.3	Balancing 3- $\emptyset$ Systems	29
2.5.4	Classification based on Control Technique	30
2.5.4.1	Open Loop Control System	30
2.5.4.2	Closed Loop Control System	31
2.5.5	Classification based on Reference Signal Estimation Technique	31
2.5.5.1	Current/Voltage Reference Synthesis	32
2.5.5.1	Current/Voltage Reference Calculation	32
2.6	Summary	35

<b>3</b>	<b>RESEARCH METHODOLOGY</b>	<b>37</b>
	3.1 Introduction	37
	3.2 Wind Turbine Generator System	39
	3.3 Power Grid Model	41
	3.4 Nonlinear Load Model	43
	3.5 Harmonics in the Power System	43
	3.6 Shunt Active Power Filter	45
	3.6.1 Selection Criteria for Shunt APF	46
	3.6.1.1 Inverter (Power Unit)	46
	3.6.1.2 Reference Signal Extraction Technique	47
	3.6.1.3 Gate Driver Signal Generator	53
	3.7 Working of Shunt Active Power Filter	54
	3.8 Operation of Considered System	56
	3.9 Summary	56
<b>4</b>	<b>RESULTS AND DISCUSSION</b>	<b>58</b>
	4.1 Introduction	58
	4.2 Operation of System with Fixed Wind Speed without Compensation	58
	4.3 Operation of System with Variable Wind Speed without Compensation	63
	4.4 Operation of System with Fixed Wind Speed and Shunt Active Power Filter with Instantaneous Reactive Power Technique	68
	4.5 Operation of System with Variable Wind Speed and Shunt Active Power Filter with Instantaneous Reactive Power Technique	72
	4.6 Operation of System with Fixed Wind Speed and Shunt Active Power Filter with Synchronous Reference Frame Technique	77



4.7	Operation of System with Variable Wind Speed and Shunt Active Power Filter with Synchronous Reference Frame Technique	82
4.8	Performance Comparison of System with Fixed and Variable Wind Speed	87
4.8.1	System without Shunt Active Power Filter	87
4.8.2	System with Shunt Active Power Filter and pq Theory	89
4.8.3	System with Shunt Active Power Filter and SRF Technique	91
4.9	Summary	93
<b>5</b>	<b>CONCLUSION AND FUTURE WORK</b>	95
5.1	Conclusion	95
5.2	Significant contribution of the Thesis	96
5.3	Future work	97
	<b>REFERENCES</b>	98
	Appendices A1-C	110-114

**LIST OF TABLES**

<b>TABLE NO.</b>	<b>TITLE</b>	<b>PAGE</b>
2.1	Voltage harmonic distortion limit	15
2.2	Current harmonic distortion limit (120 V- 69 kV)	15
2.3	Current harmonic distortion limit (69 kV- 161 kV)	15
2.4	Current harmonic distortion limit (>161 kV)	15
2.5	Evaluation of shunt and series APF	26
3.1	Parameters of PMSG wind generator	41
3.2	Parameters of grid	42
3.3	Load rating	43
4.1	System THD without shunt APF	94
4.2	System THD with shunt APF and <i>pq</i> technique	94
4.3	System THD with shunt APF and SRF technique	94

## LIST OF FIGURES

FIGURE NO.	TITLE	PAGE
2.1	Fixed Speed Squirrel Cage Induction Generator	9
2.2	Variable Speed Wind Turbine System (DFIG)	11
2.3	Variable Speed Wind Turbine System (PMSG)	12
2.4	APF Configuration (a) Shunt APF, (b) Series APF, (c) Combined Series Shunt APF	19
2.5	Generalized block diagram of APF	20
2.6	Classification of APF according to Power rating and speed of response	21
2.7	Division of Active Filter according to Power connection	24
2.8	Parallel APF	25
2.9	Series APF	27
2.10	Subsection of Active Filter according to compensation variables	27
2.11	Control techniques of Active Filter	30
2.12	Reference estimation techniques for Active Filter	32
3.1	Flow Chart of Research Methodology	38
3.2	Wind Energy Conversion System	40
3.3	Model of Grid	42
3.4	Schematic diagram of APF connected system	45
3.5	Components of Shunt APF	46
3.6	3 Arm, IGBT-Diode Bridge	47
3.7	Considered reference signal extraction techniques	48
3.8	Block diagram for $pq$ theory	48
3.9	Block diagram for SRF technique	51
3.10	Hysteresis Band Current Control Method	53
3.11	Gate driver signal generated by Hysteresis control	54
3.12	Schematic Diagram of Shunt APF	55
4.1	WTG Phase Currents and THD level at fixed speed without compensation	59

4.2	PCC Phase Currents and THD level at fixed speed without compensation	60
4.3	PCC Phase Voltage and THD level at fixed speed without compensation	61
4.4	Percentage of individual harmonic at fixed speed and without compensation (a) Percentage of individual harmonic in WTG current, (b) Percentage of individual harmonic in PCC current, (c) Percentage of individual harmonic in PCC voltage	63
4.5	WTG Phase Currents and THD level at variable speed without compensation	64
4.6	PCC Phase Currents and THD level at variable speed without compensation	65
4.7	PCC Phase Voltage and THD level at variable speed without compensation	66
4.8	Percentage of individual harmonic at variable speed and without compensation (a) Percentage of individual harmonic in WTG current (b) Percentage of individual harmonic in PCC current (c) Percentage of individual harmonic in PCC voltage	67
4.9	WTG Phase Currents and THD level at fixed speed with $pq$ technique	68
4.10	PCC Phase Currents and THD level at fixed speed with $pq$ technique	69
4.11	PCC Phase Voltage and THD level at fixed speed with $pq$ technique	70
4.12	Percentage of individual harmonic at fixed speed and $pq$ technique (a) Percentage of individual harmonic in WTG current (b) Percentage of individual harmonic in PCC current (c) Percentage of individual harmonic in PCC voltage	71
4.13	Injected current by Shunt APF using $pq$ technique and fixed speed	72

4.14	WTG Phase Currents and THD level at variable speed and <i>pq</i> technique	73
4.15	PCC Phase Currents and THD level at variable speed and <i>pq</i> technique	74
4.16	PCC Phase Voltage and THD level at variable speed and <i>pq</i> technique	75
4.17	Percentage of individual harmonic at variable speed and <i>pq</i> technique	
	(a) Percentage of individual harmonic in WTG current	
	(b) Percentage of individual harmonic in PCC current	
	(c) Percentage of individual harmonic in PCC voltage	76
4.18	Injected current by Shunt APF using <i>pq</i> technique and variable speed	77
4.19	WTG Phase Currents and THD level at fixed speed and SRF technique	78
4.20	PCC Phase Currents and THD level at fixed speed and SRF technique	79
4.21	PCC Phase Voltage and THD level at fixed speed and SRF technique	80
4.22	Percentage of individual harmonic at fixed speed and SRF technique	
	(a) Percentage of individual harmonic in WTG current	
	(b) Percentage of individual harmonic in PCC current	
	(c) Percentage of individual harmonic in PCC voltage	81
4.23	Injected current by Shunt APF using SRF technique and fixed speed	82
4.24	WTG Phase Currents and THD level at variable speed and SRF technique	83
4.25	PCC Phase Currents and THD level at variable speed and SRF technique	84
4.26	PCC Phase Voltage and THD level at variable speed and SRF technique	85

4.27	Percentage of individual harmonic at variable speed and SRF technique	
	(a) Percentage of individual harmonic in WTG current	
	(b) Percentage of individual harmonic in PCC current	
	(c) Percentage of individual harmonic in PCC voltage	86
4.28	Injected current by Shunt APF using SRF technique and variable speed	87
4.29	THD level of WTG current with fixed and variable wind speed	88
4.30	THD level of PCC current with fixed and variable wind speed	88
4.31	THD level of PCC voltage with fixed and variable wind speed	89
4.32	THD level of WTG current with fixed and variable wind speed	90
4.33	THD level of PCC current with fixed and variable wind speed	90
4.34	THD level of PCC voltage with fixed and variable wind speed	91
4.35	THD level of WTG current with fixed and variable wind speed	92
4.36	THD level of PCC current with fixed and variable wind speed	92
4.37	THD level of PCC voltage with fixed and variable wind speed	93

**LIST OF ABBREVIATIONS**

AC	-	Alternating Current
APF	-	Active Power Filter
DC	-	Direct Current
DFIG	-	Doubly Feed Induction Generator
DSP	-	Digital Signal Processing
d-q	-	Direct-Quadrature Axis
FFT	-	Fast Fourier Transform
GHG	-	Green House Gases
HBCC	-	Hysteresis Band Current Control
HVDC	-	High Voltage Direct Current
I	-	Fundamental current
IGBT	-	Insulated Gate Bipolar Transistor
PCC	-	Point of Common Coupling
PI	-	Proportional Integral
PLL	-	Phase Locked Loop
PQ	-	Power quality
PWM	-	Pulse Width Modulation
RE	-	Renewable Energy
WT	-	Wind Turbine
SCIG	-	Squirrel Cage Induction Generator
SRF	-	Synchronous Reference Frame
THD	-	Total Harmonic Distortion
WECS	-	Wind Energy Conversion System
WRIG	-	Wound Rotor Induction Generator
WTG	-	Wind Turbine Generator
WTS	-	Wind Turbine System

## LIST OF SYMBOLS

$i_d$	-	Stator direct axis current
$i_q$	-	Stator quadrature axis current
$L_d$	-	Stator direct axis inductance
$L_q$	-	Stator quadrature axis inductance
$R_s$	-	Stator resistance
$u_{sd}$	-	Stator direct axis voltage
$u_{sq}$	-	Stator quadrature axis voltage
$P$	-	Pole pair
$\omega_r$	-	Rotor Speed
$\Psi_m$	-	Amplitude of flux induced
$V_{La}, V_{Lb}, V_{Lc}$	-	Three phase source voltages
$i_a, i_b, i_c$	-	Three phase load currents
$\hat{i}_{La}, \hat{i}_{Lb}, \hat{i}_{Lc}$		
$v_\alpha, v_\beta, v_0$	-	Transformed source voltage (Clark's Transformation)
$i_\alpha, i_\beta, i_0$	-	Transformed source current (Clark's Transformation)
$i_\alpha^*, i_\beta^*$	-	Compensating current ( $pq$ theory)
$i_{ca}, i_{cb}, i_{cc}$	-	Reference current ( $pq$ theory)
$i_{sa}, i_{sb}, i_{sc}$	-	Extracted reference currents (SRF Technique)
$\overline{i_d}, \overline{i_q}$	-	Fundamental active and reactive current component
$\widetilde{i_d}, \widetilde{i_q}$	-	Harmonic active and reactive current component
$\alpha\beta 0$	-	Stationary Frame axis
$h$	-	Harmonic
$I_{sc}$	-	Short circuit current
$I_L$	-	Load current
$v_f$	-	Actual supply voltage
$I_f$	-	Actual supply current



**LIST OF APPENDICES**

<b>APPENDIX</b>	<b>TITLE</b>	<b>PAGE</b>
A1	IEEE 519 “Recommended practices and requirements for Harmonic control” for voltage	106
A2	IEEE 519 “Recommended practices and requirements for Harmonic control” for current	107
B1	Simulink Model of $pq$ Technique	108
B2	Simulink Model of SRF Technique	109
C1	List of Publications	110

## **CHAPTER 1**

### **INTRODUCTION**

#### **1.1 Background**

Generation of electricity from renewable sources such as wind, solar and wave in current scenario is really essential since the demand of power is increasing promptly and sources of fossil fuels are restricted. The non-conventional energy sources have significant contribution in power generation, the empathy and effective use of these sources is the plunge area in energy sector. Among all renewable sources, wind plays a dynamic role in energy generation. The location of wind turbine is very significant as the power output of wind is proportional to cube of wind speed [1].

The kinetic energy of air changed over into mechanical energy by windmill to directly operate a machine or to drive an alternator to generate electricity. Wind energy makes for a dynamic part in creating ecological neighborly atmosphere and draws the world more helpful for societies and for every living beings. Power for vast scale and small scale can be produced from wind turbines for utilities, commercial ventures, etc. Since early 1980's, the improvement of wind turbine energy, the rated capacity of wind turbines has expanded from a few several kW to today's MW turbines. Simultaneously, the pattern has moved from establishments, including a solitary or a couple wind turbines to arranging of substantial wind farms running from a few many MW to more than 100 MW [1].

Energy produced from wind turbines on vast scale diminishes the energy crises and anxiety can be surrendered from different wellsprings of energy era. Unexpectedly, the numbers of potential problems that must be contemplated when raising vast scale wind energy ranches for a practical power network. Installation and operation of wind farms network influence the living examples of the encompassing occupants, i.e., visual effects, clamor and demise of untamed life, etc. While combination of wind energy into the network likewise, makes potential specialized difficulties [1], that affect power quality (PQ) of the systems due to the variable nature of wind. The key potential difficulties that influence power quality because of expanded dispersion of wind vitality into the matrix comprise of, voltage fluctuation, power system transients and harmonics, reactive power, electromagnetic interference, switching actions, synchronization, long transmission lines, low power factor, storage system, load management, forecasting and scheduling [2, 3].

Power quality disturbances may be classified either between the quality of the supply voltage (source) or by the quality of the current drawn by the load. Advanced power electronic devices extensively used to rapidly draw harmonic currents and reactive power from AC mains due to their inalienable nonlinear V-I characteristics [4]. Different issues created by harmonic in the power network, furthermore have impact on customer items, for example, abnormal voltage waveforms, apparatus overheating, blown capacitor wires, transformer overheating, neutral current increment, low power factor, etc. [5-8]. Such non-linear loads contaminate the system by infusing current harmonics thus, crumbling the utility voltage and have a fall in supply voltage and escalated losses at point of common coupling (PCC). Because of presence of these harmonic, the total harmonic distortion (THD) level of the system increments above the harmonic standard set by IEEE under IEEE-519. Moreover, it affects the performance and efficiency of generator by adding intensified losses and producing extra heat. Thus, contributes to diminution of life span of generator [9].

The situation calls for alleviation of current harmonics instabilities in the cast of “filter devices” which are dexterous enough to deliver made-to-measure solution to harmonic generation. Generally as an Active Power Filter (APF), which is

employed for mitigating these harmonics and eventually enhancing power quality of the system. APFs can likewise be connected to power system to supply compensation for harmonics, reactive power, and/or neutral current. APFs can also be utilized to eradicate voltage harmonics, terminal voltage regulation, to suppress voltage flicker, and to improve three-phase balanced voltage [8]. APFs can be classified according to the type of compensation required. On the basis of this criteria, APF can be categorized as voltage source APF and current source APF. A voltage source APF has a capacitor on the DC side with a managed DC voltage, though a current source APF has an inductor with a regulated DC current. In spite of the fact that the voltage source type is better as far as filter capacity for elimination of PWM carrier harmonics and losses, the current source type is better regarding the compensating current dynamics and reliability and protection [10].

## 1.2 Problem Statement

Different techniques have been used by the researchers in last decades to overcome the consequence of these harmonic contents and to supply consistent and sinusoidal power to the consumers which does not damage to their equipment. A. Prasad et al., [11] utilized passive filter to eliminate harmonics from the system, however passive filter have drawback that it only indemnify the system for under and over compensation. H. Sasaki et al., [12] proposed active filter recognized as active power filter (APF) to minimize harmonic effects from the system. F. S. dos Reis et al., [13] applied APF to mitigate harmonics from permanent magnet synchronous generator (PMSG) based wind turbine generator (WTG) while in islanding mode with fixed wind speed (12 m/sec). J. Tsai et al., [9] also proposed APF with its variable frequency operation under islanding mode of wind turbine system (WTS). A. Gaillard et al., [14] employed APF with doubly feed induction generator (DFIG) based fixed speed (8 m/sec) wind turbine to analyze the operational features of proposed system under the same islanding mode. A. Hoseinpour et al., [15] put forward modified modulation technique for APF with PMSG WTG under islanding mode with fixed speed (8 m/sec). All of them used different reference signal extraction techniques and modulation methods.

In this research, APF is proposed to use with grid connected variable speed wind turbine system to analyze the effectiveness of proposed system. Under this study, effect of wind turbine at point of common coupling (PCC) under varying nature of wind speed will be investigated. Furthermore, the effect of nonlinear load connected at PCC and on the wind generator, considering profile of total harmonic distortion (THD) level is the ultimate interest of this research. At the end, the effective solicitation of the proposed methodology will eventually function under international standard of harmonic control i.e. IEEE-519 with improved efficiency.

### 1.3 Objectives

The objectives of research are listed below,

- (i) To develop MATLAB Simulink model for grid connected wind turbine generator based on permanent magnet synchronous generator (PMSG) subject to presence of harmonic with nonlinear loads.
- (ii) To design PI controller based APF to tackle harmonic problems in the proposed system under unbalanced nonlinear loads.
- (iii) To investigate APF with instantaneous reactive power technique ( $pq$  technique) and synchronous reference frame (SRF) technique to get similar or better results in accordance with IEEE-519 standard under fixed and fluctuating wind speed.

## 1.4 Scope

The scope of this research study will be as follow,

- (i) PMSG based wind turbine will be used in this study with 120 kV grid system. The prevailing load situation in grid connected wind turbine, especially effect of non-linear load will be studied.
- (ii) The proposed system will be studied under fixed (8 m/sec) and variable wind speeds (8-12 m/sec) for maximum power extraction from wind turbine.
- (iii) The system design will be based on variable frequency shunt active power filter and PI controller.
- (iv) MATLAB/Simulink software will be used to develop and test the proposed system model.
- (v) Simulation results will be analyzed on the basis of control methods (SRF and  $pq$  technique), to determine which method is more suitable for the proposed case study.

## 1.5 Significance of Study

The significance of this research study is as follow,

- (i) Describe viability of APF from practical applicability view-point using proportional integral (PI) controller under frequently faced load conditions and regularly experienced fault conditions and system being researched on

are set aside, as they may be more prone to failing as well as more difficult for maintenance if put into practice.

- (ii) Develop the integration principles of APF, based on instantaneous reactive power theory and synchronous reference frame technique, directly calculated from three phase a-b-c voltages and line currents using  $\alpha\beta 0$  and d-q reference frame respectively.

## **1.6 Organization of Thesis**

The thesis is organized in a manner that Chapter 1 briefly describes the introduction of studied system, Chapter 2 providing an up-to-date literature review, Chapter 3 outlining proposed methodology while Chapter 4 representing results of the studied system and in the last Chapter 5 symbolizing conclusion and future recommendations.

## REFERENCES

1. G. Shafiullah, A. MT Oo, A. Shawkat Ali, and P. Wolfs, "Potential challenges of integrating large-scale wind energy into the power grid—A review," *Renewable and Sustainable Energy Reviews*, vol. 20, pp. 306-321, 2013.
2. Z. Ming, H. Lixin, Y. Fan, and J. Danwei, "Notice of Retraction Research of the Problems of Renewable Energy Orderly Combined to the Grid in Smart Grid," in *Power and Energy Engineering Conference (APPEEC), 2010 Asia-Pacific*, 2010, pp. 1-4.
3. P. Cartwright, "Connecting renewables: the challenge of integrating large offshore wind farms," *Refocus*, vol. 7, pp. 24-26, 2006.
4. G. Singh, A. Singh, and R. Mitra, "A simple fuzzy logic based robust active power filter for harmonics minimization under random load variation," *Electric power systems research*, vol. 77, pp. 1101-1111, 2007.
5. J. S. Subjak Jr and J. S. Mcquilkin, "Harmonics-causes, effects, measurements, and analysis: an update," *Industry Applications, IEEE Transactions on*, vol. 26, pp. 1034-1042, 1990.
6. L. Duarte and M. Alves, "The degradation of power capacitors under the influence of harmonics," in *Harmonics and Quality of Power, 2002. 10th International Conference on*, 2002, pp. 334-339.
7. V. Wagner, J. Balda, D. Griffith, A. McEachern, T. Barnes, D. Hartmann, *et al.*, "Effects of harmonics on equipment," *Power Delivery, IEEE Transactions on*, vol. 8, pp. 672-680, 1993.
8. A. M. Massoud, S. Ahmed, and A. S. Abdel-Khalik, "Active Power Filter," *Power Electronics for Renewable Energy Systems, Transportation and Industrial Applications*, pp. 534-572, 2014.
9. J. Tsai and K. Tan, "H APF harmonic mitigation technique for PMSG wind energy conversion system," in *Power Engineering Conference, 2007. AUPEC 2007. Australasian Universities*, 2007, pp. 1-6.
10. L. A. Moran, J. W. Dixon, and R. R. Wallace, "A three-phase active power filter operating with fixed switching frequency for reactive power and current harmonic compensation," *Industrial Electronics, IEEE Transactions on*, vol. 42, pp. 402-408, 1995.



11. A. Prasad, P. D. Ziogas, and S. Manias, "An active power factor correction technique for three-phase diode rectifiers," *Power Electronics, IEEE Transactions on*, vol. 6, pp. 83-92, 1991.
12. H. Sasaki and T. Machida, "A new method to eliminate ac harmonic currents by magnetic flux compensation-considerations on basic design," *Power Apparatus and Systems, IEEE Transactions on*, pp. 2009-2019, 1971.
13. F. S. dos Reis, J. Ale, F. Adegas, R. Tonkoski, S. Slan, and K. Tan, "Active shunt filter for harmonic mitigation in wind turbines generators," in *Power Electronics Specialists Conference, 2006. PESC'06. 37th IEEE*, 2006, pp. 1-6.
14. A. Gaillard, P. Poure, S. Saadate, and M. Machmoum, "Variable speed DFIG wind energy system for power generation and harmonic current mitigation," *Renewable Energy*, vol. 34, pp. 1545-1553, 2009.
15. A. Hoseinpour, S. Masoud Barakati, and R. Ghazi, "Harmonic reduction in wind turbine generators using a Shunt Active Filter based on the proposed modulation technique," *International Journal of Electrical Power & Energy Systems*, vol. 43, pp. 1401-1412, 2012.
16. J. Slootweg and W. Kling, "Is the Answer Blowing in the Wind?| IEEE power & energy magazine, November," ed: December, 2003.
17. A. A. B. Mohd Zin, M. Pesaran HA, A. B. Khairuddin, L. Jahanshaloo, and O. Shariati, "An overview on doubly fed induction generators' controls and contributions to wind based electricity generation," *Renewable and Sustainable Energy Reviews*, vol. 27, pp. 692-708, 2013.
18. Y. Lang, N. Zargari, and S. Kouro, *Power conversion and control of wind energy systems* vol. 74: John Wiley & Sons, 2011.
19. R. Bansal, T. Bhatti, and D. Kothari, "Bibliography on the application of induction generators in nonconventional energy systems," *Energy Conversion, IEEE Transactions on*, vol. 18, pp. 433-439, 2003.
20. J. C. K. Shadhu Khan, P, "Three-phase induction generators: a discussion on performance," *Electric Machines & Power Systems*, vol. 27, pp. 813-832, 1999.
21. R. Bansal, "Three-phase self-excited induction generators: an overview," *Energy Conversion, IEEE Transactions on*, vol. 20, pp. 292-299, 2005.

22. H. Polinder, F. F. Van der Pijl, G.-J. De Vilder, and P. J. Tavner, "Comparison of direct-drive and geared generator concepts for wind turbines," *Energy conversion, IEEE transactions on*, vol. 21, pp. 725-733, 2006.
23. Z. Wu, X. Dou, J. Chu, and M. Hu, "Operation and Control of a Direct-Driven PMSG-Based Wind Turbine System with an Auxiliary Parallel Grid-Side Converter," *Energies*, vol. 6, pp. 3405-3421, 2013.
24. A. Nouh and F. Mohamed, "Wind energy conversion systems: Classifications and trends in application," in *Renewable Energy Congress (IREC), 2014 5th International*, 2014, pp. 1-6.
25. Y. Zhang and S. Ula, "Comparison and evaluation of three main types of wind turbines," in *Transmission and Distribution Conference and Exposition, 2008. T&D 2008; D. IEEE/PES*, 2008, pp. 1-6.
26. M. Hossain, N. Afrin, and M. F. Ali, "Approach to Harmonic Mitigation Study in Wind Turbine Energy Conversion Systems Using Three Phase Boost Rectifiers," *IOSR Journal of Engineering*, vol. 4, pp. 21-26, 2014.
27. A. M. De Broe, S. Drouilhet, and V. Gevorgian, "A peak power tracker for small wind turbines in battery charging applications," *Energy Conversion, IEEE Transactions on*, vol. 14, pp. 1630-1635, 1999.
28. A. Rolan, A. Luna, G. Vazquez, D. Aguilar, and G. Azevedo, "Modeling of a variable speed wind turbine with a permanent magnet synchronous generator," in *Industrial Electronics, 2009. ISIE 2009. IEEE International Symposium on*, 2009, pp. 734-739.
29. F. Jay and J. Goetz, "IEEE standard dictionary of electrical and electronics terms," 1988.
30. H. Akagi, "New trends in active filters for power conditioning," *Industry Applications, IEEE Transactions on*, vol. 32, pp. 1312-1322, 1996.
31. W. Kazibwe and M. Sendaula, "Electric Power Quality Control Techniques Van Nostrand Reinhold," *New York*, 1993.
32. Z. Salam, P. C. Tan, and A. Jusoh, "Harmonics mitigation using active power filter: A technological review," *Elektrika*, vol. 8, pp. 17-26, 2006.
33. R. G. Ellis and P. Eng, "Power System Harmonics—A Reference Guide to Causes, Effects and Corrective Measures," *An Allen-Brandley Series of Issues and Answers-Rockwell Automation*, p. 3, 2001.

34. Y. Oğuz, İ. Güney, and H. Çalık, "Power Quality Control and Design of Power Converter for Variable-Speed Wind Energy Conversion System with Permanent-Magnet Synchronous Generator," *The Scientific World Journal*, vol. 2013, 2013.
35. V.-T. Phan and H.-H. Lee, "Control strategy for harmonic elimination in stand-alone DFIG applications with nonlinear loads," *Power Electronics, IEEE Transactions on*, vol. 26, pp. 2662-2675, 2011.
36. I. F II, "IEEE recommended practices and requirements for harmonic control in electrical power systems," 1993.
37. S. Das, S. Gupta, and S. Bhargava, "Harmonic reduction methods for wind energy conversion systems: A review," in *Electrical, Electronics and Computer Science (SCEECS), 2014 IEEE Students' Conference on*, 2014, pp. 1-8.
38. S. Rahmani, A. Hamadi, and K. Al-Haddad, "A new combination of shunt hybrid power filter and thyristor controlled reactor for harmonics and reactive power compensation," in *Electrical Power & Energy Conference (EPEC), 2009 IEEE*, 2009, pp. 1-6.
39. W. M. Grady, M. J. Samotyj, and A. H. Noyola, "Survey of active power line conditioning methodologies," *Power Delivery, IEEE Transactions on*, vol. 5, pp. 1536-1542, 1990.
40. H. Kawahira, T. Nakamura, S. Nakazawa, and M. Nomura, "Active power filters," in *Proceedings of the 1983 International Power Electronics Conference*, 1983, pp. 981-992.
41. H. Akagi, Y. Kanazawa, and A. Nabae, "Instantaneous reactive power compensators comprising switching devices without energy storage components," *Industry Applications, IEEE Transactions on*, pp. 625-630, 1984.
42. H. Akagi, A. Nabae, and S. Atoh, "Control strategy of active power filters using multiple voltage-source PWM converters," *Industry Applications, IEEE Transactions on*, pp. 460-465, 1986.
43. G. Xiao, J. Liu, and J. Yang, "The experimental studies on active power filter for HVDC system," in *Power Electronics and Motion Control Conference, 2000. Proceedings. IPEMC 2000. The Third International*, 2000, pp. 1376-1379.

44. P. Verdelho and G. Marques, "Multiple applications control system for the PWM voltage converter connected to the AC mains," in *Power Electronics and Applications, 1993., Fifth European Conference on*, 1993, pp. 42-46.
45. M. Pereira, G. Wild, H. Huang, and K. Sadek, "Active filters in HVDC systems: actual concepts and application experience," in *Power System Technology, 2002. Proceedings. PowerCon 2002. International Conference on*, 2002, pp. 989-993.
46. A. Gole and M. Meisingset, "An AC active filter for use at capacitor commutated HVDC converters," *Power Delivery, IEEE Transactions on*, vol. 16, pp. 335-341, 2001.
47. B. Singh, K. Al-Haddad, and A. Chandra, "A review of active filters for power quality improvement," *Industrial Electronics, IEEE Transactions on*, vol. 46, pp. 960-971, 1999.
48. L. A. Morán, J. W. Dixon, J. R. Espinoza, and R. R. Wallace, "Using active power filters to improve power quality," in *5th Brazilian Power Electronics Conference*, 1999, pp. 501-511.
49. L. Pittorino, A. Horn, and J. Enslin, "Power theory evaluation for the control of an active power filter," in *AFRICON, 1996., IEEE AFRICON 4th*, 1996, pp. 676-681.
50. M. El-Habrouk, M. Darwish, and P. Mehta, "Active power filters: A review," *IEE Proceedings-Electric Power Applications*, vol. 147, pp. 403-413, 2000.
51. J. H. Enslin and J. D. Van Wyk, "Measurement and compensation of fictitious power under nonsinusoidal voltage and current conditions," *Instrumentation and Measurement, IEEE Transactions on*, vol. 37, pp. 403-408, 1988.
52. J. H. Enslin and J. D. Van Wyk, "A new control philosophy for power electronic converters as fictitious power compensators," in *Power Electronics Specialists Conference, 1988. PESC'88 Record., 19th Annual IEEE*, 1988, pp. 1188-1196.
53. G. L. van Harmelen and J. H. Enslin, "Real-time dynamic control of dynamic power filters in supplies with high contamination," *Power Electronics, IEEE Transactions on*, vol. 8, pp. 301-308, 1993.
54. M. Welsh, P. Mehta, and M. Darwish, "Genetic algorithm and extended analysis optimisation techniques for switched capacitor active filters-

- comparative study," in *Electric Power Applications, IEE Proceedings-*, 2000, pp. 21-26.
55. C.-Y. Hsu and H.-Y. Wu, "A new single-phase active power filter with reduced energy-storage capacity," *IEE Proceedings-Electric Power Applications*, vol. 143, pp. 25-30, 1996.
  56. D. A. Torrey and A. M. Al-Zamel, "Single-phase active power filters for multiple nonlinear loads," *Power Electronics, IEEE Transactions on*, vol. 10, pp. 263-272, 1995.
  57. J. Nastran, R. Cajhen, M. Seliger, and P. Jereb, "Active power filter for nonlinear AC loads," *Power Electronics, IEEE Transactions on*, vol. 9, pp. 92-96, 1994.
  58. V. Bhavaraju and P. Enjeti, "A fast active power filter to correct line voltage sags," *Industrial Electronics, IEEE Transactions on*, vol. 41, pp. 333-338, 1994.
  59. Z. Koozehkanani, P. Mehta, and M. Darwish, "Active symmetrical lattice filter for harmonic current reduction," in *EUROPEAN CONFERENCE ON POWER ELECTRONICS AND APPLICATIONS*, 1995, pp. 1.869-1.873.
  60. Z. D. Koozehkanani, P. Mehta, and M. Darwish, "An active filter for retrofit applications," 1996.
  61. W. Koczara, S. Greetham, and L. Haydock, "An investigation of the reduction of harmonics and reactive power in a single phase system using an adaptive filter'," in *Proceedings of Power Electronics and Motion Control conference, PEMC94*, 1994, pp. 196-201.
  62. A. Cavallini and G. C. Montanari, "Compensation strategies for shunt active-filter control," *Power Electronics, IEEE Transactions on*, vol. 9, pp. 587-593, 1994.
  63. P. Viriya and K. Matsuse, "Low-harmonic GTO converter for fundamental power factor compensation," *Power Electronics, IEEE Transactions on*, vol. 6, pp. 371-379, 1991.
  64. H. Fujita, H. Akagi, and M. Kohata, "Combined rectifying system including double-series capacitor-smoothed diode rectifier and series active filter," *Electrical engineering in Japan*, vol. 120, pp. 85-94, 1997.

65. H.-L. Jou, "Performance comparison of the three-phase active-power-filter algorithms," *IEE Proceedings-generation, Transmission and Distribution*, vol. 142, pp. 646-652, 1995.
66. G. Ledwich and P. Doulai, "Multiple converter performance and active filtering," *Power Electronics, IEEE Transactions on*, vol. 10, pp. 273-279, 1995.
67. W. Xu, Y. Mansour, C. Siggers, and M. Hughes, "Developing utility harmonic regulations based on IEEE STD 519-BC, Hydro's approach," *Power Delivery, IEEE Transactions on*, vol. 10, pp. 1423-1431, 1995.
68. G. Blajszczak, "Static VAR compensator with fully controlled reactors," *IEE Proceedings-Electric Power Applications*, vol. 141, pp. 264-268, 1994.
69. F. Z. Peng, J.-S. Lai, J. W. McKeever, and J. VanCoevering, "A multilevel voltage-source inverter with separate DC sources for static var generation," *Industry Applications, IEEE Transactions on*, vol. 32, pp. 1130-1138, 1996.
70. S. Fukuda and T. Endoh, "Control method for a combined active filter system employing a current source converter and a high pass filter," *Industry Applications, IEEE Transactions on*, vol. 31, pp. 590-597, 1995.
71. H. Fujita, S. Tominaga, and H. Akagi, "Analysis and design of a dc voltage-controlled static var compensator using quad-series voltage-source inverters," *Industry Applications, IEEE Transactions on*, vol. 32, pp. 970-978, 1996.
72. G. Joos, X. Huang, and B.-T. Ooi, "Direct-coupled multilevel cascaded series VAR compensators," in *Industry Applications Conference, 1997. Thirty-Second IAS Annual Meeting, IAS'97., Conference Record of the 1997 IEEE*, 1997, pp. 1608-1615.
73. D. Scheidecker and S. Tennakoon, "Optimisation of the number of levels in a multi-level advanced static VAR compensator," in *EUROPEAN CONFERENCE ON POWER ELECTRONICS AND APPLICATIONS*, 1995, pp. 2.493-2.498.
74. F. Z. Peng and J.-S. Lai, "Dynamic performance and control of a static var generator using cascade multilevel inverters," in *Industry Applications Conference, 1996. Thirty-First IAS Annual Meeting, IAS'96., Conference Record of the 1996 IEEE*, 1996, pp. 1009-1015.
75. S. Inarida, W. Miyake, N. Mizuguchi, T. Hariyama, and K. Hoshi, "Development of three-level power converter system using IGBTs for

- Shinkansen trains," in *EUROPEAN CONFERENCE ON POWER ELECTRONICS AND APPLICATIONS*, 1997, pp. 1.216-1.220.
76. H. Akagi, "New trends in active filters," in *EUROPEAN CONFERENCE ON POWER ELECTRONICS AND APPLICATIONS*, 1995, pp. 0.017-0.026.
77. F. Z. Peng, "Application issues of active power filters," *Industry Applications Magazine, IEEE*, vol. 4, pp. 21-30, 1998.
78. J. W. Dixon, G. Venegas, and L. A. Moran, "A series active power filter based on a sinusoidal current-controlled voltage-source inverter," *Industrial Electronics, IEEE Transactions on*, vol. 44, pp. 612-620, 1997.
79. F. Z. Peng, H. Akagi, and A. Nabae, "Compensation characteristics of the combined system of shunt passive and series active filters," *Industry Applications, IEEE Transactions on*, vol. 29, pp. 144-152, 1993.
80. H. Akagi, H. Fujita, and K. Wada, "A shunt active filter based on voltage detection for harmonic termination of a radial power distribution line," *Industry Applications, IEEE Transactions on*, vol. 35, pp. 638-645, 1999.
81. B.-T. Ooi and S.-Z. Dai, "Series-type solid-state static VAR compensator," *IEEE transactions on power electronics*, vol. 8, pp. 164-169, 1993.
82. R. Harley, B. Rigby, and G. Jennings, "Design of a controlled converter which emulates a series capacitive compensator for long power lines," in *Proc. Int. Conf. Power Electronics and Motion Control (PEMC'94)*, 1994, pp. 213-218.
83. G. Joos, L. Moran, and P. Ziogas, "Performance analysis of a PWM inverter VAR compensator," *Power Electronics, IEEE Transactions on*, vol. 6, pp. 380-391, 1991.
84. H. Shirahama, Y. Sakurai, Y. Matsuda, Y. Ishigaki, and K. Murai, "Instantaneous control method with a GTO converter for active and reactive powers in superconducting magnetic energy storage," *IEEE transactions on power electronics*, vol. 9, pp. 1-6, 1994.
85. M. Rastogi, N. Mohan, and A. Edris, "Hybrid-active filtering of harmonic currents in power systems," *Power Delivery, IEEE Transactions on*, vol. 10, pp. 1994-2000, 1995.
86. V. Bhavaraju and P. N. Enjeti, "Analysis and design of an active power filter for balancing unbalanced loads," *Power Electronics, IEEE Transactions on*, vol. 8, pp. 640-647, 1993.

87. P. Verdelho and G. Marques, "An active power filter and unbalanced current compensator," *Industrial Electronics, IEEE Transactions on*, vol. 44, pp. 321-328, 1997.
88. F. Z. Peng, H. Akagi, and A. Nabae, "A new approach to harmonic compensation in power systems-a combined system of shunt passive and series active filters," *Industry Applications, IEEE Transactions on*, vol. 26, pp. 983-990, 1990.
89. B. Bird, J. Marsh, and P. McLellan, "Harmonic reduction in multiplex convertors by triple-frequency current injection," in *Proceedings of the Institution of Electrical Engineers*, 1969, pp. 1730-1734.
90. Z. Chen, J. M. Guerrero, and F. Blaabjerg, "A review of the state of the art of power electronics for wind turbines," *Power Electronics, IEEE Transactions on*, vol. 24, pp. 1859-1875, 2009.
91. T.-F. Wu, C.-L. Shen, J.-Y. Chiu, and C.-C. Chen, "An APF with MAPPT scheme to improve power quality," in *TENCON 2001. Proceedings of IEEE Region 10 International Conference on Electrical and Electronic Technology*, 2001, pp. 620-626.
92. S. Buso, L. Malesani, and P. Mattavelli, "Comparison of current control techniques for active filter applications," *Industrial Electronics, IEEE Transactions on*, vol. 45, pp. 722-729, 1998.
93. S.-G. Jeong and M.-H. Woo, "DSP-based active power filter with predictive current control," *Industrial Electronics, IEEE Transactions on*, vol. 44, pp. 329-336, 1997.
94. P. Jintakosonwit, H. Fujita, and H. Akagi, "Control and performance of a fully-digital-controlled shunt active filter for installation on a power distribution system," *Power Electronics, IEEE Transactions on*, vol. 17, pp. 132-140, 2002.
95. S. Khositkasame and S. Sangwongwanich, "Design of harmonic current detector and stability analysis of a hybrid parallel active filter," in *Power Conversion Conference-Nagaoka 1997., Proceedings of the*, 1997, pp. 181-186.
96. M. Routimo, M. Salo, and H. Tuusa, "A novel control method for wideband harmonic compensation," in *Power Electronics and Drive Systems, 2003. PEDS 2003. The Fifth International Conference on*, 2003, pp. 799-804.



97. R. Li, A. Johns, M. Elkateb, and F. Robinson, "Comparative study of parallel hybrid filters in resonance damping," in *Electric Power Engineering, 1999. PowerTech Budapest 99. International Conference on*, 1999, p. 230.
98. S. Bhattacharya and D. Divan, "Synchronous frame based controller implementation for a hybrid series active filter system," in *Industry Applications Conference, 1995. Thirtieth IAS Annual Meeting, IAS'95., Conference Record of the 1995 IEEE*, 1995, pp. 2531-2540.
99. G. C. Cho, G. H. Jung, N. S. Choi, and G. H. Cho, "Analysis and controller design of static var compensator using three-level GTO inverter," *Power Electronics, IEEE Transactions on*, vol. 11, pp. 57-65, 1996.
100. L. S. Czarnecki, "Comments on" Measurement and compensation of fictitious power under nonsinusoidal voltage and current conditions" by JHR Enslin and JD Van Wyk," *Instrumentation and Measurement, IEEE Transactions on*, vol. 38, pp. 839-841, 1989.
101. L. Czarnecki, "Comments, with reply, on" A new control philosophy for power electronic converters as fictitious power compensators" by JHR Enslin and JD Van Wyk," *Power Electronics, IEEE Transactions on*, vol. 5, pp. 503-504, 1990.
102. S. Bhattacharya, A. Veltman, D. M. Divan, and R. D. Lorenz, "Flux-based active filter controller," *Industry Applications, IEEE Transactions on*, vol. 32, pp. 491-502, 1996.
103. K. George and T. Schweizer, "Renewable energy technology characterizations," ed: Finance EPRI Topical Report No. TR-109496, US Department of Energy, Washington, DC, EPRI, Palo Alto, California, Dec, 1997.
104. R. Melicio, J. P. Catalão, and V. M. Mendes, *Wind turbines with permanent magnet synchronous generator and full-power converters: modelling, control and simulation*: INTECH Open Access Publisher, 2011.
105. C.-N. Wang, W.-C. Lin, and X.-K. Le, "Modelling of a PMSG Wind Turbine with Autonomous Control," *Mathematical Problems in Engineering*, vol. 2014, 2014.
106. E. Kamal, A. Aitouche, R. Ghorbani, and M. Bayart, "Robust nonlinear control of wind energy conversion systems," *International Journal of Electrical Power & Energy Systems*, vol. 44, pp. 202-209, 2013.

107. J. Fei, K. Ma, S. Zhang, W. Yan, and Z. Yuan, "Adaptive current control with PI-fuzzy compound controller for shunt active power filter," *Mathematical Problems in Engineering*, vol. 2013, 2013.
108. S. Rahmani, N. Mendalek, and K. Al-Haddad, "Experimental design of a nonlinear control technique for three-phase shunt active power filter," *Industrial Electronics, IEEE Transactions on*, vol. 57, pp. 3364-3375, 2010.
109. R. S. Herrera, P. Salmerón, and H. Kim, "Instantaneous reactive power theory applied to active power filter compensation: Different approaches, assessment, and experimental results," *Industrial Electronics, IEEE Transactions on*, vol. 55, pp. 184-196, 2008.
110. A. Sharma and A. Upadhyay, "Harmonic Mitigation Using Inverter Based Hybrid Shunt Active Power Filter," *International Journal of Electronic and Electrical Engineering*, vol. 7, 2014.
111. S. PURUSHOTHAMAN, "DESIGN AND ANALYSIS OF ELIMINATION OF HARMONICS USING WIND ENERGY CONVERSION SYSTEMS," *Journal of Theoretical and Applied Information Technology*, vol. 61, 2014.
112. S. K. Khadem, M. Basu, and M. F. Conlon, "Harmonic power compensation capacity of shunt active power filter and its relationship with design parameters," *Power Electronics, IET*, vol. 7, pp. 418-430, 2014.
113. S. Luo and Z. Hou, "An adaptive detecting method for harmonic and reactive currents," *Industrial Electronics, IEEE Transactions on*, vol. 42, pp. 85-89, 1995.
114. L. P. Ling and N. Azli, "SVM based hysteresis current controller for a three phase active power filter," in *Power and Energy Conference, 2004. PECTON 2004. Proceedings. National*, 2004, pp. 132-136.
115. S. Buso, L. Malesani, P. Mattavelli, and R. Veronese, "Design and fully digital control of parallel active filters for thyristor rectifiers to comply with IEC-1000-3-2 standards," *Industry Applications, IEEE Transactions on*, vol. 34, pp. 508-517, 1998.
116. J.-S. Lai, "Power electronics applications in renewable energy systems," in *Industrial Electronics Society, 2003. IECON'03. The 29th Annual Conference of the IEEE*, 2003, pp. 3025-3026.
117. G. Adam, A. G. Stan, and G. Livint, "A Matlab-Simulink Approach To Shunt Active Power Filters," in *ECMS*, 2011, pp. 205-210.

118. J. L. Afonso, M. Freitas, and J. S. Martins, "pq Theory power components calculations," in *Industrial Electronics, 2003. ISIE'03. 2003 IEEE International Symposium on*, 2003, pp. 385-390.
119. V. Soares, P. Verdelho, and G. D. Marques, "An instantaneous active and reactive current component method for active filters," *Power Electronics, IEEE Transactions on*, vol. 15, pp. 660-669, 2000.
120. S. Mikkili and A. Panda, "Real-time implementation of PI and fuzzy logic controllers based shunt active filter control strategies for power quality improvement," *International Journal of Electrical Power & Energy Systems*, vol. 43, pp. 1114-1126, 2012.
121. S. Mikkili and A. Panda, "Type-1 and Type-2 Fuzzy logic controller based Shunt active filter I d-I q control strategy for mitigation of harmonics with Triangular membership function," in *Power Electronics, Drives and Energy Systems (PEDES), 2012 IEEE International Conference on*, 2012, pp. 1-6.
122. L. Malesani, P. Mattavelli, and S. Buso, "Dead-beat current control for active filters," in *Industrial Electronics Society, 1998. IECON'98. Proceedings of the 24th Annual Conference of the IEEE*, 1998, pp. 1859-1864.
123. J. Das, "Passive filters-potentialities and limitations," in *Pulp and Paper Industry Technical Conference, 2003. Conference Record of the 2003 Annual*, 2003, pp. 187-197.
124. D. Chen and S. Xie, "Review of the control strategies applied to active power filters," in *Electric Utility Deregulation, Restructuring and Power Technologies, 2004.(DRPT 2004). Proceedings of the 2004 IEEE International Conference on*, 2004, pp. 666-670.
125. M. El-Habrouk and M. Darwish, "Design and implementation of a modified Fourier analysis harmonic current computation technique for power active filters using DSPs," in *Electric Power Applications, IEE Proceedings-*, 2001, pp. 21-28.