

FAULT LOCATION USING LINE IMPEDANCE WITH THE PRESENCE OF
ARC RESISTANCE

EMAD-ELDIN MOHAMED-AHMED MOHAMED

A project report submitted in partial fulfilment of the
requirements for the award of the degree of
Master of Engineering (Electrical - Power)

Faculty of Electrical Engineering
Universiti Teknologi Malaysia

JANUARY 2014

Dedicated to my lovely Mother
To the soul of my Father
To my Brothers and Sisters
To my Wife
And to all those that believed in me

ACKNOWLEDGEMENT

First and foremost, my unlimited appreciation goes to my Lord Allah (swt) for the endless mercies, blessings and guidance through from birth till now and forever. Then I shall forever be grateful to my parents, my siblings and my wife for their belief in me and for their unending support.

My sincere appreciation goes to my supervisor **Dr. Ahmad Safawi bin Mokhtar** for his guidance and support. My earnest appreciation also goes to all my friends and colleagues that helped me to successfully complete the Master program and this project. To you all I say thank you.

Besides, I would like to thank the authority of Universiti Teknologi Malaysia (UTM) for providing us with excellent environment and useful facilities such as the rich online database that is needed to complete this project.

ABSTRACT

Many methods were developed to identify the estimated location of faults in distribution systems. They are either dealing with the travelling waves generated by faults at high frequencies or using the fundamental frequency components. Among them “Fault Impedance Methods” are the most popular, but their accuracy is affected by the presence of fault resistances and the presence of arcs. In this project, PSCAD is used for simulating several types of faults, focusing in three lines to ground faults with different cases, including faults with and without fault resistance in addition to faults with arc. The fault impedance method code that improved to consider the presence of arcs and its resistance and implemented using MATLAB programming environment is used to estimate the fault location for the previous cases. As expected, the method is sensitive to the presence of fault resistance and fault arcs. However, the improved method achieved good results for faults with arcs at distances higher than 15 km and slightly improved results for shorter distances.

ABSTRAK

Pelbagai kaedah telah dibangunkan untuk mengenal pasti lokasi kerosakan dalam sistem penghantaran bekalan elektrik. Kerosakan pada system penghantaran bekalan elektrik bergantung kepada gelombang penghantaran dihantar pada frekuensi tinggi atau komponen frekuensi asas. "Kaedah kerosakan galangan " merupakan kaedah yang paling popular, tetapi ketepatan mereka banyak dipengaruhi oleh kehadiran rintangan dan arka. Perisian PSCAD digunakan untuk menganalisis jenis kerosakan terutama sekali pada kerosakan "3 line to ground" termasuk kerosakan yang melibatkan rintangan dan juga yang tidak melibatkan rintangan. Aturcara MATLAB yang dibangunkan dalam projek ini akan digunakan untuk mengenalpasti lokasi kerosakan pada sistem penghantaran bagi kes-kes sebelumnya dengan mengambil kira rintangan dan arka. Seperti yang telah dijangkakan, kaedah yang dibangunkan dalam projek adalah sangat berkesan dan sensitif pada kehadiran rintangan dan arka. Kaedah yang dibangunkan dalam projek ini telah berjaya mengenalpasti lokasi kerosakan pada sistem penghantaran pada jarak 15km ke bawah dengan mengambil kira kehadiran rintangan dan arka

TABLE OF CONTENTS

CHAPTER	TITLE	PAGE
	DECLARATION	ii
	DEDICATION	iii
	ACKNOWLEDGMENT	iv
	ABSTRACT	v
	ABSTRAK	vi
	TABLE OF CONTENTS	vii
	LIST OF TABLES	ix
	LIST OF FIGURES	x
	LIST OF APPENDICES	xii
1	INTRODUCTION	
	1.1 Introduction	1
	1.2 Problem Statement	4
	1.3 Objectives of The Research	4
	1.4 Scope of The Research	5
	1.5 Expected Contributions	6
	1.6 Thesis Outline	7
2	LITERATURE REVIEW	
	2.1 Fault Location Methods	8
	2.1.1 Modal Analysis	8
	2.1.2 Programmable Logic Controller	9
	2.1.3 Voltage Sag	9

2.1.4 Impedance Based Methods	10
2.1.4.1 DMS Based Fault Location	11
2.1.4.2 Method of Novosel et al.	12
2.1.4.3 Technique of Das et al.	12
2.1.4.4 Algorithm of Saha et al.	13
2.2 Arc Detection Methods	14
2.3 Arc Resistance Models	15
3 METHODOLOGY	
3.1 Building of Distribution System Models	20
3.2 Simulation Using PSCAD Software	21
3.3 Development of Fault Location Method	33
3.4 Evaluation of the Developed Method	41
4 RESULTS	
4.1 Faults With No Arcs	42
4.2 Faults With Arcs	50
5 CONCLUSION AND RECOMMENDATIONS	
5.1 Conclusion	52
5.2 Recommendation for Future work	53
REFERENCES	54
Appendices	57

LIST OF TABLES

TABLE NO.	TITLE	PAGE
2.1	Range of currents for each arc resistance model	17
4.1	Fault location estimation using Z and X to fault	42
4.2	Fault location estimation using Z and X to fault (no fault resistance)	45
4.3	Fault location estimation using Z and X to fault (5 Ω fault resistance)	45
4.4	Fault location estimation using Z and X to fault (25 Ω fault resistance)	45
4.5	Fault location estimation in presence of lateral	47
4.6	Fault location estimation using fault impedance and voltage sag	48
4.7	fault location estimation using fault impedance and voltage sag (1 Ω fault resistance)	48
4.8	fault location estimation using fault impedance and voltage sag (5 Ω fault resistance)	50
4.9	Fault location estimation using fault impedance and voltage sag with arc resistance	50

LIST OF FIGURES

FIGURE NO	TITLE	PAGE
3.1	Research steps flow	19
3.2	Voltage source display, configuration and signal parameters	22
3.3	Equivalent pi model display, configuration and zero sequence impedance estimate factor	23
3.4	Transmission line model display and basic configuration	24
3.5	Transmission line model selection and configuration	24
3.6	Models “fault” and “timed fault logic” graphical display	25
3.7	Models “fault” and “timed fault logic” configuration	26
3.8	Multimeter unit graphical display and configuration	27
3.9	Data label and output channel graphical display and configuration	28
3.10	r.m.s voltage output graph	28
3.11	Source voltage output graph	29
3.12	Source current output graph	29
3.13	Arc resistance model implementation	30
3.14	Arc resistance implementation result sample	31
3.15	PSCAD project settings	32
3.16	PSCAD environment after running a project	33
3.17	r.m.s. voltage	36
3.18	Pre-fault voltage	36
3.19	Pre-fault current	37
3.20	Fault voltage	37
3.21	Fault current	37
3.22	Pre-fault voltage confirmation	38
3.23	Fault voltage confirmation	39

3.24	Fault current confirmation	39
4.1	Z and X to fault percentage error against distance	43
4.2	Z and X to fault methods with no fault impedance	44
4.3	Z and X to fault methods with 5 Ω fault impedance	44
4.4	Z and X to fault methods with 25 Ω fault impedance	44
4.5	Z to fault method percentage error for different types of faults	46
4.6	Z to fault and voltage sage methods with no fault impedance	49
4.7	Z to fault and voltage sage methods with 1 Ω fault impedance	49
4.8	Z to fault and voltage sage methods with 5 Ω fault impedance	49
4.9	Z to fault and voltage sage methods with arc fault resistance	51

LIST OF APPENDICES

APPENDIX	TITLE	PAGE
A	MATLAB SOURCE CODES	57
B	DATA FILES	67

CHAPTER ONE

INTRODUCTION

1.1 Introduction

In electrical power systems, permanent faults manifest in some sort of damage that must be repaired before restoration of supply. The process of restoration can become faster if the exact fault location is known or can be estimated with good accuracy. The estimation of fault location can be achieved by fault locators that can provide estimate for both sustained and transient faults. Despite their transient nature, as the supply can be restored normally, transient faults may cause minor damage in power system element or they may be a result of power system element aging and act as early warning for permanent fault, but evidences are not easily found during inspection. Fault locators help in those locations identification for deeper inspection, early repair and corrective actions to avoid fault recurrence and prevent the consequent major damages. [1]

In transmission systems, and due to the high impact on system stability and the wider effect of faults within them, a lot of researches were performed and sophisticated instruments and methods were developed to help in identification of the faulty section and fault location and very fast and highly selective protection systems are usually installed, among these protection systems PMUs or phase measuring units achieved high accuracy faults location using either synchronised sequence measurement or synchronised phasor measurement. [2, 3]

On the other hand, fault location process in distribution systems, traditionally, did not involve any type of instruments dedicated for the fault location purpose, where visual inspection in the form of line patrolling was usually performed and sometimes line sectioning was used to reduce the inspection area if the fault sustained but no evidence found. The traditional fault location technique is not recommended as it involves switching on fault that may lead to dangerous consequences in addition to the long downtime needed to locate the fault.

Generally, fault location methods in distribution systems use a wide range of techniques that can be divided into the following four main categories [1, 4,5]

- **Traveling wave-based methods**, which are based on the traveling waves analysis, usually use time domain information for determining the location of fault by applying signal processing techniques, the high frequency components of fault generated transients are extracted and used for fault locating and it involves some sort of transformation of the measured signal such as
 1. Wavelet transform
 2. Frequency domain analysis
 3. Cross-correlation technique
 4. Clark transformation
- **Fundamental frequency voltages and currents methods**, un-like the previous category, these methods utilize the fundamental frequency voltage and current measurements to formulate equations that help in identifying the fault location.

- **Impedance-based methods**, which can be considered as part of the previous category. However, it is classified as different category as its ease of implementation made it the most popular among utilities

- **Knowledge-Based Methods**, which can be further divided into:
 1. Artificial Neural Networks.

 2. Matching Approach.

 3. Hybrid methods.

Many challenges face fault location in distribution systems summarized as follows [4]

- Fault generated signals are recorded solely at the feeding substation

- Existence of several laterals

- Non-symmetrical lines

- Highly unbalanced operation

- Time-varying loads

1.2 Problem Statement

Due to the higher dependence on electrical supply in modern life and the increasing costs of power interruption and down time caused by faults, the fault location techniques such as line patrolling and line sectioning, which were traditionally used in distribution networks became not acceptable. Many fault type and fault location methods were developed; among them, impedance-based methods are the most common, which are calculating the distance-to-fault from impedance-to-fault and the system parameters. However, in presence of fault impedance, iterations are to be made to find the most plausible solution. The presence of arcs in distribution networks is usually accompanied with permanent faults, where the accurate identification of location is essential for fast isolation and faulty element corrective action implementation.

1.3 Objectives of The Research

The research is aimed at developing a new fault location method using line impedance technique and considering the presence of arc and its resistance, which will be achieved by:

- Developing an algorithm for the detection of the presence of faults arcs from the voltage and current measurement utilising the established and tested methods.
- Developing an algorithm for estimating the arc resistance when detected utilising the established and tested methods

- Utilising the established and tested method for fault location and combine it with arc detection and arc resistance estimation methods to develop the new method.

1.4 Scope of The Research

The scope of the research is as follows:

- Building several models for radial distribution system in order to apply the method on them, starting from simple radial system with one section, adding sections effect by introducing sections with different parameters at the end of the line and finally a model for distribution systems with lateral.
- Developing the fault location method.
- Simulating several types of faults such as
 - Single phase, three phase
 - With and with-out fault resistance
 - With and with-out arcs
- Applying the measurement taken from the simulation software for each case to the developed method to estimate the fault location and the method accuracy and make comparison with other method.

1.5 Expected Contributions

The expected contributions of the successful development of the method are

- Helping in differentiating between the permanent and transient faults.
- Providing good estimate for the location of the fault, whether it has arcs or not.

1.6 Thesis Outline

The thesis will be divided into five chapters.

Chapter One covers a brief introduction and background about faults and fault location methods, the objectives, the scope and the expected contributions of the research.

Chapter Two contains the literature review on fault location methods, arc detection methods and arc resistance estimation methods.

Chapter Three discusses the methodology employed in the method development and method evaluation including the software models used and their configuration in addition to the method development and its steps.

Chapter Four covers the results presentation in tabular and charts forms added to the analysis and discussion of these result.

Chapter Five summarizes the results, state conclusion and highlight recommendations and future work suggestions.

REFERENCES

- [1] M. M. Saha, *et al.*, "Review Of Fault Location Techniques For Distribution Systems," presented at the Power Systems and Communications Infrastructures for the future, Beijing, 2002.
- [2] Z. Miao, *et al.*, "An effective fault location technique for transmission grids using phasor measurement unit," *Electrical Power & Energy Systems*, vol. 42, pp. 653-660, 2012.
- [3] C. Wang, *et al.*, "Fault location using synchronised sequence measurements" *Electrical Power & Energy Systems*, vol. 30, pp. 134-139, 2008.
- [4] J. Sadeh, *et al.*, "A new fault location algorithm for radial distribution systems using modal analysis," *International Journal of Electrical Power & Energy Systems*, vol. 45, pp. 271-278, 2013.
- [5] L. J. AWALIN, *et al.*, "Recent Developments in Fault Location Methods for Distribution Networks," *PRZEGLĄD ELEKTROTECHNICZNY*, pp. 206-212, 2012.
- [6] Y. Aslan and Ş. Türe, "Location of faults in power distribution laterals using superimposed components and programmable logic controllers," *International Journal of Electrical Power & Energy Systems*, vol. 33, pp. 1003–1011, 2011.
- [7] S. Lotfifard, *et al.*, "Voltage Sag Data Utilization for Distribution Fault Location," *IEEE TRANSACTIONS ON POWER DELIVERY*, vol. 26, 2011.
- [8] H. Mokhlisa and H. Lia, "Non-linear representation of voltage sag profiles for fault location in distribution networks," *International Journal of Electrical Power & Energy Systems*, vol. 33, pp. 124-130, 2011.

- [9] J. Mora-Flòrez, *et al.*, "Comparison of impedance based fault location methods for power distribution systems," *Electric Power Systems Research*, vol. 78, pp. 657-666, 2008.
- [10] P. Järventausta, *et al.*, "Using Fuzzy Sets to Model the Uncertainty in the Fault Location of Distribution Feeders," *IEEE Transactions on Power Delivery*, vol. 9, pp. 954–960, 1994.
- [11] R. Das, *et al.*, "A Fault Locator for Radial Subtransmission and Distribution Lines," presented at the IEEE Power Engineering Society Summer Meeting, Seattle, Washington, USA, 2000.
- [12] M. M. Saha, *et al.*, "Fault Location Method for MV Cable Network," presented at the DPSP, Amsterdam, The Netherlands, 2001.
- [13] M. B. Djuric, *et al.*, "Time domain solution of fault distance estimation and arcing faults detection on overhead lines," *Power Delivery, IEEE Transactions on*, vol. 14, pp. 60-67, 1999.
- [14] K. J. Zoric, *et al.*, "Arcing faults detection on overhead lines from the voltage signals," *International Journal of Electrical Power & Energy Systems*, vol. 19, pp. 299-303, 1997.
- [15] M. S. Mamiş and M. E. Meral, "State-space modeling and analysis of fault arcs," *Electric Power Systems Research*, vol. 76, pp. 46-51, 2005.
- [16] V. D. Andrade and E. Sorrentino, "Typical expected values of the fault resistance in power systems," in *Transmission and Distribution Conference and Exposition: Latin America (T&D-LA), 2010 IEEE/PES*, 2010, pp. 602-609.
- [17] V. V. Terzija and H. J. Koglin, "New approach to arc resistance calculation," in *Power Engineering Society Winter Meeting, 2001. IEEE*, 2001, pp. 781-787 vol.2.
- [18] V. Terzija and H. J. Koglin, "On the modeling of long arc in still air and arc resistance calculation," in *Power Engineering Society General Meeting, 2004. IEEE*, 2004, p. 88 Vol.1.

- [19] M. F. Baharom and s. Prof Mohd. Wazir Mustafa, "Effect of arc resistance in fault resistance analysis," Universiti Teknologi Malaysia, 2012.

- [20] Houman Omid and s. Prof Mohd. Wazir Mustafa, "Enhancement of fault analysis method using ARC resistance formula," Universiti Teknologi Malaysia, 2013

- [21] "PSCAD, Power Systems Computer Aided Design User's Guide," M. H. R. Centre, Ed., Version 4.2.1 ed, 2010

- [22] W. Xi-xiu, et al, "Investigate on the Simulation of Black-box Arc Model", International Conference on Electric Power Equipment, 2011

- [23] MATLAB Help.