

# New Approach for Stochastic Modelling of Microgrid Containing CHP

Mario PERIĆ, Tomislav PLAVŠIĆ, Igor KUZLE

**Abstract:** The focus in this article is on long term load forecasting and expansion generation planning of the microgrids containing multiple load type consumption. The novel approach of planning cogeneration systems by introducing the function of simultaneous heat and electricity duration is presented. The function is extended form of load duration curve in such a way as to capture the simultaneity of different type of energy load. The paper contains seven chapters. In the second chapter the load forecasting methods are summarized. In continuation as an introduction to the main goal of this article, definition, application and restriction of load duration curve is presented. In the fourth chapter, some outlines about cogeneration system planning are given. The new approach for planning of microgrid containing CHP based on probabilistic approach is presented in the fifth chapter. In the sixth chapter are demonstrated some application functions of simultaneous heat and electricity duration as a tool for planning multi energy systems.

**Keywords:** cogeneration; function of simultaneous heat and electricity duration; load forecasting; microgrid; stochastic modelling

## 1 INTRODUCTION

The technical system lifetime cycle can be divided into several phases such as Planning, Design, Constructing, Exploitation and Decommission phase. Each of these phases can be further subdivided into more sub phases. The lifetime system quality mostly depends on **planning phase** quality. Planning can be defined as *a complex intellectual process of determining system structure and operation strategy to accomplish the objectives in the future*. Planning requires knowledge about performance of the system under observation and prediction of the environment outside the system. There are numbers of scientific and engineering papers devoted to planning mostly in electric power systems both large scale and microgrids [1, 2]. *A microgrid can be defined as a low or medium voltage distribution network comprising various DGs, storage devices, and responsive loads that can be operated in both grid-connected and islanded modes* [3]. The planning phase starts with problem definition (defining customer demands, the goals, inputs, outputs, system constraints, key performance indicators, investment evaluation criteria, etc.). In most cases, technical system under planning is going to be modelled (real world is simplified and presented by various mathematical forms – models) [4]. A special planning and modelling technics are developed for such system under uncertainty [6-11]. The level of uncertainty of inputs and outputs significantly shapes models and determines the quality of planning. Unlike the large-scale power electric system, small scale system such as microgrid has dominantly uncertain outputs. Also, unlike the non-renewable power systems the renewable power systems are examples of the systems with uncertain inputs [5]. The planning of such power systems involves various stochastic modelling and simulation methods [4, 6, 7]. The survey of stochastic modelling of microgrid is presented in [14] and [15]. A powerful mathematical tool for stochastic system analysing is the Monte Carlo Methods [16, 17].

An important phase in the modelling and planning is gathering the historical data and its usage for demand forecasting [18]. In the case of the planning of power supply systems (mechanical, electricity or/and heat) the balancing between power production (supply) and power

consumption (demand) should be in generally satisfied during all lifecycle time but it is very important to optimize flows of various energy vectors [19]. In reality despite all, power flow unbalance appears. One of the planning goals is to find commercially acceptable system architecture (usually depending on commercial tariffs [20]), component size, system operation rules and control strategies considering uncertainty [21]. The reason for power flow unbalance is inherently time unbalance between capacity and demand (that is the crucial problem in power systems based on renewables and microgrids in general). The source of unbalance is of complex nature and generally it is hard to model (prediction of the sources capacity and availability as well as load demand). Prediction of both supply and demand side of the power supply system is a key element in planning phase, [13] and [20]. Power load forecasting or demand forecasting is initial and vital process of planning. The forecasting assumes that historical analysis up to some extent can reveal the future behaviour. The process of load forecasting is always being improved since power consumption generally is increasing in magnitude and variety – so one can say that certain load forecasting of several years ago is not valid any more, [18].

Planning of multi-energy system is a more demanding task than planning of single energy systems. A subject of special interest is cogeneration facilities where two useful forms of energy are produced in the **same** technological process. While production of both forms of energy is coupled, their consumption generally is not! That introduces additional dimension in a planning process: *simultaneity of energy products*. In [23] a comprehensive two-stage optimal planning for CHP microgrid is presented. The first stage is for determination of optimal type and capacity while the second one is for operation optimization [24].

## 2 LOAD FORECASTING OVERVIEW

There are several approaches for load forecasting presented in literature, [1, 18, 25-27]. Load forecasting techniques are divided into two main groups: **Statistically based** and **artificial intelligence based** methods. The first group of methods is further divided in: *Regression-based*

methods, Time-series methods, Similar-day approach, and Simulation methods.

Regression based methods (also called econometric) are used for short and mid-term load forecast. The method is based on assumption that the load depends on several external factors. The factors can be weather depending (temperature, moisture, rainfall, wind speed and direction, solar irradiation etc.) and socio-economic factors (population, GDP) [25].

Time series group of methods is dominant and the oldest method used for load forecasting. Those methods are based on presumption that load as data has internal structure which can be decomposed into one or more components (depends on forecasting horizon) such as: *trend component*, *cyclic component*, *seasonal component* and *noise* (stochastic variation). Various types of filtering are used for getting separate components of load time series [1, 25]. The simple time series method is ARMA (auto regression moving average) method, which is, based on presumption that fluctuation pattern of load can be assessed from previous measurements. ARMA model is used for short term load forecasting and in the case where time series of load data can be treated as stationary process. The method is further expended on non-stationary process introducing ARIMA methods.

Besides standard, on statistical data based methods, by the development of computational technology and efficient software algorithms, an **Artificial Intelligence – based group** of forecasting method is appearing. The following methods belong to this group: *Artificial neural networks (ANN)*, *Expert systems*, *Fuzzy logics systems*, *Support Vector Machines*, *Ant Colony*, and *Particle Swarm Optimization*. All these methods are generally based on learning process using historical data for estimation of current one [1, 25-28].

Depending on the planning horizon, there is *short term* (for units scheduling), *middle term* (for fuel type scheduling) and *long term forecasting* (for long-term system development and expansion) [18], [27]. Other references differentiate four instead of three types of load forecasting: very short (1-7 days ahead), short (1-4 weeks), medium-term (1-12 months), long term (1-20 years) [1].

### 3 LOAD DURATION CURVE, DEFINITION, APPLICATION, RESTRICTION

#### 3.1 Definition and Presentation of Load Duration Curve

Classical load forecasting approach (above-explained regression or time series) is used for short or middle term rather than for long term planning where chronological sequence of load data is less important than information about volatility across time span. The regression approach is unpractical on long scale, because of lack of available and reliable information about the external factors (temperature, wind...) used in regression formula. The weather depending factors on long scale became a stochastic value and regressions on such external factors have dominant stochastic nature. On the other side, time series approach requires an estimation of model parameters (ARMA, ARIMA, exponential smoothing). By increasing the time horizon for modelling of the load by the time series, the error of estimator (e.g. least square method) increases. Generally, the single set of model parameters

should fit the load curve over a quite different period (season). Instead of load date being described by the deterministic expressions (*load curves*, LC) for long term planning, (especially for generation expansion or reliability evaluation) a probability description of the load via *load duration curve* LDC is more practical for usage [32, 33]. By using LDC additional information about how many hours (time) of a given period loads will have at a given value [32] i.e. how the power is used in time (frequency distribution) is available [33]. In this approach load is treated as random variable [34] instead of deterministic one (obtained in regression or time series method). This approach is often used in stochastic modelling where besides the randomness of load, unpredictable behaviour of the power source as well as probabilistic nature of discrete events (such as a failure) are properly modelled [16]. A practical way of describing the cumulative distribution function (CDF) of the load as random variables ( $P_i$ ) over long period is to use inverse function of load duration curve [4, 33-35].

Load duration curve is defined as a fraction of time, the demand is greater or equal to a certain level [32, 33]. The easiest way to evaluate LDC is to plot the load demand on a system in decreasing order of magnitude over the period of interest [35, 36]. The fraction of time for a certain event (load is greater than a certain value) has meaning the probability for such event. Thus, LDC present cumulative frequency distribution of system loads. Sometimes instead of fraction of time, total time is used. In that case, LDC is time function, where time presents cumulative time when system load is greater than given load level. An example of LDC is shown in Fig. 1, [35].




Figure 1 Load curve and Load duration curve [35]

If  $p_L(t)$  is load curve function, the load duration curve  $p_D(t)$  can be mathematically expressed as follows:

$$p = p_D(\tau) : \forall p \in (p_{L, \min}, p_{L, \max}); \tau = \int_{t=0}^T \chi(t, p) dt. \quad (1)$$

$$\text{Where } \chi(t) = \begin{cases} 1 & p_L(t, p) > p \\ 0 & \text{otherwise} \end{cases}$$

Alternative presentation of LDC is as fraction of time as a function of load level  $\tau = p_D^{-1}(p)$ . Actually, that is inverse function of (1) were time is replaced by value of fraction of total time (time horizon under consideration). The function directly corresponds to cumulative

distribution function of the load random variable (2). Relation between alternative presentation of LDC and CDF of load as a stochastic value is presented in Fig. 2.




Figure 2 a) and b) Alternative presentation of LDC, c) CDF of  $P_t$

From above elaboration, it can be written:

$$F_{P_t}(p) = 1 - \frac{p_D^{-1}(p)}{T}. \quad (2)$$

Mathematical expression in (1) is more symbolic than practical guide for getting an exact analytic form of the LDC. In several papers, a various estimation (approximation) method for analytic form of LDC are explored. Unlike the load curve, the load duration curve is much easier for approximation. In [21] an example of forecasting of LDC is described. As a first step load time series  $X_t$  are forecasted. Instead of modelling  $X_t$  directly logarithmic transformation of  $Y_t = \log(X_t)$  is modelled as Gaussian structural time series [21]. Using such approach a smooth analytic LDC is forecasted by a weighted sum of transformed normal distribution functions.

Similar approach is in [34] where MONA (mixtures of normal approximation) technique is used for approximation of load duration curve. The approximation is based on the segmentation of load range into load classes ( $k = 1, 2, \dots, K$ ). For each class parameters of corresponding normal distribution is evaluated. Approximation of LDC by MONA technique is as follows:

$$\xi(p) = \frac{\tau(p)}{T} = \frac{p_D^{-1}(p)}{T} = 1 - \sum_{k=1}^K \omega_k \Phi(p, \mu_k, \sigma_k). \quad (3)$$

Where  $\xi(p)$  is alternative presentation of LDC,  $\Phi(p, \mu_k, \sigma_k)$  is normal cumulative distribution function, corresponds to fraction of time,  $\mu_k$  and  $\sigma_k$  are mean and variance respectively for  $k$  class of load.

In [35] the LDC is approximated by Hills function which commonly used in biochemistry and ecology. It was originally put forward by Archibald Hill in 1910 to cover the dissociation curves of hemoglobin. Hill functions is generally representing by (4). The model parameters  $a$ ,  $b$ ,  $c$  and  $m$  in (4) are estimated by Levenberg-Marquardt method. [34]

$$y = a + \frac{bx^m}{c^m + x^m}. \quad (4)$$

There are many other attempts for approximation of LDC by appropriate analytic curve, such like fifth order polynomial function across several times blocks in the year (mostly four) which is also used in WASP program package or combination of exponential function to capture

LDC [31]. All above presented techniques results in mathematically well defined function representing a smooth curve as continuous approximation for LDC.

By the rising of computational capability, the number of parameters describing the LDC function became less relevant factor. Normally, LDC can be easily derived out from the series of recorded value of load across the time horizon in a way that load data are reordered by the decreasing value. Since the load is usually recorded on hourly basis, thus both LC and LDC vector contains 8760 data on one year horizon. That huge number of data involve more detail than is merited in planning models. So, LDC are generally approximated over the year by a finite number (much less than 8760) of average loads [32]. In such a discrete approximation, a time span is divided into  $N$  time segments. Approximation assumes that load value across each time segment is constant and equal to total energy consumed per time segment divided by duration of time segment. In many application of LDC discrete approximation is good enough. A further improvement of discrete approximation of LDC is piecewise linear function where LDC in each time segment is replaced by linear function. The time duration of certain segments should be chosen such that load share of all types of generation (peak, intermediate, base) is well presented [33]. Determination of the number of time series and duration of each segments is special challenging task in such approximation.

### 3.1 Usage of Load Duration Curve

Load duration curve directly brings crucial information about how power is used in system, such as total energy consumed, both maximum and minimum load value across a time span. LDC is vital part production simulation, generation expansion (long term planning) reliability evaluation and electricity market analysis [1, 36, 37].




Figure 3 Simulation by inverse transform method

Since LDC is form of cumulative distribution of load, it can be used for load simulation in the Monte Carlo method in the case where reliability or financial indices cannot be simple derive out using an analytic platforms. The simulation is based on the facts that inverse cumulative distribution function of uniformly distributed random variable is distributed on the same way as random variable which cumulative distribution is subject of interest. The method is called *inverse transform sampling* (ITS) [38-41], (5), Fig. 3.

$$x \leftarrow F_{X_i}^{-1}(u). \quad (5)$$

Where  $u$  is uniformly distributed random number on interval  $[0, 1]$ ,  $X_i$  random variable of interest and  $F_{X_i}$  distribution function of that random variable. Operator  $\leftarrow$  denotes "distributed as".

The Method has certain restriction related to inverse transform of distribution function. The issue can be involving LDC (or CDF) approximation (linear, polynomial, MONA or numbers of other approximation technique).

Most common usage of LDC is determination of optimal power technology as an initial stage of expansion planning known as a *Screening curve method* [12, 21, 29], Fig. 4. In that phase, the best candidate or plant alternatives are selected as an entry for the second phase of planning where candidates are being compared regarding certain criteria. The method is based on the operating cost function of various power production technology. Each technology is presented via function of total cost regarding capacity factor (or total time of usage) [30]. The total cost functions are linear functions which intersections divide the total load area into sections. Each section corresponds to certain power production technology ( $PT$ ) with the lowest total cost.




Figure 4 Screening Curve Method

Besides LDC provides important measures of reliability such as the loss of load probability and expected unserved demand [18]. Also, LDC is very often used in power system simulation based on probability where availability of production resources is combined with the load forming equivalent load [1, 4, 13, 16, 22]. Analysing load duration curve of equivalent load several power system indices can be derived out such as: loss of load probability (LOLP) and expected energy not supplied (EENS).

#### 4 PLANNING OF COGENERATION SYSTEMS

The focus of this article is on long term load forecasting for expansion generation planning of the microgrids containing multiple load type consumption. Cogeneration is simultaneous generation of two different useful energy forms from single primary energy source. In this article, cogeneration of electricity and heat is

considered. In that case cogeneration is also called combined heat and power production (CHP). Unlike utility based power supply, electricity and heat supply from the microgrid cogeneration system is strictly site related process. The exemption are large cogeneration plants for district heating.

Planning of cogeneration system is similar to one-energy form generation system, but with remarkable difference, certain rate of **simultaneity** of both production and consumption of both energy components should be taken into consideration. Generally, cogeneration facility always involves generation mix of different ways for electricity or heat supply (or production), Fig. 5.




Figure 5 Diagram of microgrid electricity and heat supply system

Having in mind complexity of microgrids with CHP, integrated resources planning (IRP) should be applied. The aims of IRP are identifying an optimum energy supply mix between a simultaneous electric/thermal production system and utility energy supply [41]. Planning of microgrid is more challenging issue than planning other utility connected supply system. Considering both stand-alone (SA) and grid connected (GC) mode of operation of microgrid with CHP and different type of electrical and heat loads that may be employed, it is impossible to maintain simultaneous balance in both form of the energy consumed by using CHP only. Certain level of unmatched load will appear and that may have an impact on operational cost due loss of production or due the cost of alternative supply system (from the utility or the storage).

There are several factors, which influence the microgrid planning. The most important is *heat to power ration (HPR)*. Traditional approach for planning of stand-alone cogeneration facility is based on *HPR* as selection criteria (for certain time slot *HPR* of CHP should match with the *HPR* of microgrid loads). Typical *HPR* of certain cogeneration technology is presented in Table 1, [42].

Table 1 *HPR* of different cogeneration technology

Cogeneration systems	<i>HPR</i>	Overall efficiency (%)
Back-pressure ST	14	84-92
Condensing ST	2-10	60-80
Gas turbine	1.3-2	70-85
Reciprocating engine	1.1-2,5	75-85

The load characteristic can also be quantified via *HPR* factor. *HPR* vary between different types of the microgrid application. Typical *HPR* for industrial microgrid is presented in Tab. 2.

*HPR* may vary during different times of the day and seasons of the year. To extend the range of application, several engineering methods is used to modify *HPR* of



given cogeneration facility such as: additional firing (increase  $HPR$ ) or, combining of different technology (gas turbine + steam turbine or ORC to decrease of  $HPR$ ).

**Table 2**  $HPR$  variation in industry

Industry	$HPR$
Breweries	1.1 – 4.5
Pharmaceuticals	1.5 – 2.5
Fertilizer	0.8 – 3.0
Food	0.8 – 2.5
Paper	1.5 – 2.5

*Quality of heat* (temperature and pressure of transferring media) is another important factor which strongly influence to microgrid planning. Unlike the electricity, which can be easily and efficiently transforms across the wide range of use (AC, DC, different voltage and frequency) available heat (e.g. waste heat of engine) cannot so easily being used for given heat load (free heat transfer goes from higher to lower temperature only).

*The load matching principle* is also important influencing factor. Depending on the type of the load and application, the planning may be based on electric load or heat load matching. In case of bottoming cycle, CHP is used to meet local need for heat at first. Deviation in electric power supply is settled via utility or other back up power supply or storage. In case of topping cycle the loading, priority is inversed and deviation in heat supply is settled via additional boiler or heat storage.


## 5 PLANNING OF MICROGRID CONTACTING CHP BASED ON PROBABILISTIC APPROACH

Planning based on  $HPR$  criteria is simple and fast for rough analysis of application certain cogeneration technology in given microgrid, which contain both electric and thermal load, especially in SA mode of operation. The method assumes **that  $HPR$  of the load does not change** or have small variation in each time slot or correlation between heat and electricity is strong. In reality, the microgrid contain several types of electrical or heat devices or devices which consume both energy form in same time where the heat load does not follow electricity load so strictly ( $HPR$  vary trough the time in wide range) or does not have a known pattern. The variety of the load, as well as the availability of the production unit on macro scale is further emphasized on micro scale – microgrid. So the planning of the microgrid containing both heat and electricity load cannot be based on load duration curves for heat or/and electricity only. Figs. 6 and 7 present two examples (I and II) of time series of heat and electricity respectively. For the sake of illustration, grid connected mode of microgrid is assumed where the deviation in electricity supply is settled via utility and for heat via additional heat source. In addition, it is assumed the loading follow heat priority principle.


Fig. 7 presents the same load profile for heat and the different one for electricity load presented in Fig. 6. In both cases, the load duration curves for both heat and electricity demand are the **same**.

As can be concluded from the Fig. 6 and Fig. 7 the same load duration curves and  $HPR$  index on given time slot, do not produce the same performance of certain CHP. To capture this occurrence, the load demand and unit's

capacity should be compared in the same space and manner where the time interdependence of load and CHP capacity is properly treated. As it was emphasized in chapter 3.1., for long term analysis of microgrid, stochastic simulation and analysis is more appropriate then deterministic approach as it was proposed in [13-17, 22, 29, 32, 38, 44-51]. Once developed stochastic models for loads, power supply system various reliability analysis, sizing, optimization of operation and control of microgrid can be performed using a powerful tool such as Monte Carlo Method [14, 40, 41].



**Figure 6** An example I of time series of heat and electricity



**Figure 7** An example II of time series of heat and electricity

In following subchapters, a new approach for stochastic modelling of both load and power production as well as its usage in stochastic analysis is described.

### 5.1 Stochastic Model of Two-Dimensional Load

From the reason explained in chapter 3.1., stochastic model of load demand vector of the certain microgrid  $L_{E,H} = (e, h)$  is more appropriate than time series format. In that case  $L_{E,H}$  is two-dimensional random vector, presented by its load probability density function  $LPDF_{E,H}$ . Many authors, like [45-51], used this approach. The meaning of  $LPDF_{E,H} = f_{E,H}(e, h)$  of random energy vector  $L_{E,H}$  (heat, electricity) is defined by (6).

$$f_{E,H}(e,h)d edh = P[E \in (e, e + de), H \in (h, h + dh)]. \quad (6)$$

Based on given  $LPDF_{E,H}$  and outage rate of individual energy sources, the equivalent load probability density function  $ELPDF_{E,H}$  is calculated [45, 47-50]. The  $ELPDF$ 's present alternative load probability functions where random outage of the source unit has been considered. Once  $LPDF$ 's and/or  $ELPDF$ 's are known in **analytic form**, a various availability indicators such as Loss of Load Probability ( $LOLP$ ), Expected unserved energy ( $EUE$ ) and others [1, 6, 45, 49, 50] can be calculated by analytic integration.

The analytic form of  $LPDF_{E,H}$  plays crucial role for stochastic analysis CHP in general. Special challenge is appropriate approximation of  $LPDF$  from raw date to get appropriate analytic and ease to integrate form.

The  $LPDF$  gotten from recorded data is rather "spikey" than smooth curve so large errors in approximation can be expected. Furthermore, integration of such function to get certain expected figure of merits became quite difficult.

Instead of  $LPDF_{E,H}$  cumulative distribution function of two dimensional energy vector  $CDF_{E,H}$  is proposed as basis of stochastic analysis. Moreover, this approach is based on two **graph-analytic** analogies with power only system) LDC to CDF analogy explained in the chapter 3.2 and b) the analogy of the value of the surface below the CDF and value of expected value energy used.

Since multi-dimensional nature of the energy vector under consideration, it is impractical to use a term "curve" so the term "**function of simultaneous heat and electricity duration**" ( $FSD_{E,H}$ ) is proposed.

$FSD_{E,H}(e, h)$  is two dimensional function of electricity and heat with the meaning of total number of hours in corresponding time range where electricity load demand is greater than given value  $e$  and heat load demand is greater than given value  $h$ . Note that one-dimensional load duration curve (LDC) mostly used in form offunction of time  $p = p_D(\tau)$ , while  $FSD_{E,H}$  is alternative presentation as function of energy vector (7).

$$\tau = T_{E,H}(e, h) = \int_{t=0}^T \omega(t, e, h) dt; \quad (e, h) \in LR. \quad (7)$$

$$\text{Where } \omega(t, e, h) = \begin{cases} 1 & \text{if } p_E(t) > e \text{ } p_H(t) > h \\ 0 & \text{otherwise} \end{cases} \text{ and } LR$$

$= \{(E_{\min}, E_{\max}) \times (H_{\min}, H_{\max})\}$  is load range in  $E-H$  space, Fig. 8.

The function of  $FSD_{E,H}$  presents *stochastic description* of given two-dimensional load demand on certain location. Obviously, such characteristic can be presented via surface in  $E-H$  space.  $FSD_{E,H}$  can be derived out from the recorded data and appropriate approximation.

### 5.2 Determination and Approximation of $FSD_{E,H}$

The procedure goes in several steps as follows:

**First step** is collecting a data regarding heat and electricity on given location during a certain time span, e.g. a year. For the sake of long-term analysis, at least hourly average value for electricity and heat is recommended. Very often, the load data for electricity and heat was count

separately. Thus, a certain form of data synchronization is needed. The raw data should be prepared and written in a form of load matrix  $L_{3 \times K} = \{(t_k, e_k, h_k); k = 1, 2, \dots, K\}$ , where  $t_k$ , are corresponding time interval of length  $\Delta T(h)$ ,  $e_k$  and  $h_k$  are average load of electricity and heat in that time interval. All data can be also presented as a dots in set of recorded data  $S_r = \{(e_k, h_k), k = 1, 2, \dots, K\}$  in  $E-H$  space, Fig. 8.

**Second step.** The load range  $LR$  is divided into **load subranges** ( $LR_{p,q}$ ):

$$LR_{p,q} = \{(E_{\min} + p dE, E_{\max}) \times (H_{\min} + q dH, H_{\max})\}. \quad (8)$$

Where  $p$  and  $q$  are integers in range  $(1, N)$ ,  $N$  is the fineness of approximation. Note that  $N \ll \sqrt{K}$ . Further  $dE$  and  $dH$  are load increments:  $dE = (E_{\max} - E_{\min})/N$ ;  $dH = (H_{\max} - H_{\min})/N$ .

**Third step.** For each  $p$  and  $q$  to determine subset  $S_{p,q}$  which contain a records  $(e_k, h_k)$ , which fulfil the following conditions:

$$S_{p,q} = \{(e_k, h_k), k = 1, 2, \dots, K : e_k \geq E_p \wedge h_k \geq H_q\}. \quad (9)$$

Where  $E_p = E_{\min} + p dE$  and  $H_q = H_{\min} + q dH$  presents starting coordinates of  $LR_{p,q}$  subrange, Fig. 8.

**Forth step.** Determination of the number of elements  $C_{p,q}$  in each subset  $S_{p,q}$ ;  $C_{p,q} = \text{card}(S_{p,q})$  and formation of a matrix  $T_{p,q} = \frac{1}{\Delta T} C_{p,q}$ . The values in  $p$  row and  $q$  column of the matrix present a total time of simultaneous duration of electricity and heat load above  $E_p$  and  $H_q$  value respectively.





Figure 8 Recorded data in load range, E-H space

By appropriate selection of number  $N$  according to total recorded data, every load vector  $(E, H)$  can be approximated with  $(E_p, H_q)$ , so it can be concluded that  $T_{p,q}$  is approximation of  $FSD_{E,H}$  in  $E-H$  space. For the sake of demonstration of the new approach, the load data for electricity and heat consumption in one industrial microgrid in time range July 2015 up to May 2016 are collected and used for evaluation function of simultaneous heat and electricity duration, Fig. 9.


 Figure 9 An approximation  $FSD_{E,H}$ 

### 5.3 Model of CHP device in $E$ - $H$ space

In CHP device, the rate of produced heat and electricity are strongly correlated. The correlation function can be presented by following form of HPR expression.

$$h = e \cdot HPR(f, T_{amb}, y, t, Constraints). \quad (10)$$

Where  $h$  and  $e$  are value of produced heat and produced electricity respectively. Generally,  $HPR$  depends on several parameters. Depending on the type of CHP units, the  $HPR$  is independent from a rate of partial load  $f$  in most of range of its value. Partial load  $f$  corresponds to level of fuel flow. At low partial load values the HPR function swings toward to certain point  $(0, H_r)$  Fig. 10a. That is because of very low electricity efficiency at small partial load level. In most cases, operation of CHP unit below certain partial level is not recommended.

Ambient temperature  $T_{amb}$  has a non-neglecting influence on CHP performance. There are common rules that electric efficiency decrease and thermal efficiency increase by the increase of air temperature of CHP unit. Consequently,  $HPR$  increase with ambient temperature. For the sake of demonstration, in this article the temperature dependency will be neglected.

Besides fuel control, the values of produced heat can be controlled by flow control of heating inter-media (like in extraction steam turbines based CHP) or by control of the flow of media for heat removal (like in gas engine or gas turbine based CHP). In some cases, electricity is also affected by this way. Such control is represented by non-dimensional value  $y$ . If there are more than one control options,  $y$  became a vector, Fig. 10b.

The performance of CHP also depends on the state of thermal engine: cold or hot state. That is represented by the time in operation  $t$  from cold condition. Running in cold state is operation under poor efficiency and high operational cost unless of running in hot state. For the sake of simplicity and demonstration of the CHP unit modelling this feature can be neglected in long term planning.

There are several *constrains* to be taken into consideration when CHP unit is under planning for certain microgrid. First of all, **technical constrains** are related to prevention severe damage caused by overheating either thermal units (turbines, engine, pipes and other thermal installation) or generators (overcurrent). Technical

constrains are represented by  $E_{max}$  and  $H_{max}$ . Besides there are **economical constrains** which are related to minimal partial load at which the operational costs are too high (poor efficiency). At the end, there are **legal constrains** which are related to the limits defined by legal authority such as limitation of emission or limitation for liable producer (e.g. primary energy saving rate > 10%).

Depending on variables and constrains explained above, the correlation of the produced heat and produced electricity can be presented as an **area of points**  $(h, e)$  in  $E$ - $H$  space, where each point presents allowable working condition, which can be reached by certain control. This area is called **working area (WA)** or area of feasibility operation [45, 47, 48, 52-55], Fig. 11.

The shape of WA can vary from straight line for simple CHP unit up to complex non-convex area. Fig. 11.b presents an example of WA of the CHP system containing extraction steam turbine. Where  $f$  presents the rate of fuel consumption and  $y$  presents the rate of steam extraction.





Figure 10 a) Types of Working area a) single curve in case without of flow control heating media; b) in case of flow control of heating media


 Figure 11 Presentation of Working area: a) as a set of  $(e, h)$ ; b) family of line  $h = e \cdot HPR(y, f)$ 

The working area is used to established limitation for  $e$  and  $h$  at various optimizations algorithm (11), (12), [49].

$$E_{min}^{chp}(h) \leq e \leq E_{max}^{chp}(h). \quad (11)$$

$$H_{min}^{chp}(e) \leq h \leq H_{max}^{chp}(e). \quad (12)$$

The function  $E_{min}^{chp}(h)$ ,  $E_{max}^{chp}(h)$ ,  $H_{min}^{chp}(e)$ ,  $H_{max}^{chp}(e)$  in (11) and (12) are determined by the boundary of working area, Fig. 12a. In such approach, working area is treated as a set of points  $(h, e)$  in  $E$ - $H$  space bordered by several boundary lines. This approach is preferable at short-term optimizations and economic dispatching. The alternative approach, more suitable for long term CHP planning in combination with  $FSD_{E,H}$ , is to treat the WA as a family of line  $h = e \cdot HPR(y)$ , Fig. 11b.

## 6 USAGE OF FUNCTION OF SIMULTANEOUS HEAT AND ELECTRICITY DURATION

In Chapter 5.1 the presentation of the multiple load for given period through the duration function giving the information about amplitude and frequency of occurrence of certain load level was described. Such presentation,  $FSD_{E,H}$  function, can be used for sampling the stochastic value of electricity and heat load. Following the analogy with the power-only load duration function and sampling in chapter 3.2, the inverse transform sampling (ITS) method can be applied on  $FSD_{E,H}$  too. Generally, such approach assumes analytic form of two-dimensional distribution and its inverse function what can be demanded task even for power-only system.

In case of two-dimensional distribution presented by  $FSD_{E,H}$ , the value of the distribution are **only known** in the nodes of the mesh created by discrete value of  $E_p$  and  $H_q$ , where  $p, q = 1, 2, \dots, N$ .

The creation of the analytic form of the  $FSD_{E,H}$  means determination continues two dimensional function which best describes (interpolates) the value of  $FSD_{E,H}$  in whole load range based on the discrete value in mesh of nodes  $S_{p,q}$  in (9). For similar purpose, in case of determination of the distribution function, the interpolation by some well-known distribution is very often used [17, 18, 31, 34]. For the sake of robust and fast stochastic analysis of the microgrid the piecewise linearization is suggested.

The value of the  $FSD_{E,H}$  in arbitrary point  $T(e, h)$  can be determined by known values in subsequent nodes of  $S_{p,q}$  as follows:

$$T(e, h) = \frac{1}{dE} \begin{bmatrix} E_{p+1} - e \\ e - E_p \end{bmatrix}^T \begin{bmatrix} T_{p,1} \\ T_{p+1,1} \end{bmatrix} \quad (13)$$

In case of  $e_p < e < e_{p+1}$ ;  $h = h_1$ ,  $1 < p < N$

$$T(e, h) = \frac{1}{dH} \begin{bmatrix} H_{q+1} - h \\ h - H_q \end{bmatrix}^T \begin{bmatrix} T_{1,q} \\ T_{1,q+1} \end{bmatrix} \quad (14)$$

In case of  $e = e_1$ ;  $h_q < h < h_{q+1}$ ,  $1 < q < N$

$$T(e, h) = \frac{1}{dEdH} \begin{bmatrix} E_{p+1} - e \\ e - E_p \end{bmatrix}^T \begin{bmatrix} D_{p,q} \\ \end{bmatrix} \begin{bmatrix} H_{q+1} - h \\ h - H_q \end{bmatrix} \quad (15)$$

In case of  $E_p < e < E_{p+1}$ ;  $H_q < h < H_{q+1}$ ;  $1 < p < N$ ;  $1 < q < N$ ; where  $D_{p,q} = \begin{bmatrix} T_{p,q} & T_{p,q+1} \\ T_{p+1,q} & T_{p+1,q+1} \end{bmatrix}$ ;

$$T(e, h) = 0 \quad (16)$$

In case of  $e = E_N$  or  $h = H_N$ .

Note that (13) presents marginal distribution for electricity with alternative notation  $T_E(e) = T(e, h = h_1)$  while (14) presents marginal distribution for heat  $T_H(h) = T(e = e_1, h)$ .

## 6.1 Heat and Electricity Sampling

Since the function of simultaneous heat and electricity duration  $FSD_{E,H}$  has the meaning of heat and electricity distribution where the interdependency between these two system variables are **properly** described, it can be used for heat and electricity sampling. Such obtained pseudo random system variables (load) is input set for stochastic simulation. The procedure of heat and electricity sampling using  $FSD_{E,H}$  and its numerical approximation is shown in Fig. 12.




Figure 12 Heat and Electricity sampling by  $FSD_{E,H}$

### Sampling procedure:

1. Two independent, uniformly distributed, random variables  $u_1$  and  $u_2$  was sampled;
2. Scaling of uniformly distributed random variable for heat distribution by using  $u_1$

$$t_1 = u_1 T(e, h)_{\max} \quad (17)$$

3. Sampling of heat load according to marginal distribution of heat distribution:

$$h_{\text{sampl}} = T_H^{-1}(t_1) = \frac{1}{T_{\hat{q}+1} - T_{\hat{q}}} \begin{bmatrix} T_{\hat{q}+1} - t_1 \\ t_1 - T_{\hat{q}} \end{bmatrix}^T \begin{bmatrix} H_{\hat{q}} \\ H_{\hat{q}+1} \end{bmatrix} \quad (18)$$

Where  $\hat{q}$  satisfy inequality  $T_{\hat{q}} < t_1 < T_{\hat{q}+1}$ .

4. Determination of conditional electric load distribution:  $T_{E|h_{\text{sampl}}}(e)$ , using (15) with substitution  $h = h_{\text{sampl}}$ ;

5. Determination of inverse function  $T_{E|h_{\text{sampl}}}^{-1}(t)$ :

$$T_{E|h_{\text{sampl}}}^{-1}(t) = t \frac{dEdH}{b-a} + \frac{E_p b - E_{p+1} a}{b-a} \quad (19)$$

Where  $a = T_{p,\hat{q}}(H_{\hat{q}+1} - h_1) + T_{p,\hat{q}+1}(h_1 - H_{\hat{q}})$ ,  
 $b = T_{p+1,\hat{q}}(H_{\hat{q}+1} - h_1) + T_{p+1,\hat{q}+1}(h_1 - H_{\hat{q}})$  and  $h_1 = h_{\text{sampl}}$ .

6. Scaling of uniformly distributed random variables for conditional electric distribution.

$$t_2 = u_2 T_{E|h_{\text{sampl}}}(e)_{\max} \quad (20)$$



7. Finally, by substitution  $t = t_2$  in (19), the sampled electric load is obtained.

$$e_{\text{sampled}} = t_2 \frac{dEdH}{b-a} + \frac{E_p b - E_{p+1} a}{b-a}. \quad (21)$$

Alternative procedure is similar to above explained with the difference that electric load is sampled at first and then heat load.

## 6.2 Calculation of Total Heat and Electricity Energy Produced in Cogeneration Process

Besides of the application for heat and electricity load sampling, the approximation of  $FSD_{E,H}$  is used for determination of total heat and electricity energy produced in certain cogeneration facility. The procedure is based on combining the working area of certain cogeneration facility and  $FSD_{E,H}$  in the same  $E-H$  space, Fig. 13.




Figure 13 Heat and Electricity sampling by  $FSD_{E,H}$

Let assume that working area is presented as a set of family of line  $h = e \cdot HPR(y)$ , Fig. 11, where  $y$  is heat control vector (e.g.: rate of steam extraction in case of cogeneration based on extraction steam turbine). There is certain trade-off between operational cost and rate of heat control. In most cases the least cost per produced energy is at  $y = 1$ . Other heat control, if are required often, leads to higher cost and lower efficiency).

If  $y$  is assumed as fixed value, heat and electricity production are generally linked by linear  $HPR$  correlation:

$$h = ke + r; E_{\min}^{chp} \leq e \leq E_{\max}^{chp}; H_{\min}^{chp} \leq h \leq H_{\max}^{chp}. \quad (22)$$

Where  $E_{\min}^{chp}$ ,  $E_{\max}^{chp}$ ,  $H_{\min}^{chp}$ , and  $H_{\max}^{chp}$  are limitation of CHP unit. In Fig. 14 the  $FSD_{E,H}$  of certain load and Working area/line are presented. When the working area is projected on the  $FSD_{E,H}$  surface, certain curve  $\mathcal{H}_C$  is obtained. **That curve represents the rate of heat and electricity load to be satisfied by single cogeneration unit.** Index C means that the rate of simultaneous heat and electricity load feed by single cogeneration unit depends on the way of heat control.

The practical meaning of the applied procedure is when curve  $\Psi_C$  is mapped on the heat and electrical marginal distribution plane  $T_E(e)$  and  $T_H(h)$  respectively. The curves  $\Psi_{C|H}$  and  $\Psi_{C|E}$  presents distribution function of for heat and electricity produced in certain cogeneration unit (system) and used in certain consumption area (microgrid). The surface below the curves represents the value of both heat and electricity energy supplied by the unit.

The curve  $\Psi_C$  can be determined as orthogonal mapping of the heat to electricity curve (HPR) of cogeneration unit (22) on the surface of  $FSD_{E,H}$  (13)-(16):

$$\Psi_C = \left\{ \begin{array}{l} T(e, h) = a_{p,q} + b_{p,q}e + c_{p,q}h + d_{p,q}eh \\ 0 = h - ke - r \\ e \in \langle \max(E_{\min}, E_{\min}^{chp}), \min(E_{\max}, E_{\max}^{chp}) \rangle \\ h \in \langle \max(H_{\min}, H_{\min}^{chp}), \min(H_{\max}, H_{\max}^{chp}) \rangle \end{array} \right\}. \quad (24)$$

Where  $T(e, h)$  is (15) rewritten in canonical form with following coefficients:

$$a_{p,q} = \frac{1}{dEdH} \begin{bmatrix} E_{p+1} \\ -E_p \end{bmatrix}^T [D_{p,q}] \begin{bmatrix} H_{q+1} \\ -H_q \end{bmatrix}, \quad (25)$$

$$b_{p,q} = \frac{1}{dEdH} \begin{bmatrix} -1 \\ 1 \end{bmatrix}^T [D_{p,q}] \begin{bmatrix} H_{q+1} \\ -H_q \end{bmatrix}, \quad (26)$$

$$c_{p,q} = \frac{1}{dEdH} \begin{bmatrix} E_{p+1} \\ -E_p \end{bmatrix}^T [D_{p,q}] \begin{bmatrix} -1 \\ 1 \end{bmatrix}, \quad (27)$$

$$d_{p,q} = \frac{1}{dEdH} \begin{bmatrix} -1 \\ 1 \end{bmatrix}^T [D_{p,q}] \begin{bmatrix} -1 \\ 1 \end{bmatrix}. \quad (28)$$

Also, matrix  $D_{p,q}$  are according to (15). Since  $T(e, h)$  is defined on the whole area for each combination of indexes  $p$  and  $q$ , the  $\Psi_C$  depends on  $p$  and  $q$  which are now functions of the value of electricity power or heat. To avoid confusion, they will be written as  $p'$  and  $q'$ :

$$p' = p(e) = INT \left( \frac{e - E_{\min}}{\Delta E} \right), \quad (29)$$

$$q' = q(e) = INT \left( \frac{ke + r - H_{\min}}{\Delta H} \right). \quad (30)$$

here INT is function which rounds an argument down to the nearest integer. By (29) and (30) and for a certain CHP unit a particular Unit - Load subrange (ULS) as a subset of Load Range LR is created (yellow rectangle in Fig. 15).

Solving (24) by heat value  $h$  the curve  $\Psi_{C|H}$  is obtained. On the other hand, when (23) is solved per electricity value  $e$ ,  $\Psi_{C|E}$  can be determined (29), (30).

$$\Psi_{C|E}^{p',q'} = \alpha_{p',q'} e^2 + \beta_{p',q'} e + \gamma_{p',q'}, \quad (31)$$

$$\Psi_{C|H}^{p',q'} = \delta_{p',q'} e^2 + \varepsilon_{p',q'} e + \theta_{p',q'}. \quad (32)$$

Where

$$\alpha_{p',q'} = kd_{p',q'}, \quad (33)$$

$$\beta_{p',q'} = b_{p',q'} + kc_{p',q'} + rd_{p',q'}, \quad (34)$$

$$\gamma_{p',q'} = a_{p',q'} + rc_{p',q'}, \quad (35)$$

$$\delta_{p',q'} = \frac{d_{p',q'}}{k}, \quad (36)$$

$$\varepsilon_{p',q'} = \frac{b_{p',q'}}{k} + c_{p',q'} - \frac{d_{p',q'}r}{k}, \quad (37)$$

$$\theta_{p',q'} = a_{p',q'} - \frac{b_{p',q'}r}{k}. \quad (38)$$




Figure 14 Overlap of CHP Unit Working area and Load Range

Also,  $p'$  and  $q'$  are determined by (29) and (30). Visual explanation is given in Fig. 14.

Finally, the amount of electricity produced by certain cogeneration unit and used in consumption area on yearly basis can be determined by integration of  $\Psi_{C|E}^{p',q'}$  on the range  $E_{min}^{chp}, E_{max}^{chp}$ :

$$\sum_{ULR_{p',q'}} \left( \frac{\alpha_{p',p'}}{3} e^3 + \frac{\beta_{p',p'}}{2} e^2 + \gamma_{p',p'} e \right) \Big|_{e_b}^{e_f}. \quad (39)$$

Where,  $e_f$  and  $e_b$  are the value of the electricity on the edge of Unit Load Subrange  $ULR_{p',q'}$ . In similar way, the amount of heat produced can be determined (by the integration of  $\Psi_{C|H}^{p',q'}$  on the range  $H_{min}^{chp}, H_{max}^{chp}$ ).

### 6.2 Calculation of CHP Potential in Grid Connected and Stand-Alone Mode of Operation of Microgrid

Without going in deeper elaboration, a method presented in 6.2 can be used for evaluation of efficiency of usage of certain CHP. Previously described method, brings the capacity of certain CHP unit in simultaneously production of electricity and heat in stand-alone mode without any storage capacity on the site.

In case of grid connected mode of Microgrid operation or in stand-alone with some energy storage, a certain amount of heat or electricity can be taken over or delivered aside of local consumption.

The procedure starts with mutually mapping of marginal distributions  $T_E(e)$  and  $T_H(h)$  on the opposite planes, Fig. 15:

$$T_{C|H}(e) = T_H(h(e)), \quad (40)$$

$$T_{C|E}(h) = T_E(e(h)). \quad (41)$$

Where  $h(e)$  is HPR correlation in general form.

Four characteristic area are obtained:

Area **A** is the amount of energy simultaneously produced and used in local area (stand-alone, no storage capacity of CHP, (39)).

Area **B** is the amount of energy, which cannot be produced in CHP unit because of power of load, exceeds maximum capacity of CHP unit or it is below the technical minimum of CHP unit. That amount should be purchased in any other way or it presents amount of the loss.

Area **C** corresponds to potential additional amount of heat or electricity produced above the amount of **A** in case the CHP production follows electricity or heat load respectively. That amount presents the surpluses which need to be delivered to utility or storage.

Area **D** presents the amount of heat or electricity missing for direct load of local consumption in island mode of operation.




Figure 15 CHP potential in Microgrid in Stand-alone mode

Finally,  $B + D$  is gross value of directly not-supplied energy from the CHP unit to the local consumption and  $B + D - C$  is net shortage or surplus in grid connected mode or stand-alone mode with hypothetical infinite storage.

## 7 CONCLUSION

Planning is initial phase of each life cycle of certain technical system. It determines main figures such as system structure and operation strategy. Small power system containing multi-energy load and as well distributive generation operable in both grid connected and stand-alone mode – microgrid, is special concern of planning. The quality of various planning method in most cases depends on the quality input data. Load forecasting is vital part of each planning analysis, especially where stochastically nature of load is emphasized (what is the case in microgrids). Besides of load curves, which is often used as a form of load representation, a load duration curve is also used when stochastic nature of the load need to be captured. By the using of LDC instead of LC some additional information, such as frequency distribution of the load, are available at planning.

Planning of the microgrid containing cogeneration facility is demanded task since both mode of operation and emphasized unpredictability of the load should be taken into consideration. Various stochastic model has been developed for such purpose. The article derived out a new approach in stochastic modelling of microgrid, which is equipped with cogeneration facility. The approach is based on the function of simultaneous heat and electricity duration given by bilinear interpolation of load date and appropriate presentation of the two-dimensional characteristic of the cogeneration units in the same space. Such approach can be used for numerical evaluation of the capacity of certain cogeneration unit in given load conditions on long-term basis. Besides, heat and electricity sampling can be easily derived out using such two-dimensional distribution function.

In further research, the described approach can be used for various efficiency evaluation and optimization methods of CHP unit used in microgrid.

## 8 REFERENCES

- [1] Elkarmi, F. & Abu-Shikhah, N. (2012). *Power System Planning Technologies and Applications: Concepts, Solutions and Management*. IGI Global, Hershey. <https://doi.org/10.4018/978-1-4666-0173-4>
- [2] Aurich, J. C., Fuchs, C., & Wagenknecht, C. (2006). Life cycle oriented design of technical Product-Service Systems. *Journal of Cleaner Production*, 14(17), 1480-1494. <https://doi.org/10.1016/j.jclepro.2006.01.019>
- [3] Holjevac, N., Capuder, T., & Kuzle, I. (2015). Adaptive control for evaluation of flexibility benefits in microgrid systems. *Energy*, 92(3), 487-504. <https://doi.org/10.1016/j.energy.2015.04.031>
- [4] Kremers, E. A. (2013). *Modelling and simulation of electrical energy systems through a complex systems approach using agent-based models*. KIT Scientific Publishing, Karlsruhe.
- [5] Banovac, E., Stojkov, M., & Kozak, D. (2017). Designing a global energy policy model. *Proceedings of the Institution of Civil Engineers - Energy*, 170(1), 2-11. <https://doi.org/10.1680/jener.16.00005>
- [6] Perić, M., Tomiša, T., & Antonić, R. (2003). Stochastic model of irradiation for the Analysis of Solar System. *CD Proceedings of 11<sup>th</sup> Mediterranean Conference on Control and Automation MED'03*, Rhodes, 1- 6.
- [7] Józsa, L., Šljivac, D., & Topić, D. (2010). Stochastic modelling of pump-storage hydroelectric power plants, Part I. *Tehnički vjesnik*, 17(2), 153-162.
- [8] Booth, R. R. (1972). Optimal generation planning considering uncertainty. *IEEE Transactions on Power Apparatus and Systems*, 1, 70-77. <https://doi.org/10.1109/TPAS.1972.293292>
- [9] Booth, R. R. (1972). Power system simulation model based on probability analysis. *IEEE Transactions on Power Apparatus and Systems*, 1, 62-69. <https://doi.org/10.1109/TPAS.1972.293291>
- [10] Khodaei, A., Bahramirad, S., & Shahidepour, M. (2015). Microgrid planning under uncertainty. *IEEE Transactions on Power Systems*, 30(5), 2417-2425. <https://doi.org/10.1109/TPWRS.2014.2361094>
- [11] Gu, W., Wu, Z., Bo, R., Liu, W., Zhou, G., Chen, W., & Wu, Z. (2014). Modeling, planning and optimal energy management of combined cooling, heating and power microgrid: A review. *International Journal of Electrical Power & Energy Systems*, 54, 26-37. <https://doi.org/10.1016/j.ijepes.2013.06.028>
- [12] De Jonghe, C., Delarue, E., Belmans, R., & D'haeseleer, W. (2011). Determining optimal electricity technology mix with high level of wind power penetration. *Applied Energy*, 88(6), 2231-2238. <https://doi.org/10.1016/j.apenergy.2010.12.046>
- [13] Liang, H., Su, J., & Liu, S. (2010). Reliability evaluation of distribution system containing microgrid. *Proceedings of 2010 China International Conference on Electricity Distribution (CICED)*, Nanjing, 1-7.
- [14] Liang, H. & Zhuang, W. (2014). Stochastic modelling and optimization in a microgrid: A survey. *Energies*, 7(4), 2027-2050. <https://doi.org/10.3390/en7042027>
- [15] Štřelec, M., Macek, K., & Abate, A. (2012). Modelling and simulation of a microgrid as a stochastic hybrid system. *Proceedings of Innovative Smart Grid Technologies (ISGT Europe)*, Berlin, 1-9.
- [16] Choi, J., Moon, S., Kim, H.; Lee, B., & Billinton, R. (2000). Development of the ELDC and reliability evaluation of composite power system using Monte Carlo method. *Proceedings of 2000 Power Engineering Society Summer Meeting*, Seattle, 2063-2068. <https://doi.org/10.1109/PSS.2000.866964>
- [17] Vogt, T., Keuck, L., Fröhlecke, N., Böcker, J., & Kempen, S. (2014). Analysis of industrial microgrid power curves based on the theory of stochastic variables for control system development and component sizing. *Proceedings of 2014 International Conferences on Advances in Green Energy (ICAGE)*, Thiruvananthapuram, 66-73. <https://doi.org/10.1109/ICAGE.2014.7050145>
- [18] Bruce, A., Jurke, S., & Thomson, P. (1994). Forecasting load-duration curves. *Journal of Forecasting*, 13(6), 545-559. <https://doi.org/10.1002/for.3980130606>
- [19] Holjevac, N., Capuder, T., Zhang, N., Kuzle, I., & Kang, C. (2017). Corrective receding horizon scheduling of flexible distributed multi-energy microgrids. *Applied Energy*, 207(1), 176-194. <https://doi.org/10.1016/j.apenergy.2017.06.045>
- [20] Banovac, E., Bogdan, Ž., & Kuzle, I. (2008). Choosing the optimal approach to define the methodology of a tariff system for thermal energy activities. *Strojarstvo*, 49(6), 409-420.
- [21] Almashaie, E. & Soltan, H. (2011). A methodology for electric power load forecasting. *Alexandria Engineering Journal*, 50(2), 137-144. <https://doi.org/10.1016/j.aej.2011.01.015>
- [22] Abul'Wafa, A. R. & Taha, A. T. M. (2014). Reliability Evaluation of Distribution Systems under  $\mu$  Grid-Tied and Islanded  $\mu$  Grid Modes Using Monte Carlo Simulation. *Smart Grid and Renewable Energy*, 5, 52-62. <https://doi.org/10.4236/sgre.2014.53006>
- [23] Guo, L., Liu, W., Cai, J., Hong, B., & Wang, C. (2013). A two-stage optimal planning and design method for combined cooling, heat and power microgrid system. *Energy Conversion and Management*, 74, 433-445. <https://doi.org/10.1016/j.enconman.2013.06.051>
- [24] Perić, M., Tomšić, Ž., Tomiša, T., & Galešić, J. (2016). Energy management in Industrial Microgrid in Market Condition. *Bosanskohercegovačka elektrotehnika*, 10, 78-88.
- [25] Hahn, H., Meyer-Nieberg, S., & Pickl, S. (2009). Electric load forecasting methods: Tools for decision making. *European Journal of Operational Research*, 199(3), 902-907. <https://doi.org/10.1016/j.ejor.2009.01.062>
- [26] Alfares, H. K. & Nazeeruddin, M. (2002). Electric load forecasting: literature survey and classification of methods. *International Journal of Systems Science*, 33(1), 23-34. <https://doi.org/10.1080/00207720110067421>
- [27] Mahalakshmi, G., Sridevi, S., & Rajaram, S. (2016). A survey on forecasting of time series data. *Proceeding of 2016 International Conference on Computing Technologies and Intelligent Data Engineering (ICCTIDE)*, Kovilpatti, 1-8. <https://doi.org/10.1109/ICCTIDE.2016.7725358>

- [28] Tonković, Z., Zekić-Sušac, M., & Somoljanji, M. (2009). Predicting natural gas consumption by neural networks. *Tehnički vjesnik*, 16(3), 51-61.
- [29] Liik, O., Valdma, M., Keel, M., Tammoja, H. (2004). Optimization of electricity production capacity under uncertainty. *Proceedings of International Energy Workshop*, Paris, 22-24.
- [30] Expansion Planning for Electrical Generating Systems. A guidebook. International Atomic Energy Agency, Vienna, 1984. [http://www-pub.iaea.org/MTCD/publications/PDF/TRS1/TRS241\\_Web.pdf](http://www-pub.iaea.org/MTCD/publications/PDF/TRS1/TRS241_Web.pdf) (Accessed on 1.12.2017)
- [31] Poulin, A., Dostie, M., Fournier, M., & Sansregret, S. (2008). Load duration curve: A tool for technico-economic analysis of energy solutions. *Energy and buildings*, 40(1), 29-35. <https://doi.org/10.1016/j.enbuild.2007.01.020>
- [32] Gross, G., Garapic, N. V., & McNutt, B. (1988). The mixture of normals approximation technique for equivalent load duration curves. *IEEE Transactions on Power Systems*, 3(2), 368-374. <https://doi.org/10.1109/59.192886>
- [33] Maybee, S. & Uri, N. D. (1979). Time series forecasting of utility load duration curves. *Canadian Electrical Engineering Journal*, 4(1), 4-8. <https://doi.org/10.1109/CEEJ.1979.6592401>
- [34] Mahmoud, M. O. M., Jaidane-Saidane, M., Souissi, J., & Hizaoui, N. (2008). The mixture of generalized Gaussian model for modelling of the load duration curve: Case of the Tunisian power system. *Proceedings of 2008 IEEE Mediterranean Electrotechnical Conference*, Ajaccio, 774-779. <https://doi.org/10.1109/MELCON.2008.4618529>
- [35] Kee, Figure: 2013 PJM Load Duration Curve. Nuclear Base Load. 2014. <http://nuclear-economics.com/nuclear-base-load/>. (Accessed on 1.12.2017)
- [36] Kato, M., Zhou, Y., Kang, C., Yokoyama, R. Novel approach of modeling load duration curve for generation expansion planning based on Hill's function. *IEEE Transactions on Electrical and Electronic Engineering*, 6, 4(2011), 304-310. <https://doi.org/10.1002/tee.20661>
- [37] Perić M., Baće M., & Žibrat Z. (2002). The Empirical-Stochastic Model of Irradiance for the Simulation of the Solar Systems. *Proceedings of The Fourth ISES-Europe Solar Congress EuroSun 2002*, Bologna, (CD edition)
- [38] Sankarakrishnan, A. & Billinton, R. (1995). Sequential Monte Carlo simulation for composite power system reliability analysis with time varying loads. *IEEE Transactions on Power Systems*, 10(3), 1540-1545. <https://doi.org/10.1109/59.466491>
- [39] Olver, S., & Townsend, A. (2013). Fast inverse transform sampling in one and two dimensions. arXiv preprint arXiv:1307.1223.(2013)
- [40] Zio, E. The Monte Carlo simulation method for system reliability and risk analysis. Springer, London, 2013. <https://doi.org/10.1007/978-1-4471-4588-2>
- [41] Wenyuan, L. & Billington, R. (1994). *Reliability assessment of electric power systems using Monte Carlo methods*. Springer Science & Business Media, New York.
- [42] Elsobki, M. S., & El-Salmawy, H. A. (2001). An integrated resource planning formulation using a simultaneous electric/thermal production system. In *Electricity Distribution, 2001. Part 1: Contributions. CIREN. 16<sup>th</sup> International Conference and Exhibition on* (IEE Conf. Publ No. 482) (Vol. 4, 5-pp). IET.
- [43] Darrow, K., Tidball, R., Wang, J., & Hampson, A. (2017). Catalogue of CHP technologies. US Environmental Protection Agency, Washington, DC. <https://www.epa.gov/chp/catalog-chp-technologies> (Accessed on 1.12.2017)
- [44] Ghaderi, S. F., Razmi, J., & Ostadi, B. (2006). A Mathematical Model for Load Optimization: Linear Load Curves. *Journal of Applied Sciences*, 6, 883-887. <https://doi.org/10.3923/jas.2006.883.887>
- [45] Larsen, H. V., Pålsson, H., & Ravn, H. F. (1998). Probabilistic production simulation including combined heat and power plants. *Electric Power Systems Research*, 48(1), 45-56. [https://doi.org/10.1016/S0378-7796\(98\)00080-7](https://doi.org/10.1016/S0378-7796(98)00080-7)
- [46] Youn, L. T. & Leem, K. H. (2005). Stochastic model for operation of bottoming-cycle cogeneration facility. *Proceedings of 2005 International Conference on Future Power Systems*, Amsterdam, 1-5. <https://doi.org/10.1109/FPS.2005.204271>
- [47] Sondergren, C. & Ravn, H. F. (1996). A method to perform probabilistic production simulation involving combined heat and power units. *IEEE Transactions on Power Systems*, 11(2), 1031-1036. <https://doi.org/10.1109/59.496191>
- [48] Makkonen, S. & Lahdelma, R. (2006). Non-convex power plant modelling in energy optimisation. *European Journal of Operational Research*, 171(3), 1113-1126. <https://doi.org/10.1016/j.ejor.2005.01.020>
- [49] Park, J. B., Shin, J. R., Jeong, Y. W., Choe, G. H., & Lee, K. Y. (2005). An electricity market analysis method based on probabilistic production costing technique. *IFAC Proceedings Volumes*, 38(1), 296-301. <https://doi.org/10.3182/20050703-6-CZ-1902.01778>
- [50] Wu, L., Park, J., Choi, J., El-Keib, A. A., Shahidehpour, M., & Billinton, R. (2009). Probabilistic reliability evaluation of power systems including wind turbine generators using a simplified multi-state model: A case study. *Proceedings of Conference on Power & Energy Society General Meeting*, Calgary, 1-6. <https://doi.org/10.1109/PES.2009.5275723>
- [51] Gamou, S., Yokoyama, R., & Ito, K. (2002). Optimal unit sizing of cogeneration systems in consideration of uncertain energy demands as continuous random variables. *Energy Conversion and Management*, 43(9), 1349-1361. [https://doi.org/10.1016/S0196-8904\(02\)00020-1](https://doi.org/10.1016/S0196-8904(02)00020-1)
- [52] Salgado, F. & Pedrero, P. (2008). Short-term operation planning on cogeneration systems: A survey. *Electric Power Systems Research*, 78(5), 835-848. <https://doi.org/10.1016/j.epr.2007.06.001>
- [53] Dieu, V. N. & Ongsakul, W. (2006). Augmented Lagrangian-Hopfield network for combined heat and power economic dispatch. *Proceedings of Energy for Sustainable Development: Prospects and Issues for Asia*, Phuket, 1-3.
- [54] Rong, A., Hakonen, H., & Lahdelma, R. (2006). An efficient linear model and optimisation algorithm for multi-site combined heat and power production. *European Journal of Operational Research*, 168(2), 612-632. <https://doi.org/10.1016/j.ejor.2004.06.004>
- [55] Puttgen, H. B. & MacGregor, P. R. (1989). Optimum scheduling procedure for cogenerating small power producing facilities. *IEEE Transactions on Power systems*, 4(3), 957-964. <https://doi.org/10.1109/59.32585>

**Contact information:**

**Mario PERIĆ**, M.Sc. E.E.  
Končar Power Plant and Electric Traction Engineering Inc.  
Fallerovo Šetalište 22, 10000 Zagreb, Croatia  
mario.peric@koncar-ket.hr

**Tomislav PLAVŠIĆ**, Ph.D. E.E.  
Croatian Transmission System Operator Ltd.  
Kupska 4, 10000 Zagreb, Croatia  
tomislav.plavsic@hops.hr

**Igor KUZLE**, Ph.D. E.E.  
University of Zagreb,  
Faculty of Electrical Engineering and Computing  
Unska 3, 10000 Zagreb, Croatia  
igor.kuzle@fer.hr