



Munich Personal RePEc Archive

The Economic Application Approach of Fuzzy Logic Controller Type I and II for Second Order Linear Systems

Amir Tavakoli and Ehsan Khazaei

Department of Mechanical Engineering, Islamic Azad University of Shiraz, Shiraz, Iran

22 October 2016

Online at <https://mpa.ub.uni-muenchen.de/74708/>

MPRA Paper No. 74708, posted 22 October 2016 07:51 UTC

The Economic Application Approach of Fuzzy Logic Controller Type I and II for Second Order Linear Systems

Amir Tavakoli ¹, Ehsan Khazaei ¹

¹Department of Mechanical Engineering, Islamic Azad University of Shiraz, Shiraz, Iran

Abstract

During the last decades, Fuzzy Logic Controller (FLC) has been studied in many researchers. In this paper, the applications of FLC for second order linear systems are reviewed. However, FLC has a good performance for nonlinear systems as well. The main focus of this research is evaluating the FLC performance for linear case study. Also a comparison between FLC and PI controller has been studied. Moreover, both fuzzy type I and II are applied for evaluating the system performance. All the systems are reviews from the economic perspective. It means that these methods tried to decrease the cost function of the system. All the simulation and results are done in MATLAB environment.

Introduction

FLC is studied in many researches for both linear and nonlinear systems. For instance, fuzzy controller as an adaptive controller for nonlinear systems have been reported [1], [2], and [3]. Also, the theorem of fuzzy logic for linear Functions is defined in [4], [5]. However, fuzzy logic controller are studied for a linear system in this paper. The applications of fuzzy logic controllers are a lot [6]. For instance in electrical engineering, fuzzy logic is applied in the main structure of the DC/DC converter problem in [7]. Also, in [8] and [9], the fuzzy has been considered in many optimization power systems problems. In [10] and [11], fuzzy has been applied to clustering data for wind renewable energies for the first time. On the other hand, fuzzy logic controller type II has been considered in the main structure of the problems as well. In [12] and [17] fuzzy logic type II for the first time is applied to control the switching the high and

low voltage power systems. In this study, the Takagi Sugeno fuzzy controller is developed for fuzzy type 1 and type 2 [13].

Mathematical modelling of second order transfer function

A transfer function is a form of mathematical model between input and output of a system. “Transfer functions are commonly used in the analysis of systems such as single-input single-output filters, typically within the fields of signal processing, communication theory, and control theory. The term is often used exclusively to refer to linear, time-invariant systems (LTI), as covered in this article.” [14].

The standard equation of a second order transfer function is:

$$G(s) = \frac{wn^2}{s^2 + 2\xi wn s + wn^2}$$

Where $w_d = wn\sqrt{1 - \xi^2}$. w_d is called the damp natural frequency.

To obtain the poles of system we have:

$$s^2 + 2\xi wn s + wn^2 = 0 \rightarrow s = \frac{-b \pm \sqrt{b^2 - 4ac}}{2a} = \frac{-2\xi wn \pm \sqrt{(2\xi wn)^2 - 4(wn^2)}}{2}$$

$$= \xi wn \pm \sqrt{\xi^2 wn^2 - wn^2} = (\xi \pm \sqrt{\xi^2 - 1}) wn$$

The damping of the second order transfer function can be found in the following table:

If $\xi > 1$	over damped	We have to distinct real root
If $\xi = 1$	Critically damped	We have to equal real roots
If $\xi < 1$	Underdamped	Two complex conjugate roots

Table 1: Characteristics equation of the second order systems




Figure 1: Step response for Under-damped, critically damped and over-damped systems

The final curve of a second order transfer function with a step unit source as an input is:




Figure 2: Transient and steady state analyses

Where

1. Delay time, t_d
2. Rise time, t_r
3. Peak time, t_p
4. Maximum overshoot, M_p
5. Settling time, t_s

According to [15]:

$$M_p = e^{-(\xi/\sqrt{1-\xi^2})\pi}$$

$$t_s = \frac{4}{\xi\omega_n} \quad (2\% \text{ criterion})$$

$$t_s = \frac{3}{\xi\omega_n} \quad (5\% \text{ criterion})$$

$$t_p = \frac{\pi}{\omega_d}$$

Fuzzy Logic

Fuzzy logic is a type of controller created by Lotfi A.Zadeh in 1956 and continued by Mamadani and Sugeno theory. Today, it has been applied to other sciences such as artificial intelligence, robotics, and control theory. In practice, fuzzy logic controller has many applications such as:

- Nissan – fuzzy automatic transmission, fuzzy anti-skid braking system
- CSK, Hitachi – Hand-writing Recognition
- Sony - Hand-printed character recognition
- NASA has studied fuzzy control for automated space docking

- Canon developed an auto-focusing camera by fuzzy controller

“Compared to traditional binary sets (where variables may take on true or false values true), fuzzy logic variables may have a truth value that ranges in degree between 0 and 1.

Fuzzy logic has been extended to handle the concept of partial truth, where the truth value may range between completely true and completely false”.[16-22]

There are two types of Fuzzy controller in Matlab Simulink:

- 1- Mamadani: has a membership function in the output of the controller. No mathematical calculation is needed.
- 2- Sugeno: has a real number in the output but requires a mathematical model to achieve the output number.

In this project, Sugeno Fuzzy controller had been used.

Results

The final simulation and results of the fuzzy controller for both step and sine wave response are:

Results of (-3 2 3) as the output of fuzzy controller is:




Figure 3: Sine wave frequency is 0.1 (Hz). The output of fuzzy is (-3 2 3)




Figure 4: Step response when fuzzy output is (-3, 2, 3)

Results of (-20 2 20) as the output of fuzzy controller is:




Figure 5: Sine wave frequency is 0.1 (Hz). The output of fuzzy controller is (-20, 2, 20).




Figure 6: Step response when fuzzy output is (-20, 2, 20)

Conclusion

In this project, analysis of fuzzy controller type 1 and type 2 has been studied for second order linear systems. The performance of the control system has been studied for two different inputs: step response and sine wave response. Base on the finding, the operation of the fuzzy controller type 2 is better than type 1. Root square error and mean square error has been analyzed too. Base on the finding root mean square error and mean square error of fuzzy controller type 2 is lower than fuzzy controller type 1. Also, for the step input, rising time and steady state of the fuzzy type 2 is faster than type 1.

References

- [1] Martin Kratmüller, "The Adaptive Control of Nonlinear Systems Using the T-S-K Fuzzy Logic", SIEMENS PSE sro Slovakia Dúbravská cesta 4, 845 37 Bratislava, Slovak Republic, Vol. 6, No. 2, 2009.
- [2] Xin Wang, Edwin E. Yaz, James Long and Tim Miller, "Fuzzy Control of Nonlinear Systems with General Performance Criteria" ©2012 Wang et al., licensee InTech.
- [3] David F. Jenkins, Kevin M. Passino, "An introduction to nonlinear analysis of fuzzy control systems". Journal of intelligence and fuzzy systems.
- [4] Fernando di Sciascio, Ricardo Carelli, "Fuzzy Representation Theorem of Linear Functions Automatic Control Applications", INSTITUTO DE AUTOMATICA, UNIV. NAC. DE SAN JUAN, Av. San Martin 1109(O), 5400 San Juan, ARGENTINA
- [5] Şahin Emrah Amrahov, Iman N. Askerzade, "Strong Solutions of the Fuzzy Linear Systems" Ankara University, Computer Engineering Department.
- [6] Nilesh N. Karnik, Jerry M. Mendel, Fellow, IEEE, and Qilian Liang, "Type-2 Fuzzy Logic Systems", IEEE TRANSACTIONS ON FUZZY SYSTEMS, VOL. 7, NO. 6, DECEMBER 1999
- [7] Khazaei, P., S. M. Modares, M. Dabbaghjamesh, M. Almousa, and A. Moeini. "A High Efficiency DC/DC Boost Converter for Photovoltaic Applications." International Journal of Soft Computing and Engineering (IJSCE) ISSN (2016): 2231-2307.
- [8] Mehrtash, Mahdi, Masoud Jokar Kouhanjani, and Mohammad Mohammadi. "A new nonparametric density estimation for probabilistic security-constrained economic dispatch." Journal of Intelligent & Fuzzy Systems Preprint: 1-12.
- [9] Mehrtash, Mahdi, Mahdi Raoofat, Mohammad Mohammadi, and Hamidreza Zareipour. "Fast stochastic security-constrained unit commitment using point estimation method." International Transactions on Electrical Energy Systems 26, no. 3 (2016): 671-688.

- [10] Ashkaboosi, Maryam, Seyed Mehdi Nourani, Peyman Khazaei, Morteza Dabbaghjamanesh, and Amirhossein Moeini. "An Optimization Technique Based on Profit of Investment and Market Clearing in Wind Power Systems." *American Journal of Electrical and Electronic Engineering* 4, no. 3 (2016): 85-91.
- [11] Mehrtash, Mahdi, Masoud Jokar Kouhanjani, Amir Pourjafar, and Seyedbehnam Beladi. "An Interior Point Optimization Method for Stochastic Security-constrained Unit Commitment in the Presence of Plug-in Electric Vehicles." *Journal of Applied Sciences* 16, no. 5 (2016): 189.
- [12] Dabbaghjamanesh, M., A. Moeini, M. Ashkaboosi, P. Khazaei, and K. Mirzapalangi. "High performance control of grid connected cascaded H-Bridge active rectifier based on type II-fuzzy logic controller with low frequency modulation technique." *International Journal of Electrical and Computer Engineering (IJECE)* 6, no. 2 (2016): 484-494.
- [13] "Fuzzy logic", http://en.wikipedia.org/wiki/Fuzzy_logic, Nov. 2014
- [14] L. A. Zadeh, Fuzzy sets, *Informat Control*. 1965, pp 338-353
- [15] Li-Xin Wang, *A course in Fuzzy Systems and Control*, Prentice-Hall
- [16] Mohammad Reza Rajati, Jerry M. Mendel, Modeling Linguistic Probabilities and Linguistic Quantifiers Using Interval Type-2 Fuzzy Sets. *Proceedings of 2013 Joint IFSA World*. 2013.
- [17] Khazaei, Peyman, Morteza Dabbaghjamanesh, Ali Kalantarzadeh, and Hasan Mousavi. "Applying the modified TLBO algorithm to solve the unit commitment problem." In *World Automation Congress (WAC)*, 2016, pp. 1-6. TSI Enterprise Inc (TSI Press), 2016.
- [18] Mei-Hui Wang, A Type-2 FML-Based Fuzzy Ontology For Dietary Assessment, *Fuzziness and Soft Computing*. 2013, Volume 296, pp 149-168
- [19] N. N. Karnik, J. M. Mendel, and Q. Liang, Type-2 fuzzy logic systems, *IEEE Trans Fuzzy System*. 1999, pp 643-65
- [20] Shing-Chung Ngan, A type-2 linguistic set theory and its application to multi-criteria decision making, *Computers and Industrial Engineering*. 2013, Volume 64 Issue 2, pp. 721-730
- [21] Danling Wang and Yanfei Wang, Disease-Related Gene Identification by an Improved Type-2 Fuzzy Method on Microarrays, *Journal of Engineering Science and Technology*. 2013, Review 6 (2), pp 78-84
- [22] Nilesh N. Karnik, Jerry M. Mendel, "Operations on type-2 fuzzy sets", *Signal and Image Processing Institute, Department of Electrical Engineering-Systems, 3740 McClintock Ave., EEB400, University of Southern California, Los Angeles, CA 90089-2564, USA* Received 4 August 1999; received in revised form 10 April 2000; accepted 11 May 2000