A CUMULATIVE DAMAGE FRACTION DESIGN APPROACH FOR LMFBR METALLIC FUEL ELEMENTS

Ъу

David L. Johnson, Robert E. Einziger, and Gary D. Huchman

Prepared for

5th SMiRT Conference

Berlin, Germany

August 13-17, 1979





ARGONNE NATIONAL LABORATORY, ARGONNE, ILLINOIS

Operated under Contract W-31-109-Eng-38 for the U. S. DEPARTMENT OF ENERGY

The facilities of Argonne National Laboratory are owned by the United States Government. Under the terms of a contract (W-31-109-Eng-38) among the U. S. Department of Energy, Argonne Universities Association and The University of Chicago, the University employs the staff and operates the Laboratory in accordance with policies and programs formulated, approved and reviewed by the Association.

MEMBERS OF ARGONNE UNIVERSITIES ASSOCIATION

The University of Arizona Carnegie-Mellon University Case Western Reserve University The University of Chicago University of Cincinnati Illinois Institute of Technology University of Illinois Indiana University The University of Iowa Iowa State University The University of Kansas Kansas State University Loyola University of Chicago Marquette University The University of Michigan Michigan State University University of Minnesota University of Missouri Northwestern University University of Notre Dame The Ohio State University
Ohio University
The Pennsylvania State University
Purdue University
Saint Louis University
Southern Illinois University
The University of Texas at Austin
Washington University
Wayne State University
The University of Wisconsin-Madison

-NOTICE --

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States not any agency thereof, nor any of their employees, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for any third party's use of the results of such use of any information, apparatus, product or process disclosed in this report, or represents that its use by such third party would not infringe privately owned rights. Mention of commercial products, their manufacturers, or their suppliers in this publication does not imply or connote approval or disapproval of the product by Argonne National Laboratory or the United States Government.

A CUMULATIVE DAMAGE FRACTION DESIGN APPROACH FOR LMFBR METALLIC FUEL ELEMENTS

Ъv

D. L. Johnson, R. E. Einziger and G. D. Hudman

ABSTRACT

The cumulative damage fraction (CDF) analytical technique is currently being used to analyze the performance of metallic fuel elements for proliferation-resistant LMFBRs. In this technique, the fraction of the total time to rupture of the cladding is calculated as a function of the thermal, stress, and neutronic history. Cladding breach or rupture is implied by CDF = 1. Cladding wastage, caused by interactions with both the fuel and sodium coolant, is assumed to uniformly thin the cladding wall.

The irradiation experience of the EBR-II Mark-II driver fuel with solution-annealed Type 316 stainless steel cladding provides an excellent data base for testing the applicability of the CDF technique to metallic fuel. Mark-II drivers exhibit negligible fuel-cladding mechanical interaction, so the main source of stress is fission-gas pressure, which has been well characterized. The fuel-cladding chemical interaction zone, which has a uniform front and exhibits Arrhenius time-temperature behavior, is considered as cladding wastage in determining the hoop stress. The Mark-II lifetimes provide a lower bound for comparison with the CDF calculations, since the elements breach in a restrainer dimple and not in the cladding proper. At 590°C, the measured lower bound on lifetime, 10.0 at. %, is lower than the calculated CDF lifetime of 14.5 at. %. The measured lifetime at this temperature might be consistent with the CDF calculations if the cold-worked dimple were not present, since it acts as a stress riser. At 670°C, all elements have exceeded 8 at. % burnup, which is greater than the calculated CDF lifetime of 7 at. %. Thus, CDF calculations are conservative at 670°C. With this in mind, the calculations have been extended to other types of metal fuels.

The advanced metal fuels being considered for use in LMFBRs are U-15-Pu-10Zr, Th-20Pu and Th-20U (compositions are given in weight percent). The two cladding alloys being considered are Type 316 stainless steel and a titanium-stabilized Type 316 stainless steel. Both are in the cold-worked condition. The CDF technique was applied to these fuels and claddings under the following assumed steady-state operating conditions, taken from recent system studies: Peak cladding temperature of 640°C, fast fluence of 2.1 x 10^{23} n/cm², irradiation time of 4.32 x 10^{7} s, fuel peak burnup of 7 at. %, and linear power of 50 kW/m. Transient events, consisting of six "U-2b" events (15% overpower for 300 s) plus one "E-16" (natural-circulation) event, were assumed to occur at the end of the steady-state exposure.

Calculations for all combinations of the fuel types and claddings under consideration yielded CDF values of less than 0.07. The titanium-stabilized cladding gave lower CDF values than Type 316 stainless steel, owing to its greater strength. CDF values were highest for the Th-20Pu fuel because of its greater interaction (wastage) with the cladding. The very low CDF values indicate that all these designs have substantial margins to accommodate wastage or fuel-cladding stresses in excess of those anticipated.

In summary, the CDF technique gives a conservative estimate of current metal fuel-element lifetimes at 670°C. Further, it predicts satisfactory performance of the advanced fuel designs to which it has been applied.

Introduction

renewed interest in metallic fuels for LMFBRs has arisen recently for several ans. First, the breeding potential of a metallic fuel system is generally superior to the corresponding ceramic fuel system because of the greater heavy-metal atom denture the metallic form. Second, reactor-design coolant-outlet temperatures have been asing. From a high near 650°C a few years ago, outlet temperatures have decreased to be a lower in many current designs. Finally, the desire to develop workable, proliferation-resistant fuel cycles has given a fresh impetus to metallic fuel development. Metallic fuels are amenable to on-site remote reprocessing in which the fuel is never completely demonstration and pattonium separation in spent fuel. Such a reprocessing scheme was successfully demonstrated in the EBR-II Fuel Cycle Facility in the 1960s [1].

A cumulative damage fraction (CDF) analytical method [2] has been adopted to provide a consistent basis for comparison of the expected performance of the various types of fuel elements under consideration in proliferation-resistant core design studies. In the present work, this method was first applied to the EBR-II metallic driver fuel and the results compared with actual irradiation experience. With its validity thus established the method was then applied to the advanced metal fuel systems under consideration. Uranium-plutonium-zirconium (U-Pu-Zr), thorium-plutonium (Th-Pu), and thorium-uranium (Th-U) alloy fuels were evaluated, and all were predicted to meet the goal requirements as specified by recent system-design studies [3] during both steady-state and transient operation.

CDF Method

Analysis using the CDF method assumes that the damage to the fuel-element cladding depends on the stress σ , temperature T, and fast-neutron fluence ϕ t, such that when the cumulative damage fraction reaches unity, the cladding is breached. This is formulated as

$$CDF = \int_{0}^{t} \frac{dt}{t_{R}(\sigma, T, \phi t)}$$
 (1)

reduction in element lifetime due to irradiation is greatly overestimated by the post-irradiation fluence-dependent correlations. The recommendation [2] followed in the present work assumes the use of unirradiated-material correlations for the steady-state portion of the irradiation and postirradiation correlations during transient events. Two cladding materials were considered for use with the metal fuels. They are Type 316 stain-less steel, in both the solution-annealed and 20% cold-worked conditions, and a stronger,

titanium-stabilized Type 316 stainless steel, also in the cold-worked condition. The stress-rupture correlations for these cladding materials at 640°C are shown in Fig. 1 [5-6]. The principle source of stress on the cladding was assumed to be the pressure of fission gas released from the fuel [7]. Little, if any, contribution from fuel-cladding mechanical interaction (FCMI) is expected. The stress is enhanced by the loss of cladding wall thickness as a result of sodium corrosion on the outside and interdiffusion of fuel and cladding constituents on the inside.

3. Systems Analysis

3.1 Materials Considerations

Four fuel alloys were evaluated using the CDF method. The first was the EBR-II Mark-II driver fuel, a uranium-fissium* alloy which has been extensively studied [7-11]. The other three alloys evaluated were uranium-plutonium-zirconium, thorium-plutonium, and thorium-uranium. Although these systems have not been as extensively investigated as the EBR-II driver fuel, some data are available [12-13]. All the fuel-element designs were based on the present EBR-II Mark-II driver design [7]; i.e., sodium-bonded with a fuel smear density of 75%. As the fuel swells during irradiation, the fission-gas bubble porosity in the fuel becomes interconnected just before fuel-cladding contact is established. Up to about 80% of the fission gas generated is released to the element plenum. The weak fuel produces little if any FCMI [7]. The main source of stress in the cladding is, therefore, the fission gas pressure in the plenum, which is a function of plenum-to-fuel volume ratio, temperature, and the amount of gas released from the fuel. Gas release from the Mark-II fuel has been well characterized as a function of burnup [7-9]; a constant release fraction of 80% from beginning of life was assumed for the other fuel types.

With uranium and plutonium metallic fuel systems, after fuel/cladding contact is made, the cladding diffuses into the fuel, leaving a weakened, depleted zone in the cladding. This zone has a uniform front parallel to the fuel-cladding interface and shows no penetration stringers along the grain boundaries [7,8]. The depth of this zone can be described by

$$\Delta = [D + \exp (-Q/RT)]^{\frac{1}{2}}$$

where Λ is the depth in cm,

- D is a diffusion constant in cm²/s,
- t is the irradiation time in seconds,
- Q is the activation energy,
- R is the gas constant, and
- T is the maximum cladding temperature in °K.

^{*}Fissium is the term used to denote an alloy which represents the approximate equilibrium concentration of metallic fission products.

The constants D_0 and Q are dependent on the fuel and cladding alloys. The values of D_0 and the alloys under consideration are given in Table I [7,11-13]. The fuel-cladding expectibility in the titanium-stabilized cladding was assumed to be the same as in Type 316 to takess steel.

An additional type of cladding wastage to be considered was sodium corrosion on the section 00, given by [14]

$$R = 3.31 \times 10^{-38} T^{9.494}$$
 (3)

reserve R is the corrosion rate in mm/s and T is the absolute temperature. In addition, an arbitrary 0.025-mm as-fabricated tolerance was assumed for the wall thickness. The fission-gas pressure was converted to cladding hoop stress by means of the equation

$$\sigma = P[OD^2 + ID^2)/(OD^2 - ID^2]$$
 (4)

where is the hoop stress, and P is the plenum pressure. The OD and ID were adjusted for the assumed wastages and tolerance. Changes in dimensions due to cladding creep and swelling were not considered, nor was stress relaxation in the cladding due to these mechanisms. The effect of a low melting phase ($\sim 700\,^{\circ}$ C) in the Th-Pu alloy at $\sim 2\%$ uranium has also not been considered, but poses a potentially significant problem for this system.

3.2 Design and Operating Parameters

The design and operating parameters of the fuel elements used in the analyses are shown in Table II. The Mark-II values are typical of the EBR-II design and operating parameters. The values for the advanced metal fuels reflect the recommended, optimized design from recent studies [3]. The 640° C peak cladding temperature is the 2σ temperature (the highest temperature expected, including uncertainties).

4. Results and Discussion

4.1 Mark-II Fuel Elements

A substantial number of Mark-II fuel elements have achieved high burnup at two temperatures. At 590°C, the normal peak cladding temperature for row 6 elements, 588 elements have achieved at least 10 at. % burnup. Thirteen of these incurred cladding breaches at 10 at. % burnup. At this temperature, above 10 at. % burnup, the probability of cladding breach increases very rapidly. The breaches all occurred, however, at a dimple in the cladding, initially 12 mm above the top of the fuel, which serves at a restraint to axial fuel growth. The dimple probably acts as a stress riser and, if not present, would allow the elements to achieve even higher burnup before cladding breach occurred. At 590°C, the 10 at. % burnup breach threshold is, therefore, a lower limit. No cladding breaches occurred among nineteen elements irradiated to 8 at. % burnup at 675°C, the peak temperature in a subassembly intentionally operated with reduced flow.

The calculated CDF for Mark-II elements at 590°C and 675°C is shown as a function of burnup in Fig. 2. The rather steep slopes of these semilogarithmic plots indicate that most of the damage accrues in a short time late in life. This characteristic is in good qualitative agreement with Weibull statistical analyses, which indicate essentially no breaching below the threshold and a high breaching rate above it [8]. At 590°C, the CDF analysis predicts a lifetime of 14.5 at. %. Although this is greater than the observed lifetime of 10 at. %, the analysis does not consider the effect of the cladding dimples, where the breach actually occurs. Were the dimples not present, 14.5 at. % would not be an unrealistic estimate of element life expectancy.

At 675°C, CDF analysis predicts breaching at 7 at. % burnup. The most probable source of this discrepancy is that at 675°C, significant carbide precipitation occurs in the cladding. The now relatively low-carbon matrix has a lower creep strength, allowing greater stress relaxation in the cladding. The lower cladding stress which would be reflected as a longer lifetime. At this higher temperature, the CDF calculation apparently is conservative.

4.2 Advanced Metal Fuels

CDF analyses were performed on the U-Pu-Zr, Th-Pu, and Th-U alloy fuels at the specified system design conditions given in Table II. Steady-state operation for 12,250 h (510 days) at the peak temperature [3] was assumed to be followed by typical design-basis transients; this is a conservative approach, since the cladding properties are more degraded and damage rates correspondingly greater at end of life. The transients considered were six 15%-overpower events of five minutes' duration each, followed by one naturalcirculation event resulting in a peak power/flow of ~175% for ~50 s. Peak cladding temperatures achieved during these events were 725°C and 875°C, respectively, compared with a nominal 2σ temperature of 640°C. For comparison, the fuel-cladding eutectic temperatures for U-Pu-2r, Th-Pu, and Th-U with stainless steel are approximately 825, 875, and 875°C, respectively. Enhanced fuel-cladding reaction rates and fluence-degraded cladding stressrupture properties were assumed during the transients. The results of the calculations are given in Table III. All the calculated CDF values are well below 1.0. The CDF increment due to the transients is about 30% of the total in the Type 316 stainless steel cladding but only 5-10% of the total in the titanium-stabilized cladding. The CDF values in the titanium-stabilized cladding are about an order of magnitude lower than in Type 316. Because of the very low values and conservative nature of the calculation, as evidenced by the 675°C Mark-II results, cladding breaching is not expected until much beyond 7 at. % burnup. Additional calculations were made to determine the expected breach burnup; these results are also given in Table III. Breach burnups fall within the 14-16 at. % range in Type 316 and the 20-25 at. % range in the titanium-stabilized cladding. These are all well beyond the lat. % goal burnup.

1.3 Sensitivity Studies

To determine the sensitivity of the results to variations in some of the importion fuel and cladding parameters, the uranium-plutonium-zirconium alloy in the titaniumstabilized cladding was chosen as a base case, since it has been given the most consideration in system-design studies and, therefore, may be considered as the prime candidate
system. The parameters varied were temperature, fission-gas release, fuel-cladding mechanical interaction, and cladding wastage from fuel-cladding reaction. The figure of merit
used in the sensitivity studies was the burnup to breach, i.e., CDF = 1. The results of
the sensitivity studies are shown in Table IV. The maximum decrease in burnup to breach
that can be achieved by varying a single parameter is less than 4 at. %, which is relatively
insignificant with respect to the goal burnup of 7 at. %. It is especially interesting to
note that if all the parametric variations in Table IV that resulted in decreased lifetime
are taken together in one case, the resulting calculated burnup to breach is 15.3 at. %,
still a factor of two greater than the 7 at. % goal burnup.

5. Conclusions

The following conclusions may be drawn from this study:

- 1. CDF lifetime calculations for EBR-II Mark-II elements are conservative at high temperatures and probably conservative or consistent with breach observations in Mark-II elements at lower temperatures.
- 2. Based on CDF calculations, the U-Pu-Zr, Th-Pu, and Th-U advanced metal alloy fuel systems considered may be expected to reach their goal burnups with no cladding breaches.
- 3. The greater strength of the titanium-stabilized cladding relative to Type 316 stainless steel provides a greater margin between goal burnup and burnup to breach but is not required to reach a goal burnup of 7 at. %.
- 4. The burnup to breach is not significantly affected by slight to moderate variations in temperature, fission-gas release, fuel-cladding mechanical interaction, or cladding wastage.

6. Acknowledgments

The authors would like to thank L. C. Walters for his help in initiating the CDF calculations and L. A. Neimark for his stimulating discussions. This work was supported by the United States Department of Energy.

7. References

- 1. M. J. FELDMAN et al., "Remote Refabrication of EBR-II Fuels," Nuclear Metallurgy 15, pp. 77-96 (1969).
- 2. W. F. BRIZES, personal communication, September 1977.
- 3. P. S. K. LAM, R. B. TURSKI, and W. P. BARTHOLD, "Performance of U-Pu-Zr Metal Fuel in 1000 MWe LMFBRs," International Conference on Fast Breeder Reactor Fuel Performance, Monterey, CA, USA, March 5-8, 1979, paper IV.13.
- 4. J. L. STRAALSUND et al., "Correlations of Transient Test Data with Conventional Mechanical Properties Data," Nuclear Technology 25, pp. 531-540 (1975).
- 5. E. E. BLOOM et al., "Effect of Neutron Irradiation on the Microstructure and Properties of Titanium-Stabilized Type 316 Stainless Steels," Nuclear Technology 31 (2), pp. 232-243 (1976).
- 6. A. A. SAGUES et al., "The Influence of Helium on the Mechanical Properties of DIN 1.4970," <u>Radiation Effects in Breeder Structural Materials</u>, M. L. Bleiberg and J. W. Bennett, Eds., TMS-AIME, New York (1977), pp. 367-375.
- 7. R. E. EINZIGER and B. R. SEIDEL, "The Performance of Reference Design Mark-II Metallic Fuel Elements in EBR-II to 10 at. % Burnup," to be submitted for publication in Nuclear Technology.
- 8. B. R. SEIDEL and R. E. EINZIGER, "In-Reactor Cladding Breach of EBR-II Driver-Fuel Elements," M. L. Bleiberg and J. W. Bennett, Eds., TMS-AIME, New York (1977), p. 139.
- 9. G. L. HOFMAN, W. N. BECK, R. V. STRAIN, G. O. HAYNER, and C. M. WALTER, "Irradiation Behavior of Unencapsulated EBR-II Mark-II Driver Fuel to a Maximum Burnup of 6 at. %," ANL-8119 (Feb. 1976).
- 10. R. E. EINZIGER, "The Performance of EBR-II Mark-II Metallic Driver Fuel up to 675°C," to be presented at the ANS 7: mational Conference on Fast Breeder Reactor Fuel Performance, March 1979, Monter ., CA.

- 11. S. T. ZEGLER, H. V. RHUDE, and J. A. LAHTI, "Compatibility of Uranium-5 wt % Fissium Alloy with Types 304L and 316 Stainless Steel," ANL-7596 (Sept. 1969).
- 12. C. M. WALTER, et al., "U-Pu-Zr Metal Alloy: A Potential Fuel for LMFBRs," ANL-76-28 (Nov. 1975).
- 13. 3. BALMENTHAL et al., "Thorium-Uranium-Plutonium Alloys as Potential Fast Power-Ne: tor Fuels," ANL-7259 (Oct. 1969).
- 14. A. W. THORLEY and C. TYZACK, "Corrosion Behavior of Steels and Nickel Alloys in High Temperature Sodium" IAEA Symposium on Alkali Metal Coolants, Vienna, 1967, Paper SM-85/18.

Table I. Constants for Compatibility of Metal Fuels with Type 316 Stainless Steel Cladding

Fuel Alloy	D _o , cm ² /s	Q, kcal/mole
U-Fs	3.45×10^2	62.35
U-Pu-Zr	2.56×10^{2}	62,5
Th-Pu	2.69 x 10 ⁻¹	45.6
Th-U	2.51 x 10 ⁻²	44.0

Table II. Design and Operating Parameters for Metal Fuels

	Mk-II	Advanced Fuels ^a		
Cladding Alloy	SA 316 SS	CW 316 SS, CW 316 SS + Ti		
Cladding OD, mm	4.4	7.1		
Cladding ID, mm	3.8	6.1		
Plenum/Fuel Volume Ratio	0.3	1.0		
Peak Cladding Temperature	675	640		
Peak Fuel Burnup, at. %	10	7		
Peak Linear Power, kW/m	30	66		
Irradiation Time, days	 -	510		

^aU-Pu-Zr, Th-Pu, Th-U

Table III. Summary of Advanced Metal Fuel CDF Calculations

		CDF at 7 at. % burnup		
Fuel	Cladding	Steady State	Steady State + Transient	Burnup for Steady-state CDF = 1
U-Pu-Zr	CW 310 SS	4.2 x 10 ⁻²	5.8 x 10 ⁻²	16
	CW 316 SS + Ti	3.0×10^{-3}	3.2×10^{-3}	26
Th-Pu	CW 316 SS	4.3×10^{-2}	7.0×10^{-2}	14
	CW 316 SS + Ti	3.5×10^{-3}	3.8×10^{-3}	20
Th-U	CW 316 SS	3.7×10^{-2}	5.2×10^{-2}	16
	CW 316 SS + Ti	2.7×10^{-3}	2.9 x 10 ⁻³	25

Table IV. Sensitivity Studies on U-Pu-Zr Fuel in Titanium-stabilized Type 316 Stainless Steel Cladding

Parameter Variation	Burnup to Breach, at. %		
Base Case	25.7		
Cladding Temp. Increased from 640 to 650°C	23.3		
Fission-gas Release Increased from 80 to 100%	22.2		
Fuel-cladding Mechanical Interaction Increased from 0 to 20 MPa	22.7		
End-of-life Cladding Wastage Decreased from 0.07 to 0 mm	31.4		
End-of-life Cladding Wastage Increased from 0.07 to 0.16 mm	22.7		




Fig. 1. Stress-rupture Correlations Used for Type 316 Stainless Steel and Titanium-stabilized Type 316 Stainless Steel at 640°C.




Fig. 2. Calculated CDF in Mark-II Fuel Elements.