

Conf. 790602--4

MICROWAVE HEATING SIMULATIONS OF FISSION
ENERGY GENERATION IN VOLUME-BOILING POOL SYSTEMS **

by

H. Makowitz* and T. Ginsberg

MASTER

Brookhaven National Laboratory
Thermal Hydraulic Development Division
Department of Nuclear Energy
Upton, New York 11973

NOTICE
This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Department of Energy, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

* Applied Mathematics Department, Brookhaven National Laboratory, Upton, NY.

** Work carried out under the auspices of the United States Nuclear Regulatory Commission.

MICROWAVE HEATING SIMULATIONS OF FISSION
ENERGY GENERATION IN VOLUME-BOILING POOL SYSTEMS

H. Makowitz* and T. Ginsberg

Brookhaven National Laboratory
Thermal Hydraulic Development Division
Department of Nuclear Energy
Upton, New York 11973

The transition phase of the (hypothetical) loss-of-flow accident in LMFBR's may be characterized by the temporary entrapment of boiling pools of molten fuel and steel within the original core boundaries.⁽¹⁾ Experiments to investigate the multiphase flow and heat transfer characteristics of such systems have been performed^(2,3) and are planned⁽⁴⁾ in which simulant fluids are volume-heated by microwave electromagnetic radiation. It has been assumed that the microwave radiation provides a spatially uniform energy source per unit volume of liquid in multiphase flow geometries. It is known, however, that energy absorption by dielectrics in a microwave electromagnetic field is a function of geometry, dielectric properties, and wavelength of the radiation.⁽⁵⁾ At high power density, volume-heated boiling pools exhibit a complex two-phase, liquid-vapor, geometric structure. Dispersed droplets, with diameters less than 1 mm, in a vapor continuum may coexist with continuous liquid structures of centimeter scale or greater. This study was performed to: (i) investigate the uniformity of microwave heating in boiling pool systems as a function of liquid geometry and (ii) design an experimental system employing microwave heating in which the heat generation rate per unit volume of liquid is independent of geometric structure.

* Applied Mathematics Department, Brookhaven National Laboratory, Upton, NY.

The initial conceptual approach to the problem was to ask: given a microwave electromagnetic field of a given intensity, what is the rate of energy absorbed per unit volume by spheres of liquid of diameters ranging from 10^{-4} cm to 10 cm. The effects of droplet size, dielectric properties and wavelength on the energy absorption efficiency have been investigated. Materials and wavelength combinations were sought in order to obtain uniform volumetric heating rates.

The physics of the absorption and scattering of microwaves by droplets is part of the general theory of scattering of electromagnetic radiation by spherical particles⁽⁵⁾. The quantities of interest in a quantitative analysis of microwave absorption is the cross section C_{ABS} and the corresponding efficiency factor Q_{ABS} .

The energy absorption rate is

$$P = \phi_{INC} \cdot C_{ABS} = \phi_{INC} \cdot Q_{ABS} \cdot A \quad (1)$$

and the absorption rate of energy per unit volume is

$$Q''' = \frac{P}{V} = \phi_{INC} \cdot Q_{ABS} \cdot \frac{A}{V} \quad (2)$$

To satisfy the objectives of uniform volume heating, independent of liquid geometry, Q''' should be independent of the droplet radius.

The behavior of the quantities Q_{ABS} and Q''' were evaluated as functions of droplet radius for various combination of wavelengths and materials. The computer code DILISCA,⁽⁶⁾ representing a solution to Maxwell's equations in spherical geometry, was used in the study.

Water was investigated over a range of microwave wavelengths and temperatures. Figures 1 and 2 present the results for Q_{ABS} and the dimensionless power density

$$\psi \equiv Q'''(a)/Q'''(a = 5 \text{ cm}) \quad (3)$$

The results indicate that water exhibits a strong dependence of power density on liquid geometry. The power density of water droplets of diameters less than 0.5 cm is two orders-of-magnitude lower than for centimeter-scale droplets exposed to the same incident energy flux. In a water system, therefore, uniform heating independent of liquid geometry cannot be achieved in the range of interest.

A search for an alternate fluid system was performed. It was found that the dielectric properties of mixtures of polar ethanol and non-polar cyclohexane could be tailored to optimize uniform volume-heating conditions. Results for a 25 mol percent ethanol solution are presented in Figs. 1 and 2. The power density of the ethanol/cyclohexane solution varies by only ± 25 percent over a range of droplet radius 10^{-4} cm to 10 cm.

In summary, volume-boiling of water by microwave radiation does not provide uniform energy generation per unit volume of liquid, when coexisting liquid structures are widely divergent in dimensions. It is possible, however, to create conditions close to uniform volume heating for both the liquid-continuous and dispersed droplet regimes by the appropriate choice of dielectric properties together with the use of microwaves of a matched wavelength as the heating source.

Nomenclature

A	frontal area of droplets
C_{ABS}	absorption cross-section
P	energy absorption rate
Q_{ABS}	absorption efficiency
Q'''	heat generation rate per unit volume liquid
V	droplet volume
ϕ_{INC}	incident electromagnetic energy flux

References

1. Bohl, W. R., et al., "An Analysis of Transient Undercooling and Transient Overpower Accidents Without Scram in the Clinch River River Breeder Reactor," ANL/RAS75-29, (July 1975).
2. Farahat, M., Henry, R. E., and Santon, J., "Fuel Dispersal Experiments With Simulant Fluids," Proc. Int. Meeting on Fast Reactor Safety and Related Physics, CONF-761001, 1707, (October 1976).
3. Theofanus, T. G., "Multiphase Transients with Coolant and Core Materials in LMFBR Core Disruptive Accident Energetics Evaluations," NUREG/CR-0224, p. 207 (June 1978).
4. Ginsberg, T. and Jones, O. C., Jr., "Fast Reactor Safety Assessment Accident Sequence Phenomena Studies--Work Plan," BNL-NUREG-22587, (March 1977).
5. Kerker, M., "The Scattering of Light and Other Electromagnetic Radiation," Academic Press (1969).
6. "DILISCA (Differential Light Scattering)," Science Spectrum Inc., Santa Barbara, California.

Figure 2 - Power Densities for Dielectric Liquids in Microwave Field. (No BNL Neg. No)




Figure 1 - Absorption Cross Sections for Dielectric Liquids in Microwave Field. (No BNL Neg. No)

