

Automated Fault Analysis and Diagnosis using High-Frequency and Maintenance Data from Distribution Networks

Xu Jiang, *Student Member*, Bruce Stephen, *Senior Member*, Stephen D.J. McArthur, *Fellow*

Department of Electronic and Electrical Engineering
University of Strathclyde
Glasgow, UK

x.jiang@strath.ac.uk, bruce.stephen@strath.ac.uk, s.mcarthur@strath.ac.uk

Abstract— Fault analysis based on high-resolution data acquisition is growing in use as it offers a more complete picture of faults which provides an opportunity to deal with failures more effectively. However, with increased volume of data collected, it becomes impossible for engineers to interpret every fault instance. A machine learning approach to classification should be the solution to this, but it is time-consuming to manually label faults for training and validation making data-driven approaches impossible to transfer into practical implementation. A solution to this is to unify fault analysis with maintenance report analysis to automate the generation of training labels. This paper outlines how a fully automatic fault detection and diagnostic approach based around power quality waveform analysis can be used to improve situational awareness on distribution networks. The methodology is illustrated using operational case study data and realistic simulations to demonstrate the diagnostic functionality as well as the practical benefit. In particular, classification accuracy is shown to approach that of expert labelled fault data.

Index Terms—Power Quality, Automatic Fault Analysis, Increasing Situational Awareness, High-resolution Monitoring, Fault Labelling

I. INTRODUCTION

Maintenance procedures on distribution networks can suffer from inefficient fault and outage management due to lack of observability. In distribution networks, many faults can only be detected through operational alerts from Intelligent Electronic Devices (IED) or Supervisory Control and Data Acquisition (SCADA) systems, or through customer calls when supply is lost. The data captured on these devices is based on low-resolution monitoring; however, many anomalies are transient and intermittent, and might only last for couple or even less than one cycle. This results in low-resolution fault recording missing many important signatures in the pre-failure period. Thus, many utilities' awareness of the distribution system is either "normal operation" or "failure". [1] and [2] proposed a new approach to obtain high-resolution data to find the early signatures of failures and analyse the resulting waveforms to increase situational awareness, which provides more context for remedial decision support. The system utilized a rule-based

technique with expert knowledge to analyse faults. However, developing rule-based systems to cover every eventuality can be time-consuming, and a comprehensive validation of the method is a challenge because the volume of detected anomalies is excessive [2]. A solution is to utilize an automatic labelling function to obtain more exemplars for training and validating classifiers. Pertinent maintenance reports are an ideal source for this. Maintenance reports have been widely used for utilities to schedule and validate remedial works. Previous research [3] has utilized historical maintenance reports to predict feeder failure and limit the cascading impact of problems, which has validated the use of handwritten records in decision support for the maintenance of the network in New York City.

Furthermore, many distribution network components, such as cables, overhead lines and capacitors, are invisible to utilities so far as it is expensive to install individual sensors for them; however, these make up the majority of network assets. According to the 2015 British blackout annual report [4], many outages can be attributed to low observability components. Consequently, monitoring systems such as those proposed in [1][2] were built on a single point at the substation level, which provides a means to efficiently observe the health state of all the network components downstream.

This paper demonstrates a new fault analysis system architecture developed through combining high-resolution waveform analysis at substation level with automated context extraction from historical maintenance reports to provide situational awareness of downstream network operation. This can be built around placement of intensively sampled Current Transformers (CT) which have seen a number of practical deployments at distribution level [5]. Accordingly, this paper contributes 1) a new fault analysis system based on high-resolution monitoring for improving situational awareness 2) It is a fully automatic fault diagnosis approach using both waveform and free-text data. This demonstration utilizes operational data along with simulation of faults on the IEEE 13 bus test network to validate the functionality of the approach.

II. INTELLIGENT FAULT PROCESSING WITH POWER QUALITY WAVEFORM DATA

Power Quality monitoring involves capturing voltage and current measurements at waveform level resolution, then looking for evidence of developing faults through the recognition of artefacts superimposed on the AC waveform. Fig 1 shows an example of how a fault may manifest in waveform data. This fault is caused by weather – heavy snow on the lines. During the fault, distortion of one-cycle of voltage on phase A and neutral overcurrent can be observed. This can be because the snow causes a short-circuit which conducts from the overhead line to ground.




Fig 1 PQ waveform representation

This section will describe a high-resolution monitoring based intelligent fault analysis approach to automatically extract contexts of the distribution network, then provide the context for utilities to increase situational awareness. Fig 2 demonstrates the end-to-end process of the proposed system. Fundamentally, this system utilizes historical anomalous waveforms along with the maintenance reports that




Fig 2 Proposed automation of fault processing through waveform analysis

accompanied faults emanating from their occurrence to form a fault event exemplar repository that can support training of fault classifiers. When high-frequency continuous waveform signals are streamed into the system, abnormal events will be automatically segmented out, then can be put in the fault analysis system to interpret the anomalous waveform. While fault data may naturally partition itself according to cause, this is not immediately understandable by a non-expert. To assign a human readable description to faults, the semantics of the associated maintenance record are analysed to obtain representative keywords which can then serve as a label for the fault [3]. The specifics of this functionality will now be elaborated upon. We consider two use cases for the concept; retrospective analysis of archived operational fault data and simulated operational extremes.

A. Signal Segmentation

The approach only uses fault current signals to detect the abnormal events, because current is more sensitive to events. After detection, this event can be segmented and stored in a cache for later processing. Conventional high-resolution anomaly detection schemes, such as using the RMS value of three-phase current to determine abnormal events can result in high false positive rates [6][7]. This could be resolved through tracking the shape of abnormal components decoupled from sinusoidal components [7] rather than the localized thresholding of statistics approach. Here, sequential hypothesis testing is utilized [8] to characterise then identify abnormal events; this is because the shape descriptors of abnormal components obey a Gaussian distribution which has been validated in [7]. Then it can track abnormal events through observing whether new observations can be assumed to be drawn from the distribution of the predicted shape based on the sequential estimate of the mean and variance of the prior waveform.

B. Fault Event Exemplar Generation

Through common time and location records, historical waveforms can be associated with maintenance reports which correspond to a remedial work order. Fault labelling could be automated by using maintenance reports to create labels for training and validating intelligent classifiers. These reports are not pro-forma based, which results in free-form and sometimes abbreviated text. Topic models are generally based around co-occurring word count and their resulting statistics that facilitates generalising their content into clusters that can be considered as hypothetical topics. The labelling model utilizes a topic model to generate a word occurrence distribution over each document, then the semantic relevance between documents and topics can be used to categorize the maintenance reports; the most relevant word from a selection of terms (tree, equipment, vehicle, animal, lightning) is used for labelling faults. These terms could be changed according to the specific faults of interest. Latent Dirichlet Allocation (LDA) [9] and Cosine distance are utilized for demonstration of this here. LDA models the distribution of words within topics, which

means it can produce a readable list of most likely terms for a given combination of topics associated with a fault maintenance record, removing the need for explicit labelling.

C. Fault Recognition

Fault recognition amounts to a supervised learning problem: the proposed method utilizes the segmented fault data with a label generated from maintenance reports to identify the cause of the faults. If a fault has already occurred, the root cause of the fault can be identified through combining the context with the waveform characteristic of a new event. The features selected are referenced to the ones in [10][11] which uses weather observations from public stations and pertinent waveform characteristics. For demonstration purposes, one of the simplest classifiers, K-Nearest Neighbors (KNN), is used here to identify fault causes from the waveform shapes; benchmarking against a number of state of the art classifiers revealed this to be the superior performer although a formal model selection is left to future work, with this model pursued for completeness of demonstration purposes.

The root cause is essential information for utilities to take effective maintenance action. Fault cause determines the resulting maintenance response: if equipment is damaged by a 3rd party, it may need to be replaced or repaired urgently; if the fault is caused by a lightning strike three different outcomes may result depending on whether the lightning protection scheme was defective, the lightning arrester was damaged, or a re-closer is activated, a resulting maintenance scheme needs to be undertaken for the former two situations; animal or tree contact faults may be known occurrences with low priority or longer term remedial action. Thus, the fault cause and its event




Fig 3 IEEE 13 bus distribution system for fault simulation

context can provide more observability for utilities to make an optimal maintenance response which can minimize interruptions to supply.

III. CASE STUDIES: FAULT DETECTION AND DIAGNOSIS

To demonstrate the effectiveness of the proposed fault processing method, two approaches are taken: retrospective analysis of archived operational fault data and simulated operational extremes. For the latter, the IEEE 13-Bus Test Network is a typical unbalanced US distribution network which comprises both overhead lines and underground cables, which is simulated using the Simulink network shown in Fig.3. The injected faults provide the ground truth for abnormal events which can evaluate whether a detector with high-frequency data acquisition is capable of finding anomalies and how early it can detect the event. The fault category and parameters are modified based on the work of [12]. This simulation creates high-impedance arcing faults with variable duration and fault impedance which are hard to detect using conventional schemes [12].

The US Department of Energy PQ Event Repository [13] provides an opportunity to test the classification capability on operational faults; the library includes the waveform, time, weather, fault cause and corresponding field crew fault records. The sampling frequency of waveforms is 1.92 kHz and 3.84 kHz which produces a high-resolution representation as shown in Fig 1. It also provides the fault waveform start time and end time down to millisecond level. Table I shows the additional fault details that accompany each record.

Table I Maintenance records, fault cause labels and associated weather

EventId	Cause	Weather	Details (free text)
0001	Tree	Clear Weather	Fault caused line recloser lockout. Tree Outside Right of Way (Fall/Lean On Primary)
0004	Tree	Clear Weather	Fault caused line recloser lockout. Tree Outside Right of Way (Fall/Lean On Primary)
0005	Tree	Clear Weather	Fault caused line recloser lockout. Tree Outside Right of Way (Fall/Lean On Primary)
0007	Tree	Clear Weather	Fault caused line recloser lockout. Tree Outside Right of Way (Fall/Lean On Primary)
3042	Equipment	Unknown	Equipment, Device UG, Damaged.
0021	Equipment	Clear Weather	Overhead Insulator Failure. BROKEN INSULATOR
0022	Equipment	Clear Weather	Overhead Insulator Failure. BROKEN INSULATOR
0062	Undetermined	Raining	Storm
0064	Undetermined	Raining	Storm
0067	Tree	Thunderstorm	Tree/Limb Growth
0065	Tree	Thunderstorm	Tree/Limb Growth
0068	Tree	Clear Weather	VINES ON TRANSFORMER
2760	Unknown	Unknown	Short duration variation. No outage information found.
3048	Equipment	Unknown	Equipment, Capacitor Station, Damaged.

Table I shows the free text report associated with the fault indicating its context. Furthermore, Table I demonstrates the associated weather data used as an input for fault diagnosis as shown on Fig 2. To validate fault labelling and recognition,

appropriate exemplars should be selected. Firstly, the repository has 12 fault cause labels for the fault as Fig 4 shows. However, some of the fault causes are unknown which are labelled as ‘Unknown’, ‘Undetermined’, ‘Other’ or without any labels which should be removed. These amount to nearly a third of the archive, which implies present recording systems will still fail to identify the fault cause for some events. Therefore, a fault cause classifier with low false positive rate is required. Furthermore, the prevalence of fault cause, as shown in Fig 4, is unbalanced which can be challenging for automated classification – it will be difficult to learn general representations of seldom seen events. Five fault categories have sufficient prevalence to be considered: Equipment Caused Faults (ECF), Lightning Striking Faults (LSF), Vehicle




Fig 4 DoE repository fault prevalence

Hitting Faults (VHF), Animal Contact Faults (ACF) and Tree Contact Faults (TCF). Then these five categories will be used to test the classification with automatic labelling.

IV. RESULTS

This section uses simulated and operational data from a US distribution network to validate the signal segmentation and labelling function, then test classification with automated labelling which is benchmarked against the classification with expert labelled data. To achieve this, the signal segmentation function is first validated on the simulated data; after that, the operational data will be used to test the whole system end to end including signal segmentation, fault recognition and fault labelling. The associated fault reports will be utilized to generate labels for faults. Then the faults associated with the generated labels will be presented to the classification model, meanwhile, the faults manually labelled by experts will be individually used to train another classification. Ultimately, the actual labels will be used to test both models to see how they agree with expert classification. The performance of both models will be measured using the classification accuracy:

$$\text{Accuracy} = \frac{\sum \text{True Positives} + \sum \text{True Negatives}}{\text{Total Population}}$$

In the operational environment, the fault signals would be collected from a substation CT and combined with related maintenance reports stored in a digital format.

4878 simulated anomalies are used to test the effectiveness of signal segmentation using the sequential hypothesis testing model. About 94% of anomalies were identified and segmented

correctly under simulated operational conditions which included nonlinear load and realistic noise levels.

166 labelled faults are used to go through the system from end to end to test the capacity of the whole system. Firstly, the faults need to be filtered out by signal segmentation. Then 25% of the remaining data is held out as streamed new fault to test the capability of the automatic classification, and the others are used to train it. After that, the topic model described in Section IIB is utilized to generate a repository of historical exemplars. Topic models usually capture the proportions of topics present in a document rather than just assigning a single label. As Fig 2 shows, the historical maintenance reports are linked with pertinent fault waveform records using timestamp. And the relevance between every maintenance report in training set with the defined labels, such as ‘tree’ (this represents tree contact faults), can be calculated using a pre-trained topic model. The most strongly relevant will be selected as the label of the fault. Ultimately, the training set with generated labels will be put into the fault cause classifier, which is KNN in this paper, to calculate the performance and benchmark it against the ground truth.

After the signal segmentation, none of the signals are missed by the proposed detector. Therefore, all faults can be used to split into the training set and test set. The first 14 examples of relevance calculation are demonstrated in Table II: 1 represents perfectly relevant and 0 means completely irrelevant. Most events are strongly relevant to one topic. However, event 3024,

Table II The relevance between maintenance reports and labels for first 14 cases (Relevance), T – Tree, A – Animal, L – Lightning, V – Vehicle, E – Equipment

Event id	Details (free text)	T	A	L	V	E
0001	Fault caused line recloser lockout. Tree Outside Right of Way (Fall/Lean On Primary)	0.97	0.15	0.20	0.09	0.08
0004	Fault caused line recloser lockout. Tree Outside Right of Way (Fall/Lean On Primary)	0.97	0.15	0.20	0.09	0.08
0005	Fault caused line recloser lockout. Tree Outside Right of Way (Fall/Lean On Primary)	0.97	0.15	0.20	0.09	0.08
0007	Fault caused line recloser lockout. Tree Outside Right of Way (Fall/Lean On Primary)	0.97	0.15	0.20	0.09	0.08
3042	Equipment, Device UG, Damaged.	0.22	0.15	0.22	0.93	0.94
0021	Overhead Insulator Failure. BROKEN INSULATOR	0.21	0.14	0.21	0.93	0.94
0022	Overhead Insulator Failure. BROKEN INSULATOR	0.21	0.14	0.21	0.93	0.94
0062	Storm	0.37	0.94	1	0.56	0.27
0064	Storm	0.37	0.94	1	0.56	0.27
0067	Tree/Limb Growth	0.98	0.17	0.25	0.15	0.12
0065	Tree/Limb Growth	0.98	0.17	0.25	0.15	0.12
0068	VINES ON TRANSFORMER	0.81	0.27	0.37	0.24	0.38
2760	Short duration variation. No outage information found.	0.20	0.89	0.97	0.44	0.08
3048	Equipment, Capacitor Station, Damaged.	0.28	0.18	0.28	0.90	0.98

0021, 0022 and 3048 are attributed to both VHF and ECF, and more strongly associated to ECF. This is because many VHF events in the operational dataset usually damages the poles and overhead line. The most relevant label for faults is used to train the cause classifiers. Through this way, historical anomaly

Table III Confusion matrix of fault diagnosis with expert generated labels (83% overall accuracy), T – Tree, A – Animal, L – Lightning, V – Vehicle, E – Equipment

Actual Fault	T	E	A	V	L
T	8	1	1	1	0
E	2	10	1	0	1
A	0	0	11	0	0
V	0	0	0	0	0
L	0	0	0	0	5

Table IV Confusion matrix of fault diagnosis with automatically generated labels (78% overall accuracy), T – Tree, A – Animal, L – Lightning, V – Vehicle, E – Equipment

Actual Fault	T	E	A	V	L
T	9	0	1	1	0
E	6	7	1	0	0
A	0	0	11	0	0
V	0	0	0	0	0
L	0	0	0	0	5

waveform can be labelled by different fault causes, then these automated labelled data can be used to test the fault causes classification. The confusion matrix of the classification using ground truth and generated labels on the DoE data for training are shown in Table III and Table IV respectively. Although trained on faults labelled by different means (automated and manual), both classifiers are tested against the actual labels provided by an expert. The overall classification accuracy against ground truth labels is around 83%. The overall classification accuracy of generated labels is 78% - this is only a 5% reduction in classification accuracy to achieve fully automated fault labelling using KNN with US Department of Energy data.

V. CONCLUSION AND FUTURE DIRECTION

Distribution networks can be challenging to monitor effectively given their heterogeneity and historic lack of observation. The contribution of this paper has been to demonstrate an automatic waveform-based fault analytic approach built on single point high-frequency monitoring to increase situational awareness of distribution network disturbances. This takes advantage of more comprehensive signal extraction in the form of shape information to recognize complex faults as well as an automated labelling function based on the semantics of historical maintenance reports. The use of automatically generated labels only reduces classification accuracy by approximately 5% in comparison to manually labelled data on an operationally obtained data set. If deployed in practice, this could promote the use of intelligent classifiers without the burden of having to provide them with labelled fault exemplars. Further development will entail optimisation of segmentation and classification functionality, through selection of additional

features, as well as labelling improvement through the inclusion of additional fault semantic data such as maintenance manuals. Operationally it is envisaged that the proposed system would be integrated into conventional monitoring systems informing location, protection order and power flow, to provide additional context for comprehensive post-fault analysis.

REFERENCES

- [1] J. A. Wischkaemper, C. L. Benner, B. D. Russell, and K. Manivannan, "Application of Waveform Analytics for Improved Situational Awareness of Electric Distribution Feeders," *IEEE Trans. Smart Grid*, vol. 6, no. 4, pp. 2041–2049, 2015.
- [2] K. M. Manivannan, "Power Distribution System Event Classification Using Fuzzy Logic," University of Texas A&M, 2012.
- [3] C. Rudin *et al.*, "Machine Learning for the New York City Power Grid," *IEEE Trans. Pattern Anal. Mach. Intell.*, vol. 34, no. 2, pp. 328–345, 2012.
- [4] EATON, "Blackout Tracker United Kingdom Annual Report 2015," 2015.
- [5] B. D. Russell and C. L. Benner, "Intelligent Systems for Improved Reliability and Failure Diagnosis in Distribution Systems," *IEEE Trans. Smart Grid*, vol. 1, no. 1, pp. 48–56, 2010.
- [6] IEEE Working Group on Power Quality Data Analytics, "Electrical Signatures of Power Equipment Failures Electric Signature Analytics for Equipment Condition Monitoring," 2016.
- [7] B. Li, Y. Jing, and W. Xu, "A Generic Waveform Abnormality Detection Method for Utility Equipment Condition Monitoring," *IEEE Trans. Power Deliv.*, vol. 32, no. 1, pp. 162–171, 2017.
- [8] R. P. Adams and D. J. C. MacKay, "Bayesian Online Changepoint Detection," 2007.
- [9] A. Hindle, M. W. Godfrey, and N. A. Ernst, "Automated Topic Naming to Support Cross-project Analysis of Software Maintenance Activities," in *Proceedings of the 8th Working Conference on Mining Software Repositories*, 2011, pp. 163–172.
- [10] X. Qin, P. Wang, Y. Liu, L. Guo, and G. Sheng, "Research on Distribution Network Fault Recognition Method Based on Time-Frequency Characteristics of Fault Waveforms," *IEEE Access*, vol. 6, pp. 7291–7300, 2018.
- [11] L. Xu and M.-Y. Chow, "A Classification Approach for Power Distribution Systems Fault Cause Identification," *IEEE Trans. Power Syst.*, vol. 21, no. 1, pp. 53–60, 2006.
- [12] W. Zhang, Y. Jing, and X. Xiao, "Model-Based General Arcing Fault Detection in Medium-voltage Distribution Lines," *IEEE Trans. Power Deliv.*, vol. 31, no. 5, pp. 2231–2241, 2016.
- [13] EPRI, "DOE/EPRI National Database Repository of Power System Events." [Online]. Available: http://pqmon.epri.com/disturbance_library/. [Accessed: 23-Jun-2017].

