

Transpiration Cooling System in Al-Co Open-celled Foam having PPI of 13

Bundit Krittacom^{1,*}, Pipatana Amatachaya¹ and Anucha Klamnoi²

¹Development In Technology Of Porous Materials Research Laboratory (DITO-Lab),

Department of Mechanical Engineering, Faculty of Engineering and Architecture,

²Department of Mathematics and Applied Statistics, Faculty of Sciences and Liberal Arts,

Rajamangala University of Technology Isan (RMUTI), 744 Suranarai Road,

Maung, Nakhonratchasima, 30000, THAILAND

*E-mail: bundit.kr@rmuti.ac.th, Tel: +664-423-3073, Fax: +664-423-3074

ABSTRACT

One-dimensional transpiration cooling system in open-celled foam has been conducted experimentally and numerically to investigate the heat transfer characteristics of combined convection and radiation. The Alumina–Cordierite (Al-Co) open-cell foam having porosity of 0.87 and pores per inch (PPI) of 13 was employed. The upper surface of porous plate was heated by the heat flux of incoming radiation ($q_{R,x,f}$) varying from 0.97 - 16.59 kW/m² whereas air injection velocity (u_f) fed into the lower surface was varied from 0.364 - 1.274 m/s, and then u_f was converted as Reynolds number (Re). The results show that the temperature efficiency (η_T), indicating how close the mean temperature of a porous heat plate to that of inlet air, increased rapidly with the air injection velocity (Re). It was then saturated and had a constant value at Re higher than 30. The conversion efficiency (η_C), which was regarded as the ability of porous material in transferring energy by convection after absorbed from heat radiation, decreased slightly with increasing of $q_{R,x,f}$ and u_f (Re). The numerical predictions also agreed well with experimental data.

Keyword: Open-cell foam, Radiation, Transpiration cooling, Reynolds number

1. Introduction

Transpiration cooling or effusion cooling [1] is the process of injecting a fluid (Air) into a porous material which can be served as a very efficient cooling method for protecting solid surfaces that are exposed to high-heat-flux, high-temperature from environments such as in hypersonic vehicle combustors, rocket nozzle, gas turbine blades, and the structure of re-entry aerospace vehicles [1–5]. The performance of this cooling system is governed by several parameters such as radiative

properties of porous media, the volumetric heat transfer coefficient between the solid phase and fluid, fluid velocity and irradiation. Thus, the knowledge of parameters for the design of transpiration-cooled devices is classified into two main groups including the phenomena of fluid flow and heat transfer process within the porous plate.

So far a number of experimental works [6–8] and numerical studies [9–12] have been conducted on transpiration cooling system. However, most of previous studies were mainly

intended to determine the effects of convection mode. There were only a few studies have taken into account the radiative heat transfer in the transpiration cooling system. Recently, Jiang et al. [13] and Kamiuto et al. [14] investigated experimentally and analytically to extend the validation of numerical model. Jiang et al. [13] found that the numerical results corresponded well with the experimental data including the surface temperature and heat transfer coefficients. However, their work still focused on the effects of convective heat transfer. Radiation mode was concerned in the investigation of Kamiuto et al. [14]. They reported that the agreement between theoretical prediction and experimental results was acceptable. Although Kamiuto and co-worker [14] regarded the radiation mode in the transpiration cooling system, the theoretical result was more emphasized. There exist the difference between theory and experiment.

Based on the work of Kamiuto et al. [14], the present research aims to further experiment and analyze the heat transfer phenomena as combined convection and radiation in the transpiration cooling system using open-cellular porous material. Alumina (54% wt of Al_2O_3) and Cordierite (6% wt of MgO and 40% wt of SiO_2) having PPI of 13 is adopted owing to this Alumina-Cordierite (Al-Co) has a higher porosity resulting to a higher efficient of heat transfer and is widely used as thermal insulation of industry [15]. Obtainable quantities such as temperature at the surfaces and within the porous plate, for theoretical results, are presented and comparison with experimental data is also reported. A tip for design is recommended.

2. Nomenclature

C_f	isobaric specific heat capacity (J/kg·K)
\tilde{g}	asymmetric factor of scattering phase function
G	incident radiation (W/m^2)
h_v	volumetric heat transfer coefficient between gas and solid phases ($W/m^3 \cdot K$)
k_f	thermal conductivity of a gas phase ($W/m^2 \cdot K$)
k_s	thermal conductivity of a solid phase ($W/m^2 \cdot K$)
q_{Rx}	net radiative heat flux in x direction (W/m^2)
T_f	temperature of a gas phase ($^{\circ}C$)
T_R	radiation blackbody temperature (K)
T_s	temperature of a solid phase ($^{\circ}C$)
T_{∞}	ambient temperature (K)
u_f	air flow velocity (m/s)
x	coordinate in the flow direction (m)

Greek Symbols

β	scaled extinction coefficient (m^{-1})
ϕ	porosity
η_T	temperature efficiency
η_C	conversion efficiency
ρ_f	density of a gas phase or air (kg/m^3)
σ	Stefan–Boltzmann constant ($=5.67 \times 10^{-8} W \cdot m^{-2} \cdot K^{-4}$)
τ	Optical thickness
ω	scaled albedo

3. Theoretical Analysis

3.1 Mathematical Model

The present model of a transpiration cooling system is shown in Fig. 1. The assumptions of the numerical model are similar to

those of Kamiuto et al. [14]. However, some modification was made to improve the accurate prediction. The following assumptions were introduced for this analysis as follows: 1) An open-cellular porous plate of thickness x_0 is placed horizontally; 2) The front surface of porous plate is uniformly irradiated by blackbody radiation at an equivalent temperature T_R (K), while the back surface is subject to uniform blackbody radiation at an inlet air temperature; 3) A low-temperature air is injected through the back surface of porous plate and is assumed to be non-radiating; 4) The porous medium is gray and is capable of emitting, absorbing and anisotropically scattering thermal radiation; 5) The porous medium is non-catalytic; 6) The physical properties depend on temperature differed from Kamiuto's work [14] that the physical properties of his work [14] did not depend on temperature; 7) The heat transfer within the porous plate is in an one-dimensional steady-state; 8) The behavior of air flow within porous plate is under local and non-thermal equilibrium condition.

With the use of the above assumptions, the continuity equation is given by:

$$\frac{\partial(\rho_f u_f)}{\partial x} = 0. \quad (1)$$

The governing energy equations for the gas and the solid phases (porous plate) are written as follows:

$$\rho_f u_f C_f \frac{\partial T_f}{\partial x} = \phi \frac{\partial}{\partial x} \left(k_f \frac{\partial T_f}{\partial x} \right) - h_v (T_f - T_s), \quad (2)$$

$$\frac{1}{3}(1-\phi) \frac{\partial}{\partial x} \left(k_s \frac{\partial T_s}{\partial x} \right) + h_v (T_f - T_s) - \frac{\partial q_{Rx}}{\partial x} = 0, \quad (3)$$

$$\frac{\partial q_{Rx}}{\partial x} = 4\beta(1-\omega) \left(\sigma T_s^4 - \frac{G}{4} \right), \quad (4)$$

Four physical properties, i.e., ϕ , h_v , β and ω , from Eq. (2) to (4) were summarized in Krittacom [16].




Fig.1 The theoretical model and coordinate of a transpiration cooling system

The G represents the incident radiation and q_{Rx} denotes as the net radiative heat flux in the flow direction. These quantities can be determined from the equation of transfer. Once the radiation field is specified, the quantities G and q_{Rx} can be readily evaluated. The radiative heat equation of the present research is solved by the P_1 approximation [17] and is written as:

$$\frac{dq_{Rx}}{dx} + (1-\omega)\beta(G - 4\sigma T_s^4) = 0, \quad (5)$$

$$\frac{dG}{dx} + 3(1-\omega\tilde{g})\beta q_{Rx} = 0. \quad (6)$$

The boundary conditions for (2), (3) and (4) are given as follows:

$$x = 0: T_f = T_\infty, \frac{\partial T_s}{\partial x} = 0, G - 2q_{Rx} = 4\sigma T_\infty^4, \quad (7)$$

$$x = x_0: \frac{\partial T_f}{\partial x} = \frac{\partial T_s}{\partial x} = 0, \quad G + 2q_{Rx} = 4\sigma T_R^4. \quad (8)$$

3.2 Numerical Method

For convenience of calculations, the governing equations and associated boundary equations are transformed into dimensionless forms, and then the dimensionless equations are solved numerically using an implicit difference method. For solving the equation of transfer with the P_1 equations, and calculations of the T_f and T_s , the porous plate is divided into 300 equally spaced increments, whereas the optical thickness is divided into 600 equally spaced increments. To obtain the solutions of T_f and T_s , G or q_{Rx} are first determined based on an the assumption of temperature profile, and then the quantities of G and q_R are gained by solving equation of transfer or the P_1 equations at staggered lattice points [16]. Once G is obtained, the finite difference equations for T_f and T_s can be solved readily by Gaussian elimination. Thereafter, the derived solutions of T_f and T_s are substituted into the equation of transfer or the P_1 equations and the energy equations to get new solutions of these quantities; similar calculations are repeated until the following convergence criterion is satisfied: $\left| \left(Q^{(n)} - Q^{(n-1)} \right) / Q^{(n)} \right| < 10^{-5}$. Here, Q represents T_f , T_s , G or q_{Rx} , and n is time interval of calculation. After obtaining the T_f , T_s and G , two efficiencies, temperature efficiency (η_T) and conversion efficiency (η_C) are evaluated as follows:

$$\eta_T = \frac{\left[T_R - (T_{s,x=0} - T_{s,x=x_0}) / 2 \right]}{T_R - T_\infty}, \quad (9)$$

$$\eta_C = \frac{\rho_f C_{Pf} u_f (T_{f,x=x_0} - T_{f,x=0})}{q_{Rx,f}}. \quad (10)$$

4. Experimental Apparatus and Procedure

4.1 Experimental Apparatus

Figure 2 shows a schematic diagram of the present experimental apparatus. The experimental set-up was constructed similar to that of Kamiuto et al. [14], but the double-tube heat exchanger was installed at the air inlet to keep air temperature at 25 – 30 °C when it reached the back surface of the porous plate. Therefore, the present transpiration cooling system consisted of 4 sections including heat exchanger, inlet air, porous medium, and radiation section. Air from a blower that was used as the transpiration gas was blown through the heat-exchanger and measured the flow rate using a rotermeter. The air then flowed upward through a stainless pipe (0.01 m inner diameter and 0.6 m high) instead of acrylic pipe as in Kamiuto et al. [14]. A porous plate made of Alumina-Cordierite (Al-Co) was placed on the top of the stainless pipe. The physical characteristics of the examined porous plate were summarized in Table 1. Four 250-W infrared lamps were aligned above the porous plate to irradiate the heat into the upper surface of the plate. The amount of radiant energy was measured using heat flux sensor manufactured by Hukesflux Thermal Sensor, model HFP01-05. The intensity of the infrared lamps was regulated manually from 50 V to 250 V; thus the radiative heat flux was varied from 0.97 to 16.59 kW/m².

4.2 Experimental Procedure

The procedure of the experimental operation of the present cooling system is also similar to those of Kamiuto et al. [14]. After the

infrared lamps are switched on, it takes about 40 - 60 minutes to attain a steady-state of the temperatures of the porous plate. Six type-K thermocouple elements of 0.0003 m in diameter are adhered on the upper and lower surfaces of

the porous plate by dividing as three for each surface. Inlet and outlet air temperature are measured using type-K sheathed thermocouple. The air velocity is varied from 0.364 - 1.274 m/s.




Fig.2 Schematic diagram of the experimental apparatus

Table 1 Physical characteristics of a Alumina-Cordierite (Al-Co) open-cellular porous material

Coefficients	Quantities	
Porosity	ϕ	0.87
Pores per inches	PPI	13
Thickness	x	0.0103 m
Extinction coefficient	β	249.15 m ⁻¹
Optical thickness	τ	2.554


5. Results and Discussion

5.1 Effects of Air Flow Velocity (u_f) on Temperature Profile


Figure 3 presents the theoretical results of the temperature profiles of the solid (T_s) and the gas phases (T_f) inside the Al-Co porous plate, under the condition of irradiated heat flux

$q_{R,x,f} = 12.48 \text{ kW/m}^2$. As seen first in Fig. 3 (a), the measured mean surface temperatures of the front and back porous plate are indicated by symbols, while the calculated results for the solid phase (T_s) is presented using the lines. The trend of T_s increased along the porous length because the incident radiation from the infrared lamps was emitted down to the front surface. For a fixed position of the thickness (x), the temperature profiles of T_f decreased as the air velocity (u_f) increased owing to the effects of a higher convective heat transfer [10]. Agreement between the prediction calculated by basing on the P_1 equation in the radiative transfer equation (RTE) and the experimental results at the back ($x = 0$ mm) and the front surface ($x = 10$ mm) were

satisfactory. In Fig. 3 (b), the temperature profiles of T_f showed the trend similar to T_s case; it increased along the porous length and decreased with u_f increasing. For comparison of T_s and T_f , the level of T_s was higher than T_f . This is clarified that the radiation heat flux was absorbed by the solid porous phase and then, next step, the radiative energy was transferred to the air supplied into system [18].



(a) Solid phase



(b) Gas phase

Fig.3 Profiles of T_s and T_f within the Al-Co open-cellular plate for the effect of u_f

5.2 Effects of Heat Flux on Temperature Profile


Figure 4 showed the theoretical results of the temperature profile of the solid (T_s) and the gas phases (T_f) inside the Al-Co porous plate,

under the condition of $u_f = 0.848 \text{ m/s}$. As seen first in Fig. 4 (a), the trend of T_s increased along the porous length due to incident radiation from the infrared lamps. For a fixed position of thickness x , the temperature profiles of T_s increased with radiative heat flux ($q_{R_{x,f}}$) owing to porous medium absorbed a higher radiant energy from the infrared lamps. Agreement between the prediction based on the P_1 model of RTE and the experimental results at the back ($x = 0 \text{ mm}$) and the front surface ($x = 10 \text{ mm}$) were satisfactory. In Fig. 4 (b), the temperature profiles of T_f expressed the trend similar to T_s case; it increased along the porous length gradually and increased with $q_{R_{x,f}}$. For comparison of T_s and T_f , it was obviously found that T_s was higher than T_f which was described by the same reason of Fig. 3 (b).


5.3 The Temperature Efficiency (η_T)

Figure 5 shows variations in the temperature efficiency η_T against Reynolds number (Re). In this study, Re represents the air flow velocity which is defined by using $\rho_f u_f D_s / \mu_f$, where μ_f is viscosity of a gas phase ($\text{Pa}\cdot\text{s}$), and D_s is the equivalent strut diameter (m) as described in Kittacom [16]. The experimental results are shown using symbols, while the numerical results are indicated by using the lines. The figure depicted that the η_T increased rapidly with Re and then asymptotic to a constant value for the Re higher than 30. However, at a fixed Re , the η_T decreased with the increase of the incident radiation. For $Re > 30$, the values of η_T were greater than 95 %. This indicated that the average temperature of the porous plate was very close to the average heat shield temperature and

inlet air temperature. Agreement between theory and experiment was acceptable which indicated the validity of the present numerical model.



(a) Solid phase



(b) Gas phase

Fig.4 Profiles of T_s and T_f within the Al-Co open-cellular porous plate for the effect of $q_{R,x,f}$




Fig.5 Temperature efficiency (η_T) of the Al-Co open-cellular porous plate

5.4 The Conversion Efficiency (η_C)

Figure 6 shows variations in the conversion efficiency η_C against Re. The results demonstrated that the η_C increased slightly with Re in which the η_C values were varied in the range of 35 to 50%. For a fixed value of Re, η_C increased with incident radiation ($q_{R,x,f}$) because the porous media absorbed energy from a higher heat flux and then transferred via convection through the cooled-air flow. Thus, the ability of transferring energy of Al-Co open-cellular porous plate by convection after absorbing heat radiation decreased with the increasing of heat flux. Agreement between theory and experiment was acceptable.




Fig.6 Conversion efficiency (η_C) of the Al-Co open-cellular porous plate

In addition, recently, we have used Nickel-Chrome (Ni-Cr) open-celled foam having PPI of 21.5 as porous material in transpiration cooling system [19]. We found that the value of η_C of Ni-Cr porous case was approximately 70 – 80 % which was higher than those of the present transpiration

cooling system using Al-Co porous plate ($\eta_c \approx 35 - 50 \%$). This is fact that Ni-Cr was compound metal but Al-Co was ceramics material.

6. Summary

The major conclusions that can be drawn from the present study are summarized as follows:

1) The temperature profiles of gas (T_f) and solid (T_s) phase decreased as air injection velocity (u_f) increased because of the effects of a higher convective heat transfer, whereas the profiles of both temperature increased with incident radiation ($q_{R_x,f}$) owing to the effects of higher radiant energy.

2) The temperature efficiency (η_T) increased rapidly with Re and then asymptotic to a constant value for the Re higher than 30 but the η_T decreased with an increase in the q_{R_x}

3) The conversion efficiency (η_c) of an Al-Co open-celled foam increased slightly with Re and was governed by heat flux (q_{R_x}).

4) Agreement between the predicted results based on P_1 equations and experimental data was acceptable, thereby the validity of theoretical model was confirmed.

5) Incoming radiation from a radiative environment can be almost completely protected as long as the Re of the open-cellular plate was about 30 or higher. As a result, the transpiration cooling system as used in the present open-cellular porous plate should be designed for the Re = 30.

7. Acknowledgment

The authors would like to thanks to the Rajamangala University of Technology Isan (RMUTI) for the research fund. We also express

our thanks to Mr.Jeerasak Kamluang, Miss Pensiri Thikumrum, Mr.Kriengkai Dastaisong, Mr.Kritsada Poohbunya and Mr. Chutchai Krongpeug, students who is the members of the Development in Technology of Porous Materials Research Laboratory (DITO-Lab), for their assistance in performing some part of the experiments.

8. References

- [1] P. Grootenhuis, "The mechanism and application of effusion cooling", *Journal of the Royal Aeronautic Society*, vol. 63, pp. 73–89, 1959.
- [2] S.H. Choi, S.J. Scotti, K.D. Song and H. Ries, "Transpiring cooling of a scram-jet engine combustion chamber", *NASA AIAAA-97-2576*, 1997.
- [3] D.E. Glass, A.D. Dilley and H.N. Kelly, "Numerical analysis of convection/transpiration cooling", *AIAA J Spacecraft Rockets*, vol. 38 no.1, pp. 15–20, 2001.
- [4] F.J. Bayley and A.B. Turner, "The heat transfer performance of porous gas turbine blades", *Aeronautical Journal*, vol. 72 (696), pp. 1087–1094, 1968.
- [5] F.J. Bayley, "Transpiration cooled turbines", *Proc. Instn. Mech. Engineering*, vol. 185, no. 69/71, pp. 943-956, 1970.
- [6] P. Duwez and H.L. Wheeler, "Experimental study of cooling by injection of a fluid through a porous material", *Journal of Aeronautical Sciences*, vol. 15, pp.509 – 521, 1948.
- [7] G.E. Andrews and A. Asere, "Transpiration cooling of gas turbine combustion chamber walls", *Institute of Chemical Engineering Symposium Series*, vol. 86, pp.1047-1056, 1984.

- [8] X. Fu, R. Viskanta and J.P. Gore, "Measurement and correlation of volumetric heat transfer coefficients", *Experimental and Thermal and Fluid Science*, vol. 17(4), pp.285-293, 1998.
- [9] H. Kubota, "Thermal response of a transpiration-cooled system in a radiative and convective Environment", *Transaction of the ASME: Journal of Heat Transfer*, vol. 99, pp. 628 – 633, 1977.
- [10] E.R.G. Eckert and H.H. Cho, "Transition from transpiration to film cooling", *Int J Heat Mass Transfer*, vol. 37 (supplement 1), pp.3–8, 1994.
- [11] J.V. Wolfersdorf, "Effect of coolant side heat transfer on transpiration", *Heat Mass Transfer*, vol. 41, pp.327-337, 2005.
- [12] Y.H. Andoh and B. Lips, "Prediction of porous walls thermal protection by effusion or transpiration cooling. An analytical approach", *Applied Thermal Energy*, vol. 23 (15), pp.1947-1958, 2003.
- [13] P.-X. Jiang, L. Yu, J.-G. Sun and J. Wang, "Experimental and numerical investigation of convection heat transfer in transpiration cooling", *Applied Thermal Engineering*, vol. 24 (8-9), pp.1271-1289, 2004.
- [14] K. Kamiuto, "Thermal characteristics of transpiration cooling system using open-cellular porous materials in a radiative environment", *Int. J. Trans. Phenomena*, vol. 7, pp. 58-96, 2005.
- [15] A. Ochsner, G.E. Murch and M.J.S. Lemon, "Cellular and Porous Materials", Wiley-VCH Verlag GmbH & Co. KgaA, 2008.
- [16] B. Krittacom, *Studies on Thermal Characteristics of Open-Cellular Porous Burners*, Ph.D. Dissertation, Mechanical Engineering, Oita University, Japan, 2009.
- [17] K. Kamiuto, Saito, S. and Ito, K., "Numerical model for combined conductive and radiative heat transfer in annular packed beds", *Numerical Heat Transfer, Part A*, vol. 23, pp.433-443, 1993.
- [18] B. Krittacom and P. Amatachaya, "Comparison of radiative heat transfer equation in porous materials solving by the equation of formal solution and the P_1 approximation equation", *Engineering Journal of Siam University*, vol. 9 (1), pp. 20-30, 2008. (in Thai).
- [19] P. Amatachaya, P. Khantikomol, R. Sangchot, and B. Krittacom. "Steady state transpiration cooling system in Ni-Cr open-cellular porous plate. *International Conference on Fluids and Thermal Engineering (ICFTE 2011)*, River View Hotel, Singapore: 2011.