

---

Retrospective Theses and Dissertations

---

Spring 1981

## Economics of Residential Heat Recovery Units

Muhammad N. Redhwi  
*University of Central Florida*

 Part of the [Engineering Commons](#)

Find similar works at: <https://stars.library.ucf.edu/rtd>

University of Central Florida Libraries <http://library.ucf.edu>

This Masters Thesis (Open Access) is brought to you for free and open access by STARS. It has been accepted for inclusion in Retrospective Theses and Dissertations by an authorized administrator of STARS. For more information, please contact [STARS@ucf.edu](mailto:STARS@ucf.edu).

---

### STARS Citation

Redhwi, Muhammad N., "Economics of Residential Heat Recovery Units" (1981). *Retrospective Theses and Dissertations*. 583.

<https://stars.library.ucf.edu/rtd/583>

ECONOMICS OF RESIDENTIAL  
HEAT RECOVERY UNITS

BY

MUHAMMAD N. REDHWI  
B.S., University of Petroleum & Minerals, 1977

RESEARCH REPORT

Submitted in partial fulfillment of the requirements  
for the degree of Master of Science  
in the Graduate Studies Program of the College of Engineering  
at the University of Central Florida; Orlando, Florida

Spring Quarter  
1981

## ABSTRACT

Determining residential airconditioning waste heat recovery system costs and savings is achieved using a computer program. A worksheet is designed to accept consumer data as an input to the program. The program features load and waste heat recovery calculations on a monthly basis. Economic criteria, including rate of return, present worth, and payback period are computed. Sensitivity of these criteria to fuel escalation and consumer discount rate is demonstrated. The program provides the user with both thermal analysis and economic analysis summary reports.

## ACKNOWLEDGMENTS

I would like to thank the members of my graduate committee, Dr. Harold I. Klee, Dr. R. D. Doering, and Dr. Y. Hosni, for their time and effort.

## TABLE OF CONTENTS

ACKNOWLEDGEMENT	iii
NOMENCLATURE	v
Chapter	
I. INTRODUCTION .....	1
II. THERMAL ANALYSIS .....	6
Thermal Load.....	6
Thermal Performance .....	7
III. HRU ECONOMICS .....	9
IV. WHRSC WORKSHEET .....	13
V. WHRSC PROGRAM .....	23
Description .....	23
Processing .....	24
VI. SAMPLE RESULTS .....	23
VII. CONCLUSION.....	38
APPENDIX A - DERIVATION OF EQS. (10A-D) FROM CASH FLOW IN FIGURE 4 .....	39
APPENDIX B - PROGRAM NOMENCLATURE .....	43
FLOWCHART OF WHRSC.....	45
PROGRAM LISTING .....	47
WHRSC WORKSHEET .....	51
REFERENCES.....	56

## NOMENCLATURE

$A_o$	Current Annual Savings, \$
A/C	Air Conditioning
BTU	British Thermal Unit
COP	Coefficient of Performance
$C_p$	Water Specific Heat, BTU/Lb. <sup>o</sup> F
D	Days in a Month
d	Discount Rate, \$
e	Fuel (utility) Escalation Rate, %
EASR	Economic Analysis Summary Report
EER	Energy Efficiency Ratio, BTU/Watt. Hr.
f	Fraction of the Total Heating Load Supplied by Heat Recovery Unit
Gal.	Gallon
HRU	Heat Recovery Unit
h	Enthalpy, BTU/Lb.
i	General Inflation Rate, %
KWHR	Kilowatt - Hour
n	Life of the System, Years
P	Initial Cost of the System, \$
PW	Present Worth, \$
$o_w$	Compressor Power, KW.
Comp	

$\dot{Q}_{\text{Cond}}$	Rate of Heat Rejected From the Condenser, BTU/Hr.
$\dot{Q}_{\text{Evap}}$	A/C Capacity, BTU/Hr.
$Q_{\text{W}}$	Monthly Water Heating Load, BTU/Month
$R_{\text{O}}$	Current Annual Maintenance Cost, \$
ROI	Rate of Return on Investment, %
t	Tax Credit, %
TASR	Thermal Analysis Summary Report
$T_{\text{m}}$	Cold Water Main Temperature, °F
$T_{\text{S}}$	Hot Water Temperature Setting, °F
V	Daily Hot Water Consumption, gal./day
W	Watt
WHRSC	Waste Heat Recovery System Cost
p	Water Density, lb./gal.

## CHAPTER I

### INTRODUCTION

Domestic water heating requires substantial quantities of energy and accounts for 15% of national residential use [1]. Heat recovery from refrigeration systems can be used as a thermal source to supply 100% of the energy required for heating hot water under certain conditions, while increasing the energy efficiency ratio (EER) of the refrigeration cycle.

A heat recovery unit (HRU) is inserted between the compressor and the condenser of a standard residential air conditioning system. Figure 1 shows an HRU located adjacent to the outdoor condensing unit. An HRU is a simple thermostatically controlled heat exchanger where hot refrigerant gas from the air conditioner's compressor gives up some of its superheat to lower temperature water from a standard water heater. Typical operating temperatures are shown in Figure 2. Figure 3 shows a Temperature-Enthalpy diagram of an air conditioning cycle for refrigerant R-22 operating at typical conditions. The desuperheating of hot refrigerant supplies the energy for heating the water. The COP of an A/C is given by






Figure 1. Location of heat recovery unit




Figure 2. Typical operating temperatures of the system




Figure 3. Temperature - enthalpy diagram for R-22 refrigerant cycle

$$\text{COP} = \frac{\text{Cooling}}{\text{Work In}} = \frac{h_C - h_A}{h_D - h_C} \quad (1)$$

Assuming the available desuperheat ( $h_D - h_E$ ) is equal to the work required to compress the refrigerant [2].

$$(h_D - h_E) = \frac{1}{\text{COP}} \cdot (h_C - h_A) \quad (2)$$

For typical COP's in the range 3 to 4, the useful heat recovered is somewhere between 25% and 33% of the A/C cooling capacity. In addition, air conditioning costs are reduced by as much as 10% due to the reduced load on the condenser and compressor [3].

Without an HRU, the compressor discharge pressure is higher, resulting in an increased enthalpy  $h_D$  in Equation 1. Accordingly, the COP will decrease.

Heating load, A/C capacity, fuel inflation and many other variables influence the feasibility of heat recovery systems. The purpose of this study is to design a worksheet and develop a simplified computer program called WHRSC - Waste Heat Recovery System Cost - for quick estimation of the economic implications of those variables. WHRSC is similar to RSVP [4] and SOLCOST [5] programs except WHRSC is for heat recovery systems, whereas RSVP and Solcost are solar oriented.

## CHAPTER II

### THERMAL ANALYSIS

#### Thermal Load

The domestic water heating load must be estimated for each month of the year in order to determine the energy fraction that can be supplied by the HRU. The following equations are used to calculate the average monthly water heating load in BTU's.

$$Q_w = C_p \cdot \rho \cdot V \cdot (T_s - T_m) \cdot D \quad (3)$$

where,

$Q_w$  = Average monthly water heating load, BTU's

$C_p$  = Water specific heat, BTU/lb. °F

$\rho$  = Water density, lb./gal.

$V$  = Daily hot water consumption, gal./day

$T_s$  = Hot water temperature setting, °F

$T_m$  = Cold water main temperature, °F

$D$  = Days in a month

Since the specific heat of water is 1.0 BTU/lb.°F and the density is 8.33 lb./gal. the above equation reduces to

$$Q_w = 8.33 \cdot V \cdot (T_s - T_m) \cdot D \quad (4)$$

### Thermal Performance

HRU thermal performance is characterized by the term  $f$ , which denotes the fraction of the total domestic water heating load supplied by the HRU in a month. The monthly contribution is heavily dependent on A/C demand (Kwhr.) and hot water energy demand (BTU's/Ton). A Florida electric utility company has devised an empirically based procedure for estimating A/C consumption but admits the results are more reliable over the entire cooling season than on a monthly basis [6].

Energy requirements for existing centrally air conditioned residences can be estimated from the variations in monthly Kwhr. consumption over the cooling season using a month with little or no cooling/heating as a base. Averaging over several years should improve the estimate. The following equation is used to calculate A/C hours of operation per month.

Monthly A/C Hours of Operation

$$= \frac{\text{Monthly A/C Demand (Kwhr.)}}{\text{Compressor \& Fans Rating (Kw)}} \quad (5)$$

Alternatively, estimating the A/C operating time on a "typical" day of each month during the cooling season can be used to compute the approximate monthly A/C hours of operation.

The heat recovery of HRU's is typically estimated at 25% of the total heat rejected from the condenser [6]. The estimate of reclaimed condenser rejected heat is very critical due to its direct implication on the amount of energy recovered by the HRU. The rate of heat rejected from the condenser, in BTU's/hr., is obtained from

$$Q_{\text{Cond}}^{\circ} = Q_{\text{Evap}}^{\circ} + W_{\text{Comp}}^{\circ} \quad (6)$$

$$= \frac{\text{A/C Capacity (BTU's/hr.)} + \text{Compressor Rating (Kw)}}{3413 \text{ BTU's/Kwhr.}} \quad (7)$$

Equations (5) and (6) are combined to calculate  $Q_{\text{HRU}}$ , the monthly energy recovered by the HRU, i.e.

$$Q_{\text{HRU}} = 0.25 \cdot Q_{\text{Cond}}^{\circ} \cdot \text{A/C Hrs. per month} \quad (8)$$

Finally, the HRU fraction  $f$  is calculated from

$$\text{HRU Fraction} = \frac{\text{HRU Energy Recovered (BTU's/month)}}{\text{Water Heating Load (BTU's/month)}} \quad (9)$$

## CHAPTER III

### HRU ECONOMICS

Expected monthly savings and the installed cost of the HRU system are the most important factors in determining HRU economics. Monthly savings realized from HRU generated hot water is defined as follow:

$$\begin{aligned} \text{HRU Savings (\$/month)} &= \frac{\text{Energy Delivered (BTU/month)} \cdot \text{Fuel Cost (\$/Kwhr)}}{3413 \text{ BTU's/Kwhr}} \quad (10) \end{aligned}$$

The economic analysis of HRU systems using Life-Cycle Costing begins with an assumed cash flow over the expected life of the system (usually 20 years). An HRU cash flow diagram showing the initial cost,  $P$ , end-of-period savings,  $A_i$ , and operating/maintenance expenses,  $R_i$ , increasing at different rates ( $e\%$  and  $i\%$  respectively) is shown in Figure 4. If  $A_0$  and  $R_0$  are savings and expenses respectively at time zero, they will increase to  $A_n(1+e)^n$  and  $R_n(1+i)^n$  after  $n$  years.

For a discount rate (time value of money to buyer) of  $d\%$  per year the present worth equivalent of the cash flow shown in Figure 4 is

$$\begin{aligned} \text{PW} = & (A_1 - R_1) (P/F \ d\%, 1) + (A_2 - R_2) (P/F \ d\%, 2) \\ & + \dots + (A_n - R_n) (P/F \ d\%, n) - (1-t)P \quad (11) \end{aligned}$$



The derivation of PW is included in Appendix A and the final result is given below:

$$PW = \begin{cases} A_0 \left( \frac{1+e}{d-e} \right) \left\{ 1 - \left( \frac{1+e}{1+d} \right)^n \right\} - R_0 \left( \frac{1+i}{d-i} \right) \left\{ 1 - \left( \frac{1+i}{1+d} \right)^n \right\} - P(1-t) & (12A) \\ n(A_0 - R_0) - P(1-t) & d=e=i & (12B) \\ nA_0 - R_0 \left( \frac{1+i}{d-i} \right) \left\{ 1 - \left( \frac{1+i}{1+d} \right)^n \right\} - P(1-t) & d=e \neq i & (12C) \\ A_0 \left( \frac{1+e}{d-e} \right) \left\{ 1 - \left( \frac{1+e}{1+d} \right)^n \right\} - nR_0 - P(1-t) & d=i \neq e & (12D) \end{cases}$$

where,

$P$  = Initial cost, \$

$A_0$  = Expected current annual savings, \$/year

$R_0$  = Expected current annual expenses, \$/year

$n$  = Expected life of the system, years

$t$  = Tax credit (% of initial cost)

$i$  = General inflation rate

$e$  = Fuel (utility) inflation rate (including general inflation)

$d$  = Discount rate for buyer

Three broad indicators are used for determining whether the investment to reduce energy consumption is profitable.

1. Rate of Return: The rate of return on investment (ROI) is comparable to the interest paid by a hypothetical "Energy Conservation Bank" with costs as deposits and savings as withdrawals. The PW formulas, Equation (12A-D) will be used to determine the ROI. The appropriate PW expression is set to zero and iteratively solved for  $d$  which becomes the actual rate of return, that is the ROI including general inflation [7].




Figure 4. Cash flow for life-cycle cost economic analysis (cash purchase)

2. Present Worth Analysis: For a given discount rate,  $d$ , the present worth is again calculated from Eqs. (12A-D). If the resulting PW is positive, the investment would be economically desirable; otherwise it would not be.

3. Payback Period: Both simple and discounted paybacks will be determined. The simple payback represents the time required for the net savings to equal the net initial cost, ignoring the time value of money and inflation.

$$\text{Simple payback} = \frac{(1-t)P}{A_0 - R_0} \quad (13)$$

For a given discount rate, the discounted payback is determined from a year by year calculation of PW until a positive value is obtained. Sensitivity of the above three indicators to fuel inflation rate will be examined by varying fuel inflation  $\pm 30\%$  about some nominal value. In addition, the payback period variation with buyer discount rate will also be studied.

## CHAPTER IV

### WHRSC WORKSHEET

The worksheet, page 15, is self explanatory in most cases. Section 1 identifies the project. Section 2 and 3 identify information related to the conventional system and HRU system respectively. Section 4 concerns relevant A/C system data. Section 5 requires data to calculate the hot water load. Section 6 requires data needed for A/C demand calculations. In this section, if the user has a minimum of one year's monthly utility bills, the information is entered in the columns under the heading "Monthly Utility Bills". This data is then used to compute the A/C Kwhrs. required per month. Since power utility readings generally overlap two months, a method is outlined in Chapter 6 to compute the average monthly Kwhr. consumption from consecutive bills over the same month. On the other hand, if monthly utility bills are unavailable (e.g., a new residence) the estimated A/C run time on a typical day each month is required in the last column. Section 7 defines the relevant economic analysis parameters.

Table 1 is used to estimate city water main supply temperatures for different geographic regions of the United States [8]. Table 2

contains default values for items marked (\*) on the worksheet.  
These values will be automatically used if a value is not entered  
for that item.

## WHRSC WORKSHEET

## 1. Project Data

- . Date: Month-- , Day -- , Year ----.
- . Project Name:-----.
- . Location:-----.
- . Name:-----.
- . Address:-----  
-----.

## 2. Conventional Hot Water System Data

- . System Energy Source:-----.
- . Efficiency (100% if Electric):\*-----%.
- . Present System Fuel Cost:-----\$/Kwhr.

## 3. Heat Recovery System Cost

- . Total Installed Cost:-----\$.
- . First Year Operating & Maintenance Cost:\*-----% of Initial Investment.

## 4. A/C Data

- . A/C Unit Manufacturer:-----.
- . Model Number:-----.
- . Serial Number:-----.
- . A/C Nominal Capacity:-----Tons.
- . Energy Efficiency Ratio (EER):-----.
- (Enter 0.0 if Unknown)
- . A/C Compressor Rating:\*-----KW.
- (If EER known, Skip Next Item)

. A/C Combined Compressor and Fans Rating:\*-----KW.

5. Hot Water Load

Month	<u>Days</u> Month	Hot Water Demand Gal./Day	City Water Temperature * °F	Hot Water Temp. Setting * °F
Jan.	31	_____	_____	_____
Feb.	28	_____	_____	_____
Mar.	31	_____	_____	_____
Apr.	30	_____	_____	_____
May	31	_____	_____	_____
Jun.	30	_____	_____	_____
Jul.	31	_____	_____	_____
Aug.	31	_____	_____	_____
Sep.	30	_____	_____	_____
Oct.	31	_____	_____	_____
Nov.	30	_____	_____	_____
Dec.	31	_____	_____	_____

6. A/C Demand

If previous years utility bills are not available, fill only the last column.

Month	Monthly Utility Bills				A/C Hours Day
	19__	19__	19__	19__	
	Date Read	_____	_____	_____	_____
Jan.	Kwhr.	_____	_____	_____	_____
	Days	_____	_____	_____	_____
	Date Read	_____	_____	_____	_____
Feb.	Kwhr.	_____	_____	_____	_____
	Days	_____	_____	_____	_____
	Date Read	_____	_____	_____	_____
Mar.	Kwhr.	_____	_____	_____	_____
	Days	_____	_____	_____	_____
	Date Read	_____	_____	_____	_____
Apr.	Kwhr.	_____	_____	_____	_____
	Days	_____	_____	_____	_____
	Date Read	_____	_____	_____	_____
May	Kwhr.	_____	_____	_____	_____
	Days	_____	_____	_____	_____



Month	Monthly Utility Bills				A/C Hours Day
	19__	19__	19__	19__	
	Date Read	_____	_____	_____	_____
Jun.	Kwhr.	_____	_____	_____	
	Days	_____	_____	_____	_____
	Date Read	_____	_____	_____	
Jul.	Kwhr.	_____	_____	_____	
	Days	_____	_____	_____	_____
	Date Read	_____	_____	_____	
Aug.	Kwhr.	_____	_____	_____	
	Days	_____	_____	_____	_____
	Date Read	_____	_____	_____	
Sep.	Kwhr.	_____	_____	_____	
	Days	_____	_____	_____	_____
	Date Read	_____	_____	_____	
Oct.	Kwhr.	_____	_____	_____	
	Days	_____	_____	_____	_____
	Date Reat	_____	_____	_____	
Nov.	Kwhr.	_____	_____	_____	
	Days	_____	_____	_____	_____

Month	Monthly Utility Bills				A/C Hours Day
	19__	19__	19__	19__	
Date Read	_____	_____	_____	_____	
Dec. Kwhr.	_____	_____	_____	_____	
Days	_____	_____	_____	_____	_____

7. Economic Analysis Parameters

- . Expected Life of the System: \* \_\_\_\_\_ years
- . Fuel Inflation Rate: \* \_\_\_\_\_ %/year
- . General Inflation Rate: \* \_\_\_\_\_ %/year
- . Discount Rate: \_\_\_\_\_ %/year  
(Interest Rate on Your Best Available Investment)
- . Tax Credit if Any: \_\_\_\_\_ % of the initial cost

TABLE 1

## COLD WATER MAIN TEMPERATURE

CITY	SOURCE	J	F	M	A	M	J	J	A	S	O	N	D
Albuquerque	Well	72	72	72	72	72	72	72	72	72	72	72	72
Bakersfield	Well	66	67	68	69	70	70	70	70	70	69	68	67
Boston	Reservoir	32	36	39	52	58	71	74	67	60	56	48	45
Chicago	Lake	32	32	34	42	51	57	65	67	62	57	45	35
Denver		39	40	43	49	55	60	63	64	53	56	45	37
Eureka	Well	57	53	52	53	54	58	60	61	63	63	60	59
Ft. Worth	Lake	56	49	57	70	75	81	79	83	81	72	56	46
Las Vegas	Well	73	73	73	73	73	73	73	73	73	73	73	73
Los Angeles	River	50	50	54	63	68	73	74	76	75	69	61	55
Miami	Well	70	70	70	70	70	70	70	70	70	70	70	70
Modesto	Well	56	56	57	63	62	64	65	65	65	64	61	58
Nashville	River	46	46	53	66	63	69	71	75	75	71	58	53
New York City	Well	36	35	36	39	47	54	58	60	61	57	48	45
Phoenix	River	48	48	50	52	57	59	63	75	79	69	59	54
Riverside	Well	67	68	70	72	72	73	74	75	74	72	70	68
Sacramento	River	59	61	63	70	70	75	79	79	75	72	66	61
	Well	54	55	59	66	68	73	77	77	73	70	64	57
Salt Lake City	Well	35	37	38	41	43	47	53	52	48	43	38	37
San Diego	Reservoir	54	56	58	61	65	70	75	75	74	71	64	57
San Francisco	Reservoir	47	49	49	55	58	59	63	65	63	61	58	54
Seattle	River	39	37	43	45	48	57	60	68	66	57	48	43
Washington	River	42	42	52	56	63	67	67	78	79	68	55	46

TABLE 2

## DEFAULT VALUES

SEC.	ITEM	DEFAULT
2	Efficiency of Conventional System:	
	Electric	100
	Fuel or Oil	55
3	Operating & Maintenance	2
4	A/C Compressor Rating, KW.	-
	A/C Combined Compressor & Fans Rating, KW.	-
5	City Water Temperature, °F	Table 1
	Hot Water Setting Temperature, °F	140
7	Expected Life of the System, years	20
	Fuel Escalation Rate, %	13
	General Inflation Rate, %	10

A/C power requirements will be obtained from the manufacturer if available. Otherwise, the combined compressor and fans rating can be determined by using the EER of the A/C, i.e.

Compressor and Fans Rating (KW)

$$= \frac{\text{A/C Nominal Capacity (BTU's/hr.)}}{\text{EER} \cdot 1000} \quad (14)$$

The compressor rating is estimated based on the assumption that total fan power is roughly 20% of the combined compressor and fan power draw.

The default rates of fuel and general inflation will be periodically updated as dictated by market conditions.

## CHAPTER V

### WHRSC PROGRAM

#### Description

The WHRSC program performs two types of analysis.

1. Thermal Analysis: The EER of the A/C will be calculated and printed for each month in addition to the following:

- . Hot water demand in both gal./month and BTU/month.
- . A/C usage in both Kwhr./month and hours/month, regardless of whether A/C demand is computed from monthly power bills or estimated hours/day.
- . Savings in BTU/month and \$/month.
- . Fraction of the total heat supplied by HRU.

At the end of this report the accumulated annual heating load, annual savings and HRU annual fraction will be calculated and printed.

2. Economic Analysis: The projected fuel inflation rate will be varied by  $\pm 30\%$ . The following economic indicators will be printed:

- . Actual rate of return on the investment (includes general inflation) and real return on investment (excludes general inflation).
- . Present worth for a given discount rate with "YES" when the investment is desirable and "NO" when undesirable.

. Pay back period, both simple and discounted.

If the payback is higher than the expected life of the system, "GTR SYS LIFE" appears.

#### Processing

WHRSC consists of a main program which does both thermal and economic analysis, in addition to the sensitivity of discounted payback to fuel escalation and buyer discount rate. A function sub-program is used to evaluate Eqs. (12A-D).

Program nomenclature is included in Appendix B. A simplified flow chart is shown in Appendix B and the program listing is given in Appendix B.

## CHAPTER VI

### SAMPLE RESULTS


A completed worksheet (Appendix C) is used to illustrate the features of WHRSC. Average monthly Kwhr. calculations are illustrated in Figure 5. Since some monthly bills are missing, the overlapping days of the earlier month cannot be determined and, therefore the total Kwhr. of that month cannot be estimated. Table 3 summarizes A/C Kwhr./month calculations. Since March has the lowest average Kwhr./month and typically requires little or no cooling/heating, it is selected as the base for calculating monthly A/C Kwhrs.

Project information is initially printed as shown

Date : 4/25/1981  
Project : Hot Water Recovery  
Location: Orlando, Florida  
Name : Harold I. Klee

Sample results are given in Tables 4-6. Table 4 is the thermal analysis summary report, from which the annual heating load is found to be  $9.5 \times 10^6$  BTU. The annual savings is \$86.55 and HRU anual fraction is 0.516. Table 5 is the economic analysis summary report. At the nominal fuel calculation (13% per annum)





Average Kwhr. in June 1980

$$\begin{aligned}
 &= \frac{1532 \text{ Kwhr.}}{35 \text{ days}} \times 19 \text{ June days} \\
 &\quad + \frac{1684 \text{ Kwhr.}}{35 \text{ days}} \times 11 \text{ June days (July billing)} \\
 &= 1470
 \end{aligned}$$

Figure 5. Average monthly kwhr. calculation example

TABLE 3

## A/C KWHR./MONTH CALCULATION

MONTH	TOTAL KWHR./MONTH				AVERAGE	A/C KWHR./MONTH
	1978	1979	1980	1981		
Jan.	-	1049	-	1691	1393	0
Feb.	-	1066	-	980	1023	0
Mar.	-	958	958	843	920	0
Apr.	-	1039	1019	-	1029	109
May	-	1469	1246	-	1358	438
Jun.	-	1756	1470	-	1613	693
Jul.	1976	1904	1704	-	1861	941
Aug.	1839	1750	1518	-	1702	782
Sep.	1614	1579	1283	-	1492	572
Oct.	1089	1225	1113	-	1142	222
Nov.	949	958	-	-	954	34
Dec.	1046	1021	-	-	1034	0

TABLE 4

-----  
 THERMAL ANALYSIS SUMMARY REPORT  
 -----

CONVENTIONAL SYSTEM ENERGY SOURCE : ELECTRIC  
 CONVENTIONAL SYSTEM FUEL COST : 0.060 \$/KWHR  
 A/C NOMINAL CAPACITY : 3.833 TONS  
 ENERGY EFFICIENCY RATIO (EER) : 7.301

MONTH	DAYS/MONTH	HOT WATER DEMAND GAL/M	Demand BTU/M	A/C USAGE KWHR/M	USAGE HRS/M	SAVINGS RTJ/M	SAVINGS \$/M	RTJ FRACTION
JAN	31	1395.0	0.810E 06	0.0	0.0	0.000E 00	0.00	0.000
FEB	28	1263.0	0.732E 06	0.0	0.0	0.000E 00	0.00	0.000
MAR	31	1395.0	0.810E 06	0.0	0.0	0.000E 00	0.00	0.000
APR	30	1350.0	0.784E 06	109.0	17.3	0.275E 05	4.35	0.352
MAY	31	1395.0	0.810E 06	438.0	69.5	0.810E 05	14.25	1.000
JUN	30	1350.0	0.784E 06	693.0	110.0	0.784E 05	13.79	1.000
JUL	31	1395.0	0.810E 06	941.0	149.4	0.810E 05	14.25	1.000
AUG	31	1395.0	0.810E 06	782.0	124.1	0.810E 05	14.25	1.000
SEP	30	1350.0	0.784E 06	572.0	90.8	0.784E 05	13.79	1.000
OCT	31	1395.0	0.810E 06	222.0	35.2	0.562E 05	7.37	0.593
NOV	30	1350.0	0.784E 06	34.0	5.4	0.860E 05	1.51	0.110
DEC	31	1395.0	0.810E 06	0.0	0.0	0.000E 00	0.00	0.000

-----  
 ANNUAL HEATING LOAD = 0.9543E 07 RTU  
 ANNUAL SAVINGS = \$ 85.55  
 HRU ANNUAL FRACTION = 0.515  
 -----

TABLE 5

ECONOMIC ANALYSIS SUMMARY REPORT

FUEL INFLATION RATE : 13.00 %  
 GENERAL INFLATION RATE : 10.00 %  
 DISCOUNT RATE : 5.25 %  
 NET SYSTEM COST : 493.00  
 EXPECTED LIFE OF THE SYSTEM : 20 YEARS

FUEL ESCL RATE % DEV	INCL GEN INFL	RATE OF RETURN EXCL GEN INFL	PRES WORTH	DISCOUNT RATE DESIRABLE	INTERNAL RATE OF RETURN
-30 %	9.1 %	24.4 %	\$ 1704.94	YES	5.5
-15 %	11.0 %	27.0 %	\$ 2314.01	YES	5.5
0 %	13.0 %	29.5 %	\$ 3090.28	YES	5.5
15 %	14.9 %	31.9 %	\$ 4081.21	YES	5.5
30 %	16.9 %	34.4 %	\$ 5347.16	YES	5.5

the rate of return including general inflation is 29.5% and 17.7% excluding general inflation. The investment is desirable with a present worth of \$3090.28 and discounted payback of 5.2 years. The simple payback is 6.6 years. Variation in the actual and real return on investment with changes in fuel escalation is shown in Figure 6. Table 6 shows the sensitivity of discounted payback to both fuel escalation rate and user discount rate. Note the discounted payback exceeds the simple payback (6.6 years) when the discount rate is greater than the fuel escalation rate. Table 6 is presented in graphical form in Figure 7.

The relatively high simple payback period, 6.6 years, can be attributed to low hot water demands, 45 gal./day in this example. If the daily hot water consumption is increased to 80 gal./day, the annual savings would increase to \$135.40 (Table 7) and the simple payback is reduced to 3.4 years (Table 8).

Finally, if the HRU system is not properly maintained and should last only 10 years instead of 20 years, Table 9 indicates the investment to be less desirable as expected. Furthermore, if the discount rate were increased to 18.5% the investment is undesirable under certain conditions (Table 10).




Figure 6. Rate of return vs. fuel escalation rate

TABLE 6  
SENSITIVITY OF DISCOUNTED PAYBACK TO FUEL ESCALATION RATE AND DISCOUNT RATE

DISCOUNT RATE	FUEL ESCALATION RATE				
	9.1 %	11.0 %	13.0 %	14.9 %	15.9 %
5.0 %	5.3	5.5	5.2	5.3	4.7
7.5 %	5.3	5.9	5.6	5.3	5.0
10.0 %	6.3	6.4	6.0	5.5	5.3
12.5 %	7.5	6.9	6.4	6.3	5.7
15.0 %	8.5	7.6	7.0	6.5	5.1




Figure 7. Discounted payback vs. fuel escalation rate and discounted rate



TABLE 7

-----  
 THERMAL ANALYSIS SUMMARY REPORT  
 -----

CONVENTIONAL SYSTEM ENERGY SOURCE : ELECTRIC  
 CONVENTIONAL SYSTEM FUEL COST : 0.050 \$/KWHR  
 A/C NOMINAL CAPACITY : 3.833 TONS  
 ENERGY EFFICIENCY RATIO (EER) : 7.301

MONTH	DAYS/MONTH	HOT WATER DEMAND GAL/M	HTU/M	KWHR/M	A/C USAGE HRS/M	RTJ/M	SAVINGS \$/M	RTJ FRACTION
JAN	31	2480.0	0.144E 07	0.0	0.0	0.000E 00	0.00	0.000
FEB	28	2240.0	0.130E 07	0.0	0.0	0.000E 00	0.00	0.000
MAR	31	2480.0	0.144E 07	0.0	0.0	0.000E 00	0.00	0.000
APR	30	2400.0	0.139E 07	109.0	17.3	0.275E 05	4.35	0.198
MAY	31	2480.0	0.144E 07	438.0	69.5	0.111E 07	19.43	0.753
JUN	30	2400.0	0.139E 07	693.0	110.0	0.133E 07	24.51	1.000
JUL	31	2480.0	0.144E 07	941.0	149.4	0.144E 07	25.33	1.000
AUG	31	2480.0	0.144E 07	782.0	124.1	0.144E 07	25.33	1.000
SEP	30	2400.0	0.139E 07	572.0	90.8	0.133E 07	24.51	1.000
OCT	31	2480.0	0.144E 07	222.0	35.2	0.562E 05	9.37	0.390
NOV	30	2400.0	0.139E 07	34.0	5.4	0.860E 05	1.51	0.052
DEC	31	2480.0	0.144E 07	0.0	0.0	0.000E 00	0.00	0.000

-----  
 ANNUAL HEATING LOAD = 0.1597E 08 BTU  
 ANNUAL SAVINGS = \$ 135.40  
 HRU ANNUAL FRACTION = 0.454  
 -----

TABLE 8

ECONOMIC ANALYSIS SUMMARY REPORT

FUEL INFLATION RATE : 13.00 %  
 GENERAL INFLATION RATE : 10.00 %  
 DISCOUNT RATE : 5.25 %  
 NET SYSTEM COST : 493.00  
 EXPECTED LIFE OF THE SYSTEM : 20 YEARS

FUEL ESCL RATE % DEV	INCL GEN INFL	RATE OF RETURN EXCL GEN INFL	DISCOUNT RATE PRES WORTH	DISCOUNT RATE DESIRABLE	INTERNAL RATE OF RETURN SIMPLE
-30 %	9.1 %	36.1 %	\$ 3160.14	YES	4.0
-15 %	11.0 %	38.8 %	\$ 4112.90	YES	4.0
0 %	13.0 %	41.4 %	\$ 5327.22	YES	4.0
15 %	14.9 %	44.0 %	\$ 6877.35	YES	4.0
30 %	16.9 %	46.6 %	\$ 8857.67	YES	4.0

TABLE 9

ECONOMIC ANALYSIS SUMMARY REPORT

FUEL INFLATION RATE : 13.00 X  
 GENERAL INFLATION RATE : 10.00 X  
 DISCOUNT RATE : 5.25 X  
 NET SYSTEM COST : 493.00  
 EXPECTED LIFE OF THE SYSTEM : 10 YEARS

FUEL ESCL RATE % DEV	INCL GEN INFL	RATE OF RETURN EXCL GEN INFL	PRES WORTH	DISCOUNT RATE DESIRABLE	INTERNAL RATE OF RETURN
-30 X	9.1 X	18.2 X	\$ 418.17	YES	5.5
-15 X	11.0 X	20.6 X	\$ 534.32	YES	5.5
0 X	13.0 X	23.1 X	\$ 664.08	YES	5.5
15 X	14.9 X	25.4 X	\$ 809.02	YES	5.5
30 X	16.9 X	27.8 X	\$ 970.82	YES	5.5

TABLE 10

ECONOMIC ANALYSIS SUMMARY REPORT

FUEL INFLATION RATE : 13.00 %  
 GENERAL INFLATION RATE : 10.00 %  
 DISCOUNT RATE : 18.50 %  
 NET SYSTEM COST : 493.00  
 EXPECTED LIFE OF THE SYSTEM : 10 YEARS

FUEL ESCL RATE % DEV	INCL GEN INFL	RATE OF RETURN EXCL GEN INFL	DISCOUNT RATE PRES WORTH	DISCOUNT RATE DESIRABLE	TIME DISCOUNTED		
-30 %	9.1 %	18.2 %	7.5 %	\$ -6.82	NO	5.5	37.3
-15 %	11.0 %	20.6 %	9.6 %	\$ 44.38	YES	5.5	3.9
0 %	13.0 %	23.1 %	11.9 %	\$ 100.87	YES	5.5	3.0
15 %	14.9 %	25.4 %	14.0 %	\$ 163.19	YES	5.5	7.3
30 %	16.9 %	27.8 %	16.2 %	\$ 231.98	YES	5.5	3.9

## CHAPTER VII

### CONCLUSION

WHRSC provides an inexpensive and relatively reliable way of estimating the performance and costs of A/C waste heat recovery systems as compared to conventionally fueled systems. It considers the relevant factors and enables the user to make better decisions regarding HRU energy use.

Further improvements can be achieved in WHRSC by programming it to accept overlapping monthly utility bills data (i.e., date read, Kwhrs., number of days) and computing the A/C Kwhr. consumption per month. At present this is done manually. In addition, total billing and fuel adjustment cost can be used to compute conventional system fuel cost (\$/Kwhr.). Improved estimates of daily hot water demand per household can be determined from additional data related to family size, lifestyle, etc., by redesigning section five of the worksheet. The program considered only residential A/C applications. Minor adjustments are required for heat pump applications. Finally, the major assumption, 25% rechaimed condenser rejected heat, is very critical. Further work should address this point and the program can be altered to accept values based on subsequent studies.

APPENDIX A

DERIVATION OF EQS. (10A-D) FROM CASH FLOW IN FIGURE 4

$$PW = (A_1 - R_1)(P/F d, 1) + (A_2 - R_2)(P/F d, 2) \\ + \dots + (A_n - R_n)(P/F d, n) - (1-t)P$$

$$PW = \{A_1(1+d)^{-1} + A_2(1+d)^{-2} + \dots + A_n(1+d)^{-n}\} \\ - \{R_1(1+d)^{-1} + R_2(1+d)^{-2} + \dots + R_n(1+d)^{-n}\} - (1-t)P$$

$$PW = \{A_0(1+e)(1+d)^{-1} + A_0(1+e)^2(1+d)^{-2} + \dots + A_0(1+e)^n(1+d)^{-n}\} \\ - \{R_0(1+i)(1+d)^{-1} + \dots + R_0(1+i)^n(1+d)^{-n}\} - (1-t)P$$

$$\text{let } X = (1+e)(1+d)^{-1} \text{ and } Y = (1+i)(1+d)^{-1}$$

$$PW = \{A_0X + A_0X^2 + \dots + A_0X^n\} - \{R_0Y + R_0Y^2 + \dots + R_0Y^n\} - (1-t)P$$

$$PW = \{A_0 + A_0X + \dots + A_0X^n - A_0\} - \{R_0 + R_0Y + \dots + R_0Y^n - R_0\} - (1-t)P$$

$$PW = \{A_0(1+X+X^2 + \dots + X^n) - A_0\} - \{R_0(1+Y+Y^2 + \dots + Y^n) - R_0\} - (1-t)P$$

$$PW = \{A_0 \left( \frac{1+X^{n+1}}{1-X} \right) - A_0\} - \{R_0 \left( \frac{1+Y^{n+1}}{1-Y} \right) - R_0\} - (1-t)P$$

$$PW = A_0 \left\{ \frac{1-X^{n+1} - (1-X)}{1-X} \right\} - R_0 \left\{ \frac{1-Y^{n+1} - (1-Y)}{1-Y} \right\} - (1-t)P$$

$$PW = A_0 \left\{ \frac{-X^{n+1} + X}{1-X} \right\} - R_0 \left\{ \frac{-Y^{n+1} + Y}{1-Y} \right\} - (1-t)P$$

$$PW = A_0 \left( \frac{X}{1-X} \right) (1 - X^n) - R_0 \left( \frac{Y}{1-Y} \right) (1 - Y^n)$$

$$PW = A_0 \left( \frac{1+e}{d-e} \right) \left\{ 1 - \left( \frac{1+e}{1+d} \right)^n \right\} - R_0 \left( \frac{1+i}{d-i} \right) \left\{ 1 - \left( \frac{1+i}{1+d} \right)^n \right\} - (1-t)P$$

when  $d = e = i$

$$PW = nA_0 - nR_0 - (1-t)P$$

when  $d = i \neq e$

$$PW = A_0 \left( \frac{1+e}{d-e} \right) \left\{ 1 - \left( \frac{1+e}{1+d} \right)^n \right\} - n R_0$$

and when  $d = e \neq i$

$$PW = n A_0 - R_0 \left( \frac{1+i}{d-i} \right) \left\{ 1 - \left( \frac{1+i}{1+d} \right)^n \right\} -$$




APPENDIX B



## PROGRAM NOMENCLATURE

AIC	Average Installed Cost, \$
ACR	A/C Compressor Rating, KW.
ADS	Annual Dollar Savings, \$ Year.
AES	Annual Energy Saving, BTU/Year
AIR	Actual Interest Rate, %
AMD	A/C Monthly Demand, KWHR./Month
ANC	A/C Nominal Capacity, Tons
AOP	A/C Operation, Hours/Month
ART	A/C Run Time, Hours/Day
BMP	Hot Water Demand, BTU/Month
CFR	Combined Compressor & Fans Rating, KW.
CWT	City Water Temperature, °F
DMS	Dollar Monthly Savings, \$/Month
DP	Discounted Payback, Years
DSR	Discount Rate, %
EMC	Extra Operating & Maintenance Cost, %
EMS	Energy Monthly Savings, BTU/Month
FIR	Fuel Inflation Rate, %
FRD	Deviated Fuel Inflation Rate, %

FRU	HRU Fraction
GIR	General Inflation Rate, %
GPD	Hot Water Demand, Gal./Day
GPM	Hot Water Demand, Gal./Month
IPD	Percent Deviation, %
MTH	Month
N	Expected Life of the System, Years
NDM	Days Per Month
P	First Cost After Tax Credit, \$
PFC	Persent Fuel Cost, \$/KWHR.
PWD	Present Worth at a Given DSR, \$
PWN	Present Worth For Payback Calculation, \$
PWR	Present Worth For ROR Calculation, \$
QCD	Condenser Rejected Heat, BTU/Hr.
R	Maintenance Cost, \$/Year
ROR	Rate of Return, %
S1,S2	System Energy Source
SP	Simple Payback, Years
TXC	Tax Credit, \$
WST	Hot Water Temperature Setting, °F
WTR	Water Temperature Rise, °F

## FLOWCHART OF WHRSC





```

$JOB
DIMENSION DPs(10),FRS(10),FFS(10),DRS(10)
READ(5,10)M, ID, IY, P1, P2, P3, P4, P5, L1, L2, L3, L4, N1, N2, N3, N4
10 FORMAT(2I2, I4, 13A4)
WRITE(6,15)M, ID, IY, P1, P2, P3, P4, P5, L1, L2, L3, L4, N1, N2, N3, N4
15 FORMAT('1', ,22(/),52X,'DATE' : ',2(I2,'/'),I4,4(/),52X,'PR
1 OBJECT : ',
2 5A4,4(/),52X,'LOCATION : ',4A4,4(/),52X,'NAME : ',4A4)
AES=0.0
ADS=0.0
BPY=0.0
EYS=0.0
READ(5,20)S1,S2,PFC,AIC,EMC,ANC,ACR,CFR,N,FIR,GIR,DSR,TXC,EFF,EER
20 FORMAT(2A4,F5.3,F8.2,F4.1,3F6.3,I2,4F5.2,F5.1,F7.3)
T=N
EMC=EMC/100.
TXC=TXC/100.
EFF=EFF/100.
CCC=ANC
ANC=ANC*12000.
IF(CFR.EQ.0.0.AND.EER.EQ.0.0)CFR=ACR+AFR
IF(CFR.EQ.0.0.AND.EER.NE.0.0)CFR=(ANC/EER)/1000.
IF(ACR.EQ.0.0)ACR=0.80*CFR
EER=ANC/(CFR*1000.)
WRITE(6,25)S1,S2,PFC,CCC,EER
25 FORMAT('1', ,4(/),50X,'THERMAL ANALYSIS SUMMARY REPORT',/,50X,
131(' '),
2 //7,15X,'CONVENTIONAL SYSTEM ENERGY SOURCE : ',2A4,/,15X,'CON
VENTIONAL SYSTEM FUEL COST : ',F5.3,' $/KWHR',/,15X,'A/C NOMIN
3AL CAPACITY : ',F6.3,' TONS',/,15X,'ENERGY EFFICIENCY RATIO (E
4ER) : ',F7.3,/,15X,104(' '),/,15X,'MONTH',6X,'DAYS/MONTH',6X,'
5HOT WATER DEMAND',10X,'A/C USAGE',13X,'SAVINGS',10X,'HRU FRACTION'
6',/,42X,'GAL/M',6X,'BTU/M',6X,'KWHR/M',5X,'HRS/M',6X,'RTU/M',5X,'$/
7M',/,15X,104(' -'))
DO 100 I=1,12
READ(5,30)MTH,NDM,GPD,CWT,WST,AMD,ART
30 FORMAT(A3,I2,F6.1,F4.1,F5.1,F3.1,F5.2)
WTR=WST-CWT
GPM=GPD*NDM
RPM=(GPM*WTR*8.3)/EFF
AOP=AMD/CFR
IF(AMD.EQ.999999.9)AOP=ART*NDM
AMD=ACP*CFR
QCD=ANC+(ACR*3413.0)
EMS=(C.25)*QCD*AOP
IF(EMS.GT.BPM)EMS=BPM
FRA=EMS/BPM
DMS=(EMS*PFC)/3413.0
AFS=AES+EMS
ADS=ADS+DMS
BPY=BPY+BPM
EYS=EYS+EMS
WRITE(6,35)MTH,NDM,GPM,BPM,AMD,AOP,EMS,DMS,FRA
35 FORMAT(/,16X,A3,11X,I2,9X,F7.1,3X,E9.3,3X,F7.1,5X,F5.1,4X,E9.3,2X,
1F6.2,10X,F5.3)
100 CONTINUE
AFR=EYS/BPY
WRITE(6,45)BPY,ADS,AFR
45 FORMAT(/,15X,104(' '),/,15X,'ANNUAL HEATING LOAD = ',E10.4,' BT
1U',/,15X,'ANNUAL SAVINGS = $ ',F8.2,/,15X,'HRU ANNUAL FRACTION

2= ',F5.3)
P=AIC-(TXC*AIC)
WRITE(6,55)FIR,GIR,DSR,P,N
55 FORMAT('1', ,4(/),50X,'ECONOMIC ANALYSIS SUMMARY REPORT',/,50X
1,32(' '),
2 //7,15X,'FUEL INFLATION RATE : ',F5.2,' %',/,15X,'GENERAL I
NFLATION RATE : ',F5.2,' %',/,15X,'DISCOUNT RATE : ',F5.2,'
3% ',/,15X,'NET SYSTEM COST : ',F8.2,/,15X,
4'EXPECTED LIFE OF THE SYSTEM : ',I2,' YEARS',/,15X,
5103(' '),/,15X,'FUEL ESCL RATE',14X,'RATE OF RETURN',19X,'DISCOUN
6T RATE',15X,'PAYBACK',/,15X,'% DEV',4X,'VALUE',7X,'INCL GEN INFL',
72X,'EXCL GEN INFL',7X,'PRES WORTH',3X,'DESIRABLE',7X,'SIMPLE',2X,'
7DISCOUNTED',/,15X,103(' -'))
FIR=FIR/100.
GIR=GIR/100.
DSR=DSR/100.
R=EMC*AIC
SP=P/(ADS-R)

```

```

K=0
DO 200 J=70,130,15
FRD=FIR*J
FFF=FRD/100.
K=K+1
FRS(K)=FFF
FFS(K)=FRD
IPD=J-100
DO 300 I=1,1000
AIR=I/100.
PWR=SAVE(ADS,FFF,AIR,GIR,R,T)-P
IF(PWR.LE.0.0)GO TO 250
300 CONTINUE
250 IF(PWR.EQ.0.0)GO TO 360
AIR=AIR-0.01
RRR=AIR
DO 350 I=1,1000
X=I/1000.
AIR=(AIR+X)
PWR=SAVE(ADS,FFF,AIR,GIR,R,T)-P
IF(PWR.LE.0.0)GO TO 360
350 CONTINUE
360 POR=((1.+AIR)/(1.+GIR))-1.*100.
AIR=AIR*100.
DO 400 I=1,1000
DP=I
PWN=SAVE(ADS,FFF,DSR,GIR,R,DP)-P
IF(PWN.GE.0.0)GO TO 450
400 CONTINUE
450 IF(PWN.EQ.0.0)GO TO 460
DP=DP-1.
DDD=DP
DO 410 I=1,10
X=I/10.
DP=(DP+X)
PWN=SAVE(ADS,FFF,DSR,GIR,R,DP)-P
IF(PWN.GE.0.0)GO TO 460
410 CONTINUE
460 PWD=SAVE(ADS,FFF,DSR,GIR,R,T)-P
IF(PWD.LE.0.0.AND.DP.GT.N)GO TO 561

IF(PWD.LE.0.0.AND.DP.LE.N)GO TO 560
IF(PWD.GT.0.0.AND.DP.GT.N)GO TO 562
WRITE(6,65)IPD,FRD,AIR,RRR,PWD,SP,DP
65 FORMAT(/,16X,I3,' X',3X,F4.1,' X',10X,F5.1,' X',8X,F5.1,' X',8X,' $
1 ',F8.2,7X,'YES',11X,F4.1,5X,F5.1)
GO TO 200
561 WRITE(6,76)IPD,FRD,AIR,RRR,PWD,SP
76 FORMAT(/,16X,I3,' X',3X,F4.1,' X',10X,F5.1,' X',8X,F5.1,' X',8X,' $
1 ',F8.2,7X,'NO',12X,F4.1,2X,'GTR SYS LIFE')
GO TO 200
560 WRITE(6,75)IPD,FRD,AIR,RRR,PWD,SP,DP
75 FORMAT(/,16X,I3,' X',3X,F4.1,' X',10X,F5.1,' X',8X,F5.1,' X',8X,' $
1 ',F8.2,7X,'NO',12X,F4.1,5X,F5.1)
GO TO 200
562 WRITE(6,66)IPD,FRD,AIR,RRR,PWD,SP
66 FORMAT(/,16X,I3,' X',3X,F4.1,' X',10X,F5.1,' X',8X,F5.1,' X',8X,' $
1 ',F8.2,7X,'YES',11X,F4.1,2X,'GTR SYS LIFE')
200 CONTINUE
WRITE(6,85)
85 FORMAT(/,15X,103(' '))
WRITE(6,95) (FFS(JT),J=1,5)
95 FORMAT('1',4(/),29X,'SENSITIVITY OF DISCOUNTED PAYBACK TO FU
1 EL ESCALATION RATE AND DISCOUNT RATE',
2 /,29X,74(' '),///,15X,8(' '),14
2 X,78(' '),//,15X,'DISCOUNT',42X,'FUEL ESCALATION RATE',/,37X,78(' -
3 )//,17X,'RATE',16X,5(F4.1,' X',12X),/,15X,8(' -'),14X,78(' -'))
SSS=2.5
DO 600 I=1,5
SSS=SSS+2.5
DRS(I)=SSS/100.0
DO 610 J=1,5
DO 620 M=1,100
DPS(J)=M
PWN=SAVE(ADS,FRS(J),DRS(I),GIR,R,DPS(J))-P
IF(PWN.GE.0.0)GO TO 625
620 CONTINUE
625 IF(PWN.EQ.0.0)GO TO 610
DPS(J)=DPS(J)-1.0
DDD=DPS(J)
DO 630 M=1,10

```

```

X=M/10.0
DPS(J)=DPS(J)+X
PWN=SAVE(AJS,FRS(J),DRS(I),GIR,R,DPS(J))-P
IF(PWN.GE.0.0) GO TO 610
DPS(J)=DDD
630 CONTINUE
610 CONTINUE
DRS(I)=DRS(I)*100.0
WRITE(6,99)DRS(I),(DPS(J),J=1,5)
99 FORMAT(/,17X,F4.1,'%',14X,5(F5.1,13X))
600 CONTINUE
WRITE(6,98)
98 FORMAT(/,15X,8(' '),14X,78(' '))
STOP
END

```

```

FUNCTION SAVE(A,ER,AR,FR,R,T)
IF(AR.NE.ER.AND.AR.NE.FR)GO TO 1
IF(AR.EQ.ER.AND.AR.NE.FR)GO TO 2
IF(AR.NE.ER.AND.AR.EQ.FR)GO TO 3

```

```

SAVE=T*(A-P)
GO TO 4
1 Z=A*((1.+ER)/(AR-ER))*(1.-((1.+ER)/(1.+AR))**T)
Y=R*((1.+FR)/(AR-FR))*(1.-((1.+FR)/(1.+AR))**T)
SAVE=Z-Y
GO TO 4
2 Y=R*((1.+FR)/(AR-FR))*(1.-((1.+FR)/(1.+AR))**T)
SAVE=(T*A)-Y
GO TO 4
3 Z=A*((1.+ER)/(AR-ER))*(1.-((1.+ER)/(1.+AR))**T)
SAVE=Z-(T*R)
4 RETURN
END

```

ENTRY



APPENDIX C

## WHRSC WORKSHEET

## 1. Project Data

- . Date: Month 04, Day 25, Year 1981.
- . Project Name: Hot Water Recovery-----.
- . Location: Orlando, Florida-----.
- . Name: Harold I. Klee-----.
- . Address: 8639 Portside Court  
Orlando, Fl. 32807-----.

## 2. Conventional System Data

- . System Energy Source: Electric-----.
- . Efficiency (100% if Electric): \* 100-----%.
- . Present System Fuel Cost: 0.06-----\$/Kwhr.

## 3. Heat Recovery System Cost

- . Total Installed Cost: 580.00-----\$.
- . First Year Operating & Maintenance Cost: \* 2.0-----% of Initial Investment.

## 4. A/C Data

- . A/C Unit Manufacturer: General Electric-----.
- . Model Number:-----.
- . Serial Number:-----.
- . A/C Nominal Capacity: 3.833-----Tons.
- . Energy Efficiency Ratio (EER): 0.0-----.
- (Enter 0.0 if Unknown)
- . A/C Compressor Rating: \* 5.2-----KW.
- (If EER known, Skip Next Item)

. A/C Combined Compressor and Fans Rating: \*---6.3---KW.

5. Hot Water Load

Month	Days Month	Hot Water Demand Gal./Day	City Water Temperature * OF	Hot Water Temp. Setting * OF
Jan.	31	<u>45</u>	<u>70</u>	<u>140</u>
Feb.	28	<u>45</u>	<u>70</u>	<u>140</u>
Mar.	31	<u>45</u>	<u>70</u>	<u>140</u>
Apr.	30	<u>45</u>	<u>70</u>	<u>140</u>
May	31	<u>45</u>	<u>70</u>	<u>140</u>
Jun.	30	<u>45</u>	<u>70</u>	<u>140</u>
Jul.	31	<u>45</u>	<u>70</u>	<u>140</u>
Aug.	31	<u>45</u>	<u>70</u>	<u>140</u>
Sep.	30	<u>45</u>	<u>70</u>	<u>140</u>
Oct.	31	<u>45</u>	<u>70</u>	<u>140</u>
Nov.	30	<u>45</u>	<u>70</u>	<u>140</u>
Dec.	31	<u>45</u>	<u>70</u>	<u>140</u>

## 6. A/C Demand

If previous years utility bills are not available, fill only the last column.

Month	Monthly Utility Bills				A/C Hours Day
	19 <u>78</u>	19 <u>79</u>	19 <u>80</u>	19 <u>81</u>	
	Date Read	<u>19</u>	<u>21</u>	<u>27</u>	
Jan.	Kwhr.	<u>1026</u>	<u>1211</u>	<u>1604</u>	
	Days	<u>32</u>	<u>34</u>	<u>28</u>	
	Date Read	<u>16</u>		<u>25</u>	
Feb.	Kwhr.	<u>1131</u>		<u>1043</u>	
	Days	<u>28</u>		<u>29</u>	
	Date Read	<u>19</u>	<u>18</u>	<u>26</u>	
Mar.	Kwhr.	<u>929</u>	<u>847</u>	<u>777</u>	
	Days	<u>31</u>	<u>28</u>	<u>29</u>	
	Date Read	<u>23</u>	<u>18</u>	<u>28</u>	
Apr.	Kwhr.	<u>1134</u>	<u>986</u>	<u>969</u>	
	Days	<u>35</u>	<u>31</u>	<u>33</u>	
	Date Read	<u>18</u>	<u>16</u>		
May	Kwhr.	<u>1050</u>	<u>1032</u>		
	Days	<u>25</u>	<u>28</u>		

Month	Monthly Utility Bills				A/C Hours Day
	1978	1979	1980	1981	
	Date Read				
Jun.	Kwhr.				
	Days				
	Date Read				
Jul.	Kwhr.				
	Days				
	Date Read				
Aug.	Kwhr.				
	Days				
	Date Read				
Sep.	Kwhr.				
	Days				
	Date Read				
Oct.	Kwhr.				
	Days				
	Date Reat				
Nov.	Kwhr.				
	Days				

Month	Monthly Utility Bills				A/C Hours Day
	1978	1979	1980	1981	
Date Read	<u>18</u>	<u>18</u>	_____	_____	
Dec. Kwhr.	<u>1083</u>	<u>868</u>	_____	_____	
Days	<u>31</u>	<u>28</u>	_____	_____	_____

#### 7. Economic Analysis Parameters

- . Expected Life of the System: \* 20 years
- . Fuel Inflation Rate: \* 13.0 %/year
- . General Inflation Rate: \* 10.0 %/year
- . Discount Rate: 5.25 %/year  
(Interest Rate on Your Best Available Investment)
- . Tax Credit if Any: 15.0 % of the initial cost

## REFERENCES

1. Chandra, S. "A Guide to Solar Water Heating in Florida."  
Cape Canaveral: Florida Solar Energy Center, 1978, p. 2.
2. Wetherington, T. I. "Heat Recovery Water Heating." In  
Proceedings of the 15th Annual Air Conditioning Conference,  
p. 3. Gainesville, Fl: University of Florida.
3. Klee, H. "Performance of Residential Heat Recovery Systems."  
Orlando, Fl: University of Central Florida, May 1980,  
p.4.
4. RSVP. Springfield, VA: National Solar Heating and Information  
Center.
5. SOLCOST. Washington, DC: International Service Business, Inc.,  
June 1978.
6. Chandra, S. "Analysis of Heat Recovery Units (HRU) and  
Dedicated Heat Pump Hot Water Heaters in Florida."  
Cape Canaveral: Florida Solar Energy Center, March 1980.
7. Canada, J., and White, J. Capital Investment Decision Analysis  
For Management and Engineering. Englewood Cliffs, NJ:  
Prentice-Hall, INC., 1980.
8. Howell, Y., and Bereny, A. Engineer's Guide to Solar Energy.  
San Mateo, CA: Solar Energy Information Services, 1979,  
p. 193.