

This is a repository copy of Survey on time-delay approach to networked control.

White Rose Research Online URL for this paper: http://eprints.whiterose.ac.uk/153531/

Version: Accepted Version

## Article:

Liu, K., Selivanov, A. orcid.org/0000-0001-5075-7229 and Fridman, E. (2019) Survey on time-delay approach to networked control. Annual Reviews in Control. ISSN 1367-5788

https://doi.org/10.1016/j.arcontrol.2019.06.005

Article available under the terms of the CC-BY-NC-ND licence (https://creativecommons.org/licenses/by-nc-nd/4.0/).

## Reuse

This article is distributed under the terms of the Creative Commons Attribution-NonCommercial-NoDerivs (CC BY-NC-ND) licence. This licence only allows you to download this work and share it with others as long as you credit the authors, but you can't change the article in any way or use it commercially. More information and the full terms of the licence here: https://creativecommons.org/licenses/

## Takedown

If you consider content in White Rose Research Online to be in breach of UK law, please notify us by emailing eprints@whiterose.ac.uk including the URL of the record and the reason for the withdrawal request.



eprints@whiterose.ac.uk https://eprints.whiterose.ac.uk/

## Survey on Time-delay Approach to Networked Control

Kun Liu<sup>a</sup>, Anton Selivanov<sup>b</sup>, Emilia Fridman<sup>c</sup>

<sup>a</sup>School of Automation, Beijing Institute of Technology, 100081 Beijing, P.R.China

<sup>b</sup>School of Electrical Engineering and Computer Science, Royal Institute of Technology, Stockholm 10044, Sweden

<sup>c</sup>School of Electrical Engineering, Tel Aviv University, Tel Aviv 69978, Israel

#### Abstract

This paper provides a survey on time-delay approach to networked control systems (NCSs). The survey begins from a brief summary on fundamental network-induced issues in NCSs and the main approaches to the modelling of NCSs. In particular, a comprehensive introduction to time-delay approach to sampled-data and networked control is provided. Then, recent results on time-delay approach to event-triggered control are recalled. The survey highlights time-delay approach developed to modelling, analysis and synthesis of NCSs, under communication constraints, with a particular focus on Round-Robin, Try-once-discard and stochastic protocols. The time-delay approach allows communication delays to be larger than the sampling intervals in the presence of scheduling protocols. Moreover, some results on networked control of distributed parameter systems are surveyed. Finally, conclusions and some future research directions are briefly addressed.

Key words: Networked control systems, time-delay approach, event-triggered control, distributed parameter systems, scheduling protocols.

#### 1 Introduction to NCSs

The point-to-point architecture is the traditional communication architecture for control systems, that is, sensors and/or actuators are connected to controllers via wires. Due to the expansion of physical setups and functionality, a traditional point-to-point architecture is no longer able to meet new requirements, such as modularity, integrated diagnostics, quick and easy maintenance, and low cost. Such requirements are particularly demanding in the control of complex control systems [21, 37] and remote control systems [13, 110, 114, 170].

To satisfy these new requirements, common-bus network architectures have been introduced. The common-bus network architectures can improve the efficiency, flexibility and reliability of integrated applications, and reduce installation, reconfiguration and maintenance time and costs [156]. It gives rise to the so-called networked control systems (NCSs) [8, 91, 95, 222, 250].

In general, NCSs are a type of distributed control systems where sensors, actuators, and controllers are intercon-

nected through a communication network. Sensors measure states of the plant and transmit these states over the communication network to controllers. The controllers receive these states, and calculate appropriate control actions and send them to actuators over the communication network. Actuators receive control actions and control the plant appropriately. Due to its low cost, flexibility, and less wiring, NCSs are rapidly increasing in industrial applications, including telecommunications, remote process control, altitude control of airplanes and so on [13, 37, 110, 114, 170].

In NCSs, the closed-loops are closed via communication networks. The insertion of the communication network in the feedback control loop makes the analysis and design of systems more complex than the traditional point-topoint architecture. The network can introduce unreliable and time-dependent levels of service in terms of, for example, delays, jitter, or losses. In general, network-induced imperfections can jeopardize the stability, safety, and performance of the units in a physical environment [100].

**Notations:** The symbols  $\mathbb{R}$ ,  $\mathbb{R}^+$ ,  $\mathbb{Z}^+$  and  $\mathbb{N}$  denote the set of real numbers, non-negative real numbers, non-negative integers and positive integers, respectively.  $\mathbb{R}^n$  denotes the n dimensional Euclidean space with vector norm  $|\cdot|$ ,  $\mathbb{R}^{n \times m}$  is the set of all  $n \times m$  real matrices, and the notation

Email addresses: kunliubit@bit.edu.cn (Kun Liu),

antonselivanov@gmail.com (Anton Selivanov),

emilia@eng.tau.ac.il (Emilia Fridman).

$$\begin{split} P &> 0 (\geq 0), \text{ for } P \in \mathbb{R}^{n \times n} \text{ means that } P \text{ is symmetric and positive definite (semi-positive-definite). The symmetric term in a symmetric matrix is denoted by *. The superscript 'T' stands for matrix transposition. For <math>x : \mathbb{R} \to \mathbb{R}^n$$
, we denote  $x_t(\theta) \triangleq x(t+\theta), \theta \in [-h, 0]$ . The symbol  $L_p(a, b), p \in \mathbb{N}$ , denotes the space of functions  $\phi : (a, b) \to \mathbb{R}^n$  with the norm  $\|\phi\|_{L_p} = \left[\int_a^b |\phi(s)|^p ds\right]^{\frac{1}{p}}$ . The space of functions  $\phi : [a, b] \to \mathbb{R}^n$ , which are absolutely continuous on [a, b], and have square integrable first order derivatives is denoted by W[a, b] with the norm  $\|\phi\|_W = \max_{\theta \in [a,b]} |\phi(\theta)| + \left[\int_a^b |\dot{\phi}(s)|^2 ds\right]^{\frac{1}{2}}$ .

#### 2 Fundamental Issues in NCSs

The main network-induced imperfections and constraints can be categorized in the following five types [88,255]:

## (i) Variable sampling/transmission intervals

Conventional computer-controlled systems theories assume equal-distance sampling of the plant outputs, which means the samples are taken periodically at the time instants  $kh, k \in \mathbb{Z}^+$ , where h > 0 is the constant sampling period. This assumption leads to linear time-invariant (LTI) sampled-data systems and greatly simplifies the stability and performance analysis [249].

However, the assumption of equal-distance sampling should not be imposed on the NCSs analysis. To transmit a continuous-time signal over a network, the signal must be sampled, encoded in a digital format, transmitted over the network, and finally the data must be decoded at the receiver side. This process is significantly different from the usual periodic sampling in digital control. A significant number of results have attempted to characterize maximum allowable transmission interval (MATI) for which stability can be guaranteed [88, 94, 151].

Moreover, in contrast to periodic sampling control, eventbased control aims at minimizing the bandwidth utilization while still guaranteeing the desired level of control performance. There are two main triggering strategies, one is event-triggering strategy (see e.g., [16, 141, 211]) and the other is self-triggering strategy (see e.g., [84, 144, 225]). The difference between event-triggering strategy and selftriggering strategy is that the former is reactive, while the latter is proactive. In event-triggering strategy, a triggering condition based on current measurements is monitored and when violated, an event is triggered. In self-triggering strategy, the next updating time is pre-computed at a control updating time based on predictions using previously received data and knowledge on the plant dynamics [85]. Thus, growing attention is paid to event-based control for NCSs, e.g., see [165–168, 178, 226, 241] for event-triggered control over networks, and see [5, 7, 155, 203, 247] for selftriggered control over networks.

#### (ii) Communication delay/network-induced delay

The network-induced delay, including sensor-to-controller delay and controller-to-actuator delay, that happens when data exchange among devices connected by the communication network, which will deteriorate the system performance as well as stability. This delay, depending on the network characteristics such as network load, topologies, routing schemes, can be constant, time-varying, or even random [25, 38, 39, 50, 88, 122, 123, 143, 171, 235]. In the literature, two ways of modeling network-induced uncertainties can be distinguished.

- The first approach bounds the network-induced delay and considers maximum allowable delay (MAD). The NCSs are modeled as discrete-time (uncertain) systems [25, 250], time-delay systems [64, 65, 121, 122, 205, 238], hybrid systems [86, 88] or switched systems [205, 252].
- The second one is stochastic modeling approach. By assuming that network-induced delay has a known probability distribution function [97,154], or incorporating the network-induced delays as Markov process [99,198,199, 248], the resulting closed-loop is modeled as a stochastic system.

For some systems, the presence of communication delay may have the positive effect on system performance [56,57], e.g., see [122, 184] for sampled-data stabilization, and see [237] for consensus of multi-agent systems.

# $(iii)\ Packet\ dropouts\ caused\ by\ the\ unreliability\ of\ the\ network$

Another significant difference between NCSs and standard digital control is the possibility that some packets not only suffer transmission delays but, even worse, may be lost while in transit through the network. Typically, packet dropouts result from transmission errors in physical network links (which is far more common in wireless than in wired networks) or from buffer overflows due to congestion. Thus, how much packet dropouts affect stability and performance of NCSs is an issue that must be considered [96, 232, 233].

In general, in most of the literature two different strategies are considered for dealing with packet dropouts. The first one is zero-input, i.e., the actuator input to the plant is set to zero when the control packet from the controller to the actuator is lost [101]. The second one is hold-input, i.e., the latest control input stored in the actuator buffer is used when a packet is lost [250]. By studying linear quadratic performance of NCSs where control packets are subject to loss, in [174] it was shown that none of these two control schemes can be claimed to be superior to the other.

Different control techniques have been developed for the modeling of NCSs with data packet dropouts. They can be

roughly categorized into the following types based on the resulting closed-loop systems:

- Switching systems [102, 251], asynchronous dynamical systems [250], and jump linear systems with Markov chains [174, 175]. Note that packet dropouts defined in the aforementioned references have two cases, dropped or sent successfully, which are modeled as a Bernoulli or a two-state Markov chain process based on zero-input or hold-input.
- Another type of the resulting closed-loop system is in terms of time-delay systems [65, 236]. By modeling dropouts as prolongations of the variable sampling intervals or communication delays, the NCSs with data packet dropouts are modeled as linear systems with time-varying input delays based on hold-input strategy. Then the delay-dependent approach can be applied to the resulting time-delay systems and the maximum allowable value of the successive packet dropouts can be determined by solving a set of linear matrix inequalities (LMIs).

#### (iv) Quantization errors in the signals transmitted over the network due to the finite word length of the packets

Due to the limited transmission capacity of the network, data transmitted in practical NCSs should be quantized before they are sent to the next network node [53,151,230]. A quantizer is a function that maps a real-valued function into a piecewise constant function taking on a finite set of values. At present, there exist two kinds of quantizers, which are uniform quantizers [20] and logarithmic ones [36].

- The uniform quantizer maps real-valued function to a finite number of quantization regions with rectilinear shape [20] or arbitrary shape [118, 119, 127, 151]. The study of system affected by uniform quantizer is usually based on "zoom" strategy, which is composed of two stages, i.e., "zooming-out" and "zooming-in". In the first stage, the range of quantizer is increased to guarantee the states of system can be adequately measured. In the second stage, the quantization error is decreased to drive the states to the origin.
- When system is affected by logarithmic quantizer, in which the quantization levels are linear in logarithmic scale, the simple classical approach to analysis and mitigation of quantization effects is to treat the quantization error as uncertainty or nonlinearity and bound it using a sector bound [62, 65, 239].

#### (v) Communication scheduling

In NCSs, the performance of control loops not only depend on the design of the control algorithms, but also rely on the scheduling of the shared network resource. The communication constraints impose that, per transmission, only one node can access the network and send its information.



Fig. 1. Schematic diagram of a NCS

Hence, many existing works are focused on that how often a plant should schedule to transmit the data and with what priority the packet should be sent out. There are three main classes of network protocols, namely:

- The class of static protocols, of which Round-Robin protocol is a special case [31,88,125,151,152]. In the Round-Robin protocol, the node *j* is transmitted periodically with period *l*, where *l* is the total number of nodes. The transmission order is decided in advance and this order is repeated indefinitely.
- The class of dynamic protocols, which includes the well-known try-once-discard (TOD) protocol [31, 88, 126, 151, 152]. In the TOD protocol, the node that has the largest network-induced error, i.e., the largest difference between the latest transmitted values and the current values of the signals corresponding to the node, is granted access to the network.

It was observed in some examples that the TOD protocol stabilized the system for larger MATI than the Round-Robin protocol whenever l > 1 [152,221], in some examples opposite conclusions were made [43,126].

• The stochastic protocol, which was introduced in [30, 210]. The stochastic protocol determines the transmitted node through a Bernoulli or a two-state Markov chain process [128, 256]. The quadratic and stochastic protocols belong to dynamic protocols.

#### 3 Three Main Approaches to NCSs

Consider a generic schematic diagram of NCSs as shown in Fig. 1. The LTI continuous-time plant is given by

$$\dot{x}(t) = Ax(t) + Bu(t), \tag{1}$$

where  $x(t) \in \mathbb{R}^n$  is the state vector,  $u(t) \in \mathbb{R}^{n_u}$  is the control input,  $A \in \mathbb{R}^{n \times n}$  and  $B \in \mathbb{R}^{n \times n_u}$  are system matrices with appropriate dimensions. Consider, for simplicity, the state-feedback case.

Let  $s_k$  denote the unbounded monotonously increasing sequence of sampling instants, i.e.,

$$0 = s_0 < s_1 < \dots < s_k < \dots, \quad k \in \mathbb{Z}^+, \quad \lim_{k \to \infty} s_k = \infty$$

with the time-varying sampling intervals  $h_k = s_{k+1} - s_k > 0$ . There are two sources of delays from the network: sensorto controller  $\eta_k^{sc}$  and controller-to-actuator  $\eta_k^{ca}$ . It is assumed that the sensor acts in a time-driven fashion (i.e., sampling occurs at the times  $s_k$ ,  $k \in \mathbb{Z}^+$ ) and that both the controller and the actuator act in an event-driven fashion (i.e., they respond instantaneously to newly arrived data). Under these assumptions, the two delays can be captured by a singe delay  $\eta_k = \eta_k^{sc} + \eta_k^{ca}$ . Assume that  $\eta_k \in [\eta_m, \text{ MAD}]$ , where  $\eta_m$  and MAD denote the lower and upper delay bounds on the network-induced delays  $\eta_k$ , respectively. Denote by  $t_k = s_k + \eta_k$  the updating instant time of the zero-order-hold (ZOH), finally the ZOH function transforms the discrete-time control input  $u_k$  to a continuous-time control input

$$u(t) = u_k = Kx(s_k), \ t \in [t_k, t_{k+1}), \ k \in \mathbb{Z}^+.$$
 (2)

The resulting closed-loop system is (1), (2):

$$\dot{x}(t) = Ax(t) + BKx(s_k), \ t \in [t_k, t_{k+1}), \ k \in \mathbb{Z}^+.$$
 (3)

In the literature, three main approaches have been used to the sampled-data control (see e.g., [11,14,22,35,50,93,146, 200]) and later to the NCSs.

#### 3.1 Discrete-time Modeling Approach

For the sake of clarity, we focus here on the case of small network-induced delays, where these delays are smaller than the sampling intervals, i.e.,  $\eta_k = t_k - s_k < h_k, k \in \mathbb{Z}^+$ . The most common discrete-time NCS model is explained in e.g., [153, 250]. The discrete-time uncertain system can be obtained by describing the evolution of the states between  $s_k$  and  $s_{k+1} = s_k + h_k$ . Discretizing the linear plant (1) at the sampling time  $s_k, k \in \mathbb{Z}^+$ , we obtain (see e.g., [25, 31])

$$\begin{aligned} x(s_{k+1}) &= e^{Ah_k} x(s_k) + \int_0^{h_k - \eta_k} e^{As} ds Bu_k \\ &+ \int_{h_k - \eta_k}^{h_k} e^{As} ds Bu_{k-1}. \end{aligned}$$

Using now the state vector

$$\xi(s_k) = [x^T(s_k) \ u_{k-1}^T]^T$$

that includes the current system state and the past system input, we obtain the following discrete model

$$\xi(s_{k+1}) = \begin{bmatrix} e^{Ah_k} \int_{h_k-\eta_k}^{h_k} e^{As} dsB \\ 0 & 0 \end{bmatrix} \xi(s_k) + \begin{bmatrix} \int_0^{h_k-\eta_k} e^{As} dsB \\ I \end{bmatrix} u_k$$

$$= \tilde{A}_{h_k,\eta_k} \xi(s_k),$$

$$(4)$$

where

$$\tilde{A}_{h_k,\eta_k} = \begin{bmatrix} e^{Ah_k} + \int_0^{h_k - \eta_k} e^{As} ds BK & \int_{h_k - \eta_k}^{h_k} e^{As} ds B \\ K & 0 \end{bmatrix}.$$

Hence, the stability analysis for the uncertain system (4) with the uncertainty  $\eta_k \in [\eta_m, \text{ MAD}], h_k \in (0, \text{ MATI}]$  is essentially a robust stability analysis problem. Then,

the obstruction to apply existing robust stability analysis techniques directly is that the uncertainty appears in an exponential fashion in  $A_{h_k,\eta_k}$  of (4). To make the formulation (4) suitable for robust stability analysis, overapproximation techniques are employed in the literature to embed the original model (as tight as possible) in a larger model that has nice structural properties suitable for the application of robust stability methods. Adopted over-approximation techniques are based on the real Jordan form [25–27, 219], the Taylor series [92], gridding and norm-bounding [63,201,204] and the Cayley-Hamilton theorem [68]. The over-approximation techniques typically result in discrete-time polytopic models [15, 89, 113] with (or without) additive norm-bounded uncertainties. These models are amendable for robust stability assessment using LMIs. In [89], a comparison was presented between the different over-approximation methods and the subsequent LMI-based stability analysis.

The most general and complete modeling based on discretetime approach was provided in [25] (see also [26, 27]) that includes imperfection types (i), (ii), (iii) of networkinduced uncertainties, i.e., time-varying sampling intervals, time-varying communication delays (both smaller and larger than the sampling interval) and explicit modeling of the dropouts.

In [32], the discrete-time modeling approach was further applied to the network-based stabilization including imperfection types (i), (iii), (v). In [31], small delays are taken into account. The work of [31] was extended in [220] by including quantization, where quantization-induced disturbances were incorporated as one of the stability and performance limiting factors. A state-dependent sampling approach was introduced in [40] for the stabilization of sampled-data systems to reduce the number of computations.

For LTI systems, as was shown in e.g., [31], the discretetime approach can lead to less conservative results in terms of the so-called MATI and the MAD. However, discretetime methods become complicated for systems with uncertain coefficients. Moreover, it is tedious to include large delays (that are larger than the sampling intervals) in such models and the stability analysis methods may fail when the interval between two transmissions takes small values. In this case, one can resort to the delta operator approach proposed in [70] and [145].

#### 3.2 Impulsive System Approach

The second approach is based on the representation of the system in the form of hybrid/impulsive system [200]. Impulsive dynamical systems exhibit continuous evolutions described by ordinary differential equations and instantaneous state jumps or impulses (see e.g., [69]).

The idea of the impulsive system approach is to rewrite its closed-loop system (3) as the following delay impulsive system

$$\dot{\xi}(t) = \begin{bmatrix} A & BK \\ 0 & 0 \end{bmatrix} \xi(t), \quad t \in [t_k, t_{k+1}),$$

$$\xi(t_k) = \begin{bmatrix} x(t_k^-) \\ x(s_k) \end{bmatrix}, \quad k \in \mathbb{Z}^+,$$
(5)

where  $\xi(t) = [x^T(t) \ z^T(t)]^T$ ,  $z(t) = x(s_k)$ ,  $t \in [t_k, t_{k+1})$ .

In [150], the impulsive system approach was proposed to the analysis and control of sampled-data systems ( $\eta_k \equiv 0$ , i.e.,  $t_k = s_k, k \in \mathbb{Z}^+$ ) with variable sampling. A discontinuous Lyapunov functional, which is discontinuous at input update instants and is decreasing between discontinuities, is introduced. Later on in [149] the impulsive system approach was further extended to the modeling and analysis of NCSs with variable sampling and communication delays. This discontinuous Lyapunov function method improved the existing Lyapunov-based results in e.g., [46,64,65,238]. The main advantage of this modeling approach is the possibility to incorporate time-delays larger than the sampling interval without increasing model complexity, as is the case in the discrete-time modeling approach [23, 27].

Based on the impulsive system approach, the input-output stability properties of nonlinear NCSs have been studied in [152] for NCSs with imperfection types (i), (iii), (v). In [151], stabilization of nonlinear NCSs with dynamic quantization was studied. However, delays are not included in the analysis. In [88], the imperfection types (i), (ii), (iii), (v) were considered and the methods for computing the MATI and MAD were provided, for which the stability of a nonlinear system is ensured. A unifying modeling framework was provided in [86] to incorporate all the five types of networked-induced effects. Note that some of the mentioned results that study varying transmission intervals and/or varying communication delays can be extended to include imperfection type (iii), i.e., data packet dropouts phenomena as well by modeling dropouts as prolongations of the MATI [86]. In the above works, only small communication delays were considered.

#### 3.3 Time-delay Approach

Modelling of continuous-time systems with digital control in the form of continuous-time systems with delayed control input was introduced by [146]. The digital control law for sampled-data systems ( $\eta_k \equiv 0$ , i.e.,  $t_k = s_k$ ,  $k \in \mathbb{Z}^+$ ) may be represented as delayed control as follows:

$$u(t) = Kx(t_k) = Kx(t - (t - t_k)) = Kx(t - \tau(t)),$$
  
$$t_k \le t < t_{k+1}, \quad \tau(t) = t - t_k,$$

In this case, the closed-loop system becomes an infinitedimensional delay differential equation

$$\dot{x}(t) = Ax(t) + A_1 x(t - \tau(t)), \ t_k \le t < t_{k+1}, \ k \in \mathbb{Z}^+,$$
(6)

where  $A_1 = BK$ , the time-varying delay  $\tau(t) = t - t_k$  is piecewise linear with derivative  $\dot{\tau}(t) = 1$  for  $t \neq t_k$  (see Fig. 2). Moreover,  $\tau(t) \leq t_{k+1} - t_k = s_{k+1} - s_k =$  MATI for  $t_k \leq t < t_{k+1}$ . The stability of (6) can be established using Lyapunov-Razumikin or Lyapunov-Krasovskii Theorems. The time-delay approach was applied to robust sampleddata stabilization via Lyapunov-Krasovskii technique [55].

#### 3.3.1 Delay-dependent Analysis

The choice of Lyapunov-Krasovskii functionals (LKFs) (that we will call also Lyapunov functional) is crucial for deriving stability criteria [61]. The first delay-dependent (both, Krasovskii and Razumikhin-based) conditions were derived by using the relation

$$x(t - \tau(t)) = x(t) - \int_{t - \tau(t)}^{t} \dot{x}(s) ds$$
(7)

via different model transformations and by bounding the cross terms [109, 117, 158]. The widely used first model transformation, where (7) is substituted into (6) with  $\dot{x}(s)$  substituted by the right-hand side of (6), has the form

$$\dot{x}(t) = (A+A_1)x(t) - A_1 \int_{t-\tau(t)}^t [Ax(s) + A_1x(s-\tau(s))]ds.$$
(8)

Note that this transformation is valid for  $t - \tau(t) \ge t_0$ . The latter system is not equivalent to the original one possessing some additional dynamics [75, 107]. The stability of the transformed system (8) guarantees the stability of the original one, but not vice versa.

The first delay-dependent conditions treated only the slowly-varying delays with  $\dot{\tau} \leq d < 1$ , whereas the fast-varying delay (without any constraints on the delay derivative) was analyzed via Lyapunov-Razumikhin functions.

For the first time, systems with fast-varying delays were analyzed by using Krasovskii method in [58], via the descriptor model transformation introduced in [44]:

$$\dot{x}(t) = y(t), 0 = -y(t) + (A + A_1)x(t) - A_1 \int_{t-\tau(t)}^t y(s) ds.$$
(9)

The descriptor system (9) is equivalent to (6) in the sense of stability. In the descriptor approach,  $\dot{x}(t)$  is not substituted by the right-hand side of the differential equation. Instead, it is considered as an additional state variable of the resulting descriptor system (9). Therefore, the novelty of the descriptor approach is not in  $V = x^T(t)Px(t) + \dots$ (P > 0), but in  $\dot{V}$ , where  $\frac{d}{dt} \left[ x^T(t)Px(t) \right]$  is found as

$$\frac{d}{dt} \left[ x^{T}(t) P x(t) \right] 
= 2x^{T}(t) P \dot{x}(t) + 2[x^{T}(t) P_{2}^{T} + \dot{x}^{T}(t) P_{3}^{T}] 
\times [-\dot{x}(t) + (A + A_{1}) x(t) - A_{1} \int_{t-\tau(t)}^{t} \dot{x}(s) ds],$$
(10)

and where  $P_2 \in \mathbb{R}^{n \times n}$  and  $P_3 \in \mathbb{R}^{n \times n}$  are "slack variables". This leads to  $\dot{V} \leq -\gamma(|x(t)|^2 + |\dot{x}(t)|^2), \gamma > 0.$ 



Fig. 2. Sampled-data systems: piecewise-continuous time-delay

The descriptor method brought free-weighting matrices  $P_2$ and  $P_3$  into the Lyapunov-based analysis, which is based on the application of Finsler's Lemma (see [71] and [206]). The advantages of the descriptor method are:

- less conservative conditions (even without delay) for uncertain systems,
- "unifying" LMIs for the discrete-time and for the continuous-time systems, having almost the same form and the same advantages [59],
- simple conditions for neutral type systems can be derived (where the stability of the difference operator follows from LMIs) [45],
- design is obtained for systems with state, input and output delays by choosing  $P_3 = \varepsilon P_2$  with a tuning scalar parameter  $\varepsilon$  [208],
- simple delay-dependent conditions can be derived for diffusion partial differential equations [54].

Most of the recent Krasovskii-based results do not use model transformations and cross terms bounding. They are based on the application of Jensen's inequality (see e.g., [74]).

## 3.3.2 Simple Delay-dependent Conditions

The first Krasovskii-based LMI conditions for systems with fast-varying delays (without any restrictions on the delayderivative) were derived in [58] via the descriptor method. We differentiate  $x^{T}(t)Px(t)$  as in (10) along system (6) with MATI  $\triangleq h$ . To "compensate"  $\int_{t-\tau(t)}^{t} \dot{x}(s)ds$ , consider the double integral term [58]:

$$V_R(\dot{x}_t) = \int_{-h}^0 \int_{t+\theta}^t \dot{x}^T(s) R\dot{x}(s) ds d\theta, \ R > 0.$$

The term  $V_R$  can be rewritten equivalently as

$$V_R(\dot{x}_t) = \int_{t-h}^t (h+s-t)\dot{x}^T(s)R\dot{x}(s)ds.$$

Differentiating  $V_R(\dot{x}_t)$ , we obtain

$$\frac{d}{dt}V_{R}(\dot{x}_{t}) = -\int_{t-h}^{t} \dot{x}^{T}(s)R\dot{x}(s)ds + h\dot{x}^{T}(t)R\dot{x}(t)$$

$$= -\int_{t-\tau(t)}^{t} \dot{x}^{T}(s)R\dot{x}(s)ds + h\dot{x}^{T}(t)R\dot{x}(t)$$

$$-\int_{t-h}^{t-\tau(t)} \dot{x}^{T}(s)R\dot{x}(s)ds .$$
will be ignored

We apply further Jensen's inequality

$$\begin{aligned} &-\int_{t-\tau(t)}^t \dot{x}^T(s) R \dot{x}(s) ds \\ &\leq -\frac{1}{h} \int_{t-\tau(t)}^t \dot{x}^T(s) ds R \int_{t-\tau(t)}^t \dot{x}(s) ds. \end{aligned}$$

Then, for the Lyapunov functional

$$V(x(t), \dot{x}_t) = x^T(t)Px(t) + V_R(\dot{x}_t),$$

we find

$$\begin{split} \frac{d}{dt} V(x(t), \dot{x}_t) &\leq 2x^T(t) P \dot{x}(t) + h \dot{x}^T(t) R \dot{x}(t) \\ &- \frac{1}{h} \int_{t-\tau(t)}^t \dot{x}^T(s) ds R \int_{t-\tau(t)}^t \dot{x}(s) ds \\ &+ 2[x^T(t) P_2^T + \dot{x}^T(t) P_3^T] \\ &\times [(A + A_1) x(t) - A_1 \int_{t-\tau}^t \dot{x}(s) ds - \dot{x}(t)] \\ &\leq \eta^T(t) \Psi \eta(t) \\ &< -\varepsilon (|x(t)|^2 + |\dot{x}(t)|^2), \ \varepsilon > 0, \end{split}$$

where  $\eta(t) = \operatorname{col}\{x(t), \dot{x}(t), \frac{1}{h} \int_{t-\tau}^{t} \dot{x}(s) ds\}$ , if

$$\Psi = \begin{bmatrix} \Phi & P - P_2^T + (A + A_1)^T P_3 & -hP_2^T A_1 \\ * & -P_3 - P_3^T + hR & -hP_3^T A_1 \\ * & * & -hR \end{bmatrix} < 0,$$
  
$$\Phi = P_2^T (A + A_1) + (A + A_1)^T P_2.$$

As it was understood later [54, 207], the equivalent delaydependent conditions can be derived without the descriptor method, where  $\dot{x}$  is substituted by the right-hand side of (6) and the Schur complements is applied further.

Note that  $\Psi < 0$  yields that the eigenvalues of  $hA_1$  are inside of the unit circle. In the example  $\dot{x}(t) = -x(t - \tau(t))$  with  $A_1 = -1$ , the simple delay-dependent conditions cannot guarantee the stability for  $h \ge 1$ , which is far from the analytical bound 1.5. This illustrates the conservatism of the simple conditions.

#### 3.3.3 Improved Delay-dependent Conditions

The relation between  $x(t - \tau(t))$  and x(t - h) (and not only between  $x(t - \tau(t))$  and x(t)) has been taken into account in [80]. The widely used by now LKF for delaydependent stability is state-derivative dependent one of the form

$$V(t, x_t, \dot{x}_t) = x^T(t) P x(t) + \int_{t-h}^t x^T(s) S x(s) ds + h \int_{-h}^0 \int_{t+\theta}^t \dot{x}^T(s) R \dot{x}(s) ds d\theta + \int_{t-\tau(t)}^t x^T(s) Q x(s) ds,$$
(11)

where P > 0,  $R \ge 0$ ,  $S \ge 0$ ,  $Q \ge 0$ . This functional with Q = 0 leads to delay-dependent conditions for systems with fast-varying delays, whereas for R = S = 0 it leads to delay-independent conditions (for systems with slowly-varying delays). The above V with S = 0 was introduced in [58], whereas the S-dependent term was added in [80].

Differentiating V given by (11), we find

$$\begin{aligned} \frac{d}{dt}V &\leq 2x^{T}(t)P\dot{x}(t) + h^{2}\dot{x}^{T}(t)R\dot{x}(t) \\ &-h\int_{t-h}^{t}\dot{x}^{T}(s)R\dot{x}(s)ds + x^{T}(t)(S+Q)x(t) \\ &-x^{T}(t-h)Sx(t-h) \\ &-(1-d)x^{T}(t-\tau(t))Qx(t-\tau(t)) \end{aligned}$$

and employ the representation

$$-h \int_{t-h}^{t} \dot{x}^{T}(s) R \dot{x}(s) ds = -h \int_{t-h}^{t-\tau(t)} \dot{x}^{T}(s) R \dot{x}(s) ds -h \int_{t-\tau(t)}^{t} \dot{x}^{T}(s) R \dot{x}(s) ds.$$
(12)

Applying Jensen's inequality to both terms on the righthand-side of (12), we arrive at

$$-h \int_{t-h}^{t} \dot{x}^{T}(s) R \dot{x}(s) ds \leq -\frac{h}{\tau(t)} e_{1}^{T} R e_{1} - \frac{h}{h-\tau(t)} e_{2}^{T} R e_{2},$$
(13)

where

$$e_1 = x(t) - x(t - \tau(t)), \ e_2 = x(t - \tau(t)) - x(t - h).$$

Here, for  $\tau = 0$  and  $\tau = h$ , we mean the following limits:

$$\lim_{\tau(t)\to 0} \frac{h}{\tau(t)} e_1^T R e_1 = h \lim_{\tau(t)\to 0} \tau(t) \dot{x}^T(t) R \dot{x}(t) = 0$$

and

$$\lim_{\tau(t)\to h} \frac{h}{h-\tau(t)} e_2^T R e_2 = 0$$

In [80], the right-hand side of (13) was upper-bounded by  $-e_1^T Re_1 - e_2^T Re_2$  that was conservative. The convex analysis of [159] allowed to avoid the latter restrictive bounding. The novelty of this method consists in merging the nonconvex terms into a single expression to derive an accurate convex inequality. It was notably shown in [132] that the reciprocally convex combination lemma [159] leads to the same conservatism as the Moon et al.'s inequality [148] when considering Jensen-based stability criteria, but with a lower computational burden. We reformulate the reciprocally convex combination lemma and the Moon et al.'s inequality in a more convenient form for the Lyapunov-based analysis:

**Lemma 1** (Reciprocally convex combination lemma) Let  $R_1 \in \mathbb{R}^{n_1 \times n_1}, \ldots, R_N \in \mathbb{R}^{n_N \times n_N}$  be positive matrices. For

 $e_1 \in \mathbb{R}^{n_1}, \ldots, e_N \in \mathbb{R}^{n_N}$ , and for all  $\alpha_i > 0$  with  $\sum_{i=1}^N \alpha_i = 1$ , define a reciprocally convex combination as a function of the form  $\sum_{i=1}^N \frac{1}{\alpha_i} e_i^T R_i e_i$ . Then, for all  $S_{ij} \in \mathbb{R}^{n_i \times n_j}$ ,  $j = 2, \ldots, N, \ i = 1, \ldots, j - 1$ , such that

$$\begin{bmatrix} R_i & S_{ij} \\ * & R_j \end{bmatrix} \ge 0,$$

the following inequality holds:

$$\sum_{i=1}^{N} \frac{1}{\alpha_i} e_i^T R_i e_i \ge \zeta_N^T \Phi_N \zeta_N,$$

where

$$\zeta_{N} = \begin{bmatrix} e_{1}^{T} & e_{2}^{T} & \cdots & e_{N}^{T} \end{bmatrix}^{T}, \\ \Phi_{N} = \begin{bmatrix} R_{1} & S_{12} & \cdots & S_{1N} \\ * & R_{2} & \cdots & S_{2N} \\ * & * & \ddots & \vdots \\ * & * & \cdots & R_{N} \end{bmatrix}.$$
(14)

**Lemma 2** (Moon et al.'s inequality) Let  $R_1 \in \mathbb{R}^{n_1 \times n_1}, \ldots, R_N \in \mathbb{R}^{n_N \times n_N}$  be positive matrices. Then for all  $\alpha_i > 0$  with  $\sum_{i=1}^{N} \alpha_i = 1$  and for any matrices  $M_i$  in  $\mathbb{R}^{Nn \times n}$ ,  $i = 1, \ldots, N$ , the following inequality holds:

$$\sum_{i=1}^{N} \frac{1}{\alpha_i} e_i^T R_i e_i \ge \zeta_N^T \Psi_N \zeta_N,$$

where  $\zeta_N$  is given in (14) and

$$\Psi_{N} = \Upsilon_{N} + \Upsilon_{N}^{T} - \sum_{i=1}^{N} \alpha_{i} M_{1} R_{i}^{-1} M_{i}^{T},$$
  
$$\Upsilon_{N} = M_{1} [I \quad 0_{n \times (N-1)n}] + M_{2} [0 \quad I \quad 0_{n \times (N-2)n}]) + \cdots + M_{N} [0_{n \times (N-1)n} \quad I].$$

Furthermore, a relaxed reciprocally convex combination lemma was developed in [246] without requiring any extra decision variable. This inequality was extended by the same authors in [245]. More insights on the relationship between some existing matrix inequalities was provided in a recent paper [194] that revealed strong links between the existing inequalities of [148, 159, 197, 243, 246].

#### 3.3.4 Stability Analysis of Systems with Interval or Nonsmall Delay

The time-delay approach became popular in NCSs, being applied to uncertain systems under uncertain sampling with the known upper bound on the sampling intervals [64, 65, 238]. The time-delay approach was further extended to event-triggered networked control [178, 241], distributed networked control of partial differential equations [12, 52, 104, 177], etc. By defining

 $\tau(t) = t - t_k + \eta_k, \ t_k \le t < t_{k+1}, \ k \in \mathbb{Z}^+,$ 

the digital control law has the following form:  $(1) = V_{i} (1) = (1) = (1)$ 

$$u(t) = Kx(t - \tau(t)), \ t_k \le t < t_{k+1}.$$
 (15)  
LTI system (1) under (15) is then modeled as a

Hence, the LTI system (1) under (15) is then modeled as a time-delay system with time-varying delay

$$\dot{x}(t) = Ax(t) + BKx(t - \tau(t)), \ t_k \le t < t_{k+1}, \ k \in \mathbb{Z}^+,$$
(16)

where the time-varying delay  $\tau(t)$  is piecewise linear with derivative  $\dot{\tau}(t) = 1$  for  $t \neq t_k$ . Moreover, we have

$$\eta_m \le \eta_k \le \tau(t) < t_{k+1} - t_k + \eta_k \le \tau_M,$$

where  $\eta_m$  is a lower bound on the network-induced delay,  $\tau_M$  denotes the maximum time span between the time  $s_k = t_k - \eta_k$  at which the state is sampled and the time  $t_{k+1}$  at which next update arrives at the ZOH and  $\tau_M =$ MATI + MAD. See Fig. 3 for an example of  $\tau(t)$ .

This is one of applications that motivate the stability analysis of systems with interval (or non-small) delay  $\tau(t) \in [h_0, h_1]$  with  $h_0 > 0$  (see e.g., [48,80,108]). Keeping in mind that (16) can be represented as

$$\dot{x}(t) = Ax(t) + A_1 x(t - h_0) - A_1 \int_{t - \tau(t)}^{t - h_0} \dot{x}(s) ds, \ h_0 \stackrel{\Delta}{=} \eta_m,$$

the stability of (16) can be analyzed via Lyapunov functionals of the form [48]:

$$V(t, x_t, \dot{x}_t) = V_n(x_t, \dot{x}_t) + V_1(t, x_t, \dot{x}_t),$$

where  $V_n$  is a "nominal" functional for the "nominal" system with constant delay

$$\dot{x}(t) = Ax(t) + A_1x(t - h_0)$$

and where

$$V_{1} = \int_{t-h_{1}}^{t-h_{0}} x^{T}(s) S_{1}x(s)ds + \int_{t-\tau(t)}^{t-h_{0}} x^{T}(s)Q_{1}x(s)ds + (h_{1}-h_{0}) \int_{-h_{1}}^{-h_{0}} \int_{t+\theta}^{t} \dot{x}^{T}(s)R_{1}\dot{x}(s)dsd\theta, \ h_{1} \stackrel{\Delta}{=} \tau_{M}$$
  
with  $S_{1} > 0, \ Q_{1} > 0, \ R_{1} > 0.$ 

In the case where the nominal system is stable for all constant delays from  $[0, h_0]$ ,  $V_n$  can be chosen in the form of (11), where  $h = h_0$  and Q = 0. Then the stability conditions in terms of LMIs can be derived by using standard arguments for the delay-dependent analysis, e.g., in [50, 159].

#### 3.3.5 Time-dependent Lyapunov Functionals for Sampleddata Systems

Note that the existing methods in the framework of timedelay approach are based on some Lyapunov-based analysis of systems with uncertain and bounded fast-varying delays. Therefore, these methods cannot guarantee the stability if the delay is not smaller than the analytical upper bound on the constant delay that preserves the stability. However, it is well-known that in many systems the upper bound on the sampling that preserves the stability may be higher than the one for the constant delay, see examples in [139], as well as the following Example. **Example 1** Consider the following simple and muchstudied problem (see e.g., [157] and the references therein):

$$\dot{x}(t) = -x(s_k), \ t_k \le t < t_{k+1}, \ k \in \mathbb{Z}^+.$$

It is well-known that the equation

$$\dot{x}(t) = -x(t-\tau) \tag{17}$$

with constant delay  $\tau$  is asymptotically stable for  $\tau \leq \pi/2$ and unstable for  $\tau > \pi/2$ , whereas for the fast varying delay it is stable for  $\tau < 1.5$  and there exists a destabilizing delay with an upper bound greater than 1.5. This means that all the existing methods via time-independent Lyapunov functionals cannot guarantee the stability of system (17) for the sampling intervals that may be greater than  $\pi/2$ .

It is easy to check, that in the case of pure (uniform) sampling, the system remains stable for all constant samplings less than 2 and becomes unstable for samplings greater than 2.

Therefore, it is necessary to develop new Lyapunov functional-based techniques for sampled-data control to improve the results. Inspired by the construction of discontinuous Lyapunov functions in [150] for the impulsive systems, time-dependent Lyapunov functionals were introduced in [49] for the analysis of sampled-data systems in the framework of time-delay approach. The main idea is that for (6) the standard time-independent term

$$\int_{-h}^{0}\int_{t+\theta}^{t}\dot{x}^{T}(s)R\dot{x}(s)dsd\theta,\ R>0$$

with  $h \stackrel{\Delta}{=}$  MATI, can be advantageously replaced by the term

$$V_R^s = (h - t + t_k) \int_{t_k}^t \dot{x}^T(s) R \dot{x}(s) ds, \ t_k \le t < t_{k+1}, \ (18)$$

which provides time-dependent LKFs  $\bar{V}(t) = V(t, x_t, \dot{x}_t)$ . The function  $\bar{V}(t)$  may be discontinuous in time, but it is not allowed to grow in the jumps as shown in Fig. 4. The introduced time-dependent Lyapunov functionals lead to qualitatively new results for time-delay systems, allowing a superior performance under the sampling, than the one under the constant delay. The stability of system (6) is based on the following

**Lemma 3** Let there exist positive numbers  $\alpha$ ,  $\beta$ ,  $\delta$  and a functional  $V : \mathbb{R}^+ \times W[-h, 0] \times L_2[-h, 0] \to \mathbb{R}^+$  such that

$$\beta |\phi(0)|^2 \le V(t, \phi, \phi) \le \delta \|\phi\|_W^2.$$
(19)

Let the function  $\overline{V}(t) = V(t, x_t, \dot{x}_t)$  be continuous from the right for x(t) satisfying (6), absolutely continuous for  $t \neq t_k$  and satisfy

$$\lim_{t \to t_k^-} \bar{V}(t) \ge \bar{V}(t_k). \tag{20}$$

(i) If along (6)

$$\dot{\bar{V}}(t) \le -\tilde{\beta}|x(t)|^2$$



Fig. 3. NCSs: piecewise-continuous time-delay



Fig. 4. Discontinuous in time Lyapunov functional

holds for  $t \neq t_k$  and for some scalar  $\beta > 0$ , then (6) is asymptotically stable.

(ii) If along (6)

•

$$V(t) + 2\alpha V(t) \leq 0, \quad for \ t \neq t_k,$$

then  $\bar{V}(t) \leq e^{-2\alpha t} \bar{V}(0)$ , which implies that

$$|x(t)|^2 \le e^{-2\alpha t} \frac{\delta}{\beta} ||x_0||_W^2$$

and thus, system (6) is exponentially stable with the decay rate  $\alpha$ .

Furthermore, a novel discontinuous in time Lyapunov functional was constructed in [122] based on the extension of the Wirtinger inequality [77] to the vector case:

**Lemma 4** [122, 135] Let  $z : [a, b] \to \mathbb{R}^n$  be an absolutely continuous function with  $\dot{z} \in L_2(a, b)$  and with z(a) = 0. Then for any  $n \times n$ -matrix R > 0, the following inequality holds:

$$\int_{a}^{b} z^{T}(\xi) Rz(\xi) d\xi \leq \frac{4(b-a)^{2}}{\pi^{2}} \int_{a}^{b} \dot{z}^{T}(\xi) R\dot{z}(\xi) d\xi.$$
(21)

An extended Wirtinger inequality of Lemma 4 for Lyapunov-based exponential stability analysis was presented in [179]: **Lemma 5** [179] Let  $\alpha \in \mathbb{R}$  and  $z : [a, b] \to \mathbb{R}^n$  be an absolutely continuous function with  $\dot{z} \in L_2(a, b)$  such that z(a) = 0 or z(b) = 0. Then for any  $n \times n$ -matrix R > 0, the following inequality holds:

$$\int_{a}^{b} e^{2\alpha\xi} z^{T}(\xi) R z(\xi) d\xi$$

$$\leq e^{2|\alpha|(b-a)} \frac{4(b-a)^{2}}{\pi^{2}} \int_{a}^{b} e^{2\alpha\xi} \dot{z}^{T}(\xi) R \dot{z}(\xi) d\xi.$$
(22)

Based on Wirtinger inequality of Lemma 5, a discontinuous Lyapunov functional was constructed as follows:

$$\bar{V}(t) = x^T(t)Px(t) + V_R(t, x_t, \dot{x}_t), \ P > 0$$
(23)

with a novel Wirtinger-based discontinuous term

$$V_{R} = h^{2} e^{2\alpha h} \int_{t_{k}}^{t} e^{2\alpha(s-t)} \dot{x}^{T}(s) R \dot{x}(s) ds$$
  
$$-\frac{\pi^{2}}{4} \int_{t_{k}}^{t} e^{2\alpha(s-t)} [x(s) - x(t_{k})]^{T} R[x(s) - x(t_{k})] ds,$$
  
$$R > 0, \ t \in [t_{k}, t_{k+1}).$$
(24)

Since  $[x(s) - x(t_k)]_{|s=t_k} = 0$ , by Lemma 5 we have  $V_R \ge 0$ . Moreover,  $V_R$  vanishes at  $t = t_k$ . Hence, the condition  $\lim_{t \to t_k^-} \bar{V}(t) \ge \bar{V}(t_k)$  holds. This new method leads to numerically simplified LMI condition for the stability analysis [122, 179], and it can be also applied to performance analysis such as exponential stability [179], input-to-state stability [179] and  $L_2$ -gain analysis [125].

**Remark 1** The above discontinuous Lyapunov constructions and their extensions [49, 186] give efficient tool for different control problems, see e.g., [121] for stabilization of NCSs with large network-induced delays, [42, 43, 125–127] for scheduling protocols, [254] for  $H_{\infty}$  filter of sampled-data systems, [98, 116, 140, 228] for synchronisation of complex systems.

**Remark 2** The discrete-time counterpart of the Wirtinger inequality (21) was presented in [188] for stability analysis of discrete-time sampled-data systems: for a sequence of N + 1 real n-dimensional vectors  $\xi_0, \xi_1, \ldots, \xi_N$  such that  $\xi_0 = 0$ , the following inequality holds:

$$\sum_{i=0}^{N-1} (\xi_{i+1} - \xi_i)^T R(\xi_{i+1} - \xi_i) \ge \varrho_N^2 \sum_{i=0}^{N-1} \xi_i^T R\xi_i,$$
(25)

where  $0 < R \in \mathbb{R}^{n \times n}$  and  $\varrho_N = 2 \sin \frac{\pi}{2(2N+1)}$ .

Note that the discrete-time Wirtinger's inequality (25) has been recently employed to the security analysis of discretetime multi-sensor NCSs [?].

#### 3.3.6 General and Augmented Lyapunov Functional Method

A necessary condition for the application of the simple LKFs considered in the previous sections is the asymptotic stability of (6) or (16) with  $\tau(t) = 0$ . Consider e.g., the following system with a constant delay

$$\dot{x}(t) = \begin{bmatrix} 0 & 1 \\ -2 & 0.1 \end{bmatrix} x(t) + \begin{bmatrix} 0 & 0 \\ 1 & 0 \end{bmatrix} x(t-h), \ x(t) \in \mathbb{R}^2.$$

This system is unstable for h = 0 and is asymptotically stable for the constant delay  $h \in [0.10017, 1.7178]$  [74]. For analysis of such systems (particularly, for using delay for stabilization) the simple Lyapunov functionals considered in the previous sections are not suitable. For stability conditions of system (6) or (16) with constant  $\tau(t) \equiv h$  and with  $A + A_1$  not necessary to be Hurwitz, one can use a general quadratic Lyapunov functional:

$$V(x_t) = x^T(t)Px(t) + 2x^T(t) \int_{-h}^{0} Q(\xi)x(t+\xi)d\xi + \int_{-h}^{0} \int_{-h}^{0} x^T(t+s)R(s,\xi)dsx(t+\xi)d\xi$$
(26)  
+ 
$$\int_{-h}^{0} x^T(t+\xi)S(\xi)x(t+\xi)d\xi,$$

where  $0 < P \in \mathbb{R}^n$  and where  $n \times n$  matrix functions  $Q(\xi)$ ,  $R(\xi,\eta) = R^T(\eta,\xi)$  and  $S(\xi) = S^T(\xi)$  are absolutely continuous. For the sufficiency of (26), one have to formulate conditions for  $V \ge \alpha_0 |x(t)|^2$ ,  $\alpha_0 > 0$  and  $\dot{V} \le -\alpha |x(t)|^2$ ,  $\alpha > 0$ .

LMI sufficient conditions via general Lyapunov functional of (26) and discretization were found in [72], where  $Q(\xi), R(\xi, \eta) = R^T(\eta, \xi)$  and  $S(\xi) = S^T(\xi) \in \mathbb{R}^{n \times n}$  are continuous and piecewise-linear matrix-functions. The resulting LMI stability conditions appeared to be very efficient, leading in some examples to results close to analytical ones. For the discretized Lyapunov functional method, see Section 5.7 of [74]. In [163, 164], another method was proposed based on polynomial parameters, that successfully address the asymptotic stability of timedelay systems through the SoS framework.

Till [47] no design problems were solved by this method due to bilinear terms in the resulting matrix inequalities. The latter terms arise from the substitution of  $\dot{x}(t)$  by the righthand side of the differential equation in  $\dot{V}$ . The descriptor discretized method suggested in [47] avoids this substitution. The descriptor discretized method was applied to state-feedback design of  $H_{\infty}$  controllers for neutral type systems with discrete and distributed delays [60] and to dynamic output-feedback  $H_{\infty}$  control of retarded systems with state, input and output delays [209]. For differentialalgebraic systems with delay, the corresponding general LKFs were studied in [73].

A more general quadratic Lyapunov functional has a form of

$$V(x_{t}) = x^{T}(t)Px(t) + 2x^{T}(t)\int_{-h}^{0}Q(\xi)x(t+\xi)d\xi + \int_{-h}^{0}\int_{-h}^{0}x^{T}(t+s)R(s,\xi)ds \ x(t+\xi)d\xi + \int_{t-h}^{t}x^{T}(\xi)Sx(\xi)d\xi + \int_{-h}^{0}\int_{t+\theta}^{t}\dot{x}^{T}(s)R_{0}\dot{x}(s)dsd\theta,$$
(27)

where  $P > 0, S > 0, R_0 > 0$ . Matrix-functions  $Q(\xi) \in \mathbb{R}^{n \times n}$  and  $R(\xi, \eta) = R^T(\eta, \xi) \in \mathbb{R}^{n \times n}$  are absolutely continuous. For the sufficiency of (27), one have to formulate conditions for  $V \geq \beta |x(t)|^2, \beta > 0$  and  $\dot{V} \leq -\alpha |x(t)|^2, \alpha > 0$ .

Choosing in (27) R = Q = 0 and replacing  $R_0$  by hR, we arrive at the simple Lyapunov functional (11), where Q = 0. Consider now (27) with constant  $R \equiv Z$  and Q, and replace  $R_0$  by hR. Then we arrive at the augmented Lyapunov functional of the form

$$V(x_t, \dot{x}_t) = \begin{bmatrix} x(t) \\ \int_{t-h}^t x(s)ds \end{bmatrix}^T \begin{bmatrix} P & Q \\ * & Z \end{bmatrix} \begin{bmatrix} x(t) \\ \int_{t-h}^t x(s)ds \end{bmatrix} + \int_{t-h}^t x^T(s)Sx(s)ds + h \int_{-h}^0 \int_{t+\theta}^t \dot{x}^T(s)R\dot{x}(s)dsd\theta,$$
(28)

where

$$\begin{bmatrix} P & Q \\ * & Z \end{bmatrix} > 0, \ S > 0, \ R > 0.$$

Note that the term  $Q \neq 0$  in (28) allows to derive nonconvex in *h* conditions that do not imply the stability of the original system with h = 0. A remarkable result was obtained in [189] for systems with constant discrete and distributed delays and in [193] for systems with fast-varying discrete delays: LMI conditions that may guarantee the stability of systems which are unstable with the zero delay (i.e., in the case of "stabilizing delay") were derived by the Wirtinger-based integral inequality, which includes Jensen's inequality as a particular case, and by the augmented Lyapunov functional (28).

In recent years, several other attempts have been done concerning the extension of Jensen's inequality such as auxiliary-based [160], Bessel-Legendre inequality [190–192] or polynomials-based inequality [115]. By construction of more general augmented LKFs and the application of these developed integral inequalities, a series of less conservative stability conditions was achieved [134, 190–192, 243, 244].

**Remark 3** In the literature, there are many other methods that have been proposed to stability analysis and/or control synthesis of NCSs. Networked predictive method is effective for NCSs with communication delays and packet dropouts [120, 224, 230, 231]. A looped-functional approach is for robust analysis of sampled-data system either considering directly the sampled-data system formulation [186] or the impulsive system formulation [19, 187]. Model predictive control plays an important role in dealing with constraints, such as actuator or physical limitations [?, 78, 79]. Sliding model control, as an effective robust control strategy has also been applied to NCSs [76, 196]. With the development of cloud computing technologies, the cloud-based networked control has exhibited potential advantages [4, 229].

#### 4 Time-delay Approach to Event-triggered Control

The event-triggering mechanism is used to reduce the amount of signals transmitted through a communication network. The basic idea is to send the signal only when its change is large enough. This idea has a long history (see, e.g., [10, 28, 33, 66, 111, 216, 217]) and lately became quite popular since it allows to reduce the workload in NCSs. However, the workload reduction has been analytically proved only for stochastic systems [1-3, 9]. For deterministic systems, the benefits of the event-triggering scheme are usually demonstrated by numerical simulations.

In this section, we describe the time-delay approach to the event-triggered control. We consider three types of the event-triggering mechanisms: continuous, periodic, and switching (with a dwell time). Many other types of the event-triggering mechanisms can be studied in a similar manner using the time-delay approach. Another approach is based on the impulsive systems [82, 169, 195]. A survey on the event-triggered control can be found in [85].

#### 4.1 Continuous Event-triggering Mechanism

Consider the system

$$\dot{x} = Ax + Bu, \qquad x \in \mathbb{R}^n, u \in \mathbb{R}^m, y \in \mathbb{R}^l$$

$$y = Cx, \qquad (29)$$

with the output y(t) being transmitted through a communication channel at the sampling instants  $t_k, k \in \mathbb{Z}^+$ . We start by considering the following event-based sampling (similar to the one suggested in [211]):  $t_0 = 0$ ,

$$t_{k+1} = \min\{t > t_k \mid |\sqrt{\Omega}(y(t) - y(t_k))|^2 \ge \sigma^2 |\sqrt{\Omega}y(t)|^2\},$$
(30)

where  $k \in \mathbb{Z}^+$ ,  $\sigma > 0$  and  $0 < \Omega \in \mathbb{R}^{l \times l}$ . According to (30), the output y is transmitted only when a certain "event"

occurs. The "event" is that the relative change of y since the last transmission exceeded a predefined threshold  $\sigma > 0$ . Since this condition is checked continuously, we call (30) the continuous event-triggering mechanism.

Let there exist a control gain  $K \in \mathbb{R}^{m \times l}$  such that the output feedback u(t) = -Ky(t) stabilizes the system (29). The event-triggered control is given by

$$u(t) = -Ky(t_k), \quad t \in [t_k, t_{k+1}), \quad k \in \mathbb{Z}^+$$
 (31)

with  $t_k$  defined by (30). To study the stability of (29)–(31), introduce the event-triggering error

$$e(t) = y(t_k) - y(t), \quad t \in [t_k, t_{k+1}), \quad k \in \mathbb{Z}^+.$$

Then the closed-loop system (29)–(31) can be presented as

$$\dot{x}(t) = A_{cl}x(t) - BKe(t), \quad A_{cl} = A - BKC.$$
 (32)

Note that  $A_{cl}$  is Hurwitz since u = -Ky is assumed to be stabilizing. Namely, there exists  $P \in \mathbb{R}^{n \times n}$  such that

$$P > 0, \quad A_{cl}^T P + P A_{cl} < 0.$$
 (33)

The event-triggering mechanism (30) guarantees that the event-triggering error is bounded:

$$e^T \Omega e \le \sigma^2 x^T C^T \Omega C x. \tag{34}$$

Then, for the Lyapunov function  $V = x^T P x$ , we have

$$V \stackrel{(32)}{=} 2x^T P A_{cl} x - 2x^T P B K e$$

$$\stackrel{(34)}{\leq} 2x^T P A_{cl} x - 2x^T P B K e - \sigma^{-1} e^T \Omega e + \sigma x^T C^T \Omega C x$$

$$= \begin{bmatrix} x \\ e \end{bmatrix}^T \Phi \begin{bmatrix} x \\ e \end{bmatrix},$$
(35)

where

. (22) \_

$$\Phi = \begin{bmatrix} A_{cl}^T P + P A_{cl} + \sigma C^T \Omega C & -PBK \\ * & -\sigma^{-1} \Omega \end{bmatrix}.$$

The addition of the quadratic form  $-\sigma^{-1}e^{T}\Omega e + \sigma x^{T}C^{T}\Omega Cx \geq 0$  to the right-hand side of  $\dot{V}$  is called the S-procedure [142, 234]. If  $\Phi < 0$ , then  $\dot{V} < 0$  and (32) is stable. Since  $\Omega > 0$ , by Schur's complement lemma, the conditions  $\Phi < 0$  is equivalent to

$$A_{cl}^T P + PA_{cl} + \sigma [C^T \Omega C + (PBK)\Omega^{-1}(PBK)^T] < 0.$$

Due to (33), this inequality holds for a small enough  $\sigma > 0$ . Therefore, if rank C = n and the system (29) is stable under the feedback u(t) = -Ky(t), then it remains stable under the sampled-data control (31) with the event-based sampling (30) provided the threshold  $\sigma > 0$  is small enough.

This result is very intuitive: if  $\sigma$  is small, then the eventtriggering mechanism (30) gets more sensitive to the output change and transmits the signals more often, what makes the control (31) more similar to the stabilizing continuous-time controller.

The implicitly defined sampling instants (30) can be such that  $\lim_{k\to\infty} t_k < \infty$ . This is called the Zeno phenomenon.



Fig. 5. The errors of the periodic event-triggering mechanism

Such sampling cannot be implemented since it requires to transmit an infinite number of signals in finite time. To use (30), one must ensure that  $\inf\{t_k - t_{k-1}\} > 0$ . This can be guaranteed if rank C = n [211]. However, the Zeno phenomenon can occur when rank C < n or in the presence of disturbances [18]. To avoid this, one may use the periodic event-triggering mechanism or introduce a dwell time.

#### 4.2 Periodic Event-triggering Mechanism

The periodic event-triggering mechanism is given by

$$t_{k+1} = \min_{i} \{ t_k + ih \mid | \sqrt{\Omega} (y(t_k + ih) - y(t_k)) |^2 > \sigma^2 |\sqrt{\Omega} y(t_k + ih)|^2 \}$$
(36)

with  $t_0 = 0, \sigma > 0$ , and  $0 < \Omega \in \mathbb{R}^{l \times l}$  [82, 83, 167, 240, 253]. Differently from (30), the event-triggering condition of (36) is checked periodically with the period h > 0. This approach guarantees that the inter-event time is at least h, which rules out the Zeno behavior.

To study the stability of (29) under the feedback (31) with the event-based sampling (36), introduce the errors (Fig. 5)

$$\begin{split} e(t) &= y(t_k) - y(t_k + ih), \\ v(t) &= C \int_{t_k + ih}^t \dot{x}(s) \, ds, \end{split} \qquad t \in [t_k + ih, t_k + (i+1)h). \end{split}$$

Then,  $y(t_k) = Cx(t) - v(t) + e(t)$  and the closed-loop system can be presented as

$$\dot{x}(t) = A_{cl}x(t) + BKv(t) - BKe(t).$$
(37)

Due to (36), the error due to triggering satisfies 2T

1.

$$e^{T}(t)\Omega e(t) \leq \sigma^{2}y^{T}(t_{k}+ih)\Omega y(t_{k}+ih)$$
  
=  $\sigma^{2}(Cx(t)-v(t))^{T}\Omega(Cx(t)-v(t)).$ 

Therefore, it can be compensated using the S-procedure similarly to (35). The integral term v, representing the error due to sampling, can be compensated using an appropriate LKF, e.g.,  $V = x^T P x + V_R^s$  with  $V_R^s$  defined by (18) or  $V = x^T P x + V_R$  with  $V_R$  defined by (24) or  $V = x^T P x + V_U + V_X$ , where  $V_U$  and  $V_X$  are defined in (13) and (26) of [49]. This allows to derive LMIs guaranteeing the exponential stability of the system (29) under the periodic event-triggered control (31), (36) [176, Proposition 1].

For  $\sigma = 0$ , the event-triggering mechanism (36) leads to the periodic sampling  $t_k = kh$  and the conditions of [176, Proposition 1] coincide with the stability conditions for periodic sampling from [49].

#### Event-triggering Mechanism with a Dwell Time 4.3

The event-triggering mechanism with a dwell time has the form

$$t_{k+1} = \min\{t \ge t_k + h \,|\, \eta \ge 0\},\tag{38}$$

where h > 0 is a constant dwell time and  $\eta$  is the eventtriggering condition. In [212-214], the value of h that preserves the stability was obtained by solving a scalar differential equation. For  $\eta = |y(t) - y(t_k)| - C$  with a constant C, some qualitative results concerning practical stability have been obtained in [87]. Here, we derive the stability conditions using the time-delay approach and switching as suggested in [178].

Let the sampling be given by

 $t_{k+1} = \min\{t \ge t_k + h \mid |\sqrt{\Omega}(y(t) - y(t_k))|^2 \ge \sigma^2 |\sqrt{\Omega}y(t)|^2\}$ (39)with  $t_0 = 0, \sigma > 0, 0 < \Omega \in \mathbb{R}^{l \times l}$ , and h > 0. Clearly, the inter-event time is not less than h, which rules out the Zeno behavior. The event-triggering mechanism (39) can be viewed as a switching between the periodic sampling

the closed-loop system (29), (31), (39) can be presented as  $\dot{x}(t) = A_{cl}x(t) + \chi(t)BKv(t) - (1 - \chi(t))BKe(t),$ where  $A_{cl} = A - BKC$ ,

 $t_k = kh$  and the continuous event-triggering (30). Namely,

$$\begin{split} \chi(t) &= \begin{cases} 1, & t \in [t_k, t_k + h), \\ 0, & t \in [t_k + h, t_{k+1}), \end{cases} \\ e(t) &= y(t_k) - y(t), & t \in [t_k + h, t_{k+1}), \end{cases} \\ v(t) &= C \int_{t_k}^t \dot{x}(s) \, ds, & t \in [t_k + h, t_{k+1}). \end{split}$$

Differently from (37), the errors e and v operate on disjoint time intervals. This error separation makes it easier for the stable dynamics  $\dot{x}(t) = A_{cl} x(t)$  to dominate the errors. Using the functional  $V = x^T P x + \chi(t)(V_U + V_X)$ , where  $V_U$  and  $V_X$  are defined in (13) and (26) of [49], the LMIbased stability conditions can be derived for the system (29), (31), (39) [176].

In this section, we showed that the time-delay approach can be used to study the event-triggered control. The general idea is to construct for the closed-loop system an appropriate LKF and apply the S-procedure to the quadratic form whose positiveness is guaranteed by the event-triggering condition. This idea can be extended to systems with time-varying communication delays [178], sampled-data predictors that compensate large constant input and output delays [179, 180], adaptive controllers [185], and eventtriggered control of distributed parameter systems [177].

#### 5 Time-delay Approach to Networked Control under Scheduling Protocols

In most existing literature on NCSs, it was usually assumed that all the nodes could simultaneously get access to the network to transmit their data. This assumption, however, is generally unrealistic for NCSs due to bandwidth limitations and interference channels. As such, the scheduling protocols are needed to orchestrate the transmission order of the nodes. The widely utilized protocols in the literature include the Round-Robin protocol, the TOD protocol and the stochastic protocol, see also Section 3. Three main approaches for the modelling and analysis of NCSs subject to scheduling protocols are based on discrete-time systems, impulsive/hybrid systems, and time-delay systems.

In the framework of discrete-time modelling approach, network-based stabilization of NCSs with TOD/Round-Robin protocol and without delay was considered in [32] (see also [31] for delays less than the sampling interval). In [220], stability analysis of NCSs with Round-Robin protocol and uniform quantizers was studied. The stability of NCSs under a stochastic protocol, where the activated node is modeled by a Markov chain, was studied in [30] by applying the discrete-time modeling framework. In [30], data packet dropouts can be regarded as prolongations of the sampling interval for small delays.

In the framework of impulsive system approach, stabilization of nonlinear NCSs under TOD and Round-Robin protocols was studied in [152], in which communication delays are not included in the analysis. In [88], the authors provided methods for computing the MATI and MAD for which the stability of a nonlinear system is ensured. In [86] and [151], stabilization of nonlinear NCSs including dynamic quantization was studied. In the same framework, a stochastic protocol was introduced in [210] and analyzed for the input-output stability of NCSs in the presence of data packet dropouts or collisions. An independent and identically-distributed (iid) sequence of Bernoulli random variables is applied to describe the stochastic protocol. Communication delays, however, are not included in the analysis.

Till now only the time-delay system approach is applicable to non-small network-induced delays (that may be larger than sampling intervals) in the presence of scheduling protocols [42, 43, 124–126, 128, 130, 133]. In this section, we focus mainly on the time-delay approach to the modelling and analysis of NCSs under scheduling protocols. Consider the system architecture in Fig. 6 with plant

$$\dot{x}(t) = Ax(t) + Bu(t), \ t \ge 0, \tag{40}$$

where  $x(t) \in \mathbb{R}^n$  and  $u(t) \in \mathbb{R}^m$  denote the state and the control input, respectively. The system matrices A and B can be uncertain with polytopic type uncertainties.

The system is equipped with N distributed sensors, a controller and an actuator, which are connected via the network. The measurements are given by  $y_i(t) = C_i x(t) \in \mathbb{R}^{n_i}$ ,  $i = 1, \ldots, N$ ,  $\sum_{i=1}^N n_i = n_y$ . Then we denote  $C = [C_1^T \cdots C_N^T]^T$ ,  $y(t) = [y_1^T(t) \cdots y_N^T(t)]^T \in \mathbb{R}^{n_y}$ . Let  $s_k$ 



Fig. 6. System architecture with multiple sensors

denote the unbounded and monotonously increasing sequence of sampling instants  $0 = s_0 < s_1 < \cdots < s_k < \cdots$ ,  $k \in \mathbb{Z}^+$ ,  $\lim_{k \to \infty} s_k = \infty$ .

At each sampling instant  $s_k$ , one of the outputs  $y_i(s_k) \in \mathbb{R}^{n_i}$  is transmitted via the sensor network. It is supposed that data loss does not occur and that the transmission of the information over the network experiences an uncertain, time-varying delay  $\eta_k$ . Then  $t_k = s_k + \eta_k$  is the updating time instant of the ZOH device.

Assume that the maximum sampling interval and the maximum delay between the sampling instant  $s_k$  and its updating instant  $t_k$  are bounded by MATI and MAD respectively. The transmission delays are allowed to be non-small provided that the transmission order of data packets is maintained for reception [149]. Assume that the networkinduced delay  $\eta_k$  and the time span between the updating and the most recent sampling instants are bounded:

$$t_{k+1} - t_k + \eta_k \le \tau_M, \ 0 \le \eta_m \le \eta_k \le \text{MAD}, \ k \in \mathbb{Z}^+,$$
(41)

where  $\tau_M$  denotes the maximum time span between the time  $s_k = t_k - \eta_k$  at which the state is sampled and the time  $t_{k+1}$  at which the next update arrives at the destination. Here  $\eta_m$  and MAD are known bounds and  $\tau_M = MATI + MAD$ . Note that  $MATI = \tau_M - MAD \leq \tau_M - \eta_m$ ,  $\eta_m > \frac{\tau_M}{2}$ , i.e.,  $\eta_m > \tau_M - \eta_m$  leads to  $MATI \leq \tau_M - \eta_m < \eta_m \leq \eta_k$ , which implies that the network delays are non-small.

Denote by

$$\hat{y}(s_k) = [\hat{y}_1^T(s_k) \cdots \hat{y}_N^T(s_k)]^T \in \mathbb{R}^{n_y}$$
(42)

the output information submitted to the scheduling protocol. At each sampling instant  $s_k$ , one of the system nodes  $i \in \mathcal{I} = \{1, \ldots, N\}$  is active, that is only one of  $\hat{y}_i(s_k)$  values is updated with the recent output  $y_i(s_k)$ . Let  $i_k^* \in \mathcal{I}$ denote the active output node at the sampling instant  $s_k$ , which will be chosen due to scheduling protocols. Then

$$\hat{y}_i(s_k) = \begin{cases} y_i(s_k), & i = i_k^*, \\ \hat{y}_i(s_{k-1}), & i \neq i_k^*. \end{cases}$$
(43)

The choice of  $i_k^*$  will be determined by the scheduling protocol defined below.

It is supposed that the controller and the actuator are event-driven. The most recent output information on the controller side is denoted by  $\hat{y}(s_k)$ . Assume that there exists a matrix  $K = [K_1 \cdots K_N], K_i \in \mathbb{R}^{m \times n_i}$  such that A + BKC is Hurwitz. Then, the static output feedback controller has a form

$$u(t) = K\hat{y}(s_k) = \sum_{i=1}^{N} K_i \hat{y}_i(s_k), \ t \in [t_k, t_{k+1}).$$
(44)

Therefore, due to (43), the controller for  $t \in [t_k, t_{k+1})$  can be presented as

$$u(t) = K_{i_k^*} y_{i_k^*}(t_k - \eta_k) + \sum_{i=1, i \neq i_k^*}^N K_i \hat{y}_i(t_{k-1} - \eta_{k-1}),$$
(45)

where  $i_k^*$  is the index of the active node at  $s_k$  and  $\eta_k$  is communication delay.

#### 5.1 Scheduling Protocols

### 5.1.1 TOD Protocol

In the TOD protocol, the output node  $i \in \mathcal{I}$  with the greatest weighted error will have the highest priority to be access to the network.

**Definition 1 (Weighted TOD protocol)** Let  $Q_i > 0$ , i = 1, ..., N, be some weighting matrices. At the sampling instant  $s_k$ , the weighted TOD protocol is a protocol for which the active output node with the index  $i_k^*$  is defined as any index that satisfies

$$\begin{aligned} |\sqrt{Q}_{i_k^*} e_{i_k^*}(t)|^2 &\ge |\sqrt{Q}_i e_i(t)|^2, \ t \in [t_k, t_{k+1}), \\ k \in \mathbb{Z}^+, \ i = 1, \dots, N. \end{aligned}$$
(46)

A possible choice of  $i_k^*$  is given by

$$i_k^* = \min\{ \arg \max_{i \in \mathcal{I}} |\sqrt{Q_i} \left( \hat{y}_i(s_{k-1}) - y_i(s_k) \right)|^2 \},\$$

i.e., if several errors are the same, we transmit the node i with a minimum index. The conditions for computing the weighting matrices  $Q_1, \ldots, Q_N$  will be given in Lemma 6 below.

#### 5.1.2 Periodic Protocol

The active output node is chosen in a periodic order:

$$\begin{aligned}
& i_k^* = i_{k+N}^*, \text{ for all } k \in \mathbb{Z}^+, \\
& i_j^* \neq i_l^*, \text{ for } 0 \le j < l \le N-1,
\end{aligned} \tag{47}$$

where N is the period of the protocol. The well-known Round-Robin protocol belongs to this class of protocols.

#### 5.1.3 Stochastic Protocols

There are usually two classes of stochastic protocols, which are defined by iid and Markovian process, respectively. **Iid Protocol** The choice of  $i_k^*$  is assumed to be iid with the probabilities given by

$$\operatorname{Prob}\{i_k^* = i\} = \beta_i, \ i \in \mathcal{I},\tag{48}$$

where  $\beta_i, i = 1, ..., N$  are non-negative scalars and  $\sum_{i=1}^{N} \beta_i = 1$ . Here  $\beta_j, j = 1, ..., N$  are the probabilities of the measurement  $y_j(s_k)$  to be transmitted at  $s_k$ .

**Markovian Protocol** The protocol determines  $i_k^*$  through a Markov Chain. The conditional probability that node  $j \in \mathcal{I}$  gets access to the network at time  $s_k$ , given the values of  $i_{k-1}^* \in \mathcal{I}$ , is defined by

$$\operatorname{Prob}\{i_k^* = j | i_{k-1}^* = i\} = \pi_{ij},\tag{49}$$

where  $0 \leq \pi_{ij} \leq 1$  for all  $i, j \in \mathcal{I}$ ,  $\sum_{j=1}^{N} \pi_{ij} = 1$  for all  $i \in \mathcal{I}$  and  $i_0^* \in \mathcal{I}$  is assumed to be given. The transition probability matrix is denoted by  $\Pi = {\pi_{ij}} \in \mathbb{R}^{N \times N}$ .

**Remark 4** The iid scheduling is a special case of the Markovian scheduling. For instance, assume that there are N = 2 sensor nodes, the Markovian scheduling with  $\Pi = \begin{bmatrix} p & 1-p \\ p & 1-p \end{bmatrix}$ ,  $0 \le p \le 1$ , is an iid scheduling with  $\beta_1 = p, \beta_2 = 1-p$ .

#### 5.2 TOD Protocol and an Impulsive System Model

Consider the error between the system output  $y_i(s_k)$  and the last available information  $\hat{y}_i(s_{k-1})$ :

$$e_{i}(t) = \hat{y}_{i}(s_{k-1}) - y_{i}(s_{k}), \ \hat{y}_{i}(s_{-1}) \stackrel{\Delta}{=} 0, \ i = 1, \dots, N,$$
  
$$e(t) = \operatorname{col}\{e_{1}(t), \cdots, e_{N}(t)\}, \ t \in [t_{k}, t_{k+1}), \ e(t) \in \mathbb{R}^{n_{y}}.$$
  
(50)

Denote  $\tau(t) = t - t_k + \eta_k$ ,  $t \in [t_k, t_{k+1})$ . From (41), it follows that  $\eta_m \leq \tau(t) \leq \tau_M$ . From (40), (45) and (50), we thus obtain the impulsive closed-loop model with the following dynamics:

$$\begin{cases} \dot{x}(t) = Ax(t) + A_1 x(t - \tau(t)) + \sum_{i=1, i \neq i_k^*}^N B_i e_i(t), \\ \dot{e}(t) = 0, \ t \in [t_k, t_{k+1}), \end{cases}$$
(51)

and the delayed reset system

$$\begin{cases} x(t_{k+1}) = x(t_{k+1}^{-}), \\ e_i(t_{k+1}) = C_i[x(t_k - \eta_k) - x(t_{k+1} - \eta_{k+1})], \ i = i_k^*, \\ e_i(t_{k+1}) = e_i(t_k) + C_i[x(t_k - \eta_k) - x(t_{k+1} - \eta_{k+1})], \\ i \neq i_k^*, \ i \in \mathbb{N}, \end{cases}$$

$$(52)$$

where  $A_1 = BKC, B_i = BK_i, i = 1, ..., N$ .

Note that the differential equation for x given by (51) depends on  $e_i(t) = e_i(t_k), t \in [t_k, t_{k+1})$  with  $i \neq i_k^*$  only. Consider the following Lyapunov functional:

$$V_{e}(t) = V(t, x_{t}, \dot{x}_{t}) + \sum_{i=1}^{N} e_{i}^{T}(t)Q_{i}e_{i}(t),$$

$$V(t, x_{t}, \dot{x}_{t}) = \tilde{V}(t, x_{t}, \dot{x}_{t}) + V_{G},$$

$$V_{G} = \sum_{i=1}^{N} (\tau_{M} - \eta_{m})\int_{s_{k}}^{t} e^{2\alpha(s-t)}|\sqrt{G_{i}}C_{i}\dot{x}(s)|^{2}ds,$$

$$\tilde{V}(t, x_{t}, \dot{x}_{t}) = x^{T}(t)Px(t) + \int_{t-\eta_{m}}^{t} e^{2\alpha(s-t)}x^{T}(s)S_{0}x(s)ds$$

$$+ \int_{t-\tau_{M}}^{t-\eta_{m}} e^{2\alpha(s-t)}x^{T}(s)S_{1}x(s)ds$$

$$+ \eta_{m}\int_{-\eta_{m}}^{0} \int_{t+\theta}^{t} e^{2\alpha(s-t)}\dot{x}^{T}(s)R_{0}\dot{x}(s)dsd\theta$$

$$+ (\tau_{M} - \eta_{m})\int_{-\tau_{M}}^{-\eta_{m}} \int_{t+\theta}^{t} e^{2\alpha(s-t)}\dot{x}^{T}(s)R_{1}\dot{x}(s)dsd\theta,$$
(52)

where  $P > 0, S_j > 0, R_j > 0, G_i > 0, Q_i > 0, \alpha > 0,$  $j = 0, 1, i = 1, ..., N, t \in [t_k, t_{k+1}), k \in \mathbb{Z}^+$ , and where we define  $x(t) = x_0$  for t < 0. The terms

$$e_i^T(t)Q_ie_i(t) \equiv e_i^T(t_k)Q_ie_i(t_k), \ t \in [t_k, t_{k+1})$$

are piecewise-constant,  $\tilde{V}(t, x_t, \dot{x}_t)$  presents the standard Lyapunov functional for systems with interval delays  $\tau(t) \in [\eta_m, \tau_M]$ . The piecewise-continuous in time term  $V_G$  is inserted to cope with the delays in the reset conditions. It is continuous on  $[t_k, t_{k+1})$  and does not grow in the jumps (when  $t = t_{k+1}$ ). The function  $V_e(t)$  is thus continuous and differentiable over  $[t_k, t_{k+1})$ . The following lemma gives sufficient conditions for the exponential stability of (46) and (51)–(52):

**Lemma 6** [126] Suppose that there exist positive constant  $\alpha, 0 < Q_i \in \mathbb{R}^{n_i \times n_i}, 0 < U_i \in \mathbb{R}^{n_i \times n_i}, 0 < G_i \in \mathbb{R}^{n_i \times n_i}, i = 1, \dots, N, and V_e(t) of (53) such that along (51) the following inequality holds for <math>t \in [t_k, t_{k+1})$ 

$$\dot{V}_{e}(t) + 2\alpha V_{e}(t) - \frac{1}{\tau_{M} - \eta_{m}} \sum_{i=1, i \neq i_{k}^{*}}^{N} |\sqrt{U_{i}}e_{i}(t)|^{2} -2\alpha |\sqrt{Q_{i_{k}^{*}}}e_{i_{k}^{*}}(t)|^{2} \leq 0.$$

Assume additionally that

$$\begin{bmatrix} -\frac{1-2\alpha(\tau_{M}-\eta_{m})}{N-1}Q_{i} + U_{i} & Q_{i} \\ * & Q_{i} - G_{i}e^{-2\alpha\tau_{M}} \end{bmatrix} < 0, \quad (54)$$
$$i = 1, \dots, N.$$

Then  $V_e(t)$  does not grow in the jumps along (51)–(52) and (46):

$$V_e(t_{k+1}) - V_e(t_{k+1}) + \sum_{i=1, i \neq i_k^*}^N |\sqrt{U_i} e_i(t_k)|^2 + 2\alpha(\tau_M - \eta_m) |\sqrt{Q_{i_k^*}} e_{i_k^*}(t_k)|^2 \le 0.$$

Moreover, the following bounds hold for the solutions of (51)-(52) and (46) initialized by  $x_{t_0} \in W[-\tau_M, 0], e(t_0) \in \mathbb{R}^{n_y}$ :

$$V(t, x_t, \dot{x}_t) \le e^{-2\alpha(t-t_0)} V_e(t_0), \ t \ge t_0,$$
  
$$V_e(t_0) = V(t_0, x_{t_0}, \dot{x}_{t_0}) + \sum_{i=1}^N |\sqrt{Q_i} e_i(t_0)|^2,$$
 (55)

and

$$\sum_{i=1}^{N} |\sqrt{Q_i} e_i(t)|^2 \le \tilde{c} e^{-2\alpha(t-t_0)} V_e(t_0),$$
 (56)

where  $\tilde{c} = e^{2\alpha(\tau_M - \eta_m)}$ , implying exponential stability of (51)–(52) and (46).

The exponential stability of system (51)–(52) under (46) can be alternatively analyzed via the Lyapunov functional

$$\tilde{V}_e(t) = V_e(t) + V_W(t), \ t \in [t_k, t_{k+1}), \tag{57}$$

where  $V_e(t)$  is given by (53) and

$$V_W(t) = 2\alpha(t_k - t)e_{i_k}^T(t)Q_{i_k}^*e_{i_k}^*(t) + \sum_{i=1, i \neq i_k}^N \frac{t_k - t}{t_{k+1} - t_k}e_i^T(t)U_ie_i(t).$$

The negative term  $V_W(t)$  is a piecewise-continuous in time term that was employed in [42] to simplify the exponential stability analysis of the impulsive system. The following lemma gives sufficient conditions for the positivity of  $\tilde{V}_e(t)$ and for the fact that it does not grow in the jumps  $t_k$ , and also for the exponential stability of (51)–(52) and (46):

**Lemma 7** [42] Given a tuning parameter  $\alpha > 0$ , let there exist matrices  $0 < Q_i \in \mathbb{R}^{n_i \times n_i}$ ,  $0 < U_i \in \mathbb{R}^{n_i \times n_i}$  and  $0 < G_i \in \mathbb{R}^{n_i \times n_i}$ ,  $i = 1, \ldots, N$ , that satisfy the LMIs (54). Then  $\tilde{V}_e(t)$  of (57) is positive in the sense that

$$\tilde{V}_e(t) \ge \beta \Big( |x(t)|^2 + |e(t)|^2 \Big), \ t \ge t_0,$$

for some  $\beta > 0$ . Moreover,  $\tilde{V}_e(t)$  does not grow in the jumps along (51)–(52) and (46):

$$\tilde{V}_e(t_{k+1}) - \tilde{V}_e(t_{k+1}^-) \le 0.$$

Furthermore, along (51) if the following inequality holds for  $t \in [t_k, t_{k+1})$ 

$$\tilde{V}_e(t) + 2\alpha \tilde{V}_e(t) \le 0,$$

then the bounds (55) and (56) with  $V_e(t_0)$  changed by  $\tilde{V}_e(t_0)$  hold, for the solutions of (51)–(52) and (46) initialized by  $x_{t_0} \in W[-\tau_M, 0], e(t_0) \in \mathbb{R}^{n_y}$ .

## 5.3 Round-Robin Protocol

Under Round-Robin scheduling, the measurements are sent in a periodic manner one after another. In Subsection 5.3.1, we first show a simplified closed-loop system, which is modelled as one system with multiple independent delays. A more accurate model in the form of switched subsystems with ordered multiple delays is provided in Subsection 5.3.2. Subsection 5.3.3 presents an impulsive system model, which leads to a more complicated stability analysis.

#### 5.3.1Round-Robin protocol and a simplified system model with multiple independent delays

Under Round-Robin scheduling, the components of the most recent output on the controller side  $\hat{y}(s_k)$  given by (42) can be presented as  $\hat{y}_i(s_k) = y_i(s_{k-\Delta_k^i}), i = 1, \dots, N$ with some  $\Delta_k^i \in \{0, \ldots, N-1\}$ . Following the time-delay approach to NCSs, denote  $\tau_i(t) = t - s_{k-\Delta_i^i}, t \in [t_k, t_{k+1})$ . We have

$$\begin{split} \eta_m &\leq \tau_i(t) \leq t_{k+1} - s_{k-\Delta_k^i} = s_{k+1} - s_{k-\Delta_k^i} + \eta_{k+1} \\ &\leq (\Delta_k^i + 1) \cdot \text{MATI} + \text{MAD} \\ &\leq N \cdot \text{MATI} + \text{MAD} \stackrel{\Delta}{=} \tau_M^1. \end{split}$$

Therefore, for  $t \ge t_{N-1}$  (when all the measurements are transmitted at least once) the static output-feedback (44) under Round-Robin protocol can be presented as

$$u(t) = \sum_{i=1}^{N} K_i y_i (t - \tau_i(t)), \ t \ge t_{N-1}.$$
 (58)

The resulting closed-loop model is a system with multiple delays

$$\dot{x}(t) = Ax(t) + \sum_{i=1}^{N} A_i C_i x(t - \tau_i(t)), \ t \ge t_{N-1},$$
 (59)

where  $A_i = BK_i$  and  $\tau_i(t) \in [\eta_m, \tau_M^1, ]$   $i = 1, \ldots, N$ .

The stability analysis of closed-loop model (59) can be provided by employing the Lyapunov functional proposed in [42].

#### 5.3.2Round-Robin protocol and a switched system model with multiple ordered delays

Consider Round-Robin scheduling for the choice of the active output node:  $y_i(t) = C_i x(t)$ , is transmitted only at the sampling instant  $t = s_{N\ell+i-1}, \ \ell \in \mathbb{Z}^+, \ i = 1, \dots, N.$ After each transmission and reception, the values in  $y_i(t)$ are updated with the newly received values, while the values of  $y_i(t)$  for  $j \neq i$  remain the same, as no additional information is received. This leads to the constrained data exchange expressed as

$$\hat{y}_i(s_k) = \begin{cases} y_i(s_k) = C_i x(s_k), \ k = N\ell + i - 1, \\ \hat{y}_i(s_{k-1}), & k \neq N\ell + i - 1, \end{cases} \ell \in \mathbb{Z}^+.$$

Following the assumptions given by (41) on the networkinduced delay and sampling intervals, we have for j = $1,\ldots,N$ 

$$t_{k+1} - s_{k-N+j} = s_{k+1} - s_{k-N+j} + \eta_{k+1}$$
  
$$\leq (N-j+1) \text{ MATI} + \text{ MAD} \stackrel{\Delta}{=} \tau_M^j.$$

The closed-loop system with Round-Robin protocol is modeled as a switched system:

$$\dot{x}(t) = Ax(t) + \sum_{j=1}^{N} A_{\theta(i,j)} x(t_{k-N+j} - \eta_{k-N+j}), \quad (60)$$

where  $t \in [t_k, t_{k+1}), i = 1, ..., N, A_{\theta(i,j)} = BK_{\theta(i,j)}C_{\theta(i,j)},$ 

$$k = \begin{cases} N\ell + i - 1, \text{ for } i \in \mathcal{I} \setminus \{N\}, \ \ell \in \mathbb{N} \\ N\ell - 1, \quad \text{ for } i = N, \ \ell \in \mathbb{N} \end{cases}$$
$$\theta(i, j) = \begin{cases} i + j, & \text{ if } i + j \leq N, \\ i + j - N, & \text{ if } i + j > N, \ j = 1, \dots, N. \end{cases}$$

We represent  $t_{k-N+j} - \eta_{k-N+j} = t - \tau_j(t), \ j = 1, ..., N$ , where

*(*...)

$$\begin{aligned} \tau_{\vartheta}(t) &< \tau_{\vartheta-1}(t), \ \vartheta = 2, \dots, N, \\ \tau_{\vartheta}(t) &= t - t_{k-N+\vartheta} + \eta_{k-N+\vartheta}, \\ \tau_{\vartheta-1}(t) &= t - t_{k-N+\vartheta-1} + \eta_{k-N+\vartheta-1}, \\ \tau_j(t) &\in [\eta_m, \tau_M^j], \ t \in [t_k, t_{k+1}), \ j = 1, \dots, N. \end{aligned}$$

Therefore, (60) can be considered as a system with N time-varying interval delays, where  $\tau_{\vartheta}(t) < \tau_{\vartheta-1}(t), \vartheta =$  $2, \ldots, N$ . The stability analysis of the closed-loop system (60) can be based on the common (for both subsystems of the switched system) time-independent LKF for the exponential stability of systems with time-varying delay from the maximum delay interval  $[\eta_m, \bar{\tau}_M^1]$  (see e.g., [48, 80]). Moreover, system (60) can be analyzed by taking into account the order of the delays  $\tau_{\vartheta}(t) < \tau_{\vartheta-1}(t), \vartheta = 2, \dots, N$ , and applying convexity arguments of [159] via Lemma 1. In the special case when NCSs with N = 2 sensors and with constant measurement delay, one can adopt a switched time-dependent Lyapunov functional construction, which is based on the extension of Wirtinger's inequality [77]. See more details in [125].

**Remark 5** The simplified closed-loop system model (59) consists of one system with independent delays from the maximum delay interval  $[\eta_m, \tau_M^1]$ . The closed-loop system (60) is presented in the form of switched N subsystems (instead of one system) with ordered multiple delays, which is a more accurate model of the closed-loop system under Round-Robin protocol.

#### 5.3.3Round-Robin protocol and an impulsive system model

Under Round-Robin protocol (47), the reset system (52)can be rewritten as

$$\begin{cases} x(t_{k+1}) = x(t_{k+1}^{-}), \\ e_{i_{k-j}^{*}}(t_{k+1}) = C_{i_{k-j}^{*}}[x(s_{k-j}) - x(s_{k+1})], \\ j = 0, \dots, N-1 \text{ if } k \ge N-1, \end{cases}$$
(61)

where the index k - j corresponds to the last updated measurement in the node  $i_{k-j}^*$ .

The stability of system (47), (51), (61) can be analyzed by Lyapunov functional (33) of [126], leading to a more complicated analysis.

#### 5.4 TOD/Round-Robin Protocol: N = 2

For N = 2, less restrictive analysis of exponential stability of (51)–(52) under both TOD and Round-Robin protocols can be derived via a different from (53) Lyapunov functional:

$$\hat{V}_{e}(t) = V(t, x_{t}, \dot{x}_{t}) + \frac{t_{k+1} - t}{\tau_{M} - \eta_{m}} \{ e_{i}^{T}(t) Q_{i} e_{i}(t) \}_{|i \neq i_{k}^{*}}, \quad (62)$$

where  $Q_1 > 0$ ,  $Q_2 > 0$ ,  $\alpha > 0$ ,  $t \in [t_k, t_{k+1})$ ,  $k \in \mathbb{Z}^+$ ,  $i_k^* \in \{1, 2\}$  and  $V(t, x_t, \dot{x}_t)$  is given by (53) with  $G_i = Q_i e^{2\alpha\tau_M}$ . The term  $\frac{t_{k+1}-t}{\tau_M - \eta_m} [e_i^T(t_k)Q_i e_i(t_k)]$  is inspired by the similar construction of Lyapunov functionals for the sampled-data systems [49, 150, 186]. The following statement holds:

**Lemma 8** [126] Given N = 2, if there exist positive constant  $\alpha$  and  $\hat{V}_e(t)$  of (62) such that along (51), the following inequality holds

$$\hat{V}_e(t) + 2\alpha \hat{V}_e(t) \le 0, \ t \in [t_k, t_{k+1}).$$

Then  $\hat{V}_e(t)$  does not grow in the jumps along (51), (52), (46)) ((51), (52), (47)), where

$$V_e(t_{k+1}) - V_e(t_{k+1}^-) \le 0.$$

The bound (55) is valid for the solutions of (51), (52), (46)) ((51), (52), (47)) with the initial condition  $x_{t_0} \in W[-\tau_M, 0], e(t_0) \in \mathbb{R}^{n_y}$ , implying exponential stability of (51), (52), (46)) ((51), (52), (47)) with respect to x.

**Remark 6** Differently from Lemmas 6 and 7, Lemma 8 guarantees  $\hat{V}_e(t_{k+1}) \leq e^{-2\alpha(t_{k+1}-t_0)}\hat{V}_e(t_0)$ , which does not give a bound on  $e_{i_k^*}(t_k)$  since  $\hat{V}_e(t)$  for  $t \in [t_k, t_{k+1})$  does not depend on  $e_{i_k^*}(t_k)$ . That is why Lemma 8 guarantees exponential stability only with respect to x. However, it is explained that under Round-Robin protocol exponential stability with respect to x implies boundedness of e. See Remark 5.4 in [126].

#### 5.5 Stochastic Protocol and a Stochastic Impulsive Timedelay System Model

Following the modelling of NCSs under TOD protocol, the closed-loop system of NCSs under iid protocol (48) or under Markovian protocol (49) can be also formulated as an impulsive system model (51)–(52) under (48) or under (49), respectively.

Following [242], we introduce the indicator functions

$$\pi_{\{i_k^*=i\}} = \begin{cases} 1, \ i_k^* = i \\ 0, \ i_k^* \neq i, \end{cases} \ i \in \mathcal{I}, \ k \in \mathbb{Z}^+$$

Thus, from (48) it follows that

$$\begin{split} & \mathbb{E}\{\pi_{\{i_k^*=i\}}\} = \mathbb{E}\{[\pi_{\{i_k^*=i\}}]^2\} = \operatorname{Prob}\{i_k^*=i\} = \beta_i, \\ & \mathbb{E}\{[\pi_{\{i_k^*=i\}} - \beta_i][\pi_{\{i_k^*=j\}} - \beta_j]\} = \begin{cases} -\beta_i\beta_j, \ i \neq j, \\ \beta_i(1 - \beta_i), \ i = j. \end{cases} \end{split}$$

Therefore, the stochastic impulsive system model (51)–(52) under (48) can be rewritten as

$$\begin{cases} \dot{x}(t) = Ax(t) + A_1 x(t_k - \eta_k) + \sum_{i=1}^N (1 - \pi_{\{i_k^* = i\}}) B_i e_i(t), \\ \dot{e}(t) = 0, \ t \in [t_k, t_{k+1}) \end{cases}$$

$$\tag{63}$$

with the delayed reset system

$$\begin{cases} x(t_{k+1}) = x(t_{k+1}^{-}), \\ e_i(t_{k+1}) = (1 - \pi_{\{i_k^* = i\}})e_i(t_{k+1}^{-}) \\ + C_i[x(t_k - \eta_k) - x(t_{k+1} - \eta_{k+1})], \ i = 1, \dots, N. \end{cases}$$
(64)

Consider the LKF (53). The following lemma gives sufficient conditions for exponential stability of (63)–(64) in the mean-square sense:

**Lemma 9** [128] If there exist positive constant  $\alpha$ ,  $0 < Q_i \in \mathbb{R}^{n_i \times n_i}$ ,  $0 < U_i \in \mathbb{R}^{n_i \times n_i}$ ,  $0 < G_i \in \mathbb{R}^{n_i \times n_i}$ ,  $i = 1, \ldots, N$ , and  $V_e(t)$  of (53) such that along (63) for  $t \in [t_k, t_{k+1})$ 

$$\mathbb{E}\{\mathcal{L}V_e(t) + 2\alpha V_e(t) - \frac{1}{\tau_M - \eta_m} \sum_{i=1}^N e_i^T(t) U_i e_i(t)\} \le 0$$

with

$$\begin{bmatrix} -\beta_i Q_i + U_i & (1 - \beta_i) Q_i \\ * & Q_i - G_i e^{-2\alpha \tau_M} \end{bmatrix} \le 0, \ i = 1, \dots, N.$$

Then  $V_e(t)$  does not grow in the jumps along (63)-(64)

$$\mathbb{E}\{V_e(t_{k+1}) - V_e(t_{k+1}^-) + \sum_{i=1}^N e_i^T(t_k)U_ie_i(t_k)\} \le 0.$$

Moreover, the following bounds hold for the solutions of (63)-(64) with the initial condition  $x_{t_0}$ ,  $e(t_0)$ :

$$\mathbb{E}\{V(t, x_t, \dot{x}_t)\} \le e^{-2\alpha(t-t_0)} \mathbb{E}\{V_e(t_0)\}, \ t \ge t_0, V_e(t_0) = V(t_0, x_{t_0}, \dot{x}_{t_0}) + \sum_{i=1}^N e_i^T(t_0) Q_i e_i(t_0),$$
(65)

and

$$\sum_{i=1}^{N} \mathbb{E}\{|\sqrt{Q_i}e_i(t)|^2\} \le \tilde{c}e^{-2\alpha(t-t_0)}\mathbb{E}\{V_e(t_0)\}, \qquad (66)$$

where  $\tilde{c} = e^{2\alpha(\tau_M - \eta_m)}$ , implying exponential mean-square stability of (63)–(64).

The exponential mean-square stability of stochastic Markovian jump impulsive system (51)–(52) under (49) can be similarly analyzed. See more details in [128].

**Remark 7** By the time-delay approach, the scheduling protocols were further considered in different control problems in the literature, e.g., in [218] for distributed estimation with  $H_{\infty}$  consensus, in [12] to design networkbased  $H_{\infty}$  filter for a parabolic system, in [257] for setmembership filtering problem of time-varying system, and in [227] to achieve master-salve synchronization. **Remark 8** Decentralized networked control of large-scale interconnected systems with local independent networks was studied in the framework of impulsive systems [17, 81], where variable sampling or/and small communication delays were taken into account. Distributed estimation in the presence of synchronous sampling of local networks and Round-Robin protocol was analyzed in [218] in the framework of time-delay approach. The time-delay approach was extended in [42] to decentralized NCSs with multiple local communication networks under TOD or Round-Robin protocol.

**Remark 9** Note that the aforementioned works on scheduling protocols are concerned with continuous-time systems. The time-delay approach to the modelling and analysis of NCSs with discrete-time plant under scheduling protocols can be formulated by following the same lines of reasoning, see e.g., [124] for discrete-time networked systems with actuator constraints and two sensor nodes under TOD or under Round-Robin protocol, [130] for quantized control with multiple sensor nodes under Round-Robin protocol, [133] for discrete-time networked systems with multiple sensor nodes under dynamic scheduling protocols, [43] for decentralized networked control of large-scale discrete-time systems with local networks, where the multiple sensor nodes of each subsystem are orchestrated by TOD or Round-Robin protocol.

#### 6 Networked Control of Parabolic PDEs

In this section, we show how the time-delay approach can be used for robust control of parabolic PDEs with different types of sampled in time measurements or/and actuations. Other methods for sampled-data control of PDEs include the discrete-time approach [136–138,215] (for general LTI PDE systems) and the modal decomposition technique [24, 34,67,106,112].

In the setup, the control enters PDEs through shape functions  $b_i \in L_2$  that was initiated in [51, 52]. For simplicity, we consider characteristic shape functions  $b_i = \chi_i$ . However, the results can be extended to arbitrary  $b_i$  such that  $\|b_i - \chi_i\|_{L_2}$  is small enough [181]. Note that LKFs for heat equations with fast-varying delays were introduced in [54], where LMI stability conditions were derived via the descriptor method [44] (see Section 4.7.3 of [50]). Sampled-data *point* control is a more challenging problem that is hard to solve using only LKFs. Robustness of statefeedback boundary control with respect to data sampling have been established in [106]. The analysis is based on the Fourier series and the input-to-state stability ideas of [105].



Fig. 7. Sampled in time averaged measurements

#### 6.1 Averaged Measurements

Consider the reaction-diffusion PDE

$$z_t(x,t) = z_{xx}(x,t) + az(x,t) + \sum_{j=1}^N \chi_j(x)u_j(t), \qquad (67)$$
$$z(0,t) = z(l,t) = 0$$

with the state  $z: [0, l] \times [0, \infty) \to \mathbb{R}$  and control inputs  $u_j: (0, \infty) \to \mathbb{R}$ ,  $j = 1, \ldots, N$ . The reaction coefficient a may depend on z, x, and t, but is supposed to be uniformly bounded:  $|a| \leq a_0$  and smooth with respect to all variables. Following [51], we assume that there are N+1 points  $0 = x_0 < x_1 < \cdots < x_N = l$  dividing the space domain (0, l) into N subdomains  $(x_{j-1}, x_j)$ . The control enters the system through the characteristic functions

$$\chi_j(x) = \begin{cases} 1, & x \in (x_{j-1}, x_j), \\ 0, & x \notin (x_{j-1}, x_j), \end{cases} \quad j = 1, \dots, N.$$

The sampled in time averaged measurements (Fig. 7) are given by [12, 41, 51]

$$y_{j,k} = \frac{1}{\Delta_j} \int_{x_{j-1}}^{x_j} z(\xi, t_k) \, d\xi, \tag{68}$$

where  $\Delta_j = |x_j - x_{j-1}|$  are the subdomain sizes and the sampling instants  $t_k$ ,  $k = 0, 1, \ldots$ , satisfy

$$0 = t_0 < t_1 < t_2 < \cdots, \quad \lim_{k \to \infty} t_k = \infty, \quad t_{k+1} - t_k \le h.$$

Consider the sampled-data output-feedback control

$$u_j(t) = -Ky_{j,k}, \quad t \in [t_k, t_{k+1}).$$
 (69)

The closed-loop system has the form

$$z_t(x,t) = z_{xx}(x,t) + az(x,t) - K \sum_{j=1}^N \chi_j(x) y_{j,k},$$
  
$$t \in [t_k, t_{k+1}). \quad (70)$$

The existence of a unique classical solution to (70) can be established by applying [162, Theorem 6.3.3] consecutively on each interval  $[0, t_k], [t_k, t_{k+1}], \ldots$ , where the sampled-data terms can be treated as inhomogeneities.

If  $-K \sum_{j=1}^{N} \chi_j(x) y_{j,k}$  is replaced by -Kz(x,t), then the system is stable for a large enough K [52]. The term

 $\sum_{j=1}^{N} \chi_j(x) y_{j,k}$  approximates the state z(x,t):

$$\sum_{j=1}^{N} \frac{\chi_j(x)}{\Delta_j} \int_{x_{j-1}}^{x_j} z(\xi, t_k) \, d\xi = z(x, t) - \sigma(x, t) - \kappa(x, t),$$

where, for  $x \in (0, l)$  and  $t \in [t_k, t_{k+1})$ ,

$$\kappa(x,t) = \sum_{j=1}^{N} \frac{\chi_j(x)}{\Delta_j} \int_{x_{j-1}}^{x_j} [z(\xi,t) - z(\xi,t_k)] d\xi$$
  
$$\sigma(x,t) = z(x,t) - \sum_{j=1}^{N} \frac{\chi_j(x)}{\Delta_j} \int_{x_{j-1}}^{x_j} z(\xi,t) d\xi.$$

The function  $\sigma$  represents the error that occurs when the state is approximated using the averaged measurements. It can be bounded using Pioncaré's inequality.

Lemma 10 (Poincaré's inequality [161]) Let  $f \in \mathcal{H}^1(0,l)$  be such that  $\int_0^l f(x) dx = 0$ . Then

$$\|f\|_{L_2} \le \frac{l}{\pi} \|f'\|_{L_2}$$

Since  $\int_{x_{j-1}}^{x_j} \sigma = 0$  for  $j = 1, \dots, N$ , Lemma 10 implies

$$\|\sigma\|_{L_2} \le \frac{\max \Delta_j}{\pi} \|\sigma_x\|_{L_2} = \frac{\max \Delta_j}{\pi} \|z_x\|_{L_2}$$

Thus, the upper bound on  $\sigma$  can be made smaller by reducing the maximum subdomain size max  $\Delta_j$ .

The error due to sampling  $\kappa$  can be compensated using an appropriate Lyapunov–Krasovskii term, e.g.,

$$V_W = Wh^2 e^{2\alpha h} \int_{t_k}^t e^{-2\alpha(t-s)} ||z_s(\cdot, s)||_{L_2}^2 ds$$
$$-W \frac{\pi^2}{4} \int_{t_k}^t e^{-2\alpha(t-s)} ||\kappa(\cdot, s)||_{L_2}^2 ds$$

for  $t \in [t_k, t_{k+1})$  with a scalar W > 0. To show that  $V_W \ge 0$ , note that, since  $\kappa(\cdot, t_k) = 0$ , Wirtinger's inequality (Lemma 5) implies

$$\begin{split} \int_{t_k}^t e^{-2\alpha(t-s)} \|\kappa(\cdot,s)\|_{L_2}^2 \, ds \\ &\leq e^{2\alpha h} \frac{4h^2}{\pi^2} \int_{t_k}^t e^{-2\alpha(t-s)} \|\kappa_s(\cdot,s)\|_{L_2}^2 \, ds. \end{split}$$

Using Jensen's inequality, we have

$$\begin{split} \int_{t_k}^t e^{-2\alpha(t-s)} \|\kappa_s(\cdot,s)\|_{L_2}^2 \, ds \\ &= \int_{t_k}^t e^{-2\alpha(t-s)} \int_0^l \sum_{j=1}^N \frac{\chi(x)}{\Delta_j^2} \left[ \int_{x_{j-1}}^{x_j} z_s(\xi,s) \, d\xi \right]^2 \, dx \, ds \\ &\leq \int_{t_k}^t e^{-2\alpha(t-s)} \int_0^l \sum_{j=1}^N \frac{\chi(x)}{\Delta_j} \int_{x_{j-1}}^{x_j} z_s^2(\xi,s) \, d\xi \, dx \, ds \\ &= \int_{t_k}^t e^{-2\alpha(t-s)} \|z_s(\cdot,s)\|_{L_2}^2 \, ds. \end{split}$$



Fig. 8. Sampled in time point measurements

Thus,  $V_W > 0$ . Calculating the derivative, we obtain

$$\dot{V}_W + 2\alpha V_W = Wh^2 e^{2\alpha h} \|z_t(\cdot, t)\|_{L_2}^2 - W \frac{\pi^2}{4} \|\kappa(\cdot, t)\|_{L_2}^2$$

While the negative term compensates the sampling error  $\kappa$ , the positive term can be made smaller by reducing the sampling period h.

The LMIs guaranteeing the exponential stability of (67)– (69) can be derived using  $V = ||z(\cdot,t)||_{L_2}^2 + p||z_x(\cdot,t)||_{L_2}^2 + V_W$ . As for ODEs, for PDEs we derive  $\dot{V} + 2\alpha V \leq 0$  that, by the comparison principle, implies  $V(t) \leq e^{-2\alpha t}V(0)$ , which guarantees the exponential stability. The ideas described in this subsection were originally presented in [51], where the  $H_{\infty}$  control of semilinear 1D diffusion PDE was considered. The approach has been extended to multi-dimensional systems in the presence of Round-Robin protocol [12] and to sampled-data relay control [181].

#### 6.2 Point Measurements

As introduced in [52], consider the system (67) with the point measurements (Fig. 8)

$$y_{j,k} = z(\bar{x}_j, t_k), \quad \bar{x}_j = \frac{x_{j-1} + x_j}{2}, \quad j = 1, \dots, N.$$

Let the control be given by (69), which leads to the closedloop system (70). The existence of a unique classical solution to (70) with the point measurements can be established by applying [162, Theorem 6.3.3] consecutively on each interval  $[0, t_k], [t_k, t_{k+1}], \ldots$ , where the sampled-data terms can be treated as inhomogeneities.

The term 
$$\sum_{j=1}^{N} \chi_j(x) y_{j,k}$$
 approximates the state  $z(x,t)$ :  

$$\sum_{j=1}^{N} \chi_j(x) z(\bar{x}_j, t_k) = z(x,t) - \varsigma(x,t_k) - \varkappa(x,t),$$

where, for  $x \in (0, l)$  and  $t \in [t_k, t_{k+1})$ ,

$$\varsigma(x,t_k) = z(x,t_k) - \sum_{j=1}^N \chi_j(x) z(\bar{x}_j,t_k),$$
  
$$\varkappa(x,t) = z(x,t) - z(x,t_k).$$

The error due to sampling  $\varkappa$  can be compensated using the Lyapunov–Krasovskii term similar to  $V_W$  from the previous subsection. Since  $\varsigma(\cdot, t_k) = 0$ , the error due to point

measurements  $\varsigma$  can be bounded using Wirtinger's inequality:

$$\|\varsigma\|_{L_{2}} \leq \frac{\max \Delta_{j}}{\pi} \|\varsigma_{x}(\cdot, t_{k})\|_{L_{2}} = \frac{\max \Delta_{j}}{\pi} \|z_{x}(\cdot, t_{k})\|_{L_{2}}.$$
(71)

To compensate the term  $\frac{\max \Delta_j}{\pi} \| z_x(\cdot, t_k) \|_{L_2}$ , Halanay's inequality was used in [52].

**Lemma 11 (Halanay's inequality [50])** Let  $V = [-h, \infty) \rightarrow [0, \infty)$  be absolutely continuous and such that

$$\dot{V}(t) + 2\delta_0 V(t) - 2\delta_1 \sup_{-h \le \theta \le 0} V(t+\theta) \le 0, \quad t \ge 0$$

for  $0 < \delta_1 < \delta_0$ . Then  $V(t) \le e^{-2\alpha t} \sup_{-h \le \theta \le 0} V(\theta), \quad t \ge 0,$ 

where  $\alpha$  is the solution of  $\alpha = \delta_0 - \delta_1 e^{2\alpha h}$ .

If  $V(t) = ||z(\cdot,t)||_{L_2}^2 + p||z_x(\cdot,t)||_{L_2}^2 + V_W(t)$ , where  $V_W$  is the term compensating the sampling error  $\varkappa$ , then the term

$$-2\delta_1 \sup_{-h \le \theta \le 0} V(t+\theta) \le -2\delta_1 V(t_k)$$

contains  $-2\delta_1 p \|z_x(\cdot, t_k)\|_{L_2}^2$ , which can dominate the righthand side of (71). The LMI-based stability conditions summing up the above ideas can be found in [52], where a nonlinear system was considered.

The ideas of Subsections 6.1 and 6.2 have been developed for the event-triggered control [177]. They can also be used to construct sampled-data observers compensating constant input delays in point actuators (both in-domain and boundary) [182]. The approach can be used for sampleddata stabilization of the Kuramoto–Sivashinsky equation [104].

There is an important difference between the averaged and point measurements. First, since the averaged measurements were analyzed using the direct Lyapunov–Krasovskii approach, these results can be easily extended to  $H_{\infty}$  filtering and control [51,52]. Halanay's inequality does not allow for such extension in the case of point measurements. Moreover, while averaged measurements can be easily treated in the case of multi-dimensional domains [12], point measurements cannot since extension of (71) for higher dimensions contains higher-order derivatives in the right-hand side (cf. (81) below). However, this issue has been overcome in [183] by considering pointlike measurements for 2D heat equations presented in the next subsection.

#### 6.3 Pointlike Measurements for 2D Domains

Consider the reaction-diffusion system

$$z_t(x,t) = \Delta_D z(x,t) + a z(x,t), \quad x \in \Omega, \ t > 0, z|_{\partial\Omega} = 0, \quad z|_{t=0} = z_0$$
(72)



Fig. 9. Subdomains  $\Omega_i$  and the subset supp  $c_i \subset \overline{\Omega}_i$ 

defined on  $\Omega = (0,1) \times (0,1) \subset \mathbb{R}^2$  with the state  $z : \overline{\Omega} \times [0,\infty) \to \mathbb{R}$ , reaction coefficient *a*, and diffusion term

$$\Delta_D z = \operatorname{div}(D\nabla z), \quad 0 < D = \begin{bmatrix} d_1 & d_2 \\ d_2 & d_3 \end{bmatrix} \in \mathbb{R}^{2 \times 2}.$$
(73)

Let  $\Omega$  be divided into N square subdomains  $\Omega_i$  (Fig. 9) with a sensor placed in each  $\Omega_i$  providing the measurements

$$y_{i,k} = \int_{\Omega_i} c_i(\xi) z(\xi, t_k) d\xi,$$
  

$$0 \le c_i \in L_{\infty}(\Omega_i), \quad \int_{\Omega_i} c_i = 1, \quad i = 1, \dots, N,$$
(74)

where the sampling instants  $t_k$  satisfy

$$0 = t_0 < t_1 \cdots, \quad \lim_{k \to \infty} t_k = \infty, \quad t_{k+1} - t_k \le h$$

For example,

$$c_i(\xi) = \begin{cases} \frac{1}{\varepsilon^2}, \ |\xi - x_c^i|_{\infty} < \frac{\varepsilon}{2}, \\ 0, \ |\xi - x_c^i|_{\infty} \ge \frac{\varepsilon}{2} \end{cases}$$
(75)

with a small  $\varepsilon \in (0, 1/\sqrt{N}]$  model point measurements at  $x_c^i \in \Omega_i$ . The case of  $\varepsilon = 1/\sqrt{N}$  was considered in [12].

Consider the sampled-data observer

$$\hat{z}_{t}(x,t) = \Delta_{D}\hat{z}(x,t) + a\hat{z}(x,t) + L\sum_{i=1}^{N} \chi_{i}(x) \times \begin{bmatrix} y_{i,k} - \int_{\Omega_{i}} c_{i}(\xi)\hat{z}(\xi,t_{k}) d\xi \end{bmatrix}, \quad t \in [t_{k},t_{k+1}), \ k \in \mathbb{N},$$
$$\hat{z}|_{\partial\Omega} = 0, \quad \hat{z}|_{t=0} = 0$$
(76)

with the injection gain L and characteristic functions

$$\chi_i(x) = \begin{cases} 1, \ x \in \Omega_i, \\ 0, \ x \notin \Omega_i, \end{cases} \quad i = 1, \dots, N.$$
 (77)

The estimation error  $\bar{z}(x,t) = z(x,t) - \hat{z}(x,t)$  satisfies

$$\bar{z}_{t} = \Delta_{D}\bar{z} + a\bar{z} - L\sum_{i=1}^{N} \chi_{i}(x) \int_{\Omega_{i}} c_{i}(\xi)\bar{z}(\xi, t_{k}) d\xi, t \in [t_{k}, t_{k+1}),$$
(78)

 $\bar{z}|_{\partial\Omega} = 0, \quad \bar{z}|_{t=0} = z_0,$ 

The last term approximates the stabilizing feedback  $-L\bar{z}$ :

$$-L\sum_{i=1}^{N}\chi_{i}(x)\int_{\Omega_{i}}c_{i}(\xi)\bar{z}(\xi,t_{k})\,d\xi=-L\bar{z}+\sigma+\kappa,$$



Fig. 10. Four rectangles cornered at  $x^i \in \operatorname{supp} c_i$ 

where

$$\sigma(x,t) = L\bar{z}(x,t) - L\sum_{i=1}^{N} \chi_i(x) \int_{\Omega_i} c_i(\xi) \bar{z}(\xi,t) d\xi,$$

$$\kappa(x,t) = L\sum_{i=1}^{N} \chi_i(x) \int_{\Omega_i} c_i(\xi) \left[ \bar{z}(\xi,t) - \bar{z}(\xi,t_k) \right] d\xi.$$
(79)

Using these notations, the system (78) can be presented as

$$\bar{z}_t = \Delta_D \bar{z} + (a - L)\bar{z} + \sigma + \kappa, \quad x \in \Omega, \ t > 0,$$
  
$$\bar{z}|_{\partial\Omega} = 0, \qquad \bar{z}|_{t=0} = z_0.$$
(80)

If  $\sigma \equiv 0$  and  $\kappa \equiv 0$ , then the system (80) is stable for a large enough injection gain L. If  $\Omega = (0, 1)$ , the error  $\sigma \neq 0$  can be bounded using Wirtinger's inequality, which was used in [52] to prove the stability of (80) for large L and N. The following inequality can be used to bound the error  $\sigma$  in the case of  $\Omega = (0, 1)^2$ . This lemma refines [103, Lemma 4.1].

**Lemma 12 ( [183])** Let  $f \in H^2((0,l)^2;\mathbb{R})$ , f(0,0) = 0. Then

$$\|f\|_{L_{2}}^{2} \leq \frac{1}{\alpha_{1}} \left(\frac{2l}{\pi}\right)^{2} \left\|\frac{\partial f}{\partial x_{1}}\right\|_{L_{2}}^{2} + \frac{1}{\alpha_{2}} \left(\frac{2l}{\pi}\right)^{2} \left\|\frac{\partial f}{\partial x_{2}}\right\|_{L_{2}}^{2} + \frac{1}{\alpha_{3}} \left(\frac{2l}{\pi}\right)^{4} \left\|\frac{\partial^{2} f}{\partial x_{1} \partial x_{2}}\right\|_{L_{2}}^{2}$$
(81)

for any positive  $\alpha_1$ ,  $\alpha_2$ ,  $\alpha_3$  such that  $\alpha_1 + \alpha_2 + \alpha_3 = 1$ .

**Corollary 1** Let  $f \in H^2((0,l)^2; \mathbb{R})$ , f(0,0) = 0,  $\eta > 0$ . Then

$$\eta \|f\|_{L_{2}}^{2} \leq \lambda_{1} \left(\frac{2l}{\pi}\right)^{2} \left\|\frac{\partial f}{\partial x_{1}}\right\|_{L_{2}}^{2} + \lambda_{2} \left(\frac{2l}{\pi}\right)^{2} \left\|\frac{\partial f}{\partial x_{2}}\right\|_{L_{2}}^{2} + \lambda_{3} \left(\frac{2l}{\pi}\right)^{4} \left\|\frac{\partial^{2} f}{\partial x_{1} \partial x_{2}}\right\|_{L_{2}}^{2}$$
(82)

for any  $\lambda_1$ ,  $\lambda_2$ ,  $\lambda_3$  satisfying

diag 
$$\lambda_1, \lambda_2, \lambda_3 \ge \eta \begin{bmatrix} 1 & 1 & 1 \\ 1 & 1 & 1 \\ 1 & 1 & 1 \end{bmatrix}$$
. (83)

By the mean value theorem (this idea comes from [223]),

$$\int_{\Omega_i} c_i(\xi) \bar{z}(\xi, t) \, d\xi = \bar{z}(x^i(t), t),$$

where  $x^{i}(t)$  belongs to the convex hull of the support of  $c_{i}$  for  $t \geq 0$  and i = 1, ..., N. Each rectangle cornered at

 $x^i \in \operatorname{supp} c_i$  and lying in  $\Omega_i$  (see Fig. 10) has sides smaller than

$$l = \max_{i=1,\dots,N} \max_{\substack{\omega \in \partial \Omega_i \\ d \in \operatorname{supp} c_i}} |\omega - d|_{\infty}.$$
 (84)

Applying Corollary 1 to  $\sigma$  defined in (79) on each of such rectangles and summing over them, we obtain

$$0 \leq -\eta \frac{\|\sigma\|_{L_{2}}^{2}}{L^{2}} + \lambda_{1} \left(\frac{2l}{\pi}\right)^{2} \|\bar{z}_{x_{1}}\|_{L_{2}}^{2} + \lambda_{2} \left(\frac{2l}{\pi}\right)^{2} \|\bar{z}_{x_{2}}\|_{L_{2}}^{2} + \lambda_{3} \left(\frac{2l}{\pi}\right)^{4} \|\bar{z}_{x_{1}x_{2}}\|_{L_{2}}^{2}$$
(85)

with  $\eta > 0$ ,  $\lambda_1$ ,  $\lambda_2$ ,  $\lambda_3$  satisfying (83). The positive terms in (85) can be made arbitrarily small by reducing l, i.e., by increasing the number of sensors N. In order to compensate the second order derivative, one has to consider  $V = \|\bar{z}\|_{L_2}^2 + p\|\bar{z}_x\|_{L_2}^2$ .

The error due to sampling  $\kappa$  is compensated by the Wirtinger-based term

$$V_{\kappa} = p_{\kappa} e^{2\alpha h} \int_{t_{k}}^{t} e^{-2\alpha(t-s)} \|\kappa_{s}(\cdot,s)\|_{L_{2}}^{2} ds$$
$$-\nu \int_{t_{k}}^{t} e^{-2\alpha(t-s)} \|\kappa(\cdot,s)\|_{L_{2}}^{2} ds,$$

which gives

$$\dot{V}_{\kappa} + 2\alpha V_{\kappa} = \max_{i} \|c_{i}\|_{L_{\infty}} h^{2} e^{2\alpha h} \tilde{p}_{\kappa} \int_{\Omega} \bar{z}_{t}^{2}(\xi, t) d\xi - \nu \|\kappa(\cdot, t)\|_{L_{2}}^{2}.$$

Note that the coefficient  $\max_i \|c_i\|_{L_{\infty}} h^2$  makes this approach inapplicable to  $c_i = \delta$ . Moreover, if  $\varepsilon$  from (75) gets smaller (i.e.,  $\max_i \|c_i\|_{L_{\infty}}$  gets bigger), then the maximum allowable sampling h decreases. The LMI-based convergence conditions combining the above ideas can be found in [183].

If  $\Omega = (0, 1)^3$ , an upper bound for  $\sigma$  similar to (85) can be derived. This bound will involve the 3rd order space derivative, which we do not know how to compensate. Thus, it is not clear how to extend the proposed method to 3D domains.

#### 7 Conclusions and Suggestions for Further Research

This paper has presented fundamental network-induced issues in NCSs and the main approaches to the modelling of NCSs: discrete-time modeling approach, impulsive system approach and time-delay approach. Recent results on time-delay approach to event-triggered control, modelling and analysis of NCSs under scheduling protocols, and networked control of distributed parameter systems have been surveyed, respectively. This survey has mostly focused on linear systems, where constructive LMI conditions are available. Note that many of the presented ideas can be extended to nonlinear systems (see e.g., [104]). Although a number of remarkable results on networked control under communication constraints have been achieved in the literature, the following problems are of interest to future research:

- The time-delay approach has been utilized to the modelling and analysis of NCSs under scheduling protocols for the sensor nodes. How to include the consideration of scheduling protocols for the actuator nodes is worthy of further study.
- In [172], it is revealed that in general the networkinduced communication delay is modelled as a gamma distribution model. By direct Lyapunov approach, stability analysis of linear continuous-time systems with gamma-distributed delays [129, 202] and linear discretetime systems with poisson-distributed delays [131] has been studied. In network environments, how to include gamma-distributed or poisson-distributed delays in the model formulation of NCSs under scheduling protocols is significant in theory and in practice.
- Due to the openness of the network, NCSs are more vulnerable to malicious threats such as data tampering, eavesdropping and interception. The issues of network security have attracted ever-increasing attention in recent years, see e.g., [?, 6, 29, 90, 147, 173] and the references therein. It would be interesting to extend the current frameworks on scheduling protocols to security control of NCSs.
- We have demonstrated that the time-delay approach can be used to study the networked control of PDEs with actuators modeled by shape functions. The analysis of sampled-data control with point actuators is a more challenging problem. The solution may be to combine the time-delay approach with the Fourier series.

#### Acknowledgment

This work is partially supported by the National Natural Science Foundation of China (grant no. 61503026, 61873034), the Beijing Natural Science Foundation (grant no. 4182057), the Israel Science Foundation (grant no. 1128/14), Chana and Henrich Manderman Chair at Tel Aviv University.

#### References

- K. J. Åström. Event based control. In Analysis and design of nonlinear control systems, pages 127–148. Springer, 2008.
- [2] K. J. Åström and B. M. Bernhardsson. Comparison of Periodic and Event Based Sampling for First-Order Stochastic Systems. In 14th IFAC World Congress, pages 301–306, 1999.
- [3] K. J. Åström and B. M. Bernhardsson. Comparison of Riemann and Lebesgue sampling for first order stochastic systems. In Proceedings of the 41st IEEE Conference on Decision and Control, pages 2011–2016, 2002.
- [4] A. Adaldo, D. Liuzza, D. V. Dimarogonas, and K. H. Johansson. Cloud-supported formation control of secondorder multi-agent systems. *IEEE Transactions on Control of Network Systems*, 5(4):1563–1574, 2018.

- [5] J. Almeida, C. Silvestre, and A. Pascoal. Synchronization of multiagent systems using event-triggered and self-triggered broadcasts. *IEEE Transactions on Automatic Control*, 62(9):4741–4746, 2017.
- [6] S. Amin, G. A. Schwartz, and S. S. Sastry. Security of interdependent and identical networked control systems. *Automatica*, 49(1):186–192, 2013.
- [7] A. Anta and P. Tabuada. To sample or not to sample: Selftriggered control for nonlinear systems. *IEEE Transactions on Automatic Control*, 55(9):2030–2042, 2010.
- P. Antsaklis and J. Baillieul. Special issue on technology of networked control systems. *Proceedings of the IEEE*, 95(1):5– 8, 2007.
- [9] D. Antunes and W. P.M.H. Heemels. Rollout eventtriggered control: Beyond periodic control performance. *IEEE Transactions on Automatic Control*, 59(12):3296–3311, 2014.
- [10] K E Årzén. A simple envent-based PID controller. In Proceedings of the 14th World Congress of the International Federation of Automatic Control, pages 423–428, Beijing, China, July 1999.
- [11] B. Bamieh, J.B. Pearson, B.A. Francis, and A. Tannenbaum. A lifting technique for linear periodic systems with applications to sampled-data control. Systems & Control Letters, 17(2):79– 88, 1991.
- [12] N. Bar Am and E. Fridman. Network-based H<sub>∞</sub> filtering of parabolic systems. Automatica, 50(12):3139–3146, 2014.
- [13] J. E. F. Baruch and M. J. Cox. Remote control and robots: an Internet solution. Computing & Control Engineering Journal, 7:39–45, 1996.
- [14] T. Başar and P. Bernhard.  $H_{\infty}$  Optimal Control and Related Minimax Design Problems. A Dynamic Game Approach. Birkhäuser, Boston, 1995.
- [15] F. Blanchini and S. Miani. Stabilization of LPV systems: state feedback, state estimation, and duality. *SIAM Journal* on Control and Optimization, 42(1):76–97, 2003.
- [16] D. P. Borgers and W. P. M. H. Heemels. Eventseparation properties of event-triggered control systems. *IEEE Transactions on Automatic Control*, 59(10):2644–2656, 2014.
- [17] D. P. Borgers and W. P. M. H. Heemels. Stability analysis of large-scale networked control systems with local networks: A hybrid small-gain approach. In *Proceedings of the 17th International Conference on Hybrid Systems: Computation* and Control, Berlin, Germany, April 2014.
- [18] D.P. Borgers and W. P. M. H. Heemels. Eventseparation properties of event-triggered control systems. *IEEE Transactions on Automatic Control*, 59(10):2644–2656, 2014.
- [19] C. Briat and A. Seuret. A looped-functional approach for robust stability analysis of linear impulsive systems. Systems & Control Letters, 61(10):980–988, 2012.
- [20] R. Brockett and D. Liberzon. Quantized feedback stabilization of linear systems. *IEEE Transactions on Automatic Control*, 45(7):1279–1289, 2000.
- [21] H. Chan and Ü. Özgüner. Closed-loop control of systems over a communications network with queues. *International Journal* of Control, 62(3):493–510, 1995.
- [22] T. W. Chen and B. A. Francis. Optimal Sampled-data Control Systems. Springer-Verlag, London, 1995.
- [23] W. H. Chen and W. X. Zheng. Input-to-state stability for networked control systems via an improved impulsive system approach. Automatica, 47(4):789–796, 2011.
- [24] P. D. Christofides. Nonlinear and Robust Control of PDE Systems. Systems & Control: Foundations & Applications. Birkhäuser Boston, Boston, MA, 2001.

- [25] M. B. G. Cloosterman, L. Hetel, N. van de Wouw, W. P. M. H. Heemels, J. Daafouz, and H. Nijmeijer. Controller synthesis for networked control systems. *Automatica*, 46(10):1584–1594, 2010.
- [26] M. B. G. Cloosterman, N. van de Wouw, W. P. M. H. Heemels, and H. Nijmeijer. Stability of networked control systems with large delays. In *Proceedings of the 46th IEEE Conference on Decision and Control*, New Orleans, USA, December 2007.
- [27] M. B. G. Cloosterman, N. van de Wouw, W. P. M. H. Heemels, and H. Nijmeijer. Stability of networked control systems with uncertain time-varying delays. *IEEE Transactions on Automatic Control*, 54(7):1575–1580, 2009.
- [28] S. J. Dodds. Adaptive, high precision, satellite attitude control for microprocessor implementation. Automatica, 17(4):563– 573, 1981.
- [29] V. S. Dolk, P. Tesi, C. De Persis, and W. P. M. H. Heemels. Event-triggered control systems under denial-ofservice attacks. *IEEE Transactions on Control of Network* Systems, 4(1):93–105, 2017.
- [30] M. C. F. Donkers, W. P. M. H. Heemels, D. Bernardini, A. Bemporad, and V. Shneer. Stability analysis of stochastic networked control systems. *Automatica*, 48(5):917–925, 2012.
- [31] M. C. F. Donkers, W. P. M. H. Heemels, N. van de Wouw, and L. Hetel. Stability analysis of networked control systems using a switched linear systems approach. *IEEE Transactions* on Automatic Control, 56(9):2101–2115, 2011.
- [32] M. C. F. Donkers, L. Hetel, W. P. M. H. Heemels, N. van de Wouw, and M. Steinbuch. Stability analysis of networked control systems using a switched linear systems approach. *Hybrid Systems: Computation and Control, Lecture Notes in Computer Science*, 5469:150–164, 2009.
- [33] C. S. Draper, W. Wrigley, and J. Hovorka. *Inertial Guidance*. Pergamon Press, New York, 1960.
- [34] S. Dubljevic, N. H. El-Farra, P. Mhaskar, and P. D. Christofides. Predictive control of parabolic PDEs with state and control constraints. *International Journal of Robust and Nonlinear Control*, 16:749–772, 2006.
- [35] G. Dullerud and K. Glover. Robust stabilization of sampleddata systems to structured LTI perturbations. *IEEE Transactions on Automatic Control*, 38(10):1497–1508, 1993.
- [36] N. Elia and S. K. Mitter. Stabilization of linear systems with limited information. *IEEE Transactions on Automatic Control*, 46(9):1384–1400, 2001.
- [37] B. Etkin and L. D. Reid. Dynamics of Flight: Stability and Control. Wiley, New York, 1996.
- [38] Z. G. Feng, J. Lam, and G. H. Yang. Optimal partitioning method for stability analysis of continuous/discrete delay systems. *International Journal of Robust and Nonlinear Control*, 25(4):559–574, 2015.
- [39] Z. G. Feng and W. X. Zheng. On extended dissipativity of discrete-time neural networks with time delay. *IEEE* transactions on Neural Networks and Learning Systems, 26(12):3293–3300, 2015.
- [40] C. Fiter, L. Hetel, W. Perruquetti, and J. P. Richard. A state dependent sampling for linear state feedback. *Automatica*, 48(8):1860–1867, 2012.
- [41] C. Foias, C. F. Mondaini, and E. S. Titi. A discrete dData assimilation scheme for the solutions of the two-dimensional Navier-Stokes equation and their statistics. *SIAM Journal on Applied Dynamical Systems*, 15(4):2109–2142, 2016.
- [42] D. Freirich and E. Fridman. Decentralized networked control of systems with local networks: A time-delay approach. *Automatica*, 69:201–209, 2016.

- [43] D. Freirich and E. Fridman. Decentralized networked control of discrete-time systems with local networks. *International Journal of Robust and Nonlinear Control*, 28(1):365–380, 2018.
- [44] E. Fridman. New Lyapunov-Krasovskii functionals for stability of linear retarded and neutral type systems. Systems & Control Letters, 43(4):309–319, 2001.
- [45] E. Fridman. Stability of linear descriptor systems with delay: a lyapunov-based approach. *Journal of Mathematical Analysis* and Applications, 273(1):24–44, 2002.
- [46] E. Fridman. Discussion on: "stabilization of networked control systems with data packet dropout and transmission delays: continuous-time case". *European Journal of Control*, 11(1):53– 55, 2005.
- [47] E. Fridman. Descriptor discretized lyapunov functional method: analysis and design. *IEEE Transactions on Automatic Control*, 51(5):890–897, 2006.
- [48] E. Fridman. A new Lyapunov technique for robust control of systems with uncertain non-small delays. IMA Journal of Mathematical Control and Information, 23(2):165–179, 2006.
- [49] E. Fridman. A refined input delay approach to sampled-data control. Automatica, 46(2):421–427, 2010.
- [50] E. Fridman. Introduction to Time-Delay Systems. Birkhäuser, Basel, 2014.
- [51] E. Fridman and N. Bar Am. Sampled-data distributed  $H_{\infty}$  control of transport reaction systems. SIAM Journal on Control and Optimization, 51(2):1500–1527, 2013.
- [52] E. Fridman and A. Blighovsky. Robust sampled-data control of a class of semilinear parabolic systems. *Automatica*, 48(5):826– 836, 2012.
- [53] E. Fridman and M. Dambrine. Control under quantization, saturation and delay: an LMI approach. Automatica, 45(10):2258–2264, 2009.
- [54] E. Fridman and Y. Orlov. Exponential stability of linear distributed parameter systems with time-varying delays. *Automatica*, 45(1):194–201, 2009.
- [55] E. Fridman, A. Seuret, and J. P. Richard. Robust sampleddata stabilization of linear systems: an input delay approach. *Automatica*, 40(8):1441–1446, 2004.
- [56] E. Fridman and L. Shaikhet. Delay-induced stability of vector second-order systems via simple Lyapunov functionals. *Automatica*, 74:288–296, 2016.
- [57] E. Fridman and L. Shaikhet. Stabilization by using artificial delays: An LMI approach. Automatica, 81:429–437, 2017.
- [58] E. Fridman and U. Shaked. Delay-dependent stability and  $H_{\infty}$  control: constant and time-varying delays. International Journal of Control, 76(1):48–60, 2003.
- [59] E. Fridman and U. Shaked. Input-output approach to stability and L<sub>2</sub>-gain analysis of systems with time-varying delays. Systems & Control Letters, 55(12):1041–1053, 2006.
- [60] E. Fridman and G. Tsodik.  $H_{\infty}$  control of distributed and discrete delay systems via discretized Lyapunov functional. *European Journal of Control*, 15(1):84–96, 2009.
- [61] Emilia Fridman. Tutorial on Lyapunov-based methods for time-delay systems. European Journal of Control, 20(6):271– 283, 2014.
- [62] M. Y. Fu and L. H. Xie. The sector bound approach to quantized feedback control. *IEEE Transactions on Automatic Control*, 50(11):1698–1711, 2005.
- [63] H. Fujioka. Stability analysis for a class of networked/embedded control systems: a discrete-time approach. In *Proceedings of the 2008 American Control Conference*, Washington, USA, June 2008.

- [64] H. J. Gao and T. W. Chen. Network-based H<sub>∞</sub> output tracking control. *IEEE Transactions on Automatic Control*, 53(3):655– 667, 2008.
- [65] H. J. Gao, T. W. Chen, and J. Lam. A new delay system approach to network-based control. *Automatica*, 44(1):39–52, 2008.
- [66] A. K. Gelig and A. Churilov. Stability and Oscillations of Nonlinear Pulse-modulated Systems. Birkhäuser, Boston, 1998.
- [67] S. Ghantasala and N. H. El-Farra. Active fault-tolerant control of sampled-data nonlinear distributed parameter systems. *International Journal of Robust and Nonlinear Control*, 22:24– 42, 2012.
- [68] R. H. Gielen, S. Olaru, M. Lazar, W. P. M. H. Heemels, N. van de Wouw, and S. I. Niculescu. On polytopic inclusions as a modeling framework for systems with time-varying delays. *Automatica*, 46(3):615–619, 2010.
- [69] R. Goebel, R. G. Sanfelice, and A. Teel. Hybrid dynamical systems. *IEEE Control Systems Magazine*, 29(2):28–93, 2009.
- [70] G. C. Goodwin, R. L. Leal, D. Q. Mayne, and R. H. Middleton. Rapprochement between continuous and discrete model reference adaptive control. *Automatica*, 22(2):199–207, 1986.
- [71] F. Gouaisbaut and D. Peaucelle. Delay-dependent robust stability of time delay systems. In *Proceedings of the 5th IFAC Symposium on Robust Control Design*, Toulouse, France, July 2006.
- [72] K. Gu. Discretized LMI set in the stability problem of linear uncertain time-delay systems. *International Journal of Control*, 68(4):923–934, 1997.
- [73] K. Gu. Stability problem of systems with multiple delay channels. Automatica, 46:743–751, 2010.
- [74] K. Gu, V. Kharitonov, and J. Chen. Stability of Time-Delay Systems. Birkhäuser, Boston, 2003.
- [75] K. Gu and S. I. Niculescu. Further remarks on additional dynamics in various model transformations of linear delay systems. *IEEE Transactions on Automatic Control*, 46(3):497– 500, 2001.
- [76] X. R. Han, E. Fridman, and S. K. Spurgeon. Sampled-data sliding mode observer for robust fault reconstruction: A timedelay approach. *Journal of the Franklin Institute*, 351(4):2125– 2142, 2014.
- [77] G. Hardy, J. Littlewood, and G. Pólya. Inequalitites. Cambridge, 1934.
- [78] K. Hashimoto, S. Adachi, and D. V. Dimarogonas. Eventtriggered intermittent sampling for nonlinear model predictive control. *Automatica*, 81:148–155, 2017.
- [79] K. Hashimoto, S. Adachi, and D. V. Dimarogonas. Selftriggered model predictive control for nonlinear input-affine dynamical systems via adaptive control samples selection. *IEEE Transactions on Automatic Control*, 62(1):177–189, 2017.
- [80] Y. He, Q. G. Wang, C. Lin, and M. Wu. Delay-range-dependent stability for systems with time-varying delay. *Automatica*, 43(2):371–376, 2007.
- [81] W. P. M. H. Heemels, D. Borgers, N. van de Wouw, D. Nesic, and A. R. Teel. Stability analysis of nonlinear networked control systems with asynchronous communication: A smallgain approach. In *Proceedings of the 52nd IEEE Conference on Decision and Control*, Florence, Italy, December 2013.
- [82] W. P. M. H. Heemels and M. C. F. Donkers. Model-based periodic event-triggered control for linear systems. *Automatica*, 49(3):698–711, 2013.

- [83] W. P M H Heemels, M. C F Donkers, and Andrew R. Teel. Periodic event-triggered control for linear systems. *IEEE Transactions on Automatic Control*, 58(4):847–861, 2013.
- [84] W. P. M. H. Heemels, K. H. Johansson, and P. Tabuada. An introduction to event-triggered and self-triggered control. In *Proceedings of Conference on Decision and Control*, Hawaii, USA, December 2012.
- [85] W. P. M. H. Heemels, Karl H. Johansson, and Paulo Tabuada. An introduction to event-triggered and self-triggered control. In *IEEE Conference on Decision and Control*, pages 3270– 3285, 2012.
- [86] W. P. M. H. Heemels, D. Nesic, A. R. Teel, and N. van de Wouw. Networked and quantized control systems with communication delays. In *Proceedings of the 48th IEEE Conference on Decision and Control*, Shanghai, China, December 2009.
- [87] W. P. M. H. Heemels, J. H. Sandee, and P. P. J. Van Den Bosch. Analysis of event-driven controllers for linear systems. *International Journal of Control*, 81(4):571–590, 2008.
- [88] W. P. M. H. Heemels, A. Teel, N. van de Wouw, and D. Nesic. Networked control systems with communication constraints: tradeoffs between transmission intervals, delays and performance. *IEEE Transactions on Automatic Control*, 55(8):1781–1796, 2010.
- [89] W. P. M. H. Heemels, N. van de Wouw, R. H. Gielen, M. C. F. Donkers, L. Hetel, S. Olaru, M. Lazar, J. Daafouz, and S. I. Niculescu. Comparison of overapproximation methods for stability analysis of networked control systems. In *Proceedings of the 13th International Conference on Hybrid Systems: Computation and Control*, Stockholm, Sweden, April 2010.
- [90] J. M. Hendrickx, K. H. Johansson, R. M. Jungers, H. Sandberg, and K. C. Sou. Efficient computations of a security index for false data attacks in power networks. *IEEE Transactions on Automatic Control*, 59(12):3194–3208, 2014.
- [91] J. Hespanha, P. Naghshtabrizi, and Y. Xu. A survey of recent results in networked control systems. *Proceedings of the IEEE*, 95(1):138–162, 2007.
- [92] L. Hetel, J. Daafouz, and C. Iung. Stabilization of arbitrary switched linear systems with unknown time-varying delays. *IEEE Transactions on Automatic Control*, 51(10):1668–1674, 2006.
- [93] L. Hetel, C. Fiter, H. Omran, A. Seuret, E. Fridman, J. P. Richard, and S. I. Niculescu. Recent developments on the stability of systems with aperiodic sampling: An overview. *Automatica*, 76:309–335, 2017.
- [94] L. Hetel, A. Kruszewski, W. Perruquetti, and J. P. Richard. Discrete and intersample analysis of systems with aperiodic sampling. *IEEE Transactions on Automatic Control*, 56(7):1696–1701, 2011.
- [95] D. Hristu-Varsakelis and W. S. Levine. Handbook of Networked and Embedded Control Systems. Birkhäuser, Boston, 2005.
- [96] S. Hu and W. Y. Yan. Stability robustness of networked control systems with respect to packet loss. *Automatica*, 43(7):1243– 1248, 2007.
- [97] S. S. Hu and Q. X. Zhu. Stochastic optimal control and analysis of stability of networked control systems with long delay. *Automatica*, 39(11):1877–1884, 2003.
- [98] C. C. Hua, C. Ge, and X. P. Guan. Synchronization of chaotic Lur'e systems with time delays using sampled-data control. *IEEE Transactions on Neural Networks and Learning Systems*, 26(6):1214–1221, 2015.
- [99] D. Huang and S. K. Nguang. State feedback control of uncertain networked control systems with random time delays.

IEEE Transactions on Automatic Control, 53(3):829–834, 2008.

- [100] D. Huang and S. K. Nguang. Robust Control for Uncertain Networked Control Systems with Random Delays. Springer-Verlag, Berlin, 2009.
- [101] O. C. Imer, S. Yüksel, and T. Başar. Optimal control of LTI systems over unreliable communication links. *Automatica*, 42(9):1429–1439, 2006.
- [102] H. Ishii.  $H_{\infty}$  control with limited communication and message losses. Systems & Control Letters, 57(4):322–331, 2008.
- [103] D. Jones and E. S. Titi. Upper bounds on the number of determining modes, nodes, and volume elements for the Navier-Stokes equations. *Indiana University Mathematics Journal*, 42(3):875–887, 1993.
- [104] W. Kang and E. Fridman. Distributed sampled-data control of Kuramoto–Sivashinsky equation. Automatica, 95:514–524, 2018.
- [105] I. Karafyllis and M. Krstic. ISS with respect to boundary disturbances for 1-D parabolic PDEs. *IEEE Transactions on Automatic Control*, 61(12):1–23, 2016.
- [106] I. Karafyllis and M. Krstic. Sampled-data boundary feedback control of 1-D parabolic PDEs. Automatica, 87:226–237, 2018.
- [107] V. L. Kharitonov and D. Melchor-Aguilar. On delay-dependent stability conditions. Systems & Control Letters, 40(1):71–76, 2000.
- [108] V. L. Kharitonov and S. I. Niculescu. On the stability of linear systems with uncertain delay. *IEEE Transactions on Automatic Control*, 48(1):127–132, 2003.
- [109] V. B. Kolmanovskii and J.P. Richard. Stability of some linear systems with delays. *IEEE Transactions on Automatic Control*, 44(5):984–989, 1999.
- [110] G. V. Kondraske, R. A. Volz, D. H. Johnson, D. Tesar, J. C. Trinkle, and C. R. Price. Network-based infrastructure for distributed remote operations and robotics research. *IEEE Transactions on Robotics and Automation*, 9(5):702–704, 1993.
- [111] H. Kopetz. Should responsive systems be event-triggered or time-triggered? *IEICE Transactions on Information and Systems*, E76-D:1325–1332, 1993.
- [112] L. F. Lao, M. Ellis, and P. D. Christofides. Economic model predictive control of parabolic PDE systems: Addressing state estimation and computational efficiency. *Journal of Process Control*, 24(4):448–462, 2014.
- [113] J. W. Lee. On uniform stabilization of discrete-time linear parameter-varying control systems. *IEEE Transactions on Automatic Control*, 51(10):1714–1721, 2006.
- [114] K. B. Lee and R. D. Schneeman. Internet-based distributed measurement and control applications. *IEEE Instrumentation & Measurement Magazine*, 2(2):23–27, 1999.
- [115] S. Y. Lee, W. I. Lee, and P. G. Park. Polynomials-based integral inequality for stability analysis of linear systems with timevarying delays. *Journal of the Franklin Institute*, 354(4):2053– 2067, 2017.
- [116] T. H. Lee, J. H. Park, S. M. Lee, and O. M. Kwon. Robust synchronisation of chaotic systems with randomly occurring uncertainties via stochastic sampled-data control. *International Journal of Control*, 86(1):107–119, 2013.
- [117] X. Li and C. E. de Souza. Criteria for robust stability and stabilization of uncertain linear systems with state delay. *Automatica*, 33(9):1657–1662, 1997.
- [118] D. Liberzon. Hybrid feedback stabilization of systems with quantized signals. Automatica, 39(9):1543–1554, 2003.

- [119] D. Liberzon and D. Nesic. Input-to-state stabilization of linear systems with quantized state measurements. *IEEE Transactions on Automatic Control*, 52(5):767–781, 2007.
- [120] G. P. Liu, Y. Q. Xia, J. Chen, D. Rees, and W. S. Hu. Networked predictive control of systems with random network delays in both forward and feedback channels. *IEEE Transactions on Industrial Electronics*, 54(3):1282–1297, 2007.
- [121] K. Liu and E. Fridman. Networked-based stabilization via discontinuous Lyapunov functionals. International Journal of Robust and Nonlinear Control, 22(4):420–436, 2012.
- [122] K. Liu and E. Fridman. Wirtinger's inequality and Lyapunovbased sampled-data stabilization. Automatica, 48(1):102–108, 2012.
- [123] K. Liu and E. Fridman. Delay-dependent methods and the first delay interval. Systems & Control Letters, 64(1):57–63, 2014.
- [124] K. Liu and E. Fridman. Discrete-time network-based control under scheduling and actuator constraints. *International Journal of Robust and Nonlinear Control*, 25(12):1816–1830, 2015.
- [125] K. Liu, E. Fridman, and L. Hetel. Stability and L<sub>2</sub>-gain analysis of networked control systems under Round-Robin scheduling: a time-delay approach. Systems & Control Letters, 61(5):666– 675, 2012.
- [126] K. Liu, E. Fridman, and L. Hetel. Networked control systems in the presence of scheduling protocols and communication delays. *SIAM Journal of Control and Optimization*, 53(4):1768–1788, 2015.
- [127] K. Liu, E. Fridman, and K. H. Johansson. Dynamic quantization of uncertain linear networked control systems. *Automatica*, 59:248–255, 2015.
- [128] K. Liu, E. Fridman, and K. H. Johansson. Networked control with stochastic scheduling. *IEEE Transactions on Automatic Control*, 60(11):3071–3076, 2015.
- [129] K. Liu, E. Fridman, K. H. Johansson, and Y. Q. Xia. Generalized jensen inequalities with application to stability analysis of systems with distributed delays over infinite timehorizons. *Automatica*, 69:222–231, 2016.
- [130] K. Liu, E. Fridman, K. H. Johansson, and Y. Q. Xia. Quantized control under Round-Robin communication protocol. *IEEE Transactions on Industrial Electronics*, 63(7):4461–4471, 2016.
- [131] K. Liu, K. H. Johansson, E. Fridman, and Y. Q. Xia. Stability analysis of discrete-time systems with poisson-distributed delays. In *Proceedings of the 54th IEEE Conference on Decision* and Control, Osaka, Japan, December 2015.
- [132] K. Liu and A. Seuret. Comparison of bounding methods for stability analysis of systems with time-varying delays. *Journal* of the Franklin Institute, 354(7):2979–2993, 2017.
- [133] K. Liu, A. Seuret, E. Fridman, and Y. Q. Xia. Improved stability conditions for discrete-time systems under dynamic network protocols. *International Journal of Robust and Nonlinear Control*, 28:4479–4499, 2018.
- [134] K. Liu, A. Seuret, and Y. Q. Xia. Stability analysis of systems with time-varying delays via the second-order Bessel-Legendre inequality. *Automatica*, 76:138–142, 2017.
- [135] K. Liu, V. Suplin, and E. Fridman. Stability of linear systems with general sawtooth delay. IMA Journal of Mathematical Control and Information, 27(4):419–436, 2010.
- [136] H. Logemann. Stabilization of well-posed infinite-dimensional systems by dynamic sampled-data feedback. SIAM Journal on Control and Optimization, 51(2):1203–1231, 2013.
- [137] H. Logemann, R. Rebarber, and S. Townley. Stability of infinite-dimensional sampled-data systems. *Transactions of the American Mathematical Society*, 355(8):3301–3328, 2003.

- [138] H. Logemann, R. Rebarber, and S. Townley. Generalized sampled-data stabilization of well-posed linear infinitedimensional systems. SIAM Journal on Control and Optimization, 44(4):1345–1369, 2005.
- [139] J. Louisell. New examples of quenching in delay differential equations having time-varying delay. In *Proceedings of* the 4th European Control Conference, Karlshruhe, Germany, September 1999.
- [140] R. Q. Lu, P. Shi, H. Y. Su, Z. G. Wu, and J. Q. Lu. Synchronization of general chaotic neural networks with nonuniform sampling and packet missing: a switched system approach. *IEEE Transactions on Neural Networks and Learning Systems*, 29(3):523–533, 2018.
- [141] J. Lunze and D. Lehmann. A state-feedback approach to eventbased control. Automatica, 46(1):211–215, 2010.
- [142] A. I. Lurie. Some Non-linear Problems in the Theory of Automatic Control. H.M. Stationery, London, 1957.
- [143] T. D. Ma, F. L. Lewis, and Y. D. Song. Exponential synchronization of nonlinear multi-agent systems with time delays and impulsive disturbances. *International Journal of Robust and Nonlinear Control*, 26(8):1615–1631, 2016.
- [144] M. Mazo, A. Anta, and P. Tabuada. An ISS self-triggered implementation of linear controllers. *Automatica*, 46(8):1310– 1314, 2010.
- [145] R. Middleton and G. C. Goodwin. Improved finite word length characteristics in digital control using delta operators. *IEEE Transactions on Automatic Control*, 31(11):1015–1021, 1986.
- [146] Y. Mikheev, V. Sobolev, and E. Fridman. Asymptotic analysis of digital control systems. Automation and Remote Control, 49(9):1175–1180, 1988.
- [147] R. Mitchell and R. Chen. Adaptive intrusion detection of malicious unmanned air vehicles using behavior rule specifications. *IEEE Transactions on Systems, Man, and Cybernetics: Systems*, 44(5):593–604, 2014.
- [148] Y. S. Moon, P. Park, W. H. Kwon, and Y. S. Lee. Delaydependent robust stabilization of uncertain state-delayed systems. *International Journal of Control*, 74(14):1447–1455, 2001.
- [149] P. Naghshtabrizi, J. Hespanha, and A. R. Teel. Stability of delay impulsive systems with application to networked control systems. *Transactions of the Institute of Measurement and Control*, 32(5):511–528, 2010.
- [150] P. Naghshtabrizi, J. P. Hespanha, and A. R. Teel. Exponential stability of impulsive systems with application to uncertain sampled-data systems. *Systems & Control Letters*, 57(5):378– 385, 2008.
- [151] D. Nesic and D. Liberzon. A unified framework for design and analysis of networked and quantized control systems. *IEEE Transactions on Automatic Control*, 54(4):732–747, 2009.
- [152] D. Nesic and A. R. Teel. Input-output stability properties of networked control systems. *IEEE Transactions on Automatic Control*, 49(10):1650–1667, 2004.
- [153] J. Nilsson. Real-time control systems with delays. PhD thesis, Lund Institute of Technology, 1998.
- [154] J. Nilsson, B. Bernhardsson, and B. Wittenmark. Stochastic analysis and control of real-time systems with random time delays. *Automatica*, 34(1):57–64, 1998.
- [155] C. Nowzari and J. Cortés. Self-triggered coordination of robotic networks for optimal deployment. Automatica, 48(6):1077– 1087, 2012.
- [156] P. G. Otanez, J. R. Moyne, and D. M. Tilbury. Using deadbands to reduce communication in networked control

systems. In *Proceedings of the 2002 American Control* Conference, Alaska, USA, May 2002.

- [157] A. Papachristodoulou, M. M. Peet, and S. I. Niculescu. Stability analysis of linear systems with time-varying delays: delay uncertainty and quenching. In *Proceedings of the 46th IEEE Conference on Decision and Control*, New Orleans, USA, December 2007.
- [158] P. G. Park. A delay-dependent stability criterion for systems with uncertain time-invariant delays. *IEEE Transactions on Automatic Control*, 44(4):876–877, 1999.
- [159] P. G. Park, J. Ko, and C. Jeong. Reciprocally convex approach to stability of systems with time-varying delays. *Automatica*, 47(1):235–238, 2011.
- [160] P. G. Park, W. I. Lee, and S. Y. Lee. Auxiliary functionbased integral inequalities for quadratic functions and their applications to time-delay systems. *Journal of the Franklin Institute*, 352(4):1378–1396, 2015.
- [161] L. E. Payne and H. F. Weinberger. An optimal Poincaré inequality for convex domains. Archive for Rational Mechanics and Analysis, 5(1):286–292, 1960.
- [162] A. Pazy. Semigroups of Linear Operators and Applications to Partial Differential Equations. Springer, New York, 1983.
- [163] M. M. Peet and P. A. Bliman. On the conservatism of the sum-of-squares method for analysis of time-delayed systems. *Automatica*, 47(11):2406–2411, 2011.
- [164] M. M. Peet, A. Papachristodoulou, and S. Lall. Positive forms and stability of linear time-delay systems. SIAM Journal on Control and Optimization, 47(6):3237–3258, 2009.
- [165] C. Peng and Q. L. Han. A novel event-triggered transmission scheme and L<sub>2</sub> control co-design for sampled-data control systems. *IEEE Transactions on Automatic Control*, 58(10):2620-2626, 2013.
- [166] C. Peng, S. D. Ma, and X. P. Xie. Observer-based non-PDC control for networked T–S fuzzy systems with an eventtriggered communication. *IEEE Transactions on Cybernetics*, 47(8):2279–2287, 2017.
- [167] C. Peng and T. C. Yang. Event-triggered communication and  $H_{\infty}$  control co-design for networked control systems. *Automatica*, 49(5):1326–1332, 2013.
- [168] C. Peng, J. Zhang, and Q. L. Han. Consensus of multiagent systems with nonlinear dynamics using an integrated sampleddata-based event-triggered communication scheme. *IEEE Transactions on Systems, Man, and Cybernetics: Systems*, 49(3):589–599, 2019.
- [169] R. Postoyan, P. Tabuada, D. Nešić, and A. Anta. A framework for the event-triggered stabilization of nonlinear systems. *IEEE Transactions on Automatic Control*, 60(4):982–996, 2015.
- [170] A. Ray. Distributed data communication networks for realtime process control. *Chemical Engineering Communications*, 65(1):139–154, 1988.
- [171] J. P. Richard. Time-delay systems: An overview of some recent advances and open problems. *Automatica*, 39(10):1667–1694, 2003.
- [172] O. Roesch, H. Roth, and S. I. Niculescu. Remote control of mechatronic systems over communication networks. In Proceedings of the IEEE International Conference on Mechatronics & Automation, Niagara Falls, Canada, July 2005.
- [173] H. Sandberg, S. Amin, and K. H. Johansson. Special issue on cyberphysical security in networked control systems. *IEEE Control Systems Magazine*, 35(1):20–23, 2015.
- [174] L. Schenato. To zero or to hold control inputs with lossy links? *IEEE Transactions on Automatic Control*, 54(5):1093–1099, 2009.

- [175] P. Seiler and R. Sengupta. An  $H_{\infty}$  approach to networked control. *IEEE Transactions on Automatic Control*, 50(3):356–364, 2005.
- [176] A. Selivanov and E. Fridman. A switching approach to eventtriggered control. In *Proceedings of the 54th IEEE Conference* on Decision and Control, pages 5468–5473, 2015.
- [177] A. Selivanov and E. Fridman. Distributed event-triggered control of diffusion semilinear PDEs. Automatica, 68:344–351, 2016.
- [178] A. Selivanov and E. Fridman. Event-triggered  $H_{\infty}$  control: A switching approach. *IEEE Transactions on Automatic Control*, 61(10):3221–3226, 2016.
- [179] A. Selivanov and E. Fridman. Observer-based input-to-state stabilization of networked control systems with large uncertain delays. *Automatica*, 74:63–70, 2016.
- [180] A. Selivanov and E. Fridman. Predictor-based networked control under uncertain transmission delays. *Automatica*, 70:101–108, 2016.
- [181] A. Selivanov and E. Fridman. Sampled-data relay control of diffusion PDEs. Automatica, 82:59–68, 2017.
- [182] A. Selivanov and E. Fridman. Delayed point control of a reaction-diffusion PDE under discrete-time point measurements. *Automatica*, 96:224–233, 2018.
- [183] A. Selivanov and E. Fridman. Sampled-data  $H_{\infty}$  filtering of a 2D heat equation under pointlike measurements. In *Proceedings of the 57th Conference on Decision and Control*, 2018.
- [184] A. Selivanov and E. Fridman. Sampled-data implementation of derivative-dependent control using artificial delays. *IEEE Transactions on Automatic Control*, 63(10):3594–3600, 2018.
- [185] A. Selivanov, E. Fridman, and A. Fradkov. Event-triggered adaptive control of minimum-phase systems. In Proceedings of the 20th World Congress of the International Federation of Automatic Control, Toulouse, France, July 2017.
- [186] A. Seuret. A novel stability analysis of linear systems under asynchronous samplings. Automatica, 48(1):177–182, 2012.
- [187] A. Seuret and C. Briat. Stability analysis of uncertain sampleddata systems with incremental delay using looped-functionals. *Automatica*, 55:274–278, 2015.
- [188] A. Seuret and E. Fridman. Wirtinger-like Lyapunov-Krasovskii functionals for discrete-time delay systems. IMA Journal of Mathematical Control and Information, 35(3):861–876, 2018.
- [189] A. Seuret and F. Gouaisbaut. Wirtinger-based integral inequality: Application to time-delay systems. *Automatica*, 49(9):2860–2866, 2013.
- [190] A. Seuret and F. Gouaisbaut. Hierarchy of LMI conditions for the stability analysis of time-delay systems. Systems & Control Letters, 81:1–7, 2015.
- [191] A. Seuret and F. Gouaisbaut. Stability of linear systems with time-varying delays using Bessel-Legendre inequalities. *IEEE Transactions on Automatic Control*, 63(1):225–232, 2018.
- [192] A. Seuret, F. Gouaisbaut, and Y. Ariba. Complete quadratic Lyapunov functionals for distributed delay systems. *Automatica*, 62:168–176, 2015.
- [193] A. Seuret, F. Gouaisbaut, and E. Fridman. Stability of systems with fast-varying delay using improved Wirtinger's inequality. In Proceedings of the 52nd IEEE Conference on Decision and Control, pages 946–951, Florence, Italy, December 2013.
- [194] A. Seuret, K. Liu, and F. Gouaisbaut. Generalized reciprocally convex combination lemmas and its application to time-delay systems. *Automatica*, 95:488–493, 2018.

- [195] A. Seuret, C. Prieur, S. Tarbouriech, and L. Zaccarian. LQbased event-triggered controller co-design for saturated linear systems. *Automatica*, 74:47–54, 2016.
- [196] D. H. Shah and A. Mehta. Discrete-Time Sliding Mode Control for Networked Control System. Springer Nature, Singapore, 2018.
- [197] H. Y. Shao. New delay-dependent stability criteria for systems with interval delay. Automatica, 45(3):744–749, 2009.
- [198] Y. Shi and B. Yu. Output feedback stabilization of networked control systems with random delays modeled by Markov chains. *IEEE Transactions on Automatic Control*, 54(7):1668–1674, 2009.
- [199] Y. Shi and B. Yu. Robust mixed  $H_2/H_{\infty}$  control of networked control systems with random time delays in both forward and backward communication links. *Automatica*, 47(4):754–760, 2011.
- [200] N. Sivashankar and P. P. Khargonekar. Characterization of the L<sub>2</sub>-induced norm for linear systems with jumps with applications to sampled-data systems. SIAM Journal on Control and Optimization, 32(4):1128–1150, 1994.
- [201] J. Skaf and S. Boyd. Analysis and synthesis of state-feedback controllers with timing jitter. *IEEE Transactions on Automatic Control*, 54(3):652–657, 2009.
- [202] O. Solomon and E. Fridman. New stability conditions for systems with distributed delays. Automatica, 49(11):3467– 3475, 2013.
- [203] M. Souza, G. S. Deaecto, J. C. Geromel, and J. Daafouz. Selftriggered linear quadratic networked control. *Optimal Control Applications and Methods*, 35(5):524–538, 2014.
- [204] Y. S. Suh. Stability and stabilization of nonuniform sampling systems. Automatica, 44(12):3222–3226, 2008.
- [205] X. M. Sun, G. P. Liu, W. Wang, and D. Rees. Stability analysis for networked control systems based on average dwell time method. *International Journal of Robust and Nonlinear Control*, 20(15):1774–1784, 2010.
- [206] V. Suplin, E. Fridman, and U. Shaked. A projection approach to h<sub>∞</sub> control of time-delay systems. In *Proceedings of the 43rd IEEE Conference on Decision and Control*, volume 5, pages 4548–4553. IEEE, 2004.
- [207] V. Suplin, E. Fridman, and U. Shaked.  $H_{\infty}$  control of linear uncertain time-delay systems-a projection approach. *IEEE Transactions on Automatic Control*, 51(4):680–685, 2006.
- [208] V. Suplin, E. Fridman, and U. Shaked. Sampled-data  $H_{\infty}$  control and filtering: nonuniform uncertain sampling. Automatica, 43(6):1072–1083, 2007.
- [209] V. Suplin, E. Fridman, and U. Shaked.  $H_{\infty}$  sampled-data control of systems with time-delays. International Journal of Control, 82(2):298–309, 2009.
- [210] M. Tabbara and D. Nesic. Input-output stability of networked control systems with stochastic protocols and channels. *IEEE Transactions on Automatic Control*, 53(5):1160–1175, 2008.
- [211] P. Tabuada. Event-triggered real-time scheduling of stabilizing control tasks. *IEEE Transactions on Automatic Control*, 52(9):1680–1685, 2007.
- [212] P. Tallapragada and N. Chopra. Event-triggered decentralized dynamic output feedback control for LTI systems. In *IFAC Proceedings Volumes*, volume 45, pages 31–36, 2012.
- [213] P. Tallapragada and N. Chopra. Event-triggered dynamic output feedback control for LTI systems. In *Proceedings of the* 51st IEEE Conference on Decision and Control, Hawaii, USA, December 2012.

- [214] P. Tallapragada and N. Chopra. Decentralized event-triggering for control of nonlinear systems. *IEEE Transactions on Automatic Control*, 59(12):3312–3324, 2015.
- [215] Y. Tan, E. Trélat, Y. Chitour, and D. Nešić. Dynamic practical stabilization of sampled-data linear distributed parameter systems. In *Proceedings of the 48th IEEE Conference on Decision and Control*, Shanghai, China, December 2009.
- [216] Y. Z. Tsypkin. Theory of Impulse Systems. State Publisher for Physical and Mathematical Literature, Moscow, 1958.
- [217] Y. Z. Tsypkin. *Relay Control Systems*. Cambridge University Press, Cambridge, UK, 1984.
- [218] V. Ugrinovskii and E. Fridman. A Round-Robin type protocol for distributed estimation with  $H_{\infty}$  consensus. Systems & Control Letters, 69:103–110, 2014.
- [219] N. van de Wouw, P. Naghshtabrizi, M. B. G. Cloosterman, and J. P. Hespanha. Tracking control for sampled-data systems with uncertain time-varying sampling intervals and delays. *International Journal of Robust and Nonlinear Control*, 20(4):387–411, 2009.
- [220] S. van Loon, M. Donkers, N. van de Wouw, and W. P. M. H. Heemels. Stability analysis of networked control systems with periodic protocols and uniform quantizers. In *Proceedings of the 4th IFAC Conference on Analysis and Design of Hybrid Systems*, Eindhoven, Netherlands, June 2012.
- [221] G. C. Walsh, O. Beldiman, and L. G. Bushnell. Asymptotic behavior of nonlinear networked control systems. *IEEE Transactions on Automatic Control*, 46(7):1093–1097, 2001.
- [222] G. C. Walsh, H. Ye, and L. G. Bushnell. Stability analysis of networked control systems. *IEEE Transactions on Control* Systems Technology, 10(3):438–446, 2002.
- [223] J. W. Wang and H. N. Wu. Lyapunov-based design of locally collocated controllers for semi-linear parabolic PDE systems. *Journal of the Franklin Institute*, 351(1):429–441, 2014.
- [224] R. Wang, G. P. Liu, W. Wang, D. Rees, and Y. B. Zhao.  $H_{\infty}$  control for networked predictive control systems based on the switched lyapunov function method. *IEEE Transactions on Industrial Electronics*, 57(10):3565–3571, 2010.
- [225] X. F. Wang and M. D. Lemmon. Self-triggered feedback control systems with finite-gain L<sub>2</sub> stability. *IEEE Transactions on Automatic Control*, 54(3):452–467, 2009.
- [226] X. F. Wang and M. D. Lemmon. Event-triggering in distributed networked control systems. *IEEE Transactions on Automatic Control*, 56(3):586–601, 2011.
- [227] G. H. Wen, Y. Wan, J. D. Cao, T. W. Huang, and W. W. Yu. Master-slave synchronization of heterogeneous systems under scheduling communication. *IEEE Transactions on Systems*, *Man, and Cybernetics: Systems*, 48(3):473–484, 2018.
- [228] Z. G. Wu, J. H. Park, H. Y. Su, and J. Chu. Discontinuous lyapunov functional approach to synchronization of time-delay neural networks using sampled-data. *Nonlinear Dynamics*, 69(4):2021–2030, 2012.
- [229] Y. Q. Xia. Cloud control system. IEEE/CAA of Journal of Automatica Sinica, 2(2):134–142, 2015.
- [230] Y. Q. Xia, M. Y. Fu, and G. P. Liu. Analysis and Synthesis of Networked Control Systems. Springer-Verlag, Berlin, 2011.
- [231] Y. Q. Xia, G. P. Liu, M. Y. Fu, and D. Rees. Predictive control of networked systems with random delay and data dropout. *IET Control Theory & Applications*, 3(11):1476–1486, 2009.
- [232] J. L. Xiong and J. Lam. Stabilization of linear systems over networks with bounded packet loss. *Automatica*, 43(1):80–87, 2007.

- [233] J. L. Xiong and J. Lam. Stabilization of networked control systems with a logic ZOH. *IEEE Transactions on Automatic Control*, 54(2):358–363, 2009.
- [234] V.A. Yakubovic. S-procedure in nonlinear control theory. Vestnik Leningrad Univ. Math., 4:73–93, 1977.
- [235] T. Yang, J. Lu, D. Wu, J. F. Wu, G. D. Shi, Z. Y. Meng, and K. H. Johansson. A distributed algorithm for economic dispatch over time-varying directed networks with delays. *IEEE Transactions on Industrial Electronics*, 64(6):5095–5106, 2017.
- [236] M. Yu, L. Wang, T. Chu, and F. Hao. Stabilization of networked control systems with data packet dropout and transmission delays: continuous-time case. *European Journal* of Control, 11(1):40–49, 2005.
- [237] W. W. Yu, G. R. Chen, M. Cao, and W. Ren. Delay-induced consensus and quasi-consensus in multi-agent dynamical systems. *IEEE Transactions on Circuits and Systems I: Regular Papers*, 60(10):2679–2687, 2013.
- [238] D. Yue, Q. L. Han, and J. Lam. Network-based robust  $H_\infty$  control of systems with uncertainty. Automatica, 41(6):999–1007, 2005.
- [239] D. Yue, C. Peng, and G. Y. Tang. Guaranteed cost control of linear systems over networks with state and input quantisations. *IEE Proceedings: Control Theory and Applications*, 153(6):658–664, 2006.
- [240] D. Yue, E. G. Tian, and Q. L. Han. A delay system method to design of event-triggered control of networked control systems. *Proceedings of the 50th IEEE Conference on Decision and Control and European Control Conference*, 58(2):1668–1673, December 2011.
- [241] D. Yue, E. G. Tian, and Q. L. Han. A delay system method for designing event-triggered controllers of networked control systems. *IEEE Transactions on Automatic Control*, 58(2):475– 481, 2013.
- [242] D. Yue, E. G. Tian, Y. Zhang, and C. Peng. Delay-distributiondependent robust stability of uncertain systems with timevarying delay. *International Journal of Robust and Nonlinear Control*, 19(4):377–393, 2009.
- [243] H. B. Zeng, Y. He, M. Wu, and J. H. She. Free-matrixbased integral inequality for stability analysis of systems with time-varying delay. *IEEE Transactions on Automatic Control*, 60(10):2768–2772, 2015.
- [244] H. B. Zeng, Y. He, M. Wu, and J. H. She. New results on stability analysis for systems with discrete distributed delay. *Automatica*, 60:189–192, 2015.
- [245] C. K. Zhang, Y. He, L. Jiang, M. Wu, and Q. G. Wang. An extended reciprocally convex matrix inequality for stability analysis of systems with time-varying delay. *Automatica*, 85:481–485, 2017.
- [246] C. K. Zhang, Y. He, L. Jiang, M. Wu, and H. B. Zeng. Stability analysis of systems with time-varying delay via relaxed integral inequalities. Systems & Control Letters, 92:52–61, 2016.
- [247] J. H. Zhang, D. Y. Zhao, and W. X. Zheng. Output feedback control of discrete-time systems with self-triggered controllers. *International Journal of Robust and Nonlinear Control*, 25:3698–3713, 2015.
- [248] L. Zhang, Y. Shi, T. Chen, and B. Huang. A new method for stabilization of networked control systems with random delays. *IEEE Transactions on Automatic Control*, 50(8):1177–1181, 2005.
- [249] W. Zhang. Stability analysis of networked control systems. PhD thesis, Case Western Reserve University, 2001.

- [250] W. Zhang, M.S. Branicky, and S. M. Phillips. Stability of networked control systems. *IEEE Control Systems Magazine*, 21(1):84–99, 2001.
- [251] W. A. Zhang and L. Yu. Modelling and control of networked control systems with both network-induced delay and packetdropout. *Automatica*, 44(12):3206–3210, 2008.
- [252] W. A. Zhang and L. Yu. A robust control approach to stabilization of networked control systems with time-varying delays. *Automatica*, 45(10):2440–2445, 2009.
- [253] X. M. Zhang and Q. L. Han. Event-triggered dynamic output feedback control for networked control systems. *IET Control Theory & Applications*, 8(4):226–234, 2014.
- [254] X. M. Zhang and Q. L. Han. Event-based  $H_\infty$  filtering for sampled-data systems. Automatica, 51:55–69, 2015.
- [255] X. M. Zhang, Q. L. Han, and X. H. Yu. Survey on recent advances in networked control systems. *IEEE Transactions on Industrial Informatics*, 12(5):1740–1752, 2016.
- [256] L. Zou, Z. D. Wang, and H. J. Gao. Observer-based  $H_{\infty}$  control of networked systems with stochastic communication protocol: The finite-horizon case. *Automatica*, 63:366–373, 2016.
- [257] L. Zou, Z. D. Wang, and H. J. Gao. Set-membership filtering for time-varying systems with mixed time-delays under Round-Robin and weighted Try-Once-Discard protocols. *Automatica*, 74:341–348, 2016.