

Robust Tuning Of Power System Stabilizers In Multimachine Powersystems

Abdel-Magid, Y.L. Abido, M.A. Mantawy, A.H.;Dept. of Electr. Eng., King Fahd Univ. of Pet.Miner., Dhahran;

Power Engineering Society Winter Meeting, 2000. IEEE;Publication Date:

2000;Vol: 2,On page(s): 1425 vol.2-;ISBN: 0-7803-5935-6

King Fahd University of Petroleum & Minerals

<http://www.kfupm.edu.sa>

Summary

Summary form only given as follows. This paper demonstrates the robust tuning of power systems stabilizers for power systems, operating at different loading conditions. A classical lead-lag power system stabilizer is used to demonstrate the technique. The problem of selecting the stabilizer parameters is converted to a simple optimization problem with an eigenvalue-based objective function, which is solved by a tabu search algorithm. The objective function allows the selection of the stabilizer parameters to optimally place the closed-loop eigenvalues in the left-hand side of a vertical line in the complex s-plane. The effectiveness of the stabilizers tuned using the suggested technique, in enhancing the stability of power systems, is confirmed through eigenvalue analysis and simulation results

For pre-prints please write to:abstracts@kfupm.edu.sa