

Experimental Study on Lighting Air Terminal Performance Based on Material Type

by Abdul Syakur

Submission date: 08-Jan-2020 01:48PM (UTC+0700)

Submission ID: 1239981052

File name: Air_Terminal_Performance_Based_on_Material_Type_no_abstract.pdf (260.58K)

Word count: 2112

Character count: 11087

Experimental Study on Lightning Air Terminal Performance based on Material Type

Abdul Syakur, Agung Nugroho, Anastasia Br. Napitupulu

in the cloud grows, the greater the induced charge so that the potential difference between the clouds with the earth become even greater. The incident was followed by the release of the electron charge in the form of tongues of lightning that came down from the clouds and also up from the earth. [1,6]

Indonesia is an area that has the high intensity of a lightning strike. This is supported by the location of Indonesia in the tropical region that have high levels of moisture and high heating [2]. Given the damage that can arise as a result of lightning strikes, it appears efforts to overcome the damage. One of the efforts is to turn on a protection system that will deliver the lightning current to return to the ground, the equipment used is usually a *Lightning air terminals (LAT), down conductors and grounding*[3]. *Lightning air terminal* is part of the external lightning protection system is devoted to capturing lightning strikes, in the form of metal electrodes are mounted vertically or horizontally. The main parameters that determine whether the poor *Lightning air terminals* seen from the breakdown voltage level (after corona) that occurred. According to Schwaiger, breakdown voltage level or levels is influenced by the electric field distribution. [4]

Selection of *Lightning air terminals (LAT)* with the type of material that is not in accordance with the building can not be a good lightning catcher, so that the lightning current can not be supplied to the maximum ground and cause damage to electronic equipment as well as people who live in the building. As according to the General Rules of Installation of Lightning (PUIPP) that the location, shape, and size of the building is very affecting difficult or easy it is to a building struck by lightning [5]

II. EXPERIMENTAL SETUP

A. Preparation of test samples

The sample used in this study is an aluminum plate that has a diameter of 50 cm and a thickness of 1.5 mm and *Lightning air terminals* with 3 different type of material, namely copper, aluminum and galvanized iron. The third dimension of the *Lightning air terminals* in accordance to IEC 62305. The geometric parameters are shown in Table I. Total sample preparation is numbered 3 pieces, which consist of the types of materials as copper, aluminum and galvanized iron. All three samples were tested with the breakdown voltage variation of

I. INTRODUCTION

Lightning is a natural phenomenon which occurs stepping electric charge between the clouds with the earth. If the charge

the gap distance between measured resistance as well as the calculation of the conductivity of each material.




Fig. 1. Dimension of Lightning air terminal

TABLE I.	SAMPLE TEST
Name Test Materials	Lightning air terminals
Total height	30 cm
Material	Copper (Cu) Aluminum (Al) Galvanized Iron
Outside Diameter	2:54 cm (1 inch)

B. Breakdown Voltage testing

The parameters for both the poor performance of *Lightning air* terminal seen from its breakdown voltage after (corona) occurs. Breakdown voltage testing is done by using an aluminum plate that is modeled as clouds and 3 pieces *Lightning air* terminals with different material. Then eliminate the type of material of *Lightning air* terminals which has a high probability of most major breakdown voltage. Breakdown voltage testing using the generation of high voltage (DC) negative polarity.




Fig. 2. The test circuit of negatif polarity DC Voltage

Caption:

- TU = Transformer Test of three high-voltage winding 220 V / 220 V / 100 kV
- d1 = Diodes high voltage
- Cm = capacitors measurement of 10000 pF
- Rh = Resistor measurement of high 280 MΩ
- RL = Resistor measurement of the low 15 KΩ
- DMI = gauge high voltage DC (kV)

Unidirectional high voltage generation can use the generation of high voltage alternating output associated with a half-wave rectifier circuit (using high voltage diodes). For the rectifier circuit with a capacitor rectifier, providing direct voltage purer than without the capacitor. By enlarging the size of the capacitor grader, frequency and number of phases will reduce defects generated voltage [4]. As breakdown voltage test pictures can be seen in Fig. 2.

According to tables normalization and standardization states that for various tool applies a certain voltage sparks in the standard state. For example, according to Japanese Industrial Standard (JIS) and Japanese Electrotechnical Committee (JEC). Testing in the standard state is:

- barometer pressure 760 mmHg
- temperature around 20°C
- absolute humidity 11 g / m³

Therefore, sparks circumstances are always influenced by the circumstances of dry air. So to be able to compare the test results with the existing table the necessary normalization formula that can transform these results into the standard state. This is to determine whether the specimens tested are qualified or not.

To correct the test results of the pressures and temperatures used formula:

$$V_s = \frac{V_b}{\delta} \dots \dots \dots (1)$$

Where:

Vs = voltage jump on the state standard (KV)

Vb = voltage jump on the real situation (KV)

δ = air correction factor.

$$= \frac{p}{760} \times \frac{273 + \theta}{273 + \theta} = \frac{0.2864p}{273 + \theta} \dots \dots \dots (2)$$

Whereas p = air pressure at the time of testing (mmHg) and θ = ambient temperature during the test (°C). As a correction to the absolute humidity is used empirical formula:

$$V_D = \frac{V_s}{K_h} \dots \dots \dots (3)$$

Description:

Vs = standard breakdown voltage (KV)

Vb = breakdown voltage measured on the real situation (KV)

Kh = a correction factor dependent on the humidity

C. Resistance Measurements

Measuring resistance intended to determine the magnitude of custody on a material kind of *lightning air terminals*. Meter resistance measurement using mili-Ohm Meter placed at both ends of the *Lightning air terminals* the ability to carry current gets smaller as for the image using mili-ohm Meter resistance measurement shown in Fig. 3.



Fig. 3. Resistance measurement using mili-ohm meter

III. RESULTS AND DISCUSSION

A. Breakdown voltage

The average value of breakdown voltage testing of lightning air terminal with 3 different type of materials that can be seen in the table 2.

TABLE II. AVERAGE BREAKDOWN VOLTAGE

Average of breakdown voltage [kV]	Copper	Aluminum	Galvanized Iron
1	-8.23	-8.48	-8.64
2	-11.66	-13.05	-13.06
3	-15.59	-18.16	-18.39
4	-18.93	-21.60	-21.71
5	-21.31	-24.90	-25.56

It can be seen in table II above the average value of breakdown voltage of each lightning air terminal at certain intervals. The average value of breakdown voltage of lightning air terminal with copper material at distance of 1 cm intervals for -8.23 kV, on aluminum -8.481 kV, on galvanized iron materials -8.64 kV.

At distance of between 2 cm, breakdown voltage value of the Lightning air terminals with the copper material amounting to -11.66 KV, on the kind of aluminum material at -13.05 KV as well as on the type of material galvanized iron for KV -13.06 at distance of between 3 cm, breakdown voltage value of Lightning air terminals with the copper material amounted to -15.59 KV, on the kind of aluminum amounted to -18.11 KV as well as on the type of galvanized iron material at -18.39 KV at distance of between 4 cm, the value of breakdown voltage Lightning air terminals with the type of material amounted to -18.931 KV copper, on the kind of aluminum material at -21.598 KV as well as on the type of material of galvanized iron -21.705 KV.

At distance of between 5 cm, the value of breakdown voltage Lightning air terminals with the type of material amounted to -21.311 KV copper, on the kind of aluminum material at -24.896 KV as well as the type of materials amounted to -25.561 kV galvanized iron.




Fig. 4. Comparison breakdown voltage

The probability of exposed material breakdown voltage on any type of material Lightning air terminals at certain intervals between the type of copper by 100%, 100% aluminum material types, types of galvanized iron materials by 96.67% on every test with distance of between 1 cm

The parameters good poor performance of lightning air terminal can be seen from the breakdown voltage value (after the corona) [4] as in figure 4. the difference in the value of the breakdown voltage lightning air terminals with different type of material is influenced by the resistance of each material type of lightning air terminals. The greater the custody of a type of material of Lightning air terminals the breakdown voltage of the larger types of material. This means that the process of breakdown in the longer isolation.

B. Resistance of material

From the measurements that have been carried out, the resistance value of each test sample can be seen in Table III.

TABLE III. RESISTANCE OF MATERIAL

No.	Material Type Lightning air terminal	resistance (Ω)
1	Copper	0.06
2	Aluminum	0.08
3	Galvanized Iron	0.10

Data resistance measurement result types of materials of Lightning air terminals using mili-ohm meter indicates that the sequence resistance of Lightning air terminals of the largest to the smallest the type of material galvanized iron, aluminum and copper.

From the measurement results can be calculated resistance value conductivity, indicated that things that affect the electrical conductivity in a material depends on the internal structure of the conducting material. Copper material has the smallest resistance value of the other materials because it is a metallic material that has number of free electrons are more apart from the nucleus.

After using mili-ohm meter resistance measurement, then the calculation of the conductivity of any material from the Lightning air terminals to the equation as below.

$$R = \rho \frac{L}{A} \dots \dots \dots (4)$$

$$\sigma = \frac{L}{R \cdot A} \dots \dots \dots (5)$$

where:

R = resistance (Ω)

ρ = resistivity (Ω.m)

L = length of lightning air terminals (m)

A = area (m²)

σ = electrical conductivity (Ω⁻¹m⁻¹)

By using the equation above, the conductivity values of each type of material from Lightning air terminals obtained as shown in table IV.

TABLE IV. CONDUCTIVITY OF MATERIAL

No	Material Type Composer <i>Lightning Air Terminal</i>	Resistivity ($\Omega \cdot m$)	Conductivity ($\Omega^{-1}m^{-1}$)
1	Copper	0.002	408 197
2	Aluminum	0.003	306 147
3	Galvanized Iron	0004	244 918

Based on the graphic, conductivity values *lightning air terminal* above obtained the highest conductivity values contained in the copper material types whereas the lowest conductivity values are the type of galvanized iron materials. This is because each material has a different internal structure. The conductivity of a type of material depends on the number of free electrons that are not bound to the nucleus, the process of releasing electrons in the metal into the gas (emission events), the charge density and electron mobility. it has the highest conductivity values of the four other ingredients. Ingredients of *lightning air terminal* which has the highest conductivity values capable of delivering current and voltage induced excess to the *ground*.




Fig. 5. Comparison conductivity of materials

IV. CONCLUSION

After considering the breakdown voltage value, the value of resistance measurement, calculation of electrical conductivity in all four types of material from *lightning air terminal* then found that the type of material that has an average breakdown voltage of the largest and has the highest probability of breakdown voltage exposed in testing I that kind of material copper with a probability of 100% and the testing of the second type of material that has the highest probability that the type of the aluminum material as well as the testing of the third type of material that has the highest probability is 96.67% on the kind of material galvanized iron on the distance between particular by eliminating each type of material has a probability highest in earlier tests. The average value of breakdown voltage is different for each type of material caused by the difference in resistance value of each ingredient *lightning air terminal*. Resistance affects the ability of electrical conductivity to the *ground*. The resistance value of the type of materials which have the smallest breakdown voltage that is at 0:06 Ω copper, aluminum resistance value Ω at 0:08 and the types of materials that have an average value of breakdown voltage and the greatest resistance value contained in the type of galvanized iron materials by 0:10 Ω . The resistance value will affect the resistivity and conductivity type of materials of *lightning air terminals*. The conductivity of a material is influenced by the internal structure of the introductory material, the release of electrons from a metal surface into free electrons in the gas (emission), the charge density (ρ_c) and electron mobility (μ_e).

Experimental Study on Lighting Air Terminal Performance Based on Material Type

ORIGINALITY REPORT

4%

SIMILARITY INDEX

1%

INTERNET SOURCES

2%

PUBLICATIONS

3%

STUDENT PAPERS

PRIMARY SOURCES

1

A.G. Abdullayev, A.V. Evdokimov, M.N. Murshudly, M.I. Scheglov. "Gas sensor based on a transistor structure", *Sensors and Actuators*, 1987

Publication

1%

2

ar.scribd.com

Internet Source

1%

3

Submitted to Higher Education Commission
Pakistan

Student Paper

1%

4

van der Born, D., P. H. F. Morshuis, J. J. Smit, and A. Girodet. "The influence of thin dielectric coatings on LI and AC breakdown strength in SF6 and dry air", 2013 IEEE International Conference on Solid Dielectrics (ICSD), 2013.

Publication

1%

5

www.cigareturkiye.org.tr

Internet Source

<1%

Exclude quotes Off

Exclude matches Off

Exclude bibliography Off

Experimental Study on Lighting Air Terminal Performance Based on Material Type

GRADEMARK REPORT

FINAL GRADE

/0

GENERAL COMMENTS

Instructor

PAGE 1

PAGE 2

PAGE 3

PAGE 4
