




UNIVERSITÀ
DEGLI STUDI
DI PADOVA



Evento patrocinato dal
Comune di Padova



Società Chimica Italiana
Divisione di Elettrochimica

Giornate dell'Elettrochimica Italiana GEI 2019



Program and Book of Abstracts

8-12 September 2019 Padova, Italy

Influence of process parameters of simultaneous anodization/anaphoretic electrodeposition synthesis of hydroxyapatite/titanium oxide composite coatings on adhesion

Marijana R. Pantović Pavlović^{a,b}, Miroslav M. Pavlović^a, Sanja G. Eraković^a, Jasmina S. Stevanović^{a,b}, Nenad L. Ignjatović^c, Vladimir V. Panić^{a,b,d}

^a Institute of Chemistry, Technology and Metallurgy, University of Belgrade, Njegoševa 12, Belgrade, Serbia

^b Center of Excellence in Environmental Chemistry and Engineering - ICTM, University of Belgrade, Njegoševa 12, 11000 Belgrade, Serbia

^c Institute of Technical Science of the Serbian Academy of Sciences and Arts, Knez Mihailova 35, Belgrade, Serbia

^d State University of Novi Pazar, Department of Chemical-Technological Sciences, Novi Pazar, Serbia

E-mail: m.pantovic@ihm.bg.ac.rs

In-situ synthesis of hydroxyapatite/titanium oxide (HAp/TiO₂) coating on titanium was performed via anaphoretic deposition of hydroxyapatite (HAp) and simultaneous anodization of Ti to produce highly adherent and strengthened composite coating. The influence of electric potential, time, electrolyte concentration and pH value of the anodization process on titanium surface roughness and anodization of titanium was examined, as well as influence of same process parameters on adhesion strength and compactness of composite HAp/TiO₂ coatings was investigated. Prior to novel *in situ* method of synthesis of hydroxyapatite/titanium oxide composite coatings by simultaneous anodization/anaphoretic electrodeposition described in this manuscript, optimization of anodization process of titanium was performed. Anodization was executed under different electric potentials and different distances of counter electrodes from working electrodes, but all anodization processes had constant quantity of electric charge. Characterization of titanium samples, prepared from grade 6 Ti, and having rectangular contact surfaces of 10×10×0.89 mm included SEM/EDS analyses, X-ray diffraction analyses, AFM surface topography, morphology and roughness analyses and linear measurements of roughness.

A chemical precipitation method was used to prepare hydroxyapatite powder by the reaction of calcium oxide (obtained by calcination of CaCO₃ for 5 h at 1000 °C in air) and phosphoric acid. A stoichiometric amount of the calcium oxide was stirred in distilled water and phosphoric acid was added drop wise to the suspension in order to obtain hydroxyapatite powder, Ca₁₀(PO₄)₆(OH)₂.

Two types of HAp coatings were prepared, in order to compare the adhesion, morphology and consistency of the HAp and composite HAp/TiO₂ on Ti, namely cathaphoretic and anaphoretic coatings, respectively [1,2]. The prepared coatings were characterized by field emission scanning electron microscopy, X-ray diffraction and electron dispersive spectroscopy. Adhesion was investigated by ASTM D 3359 – 97 Test method B. Uniform and adherent HAp/TiO₂ composite coating on Ti was obtained. Since smaller size of HAp crystals within highly porous coating structures is of improved binding ability to various biomolecules, our coating is expected to be of excellent coverage and compactness. The obtained coating can be good candidate for bone implants due to improved adhesion.

- [1] S. Eraković, A. Janković, I.Z. Matić, Z.D. Juranić, M. Vukašinović-Sekulić, T. Stevanović and V. Mišković-Stanković, *Mater. Chem. Phys.*, 2013, **142**, 521–530.
[2] M.R. Pantović Pavlović, S.G. Eraković, M.M. Pavlović, J.S. Stevanović, V. V. Panić and N.L. Ignjatović, *Surf. Coatings Technol.*, 2019, **358**, 688–694.