



Vaasan yliopisto
UNIVERSITY OF VAASA

OSUVA Open
Science

This is a self-archived – parallel published version of this article in the publication archive of the University of Vaasa. It might differ from the original.

Towards flexibility trading at TSO-DSO-customer levels : a review

Author(s): Khajeh, Hosna; Laaksonen, Hannu; Gazafroudi, Shokri; Shafie-khah, Miadreza

Title: Towards flexibility trading at TSO-DSO-customer levels : a review

Year: 2020

Version: Publisher's PDF



Copyright © 2019 by the author(s). Licensee MDPI, Basel, Switzerland. This article is an open access article distributed under the terms and conditions of the Creative Commons Attribution (CC BY) license, <http://creativecommons.org/licenses/by/4.0/>

Please cite the original version:

Khajeh, H., Laaksonen, H., Gazafroudi, S., & Shafie-khah, M., (2020). Towards flexibility trading at TSO-DSO-customer levels : a review. *Energies* 13(1), 165. <https://doi.org/10.3390/en13010165>

Review

Towards Flexibility Trading at TSO-DSO-Customer Levels: A Review

Hosna Khajeh ¹, Hannu Laaksonen ¹, Amin Shokri Gazafroud ² and Miadreza Shafie-khah ^{1,*}

¹ School of Innovations and Technology, Electrical Engineering, University of Vaasa, 65200 Vaasa, Finland; hosna.khajeh@uwasa.fi (H.K.); hannu.laaksonen@uwasa.fi (H.L.)

² Institute for Automation and Applied Informatics, Karlsruhe Institute of Technology (KIT), 76344 Eggenstein-Leopoldshafen, Germany; shokri@kit.edu

* Correspondence: mshafiek@univaasa.fi

Received: 26 November 2019; Accepted: 25 December 2019; Published: 30 December 2019



Abstract: The serious problem of climate change has led the energy sector to modify its generation resources from fuel-based power plants to environmentally friendly renewable resources. However, these green resources are highly intermittent due to weather dependency and they produce increased risks of stability issues in power systems. The deployment of different flexible resources can help the system to become more resilient and secure against uncertainties caused by renewables. Flexible resources can be located at different levels in power systems like, for example, at the transmission-level (TSO), distribution-level (DSO) and customer-level. Each of these levels may have different structures of flexibility trading as well. This paper conducts a comprehensive review from the recent research related to flexible resources at various system levels in smart grids and assesses the trading structures of these resources. Finally, it analyzes the application of a newly emerged ICT technology, blockchain, in the context of flexibility trading.

Keywords: flexibility; flexibility trading; flexible resources; blockchain technology

1. Introduction

Electricity generation has been one of the largest sectors in producing emissions due to the utilization of fuel-based power plants [1,2]. The recent development in the energy sector has led to the large-scale use of renewable energy sources (RESs) in order to prevent climate change. Also, constant political pressure to decrease the amount of carbon emissions, as well as subsidization of RESs, has led to an increase in using renewable, distributed energy resources in the form of roof-mounted photovoltaic panels or small wind turbines in residential and commercial buildings.

Nevertheless, RESs are extremely volatile due to their dependency on weather conditions [3]. The power produced by renewables is highly variable and challenging to predict [4]. Therefore, the power system balancing between generation and load becomes also more challenging, and the risk of security and stability issues increases due to RESs. Traditionally, balancing issues in power systems have been related to the variability of loads and errors in the load forecasts due to the unpredictable nature of customer demand. The increasing penetration of renewables combined with increasing penetration of electric vehicles (EVs) in distribution systems will result in highly volatile net-load profiles. In other words, the growing penetration of RESs along with the entry of EVs in distribution networks will increase the fluctuations in power systems. Besides, the growing use of renewables instead of conventional generators reduces system inertia due to inverter-based interfaces which in turn deteriorates the system volatility and risk for stability issues [5,6].

In order to tackle the above-mentioned challenges, system operators need to increase the flexibility of the system through flexible resources [7]. There exist several definitions of flexibility in the context

of power systems. One quite comprehensive definition describes the flexibility of power systems as the ability to adjust the operating point of the power system continuously and to resist the expected and unexpected changes happening in the operating conditions [8]. Hence, the flexible power system should adapt to the changes in both demand and generation in a timely and harmonized manner. On the other hand, flexibility can be also defined as the adaptability of the generation- or demand-based flexible resources to modify their behavior during operation in order to respond to external signals sending from the grid operators [9]. According to this definition, any resources which are located in the demand- or generation-side, and can react to the system changes, can be considered as flexible resources.

Traditionally, large centralized generators were responsible for fulfilling the flexibility requirements of the power system by offering different ancillary services [10]. Quite recently, the possibility to utilize demand-side resources and loads for power-system-balancing-related ancillary services has also been considered more extensively. It means that the demand can follow the generation changes. This is typically considered as demand response (DR) and, for example, reference [11] presents a review from different possible DR classifications and definitions. In the literature also the effect of DR on market prices has been studied. For example, reference [12] presents a comprehensive survey from the potential of smart grids to provide DR-related services as well as from the potential benefits of DR in smart grids. Also, the role of advanced technologies in boosting the efficiency and the coordination of DR were also estimated in [12]. In addition, different advantages and challenges of DR were fully discussed in [13]. Residential DR resources, in particular, were taken into consideration in [14] which also reviewed the latest information and communication technologies supporting the utilization of this type of DR resource.

The most recent research has evaluated the flexibility by considering both generation- and demand-side resources. For example, an index for flexibility of DR units has been introduced and various classifications and forms of flexibility have been presented in [15]. Then, different flexibility products and markets have been classified by also considering their location [16]. However, all different flexible resources and system levels were not thoroughly considered [16]. An in-depth review of flexible ramping products (FRPs), which are mainly intended to the transmission-level networks (TSO), was presented in [17]. Respectively, [18] also reviewed feasible technologies for improving transmission-level flexibility. Thus, the flexibility of distribution networks was not within the scope of these papers. On the contrary, there has been a thorough review of forecasting, controlling and planning of flexibility in active distribution networks, but the TSO level was beyond the scope of the research conducted by [9].

The main aims of the paper can be explained as the following:

- Conducting a comprehensive review of conventional as well as new potential flexible resources located at different levels of power systems including transmission-level, distribution-level (DSO) and customer-level. At each level, the system operator has different responsibilities which make them deploy different kinds of flexible resources in order to enhance the flexibility of the power system.
- Seeking the existing flexibility trading structures of different-level systems proposed by the recent research. The trading structures aim to facilitate injecting flexibility to the DSO-, TSO-, and customer-level networks.
- A newly emerged ICT technology, blockchain technology, is analyzed in this paper and its merits and applications in the flexibility trading are discussed as well.

Since market and trading structures at each level can be different depending on the different-sized resources with various behaviors and objectives, the flexible resources and trading structures of each level are evaluated distinctively. To the best of the authors' knowledge, there do not exist any previous studies which introduce different-level flexible resources and the trading structures of these resources, especially in the customer-level context.

The rest of the paper is organized as follows. Section 2 reviews flexibility at the transmission system operator (TSO) and network level. Section 3 introduces flexible resources and trading structures at the distribution system operator (DSO) and network level. Customer-level flexibility is discussed in Section 4. Section 5 analyzes the applications of blockchain technology in flexibility trading. Finally, a summary of the paper is done in Section 6.

2. Flexibility at TSO Level

The main responsibilities of TSOs in power systems are related to generation and demand balancing and transmission-network congestion management. Balancing and congestion management can consist of different issues related to, for example, the hierarchical (primary, secondary, tertiary) frequency and voltage control [19]. The actions associated with congestion management are completely dependent on the states of the system. Flexible ramping products (FRPs) along with ancillary service products help the independent system operator (ISO) or TSO to regulate the network frequency and voltage aiming to maintain the security of the power system.

There should be a distinction between ancillary services and FRPs deployed by the ISO [20]. Although both of these products can be considered as market-based, FRPs are used to address uncertainties of net loads in the future dispatch time slots while ancillary regulation services are utilized to capture uncertainties related to the error of forecast in a matter of seconds. Besides, some ancillary services such as operating reserves are planned to react to a sudden loss of supply, known as contingency reserves. These ancillary service products can only provide the network with upward regulation whereas FRPs are able to present ramping in both directions by flexibility ramp down (FRD) and flexibility ramp up (FRU) products. The optimal FRPs are proposed to be purchased in the existing real-time markets. However, ISOs often provide a separate market for reserves which increases the total costs.

ISOs can combine congestion management with the balancing market or perform them in separate markets [21]. Although the separate markets may lead to higher prices, they will create less confusion over cost management of two different flexibility products. Besides, the separate markets may need less complex governance and implementation considering the management of transmission networks. On the other hand, the combined flexibility markets would enjoy more liquidity as well as lower costs in comparison with the separate ones.

Cooperation among TSOs is also needed in the operation of transmission networks. For instance, it has been proven that optimal cooperation between TSOs would lead to enhanced flexibility in transmission networks and could simultaneously enable higher penetration of renewables into the power system [22]. In addition, the cooperation between 34 European countries has been presented with the aim to increase the security and sustainability of the interconnected European power system as well as to develop the European energy markets [23].

TSOs use different kinds of flexible resources and ancillary/flexibility services in order to increase the flexibility of transmission networks. These resources can be connected to low-voltage (LV), medium-voltage (MV) or high-voltage (HV) networks. In addition to large-scale flexibility providers/aggregators, flexibility provision potential of aggregated small-scale (LV and MV network connected) customers is also increasingly necessary in order to fulfill the future TSO-level flexibility needs. The next section presents the potential flexible resources in the TSO-level power system.

2.1. Flexible Resources at TSO Level

TSO-level flexible resources can be categorized into supply- and demand-side resources. The demand-side resources consist of aggregated customers who can adjust their demand to provide the transmission grid with flexibility and aggregated prosumers equipped with a larger flexibility mix consisting of renewable resources, electric vehicles (EVs) and/or storages. Supply-side resources include traditional generators, wind power producers (WPPs), virtual power plants (VPPs) and any large-scale generators which are able to react to the TSO's flexibility needs. Figure 1 illustrates different potential flexible resources in TSO-level networks.

Various studies exist related to flexible resource utilization for TSO needs. For example, customers have been proposed to be aggregated and react to the price signals sent by the TSO. The TSO determines the price signals taking into account its estimation about available demand flexibility [24]. In [25], customers were classified according to their elasticity and preferences in order to quantify demand flexibility for balancing purposes in transmission networks. Also, customers' responsiveness to time-varying prices was analyzed to show how much these resources could contribute to ancillary service requirements.

EV's contribution to flexibility services provision has been considered [26]. Two different types of EV participation have been considered [26]. In the first case, aggregated EVs only participated in the ramp markets. In the second case, the focus was on the EV's ability to cooperate with traditional generators in order to improve their ramp rate. The results based on EV contribution to providing flexibility services demonstrate that the system would have a higher probability to respond to the ramp requirements. For instance, it states that the system would be able to deal with more uncertainty and variability within the probability of 99.9%. Driver behavior, along with EV stochastic mobility, were also taken into account to enhance the efficiency of the proposed models. Another study developed a bi-level model in order to investigate the potential of EV aggregators to present FRPs in the spot markets [27]. It concluded that this kind of aggregator would be able to give the power system a considerable economic advantage [27].




Figure 1. Flexible resources at transmission system operator (TSO).

Traditional generators have usually had the responsibility of providing flexible ramping services to the TSO-level network by submitting their available ramping capacities as well as operational limits to the TSO or ISO. Afterward, the ISO/TSO jointly clears these capacities with energy and ancillary services markets to overcome uncertainties that jeopardize the system security [28]. Conventional units have been proposed to be utilized for generation ramping reserve and generation capacity reserve [29]. The ramping capability of a generator would be locked when scheduling the security-based economic dispatch. As a result, it forms the generation ramping reserve while the unused capacity of a unit was considered as the capacity reserve.

Wind power producers (WPPs) were also considered as TSO-level flexible resources in the literature. Although the resources' low marginal costs may make them non-beneficial to be used for flexible ramping capacities, reference [30] proved that they would bring benefits for the system by eliminating the commitment of costly fast-start generating units. As the results indicate, introducing a WPP as a flexible resource has reduced the overall cost of the system by 5.5%. Wind power ramping products were also modeled in [31] which studied the impact of different forecasted values on the conditional distribution of WPPs' ramping. Wind power ramping products were also considered in [32] regarding the potential economic benefits of wind-power-based ramping products under various ramping reserve needs.

Storages are also very potential flexibility providers for future TSO needs. References [26,33] stated that the battery energy storage (BES) and plugged-in EVs might be the most suitable options to produce flexible ramping products due to their frequent usage and time-related constraints. Since ramp-based markets are cleared sub-hourly, the time-related limitations of batteries would be relieved. DR was also proposed to be used as a supplementary flexible resource which aim to make customers react to changing market conditions. Reference [20] proposed the aggregator of BES to participate in multi-product markets including FRP, energy and reserve products. The paper stated that it would be profitable for the aggregator to submit a part of its capacities for FRP purposes instead of taking part just in energy and reserve markets. Large bulk energy storages are also very potential flexible resources in future power systems [34] and the deployment of bulk energy storage with transmission-capacity expansion has been compared in the literature from a flexibility provision point of view.

DR has been also regarded as one of the most cost-efficient sources of flexibility [35], because of DR availability and ability to respond rapidly to the system changes. For example, in Singapore's electricity market, customers are allowed to bid their flexible demand to the markets [36]. Also, DR services like load shifting and curtailment have been introduced, which can be aggregated in power systems to help the system respond to real-time electricity prices [37].

In addition to the potential of the above-mentioned energy resources in providing flexibility to the transmission networks, some operational actions as well as technology and devices can be also employed to increase flexibility. For example, power electronics-based solutions like flexible AC transmission systems (FACTS) and high voltage DC (HVDC) are capable of improving the flexibility and controllability of transmission systems [18]. The combination of wide-area monitoring protection and control (WAMPAC) with FACTS devices and HVDC is able to react rapidly to the unexpected changes in active and reactive power flows [18]. Controlling power flows in transmission networks can be also performed through two other technologies like on-load tap changing (OLTC) transformers and phase-shifting transformers (PSTs) [38]. OLTCs are utilized to regulate the magnitude of voltages, leading to the proper control of reactive power flows [38]. These above-mentioned resources can provide flexibility services for the TSO-level networks, but they are not traded in market-based platforms.

2.2. Flexibilities Related Trading at TSO Level

The optimal FRPs are often proposed to be co-optimized with the existing energy and ancillary service markets. In the day-ahead market, security-based unit commitment (SCUC) and the real-time security-based economic dispatch (SCED) are employed to schedule the resources. There exist two basic methods in order to provide the TSO-level system with sufficient FRPs. The first method is to set

the system ramping capability related constraints so that the main objective function of the system does not change. The second method adds additional terms to the objective function of SCUC and SCED while setting constraints related to the ramping capabilities [17].

In most of the studies, flexible resources i.e., flexibilities, can voluntarily participate in the market in order to make profits. Moreover, opportunity costs are mainly paid to flexibility providers, i.e., they will receive as much profits as they could have made through providing energy. Accordingly, they do not need to submit separate bids for their offered flexibility capacities. Besides, it has been indicated that allowing flexibility to submit bids may result in false incentives as they prefer to take part in reserve markets with higher prices rather than the flexibility markets [39]. However, it has been proposed that FRPs can be also products with their own pricing which can send clearer signals to the market [40]. When it comes to pricing, the effect of various dynamic tariffs including time-of-use, real-time, critical peak pricing and emergency DR program tariffs on flexible ramp markets has been investigated [41].

In terms of trading timeframes, it would be better for flexibility markets to be settled in spot markets as FRPs are often procured from SCUC and SCED processes. Further, uncertainties coming from forecast errors are well-captured in spot markets. Firstly, the optimal amount of FRPs is obtained from SCUC in a way that it covers 15 min forecast errors [42]. Secondly, the incremental values of FRPs are determined through the real-time dispatch process in order to compensate for the 5 min forecast errors. In MISO (Midcontinent Independent System Operator) and CAISO (California Independent System Operator) markets, FRPs are implemented through both day-ahead and real-time markets so that they have a two-settlement system [17,43]. In MISO, FRPs are obtained from applying single-interval ramp-related constraints while CAISO considers several intervals ahead in order to calculate system ramping capabilities. With regard to ancillary services, there exist various timeframes depending on the type of services. Services that are related to emergency conditions should be provided in real-time or near real-time while the ones operating in steady-state conditions such as power flow optimizations can be used each day, month or even year [22]. The flexible resources associated with resource adequacy and grid developments are usually deployed for mid- and long-term planning which is done for many years ahead. Figure 2 shows the timeframes of flexibility services in TSO-level networks.




Figure 2. Operation and planning timeframes for TSO-level flexibility trading.

3. Flexibility at DSO Level

With the arrival of renewables, smart metering, smart grid technologies, EVs, etc., the role of DSOs is going to change considerably. Traditional DSOs are recently and in the future burdened with various new responsibilities. First, they should, for example, handle the data received from smart meters, and manage and utilize them for the purpose of forecasting, risk management, scheduling and planning of distribution systems [44]. Second, managing local markets in the distribution systems level can be in the future one of the new responsibilities of the DSOs and they should simultaneously ensure that the system constraints are not violated. Feeder congestion management and reactive power (Q)–voltage (U) (i.e., QU- or Volt/Var) management for distribution network voltage control, are regarded as vital responsibilities of DSOs [45]. However, these are becoming more challenging due to increased amount of intermittent renewable-based generation and the growing number of EVs in the distribution system. As a result, DSOs also need more flexibility services in the future,

e.g., from customers with production (prosumers), in order to provide infrastructure for EVs [46] and renewables-based distributed generation.

There exist different flexibility services and products which can be deployed by DSOs so as to enhance system security. These services can be related to congestion management, voltage control and system maintenance, and be realized by using various information and communication technologies [46]. In order to determine the optimal amount of flexibility, a DSO can utilize, for example, the values from metering devices and use them to calculate the amount of available flexibility. In addition, customers/prosumers with flexibilities should be motivated in order to react to DSO flexibility service needs. In the following section, the main flexible resources at distribution networks (DSO level) are introduced briefly.

3.1. Flexible Resources at DSO Level

Traditionally, DSOs invest in upgrading the distribution grids in order to effectively resolve different current or future grid issues [47]. The components such as transformers and cables are upgraded and replaced by the ones with higher capacity limits to avoid congestion in the grid [48]. Besides, capacitor banks or transformers equipped with OLTCs are used for voltage control [47]. Changing topology of the grid known as network reconfiguration is also one potential action used by DSOs to relieve network congestion [49,50]. DSOs may plan the topology reconfiguration for different timeframes like day-ahead, intraday and real-time. As part of distribution network topology changes, circuit-breakers and switches can be controlled together with demand response/shifting in order to solve DSO network congestions [51]. Flexibility can be also obtained from advanced monitoring techniques like dynamic line rating (DLR) [52].

Active management of DSO-network-connected distributed energy resources (DERs) can be seen as very potential future DSO-level flexible resources, reducing the need for grid reinforcement and reconfiguration. DERs can be curtailed dynamically or statically to increase system flexibility [9]. In the static curtailment, there exists a predefined threshold for the injection of active power (P) from renewable DER. In contrast, regarding dynamic curtailment, the injection of active power (P) is only controlled and curtailed if the congestion happens. Capacity-limitation-related flexibility services could be provided to DSOs e.g., by aggregating multiple DERs through a FLECH (flexibility clearing house) service-oriented platform [53]. The encouraging results demonstrated that these resources could meet the DSO requirements in an acceptable manner. For instance, their capacities decreased by 38.5 kW in response to the required 37.8 kW reduction offered by the DSO. Hence, DERs would be utilized as flexible resources in an aggregated manner or through curtailment.

Demand response (DR) resources and microgrids (MGs) are also able to contribute to the provision of flexibility for DSOs' needs. For example, reference [54] investigated the effect of DR resources on mitigating the uncertainties coming from the penetration of intermittent wind power. In [55], responsive loads were proposed to be rescheduled considering DSO preferences and in order to maximize the profits and load leveling. The proposed load scheduling approach was proved to lead to the highest load reduction (26.8%) which had been requested by the DSO. DSOs may also benefit from flexibility services provided by MGs connected to the distribution grids. Reference [56] illustrated how MGs could control their local resources to provide the grid with flexibility/ancillary services. However, the results of [56] advocate that MGs should deviate from their optimal profits in order to provide the distribution grid with the desired ramping needs. This amount was estimated to be \$328.7 for 24 h in the literature. Accordingly, the DSO needs to incentivize these resources by paying the aforementioned deviation profits to the MGs. An aggregator of different small-scale flexible resources could provide the flexibility services for DSOs and act as an intermediary between DSOs and the customer-level resources [57]. The proposed decentralized aggregator-based market design was proved to facilitate flexibility integration from prosumers seeking autonomy and privacy. In [58], the aggregator utilized small prosumers' flexibility for participation in energy and tertiary frequency

reserve markets. The research adopts the two-stage stochastic programming to exploit the flexibility of prosumers in both generation-side and demand-side.

DSO-level storage-based resources are also naturally have potential to be providers of flexibility for distribution network needs through different active network management (ANM) schemes. For example, reference [59] proposed to coordinate load shedding and EV charging by ANM in future distribution networks. The work in [59] took into account the satisfaction of EV customers along with interruptible load compensation in its optimization problem. The paper concludes that the proposed flexible resources increased the average qualified voltage ratio from 82.7% to 100% while the average ratio of primary line load decreased from 41.57% to 38.32%. Reference [60] suggested that EVs are one of the efficient flexibility providers in terms of issues associated with congestion management and voltage regulation. In addition, a real-time congestion management method, named “swap”, was introduced in [61] focusing on flexibility services provided by EVs and heat pumps. Reference [62] discussed that battery energy storage (BES) could provide a wide range of flexibility services including the provision of the spinning and non-spinning reserve, power quality and primary frequency regulation. Following this research, reference [63] assessed the integration of BESs and hybrid photovoltaic (PV) arrays in order to meet short-term flexibility requirements.

The market- or pricing/tariff-based approach is another method implemented by the DSO in order to relieve network congestion in the distribution grids. Reference [64] utilized dynamic tariffs along with power-based network tariffs in order to motivate heat pumps and EVs to react to the changes in the distribution system. In addition, locational marginal pricing was employed by [65] in order to provide flexibility to the distribution network.

Traditional methods like network reconfiguration are also combined with flexibility services/products in the literature in order to operate the distribution grid in a more efficient way. For example, in [66] a DSO-level capacity market was integrated with the network reconfiguration in order to resolve the congestion issues through an iteration process between the DSO and aggregators. According to the paper’s simulation results, this combination would be able to enlarge the control space that pricing approach alone cannot reach at some certain times of the day, while guaranteeing minimal investment costs in the grid development. Furthermore, in [51] a combination of price- and incentive-based DR programs was proposed. Table 1 illustrates the potential flexible resources in the distribution networks (DSO-level).

Table 1. Potential flexible resources at distribution networks (distribution system operator (DSO) level).

References	Reconfiguration and Reinforcing Method	DERs	Aggregators and MGs	Storage-Based and EVs	DR	Market-Based	Others
[47]	✓						✓
[48]	✓						
[49]	✓						
[50]	✓						
[51]							✓
[52]							✓
[66]		✓					
[9]		✓					
[54]					✓		
[55]					✓		
[56]			✓				
[57]			✓				
[58]			✓				
[59]				✓			
[60]				✓			
[61]				✓			
[62]				✓			
[63]				✓			
[64]						✓	
[65]						✓	
[67]	✓					✓	

3.2. Flexibilities Related Trading at DSO Level

There exist three main methods to implement flexibility services for DSOs' needs. The first method is the rule- or grid-code-based method in which some strict requirements are set to the behavior of DER units in order to support the needs of the distribution networks. In the second method, DSOs execute bilateral contracts to buy flexibility services from the resources [53]. Flexibility services at the DSO-level could be also traded in the market environment which forms the third method of flexibility services trading.

Grid codes can be different for different countries. DER units connected to the grid must follow the strict rules and regulations imposed by the system operator. For example, some grid codes associated with integrating solar power into the DSO-level network have been introduced [68]. However, it should be kept in mind that most DER-related grid codes are traditionally made for emergency situations in order to support the transmission network and whole power system stability during large disturbances. In addition, DER grid codes are under constant development and in the future they will also increasingly take into account the needs of distribution networks and microgrids (intended island operation).

The bilateral contracts can be negotiated between a DSO and a broker aggregating flexible resources (like the aggregator-DSO contract in [69]) or the DSO can carry out contracts for each end-user [70]. Reference [69] defined aggregator-DSO contracts as including the awards which should be given to the aggregator when it reacts to the DSO request. In [57], a DSO buys/sells flexibility contracts from/to aggregators acting as mediators between small-scale flexible resources and the DSO. The DSO will buy flexibility contracts during time intervals in which the demand violates the predefined levels, and sell them when there is no violation. In [70], the traffic light concept presented by [71] was utilized to introduce the system states to the flexible resources before the DSO asks for corrective actions. Figure 3 shows the various flexibility trading structures for DSO-level networks.




Figure 3. Flexibility trading structure at DSO level.

Related to the market-based approach, reference [45] introduced two different frameworks for the interaction between a DSO and aggregators. In the first framework, the DSO first asks for quantities of various kinds of flexibility services. After that, the aggregators submit offers to respond to the request and finally, the DSO selects appropriate flexibility services. In the second framework, aggregators must estimate the required flexibility services and show services at different prices, similar to a supermarket. Reference [66] also proposed a mid-term market in which aggregators build a price/quantity curve to react to the DSO requests for services related to the capacity limitation.

4. Flexibility at Customer Level

Nowadays, the roles of small customers are undergoing a significant change. Customers have been typically considered as submissive ratepayers who were not subject to variations in the network. However, in the future, customers/prosumers are increasingly going to react to system changes and make profits, for example, by reshaping their demand based on price signals. Prosumers with renewable resources and batteries can also provide an increased amount of competitive flexibility services at local (DSO) and system-wide (TSO) levels [72]. They can also be more and more capable of meeting their own demand, known as self-consumption. In addition, EVs can be considered as one flexible resource of customers, if charging power and time of EVs can be controlled and scheduled.

Automatic home systems (AHSs) equipped with sensors and actuators are utilized to monitor and control the household energy consumption and generation [73]. In general, home energy management systems (HEMSs) are introduced to manage household appliances as well as generate resources in an optimal manner. HEMS can add intelligence as well as comfort to the home environment while aiming to save energy through optimal scheduling of controllable appliances. The last approaches in the field of real-time monitoring and measuring of prosumers' energy include advanced metering infrastructure (AMI) [74], smart sensors [75], home area networks [76] and home energy storage systems [77]. In order to manage power at the customer-level, the existence of these systems is necessary [78].

4.1. Flexible Resources at Customer Level

Correspondingly to the potential flexibilities connected at DSO and TSO levels, small-scale customers with flexible resources, like roof-mounted photovoltaics (PV), storages, controllable appliances (loads) and EVs, can be regarded as customer-level flexible resources on the demand-side of the system. Total customer load consists of non-flexible and flexible (controllable/shiftable) loads [79]. On the other hand, energy storage (e.g., batteries and EVs) can be utilized for flexibility provision instead of controlling the customer loads.

Regarding controllable appliances (loads) of households, they can be divided into three types: (1) interruptible appliances such as pool pump and EVs, (2) non-interruptible appliances like washing machines and dishwashers, and (3) thermostatically controlled appliances such as air conditioners and water heaters [80]. The user could define the preferred interval for operating particular appliances. Following the user's preference, the HEMS determines the optimal operation time taking into account the type of appliances. For example, interruptible appliances are allowed to operate at any time during the user's predefined interval whereas the operation of non-interruptible appliances cannot be interrupted while they are working [80].

4.2. Flexibilities Related Trading at Customer Level

Flexibility could be traded between customers/prosumers in a peer-to-peer way without any entity to play the role of mediator. For instance, authors in [81] proposed a peer-to-peer market that empowers customers to transact energy directly. In this way, producers and customers with flexible demand trade electricity with each other. The results of the paper verify that the proposed P2P approach can preserve the privacy of players considerably compared to the centralized one while the social welfare of players decreases negligibly from €50.75 to €50.55. In [57], a decentralized flexibility market was designed where all players of the distribution network make decisions autonomously.

The proposed market design in [57] consisted of electricity transactions between DSO-to-aggregators, aggregators-to-customers and customers-to-customers. The simulation results state that the peak shaving obtained from the proposed flexibility local market can enhance the minimum voltage magnitude (from 0.93 pu to 0.945 pu).

Prosumers could also trade their flexibility with an upstream entity such as an aggregator. Reference [82] proposed a method to provide flexibility services for aggregators in large-scale energy communities. A bottom-up decentralized approach has been used for trading energy among customers and aggregators in [83–85]. In [86,87], an iterative algorithm has been introduced to transact energy flexibility locally from customers to aggregators to DSO. Moreover, authors in [88] presented game-based and monopolistic-based approaches to transactions for the energy flexibility service between customers and aggregators in the distribution network. According to the paper’s simulation results, the proposed monopolistic approach can be profitable for aggregators acting as mediators if all end-users would be able to take part as interruptible loads.

Prosumers could also sell flexibility to the local markets. For instance, authors in [89] defined a local market (LM) in which players of the bottom-layer of the power system can participate in the LM with regard to flexibility. Authors in [90] introduced the local market scheme from the EMPOWER-project, which is based on a value-oriented approach. In this way, different services (e.g., flexibility) are provided by contracts among players. In [91], a decision-support tool was presented in which local market players are able to present their flexibility offer to the local markets through the MASCEM simulation platform proposed in [92]. The simulation results verify that the total profits of the end-users coming from the local market trading can be estimated to double in amount compared with the profits stemming from participation in the conventional day-ahead spot markets. In [57], authors designed decentralized local load management with the flexibility provided by prosumers and aggregators. In [93], the flexibility was defined as a load reduction service during peak hours which means that the DSO is able to buy the flexibility service from demand response aggregators based on monthly contracts. Table 2 shows different flexibility-related trading models at the customer level.

Table 2. Flexibility-related trading models at the customer level.

References	Customer to Customer	Customer to Aggregator	Customer to Local Market
[81]	✓		
[57]	✓		✓
[82]		✓	
[83]		✓	
[84]		✓	
[85]		✓	
[86]		✓	
[87]		✓	
[88]		✓	
[89]			✓
[90]			✓
[91]			✓
[92]		✓	✓
[93]			✓

5. Application of Blockchain Technology in Flexibility Trading

In the context of flexibility trading at different levels, all of the players are looking for a digital platform through which flexible resources could offer flexibility services and the operators (like TSOs and DSOs) would be able to send requests for buying flexibility. In other words, the platform is used to facilitate the sharing of information between different players. The platform should contain the functionality to help to aggregate the resources and perform market clearing and settlement. The platform needs to be capable of preserving the privacy of inputs while maintaining security against external signals and cyberattacks. Transparency and immutability are other key features

that a suitable platform should retain in order to avoid information asymmetry. For this purpose, blockchain offers a distributed-based trusted platform for storing data in a secure way as well as for simplifying transactions between the actors.

A platform integrated with Blockchain technology mainly consists of a distributed ledger, a decentralized consensus mechanism, along with cryptographic security measures [94]. All users can share information as well as hold the transaction data. In a blockchain-based platform, the confirmation of validity is obtained providing that all of the nodes (users) reach a common consensus [95]. A simple architecture of blockchain technology is presented in Figure 4. Transactions are confirmed using the pre-defined consensus in a shared execution way, named smart contracts. Despite the unrestricted access of users to the transaction data, each user can only access transactions in which it has been involved and no one is allowed to modify them. In order to preserve the privacy of input data, cryptographic hash functions are also employed in the blockchain-based platform. Further, each block containing transactions is linked to the previous block so that the information cannot be tampered with.




Figure 4. A simple architecture of blockchain technology.

Recently, the applications of blockchain technology have been extended to the energy field. Some unique features of blockchain technology can help to implement a secure decentralized energy trading environment. In a blockchain-based trading structure, there is no centralized entity to control, monitor, and confirm the legitimacy of the transactions. As a result, all users of a blockchain-based platform have equal rights, as they can share information such as submitting and accepting bids freely. The personal user information remains secure as they do not need to share it with another entity. Decentralization may decrease the costs typically allocated to the mediator. Besides, transactions recorded in the system are open and transparent and therefore information asymmetry can be avoided [96]. Accordingly, it can ensure that the data entered into the blockchain-based network remains safe and secure. Finally, users of this platform are able to trade together without knowing each other based on another key feature of blockchain technology called anonymity.

Reference [97] denoted that the blockchain-based platform for demand response resources can provide the following benefits for the system:

- (1) All DR products can be integrated through a single venue, enhancing the liquidity as well as providing a combination of different DR products.
- (2) It has the ability to allocate the value of flexibility in a fair manner.
- (3) It promotes competitive operation and reduces costs by eliminating centralized entities.
- (4) A blockchain-based platform may incentivize users to innovate and extend functionality as needed.
- (5) Users can manage their own personal data as there is no need for a centralized entity to take control of their private data.

Blockchain technology provides a trading platform through which flexible resources and operators located at TSO, DSO and customer levels can trade collaboratively without giving power to a single entity. Finally, all market participants can confirm the allocation of value according to the rules of the system.

Authors in [98] proposed adopting the blockchain technology to help customers to provide ancillary services for a microgrid. In the study, for each transaction, energy losses were calculated and after that, the required reactive power and its remuneration at each regulator node was estimated. Then, smart contracts were utilized to define interactions between sellers and buyers and finally the transactions related to active and reactive power were written in the blockchain. These actions were taken in order to monetize voltage regulation as well as the provision of reactive power. Smart contracts, as one of the key features of blockchain technology, were employed in [99] to guarantee the expected flexibility levels along with the balance between generation and demand. Blockchain technology was also proposed to facilitate the validation of DR agreements.

To summarize, blockchain technology can provide a secure transparent platform that does not require any agents to act as a centralized entity. However, the main issue related to the provision of a platform for flexibility trading is related to the required coordination between operators of different network levels. For example, should TSO and DSO interact via their common blockchain-based platform, or should each of them have a separate platform to aggregate their own flexible resources [21]?

6. Discussion and Conclusions

This paper focuses on the flexible resources, potential services and trading structures at different levels (TSO, DSO, customer) of the power system. Moreover, it discusses the applicability of blockchain technology in providing a suitable platform for trading flexibility.

At first, the flexible resources at TSO level were discussed. Traditional generators have been typically responsible for providing flexibility services in TSO-level networks. However, recent studies proved that large-scale aggregators aggregating EVs, prosumers, DR, storage-based resources as well as WPPs could also provide the needed flexibility at TSO-level. For example, it has been proven that the use of EV aggregators as flexible resources would help the system deal with more uncertainty and variability within the probability of 99% [26], and according to results obtained by [30], participation of WPPs as flexible resources can reduce the overall cost of the system by 5.5%.

Flexibility products at the TSO level could be divided into FRPs and ancillary services. The trading timeframes are mostly dependent on the types of flexibility services. Services belonging to the contingency situations can be traded in real-time or near real-time while planning-related services could be traded years ahead. FRPs are often proposed to be sold in existing markets, meaning that they do not have a separate market, whereas ancillary services can be traded in a separate market. In this context, there may exist a need for a separate market for ramping products. Flexible resources which are able to provide a faster response could participate in the ramp market in order to enhance the system resiliency and stability at the TSO level.

After the TSO level, potential flexible resources at the DSO level were also reviewed. Apart from conventional control-based methods, DER units connected to distribution networks can also

provide the needed flexibility for DSO requirements. Renewable DERs and EVs, which to a large extent created the need for flexibility in distribution networks, are also the most potential providers of the needed flexibility services at the DSO-level. According to [53], the capacities of these resources have the potential to decrease by 38.5 kW in response to the required 37.8 kW reduction offered by the DSO. Also, the combination of conventional and new potential flexible resources can increase the distribution network's controllability and flexibility. Related to trading, DSOs may need to restrict trading in some situations so as to avoid violations of the distribution network limits. They can sign a contract with aggregators or directly with prosumers to procure flexibility services. In addition, the aggregators may provide flexibility for DSOs through market-based approaches.

Furthermore, the customer level flexibility trading was considered. At this level, small household size customers are allowed to provide flexibility and sell to other customers, the aggregator or local markets. Some of the reviewed papers analyzed peer-to-peer models for flexibility trading, but most of the studies considered a local market in which prosumers can sell flexibility and make profits. As mentioned in [91], the total profits of end-users participating in local markets can be estimated to double in amount compared with the profits stemming from participation in the conventional day-ahead spot markets. Besides, with the existence of local markets, prosumers will have more incentive to participate solely in the local markets and compete against other approximately equal-sized competitors. Moreover, in some cases the customer or prosumer itself may also need to buy flexibility in order to compensate for fluctuations of its renewables or in situations in which the prosumer cannot sell the flexibility it had promised.

Finally, an appropriate platform is needed to facilitate flexibility trading while promoting cooperative trading between operators. Blockchain technology can ensure that the data would remain secure, it would not be tampered as well as it is transparent for all of the participants. In addition, the blockchain technology could also potentially eliminate the dependency from the centralized entity (such as an aggregator) as all of the rules and transactions can be determined and confirmed through smart contracts.

Author Contributions: Conceptualization and Supervision, H.L. and M.S.-k.; Writing, H.K. and A.S.G.; Investigation, H.K. and M.S.-k. All authors have read and agreed to the published version of the manuscript.

Funding: This work was done as part of FLEXIMAR—project (Novel marketplace for energy flexibility) which is funded by Business Finland and Finnish companies (<https://www.univaasa.fi/en/research/projects/fleximar/>).

Conflicts of Interest: The authors declare no conflict of interest.

Nomenclature

AHS	Automatic Home System	FACTS	Flexible AC Transmission System
AMI	Advanced Metering Infrastructure	FLECH	Flexibility Clearing House
ANM	Active Network Management	FRP	Flexible Ramping Product
BES	Battery Energy System	HEM	Home Energy Management
DER	Distributed Energy Resources	HV	High Voltage
DLR	Dynamic Line Rating	HVDC	High Voltage DC
DR	Demand Response	ICT	Information and Communication Technology
DSO	Distribution System Operator	LV	Low Voltage
EV	Electric Vehicle	MG	Microgrid
MV	Medium Voltage	SCUC	Security-Constrained Unit Commitment
OLTC	On-Load Tap Changing	SCED	Security-Constrained Economic Dispatch
PST	Phase Shifting Transformer	TSO	Transmission System Operator
PV	Photovoltaic	WPP	Wind Power Producer
RES	Renewable Energy Source	WAMPAC	Wide-Area Monitoring Protection and Control

References

1. Change, I.C. Mitigation of climate change. In *Contribution of Working Group III to the Fifth Assessment Report of the Intergovernmental Panel on Climate Change*; IPCC Climate: Geneva, Switzerland, 2014; Volume 1454, pp. 559–560.
2. Stocker, T.F.; Qin, D.; Plattner, G.K.; Alexander, L.V.; Allen, S.K.; Bindoff, N.L.; Breon, F.M.; Church, J.A.; Cubasch, U.; Emori, S. Technical Summary—Climate Change 2013: The Physical Science Basis. In *Contribution of Working Group I to the Fifth Assessment Report of the Intergovernmental Panel on Climate Change*; IPCC Climate: Geneva, Switzerland, 2013; pp. 33–115. [[CrossRef](#)]
3. Ssekulima, E.B.; Anwar, M.B.; Al Hinai, A.; El Moursi, M.S. Wind speed and solar irradiance forecasting techniques for enhanced renewable energy integration with the grid: A review. *IET Renew. Power Gener.* **2016**, *10*, 885–989. [[CrossRef](#)]
4. Heydarian-Forushani, E.; Moghaddam, M.P.; Sheikh-El-Eslami, M.K.; Shafie-Khah, M.; Catalão, J.P.S. A stochastic framework for the grid integration of wind power using flexible load approach. *Energy Convers. Manag.* **2014**, *88*, 985–998. [[CrossRef](#)]
5. Anwar, M.B.; El Moursi, M.S.; Xiao, W. Dispatching and frequency control strategies for marine current turbines based on doubly fed induction generator. *IEEE Trans. Sustain. Energy* **2015**, *7*, 262–270. [[CrossRef](#)]
6. Wang, Y.; Silva, V.; Lopez-Botet-Zulueta, M. Impact of high penetration of variable renewable generation on frequency dynamics in the continental Europe interconnected system. *IET Renew. Power Gener.* **2016**, *10*, 10–16. [[CrossRef](#)]
7. Lovins, A.B. Reliably integrating variable renewables: Moving grid flexibility resources from models to results. *Electr. J.* **2017**, *30*, 58–63. [[CrossRef](#)]
8. Ela, E.; Milligan, M.; Bloom, A.; Botterud, A.; Townsend, A.; Levin, T. *Evolution of Wholesale Electricity Market Design with Increasing Levels of Renewable Generation*; National Renewable Energy Laboratory (NREL): Golden, CO, USA, 2014.
9. Dalhues, S.; Zhou, Y.; Pohl, O.; Rewald, F.; Erlemeyer, F.; Schmid, D.; Zwartscholten, J.; Hagemann, Z.; Wagner, C.; Gonzalez, D.M. Research and practice of flexibility in distribution systems: A review. *CSEE J. Power Energy Syst.* **2019**, *5*, 285–294.
10. Lannoye, E.; Flynn, D.; O'Malley, M. Evaluation of power system flexibility. *IEEE Trans. Power Syst.* **2012**, *27*, 922–931. [[CrossRef](#)]
11. Aghaei, J.; Alizadeh, M.-I. Demand response in smart electricity grids equipped with renewable energy sources: A review. *Renew. Sustain. Energy Rev.* **2013**, *18*, 64–72. [[CrossRef](#)]
12. Siano, P. Demand response and smart grids—A survey. *Renew. Sustain. Energy Rev.* **2014**, *30*, 461–478. [[CrossRef](#)]
13. Pinson, P.; Madsen, H. Benefits and challenges of electrical demand response: A critical review. *Renew. Sustain. Energy Rev.* **2014**, *39*, 686–699.
14. Haider, H.T.; See, O.H.; Elmenreich, W. A review of residential demand response of smart grid. *Renew. Sustain. Energy Rev.* **2016**, *59*, 166–178. [[CrossRef](#)]
15. Mohandes, B.; El Moursi, M.S.; Hatziargyriou, N.D.; El Khatib, S. A review of power system flexibility with high penetration of renewables. *IEEE Trans. Power Syst.* **2019**. [[CrossRef](#)]
16. Villar, J.; Bessa, R.; Matos, M. Flexibility products and markets: Literature review. *Electr. Power Syst. Res.* **2018**, *154*, 329–340. [[CrossRef](#)]
17. Wang, Q.; Hodge, B.-M. Enhancing power system operational flexibility with flexible ramping products: A review. *IEEE Trans. Ind. Inform.* **2016**, *13*, 1652–1664. [[CrossRef](#)]
18. ISGAN—Smarter & Stronger Power Transmission: Review of feasible technologies for enhanced capacity and flexibility. Available online: <https://www.iea-iskan.org/smarter-stronger-power-transmission-review-of-feasible-technologies-for-enhanced-capacity-and-flexibility/> (accessed on 20 November 2019).
19. Tchoubraev, D.; Wiczynski, D. Swiss TSO integrated operational planning, optimization and ancillary services system. In Proceedings of the 2015 IEEE Eindhoven PowerTech, Eindhoven, The Netherlands, 29 June–2 July 2015; IEEE: Piscataway, NJ, USA, 2015; pp. 1–6.
20. Hu, J.; Sarker, M.R.; Wang, J.; Wen, F.; Liu, W. Provision of flexible ramping product by battery energy storage in day-ahead energy and reserve markets. *IET Gener. Transm. Distrib.* **2018**, *12*, 2256–2264. [[CrossRef](#)]

21. Cedec, E.; ENTSOe, E. Geode, «TSO-DSO Report-An Integrated Approach to Active System Management». 2019. Available online: https://docstore.entsoe.eu/Documents/Publications/Position%20papers%20and%20reports/TSO-DSO_ASM_2019_190416.pdf (accessed on 30 December 2019).
22. Thakurta, P.G.; Maeght, J.; Belmans, R.; Van Hertem, D. Increasing transmission grid flexibility by TSO coordination to integrate more wind energy sources while maintaining system security. *IEEE Trans. Sustain. Energy* **2014**, *6*, 1122–1130. [[CrossRef](#)]
23. Verseille, J.; Staschus, K. The Mesh-Up: ENTSO-E and European TSO Cooperation in Operations, Planning, and R&D. *IEEE Power Energy Mag.* **2014**, *13*, 20–29.
24. Widergren, S.; Subbarao, K.; Chassin, D.; Fuller, J.; Pratt, R. Residential real-time price response simulation. In Proceedings of the 2011 IEEE Power and Energy Society General Meeting, Detroit, MI, USA, 24–28 July 2011; IEEE: Piscataway, NJ, USA, 2011; pp. 1–5.
25. De Zotti, G.; Pourmousavi, S.A.; Morales, J.M.; Madsen, H.; Poulsen, N.K. Consumers’ Flexibility Estimation at the TSO Level for Balancing Services. *IEEE Trans. Power Syst.* **2018**, *34*, 1918–1930. [[CrossRef](#)]
26. Zhang, B.; Kezunovic, M. Impact on power system flexibility by electric vehicle participation in ramp market. *IEEE Trans. Smart Grid* **2015**, *7*, 1285–1294. [[CrossRef](#)]
27. Chen, K.; Han, D.; Sun, W. Modeling for operational strategy of flexible ramping capacity in deregulated power system considering EV aggregators participation. In Proceedings of the 2018 International Conference on Power System Technology (POWERCON), Guangzhou, China, 6–8 November 2018; IEEE: Piscataway, NJ, USA, 2018; pp. 4175–4180.
28. Khoshjahan, M.; Moeini-Aghaie, M.; Fotuhi-Firuzabad, M. Developing new participation model of thermal generating units in flexible ramping market. *IET Gener. Transm. Distrib.* **2019**. [[CrossRef](#)]
29. Ye, H.; Li, Z. Deliverable robust ramping products in real-time markets. *IEEE Trans. Power Syst.* **2017**, *33*, 5–18. [[CrossRef](#)]
30. Chen, R.; Wang, J.; Botterud, A.; Sun, H. Wind power providing flexible ramp product. *IEEE Trans. Power Syst.* **2016**, *32*, 2049–2061. [[CrossRef](#)]
31. Wang, Z.; Shen, C.; Liu, F.; Wang, J.; Wu, X. An Adjustable Chance-Constrained Approach for Flexible Ramping Capacity Allocation. *IEEE Trans. Sustain. Energy* **2018**, *9*, 1798–1811. [[CrossRef](#)]
32. Cui, M.; Zhang, J.; Wu, H.; Hodge, B.-M. Wind-friendly flexible ramping product design in multi-timescale power system operations. *IEEE Trans. Sustain. Energy* **2017**, *8*, 1064–1075. [[CrossRef](#)]
33. Heydarian-Forushani, E.; Golshan, M.E.H.; Shafie-khah, M.; Siano, P. Optimal operation of emerging flexible resources considering sub-hourly flexible ramp product. *IEEE Trans. Sustain. Energy* **2017**, *9*, 916–929. [[CrossRef](#)]
34. Zach, K.A.; Auer, H. Bulk energy storage versus transmission grid investments: Bringing flexibility into future electricity systems with high penetration of variable RES-electricity. In Proceedings of the 2012 9th International Conference on the European Energy Market, Florence, Italy, 10–12 May 2012; IEEE: Piscataway, NJ, USA, 2012; pp. 1–5.
35. Wang, F.; Xu, H.; Xu, T.; Li, K.; Shafie-Khah, M.; Catalão, J.P.S. The values of market-based demand response on improving power system reliability under extreme circumstances. *Appl. Energy* **2017**, *193*, 220–231. [[CrossRef](#)]
36. Zhou, S.; Shu, Z.; Gao, Y.; Gooi, H.B.; Chen, S.; Tan, K. Demand response program in Singapore’s wholesale electricity market. *Electr. Power Syst. Res.* **2017**, *142*, 279–289. [[CrossRef](#)]
37. Khajeh, H.; Foroud, A.A.; Firoozi, H. Robust bidding strategies and scheduling of a price-maker microgrid aggregator participating in a pool-based electricity market. *IET Gener. Transm. Distrib.* **2018**, *13*, 468–477. [[CrossRef](#)]
38. Nikoobakht, A.; Aghaei, J.; Khatami, R.; Mahboubi-Moghaddam, E.; Parvania, M. Stochastic flexible transmission operation for coordinated integration of plug-in electric vehicles and renewable energy sources. *Appl. Energy* **2019**, *238*, 225–238. [[CrossRef](#)]
39. Cornelius, A. Assessing the Impact of Flexible Ramp Capability Products in the Midcontinent ISO. Master’s Thesis, Duke University, Durham, NC, USA, 2014.
40. Navid, N.; Rosenwald, G. Market solutions for managing ramp flexibility with high penetration of renewable resource. *IEEE Trans. Sustain. Energy* **2012**, *3*, 784–790. [[CrossRef](#)]

41. Osório, G.J.; Shafie-Khah, M.; Soares, N.G.S.; Catalão, J.P.S. Optimal Dynamic Tariffs for Flexible Ramp Market in the Presence of Wind Power Generation and Demand Response. In Proceedings of the 2018 IEEE International Conference on Environment and Electrical Engineering and 2018 IEEE Industrial and Commercial Power Systems Europe (EEEIC/I&CPS Europe), Palermo, Italy, 12–15 June 2018; IEEE: Piscataway, NJ, USA, 2018; pp. 1–5.
42. Wang, B.; Hobbs, B.F. Real-time markets for flexiramp: A stochastic unit commitment-based analysis. *IEEE Trans. Power Syst.* **2015**, *31*, 846–860. [[CrossRef](#)]
43. MISO, M. Energy and Operating Reserve Markets. Bus. Pract. Man. BPM-002-r11. 2018. Available online: <https://www.misoenergy.org/legal/business-practice-manuals/> (accessed on 30 December 2019).
44. Thomas, D.; Iain, M.; Dale, G. Virtual power plants leveraging energy flexibility in regional markets. *CIREN-Open Access Proc. J.* **2017**, *2017*, 2939–2943. [[CrossRef](#)]
45. Zhang, C.; Yi, D.; Nordentoft, N.C.; Pinson, P.; Østergaard, J. FLECH: A Danish market solution for DSO congestion management through DER flexibility services. *J. Mod. Power Syst. Clean Energy* **2014**, *2*, 126–133. [[CrossRef](#)]
46. Alkandari, A.; Sami, A.A.; Sami, A. Proposed DSO ancillary service processes considering smart grid requirements. *CIREN-Open Access Proc. J.* **2017**, *2017*, 2846–2847. [[CrossRef](#)]
47. Short, T.A. *Electric Power Distribution Handbook*; CRC Press: Boca Raton, FL, USA, 2018; ISBN 1315215551.
48. Ding, Y.; Hansen, L.H.; Cajar, P.D.; Brath, P.; Bindner, H.W.; Zhang, C.; Nordentoft, N.C. Development of a DSO-market on Flexibility Services. 2013. Available online: https://backend.orbit.dtu.dk/ws/portalfiles/portal/176493622/WP_3_8_report.pdf (accessed on 30 December 2019).
49. Huang, S.; Wu, Q.; Cheng, L.; Liu, Z. Optimal reconfiguration-based dynamic tariff for congestion management and line loss reduction in distribution networks. *IEEE Trans. Smart Grid* **2015**, *7*, 1295–1303. [[CrossRef](#)]
50. Kulmala, A.; Alonso, M.; Repo, S.; Amaris, H.; Moreno, A.; Mehmedalic, J.; Al-Jassim, Z. Hierarchical and distributed control concept for distribution network congestion management. *IET Gener. Transm. Distrib.* **2017**, *11*, 665–675. [[CrossRef](#)]
51. Shen, F.; Huang, S.; Wu, Q.; Repo, S.; Xu, Y.; Østergaard, J. Comprehensive Congestion Management for Distribution Networks based on Dynamic Tariff, Reconfiguration and Re-profiling Product. *IEEE Trans. Smart Grid* **2018**. [[CrossRef](#)]
52. Brochure, C. Guidelines for increased utilization of existing overhead transmission lines. *WG B2* **2008**, *13*, 26–31.
53. Heussen, K.; Bondy, D.E.M.; Hu, J.; Gehrke, O.; Hansen, L.H. A clearinghouse concept for distribution-level flexibility services. In Proceedings of the IEEE PES ISGT Europe 2013, Lyngby, Denmark, 6–9 October 2013; IEEE: Piscataway, NJ, USA, 2013; pp. 1–5.
54. Heydarian-Forushani, E.; Moghaddam, M.P.; Sheikh-El-Eslami, M.K.; Shafie-khah, M.; Catalão, J.P.S. Risk-constrained offering strategy of wind power producers considering intraday demand response exchange. *IEEE Trans. Sustain. Energy* **2014**, *5*, 1036–1047. [[CrossRef](#)]
55. Panwar, L.K.; Reddy, S.; Verma, A.; Panigrahi, B.K. Dynamic incentive framework for demand response in distribution system using moving time horizon control. *IET Gener. Transm. Distrib.* **2017**, *11*, 4338–4347. [[CrossRef](#)]
56. Majzoobi, A.; Khodaei, A. Application of microgrids in supporting distribution grid flexibility. *IEEE Trans. Power Syst.* **2016**, *32*, 3660–3669. [[CrossRef](#)]
57. Morstyn, T.; Teytelboym, A.; McCulloch, M.D. Designing Decentralized Markets for Distribution System Flexibility. *IEEE Trans. Power Syst.* **2018**, *34*, 2128–2139. [[CrossRef](#)]
58. Iria, J.P.; Soares, F.J.; Matos, M.A. Trading small prosumers flexibility in the energy and tertiary reserve markets. *IEEE Trans. Smart Grid* **2018**, *10*, 2371–2382. [[CrossRef](#)]
59. Zhu, X.; Han, H.; Gao, S.; Shi, Q.; Cui, H.; Zu, G. A multi-stage optimization approach for active distribution network scheduling considering coordinated electrical vehicle charging strategy. *IEEE Access* **2018**, *6*, 50117–50130. [[CrossRef](#)]
60. Knezović, K.; Marinelli, M.; Codani, P.; Perez, Y. Distribution grid services and flexibility provision by electric vehicles: A review of options. In Proceedings of the 2015 50th International Universities Power Engineering Conference (UPEC), Stoke on Trent, UK, 1–4 September 2015; IEEE: Piscataway, NJ, USA, 2015; pp. 1–6.
61. Huang, S.; Wu, Q. Real-time congestion management in distribution networks by flexible demand swap. *IEEE Trans. Smart Grid* **2017**, *9*, 4346–4355. [[CrossRef](#)]

62. Stadler, I. Electrical Energy Storage. In *Handbook of Energy Storage*; Springer: Berlin/Heidelberg, Germany, 2019; pp. 191–225.
63. Parthasarathy, C.; Hafezi, H.; Laaksonen, H.; Kauhaniemi, K. Modelling and Simulation of Hybrid PV & BES Systems as Flexible Resources in Smartgrids—Sundom Smart Grid Case. In Proceedings of the 2019 IEEE Milan PowerTech, Milan, Italy, 23–27 June 2019; IEEE: Piscataway, NJ, USA, 2019; pp. 1–6.
64. Ghazvini, M.A.F.; Lipari, G.; Pau, M.; Ponci, F.; Monti, A.; Soares, J.; Castro, R.; Vale, Z. Congestion management in active distribution networks through demand response implementation. *Sustain. Energy Grids Netw.* **2019**, *17*, 100185. [[CrossRef](#)]
65. Zhao, J.; Wang, Y.; Song, G.; Li, P.; Wang, C.; Wu, J. Congestion Management Method of Low-Voltage Active Distribution Networks Based on Distribution Locational Marginal Price. *IEEE Access* **2019**, *7*, 32240–32255. [[CrossRef](#)]
66. Ziras, C.; Kazempour, J.; Kara, E.C.; Bindner, H.W.; Pinson, P.; Kiliccote, S. A Mid-Term DSO Market for Capacity Limits: How to Estimate Opportunity Costs of Aggregators? *IEEE Trans. Smart Grid* **2019**. [[CrossRef](#)]
67. Vo, T.H.; Haque, A.; Nguyen, P.H.; Kamphuis, I.G.; Eijgelaar, M.; Bouwman, I. A study of congestion management in smart distribution networks based on demand flexibility. In Proceedings of the 2017 IEEE Manchester PowerTech, Manchester, UK, 18–22 June 2017; IEEE: Piscataway, NJ, USA, 2017; pp. 1–6.
68. Crăciun, B.-I.; Kerekes, T.; Séra, D.; Teodorescu, R. Overview of recent grid codes for PV power integration. In Proceedings of the 2012 13th International Conference on Optimization of Electrical and Electronic Equipment (OPTIM), Brasov, Romania, 24–26 May 2012; IEEE: Piscataway, NJ, USA, 2012; pp. 959–965.
69. Olivella-Rosell, P.; Lloret-Gallego, P.; Munné-Collado, Í.; Villafafila-Robles, R.; Sumper, A.; Ottessen, S.; Rajasekharan, J.; Bremdal, B. Local flexibility market design for aggregators providing multiple flexibility services at distribution network level. *Energies* **2018**, *11*, 822. [[CrossRef](#)]
70. Olivella-Rosell, P.; Bullich-Massagué, E.; Aragüés-Peñalba, M.; Sumper, A.; Ottesen, S.Ø.; Vidal-Clos, J.-A.; Villafafila-Robles, R. Optimization problem for meeting distribution system operator requests in local flexibility markets with distributed energy resources. *Appl. Energy* **2018**, *210*, 881–895. [[CrossRef](#)]
71. Zoeller, H.; Reischboeck, M.; Henselmeyer, S. *Managing Volatility in Distribution Networks with Active Network Management*; IET: London, UK, 2016.
72. Damisa, U.; Nwulu, N.I.; Sun, Y. Microgrid energy and reserve management incorporating prosumer behind-the-meter resources. *IET Renew. Power Gener.* **2018**, *12*, 910–919. [[CrossRef](#)]
73. Pau, G.; Collotta, M.; Ruano, A.; Qin, J. Smart home energy management 2017. *Energies* **2017**, *10*, 382. [[CrossRef](#)]
74. Ikpehai, A.; Adebisi, B.; Rabie, K. Broadband PLC for clustered advanced metering infrastructure (AMI) architecture. *Energies* **2016**, *9*, 569. [[CrossRef](#)]
75. Ahmed, M.; Kang, Y.; Kim, Y.-C. Communication network architectures for smart-house with renewable energy resources. *Energies* **2015**, *8*, 8716–8735. [[CrossRef](#)]
76. Bradac, Z.; Kaczmarczyk, V.; Fiedler, P. Optimal scheduling of domestic appliances via MILP. *Energies* **2015**, *8*, 217–232. [[CrossRef](#)]
77. Pascual, J.; Sanchis, P.; Marroyo, L. Implementation and control of a residential electrothermal microgrid based on renewable energies, a hybrid storage system and demand side management. *Energies* **2014**, *7*, 210–237. [[CrossRef](#)]
78. Collotta, M.; Pau, G. A solution based on bluetooth low energy for smart home energy management. *Energies* **2015**, *8*, 11916–11938. [[CrossRef](#)]
79. Paudel, A.; Chaudhari, K.; Long, C.; Gooi, H.B. Peer-to-Peer Energy Trading in a Prosumer-Based Community Microgrid: A Game-Theoretic Model. *IEEE Trans. Ind. Electron.* **2018**, *66*, 6087–6097. [[CrossRef](#)]
80. Liu, Y.; Xiao, L.; Yao, G.; Bu, S. Pricing-based demand response for a smart home with various types of household appliances considering customer satisfaction. *IEEE Access* **2019**, *7*, 86463–86472. [[CrossRef](#)]
81. Khorasany, M.; Mishra, Y.; Ledwich, G. A decentralised bilateral energy trading system for peer-to-peer electricity markets. *IEEE Trans. Ind. Electron.* **2019**. [[CrossRef](#)]
82. Olivella-Rosell, P.; Rullan, F.; Lloret-Gallego, P.; Prieto-Araujo, E.; Ferrer-San-José, R.; Barja-Martinez, S.; Bjarghov, S.; Lakshmanan, V.; Hentunen, A.; Forsström, J. Centralised and Distributed Optimization for Aggregated Flexibility Services Provision. *arXiv* **2019**, arXiv:1907.08125.

83. Gazafroudi, A.S.; Corchado, J.M.; Keane, A.; Soroudi, A. Decentralised flexibility management for EVs. *IET Renew. Power Gener.* **2019**, *13*, 952–960. [[CrossRef](#)]
84. Prieto-Castrillo, F.; Shokri Gazafroudi, A.; Prieto, J.; Corchado, J.M. An ising spin-based model to explore efficient flexibility in distributed power systems. *Complexity* **2018**, *2018*. [[CrossRef](#)]
85. Gazafroudi, A.S.; Prieto-Castrillo, F.; Pinto, T.; Corchado, J.M. Energy flexibility management in power distribution systems: Decentralized approach. In Proceedings of the 2018 International Conference on Smart Energy Systems and Technologies (SEST), Sevilla, Spain, 10–12 September 2018; IEEE: Piscataway, NJ, USA, 2018; pp. 1–6.
86. Shokri Gazafroudi, A.; Prieto, J.; Corchado, J.M. Virtual Organization Structure for Agent-Based Local Electricity Trading. *Energies* **2019**, *12*, 1521. [[CrossRef](#)]
87. Gazafroudi, A.S.; Corchado, J.M.; Shafie-khah, M.; Lotfi, M.; Joao Catalao, P.S. Iterative Algorithm For Local Electricity Trading. In Proceedings of the 2019 IEEE Milan PowerTech, Milan, Italy, 23–27 June 2019; IEEE: Piscataway, NJ, USA, 2019; pp. 1–6.
88. Gazafroudi, A.S.; Shafie-khah, M.; Prieto-Castrillo, F.; Corchado, J.M.; Catalao, J.P.S. Monopolistic and Game-based Approaches to Transact Energy Flexibility. *IEEE Trans. Power Syst.* **2019**, *1*. [[CrossRef](#)]
89. Ramos, A.; De Jonghe, C.; Gómez, V.; Belmans, R. Realizing the smart grid’s potential: Defining local markets for flexibility. *Util. Policy* **2016**, *40*, 26–35. [[CrossRef](#)]
90. Bremdal, B.A.; Olivella-Rosell, P.; Rajasekharan, J.; Ilieva, I. Creating a local energy market. *CIREC-Open Access Proc. J.* **2017**, *2017*, 2649–2652. [[CrossRef](#)]
91. Pinto, T.; Faia, R.; Ghazvini, M.A.F.; Soares, J.; Corchado, J.M.; do Vale, Z.M.A. Decision support for small players negotiations under a transactive energy framework. *IEEE Trans. Power Syst.* **2018**. [[CrossRef](#)]
92. Praça, I.; Ramos, C.; Vale, Z.; Cordeiro, M. MASCEM: A multiagent system that simulates competitive electricity markets. *IEEE Intell. Syst.* **2003**, *18*, 54–60. [[CrossRef](#)]
93. Kok, C.; Kazempour, J.; Pinson, P. A DSO-level contract market for conditional demand response. In Proceedings of the 13th IEEE PES PowerTech Conference, Milan, Italy, 23–27 June 2019; IEEE: Piscataway, NJ, USA, 2019.
94. Mengelkamp, E.; Notheisen, B.; Beer, C.; Dauer, D.; Weinhardt, C. A blockchain-based smart grid: Towards sustainable local energy markets. *Comput. Sci. Dev.* **2018**, *33*, 207–214. [[CrossRef](#)]
95. Debus, J. *Consensus Methods in Blockchain Systems*; Technical Report; Frankfurt School of Finance & Management, Blockchain Center: Frankfurt am Main, Germany, 2017; pp. 1–58.
96. Gao, C.; Ji, Y.; Wang, J.; Sai, X. Application of blockchain technology in peer-to-peer transaction of photovoltaic power generation. In Proceedings of the 2018 2nd IEEE Advanced Information Management, Communicates, Electronic and Automation Control Conference (IMCEC), Xi’an, China, 25–27 May 2018; IEEE: Piscataway, NJ, USA, 2018; pp. 2289–2293.
97. Ellis, P.; Hubbard, J. Flexibility Trading Platform—Using Blockchain to Create the Most Efficient Demand-side Response Trading Market. In *Transforming Climate Finance and Green Investment with Blockchains*; Elsevier: Amsterdam, The Netherlands, 2018; pp. 99–109.
98. Di Silvestre, M.L.; Gallo, P.; Ippolito, M.G.; Musca, R.; Sanseverino, E.R.; Tran, Q.T.T.; Zizzo, G. Ancillary Services in the Energy Blockchain for Microgrids. *IEEE Trans. Ind. Appl.* **2019**. [[CrossRef](#)]
99. Pop, C.; Cioara, T.; Antal, M.; Anghel, I.; Salomie, I.; Bertoncini, M. Blockchain based decentralized management of demand response programs in smart energy grids. *Sensors* **2018**, *18*, 162. [[CrossRef](#)] [[PubMed](#)]

