

Date of publication xxxx 00, 0000, date of current version xxxx 00, 0000.

Digital Object Identifier ...

Data-driven model of the power-grid frequency dynamics

LEONARDO RYDIN GORJÃO^{1,2}, MEHRNAZ ANVARI³, HOLGER KANTZ³, CHRISTIAN BECK⁴, DIRK WITTHAUT^{1,2}, MARC TIMME^{5,6,7}, BENJAMIN SCHÄFER^{4,5,6,7}

¹Forschungszentrum Jülich, Institute for Energy and Climate Research - Systems Analysis and Technology Evaluation (IEK-STE), 52428 Jülich, Germany

²Institute for Theoretical Physics, University of Cologne, 50937 Köln, Germany

³Max-Planck Institute for the Physics of Complex Systems (MPIPKS), 01187 Dresden, Germany

⁴School of Mathematical Sciences, Queen Mary University of London, London E1 4NS, United Kingdom

⁵Chair for Network Dynamics, Center for Advancing Electronics Dresden (cfaed) and Institute for Theoretical Physics, Technical University of Dresden, 01062 Dresden, Germany

⁶Network Dynamics, Max Planck Institute for Dynamics and Self-Organization (MPIDS), 37077 Göttingen, Germany

⁷Contributed equally

Corresponding author: Leonardo Rydin Gorjão (e-mail: l.rydin.gorjao@fz-juelich.de).

We gratefully acknowledge support from the Federal Ministry of Education and Research (BMBF grant no. 03SF0472 and 03EK3055), the Helmholtz Association (via the joint initiative *Energy System 2050 - A Contribution of the Research Field Energy*, the grant No. VH-NG-1025), the German Science Foundation (DFG) by a grant toward the *Cluster of Excellence Center for Advancing Electronics Dresden* (cfaed), and the *STORM - Stochastics for Time-Space Risk Models* project of the Research Council of Norway (RCN) No. 274410. This project has received funding from the European Union's Horizon 2020 research and innovation programme under the Marie



Co-funded by the Horizon 2020 programme of the European Union

Skłodowska-Curie grant agreement No. 840825.

ABSTRACT The energy system is rapidly changing to accommodate the increasing number of renewable generators and the general transition towards a more sustainable future. Simultaneously, business models and market designs evolve, affecting power-grid operation and power-grid frequency. Problems raised by this ongoing transition are increasingly addressed by transdisciplinary research approaches, ranging from purely mathematical modelling to applied case studies. These approaches require a stochastic description of consumer behaviour, fluctuations by renewables, market rules, and how they influence the stability of the power-grid frequency. Here, we introduce an easy-to-use, data-driven, stochastic model for the power-grid frequency and demonstrate how it reproduces key characteristics of the observed statistics of the Continental European and British power grids. **Using data analysis tools and a Fokker-Planck approach, we estimate parameters of our deterministic and stochastic model.** We offer executable code and guidelines on how to use the model on any power grid for various mathematical or engineering applications.

INDEX TERMS Stochastic modelling, Power-grid frequency, Swing equation, Control systems, Parameter estimation, Fokker-Planck equation, data-driven model

I. INTRODUCTION

The energy system is currently undergoing a rapid transition towards a more sustainable future. Greenhouse gas emissions are reduced by implementing distributed renewable-energy sources at ever growing rates in the world [1]. Simultaneously, new policies, technologies, and market structures are being implemented in various regions in the energy systems [2]. These new market structures are not necessarily benefiting the stability of the power grid: A control power shortage in the German grid in June 2019 was potentially

caused by unknown traders exploiting the energy market structure [3], [4].

The field of energy research itself is quickly developing and attracting researchers from various disciplines working towards new control systems, new market models, and new technologies every year [5], [6]. Regardless of the specific aspect of the energy system, one element remains unchanged: The electrical power system and the stability of its frequency are critical for a stable operation of our society [7].

The power-grid (mains) frequency dynamics mirrors the balance of supply and demand of the power grid: An excess of generation leads to an increased frequency and a shortage of generation leads to a reduced frequency value. The power grid is stabilised by controlling the frequency and maintaining it at a nominal frequency [8]. But the task of maintaining a set frequency across an entire power-grid system is not a simple one: systems vary in size and structure, energy sources are possibly volatile in their output, as for example are wind or photo-voltaic generators [9], [10], and the dispatch of electrical energy and market activity have an impact on the overall dynamics.

Understanding the intricacies of the frequency dynamics becomes of great importance, both to control the current power grid [8], [11] but also for implementing real-time pricing schemes [12], [13] or smart grids in the future [14]. Solid estimates of fluctuations are essential for example when dimensioning back-up or control options, such as determining the capacity of batteries or other energy storage to balance periods with highly fluctuating demand or times without renewable generation [15]. Similarly, when establishing new power grid types, such as smart grids with potentially novel electricity market structure, the market design should ideally support the stability of the grid.

While both the power-grid frequency dynamics and the stochastic nature of the power-grid frequency have been intensely studied, we require a better understanding of the interaction of frequency dynamics with both stochastic fluctuations and market behaviour. The dynamics of the power-grid variables, including frequency, voltage, reactive power, etc., may be modelled with arbitrary complexity based on various models [8], [16], [11], [17], [18], [19]. Simultaneously, stochastic modelling of fluctuations within the power grid [18], [20] still often uses Gaussian noise models [21], [14], [22], while non-Gaussian statistics [9], [23] as well as deterministic events caused by trading [24] are rarely included.

Existing literature that explicitly deals with realistic forecasts of the power grid frequency often focuses on inverter control [25] or the power interface between grid layers [26]. Alternatively, forecasts are done for electricity consumption [27] or for renewable generation, such as solar generators [28]. In contrast, models that predict or even give stochastic characteristics of the power-grid frequency are very rare [29].

Here, we propose an accessible and easy-to-use stochastic model that seeks to describe the dynamics of the power-grid frequency in a reduced framework combining stochastic and deterministic factors acting on the power-grid frequency. We focus on the intermediate time scale of several seconds to few hours, leaving very short or very long time scale for future work. Simultaneously, our modelling approach balances the benefits of realistic case studies, generally applicable and abstract stochastic models as well as application-oriented data-driven approaches.

We first review the factors influencing the power-grid




FIGURE 1. The frequency dynamics is influenced by both stochastic and deterministic aspects. The trajectory of the power-grid frequency is substantially influenced by stochastic effects, as seen by the erratic motion. In addition, we observe deterministic behaviour: Every 15 minutes (vertical lines) the frequency abruptly decreases and then slowly trends upwards for the next 15 minutes. The plot uses the TransNetBW data [30] from the European Central power grid CE, from January, 10th 2019, 20:45 to 21:45.

frequency dynamics, based on frequency recordings from European grids. Next, we introduce a general stochastic model and discuss three particular cases of how the model may be implemented. For each case we estimate the system parameters, such as control strength and noise amplitude using stochastic theory and data-driven approaches.

We compare the frequency statistics of the models with real-world measurements to showcase how they reproduce characteristic features. Overall, our modelling approach is very flexible and easily applicable to many different power grids and could be used for planning purposes, e.g. when setting security operational limits or designing markets. We provide executable code for the model in the supplementary material.

II. FACTORS IMPACTING THE POWER-GRID FREQUENCY

To construct a model describing the intermediate time scale dynamics and characteristics of the power-grid frequency, we must first recall the nature and the intricate details of the power-grid frequency dynamics, both deterministic and stochastic, as we observe them in frequency trajectories [30], see Fig. 1.

The power-grid frequency is not following a simple Gaussian process but displays heavy tails and regular correlation peaks, see Fig. 2 and [23], [31], [32] for more detailed analysis. To get a better understanding of the different factors impacting the grid frequency, we give an overview of these: First, we review the innate and humanly devised control systems, continue with the market and power dispatch design and close the section with a stochastic description of the noise acting on the power grid.

A. THE FUNDAMENTAL CONTROL SCHEMES

The power supply of the grid is designed so that the frequency of the alternating current is kept steadily at a fixed nominal value, i.e., 50 Hz in Europe and many parts of the world, or 60 Hz in the Americas, Southern Japan and some other regions. The electrical frequency of e.g.

50 Hz corresponds to large mechanical generators rotating in synchrony at this frequency (or integer multiples of it) across each synchronous region, such as the Continental European grid. How is this frequency kept fixed when facing fluctuations or larger disturbances?

Suppose a large generator disconnects from the grid while the power demand in the region stays constant. The missing energy cannot be drawn from the grid itself, as it cannot store any energy directly [34]. Instead, power is first provided by inertial energy until primary, secondary, and potentially tertiary control set in to ensure the provision of the missing power [34]. In the first moments after the disturbance, the missing power is drawn from the kinetic energy of the large rotating machines. Their kinetic energy is converted into electrical energy and the generators are slowed down, thereby reducing the overall frequency in the grid. This inertial response ensures the system does not drift off from its designed nominal frequency too rapidly and smoothens any disturbances. Nevertheless, the generators continue to slow down. Moments later, primary control activates: Dedicated power plants, and recently also battery stacks [35], measure the deviation of the frequency from the reference and insert additional power into the grid proportional to the frequency deviation. This power influx prevents a further decrease of the frequency and stabilises it at a fixed but lower frequency, which is not desired for operation, as any further problems might cause the frequency to leave the stable operational limits [34], [8]. While the primary control compensates for the missing power, the kinetic energy of the rotors is still lower than initially and thereby the frequency is not at the reference value. To restore the frequency back to the reference frequency an integrative control, secondary control, is necessary. A few minutes after the disturbance, this control fully restores the energetic state and the grid is brought back into a new stable state at its nominal frequency (i.e., 50 Hz or 60 Hz, depending on the grid in question). On even longer time scales of potentially hours, tertiary control, often operated manually, sets in [36]. As this tertiary control sets in, primary and secondary control can be reduced to become available for further control actions.

Here, we focus on the effects of inertia, as well as primary (proportional) and secondary (integrative) control in our synthetic model. The time scales of these three controls are significantly different, and they functionally react to deviations of different variables of the system: Where primary control stabilises the grid based on the frequency deviations of the system, the secondary control balances the total power to ensure stability based on an integral of the frequency, i.e., an angle.

As a recent challenge, the replacement of conventional power generators with renewable generators reduces the overall system inertia [37] and thereby makes complementary control mechanisms or virtual inertia increasingly important [38].

B. ELECTRICITY DISPATCH AND MARKET

While the control schemes keep the frequency close to the reference for small and unforeseen changes of supply and demand, an electricity market has been established to coordinate longer-term power dispatches dealing with large and predictable variations.

The effective demand acting on the power grid is the aggregation of millions of consumers throughout the synchronous region. This aggregated demand is continuously changing over time since consumption during the day tends to be higher than during the night and industrial activities during the week lead to higher consumption than during the weekends [34].

The continuously changing demand has to be met with sufficient supply of electrical power in the same synchronous grid. Therefore, power plant operators have to adjust their generation according to the needs of the consumers. While some power plants, such as gas turbines, can ramp their generation up or down very fast, other plants, such as coal or nuclear power plants, require more time and therefore prefer to commit generation for longer time periods [39], [36]. Demand response schemes, where consumers shift their demand to periods of higher generation, bring additional flexibility to the grid [40].

To reach an economic optimum on who is supplying and when, power-plant operators bid on spot markets to offer power generation [36]. This includes a day-ahead market to fulfil the expected power demand, and an intra-day market acting on time scales of few hours to several minutes, to balance short-term mismatches, amongst other [41]. This bidding on the market takes place in discrete time-slots: Any power provided by one operator is provided for a fixed interval, e.g. one hour, half an hour, or 15 minutes, as is often the case, such as in the European Energy Exchange (EEX) [42].

An important consequence of the fixed intervals of generation is that it does not perfectly fit the smooth demand curve. If we approximate a monotonically increasing demand function (such as during the early morning hours) with a step function assuming the mean for a given time interval, we will initially overestimate the demand, which is still growing. After some time, supply and demand perfectly match but then the demand surpasses the supply again. This leads to the balance between supply and demand being approximately a sawtooth function, see Fig. 3.

Indeed, we also observe the consequences of the intervals when analysing the frequency trajectory [24] or its autocorrelation in the Continental European grid. The frequency displays regular surges and sags approximately every 15 minutes, where the supply updates to the new demand interval. At full hours these effects are more pronounced since the total dispatch and trading volume is higher at full hours compared to other 15 minute intervals [43]. Not only the frequency trajectory displays these jumps and sags, see Fig. 1 but also the autocorrelation function of the power-




FIGURE 2. The power-grid frequency is heavy-tailed and has regular correlation peaks. (a) The frequency histogram displays heavy tails, which are quantified by a kurtosis κ that is much larger than the Gaussian value of $\kappa_{\text{Gaussian}} = 3$. Consistently, the best-fitting Gaussian distribution (dashed line) does not capture the tails. (b) The autocorrelation function of the grid frequency decays exponentially within the first minutes, which is a typical behaviour for many stochastic processes [33]. In addition, the autocorrelation peaks every 15 minutes due to trading activity. The plots use the TransNetBW data from January 2019 [30].

grid frequency $c(\Delta t)$ reveals distinct peaks at 15, 30, 45 and 60 minutes, see Fig. 2 and [23], [31].

We will include the market influence by employing a deterministic power-mismatch model in our stochastic model. But more importantly, we can extract vital information by observing this phenomenon, as we will highlight below.

C. NOISE

So far, we have introduced the two deterministic elements of our model: Control in the form of inertia, primary and secondary control, and electricity trading occurring at fixed times. We are only missing the stochastic element of the model, i.e., the noise acting on the system. Noise here is meant as any form of stochastic fluctuation. Its sources are plentiful, ranging from demand fluctuations [44], [40] to intermittency in the renewable generators [45], [9], thermal fluctuations, and others, many of which are typically unknown [23]. However, the precise origin of the noise is not essential for our modelling approach. In fact, we only observe the cumulative effect of the noise in how it influences the power-grid frequency, regardless whether it originates from local disturbances or system-wide variations. Aggregating all sources of noise allows it to be handled as a stochastic process, see also [32] for more details.

As a first approximation for the noise, we will assume white Gaussian noise, based on two important observations. First, Gaussian noise arises naturally in many settings due to the Central Limit Theorem. In its simplest form it states that the sum of randomly drawn numbers, in our case the aggregation of renewable, demand and any other form of fluctuation, approximates a Gaussian distribution if sufficiently many contributions are summed up [33]. Second, we note that non-Gaussian frequency distributions can easily be described by super-imposed Gaussian distributions, following superstatistics [23], [46], [38], where parameters, such as the standard deviation change over time. Moreover, the above mentioned trading intervals are known to contribute significantly to these tails [31].

If so desired, employing another form of noise is left open in the model, without any fundamental change of the

model itself. There are plenty of non-Gaussian sources of noise impacting the power grid, such as jump noise from solar panels [9] or turbulence from wind turbines [47], [20]. Instead of Gaussian noise, we could include for example non-Gaussian effects via Lévy-stable distributions or q -Gaussian distributions [48], [38].

III. DATA-DRIVEN MODEL

Now, we formulate a simple dynamical model for the frequency dynamics that includes all factors influencing the power-grid frequency. First, we present the model and explain how the above-mentioned factors enter the model. We then discuss special cases of how some parameters could be set as constants or as time-dependent. We close the section by proving the theory to estimate the parameters of the model.

For simplicity, we do not use the frequency f as the variable but the bulk angular velocity $\omega = 2\pi(f - f_{\text{ref}})$, with reference frequency $f_{\text{ref}} = 50$ or 60 Hz, i.e., we move into the rotating reference frame. In this frame, the dynamics of the angular velocity ω and the bulk angle θ may be modelled in an aggregated swing equation [49] as

$$\begin{aligned} \frac{d\theta}{dt} &= \omega, \\ M \frac{d\omega}{dt} &= -c_1\omega - c_2\theta + \Delta P + \epsilon\xi. \end{aligned} \quad (1)$$

The factor M gives the inertial constant of the system and sets the time scale it reacts to changes. For simplicity, we absorb it in the remaining constants and set $M = 1$ in the following, i.e., $c_1 \rightarrow c_1/M$, $c_2 \rightarrow c_2/M$, $\Delta P \rightarrow \Delta P/M$ and $\epsilon \rightarrow \epsilon$.

The term $-c_1\omega$ models primary control and general damping acting on the system [34], [16]. The larger the deviation from the nominal frequency, i.e., the larger ω , the larger the damping and control force.

The expression $-c_2\theta$ models the secondary control [50], [51]. If the system deviates from the nominal frequency, e.g. because $\omega > 0$ for a long time, then the bulk angle θ increases more and more and thereby the secondary control increases and acts as an increasing force to return the system




FIGURE 3. The effective power balance approximates a sawtooth function over time. We schematically depict the interplay between generation, demand and the resulting power imbalance: **(a)** While the demand curve is approximately smooth, the scheduled generation approximates the curve using step functions. **(b)** The resulting power balance is approximately a sawtooth function with jumps upwards and ramps downwards if the demand rises and ramps upwards and jumps downwards if the demand decreases. Here, we display all jumps with the same height for simplicity. In our model, we use different jump heights of the Heaviside and thereby also of the sawtooth function for hourly, half- or quarter-hourly jumps.

towards the nominal frequency. We use the simplest integral control, whereas other secondary control implementations [50], [52], [53], [54], [55], [56] might be considered in the future. Typically, the magnitude of the primary control parameter is much larger than the secondary control parameter $c_1 \gg c_2$ to implement that primary control acts faster than secondary control.

The power mismatch is given as ΔP . It contains only the deterministic mismatch between supply and demand. If generation surpasses consumption, ΔP becomes positive and vice versa. In our market model, we will employ a time-dependent ΔP , inspired by empirical power trajectories, see Fig. 3.

Finally, $\epsilon\xi$ denotes the aggregated noise acting on the system. As pointed out in the previous section, we assume ξ to be white Gaussian noise, i.e., its time average is zero $\langle \xi(t) \rangle = 0$ and its correlation is zero for non-identical times, i.e., it is a delta function $\langle \xi(t)\xi(t') \rangle = \delta(t-t')$ [33]. **Extensions using correlated or non-Gaussian noise are also possible in the same framework and can prove very useful if the noise function or its characteristics are known. From an *a priori* point-of-view, employing coloured noise would require an explicit knowledge of its presence in power-grid frequency systems and would complicate the parameter extraction.**

The model (1) is very general as we have not yet specified the parameters c_1 , c_2 , ϵ or the function ΔP . Note again the different roles of primary and secondary control: Assume $\Delta P = P_0 > 0$, this will increase the angular velocity ω and thereby the angle θ . Without secondary control and noise, i.e., $c_2 = \epsilon = 0$, the new quasi-steady state becomes $\omega^* \approx P_0/c_1 > 0$. The full fixed point $\omega = 0$ can only be restored with an additional (integrative) secondary control.

A. CASES

We consider some special cases of parameter choices for model (1) here. Theoretically, the model proposed so far would allow that the three parameters c_1 , c_2 , and ϵ are chosen as zero or non-zero constants, time-dependent functions, or to follow their own stochastic process. Similarly,

the power mismatch ΔP could be any function, as long as the differential equation is still well-defined. We review three cases, see also Fig. 4 for an overview.

The distinguishing factor between those cases is the role of secondary control c_2 and power imbalance ΔP : Any non-zero power imbalance ΔP will be compensated by secondary control if $c_2 > 0$. This means from a data-analysis it is virtually impossible to distinguish cases where $\Delta P = 0$ and no secondary control is active or $\Delta P \neq 0$ and secondary control restored the frequency or a case where a slowly changing ΔP restored the frequency on its own without secondary control active. Complementary, large and rapid changes in the power imbalance are clearly visible in the frequency trajectory and always have to be included in the models.

Case A: A simple starting point is to set c_1 , c_2 , and ϵ all as non-zero constants. By including an active secondary control, we neglect slow changes in the power imbalance ΔP and assume that secondary control is the main restoring force following a sudden jump. Specifically, we assume that the power mismatch ΔP is given as a piece-wise constant function, i.e., a Heaviside function. This model has the advantage that we can easily estimate all parameters from the trajectory.

Case B: Alternatively, we may neglect the effects of secondary control, setting $c_2 = 0$. To balance the frequency, we then require a balanced power dispatch on average, i.e., $\langle \Delta P \rangle = 0$. A simple function to realise this, while maintaining the jumps, which are visible from the frequency trajectories, is a sawtooth function, i.e., piecewise linearly increasing or decreasing over time. Similar to Case A, we still use constant non-zero c_1 and ϵ .

Case C: We again repeat Case A but instead of estimating the power mismatch ΔP from frequency trajectories, we use historic demand data of Germany, based on data published by ENTSO-E [57].

B. ESTIMATING PARAMETERS

To generate a synthetic trajectory approximating real data, we need to estimate suitable parameters for our model. Here,




FIGURE 4. We consider three different cases to model the power-grid frequency based on the model (1). In Case A, we apply constant primary and secondary control, white Gaussian noise with constant amplitude ϵ and a Heaviside power mismatch ΔP . In contrast, Case B uses no secondary control and applies a sawtooth function for the power mismatch ΔP . We still apply a constant primary control c_1 and white Gaussian noise with constant amplitude ϵ . Finally, Case C uses Case A's settings but we extract the jump heights of the Heaviside function from independent historic demand data [57] and not from the frequency trajectory. As in Fig. 3, we display all jumps with the same height for simplicity.

we present the mathematical background and basics that allow this parameter estimation as well as illustrations of the procedure in Figs. 5, 6 and 7. We provide additional guidance and code on how the estimators can be applied in practice in the Supplemental Material.

We estimate the parameters of the synthetic model as follows: The primary control c_1 and the noise ϵ are obtained from using the first and second Kramers–Moyal coefficient respectively. Next, the power mismatch ΔP and the secondary control c_2 are determined from the trajectory at the trading times.

1) Kramers–Moyal and Fokker–Planck

Let us briefly review some relevant stochastic theory necessary to estimate the parameters. The synthetic model (1) includes stochastic and deterministic dynamics. Assuming that the deterministic contribution given by ΔP and the secondary control c_2 are either very small or subtracted from the trajectory, we are left with a purely stochastic process for ω in the form of a Langevin equation. Such an equation cannot be solved deterministically but we may formulate the Fokker–Planck equation of the stochastic system instead [33]:

$$\frac{\partial p}{\partial t} = -\frac{\partial}{\partial \omega}(-c_1 \omega p) + \frac{\epsilon^2}{2} \frac{\partial^2 p}{\partial \omega^2} - \frac{\partial}{\partial \omega} \mathcal{D}^{(1)} p + \frac{\partial^2}{\partial \omega^2} \mathcal{D}^{(2)} p. \quad (2)$$

This Fokker–Planck equation is a partial differential equation for the probability density function $p(\omega, t)$ of the system. Solving this Fokker–Planck equation thereby returns the probability $p(\omega, t)$ to observe the system in state ω at time t , see e.g. [33] for an introduction to Fokker–Planck equations.

Terms subject to first derivatives are known as drift terms $\mathcal{D}^{(1)}$, while terms subject to second derivatives are called diffusion terms $\mathcal{D}^{(2)}$ [33]. Drift terms describe the deterministic behaviour of the full stochastic system, e.g. the movement of a particle within a potential or in our case the control and damping forces acting within the power grid, causes a “drift” towards the stable state. Complementary, the diffusion terms determine the stochastic part of the trajectory. Random noise makes state of the grid “diffuse” through the available state space and typically leads to a broadening of the probability distribution p [33]. We can read off the drift and the diffusion terms of the angular velocity ω as $\mathcal{D}^{(1)} = -c_1 \omega$ and $\mathcal{D}^{(2)} = \frac{\epsilon^2}{2}$ respectively. These drift and diffusion terms of the Fokker–Planck equation are also known as the Kramers–Moyal coefficients from the Kramers–Moyal expansion of the fundamental master equation of the system. Only this approximation allows us to write the Fokker–Planck equation [58], [59]. From these coefficients we estimate the mentioned parameters.

From a data-driven perspective, we can recover the drift $\mathcal{D}^{(1)}$ and diffusion $\mathcal{D}^{(2)}$ coefficients strictly from the data by employing a histogram regression or a Nadaraya–Watson kernel estimator. This approach is particularly useful when the fundamental equations of motion are not known but we also use it here to approximate the functional form of the Fokker–Planck equation and recover the primary control c_1 and noise amplitude ϵ , as given by (3) and , respectively. The drift and diffusion coefficients are the two lowest-order Kramers–Moyal coefficients. Further information on Fokker–Planck equations, Kramers–Moyal expansion, and stochastic modelling is available in [58], [33], [59].




FIGURE 5. The primary control c_1 is computed from fluctuations around the trend. To estimate the primary control c_1 , we first detrend the data by applying a Gaussian kernel and then compute the drift coefficient. (a): We display a snippet of the power-grid frequency trajectory from the CE data from January 2019, as in Fig. 1, alongside with the 60 seconds window Gaussian kernel detrending, that captures the deterministic and slowly changing contributions of the power-grid frequency. (b): We extract the stochastic motion by subtracting the deterministic trend from the power-grid frequency. What is left is a stochastic trajectory resembling approximately an Ornstein–Uhlenbeck process. (c): We compute the first Kramers–Moyal coefficient, known as the drift coefficient, of the now purely stochastic process. The slope of the drift coefficient is equal to the primary control $-c_1$.

2) Estimating the primary control c_1

Having set out the theory of Fokker–Planck equations and Kramers–Moyal coefficients, we now apply them to determine the primary control c_1 , by applying a two-step process: We first subtract the deterministic and slow time scale components from the trajectory and then determine the first Kramers–Moyal coefficient.

We first remove the driving deterministic characteristics of the model (1) from any trajectory we analyse. To do so, we filter the data with a Gaussian kernel filtering, with a window of 60 seconds, to remove the deterministic trend and any slow process, such as secondary control, and thus remain solely with the stochastic component of the process. **A window too small (e.g. 5 seconds) would still contain noise contributions, while a large window (e.g. 300 seconds) leads to an almost flat signal.** The procedure is independent of the specific driving method (cf. Case A and Case B).




FIGURE 6. The noise amplitude ϵ is obtained using the diffusion coefficient. We display the diffusion coefficient, or second Kramers–Moyal coefficient around 50 Hz for the CE grid for the month of January 2019. By taking the value at 50 Hz, indicated on the plot, and by using relation (4), we obtain the noise ϵ .

The detrending is illustrated in Fig. 5: The same snippet of data from Fig. 1 is shown alongside with the Gaussian kernel detrending. In panel (b) the subtraction of the detrending on the data yields the purely stochastic process governing the power-grid frequency dynamics without deterministic or slow time scale influences. Finally, we extract the first Kramers–Moyal coefficient in panel (c):

$$\mathcal{D}^{(1)}(\omega) = \frac{1}{\Delta t} \langle (\omega(t + \Delta t) - \omega(t)) |_{\omega(t)=\omega} \rangle = -c_1 \omega, \quad (3)$$

where Δt is the sampling rate of the process at hand, which is $\Delta t = 1$ s for our data sets. Furthermore, $\langle \dots |_{\omega(t)=\omega} \rangle$ denotes the following: A spatial average of the difference $(\omega(t + \Delta t) - \omega(t))$ is taken at the point of evaluation $\omega(t) = \omega$, i.e., at a particular frequency ω all differences $(\omega(t + \Delta t) - \omega(t))$ are evaluated and the diffusion $\mathcal{D}^{(1)}$ is obtained as a function of ω . Based on our modelling assumptions, we presume this function to be linear in ω . And, when we apply this to the real data in Fig. 5, we notice that the numerically extracted drift term is indeed well described as a linear function with slope $-c_1$.

3) Estimating the noise amplitude ϵ

The noise amplitude ϵ is unravelled from data by studying the second Kramers–Moyal coefficient. In our case, we obtain the second conditional moment as

$$\mathcal{D}^{(2)}(\omega) = \frac{1}{\Delta t} \langle (\omega(t + \Delta t) - \omega(t))^2 |_{\omega(t)=\omega} \rangle = \frac{\epsilon^2}{2}, \quad (4)$$

where Δt is again the sampling rate of the process and the empirical $\mathcal{D}^{(2)}(\omega)$ is assumed to approximately constant, based on our model. Computing the second conditional moment $\mathcal{D}^{(2)}$ thereby yields the noise amplitude ϵ . Empirically, we note that the de-trending is not even necessary to determine the correct diffusion coefficient. So we instead compute the diffusion from the original data directly.

We display the diffusion coefficient, i.e., the second Kramers–Moyal coefficient, as a function of the frequency in Fig. 6 for the month of January 2019 for the CE grid. We determine the diffusion coefficient value at 50 Hz and by using (4) thus determine the noise amplitude ϵ .




FIGURE 7. Power imbalance ΔP and secondary control c_2 are determined from trading peaks. We investigate the frequency trajectory at a trading peak: The power imbalance ΔP is obtained from the initial slope, i.e., the rate of change of frequency (ROCOF) and the secondary control c_2 from the following exponential decay, see (6). The frequency trajectory is using the CE data from January 10 2019.

4) Estimating the market impact ΔP

To determine both ΔP and c_2 , we have a closer look at the frequency behaviour following a sudden power imbalance. Assuming that the power imbalance is large enough, we can neglect the noise amplitude $\epsilon \approx 0$ as the dynamics close to the power jump are approximately deterministic. Before the power imbalance, we assume that the system is close to the nominal frequency, i.e., $\Delta P = 0$, $\theta \approx 0$ and $\omega \approx 0$. Next, we introduce a power imbalance, e.g. due to trading by setting $\Delta P = P_0$. The equations of motion then are

$$\begin{aligned} \frac{d\theta}{dt} &= \omega, \\ \frac{d\omega}{dt} &= -c_1\omega - c_2\theta + P_0. \end{aligned} \quad (5)$$

A full solution of this driven, damped harmonic oscillator is given by

$$\omega(t) = \frac{P_0 e^{-\frac{1}{2}t(\sqrt{c_1^2 - 4c_2} + c_1)}}{\sqrt{c_1^2 - 4c_2}} \left[e^{t\sqrt{c_1^2 - 4c_2}} - 1 \right]. \quad (6)$$

We evaluate the rate of change of frequency (ROCOF) at the jump time, i.e., at $t = 0$ to be

$$\left. \frac{d\omega}{dt} \right|_{t=0} = P_0, \quad (7)$$

and thereby determine the jump height P_0 , which gives us the power imbalance ΔP , again assuming $\theta(0) = \omega(0) \approx 0$. Recall that we rescaled all variables with the inertia M so that the ROCOF depends on the change of power and the inertia as expected.

Note, while the solution (6) explicitly used the Heaviside function with secondary control (Case A), the ROCOF also determines the power jump in the case of a sawtooth function (Case B). The reason is that the derivative at $t = 0$ is independent of what happens for $t > 0$ and also does not depend on c_1 or c_2 .

5) Estimating the secondary control c_2

The estimation of c_2 is only necessary for models that include it, such as Case A with its simple Heaviside function.

We know how the trajectory of the angular velocity ω , given by (6), develops following a jump: Initially, the value of ω increases and then decays approximately exponentially back to the reference value.

Since the primary control parameter c_1 is typically much larger than the secondary control parameter c_2 , we make use of the following approximation: $\sqrt{c_1^2 - 4c_2} \approx c_1 - \frac{2c_2}{c_1}$. Thus (6) reduces to

$$\omega(t) = \frac{P_0 e^{-t\frac{c_2}{c_1}}}{c_1 - \frac{2c_2}{c_1}} \left[1 - e^{-t\left(c_1 - \frac{2c_2}{c_1}\right)} \right]. \quad (8)$$

For larger times $t \gg 1s$, the second term in (8) decays much faster than the first term. We can therefore further approximate the angular velocity ω as

$$\omega(t) \sim \exp\left(-\frac{c_2}{c_1}t\right), \quad (9)$$

which allows an estimate of the secondary control c_2 , taken we determined the primary control c_1 earlier. We only need to determine the exponent of the exponential decay, as depicted in Fig. 7. Note that the exponential decay constant does not depend on which trading interval we analyse. For more robust analysis, we perform the fits using the decay following hourly jumps, see also Supplemental Material.

This sequence of parameter estimations allows us to uncover all underlying parameters of the system directly from power-grid frequency measurements. In fact, a single measurement of 60 minutes of data already entails a good ground for estimation but naturally employing as much data as possible yields more reliable parameter estimations, as well as the possibility of error estimation in an efficient way.

IV. CASE STUDY: CONTINENTAL EUROPEAN GRID

With the model properly defined, we now show how it approximates the stochastic behaviour of real frequency trajectories in Europe. The frequency statistics and also market setting differ substantially between different power grids [23]. So, instead of applying each case to all potential power grids, we showcase it on one power grid example where the statistics are well approximated.

Hence, we first apply Case A to data from Continental Europe, Case B to data from Great Britain and finally show that we can also import and utilize real dispatch data to further improve the model predictions in Case C.

A. CASE A: PARAMETER EXTRACTION FOR JANUARY 2019, CENTRAL EUROPE

We analyse power-grid frequency data for the month of January 2019, using measurements provided by the transmission system operator TransnetBW GmbH who operates the German grid in the state Baden-Württemberg [30]. For this month, we estimate the following parameters:




FIGURE 8. Case A: Heaviside dispatch approximates CE trajectories. We compare two days of the power-grid frequency of the Central European (CE) power grid in January 2019 with synthetic data generated by our model (1). For this particular analysis, we utilise Case A that relies on a step function mimicking the jumps of the power mismatch ΔP . The four governing parameters: Noise ϵ , primary c_1 and secondary c_2 control, and power mismatch ΔP parameters are given in Section IV-A, further details are given in the Supplemental Material. **(a)** We plot a snippet of the power-grid frequency trajectory from the CE data, the model, and the surrogate model without power dispatch. The 15 minute trading intrinsic to the model and the data is highlighted with grey lines. **(b)** We display the probability density function of the CE data (histogram), the model data (solid line), and the surrogate model data without dispatch (dashed line). Standard deviation and kurtosis of each process are indicated in the legend. **(c)** We display the autocorrelation of the processes for a time window of 75 minutes, noting the initial exponential decay and regular peaks.

Central Europe, January, 2019.

ϵ [s^{-2}]	c_1 [s^{-1}]	c_2 [s^{-2}]
0.00105	0.008311	0.000030

For simplicity, we considered the dispatch at the hourly mark as the reference, as can be seen in Fig. 1 to be the strongest driver of the system.

Case A: CE P_0 , January, 2019

	at :00	at :30	at :15, :45
P_0 [s^{-2}]	0.001641	0.000547	0.000273

Extracting the value, as described, of the ΔP for the hourly mark, we considered the half-hour and quarter-hour trading windows to be $1/3$ and $1/6$ of the hourly value of ΔP . Notice that there is no limitation in calculating this

from data but the results can prove unreliable given the small differences in dispatch. Furthermore, to mimic the structure of the dispatch [24], we take a naïve 6-hour window where the P_0 jumps are positive values, followed by an equivalent 6-hour window with negative peaks. This should approximate the daily cycles of human daily activity: The work schedule begins: demand increases; Work schedule ends: demand decreases; Private consumption at home begins: demand increases; Night time begins, demand decreases.

Having these parameters at hand, we can now employ our model (1) to integrate synthetic power-grid frequency trajectories. We employ an Euler–Mayurama stochastic integrator, with a time sampling of 0.001 seconds, for a total length of two days, and make use on a step function with changing values every 15 minutes, as formulated in Case A, to mimic the power dispatch curve.

We compare the data, the synthetic model based on (1) and surrogate model without the market structure, i.e., where we set $\Delta P = 0$, in Fig. 8. The introduction of the model without the market allows us to understand concisely the influence of the dispatch on the trajectory of the power-grid frequency, as well as the influence it has on the statistical behaviour of the system.

Several distinct features of the market effect can be seen in Fig. 8: While the surrogate only fluctuates randomly close to the reference frequency, both the real and the synthetic trajectory display surges of the frequency close to the 15 minute trading windows, see panel (a). These large surges lead to a non-Gaussian probability distribution of the power-grid frequency, evidenced in panel (b). Both the data and the synthetic model with the market display a high kurtosis ($\kappa > 3$), while the surrogate model without any market is essentially Gaussian. This indicates that the market activity has a considerable impact on the distribution of the frequency, specifically its tails. With the market, the system reaches critical values much more often than what would be expected by a normally distributed process. We finally compare the autocorrelation functions of the power-grid frequency for the CE data of January 2019, the modelled data, and the surrogate model in panel (c). We note that the system’s scheduled trading/dispatch windows generate defined peaks at exactly 15, 30, 45, and 60 minutes. By comparison, a surrogate system without a market structure displays no correlation peaks at any time lag. Moreover, it is importance to notice that *all* peaks in the autocorrelation function are positive valued, both for the synthetic and the real data. This indicates that the system’s dispatch is not an uncorrelated random process but the direction of the frequency change is correlated: Frequency surges are more likely followed by more frequency surges and vice versa for frequency sags. The modelled data mimics this with accuracy by implementing an over-simplistic yet successful heuristic argument based on human daily cycles, as explained before.




FIGURE 9. Case B: Sawtooth dispatch approximates GB trajectories. We compare two days of the power-grid frequency of the British (GB) power grid in January 2019 with synthetic data generated by our model (1). Here, a sawtooth function is used to describe the mismatch in power ΔP , see Fig. 4, Case B. Noise amplitude ϵ , primary c_1 control, and power mismatch ΔP are given in Section IV-B, see also Supplemental Material for details on parameter estimation. Note that Case B does not use secondary control. (a) We plot snippet of the power-grid frequency trajectory from the GB data, the model, and the surrogate model without power dispatch. (b) We display the probability density function of the GB data (histogram), the model data (solid line), and the surrogate model data without dispatch (dashed line). Standard deviation and kurtosis of each process are indicated in the legend. (c) We display the autocorrelation of the processes for a time window of 75 minutes, noting the initial exponential decay and regular peaks. Contrary to the Heaviside function of Case A, the sawtooth function forces a negative correlation of the system by first driving the system driven to one state and then inverting this trend at the trading interval.

B. CASE B: PARAMETER EXTRACTION FOR JANUARY 2019, GREAT BRITAIN

Analogously, we analyse data from Great Britain for the month of January 2019, obtained from the British transmission system operator National Grid ESO [60]. Applying the discussed methods, we derive the following parameters

Great Britain, January, 2019			
ϵ [s^{-2}]	ΔP [s^{-2}]	c_1 [s^{-1}]	c_2 [s^{-2}]
0.00205	0.00204	0.00606	#

where in this case we set the value of the secondary control c_2 to be zero. Here, we apply Case B, for two reasons: First, we wish to show that it is also capable of capturing the

frequency distributions of a given grid. Second, the British frequency trajectory does not display any clear exponential decay following the trading activity. This is likely caused by a smaller relative trading volume and a larger relative noise amplitude [23]. Both effects also contribute to much smaller autocorrelation peaks at the trading intervals.

We recover the statistics of the British power-grid frequency data with remarkable precision using a sawtooth function for the power dispatch ΔP , see Fig. 9. The GB data exhibits low kurtosis values ($\kappa < 3$), especially when compared to the Continental European values. Our employed model captures the process with high accuracy, when we apply a sawtooth function for ΔP (Case B). Notably, for the case of the surrogate model without market activity, the probability distribution again approximates a Gaussian distribution with kurtosis $\kappa = 3$. Although the autocorrelation function exacerbates the peaks, it captures the initial decay and the trend of regular peaks well. The oversized oscillations arise since we assumed consistent periods of six hours with the same jump and ramp behaviour. In turn, the negative autocorrelation arises as the sawtooth function suddenly changes the sign of the market effect. Both assumptions are part of a very simple but thereby easy-to-use model of the British grid, which still captures the probability distribution (histogram) very well.

C. CASE C: USING REAL POWER DISPATCH FOR CONTINENTAL EUROPE

Finally, we use real dispatch data from Germany, provided by ENTSO-E [57], to determine the power mismatch ΔP in our model (1) and compare synthetic and real trajectories in Fig. 10. To this end, we simply set the power mismatch ΔP as a Heaviside function based on the real demand for the German grid, i.e., we use the actual demand and assume it stays constant for a given 15 minute interval. While the autocorrelation and the rough shape of the histogram of the model data closely match those of the real data set, we note a substantial difference in the computed kurtosis values. This discrepancy is likely caused by the large variations in the volume of the dispatched power. Here we use data from the German grid to allow a 15 minute resolution. However, the full power dispatch affecting the Continental European grid is given as the sum over all participating countries and would likely be smoother and lead to lower kurtosis values. As noted before, we only require the jump height in ΔP , here as the demand, while the generation enters as the simplified secondary control term $-c_2\theta$. We chose the German data because its time resolution of ΔP is 15 minutes, compared to 1 hour resolution for many other countries. Using such real demand data breaks the symmetrical and regular six hour patterns we have been using so far in Cases A and B. Thereby, we also include larger time scales in the synthetic frequency data since the real demand naturally includes for example daily and weekly cycles. Aside from ΔP , we use the same values as in Case A for the other parameters, i.e., noise ϵ , primary and secondary




FIGURE 10. Case C: Realistic dispatch trajectories better approximate the real frequency statistics. (a) We use the real dispatch trajectories of the demand in Germany [57] to obtain the correct jumps for the Heaviside function (as in Case A) of the power mismatch ΔP and use our model (1) to generate a synthetic trajectory. (b) The synthetic frequency trajectory statistically resembles the real trajectory for the two day period depicted here. Noise amplitude ϵ , primary c_1 and secondary c_2 control were calculated as described in the Supplemental Material. (c) We display the probability density function of the CE data (histogram), the model data (solid line), and the surrogate model data without dispatch (dashed line). Standard deviation and kurtosis of each process are indicated in the legend. (d) We display the autocorrelation of the processes for a time window of 75 minutes, noting the initial exponential decay and regular peaks.

control c_1 and c_2 . Comparing the synthetic trajectory and derived measures with the real frequency trajectory, we note that including the real demand data improves the approximation further, see Fig. 10. For example the probability density of the real frequency is even better approximated by the synthetic data than in Case A.

V. DISCUSSION

We set out to devise a model to generate realistic synthetic trajectories of the power-grid frequency to be used in simulations of power and control system dynamics and to assist planning and operation of today's and future power grids. To that end, we first showed that the frequency trajectories show both deterministic and stochastic features, leading to non-standard frequency statistics: Heavy tails in the probability distributions and regular autocorrelation peaks pose challenges to properly model the trajectories.

We proposed a simple model combining the deterministic and stochastic aspects of the trajectories. Using stochastic theory and data analysis we were able to extract all essential parameters of the model from real trajectories. We specifically highlighted how the model approximates probability distributions and autocorrelation functions of realistic grids. A more detailed analysis of the mathematical properties of both real trajectories and the model is presented in [32].

The presented model was designed to be generally applicable, easily extendible and usable, which inevitably requires several simplifications: It does not capture the very short time scale when short-term noise, dynamical behaviour of the rotation machines or switching delays play

an important role. Similarly, the model does also not include the long time scale with effects such as synoptic or even seasonal cycles, long-term trading commitment etc. Finally, the model is a stochastic model, i.e., it is not suitable for forecasting of the near future but instead it reproduces critical statistical properties such as large frequency deviations. Conceptually, our modelling approach bridges power engineering, stochastic modelling and data analysis. Power engineering serves as the inspiration to our model building blocks like primary and secondary control. The universality of stochastic modelling is used in formulating the Fokker-Planck equation and deriving both the diffusion coefficient and primary control. Finally, more data analysis tools are necessary to estimate remaining parameters such as the secondary control or the strength of the dispatch or market actions.

Critically, we unveiled how much the market activity influences the tails of the probability distribution, i.e., the probability to observe large deviations from the reference. Comparing models with and without market revealed that just by including the market activity most large events can be explained, consistent with earlier findings [43], [31]. This emphasizes the role the market design has on the stability of the power grid.

The explicit modelling of the market in the stochastic model is specifically interesting when designing new market rules or introducing new business models. As we have seen, the market has a dramatic influence on the stability-defining large deviations. Our model can easily predict the effects on the frequency when shifting from 15-minute to 5-minute

dispatch actions or when introducing real-time pricing. New proposals of smart grids, the impact of demand-side management etc. can all be captured by appropriately modifying the power dispatch ΔP of our model. Thereby, we provide guidelines how new concepts and devices can be introduced in the grid without destabilizing it but ideally providing additional stability.

Concluding, our research offers a tool that can be used by natural scientists, mathematicians, engineers, economists or industry practitioners on various questions related to the electricity system. It can be used to plan future grids, such as setting up smart grids and microgrids by providing guidelines on how control parameters should be set to guarantee a certain frequency quality. Executable computer code and easy-to-read pseudo-code of the model and the parameter estimation are provided in the supplementary material.

The model presented here can easily be extended in multiple directions: We could apply more advanced stochastic measures to compare the synthetic trajectory with the real trajectory, as partially done in [32]. Simultaneously, the frequency dynamics considered here could be extended by voltage amplitude dynamics. **While we included primary and secondary control, additional work is necessary if tertiary control should be part of the model.** Furthermore, while we only considered constant Gaussian noise, this noise could easily be extended: Either by including explicit non-Gaussian noise [23], as it is observed from wind and solar generators [9] or by making the noise or the control time-dependent, leading to superstatistical modelling [46]. **Finally, the proposed model and possible extensions should be systematically compared to alternative power grid frequency forecast methods and their performance versus historic data.**

REFERENCES

- [1] Sawin, J. L. et al. Renewables 2018-global status report (2018).
- [2] Rodríguez-Molina, J., Martínez-Núñez, M., Martínez, J.-F. & Pérez-Aguiar, W. Business models in the smart grid: Challenges, opportunities and proposals for prosumer profitability. *Energies* **7**, 6142–6171 (2014).
- [3] Schultz, S. Deutsche Netzbetreiber kämpfen mit akuter Stromnot. SPIEGEL ONLINE <https://www.spiegel.de/wirtschaft/unternehmen/stromnetz-deutsche-netzbetreiber-kaempfen-mit-akuter-stromnot-a-1275323.html> (2019).
- [4] Company, M. . Energiewende-Index. McKinsey & Company <https://www.mckinsey.de/branchen/chemie-energie-rohstoffe/energiewende-index> (2020).
- [5] Panwar, N., Kaushik, S. & Kothari, S. Role of renewable energy sources in environmental protection: A review. *Renewable and Sustainable Energy Reviews* **15**, 1513–1524 (2011).
- [6] Tuballa, M. L. & Abundo, M. L. A review of the development of smart grid technologies. *Renewable and Sustainable Energy Reviews* **59**, 710–725 (2016).
- [7] Obama, B. H. Presidential policy directive 21: Critical infrastructure security and resilience. Washington, DC (2013).
- [8] Kundur, P., Balu, N. J. & Lauby, M. G. Power system stability and control, vol. 7 (McGraw-hill, New York, 1994).
- [9] Anvari, M. et al. Short term fluctuations of wind and solar power systems. *New Journal of Physics* **18**, 063027 (2016).
- [10] Wolff, M. F. et al. Heterogeneities in electricity grids strongly enhance non-gaussian features of frequency fluctuations under stochastic power input. arXiv preprint arXiv:1908.07997 (2019).
- [11] Rohden, M., Sorge, A., Timme, M. & Witthaut, D. Self-organized Synchronization in Decentralized Power Grids. *Physical Review Letters* **109**, 064101 (2012).
- [12] Walter, T. Smart Grid neu gedacht: Ein Lösungsvorschlag zur Diskussion in VDEIETG (2014). URL <http://www.vde.com/de/fg/ETG/Pbl/MI/2014-01/Seiten/Homepage.aspx>.
- [13] Schäfer, B., Matthiae, M., Timme, M. & Witthaut, D. Decentral Smart Grid Control. *New Journal of Physics* **17**, 015002 (2015).
- [14] Fang, X., Misra, S., Xue, G. & Yang, D. Smart Grids - The new and improved Power Grid: A Survey. *Communications Surveys & Tutorials, IEEE* **14**, 944–980 (2012).
- [15] Weber, J. et al. Wind power persistence is governed by superstatistic. arXiv preprint arXiv:1810.06391 (2018).
- [16] Filatrella, G., Nielsen, A. H. & Pedersen, N. F. Analysis of a Power Grid using a Kuramoto-like Model. *The European Physical Journal B* **61**, 485–491 (2008).
- [17] Nishikawa, T. & Motter, A. E. Comparative analysis of existing models for power-grid synchronization. *New Journal of Physics* **17**, 015012 (2015).
- [18] Schmietendorf, K., Peinke, J. & Kamps, O. The impact of turbulent renewable energy production on power grid stability and quality. *The European Physical Journal B* **90**, 222 (2017).
- [19] Böttcher, P. C., Otto, A., Kettemann, S. & Agert, C. Time delay effects in the control of synchronous electricity grids. arXiv preprint arXiv:1907.13370 (2019).
- [20] Haehne, H., Schottler, J., Waechter, M., Peinke, J. & Kamps, O. The footprint of atmospheric turbulence in power grid frequency measurements. *Europhysics Letters* **121**, 30001 (2018).
- [21] Zhang, H. & Li, P. Probabilistic analysis for optimal power flow under uncertainty. *IET Generation, Transmission & Distribution* **4**, 553–561 (2010).
- [22] Schäfer, B. et al. Escape routes, weak links, and desynchronization in fluctuation-driven networks. *Physical Review E* **95**, 060203 (2017).
- [23] Schäfer, B., Beck, C., Aihara, K., Witthaut, D. & Timme, M. Non-gaussian power grid frequency fluctuations characterized by lévy-stable laws and superstatistics. *Nature Energy* **3** (2018).
- [24] Weißbach, T. & Welfonder, E. High frequency deviations within the european power system: Origins and proposals for improvement. In *Power Systems Conference and Exposition, 2009. PSCE'09. IEEE/PES, 1–6* (IEEE, 2009).
- [25] Scoltock, J., Geyer, T. & Madawala, U. K. Model predictive direct power control for grid-connected npc converters. *IEEE Transactions on industrial Electronics* **62**, 5319–5328 (2015).
- [26] Dong, D. et al. Frequency behavior and its stability of grid-interface converter in distributed generation systems. In *2012 Twenty-Seventh Annual IEEE Applied Power Electronics Conference and Exposition (APEC), 1887–1893* (IEEE, 2012).
- [27] Tso, G. K. & Yau, K. K. Predicting electricity energy consumption: A comparison of regression analysis, decision tree and neural networks. *Energy* **32**, 1761–1768 (2007).
- [28] Sharma, N., Sharma, P., Irwin, D. & Shenoy, P. Predicting solar generation from weather forecasts using machine learning. In *2011 IEEE international conference on smart grid communications (SmartGridComm)*, 528–533 (IEEE, 2011).
- [29] Tchuisseu, E. T., Gomila, D., Brunner, D. & Colet, P. Effects of dynamic-demand-control appliances on the power grid frequency. *Physical Review E* **96**, 022302 (2017).
- [30] TransnetBW GmbH. Regelenergie Bedarf + Abruf (2019). URL <https://www.transnetbw.de/de/strommarkt/systemdienstleistungen/regelenergie-bedarf-und-abruf>.
- [31] Schäfer, B., Timme, M. & Witthaut, D. Isolating the impact of trading on grid frequency fluctuations. In *2018 IEEE PES Innovative Smart Grid Technologies Conference Europe (ISGT-Europe)*, 1–5 (IEEE, 2018).
- [32] Anvari, M. et al. Stochastic properties of the frequency dynamics in real and synthetic power grids. arXiv preprint arXiv:1909.09110 (2019).
- [33] Gardiner, C. W. *Handbook of Stochastic Methods: for Physics, Chemistry and the Natural Sciences* (Springer, 1985).
- [34] Machowski, J., Bialek, J. & Bumby, J. *Power System Dynamics: Stability and Control* (John Wiley & Sons, Chichester, 2011).
- [35] Oudalov, A., Chartouni, D. & Ohler, C. Optimizing a battery energy storage system for primary frequency control. *IEEE Transactions on Power Systems* **22**, 1259–1266 (2007).
- [36] Wood, A. J. & Wollenberg, B. F. *Power generation, operation, and control* (John Wiley & Sons, 2012).

- [37] Milano, F., Dörfler, F., Hug, G., Hill, D. J. & Verbič, G. Foundations and challenges of low-inertia systems. In 2018 Power Systems Computation Conference (PSCC), 1–25 (IEEE, 2018).
- [38] Beck, H.-P. & Hesse, R. Virtual synchronous machine. In Electrical Power Quality and Utilisation, 2007. EPQU 2007. 9th International Conference on, 1–6 (IEEE, 2007).
- [39] Kundur, P. et al. Definition and classification of power system stability ieee/cigre joint task force on stability terms and definitions. *IEEE Transactions on Power Systems* **19**, 1387–1401 (2004).
- [40] Palensky, P. & Dietrich, D. Demand Side Management: Demand Response, Intelligent Energy Systems, and Smart Loads. *IEEE Transactions on Industrial Informatics* **7**, 381–388 (2011).
- [41] Kovacevic, R. M., Pflug, G. C. & Vespucci, M. T. Handbook of risk management in energy production and trading (Springer, 2013).
- [42] National Academies of Sciences Engineering and Medicine. The Power of Change: Innovation for Development and Deployment of Increasingly Clean Electric Power Technologies (The National Academies Press, Washington, DC, 2016).
- [43] Weißbach, T. & Welfonder, E. High frequency deviations within the european power system—origins and proposals for improvement. *VGB powertech* **89**, 26 (2009).
- [44] González-Romera, E., Jaramillo-Morán, M. Á. & Carmona-Fernández, D. Forecasting of the electric energy demand trend and monthly fluctuation with neural networks. *Computers & Industrial Engineering* **52**, 336–343 (2007).
- [45] Milan, P., Wächter, M. & Peinke, J. Turbulent Character of Wind Energy. *Physical Review Letters* **110**, 138701 (2013).
- [46] Beck, C. & Cohen, E. G. D. Superstatistics. *Physica A* **322**, 267–275 (2003).
- [47] Milan, P., Wächter, M. & Peinke, J. Stochastic modeling and performance monitoring of wind farm power production. *Journal of Renewable and Sustainable Energy* **6**, 033119 (2014).
- [48] Beck, C., Cohen, E. G. D. & Swinney, H. L. From time series to superstatistics. *Physical Review E* **72**, 056133 (2005).
- [49] Ulbig, A., Borsche, T. S. & Andersson, G. Impact of low rotational inertia on power system stability and operation. *IFAC Proceedings Volumes* **47**, 7290–7297 (2014).
- [50] Weitenberg, E. et al. Robust decentralized secondary frequency control in power systems: Merits and trade-offs. arXiv preprint arXiv:1711.07332 (2017).
- [51] Tchuisseu, E. B. T. et al. Curing braess' paradox by secondary control in power grids. *New Journal of Physics* **20**, 083005 (2018).
- [52] Wang, C., Grebogi, C. & Baptista, M. S. Control and prediction for blackouts caused by frequency collapse in smart grids. *Chaos: An Interdisciplinary Journal of Nonlinear Science* **26**, 093119 (2016).
- [53] Simpson-Porco, J. W., Dörfler, F. & Bullo, F. Droop-controlled inverters are kuramoto oscillators. *IFAC Proceedings Volumes* **45**, 264–269 (2012).
- [54] Hammid, A. T., Hojabri, M., Sulaiman, M. H., Abdalla, A. N. & Kadhim, A. A. Load frequency control for hydropower plants using pid controller. *Journal of Telecommunication, Electronic and Computer Engineering (JTEC)* **8**, 47–51 (2016).
- [55] Dongmo, E. D., Colet, P. & Wofo, P. Power grid enhanced resilience using proportional and derivative control with delayed feedback. *The European Physical Journal B* **90**, 6 (2017).
- [56] Martyr, R., Schäfer, B., Beck, C. & Latora, V. Benchmarking the performance of controllers for power grid transient stability. *Sustainable Energy, Grids and Networks* **18**, 100215 (2019).
- [57] ENTSO-E. Generation Forecast - Day ahead. ENTSO-E <https://transparency.entsoe.eu/generation/r2/dayAheadAggregatedGeneration/show> (2019).
- [58] Risken, H. The Fokker-Planck Equation (Springer, Berlin, 1984).
- [59] Friedrich, R., Peinke, J., Sahimi, M. & Tabar, M. R. R. Approaching complexity by stochastic methods: From biological systems to turbulence. *Physics Reports* **506**, 87–162 (2011).
- [60] National Grid ESO. Historic frequency data (2019). URL <https://www.nationalgrideso.com/balancing-services/frequency-response-services/historic-frequency-data>.
- [61] Gorjão, L. R. & Meirinhos, F. kramersmoyal: Kramers–Moyal coefficients for stochastic processes. *Journal of Open Source Software* **4** (2019).
- [62] Rinn, P., Lind, P. G., Wächter, M. & Peinke, J. The Langevin approach: An R package for modeling markov processes. *Journal of Open Research Software* **4**, e34 (2016).

VI. SUPPLEMENTAL MATERIAL

A. PARAMETER EXTRACTION GUIDELINES

Following the mathematical foundations presented in the main text, we present hands-on instructions on how to extract the parameters for the example of a month-long recording of the power-grid frequency in Germany for the month of January 2019. As we focus mainly on specific characteristics of the power dynamics, we calculate, strictly from the data, the noise amplitude ϵ , the power mismatch at the hourly stamp ΔP , the primary and secondary control amplitudes c_1 and c_2 . The procedure follows in a simple manner:

- Noise amplitude ϵ : Utilise the second Kramers–Moyal coefficient, i.e., the diffusion, to extract the noise strength ϵ from the timeseries of the data. Use relation (4) to obtain the value, by taking either the value of the diffusion at $f = 50$ Hz or averaging in windows around $f = 50$ Hz.
- Power mismatch ΔP (for the hourly jumps): Take the first 10 seconds of data just after the hour, e.g. from 12:00:00 to 12:00:10. Calculate the slope of the frequency increase or decrease in this window with a linear fit. Given that the process displays jumps up and down, i.e., excess and lack of power supply, take the absolute value to obtain the general power mismatch ΔP . Average to obtain the average effect.
- Primary control c_1 : This is a two-step process: Perform a Gaussian kernel de-trending of the data, with a 60-seconds window, to remove the effects of the market and dispatch, so to capture the system's stochastic nature. The choice of a 60-second window ensures one removes only the deterministic characteristics of the frequency trajectory: a smaller window will mimic the noise, a larger window will reflect the overall mean of 50 Hz (60 Hz) of the process. Utilise now the first Kramers–Moyal coefficient, i.e., the drift term, to obtain a negatively tilted line: linearly fit the line around $f = 50$ Hz (or 60 Hz) and extract the slope, which is the drift coefficient of the governing Ornstein–Uhlenbeck process. The slope is the negative primary control $-c_1$.
- Secondary control c_2 : This is the last parameter to calculate, and it depends on the primary control c_1 . Take 900 seconds windows at every hourly jump, similarly to the above calculations for the power mismatch ΔP . Fit (8) to the data snippets (or (6), although strictly mathematically correct, it is harder to fit). Obtain the exponential decay made explicit in (9), i.e., the last term of (8). Input the previously obtained value for the primary control c_1 (step above) to determine the secondary control c_2 .

Having concluded these four steps, we possess all the necessary variables to numerically integrate a synthetic version of the evaluated power-grid frequency.

The simplest and most straightforward method is to implement an Euler–Mayurama integration scheme. This is

a scheme identical to a regular Euler integration scheme, incorporating a noise function ξ . This is done by generating a set of normally distributed values with mean $\mu = 0$ and variance $\sigma = \sqrt{\tau}$, with τ the employed time-step of integration. Stochastic integration requires small time-steps, thus we suggest using at least 0.01 seconds, or better even 0.001 seconds. From this store only the 1 second recording to accurately compare with available real power-grid data (if your temporal resolution is different, match it). Other more integrators, such as Runge–Kutta integrators for stochastic equations, can be used to ensure higher precision of the numerical results.

To extract the Kramers–Moyal coefficients there are open source Python ('Python KM') or R ('Langevin') packages, see [61] and [62], respectively.

VII. PSEUDO-CODE

Pseudo-code for extracting the parameters from data, based on the methodology implemented for the Central European power grid. As Supplemental Material, a minimal `python` code is attached. This was the code used for obtaining the parameters from the data.

In the following we compartmentalise the code in four sections, each corresponding to the parameter recovery of each of the four parameters under analysis: Noise ϵ , primary control c_1 , secondary control c_2 , and dispatch ΔP

For all cases below, the first step is naturally to import the data

Import data

- Load data

IF data is recorded at 50 hz: `data = data - 50`

Retrieving the Noise ϵ

- Load module `km` to obtain Kramers–Moyal coefficients
- `diffusion, space = km(data, coefficient = 2)`
- `find f=0 in space`
- $\epsilon = \sqrt{\text{diffusion}(\text{space} = 0) \times 2}$

Retrieving the primary control c_1

- Load module `km` to obtain Kramers–Moyal coefficients
- Load module `filter` to obtain the Gaussian kernel filtering
- `data_filtered = data - filter(data)`
- `drift, space = km(data_filtered, coefficient = 1)`
- `find f=0 in space`
- `fit line to drift around space = 0`
- $c_1 = -\text{slope of fit}$

Retrieving the dispatch ΔP

FOR every hour:

- fit line to data[first 10 secs]
- save slope to record
- Take absolute of record
- $\Delta P = \text{mean}(\text{abs}(\text{record}))$

Retrieving the secondary control c_2

FOR every hour

- fit curve of (8) to data[900 seconds]
- save exp. decay to record
- $c_2 = \text{mean}(\text{record}) \times c_1$

It is advisable to discard the statistical outliers, since fitting an exponential decay to the frequency data is especially unreliable if the dispatch difference is very small for that period.

VIII. PYTHON MINIMAL-WORKING CODE

Listing 1. Load libraries and data

```

1 # Set of required python libraries
2 import numpy as np
3 from scipy.optimize import curve_fit
4
5 # Library for the gaussian kernel filter
6 from scipy.ndimage.filters import gaussian_filter1d
7
8 # Library for calculating Kramers—Moyal
  coefficients
9 from kramersmoyal import km
10
11
12 # Preliminaries
13 # Allocate the power-grid frequency data to
  a numpy array. Make sure the first
14 # entry corresponds to the zero second of
  an hour period, e.g. data[0] is the
15 # start of the data at some HH:00:00
16
17 data = np.loadtxt('location/of/data.txt')
18
19 # if the data is recorded at a reference (e
  .g. 50 Hz), remove the reference
20 data = data - 50.0

```

Listing 2. Noise ϵ

```

1 # Noise epsilon
2 # In order to calculate the noise epsilon
  you need to extract the diffusion term
3 # of the stochastic processes. Employ the
  km function from the kramersmoyal
4 # library
5
6 # Retrieve the diffusion coefficient
7 diffusion, space = km(data, powers = [0,
  2], bins = np.array([6000]), bw = 0.05)
8
9 # find the zero frequency
10 zero_frequency = np.argmin(space[0]**2)
11
12 # evaluate the diffusion at that point and
  extract epsilon
13 epsilon = np.sqrt(diffusion[1,
  zero_frequency]*2)

```

Listing 3. Primary control c_1

```

1 # Primary control c_1
2 # To calculate the primary control c_1 we
  need to emply a two step process.
3 # First remove the general trend by a
  gaussian kernel filtering, then employ
4 # again the km function from the
  kramersmoyal librayr to obtain the
  drift term
5
6 data_filter = gaussian_filter1d(data, sigma
  = 60)
7
8 # Obtain the drift coefficient
9 drift, space = km(data-data_filter, powers
  = [0, 1], bins = np.array([6000]), bw =
  0.01)
10
11 # find the zero frequency
12 mid_point = np.argmin(space[0]**2)
13
14 # Calculate the slope of the drift term,
  which gives the primary control c_1.
15 # The fitting is to a line of intercept a
  and slope b. T
16 c_1 = curve_fit(lambda t,a,b: a - b*t,
  space[0][mid_point - 500:mid_point +
  500],
17                 drift[1,mid_point - 500:mid_point +
  500], p0=(0.0002, 0.005),
18                 maxfev=10000
19                 )[0][1]

```

Listing 4. ΔP

```

1 # Delta P / RoCoF
2 # To calculate the dispatch Delta P
  evaluate the process at every hourly
  jump.
3 # If there is a different dispatch seems,
  change the evaluation to that period.
4 # In principle this can be calculated for
  any interval of power dispatch but
5 # to ensure a good fit, bigger jumps =
  bigger dispatch = better fit
6
7 # Define window of jumps. In this case,
  evaluate the Delta P every hour
8 window = 3600 # 3600 seconds = 1 hour
9
10 # Set the total length to evaluate
11 data_range = data.size // window
12
13 # Initialise an array to record the Delta P
14 Delta_P_slopes = np.zeros(data_range)
15
16 # The jumps are to be evaluate at t=0 but
  since we have noise data, we fit the
17 # first 10 seconds to calculate the slope
18 for j in range(data_range):
19     Delta_P_slopes[j] = curve_fit(lambda t,
    a,b: a + b*t, np.linspace(0,9,10),
20     data[3600*(j)
    :3600*(j)+10],
    p0=(0.0, 0.0),
21     maxfev=10000
22     )[0][1]
23 # This results is an array with positive
  and negative slopes, since some
24 # frequency changes are positive (excess
  energy), some are negative. Find the
25 # absolute value for them and take the
  average as the reference Delta P.
26
27 # This is the mean Delta P
28 Delta_P = np.mean(np.abs(Delta_P_slopes))

```

Listing 5. Secondary control c_2

```

1 # Secondary control c_2
2 # To calculate the secondary control c_2 we
  will need, just as above, snippets
3 # of the hourly jumps and the subsequent
  decay of the frequency back to the
4 # nominal values. Due to the complicated
  frequency behaviour, we will fit an
5 # entire curve to the 900 seconds but we
  shall only extract the decay rate
6
7 # Define window of jumps. In this case,
  evaluate the secondary control c_2
  every
8 # hour
9 window = 3600 # 3600 seconds = 1 hour
10
11 # Set the total length to evaluate
12 data_range = data.size // window
13
14 # Initialise an array to record the Delta P
15 c_2_decays = np.zeros(data_range)
16
17 # Since we have up and down jumps, we have
  to separate the trajectories that
18 # move up and those that move down but we
  still calculate the same decay
19 # behaviour of both
20 for j in range(data_range):
21     # if the frequency trajectory moves
    positively
22     if np.sum((np.diff(data[3600*(j):3600*(
    j)+10]))) > 0:
23         c_2_decays[j] = curve_fit(lambda t,
    a,b,c:
24         a*np.exp(-b*t)*(1-np.exp(-c*t
    +2*b*t)),
25         np.linspace(0,899,900), data
    [3600*(j):3600*(j)+900],
26         p0=(0.08, .0045, 0.035), maxfev
    =10000
27         )[0][1]
28     else:
29         c_2_decays[j] = curve_fit(lambda t,
    a,b,c:
30         -a*np.exp(-b*t)*(1-np.exp(-c*t
    +2*b*t)),
31         np.linspace(0,899,900), data
    [3600*(j):3600*(j)+900],
32         p0=(0.08, .0045, 0.035), maxfev
    =10000
33         )[0][1]
34
35 # We have thus stored the decay rate b of
  every power mismatch in the system.
36 # Due to statistical outliers, discard 20%
  of the data
37
38 # Sort the array and discard 20% of the
  largest values
39 temp_c_2_decays = c_2_decays[np.argsort(
  c_2_decays)][:-c_2_decays.size//5]
40
41 # Recall here that to calculate c_2 you
  need to know c_1
42 c_2 = np.mean(temp_c_2_decays) * c_1

```

...