

Received February 4, 2020, accepted February 28, 2020, date of publication March 6, 2020, date of current version March 20, 2020.

Digital Object Identifier 10.1109/ACCESS.2020.2978398

Parameter Estimation of Electric Power Transformers Using Coyote Optimization Algorithm With Experimental Verification

MOHAMED I. ABDELWANIS¹, AMLAK ABAZA¹, RAGAB A. EL-SEHIEMY¹,
MOHAMED N. IBRAHIM^{1,2,3}, AND HEGAZY REZK^{4,5}

¹Electrical Engineering Department, Kafr El Sheikh University, Kafr El-Sheikh 33511, Egypt²Department of Electromechanical, Systems and Metal Engineering, Ghent University, 9000 Ghent, Belgium³FlandersMake@UGent-Corelab EEDT-MP, 3001 Leuven, Belgium⁴College of Engineering at Wadi Addawaser, Prince Sattam Bin Abdulaziz University, Wadi Aldawaser 11991, Saudi Arabia⁵Electrical Engineering Department, Faculty of Engineering, Minia University, Minia 61519, Egypt

Corresponding author: Mohamed I. Abdelwanis (Mohamed.soliman4@eng.kfs.edu.eg)

ABSTRACT In this work, the Coyote Optimization Algorithm (COA) is implemented for estimating the parameters of single and three-phase power transformers. The estimation process is employed on the basis of the manufacturer's operation reports. The COA is assessed with the aid of the deviation between the actual and the estimated parameters as the main objective function. Further, the COA is compared with well-known optimization algorithms i.e. particle swarm and Jaya optimization algorithms. Moreover, experimental verifications are carried out on 4 kVA, 380/380 V, three-phase transformer and 1 kVA, 230/230 V, single-phase transformer. The obtained results prove the effectiveness and capability of the proposed COA. According to the obtained results, COA has the ability and stability to identify the accurate optimal parameters in case of both single phase and three phase transformers; thus accurate performance of the transformers is achieved. The estimated parameters using COA lead to the highest closeness to the experimental measured parameters that realizes the best agreements between the estimated parameters and the actual parameters compared with other optimization algorithms.

INDEX TERMS Coyote, PSO, Jaya, single-phase transformer, transformer equivalent circuit.

I. INTRODUCTION

The transformer is a vital element in electrical power systems. The failure of transformer or the wrong operation affects the overall power system reliability and performance. The transformer has its own model. The parameters of the transformer model depict its performance over different conditions [1]. The accurate estimation of the transformer equivalent circuit parameters helps in efficient monitoring process of power transformers. The importance of accurate estimation process is resulted from the need to enhance the performance characteristics of transformers in both steady-state and transient cases [2], [3]. The existence of harmonics, saturation, and transient conditions in transformer affects the parameter estimation process. Thus, real time measurements were used by applying frequency response [4] or time domain analysis to obtain an accurate estimation of the transformer parameters [5]–[8]. The saturation of transformer core was consid-

ered in parameter estimation by using inrush current measurements [9]. The real time measurement process includes load terminal data, phase measurement unit (PMU), inrush current test, open circuit and short-circuit tests. This process, in most cases, requires disconnecting the transformer from operation, which is considered an impractical solution.

Optimization techniques have become the most popular strategies for solving different electrical problems such as the parameter estimation of electrical elements such as electric machines, transformers, power lines, fuel cells and photovoltaic modules, batteries, management of electrical distribution system with soft open point, optimal power flow problem [10]–[15]. . . etc. In the estimation problems, the optimization methods compare the actual and estimated data to minimize the deviation between them [16]–[18]. Many of optimization methods use the name-plate data as actual data [5], [8]. The equivalent circuit parameters were then estimated using evolutionary techniques such as Particle Swarm Optimization (PSO) Algorithm, Jaya Optimization Algorithm (JOA) and Genetic Algorithm (GA). Eventually,

The associate editor coordinating the review of this manuscript and approving it for publication was Yu-Huei Cheng¹.

the by minimizing the error between the measured power and voltage at different loading conditions and the estimated values are minimized to obtain the optimal estimated parameters [2], [19]–[22].

Chaotic Optimization Algorithm was used the name-plate and the load test data to estimate the parameters of single phase transformer in [23]. In [24], Bacterial Foraging Algorithm (BFA) is used to estimate the single- phase and three-phase transformer parameters by applying open and short-circuit experimental tests. Imperialist competitive and gravitational search algorithms (GSA) have been proposed to estimate the single-phase transformer parameters from name-plate data [25]. In addition, Artificial Bee Colony Algorithm was used in [26] to estimate the transformer parameters. All of these algorithms can be applied using name-plate or load data during the operation of transformer without having to disconnect the transformer for testing purposes. Moreover, these algorithms can estimate three-phase transformer parameters as well as those of single-phase transformer [27], [28] and for optimal design of a three-phase high-speed flux reversal machine in [29].

Coyote optimization algorithm (COA) is a new meta-heuristic optimization algorithm designed in [30]. The coyote's social organization and exchanging experiences is the base of adaptation (optimization) to the environmental conditions. COA has been classified as both swarm intelligence and evolutionary heuristic. Several applications of COA are reported in the literature as for optimizing the estimated parameters of fuel cell [31] and for parameter estimation of solar cells [32].

In the current study, the COA is developed to estimate the optimal parameters of single and three phase transformers. This work has the following main features:

- This study proposed COA for parameters estimation of transformers;
- This work is applied to both single- phase and three-phase transformers;
- Parameter estimation of three and single-phase transformers using the proposed COA is assessed with those obtained by JOA and PSO competitive algorithms;
- The estimation process aims to realize the best voltage regulation and efficiency by accurate modeling of transformer equivalent circuit parameters;
- Experimental tests (open and short circuit tests) are done on single and three-phase transformer to verify the estimated parameters.

II. STEADY STATE CHARACTERISTICS OF TRANSFORMER

The steady-state single phase equivalent circuit of the transformer is shown in Figure 1 [14].

Applying Kirchhoff voltage and current laws to the per-phase transformer equivalent circuit (Figure 1), the following relations can be obtained:

$$V_1 = \underline{E}_1 + I_1 Z_1 \quad (1)$$

$$\underline{E}_1 = \underline{V}'_2 + I'_2 Z'_2 \quad (2)$$




FIGURE 1. Per phase equivalent circuit of transformer.

$$\underline{E}_1 = I_o Z_{ma} \quad (3)$$

$$\underline{I}_1 = I_o + I'_2 \quad (4)$$

From the four equations, the primary current I_1 and the primary induced voltage E_1 can be obtained as follows:

$$\underline{I}_1 = \frac{V_1 + I'_2 Z'_2}{Z_1 + Z_m} \quad (5)$$

$$\underline{E}_1 = \underline{V}_1 - \underline{I}_1 Z_1 \quad (6)$$

The referred secondary voltage will be:

$$\underline{V}'_2 = \underline{E}_1 - I'_2 Z'_2 \quad (7)$$

The core current I_o can be obtained as an equivalent value to the core magnetizing current component I_m and the core loss current component I_{e+h} as follows:

$$I_o = \frac{\underline{E}_1}{Z_m} = \frac{\underline{E}_1}{R_{e+h}} - j \frac{\underline{E}_1}{X_m} = I_{e+h} - j I_m \quad (8)$$

The transformer voltage regulation is given as:

$$VR = \frac{V_1 - V'_2}{V_1} \quad (9)$$

The primary power factor pf_1 , input power P_{in} , and the output power P_o can be obtained as follows:

$$pf_1 = \cos(\angle(\underline{I}_1)) \quad (10)$$

$$P_{in} = \text{real}(V_1 \times I_1^*) \quad (11)$$

$$P_o = \text{real}(V'_2 \times I_2'^*) \quad (12)$$

Efficiency of the transformer can be calculated from:

$$\eta_r = \frac{P_o}{P_{in}} \quad (13)$$

It is required to identify the equivalent circuit parameters $R_1, X_1, R_2, X_2, R_{e+h}, X_m$ accurately as possible. This goal can be achieved through an optimization algorithm.

III. PROPOSED COYOTE OPTIMIZATION ALGORITHM

Coyote optimization algorithm (COA) is a new nature-inspired metaheuristic algorithm [30]. It is a population-based algorithm, which depends on the social organization and conditions of coyotes. COA has been classified as both swarm intelligence and evolutionary heuristic. The objective function is optimized based on the social organization and exchanging experiences among the coyotes. The population of coyotes consists of number of packs, NP ; each pack

contains NC coyote. The total number of coyotes in all packs represents the population of the optimization problem. The solution of the optimization problem means the optimal adaptation to all social conditions. These social conditions of coyotes depict the d -space decision variables of the optimization problem.

The social condition ' soc ', of the coyote in the p^{th} pack at t^{th} instant of time, is $soc_c^{p,t}$. These conditions of the coyote represent the decision variables \bar{X} of a specified global optimization problem [24]. It is given as:

$$soc_c^{p,t} = \bar{X} = (x_1, x_2, \dots, x_d) \quad (14)$$

The initial social conditions are started randomly for each coyote c^{th} of p^{th} at instant t^{th} and j^{th} dimension in the range of the lower and upper bounds, LB_j and UB_j of the decision variable as follows:

$$soc_{c,j}^{p,t} = LB_j + r_j \times (UB_j - LB_j) \quad (15)$$

where, r_j is a real random number lies in the [0-1] range which generated using a uniform probability.

The objective function is obtained by evaluating the coyote's conditions corresponding to the current decision variables, as follows:

$$fit_c^{p,t} = f(soc_c^{p,t}) \quad (16)$$

The social organization of coyotes enables it to leave its pack or join to another one according to the current coyote in the pack, NC (limited to 14 coyote inside the pack). The best solution to the optimization problem at t^{th} instant of time of P^{th} pack is 'alpha' for the global population. It is determined as follows:

$$alpha^{p,t} = \{ soc_c^{p,t} | \arg_{c=(1,2,\dots,NC)} \min f(soc_c^{p,t}) \} \quad (17)$$

The COA enables the sharing of social conditions and links all information from the global population. COA, then, computes the cultural tendency of the pack, which is the median social condition of all coyote from that defined pack.

$$cult_j^{p,t} = \begin{cases} O_{\frac{(N_c+1)}{2}}^{p,t}, & N_c \text{ is odd} \\ \frac{O_{\frac{N_c}{2}}^{p,t} + O_{\frac{(N_c+1)}{2}}^{p,t}}{2}, & \text{otherwise} \end{cases} \quad (18)$$

where $O^{p,t}$ is the ranked decision variables (i.e. social conditions) of all coyote inside the p^{th} pack at t^{th} instant for every j in the space of decision variables, d .

The updating of coyote's new social conditions, $new_soc_c^{p,t}$ depends on two factors; the first is the alpha influence, δ_1 , and the second is the cultural tendency influence δ_2 , as follows.

The influence δ_1 is taken as the difference from a random coyote (Cr_1) inside the pack to the alpha coyote. On the other hand, the pack influence (δ_2) is considered as the difference from a random coyote (Cr_2) of a pack to the cultural tendency of that pack.

$$\delta_1 = alpha^{p,t} - soc_{cr_1}^{p,t} \quad (19)$$

TABLE 1. Experimental tests of three and single phase transformers (cases 1 and 2).

Variables	No load test		SC test		DC test	
	Case 1	Case 2	Case 1	Case 2	Case 1	Case 2
Voltage (V)	222.2	228	23.72	20.8	-	-
Current (A)	0.11	0.05	1.08	0.18	-	-
P (W)	0.834	3.28	3.97	2.58	-	-
$R_1(\Omega)$	-	-	-	-	1.7	52.5
$R_2(\Omega)$	-	-	-	-	1.7	27.12

$$\delta_2 = cult^{p,t} - soc_{cr_2}^{p,t} \quad (20)$$

$$new_soc_c^{p,t} = soc_c^{p,t} + r_1 \delta_1 + r_2 \delta_2 \quad (21)$$

where, r_1 and r_2 are uniformly random numbers within the range [0-1].

The new value of the objective function is determined by evaluation of the new social conditions, as follows:

$$new_fit_c^{p,t} = f(new_soc_c^{p,t}) \quad (22)$$

At the next $(t + 1)^{th}$ time instant, the decision is taken about the new social conditions according to the value of the objective function, as follows:

$$soc_c^{p,t+1} = \begin{cases} new_soc_c^{p,t}, & new_fit_c^{p,t} \leq fit_c^{p,t} \\ soc_c^{p,t}, & \text{otherwise} \end{cases} \quad (23)$$

The global solution of the problem is that the social conditions of a coyote that best adapted itself to the environment. In order to keep the pack size static, COA computes the ages of all coyote inside a pack (in years) as $age_c^{p,t} \in N$. The birth of a new coyote is represented by a combination of the social conditions of two parents inside a pack, which are chosen randomly, as follows:

$$pup_j^{p,t} = \begin{cases} soc_{r_1,j}^{p,t}, & r \text{ and } j \leq P_s \text{ or } j = j_1 \\ soc_{r_1,j}^{p,t}, & r \text{ and } j \geq (P_s + P_a) \text{ or } j = j_2 \\ R_j, & \text{otherwise} \end{cases} \quad (24)$$

where, r_1 and r_2 are random coyote inside P^{th} pack. j_1 and j_2 represent two randomly dimensions of the optimization problem. P_s and P_a are the scatter and association probabilities, given by Eqs. (22)-(24). R_j is a random number lies inside the decision variable bound of the j^{th} dimension. The value of the real random number $ran\ d_j$ lies in the range [0-1], and generated using uniform probability.

$$P_s = 1/d \quad (25)$$

$$P_a = (1 - P_s)/2 \quad (26)$$

The birth and the death of coyotes are syncs as the following steps (Algorithm #1):

Step 1: Compute the group worse adapted to the environment than the pups, 'w' and the number of coyotes in this group, ' φ' '.





FIGURE 2. Proposed COA flowchart for transformer.

TABLE 2. Optimal parameters of three phase transformer Case 1 (4 kVA, 380/380 V).


Algorithm	Name-plate	PSO	Jaya	Coyote
$R_1(\Omega)$	1.7	1.6889	1.731	1.7099
$X_1(\Omega)$	10.84	10.7813	10.7237	10.7782
$R_2(\Omega)$	1.7	1.7113	1.6685	1.69
$X_2(\Omega)$	10.84	10.7889	10.8482	10.85
$R_{e+h}(\Omega)$	59252	59254	59289	59200
$X_m(\Omega)$	2021	2011.4	2023	2022
Average error (%)	base	0.0033	0.0083	0.0032

Step 2: Check if φ equals 1 then go to step3 else if φ is greater than 1 go to step4 else the pub dies.

Step 3: The pub survives and the only coyote representing w dies.



(a)



(b)

FIGURE 3. Photograph of the experimental setup: (a) three (Case 1) and (b) single (Case 2) phase transformers.

TABLE 3. Optimal parameters single phase transformer Case 2 (1 kVA, 230/230 V).

Algorithm	Name-plate	PSO	Jaya	Coyote
$R_1(\Omega)$	52.5	50.087	50.112	51.75
$X_1(\Omega)$	41.85	42.844	43.735	39.301
$R_2(\Omega)$	27.12	30.211	30.186	28.154
$X_2(\Omega)$	41.85	48.009	47.226	38.054
$R_{e+h}(\Omega)$	15849	15935	15932	15862
$X_m(\Omega)$	47589	46757	46810	47812
Average error (%)	base	5.896	5.450	3.224



TABLE 4. Statistical indices of PSO, JOA and COA.

Case	Algorithm	Best OF	mean OF	Median	Standard deviation	Variance
#1	COA	8.8e-10	8.8e-10	8.8e-10	3.76e-23	1.41e-45
	JOA	8.7e-10	9.7e-9	1.7e-9	3.1e-8	9.4e-16
	PSO	8.4e-10	9.9e-10	9.9e-10	6.9e-11	4.8e-21
#2	COA	4.2e-30	4.5e-14	3.2e-14	4.8e-14	2.3e-27
	JOA	2.2e-12	9.9e-9	8.0e-9	8.8e-9	7.8e-17
	PSO	2.0e-15	6.1e-9	5.4e-9	1.2e-8	1.5e-16

Step 4: The pub survives and the oldest coyote in w dies. If two or more coyotes have the same age, the one which has less adaptive dies.

TABLE 5. Simulation full load data of Case 2 (1 kVA, 230/230 V).


Algorithm	Tested	Calculated	PSO	Jaya	Coyote
I_1 (A)	0.16	0.159	0.1589	0.1589	0.1589
η_{FL}	0.863	0.859	0.859	0.859	0.859
Pf	0.99	0.988	0.9877	0.9877	0.9877
SSAP	base	4.323e-3	2.87e-11	1.017e-12	9.55e-14

**FIGURE 4.** Convergence curves of the objective function for transformer; Case 1 (4 kVA, 380/380 V).**FIGURE 5.** Convergence curves of the objective function for transformer; Case 2 (1 kVA, 230/230 V).

Finally, the optimal values of transformer parameters (R_1 , X_1 , R_2 , X_2 , R_{e+h} , X_m) are reached by evaluating the objective function and checking the maximum number of iterations.

IV. PARAMETER ESTIMATION OF SINGLE- PHASE AND THREE-PHASE TRANSFORMERS

The objective function of the transformer parameter estimation problem aims to minimize the deviation between the estimated and the manufacturer's data. The optimized

**FIGURE 6.** Performance of 4 kVA, 380/380 V, 50Hz 3 ϕ transformer; (a): Efficiency%, (b) Voltage regulation% and (c) Power factor.

parameters, R_1 , X_1 , R_2 , X_2 , R_{e+h} , X_m are affecting Eqs.(8)-(13) that, in turn, affect the primary current, efficiency, and the power factor of the load.

The calculated values are required to be assessed with the manufacturer's data. To realize the convergence, the sum of square absolute percentage error (SSAPE) between manufacturer's data and the estimated values must be minimized. COA and JOA as a meta-heuristic optimization algorithm are

TABLE 6. Simulation full load data of Case 1 (4kVA, 380/380 V).

Algorithm	Calculated	PSO	Jaya	Coyote
I_1 (A)	7.0424	7.0424	7.0424	7.0424
η_{FL}	0.9013	0.9013	0.9013	0.9013
Pf	0.9999	0.9999	0.9999	0.9999
SSAP	base	9.753e-10	9.168e-10	.8774e-10

applied to minimize the objective function of the problem.

$$f_1 = \frac{e\eta_r - m\eta_r}{m\eta_r} \quad (27)$$

$$f_2 = \frac{eI_1 - mI_1}{mI_1} \quad (28)$$

$$f_3 = \frac{epf - mpf}{mpf} \quad (29)$$

$$SSAPE = f_1^2 + f_2^2 + f_3^2 \quad (30)$$

The problem objective function is expressed as:

$$OF = \min(SSAPE) \quad (31)$$

Eq. (31) is subjected to the boundary constraints of the problem control variables as:

$$\begin{aligned} R_1^{\min} &\leq R_1 \leq R_1^{\max}, R_2^{\min} \leq R_2 \leq R_2^{\max} \\ X_1^{\min} &\leq X_1 \leq X_1^{\max}, X_2^{\min} \leq X_2 \leq X_2^{\max} \\ R_{e+h}^{\min} &\leq R_{e+h} \leq R_{e+h}^{\max}, X_m^{\min} \leq X_m \leq X_m^{\max} \end{aligned} \quad (32)$$

Figure 2 shows the flowchart of the proposed COA for estimating the parameters of single and three-phase transformers. In this study, COA has 10 packs, each of them contains 10 coyotes. Thus, the population number is 100 coyotes. The maximum number of iterations is set to 350 and it is considered as the stopping criterion of the optimization process. JOA and PSO parameters are customized from [33]–[37].

V. CASE STUDIES

The effectiveness of the proposed COA is verified through the estimation of the parameters of single and three-phase transformers. These transformers are described as:

Case 1: 4 kVA, 380/380 V, 50 Hz, three-phase transformer: Open circuit, short circuit and DC tests are carried out to obtain the actual parameters of the equivalent circuit. Photograph of the experimental implementation is provided in Figure 3.

Case 2: 1 kVA, 230/230 V, 50 Hz, single-phase transformer, Open circuit, short circuit, DC and load tests are carried out to obtain the actual parameters of the equivalent circuit.

Table 1 lists the recorded measurements at no load and short circuit tests for single and three-phase transformers. In these cases, the actual data of the transformers have been obtained using the open and short-circuited experimental tests. The open circuit test is performed at the nominal voltage and the measured current and power are used to determine




FIGURE 7. Performance of Case 2, 1 kVA, 230/230 V, 50 Hz single phase transformer; (a) Efficiency%, (b) Voltage regulation% and (c) Power factor.

the core resistance and magnetizing reactance i.e. R_{e+h} and X_m respectively. In addition, short-circuit test measurements (voltage, current and power) are used to determine the primary and secondary resistances and leakage reactances i.e. R_1 , X_1 , R_2 , X_2 respectively.

The parameters of both cases are estimated optimally using the COA compared with PSO, Jaya and with those customized from the name-plate and loading data. The obtained results using the competitive algorithms are compared with the actual values, as explained in Tables 2 and 3. The estimated parameters are used to calculate the transformer




FIGURE 8. Robustness of the competitive algorithms (PSO, JOA and COA); (a) Case 1 and (b) Case 2.

current, power factor, voltage regulation, and efficiency at full-load conditions.

Tables 4 and 5 compare the estimated and actual performance (current, power factor, and efficiency) at full load besides the voltage regulation at different load conditions. The results prove that the proposed COA gives the most accurate operating performance. In Case 1, the errors obtained are $9.753\text{e-}10$ with PSO, $9.168\text{e-}10$ with Jaya, and $9.168\text{e-}10$ with COA. In Case 2, it is cleared that COA has the lowest error for estimating the transformer performance. Good convergences of the three competitive algorithms are illustrated in Figs. 4 and 5 for Cases 1 and 2, respectively. It was noticed that PSO converges faster than the others; however, COA has reached the lowest objective function than JOA and PSO. Figure 6 shows the performance using the estimated parameters of Case 1 compared with those of the actual data. High closeness between estimated efficiency and input power factor are noticed at different loading percentage to the actual characteristic using COA, then JOA and later PSO. However, voltage regulation optimized by JOA is the nearest to the actual curve. Figure 7 shows the performance data of Case 2 compared with the reported name-plate data. Estimated efficiency and voltage regulation using the proposed COA are very close to the actual values. JOA and COA outperform in estimating the input Power factor.

As the objective function compromise efficiency, voltage regulation, and input power factor, it can be concluded that best estimation of transformer parameters is obtained. All results show the effectiveness of the proposed competitive algorithms to identify the transformer parameters compared with the actual nameplate data. The proposed COA outperforms the other in performance verification.

To verify the robustness of the proposed algorithms, 100 separate runs are applied to COA, JOA and PSO for Cases 1 and 2. Figure 8 illustrates the robustness of the three algorithms. It is clear that, the proposed COA has the highest robustness, then JOA and later PSO. Table 4 presents the statistical indices of the proposed method at the defined cases.

VI. CONCLUSION

In this paper, the COA optimization algorithm has been proposed for estimating accurate model parameters of the single and three-phase transformers. The estimated parameters of three competitive algorithms i.e. PSO, JOA and COA are used to calculate the operating performance of the transformer at different loading conditions. The results obtained have been compared with the recorded experimental results. The results signify the effectiveness and reliability of the proposed (COA) in estimating accurate model of the transformers. The COA realizes rapid, smooth, and steady convergence than PSO and Jaya. According to the results obtained, the COA has the ability and stability to identify optimal parameters and accurate performance of both single and three phase transformers. It can be concluded from all results obtained that COA is more simple, stable, global outperformance optimization algorithm in estimating the power transformer parameters compared to PSO and JOA.

REFERENCES

- [1] H. D. Mehta and R. M. Patel, "A review on transformer design optimization and performance analysis using artificial intelligence techniques," *Int. J. Sci. Res.*, vol. 3, no. 9, pp. 726–733, 2014.
- [2] R. Aghmasheh, V. Rashtchi, and E. Rahimpour, "Gray box modeling of power transformer windings based on design geometry and particle swarm optimization algorithm," *IEEE Trans. Power Del.*, vol. 33, no. 5, pp. 2384–2393, Oct. 2018.
- [3] A. Shintemirov, W. H. Tang, and Q. H. Wu, "Transformer core parameter identification using frequency response analysis," *IEEE Trans. Magn.*, vol. 46, no. 1, pp. 141–149, Jan. 2010.
- [4] S. D. Mitchell and J. S. Welsh, "Modeling power transformers to support the interpretation of frequency-response analysis," *IEEE Trans. Power Del.*, vol. 26, no. 4, pp. 2705–2717, Oct. 2011.
- [5] A. Keyhani, S. M. Miri, and S. Hao, "Parameter estimation for power transformer models from time-domain data," *IEEE Power Eng. Rev.*, vol. PER-6, no. 7, pp. 46–47, Jul. 1986.
- [6] H. Dirik, C. Gezeğin, and M. Özdemir, "A novel parameter identification method for single-phase transformers by using real-time data," *IEEE Trans. Power Del.*, vol. 29, no. 3, pp. 1074–1082, Jun. 2013.
- [7] J. A. Martinez, R. Walling, B. A. Mork, J. Martin-Arnedo, and D. Durbak, "Parameter determination for modeling system transients—Part III: Transformers," *IEEE Trans. Power Del.*, vol. 20, no. 3, pp. 2051–2062, Jul. 2005.
- [8] M. Wang, "Online estimation of transformer parameters based on PMU measurements," *Autom. Electric Power Syst.*, vol. 35, pp. 61–65, Jul. 2011.
- [9] S. Bogarra, A. Font, I. Candela, and J. Pedra, "Parameter estimation of a transformer with saturation using inrush measurements," *Electr. Power Syst. Res.*, vol. 79, no. 2, pp. 417–425, Feb. 2019.

- [10] D. Bhowmick, M. Manna, and S. K. Chowdhury, "Estimation of equivalent circuit parameters of transformer and induction motor from load data," *IEEE Trans. Ind. Appl.*, vol. 54, no. 3, pp. 2784–2791, May 2018.
- [11] M. I. Abd-Elwanis and R. A. El-Sehiemy, "Synchronous motor design using particle swarm optimization technique," in *Proc. 14th Int. Middle East Power Syst. Conf. (MEPCON)*. Giza, Egypt: Cairo Univ., Dec. 2010, pp. 19–21.
- [12] R. A. El-Sehiemy, M. A. Hamida, and T. Mesbahi, "Parameter identification and state-of-charge estimation for lithium-polymer battery cells using enhanced sunflower optimization algorithm," *Int. J. Hydrogen Energy*, vol. 45, no. 15, pp. 8833–8842, Mar. 2020.
- [13] M. B. Shafik, H. Chen, G. I. Rashed, R. A. El-Sehiemy, M. R. Elkadeem, and S. Wang, "Adequate topology for efficient energy resources utilization of active distribution networks equipped with soft open points," *IEEE Access*, vol. 7, pp. 99003–99016, 2019.
- [14] A. M. Shaheen, R. A. El-Sehiemy, and S. M. Farrag, "Adequate planning of shunt power capacitors involving transformer capacity release benefit," *IEEE Syst. J.*, vol. 12, no. 1, pp. 373–382, Mar. 2015.
- [15] B. Bentouati, S. Chettih, R. El Sehiemy, and G. G. Wang, "Elephant herding optimization for solving non-convex optimal power flow problem," *J. Elect. Electron. Eng.*, vol. 10, no. 1, pp. 31–36, 2017.
- [16] R. Chenouard and R. A. El-Sehiemy, "An interval branch and bound global optimization algorithm for parameter estimation of three photovoltaic models," *Energy Convers. Manage.*, vol. 205, Feb. 2020, Art. no. 112400.
- [17] M. A. Mohamed, A. A. Zaki Diab, and H. Rezk, "Partial shading mitigation of PV systems via different meta-heuristic techniques," *Renew. Energy*, vol. 130, pp. 1159–1175, Jan. 2019.
- [18] O. Abdalla, H. Rezk, and E. M. Ahmed, "Wind driven optimization algorithm based global MPPT for PV system under non-uniform solar irradiance," *Sol. Energy*, vol. 180, pp. 429–444, Mar. 2019.
- [19] S. H. Thilagar and G. S. Rao, "Parameter estimation of three-winding transformers using genetic algorithm," *Eng. Appl. Artif. Intell.*, vol. 15, no. 5, pp. 429–437, Sep. 2002.
- [20] M. I. Mossad, M. Azab, and A. Abu-Siada, "Transformer parameters estimation from nameplate data using evolutionary programming techniques," *IEEE Trans. Power Del.*, vol. 29, no. 5, pp. 2118–2123, Oct. 2014.
- [21] K. Yu, J. J. Liang, B. Y. Qu, X. Chen, and H. Wang, "Parameters identification of photovoltaic models using an improved JAYA optimization algorithm," *Energy Convers. Manage.*, vol. 150, pp. 742–753, Oct. 2017.
- [22] D.-C. Du, H.-H. Vinh, V.-D. Trung, N.-T. Hong Quyen, and N.-T. Trung, "Efficiency of jaya algorithm for solving the optimization-based structural damage identification problem based on a hybrid objective function," *Eng. Optim.*, vol. 50, no. 8, pp. 1233–1251, Aug. 2018.
- [23] M. Čalasan, D. Mujičić, V. Rubežić, and M. Radulović, "Estimation of equivalent circuit parameters of single-phase transformer by using chaotic optimization approach," *Energies*, vol. 12, no. 9, pp. 1697–1701, 2019.
- [24] S. Subramanian and S. Padma, "Bacterial foraging algorithm based parameter estimation of three winding transformer," *Int. Rev. Model. Simul.*, vol. 4, no. 2, pp. 310–317, 2011.
- [25] H. A. Illias, K. J. Mou, and A. H. A. Bakar, "Estimation of transformer parameters from nameplate data by imperialist competitive and gravitational search algorithms," *Swarm Evol. Comput.*, vol. 36, pp. 18–26, Oct. 2017.
- [26] Z. Yilmaz, M. Oksar, and F. Basciftci, "Multi-objective artificial bee colony algorithm to estimate transformer equivalent circuit parameters," *Periodicals Eng. Natural Sci.*, vol. 5, no. 3, pp. 271–277, 2017.
- [27] Y. Wang, Y. Shangguan, and J. Yuan, "Determination approach for the parameters of equivalent circuit model of deep saturated three-phase integrative transformers," *IEEE Trans. Magn.*, vol. 54, no. 11, pp. 1–5, Nov. 2018.
- [28] R. Kazemi, S. Jazebi, D. Deswal, and F. de Leon, "Estimation of design parameters of single-phase distribution transformers from terminal measurements," *IEEE Trans. Power Del.*, vol. 32, no. 4, pp. 2031–2039, Aug. 2017.
- [29] V. Prakht, V. Dmitrievskii, V. Kazakbaev, S. Oshurbekov, and M. N. Ibrahim, "Optimal design of a novel three-phase high-speed flux reversal machine," *Appl. Sci.*, vol. 9, no. 18, p. 3822, 2019.
- [30] J. Pierzan and L. Dos Santos Coelho, "Coyote optimization algorithm: A new metaheuristic for global optimization problems," in *Proc. IEEE Congr. Evol. Comput. (CEC)*, Rio de Janeiro, Brazil, Jul. 2018, pp. 2633–2640.
- [31] A. Abaza, R. A. El Sehiemy, and A. S. Abdelrazek, "Optimal parameter estimation of solid oxide fuel cells model using coyote optimization algorithm," in *Proc. Recent Adv. Eng. Math. Phys.* Giza, Egypt Cairo Univ., Dec. 2019, pp. 1–6.
- [32] M. H. Qais, H. M., Hasanien, S. Alghuwainem, A. S. Nouh, "Coyote optimization algorithm for parameters extraction of three-diode photovoltaic models of photovoltaic modules," *Energy*, vol. 187, Nov. 2019, Art. no. 116001.
- [33] M. G. Gafar, R. A. El-Sehiemy, and H. M. Hasanien, "A novel hybrid fuzzy-JAYA optimization algorithm for efficient ORPD solution," *IEEE Access*, vol. 7, pp. 182078–182088, 2019.
- [34] S. A. El-Sattar, S. Kamel, R. A. El Sehiemy, F. Jurado, and J. Yu, "Single- and multi-objective optimal power flow frameworks using Jaya optimization technique," *Neural Comput. Appl.*, vol. 31, no. 12, pp. 8787–8806, Dec. 2019.
- [35] A. F. Barakat, R. A. El-Sehiemy, M. I. Elsayd, and E. Osman, "An enhanced jaya optimization algorithm (EJOA) for solving multi-objective ORPD problem," in *Proc. Int. Conf. Innov. Trends Comput. Eng. (ITCE)*, Aswan, Egypt, Feb. 2019, pp. 2–4.
- [36] R. A. El Sehiemy, F. Selim, B. Bentouati, and M. A. Abido, "A novel multi-objective hybrid particle swarm and salp optimization algorithm for technical-economical-environmental operation in power systems," *Energy*, vol. 193, Feb. 2020, Art. no. 116817.
- [37] A. A. Fathy, M. S. Elbages, R. A. El-Sehiemy, and F. M. Bendary, "Static transmission expansion planning for realistic networks in Egypt," *Elect. Power Syst. Res.*, vol. 151, pp. 404–418, Oct. 2017.



MOHAMED I. ABDELWANIS received the B.Sc., M.Sc., and Ph.D. degrees from Alazhar University, Egypt, in 2003, 2008, and 2011, respectively, all in electrical power and machines engineering. In 2009, he became a Teaching Assistant with the Electrical Engineering Department, Kafr El Sheikh University, where he is currently an Assistant Professor with the Department of Electrical Engineering. His current research interest includes design and control of electrical machines for industrial, and renewable energy applications and optimization. He received several times the Kafrelsheikh University Award for his international scientific publications.



AMLAK ABAZA was born in Kafr El-Sheikh, Egypt, in 1974. She received the degree from Tanta University, Egypt, in 1997, and the M.Sc. and Ph.D. degrees from Tanta University, in 2002 and 2015, respectively. She joined as a Demonstrator with the Faculty of Engineering, Tanta University, in 2009. She is currently an Assistant Professor with the Electrical Power and Machines Department, Kafr El Sheikh University. Her research interests are in the area of smart grid, micro-grids, and renewable integration in electrical power systems, optimization of power systems, virtual power plants, modeling of PV, and fuel cells.



RAGAB A. EL-SEHIEMY was born in Menoufia, Egypt, in 1973. He received the B.Sc. degree in electrical engineering and the M.Sc. and Ph.D. degrees from Menoufia University, Egypt, in 1996, 2005, and 2008, respectively. He is currently an Associate Professor with the Electrical Engineering Department, Faculty of Engineering, Kafr El Sheikh University, Egypt. His research interests include smart grid and its applications, optimization and AI, and its application to power systems. He received Prof. Mahmoud Khalifia Award in power system engineering from the Academy of Research and Technology, in 2016. He is an Editor of the *International Journal of Engineering Research in Africa*.



MOHAMED N. IBRAHIM received the B.Sc. degree in electrical power and machines engineering from Kafr El Shiekh University, Egypt, in 2008, the M.Sc. degree in electrical power and machines engineering from Tanta University, Egypt, in 2012, and the Ph.D. degree in electromechanical engineering from Ghent University, Belgium, in 2017. In 2008, he became a Teaching Assistant with Electrical Engineering Department, Kafr El Shiekh University. He was an Assistant Professor (on leave) with the Department of Electrical Engineering, Kafr El Shiekh University. He is currently a Postdoctoral Researcher with the Department of Electromechanical, Systems and Metal Engineering, Ghent University, Belgium. His current research interest includes design and control of electrical machines and drives for industrial and sustainable energy applications. He received several times the Kafrelshiekh University Award for his international scientific publications. He serves as a Reviewer for several journals and conferences including the IEEE TRANSACTIONS ON INDUSTRIAL ELECTRONICS, the IEEE TRANSACTIONS ON INDUSTRY APPLICATIONS, and the IEEE TRANSACTIONS ON MAGNETICS.



HEGAZY REZK received the B.Eng. and M.Eng. degrees in electrical engineering from Minia University, Egypt, in 2001 and 2006, respectively, and the Ph.D. degree from the Moscow Power Engineering Institute, Moscow. He was an Associate Professor (on leave) with the Electrical Engineering Department, Minia University. He was a Postdoctoral Research Fellow with the Moscow State University of Mechanical Engineering, Russia, for six months. He was a Visiting Researcher with Kyushu University, Japan. He is currently an Associate Professor with the Electrical Engineering Department, College of Engineering at Wadi Addwaser, Prince Sattam Bin Abdulaziz University, Saudi Arabia. He has authored more than 50 technical articles. His current research interests include renewable energy, smart grid, hybrid systems, power electronics, and optimization and artificial intelligence.

...