New application of superconductors: high sensitivity cryogenic light detectors

L.Cardani^{a,b}, F. Bellini^{a,c}, N. Casali^{a,c}, M. G. Casellano^d, I. Colantoni^a, A. Coppolecchia^a, C. Cosmelli^{a,c}, A. Cruciani^{a,c}, A. D'Addabbo^e, S. Di Domizio^{f,g}, M. Martinez^{a,c,h}, C. Tomei^c, M. Vignati^{a,c}

> ^aDipartimento di Fisica - Sapienza Università di Roma, Piazzale Aldo Moro 2, 00185, Roma - Italy Physics Department - Princeton University, Washington Road, 08544, Princeton - NJ, USA ^cINFN - Sezione di Roma, Piazzale Aldo Moro 2, 00185, Roma - Italy ^dIstituto di Fotonica e Nanotecnologie - CNR, Via Cineto Romano 42, 00156, Roma - Italy ^eINFN - Laboratori Nazionali del Gran Sasso, Assergi (L'Aquila) 67010 - Italy ^fINFN - Sezione di Genova, Via Dodecaneso 33, 16146, Genova - Italy ⁸ Dipartimento di Fisica - Università degli Studi di Genova, Via Dodecaneso 33, 16146, Genova - Italy ^hLaboratorio de Fisica Nuclear y Astroparticulas, Universidad de Zaragoza, Zaragoza 50009 - Spain

Abstract

In this paper we describe the current status of the CALDER project, which is developing ultra-sensitive light detectors based on superconductors for cryogenic applications. When we apply an AC current to a superconductor, the Cooper pairs oscillate and acquire kinetic inductance, that can be measured by inserting the superconductor in a LC circuit with high meri factor. Interactions in the superconductor can break the Cooper pairs, causing sizable variations in the kinetic inductance and, thus, in the response of the LC circuit. The continuous monitoring of the amplitude and frequency modulation allows to reconstruct the incident energy with experiments the superconductor or an activation of the LC circuit. The continuous monitoring of the amplitude and frequency modulation allows to reconstruct the incident energy with experiments enhanced the experiments because the incident energy with experiments the incident energy with experiments the incident energy with conditions of the LC circuit. The continuous monitoring of the amplitude and frequency modulation allows to reconstruct the incident energy with experiments enhanced the experiments of Kilbs), that are characterized by natural aptitude excellent energy with the experiments of the incident energy with conditions of the condition of the superconductor over a wide temperature range, and ease in fabrication. We present the recharacterized by natural aptitude collaboration with 2×2 cm² substrates sampled by 1 or 4 Aluminum KIDs. We show that the performances of the first prototypes are already competitive with those of other commonly used light detectors, and we discuss the strategies for a further improvement. Keywords: Kinetic Inductance Detectors, light detectors, and we discuss the strategies for a further improvement. (of the order of all the experiments looking for rare events, such quarter and the experiments looking for rare events, such quarter and the experiment and the experiment should be a mentional proposed for these searches, cryogeni

sible solution consists in equipping the bolometer with a light detector, that enables particle identification exploiting the different light emission of α 's, electrons and nuclear recoils. This technique has been successfully exploited for bolometers emitting scintillation light, like ZnSe [1], ZnMoO₄ [2], LiMoO₄ [3]

 $(5\times5 \text{ cm}^2)$ and ease in fabricating/operating up to 1000 chan-

The growing interest in developing sensitive light detectors (that would be important also for other applications [1]) gave birth to several R&D activities exploiting different technologies [9, 10, 11]. None of these technological approaches is (yet) able to fulfill all the requirements for next generation projects.

Email address: laura.cardani@roma1.infn.it (L.Cardani)

For this reason, the CALDER (Cryogenic wide-Area Light Detectors with Excellent Resolution [12]) project proposes a new technique, based on Kinetic Inductance Detectors.

2. Phonon-mediated Kinetic Inductance Detectors

Kinetic Inductance Detectors (KIDs) are superconductors biased with an AC current [13]. The energy of the electric field applied to the superconductor is stored in the kinetic energy of Cooper pairs. The oscillation of the field and, as a consequence, of the Cooper pairs, produces an additional inductance in the superconductor, called kinetic inductance L_K . By coupling the superconductor with a capacitor, we can realize a RLC circuit, that acts like a resonator with resonant frequency $f_0 = \frac{1}{2\pi\sqrt{LC}}$. The properties of superconductors allow to fabricate resonators with typical quality factor (Q) of the order of 10^4 - 10^5 .

A photon interacting in the superconductor breaks Cooper pairs, increasing the average momentum per Cooper pair and, as a consequence, increasing L_K . Moreover, the breaking of Cooper pairs into quasiparticles increases the dissipation of the resonator, thus reducing Q. Monitoring the changes in the resonance parameters (frequency and phase) we can infer the energy that was deposited by the photon interaction. This is the working principle at the basis of KIDs that, besides an excellent energy resolution (\sim eV) bring the advantage of being naturally multiplexed in the frequency domain; this means that hundreds of KIDs can be coupled to a single read-out wire, decreasing the number of electronics channels, as well as the heat-load on the cryogenic system.

The main limit of this technology is that KIDs can feature a maximum active area of a few mm², while next generation experiments demand for light detectors with surface of tens of cm². In principle, we could realize a large area light detector with an array of hundreds of KIDs. This is not a realistic option, because photons do not interact efficiently in the superconductor and, in addition, the operation of about 1000 light detectors would require a very large number of KIDs (hundreds of thousands).

For this reason, we deposit KIDs on an insulating substrate that is used to absorb the interacting photon. The absorption of a photon produces phonons, that travel in the substrate until they are absorbed by the KIDs or lost in the substrate supports or defects. The goal of the CALDER project is proving that this approach, proposed by Swenson et al. [14] and Moore et al. [15] for other applications, allows to realize a light detector with all the characteristics required by next-generation experiments.

The project foresees three main phases. The fist stage is devoted to the development of all the necessary acquisition and analysis tools and to the optimization of the detector geometry. For this phase we decided to work with a well known material for KIDs applications, Aluminum, that will allow to reach an RMS energy resolution of about 80 eV. In the second stage we will move to more sensitive superconductors, such as TiN, Ti+TiN, or TiAl, in order to lower the energy resolution below 20 eV. Finally, we will couple the optimized light detectors to an array of TeO₂ bolometer to prove the potential of this technology.

3. Results of the first phase: Aluminum KIDs

The Aluminum prototypes, produced at Consiglio Nazionale delle Ricerche Istituto di Fotonica e Nanotecnologie (CNR-IFN, Rome, Italy), are fabricated using direct-write electron beam lithography (Vistec EBPG 5000). The resonators are deposited on high resistivity (>10 k Ω ·cm) Si(100) substrates. For the first detectors we used 275 μ m thick substrates, but we will investigate soon other thicknesses to better understand the efficiency in photons absorption and phonons propagation. The Aluminum layer is evaporated in an electron-gun evaporator that allows to deposit the desired superconductor thickness (25 or 40 nm for the detectors described later). After the lift-off, we cut the Si wafer into a 2×2 cm² chip, that is assembled in a copper structure using insulating PTFE elements, as shown in Figure 1.




Figure 1: A single Al KID deposited on a 2×2 cm² Si substrate. The chip was assembled in a copper structure using four PTFE elements.

The detectors are cooled below the critical temperature using a ${}^{3}\text{He}/{}^{4}\text{He}$ dilution refrigerator with base temperature of about 10 mK. The output signal is fed into a CITLF4 SiGe low noise amplifier [16], which is thermally anchored to the 4 K plate of the cryostat. The rest of the electronics is located at room temperature and its features, together with the description of the cryogenic facility and the acquisition software, can be found in references [12, 17, 18].

We developed several analysis tools to fit the complex transmission function S_{21} in order to extract useful parameters, like the resonance frequency, the quality factor Q, the internal and coupling quality factors Q_{int} and Q_c ($Q^{-1}=Q_{int}^{-1}+Q_c^{-1}$). Taking advantage from the analysis done by Swenson et al. [19] and Khalil et al. [20], we developed a model of the resonator that allows to extract the parameters of interest even in presence of large distortions produced, for example, by impedance mismatches between the feed-line and the chip [21].

The resonance fit allows to determine also the center and radius of the resonance loop. When an interactions occurs, the phase and amplitude of the resonance vary with respect to this reference frame, producing two readable signals. Since the phase signal $\delta\phi$ has a much better signal to noise ratio, we use

this estimator to reconstruct the energy spectrum of the detector. According to our signal model, an energy release E produces a phase variation $\delta \phi$:

$$\delta\phi = \frac{\alpha S_2(\omega, T)}{N_0 \Delta_0^2} \cdot \frac{Q}{V} \cdot \epsilon E.$$
 (1)

The first term in this formula is mainly material dependent: α is the fraction of kinetic inductance (of the order of 4–15% for Al), $S_2(\omega,T)$ is a slow function of the temperature (about 2.3–2.6 for our detectors), N_0 is the single spin density of states (for Al $1.72\times10^{10}\,\mathrm{eV}^{-1}\mu m^{-3}$), and $2\Delta_0$ is the binding energy of Cooper pairs (about $200\,\mu\mathrm{eV}$ for thin Al films). The second term, containing the resonator Q and active volume V, depends mostly on the geometry of the device and can be easily varied up to an order of magnitude. Finally, ϵ is the detection efficiency.

3.1. Efficiency optimization

To measure the efficiency of our device, we performed several tests using a 2×2 cm², $275\,\mu m$ thick Silicon substrate. The substrate was illuminated with an optical source (400 nm room-temperature LED coupled to an optical fiber) producing pulses up to ~30 keV, and with 55 Fe/ 57 Co X-rays sources with peaks between 5.9 and 14.4 keV, in order to cross-check the results. The calibration of the optical apparatus, indeed, is made with a photomultiplier at room temperature and is corrected using a Monte Carlo that accounts for the geometry of the set-up and for the optical properties of Si. On the contrary, the nominal energy of X-rays is known with high precision, allowing to investigate possible systematic errors in the calibration of optical pulses. All the sources were always placed on the back of the substrate to prevent direct illumination of the resonators.

Since we expect the efficiency to scale with the detector volume, we tested different KIDs geometries: (1) a 25 nm thick Al KID with active area of 2.4 mm², (2) a 40 nm thick KID with the same active area, and (3) a 40 nm thick KID with an increased active area of 4.0 mm². The results, reported in Table 1, were obtained by illuminating the substrate in the proximity of the resonator, or as far as possible from it.

Table 1: Number of KIDs deposited on the $2\times 2\,\mathrm{cm}^2$ Si substrate; thickness (t) and area (A) of the inductor; total detection efficiency measured with optical pulses illuminating the substrate region close to the KID (ϵ_{near}) and far from the KID (ϵ_{far}).

KIDs	$t \times A$	ϵ_{near}	ϵ_{far}
number	$[nm \times mm^2]$	[%]	[%]
1	25×2.4	2	_
1	40×2.4	7	6
1	40×4.0	11	8
4	40×2.4	18	18

According to our predictions, the geometry with the largest active volume (geometry (3)) provides the highest detection efficiency. The active volume of geometry (2) is about 60% of the one of geometry (3), and this results in a similar decrease of the efficiency. On the contrary, given the ratio between the active volume of geometry (1) and geometry (3), we would have

expected an efficiency of 4% for the 25 nm KID. Even if the errors on these values are rather large (about 20% for geometry (1) and 12% for geometry (2) and (3)), there is some tension between the expected number and the measured one, that has still to be understood. All these results were confirmed using the X-rays sources instead of the optical apparatus.

The results reported in Table 1 show also that the detection efficiency is lower when the source is placed far from the KID. This behavior can be corrected exploiting the time development of pulses: events occurring close to the KID show a larger amplitude, but also faster rise-time and faster-decay time.

Finally, we increased the number of resonators depositing 4 geometry (2) pixels on a single substrate. Summing the single efficiencies of 4 pixels of type (2) would result in an efficiency of 28%, much larger with respect to the measured one (18%). This can be explained measuring the efficiencies of the single resonators: those placed in the nearby of the source show an efficiency similar to the one of the single pixel (6-7%), while those far from the source feature a much lower efficiency, meaning that part of the signal was absorbed by the first pixels or lost through the substrate. Moving the source in another point of the substrate resulted in different efficiencies for the single pixels but, as shown in Table 1, did not cause a significant variation of the *total* efficiency of the detector. This means that the 4-pixels configuration allows to efficiently collect the produced phonons.

As a final cross-check, we varied the resonator quality factor of one order of magnitude (from 10^4 to a few 10^5), we changed the coupling of the KIDs to the feed-line (from inductive to capacitive coupling) and we doubled the thickness of the resonators feed-line to investigate other possible systematics. The results were in full agreement with those reported in Table 1, proving that our evaluation of the efficiency is robust.

3.2. Noise optimization

In parallel with the efficiency studies, we are performing a campaign devoted to the understanding and optimization of the detector noise. In the ideal case, we would expect our noise power spectrum to be dominated by the cryogenic amplifier, which contribution to the resolution scales as:

$$\sigma_E \propto \frac{N_0 \Delta_0^2}{\alpha S_2(\omega, T)} \frac{V}{Q\epsilon} \sqrt{\frac{kT_N}{P_f \tau_{qp}}}$$
 (2)

where k is the Boltzmann constant, T_N the noise temperature of the amplifier, P_f the micro-wave power at the amplifier input and τ_{qp} the time constant in which quasi-particles recombine in Cooper pairs (of the order of hundreds of μ s for these devices). As explained in the previous section, some of these parameters, like the resonator Q or the active volume, can be varied up to one order of magnitude simply changing the pixel geometry or its coupling to the feed-line. The optimization of the detector design allowed to improve the energy resolution from $\sim 150 \, \text{eV}$ [22] to about 90 eV both in the single-pixel and in the 4-pixels configuration. This value, which is already approaching the target of Phase–I (80 eV), could be further improved

by suppressing the low-frequency noise that appears in all the prototypes that have been tested up to now (see Figure 2). This noise source is likely ascribable to the electronics and is now under investigation.




Figure 2: Average noise power spectra for amplitude (dotted line) and phase (continuous line) read-out of a typical high-Q (KID-4) and a low-Q (KID-1) resonators. The flat noise is consistent with the amplifier noise. At low frequency another source of noise, not yet identified, appears in the phase noise power spectra, spoiling the energy resolution.

4. More sensitive superconductors

In the next months we will continue the tests with Al-based prototypes to further optimize the detector design and to understand all the noise contributions. In the meanwhile, we are starting the production of chips based on other, more sensitive superconductors. The resolution, indeed, scales as:

$$\Delta E \propto \frac{T_C}{\epsilon \sqrt{QL}} \tag{3}$$

thus, superconductors with lower critical temperature and higher inductance would allow to further enhance the sensitivity. Possible candidates are sub-stoichiometric Titanium Nitride (TiN), or composite superconductors such as Ti+TiN or Ti+Al, which features are shown in Table 2.

Table 2: Critical temperature T_C and inductance L for the superconductors of interest. The values of Al and TiN (α state) were measured using a film thickness of 40 nm and 80 nm respectively. The values of Ti+Al refer to a chip realized superimposing 10 nm of Ti and 25 nm of Al.

	Al	TiN	Ti+TiN	Ti+Al
		sub-stoich.		
T_C	1.2	0.5	0.5-0.8	0.6-0.9
L [pH/square]	0.5	up to 50	6	1

We have already realized a single pixel detector with geometry (3) by depositing Ti+Al (10 nm of Ti and 25 nm of Al) on a 2×2 cm² Si substrate. The first prototype, that was produced in collaboration with CSNSM (Orsay, France) and Institut Néel, CNRS (Grenoble, France), is currently being tested and shows very encouraging results.

5. Conclusion

In this paper we presented a novel technology for the development of sensitive light detectors, based on phonon-mediated

KIDs. We presented the results obtained depositing prototypes of Al KIDs with different geometries on $2\times2\,\mathrm{cm}^2$ Si substrates and we derived the detection efficiency. We evaluated the noise of the detectors and showed that the optimization of the design allowed to reach a baseline noise of about 90 eV RMS. Finally, we discussed the perspectives of this technology, explaining how more sensitive superconductors will allow to reach the target sensitivity.

Acknowledgements

This work was supported by the European Research Council (FP7/2007-2013) under contract CALDER no. 335359 and by the Italian Ministry of Research under the FIRB contract no. RBFR1269SL.

References

- J. W. Beeman, et al., Performances of a large mass ZnSe bolometer to search for rare events, JINST 8 (2013) P05021. arXiv:1303.4080, doi:10.1088/1748-0221/8/05/P05021.
- [2] J. W. Beeman, et al., Performances of a large mass ZnMoO(4) scintillating bolometer for a next generation 0vDBD experiment, Eur. Phys. J. C 72 (2012) 2142. arXiv:1207.0433, doi:10.1140/epjc/s10052-012-2142-7.
- [3] L. Cardani, et al., Development of a Li2MoO4 scintillating bolometer for low background physics, JINST 8 (2013) P10002. arXiv:1307.0134, doi:10.1088/1748-0221/8/10/P10002.
- [4] J. W. Beeman, et al., Characterization of bolometric Light Detectors for rare event searches, JINST 8 (2013) P07021. arXiv:1304.6289, doi: 10.1088/1748-0221/8/07/P07021.
- [5] F. Bellini, et al., Measurements and optimization of the light yield of a TeO₂ crystal, JINST 9 (10) (2014) P10014. arXiv:1406.0713, doi: 10.1088/1748-0221/9/10/P10014.
- [6] N. Casali, et al., TeO₂ bolometers with Cherenkov signal tagging: towards next-generation neutrinoless double beta decay experiments, Eur. Phys. J. C 75 (1) (2015) 12. arXiv:1403.5528, doi:10.1140/epjc/s10052-014-3225-4.
- [7] G. Wang, et al., R&D towards CUPID (CUORE Upgrade with Particle IDentification) (2015). arXiv:1504.03612.
- [8] G. Wang, et al., CUPID: CUORE (Cryogenic Underground Observatory for Rare Events) Upgrade with Particle IDentification (2015). arXiv: 1504.03599
- [9] K. Schaeffner, et al., Particle discrimination in TeO₂ bolometers using light detectors read out by transition edge sensors, Astropart. Phys. 69 (2015) 30-36. arXiv:1411.2562, doi:10.1016/j.astropartphys. 2015.03.008.
- [10] M. Willers, et al., Neganov-Luke amplified cryogenic light detectors for the background discrimination in neutrinoless double beta decay search with TeO₂ bolometers, JINST 10 (03) (2015) P03003. arXiv:1407. 6516, doi:10.1088/1748-0221/10/03/P03003.
- [11] M. Biassoni, et al., Large area Si low-temperature light detectors with Neganov Luke effect, Eur. Phys. J. C 75 (10) (2015) 480. arXiv:1507.08787, doi:10.1140/epjc/s10052-015-3712-2.
- [12] E. Battistelli, F. Bellini, C. Bucci, M. Calvo, L. Cardani, N. Casali, M. G. Castellano, I. Colantoni, A. Coppolecchia, C. Cosmelli, et al., CALDER: Neutrinoless double-beta decay identification in TeO₂ bolometers with kinetic inductance detectors, Eur. Phys. J. C 75 (8). arXiv:1505.01318.
- [13] P. K. Day, H. G. LeDuc, B. A. Mazin, A. Vayonakis, J. Zmuidzinas, A broadband superconducting detector suitable for use in large arrays, Nature 425 (6960) (2003) 817–821. doi:10.1038/nature02037.
- [14] L. J. Swenson, A. Cruciani, A. Benoit, M. Roesch, C. S. Yung, A. Bideaud, A. Monfardini, High-speed phonon imaging using frequency-multiplexed kinetic inductance detectors, Appl.Phys.Lett. 96 (2010) 263511. arXiv:1004.5066, doi:10.1063/1.3459142.

- [15] D. C. Moore, S. R. Golwala, B. Bumble, B. Cornell, P. K. Day, H. G. LeDuc, J. Zmuidzinas, Position and energy-resolved particle detection using phonon-mediated microwave kinetic inductance detectors, Appl.Phys.Lett. 100 (2012) 232601. arXiv:1203.4549, doi: 10.1063/1.4726279.
- [16] CITLF4 SiGe Data Sheet. http://radiometer.caltech.edu/datasheets/amplifiers/CITLF4.pdf
- [17] O. Bourrion, A. Bideaud, A. Benoit, A. Cruciani, J. F. Macias-Perez, A. Monfardini, M. Roesch, L. Swenson, C. Vescovi, Electronics and data acquisition demonstrator for a kinetic inductance camera, JINST 6 (2011) P06012. arXiv:1102.1314, doi:10.1088/1748-0221/6/ 06/P06012.
- [18] O. Bourrion, C. Vescovi, A. Catalano, M. Calvo, A. D'Addabbo, J. Goupy, N. Boudou, J. F. Macias-Perez, A. Monfardini, High speed readout electronics development for frequency-multiplexed kinetic inductance detector design optimization, JINST 8 (2013) C12006. arXiv: 1310.5891, doi:10.1088/1748-0221/8/12/C12006.
- [19] L. J. Swenson, P. K. Day, B. H. Eom, H. G. Leduc, N. Llombart, C. M. McKenney, O. Noroozian, J. Zmuidzinas, Operation of a titanium nitride superconducting microresonator detector in the nonlinear regime, J. Appl. Phys. 113 (2013) 104501. arXiv:1305.4281, doi:10.1063/1.4794808.
- [20] M. S. Khalil, M. J. A. Stoutimore, F. C. Wellstood, K. D. Osborn, An analysis method for asymmetric resonator transmission applied to superconducting devices, J. Appl. Phys. 111 (2012) 054510. doi:10.1063/ 1.3692073.
- [21] N. Casali, et al., Characterization of the KID-Based Light Detectors of CALDER, Journal of Low Temp. Phys.arXiv:1511.05038, doi:10. 1007/s10909-015-1358-y.
- [22] L. Cardani, et al., Energy resolution and efficiency of phonon-mediated Kinetic Inductance Detectors for light detection, Appl. Phys. Lett. 107 (2015) 093508. arXiv:1505.04666, doi:10.1063/1.4929977.