

We are IntechOpen, the world's leading publisher of Open Access books Built by scientists, for scientists

4,800

Open access books available

122,000

International authors and editors

135M

Downloads

Our authors are among the

154

Countries delivered to

TOP 1%

most cited scientists

12.2%

Contributors from top 500 universities



WEB OF SCIENCE™

Selection of our books indexed in the Book Citation Index
in Web of Science™ Core Collection (BKCI)

Interested in publishing with us?
Contact book.department@intechopen.com

Numbers displayed above are based on latest data collected.
For more information visit www.intechopen.com



Clustering, Classification and Explanatory Rules from Harmonic Monitoring Data

Ali Asheibi, David Stirling, Danny Sutanto and Duane Robinson
*The University of Wollongong
 Australia*

1. Introduction

With the increased use of power electronics in residential, commercial and industrial distribution systems, combined with the proliferation of highly sensitive micro-processor controlled equipment, a greater number of distribution customers are becoming sensitive to excessive harmonics in the supply system. In industrial systems for example, harmonic losses can increase the operational cost and decrease the useful life of the system equipment (Lamedica, et al., 2001). For these reasons, large industrial and commercial customers are becoming proactive with regards to harmonic monitoring. The deregulation in the utility industry makes it necessary for some utilities to carry out extensive harmonic monitoring programs to retain current customers and targeted new customers by ensuring disturbance levels remain within predetermined limits (Dugan, et al. 2002). This will lead to a rapid escalation of harmonic data that needs to be stored and analysed.

Utility engineers are now seeking new tools in order to extract information that may otherwise remain hidden within this large volume of data. Data mining tools are an obvious candidate for assisting in such analysis of large scale data. Data mining can be understood as a process that uses a variety of analysis tools to identify hidden patterns and relationships within data. Classification based on clustering is an important unsupervised learning technique within data mining, in particular for finding a variety of patterns and anomalies in multivariate data through machine learning techniques and statistical methods. Clustering is often used to gain an initial insight into complex data and particularly in this case, to identify underlying classes within harmonic data. Many different types of clustering have been reported in the literature, such as: hierarchical (nested), partitioned (un-nested), exclusive (each object assigned to a cluster), non-exclusive (an object can be assigned to more than one cluster), complete (every object should belong to a cluster), partial (one or more objects belong to none), and fuzzy (an object has a membership weight for all clusters) (Pang, et al., 2006).

A method based on the successful AutoClass (Cheeseman & Stutz, 1996) and the Snob research programs (Wallace & Dowe, 1994); (Baxter & Wallace, 1996) has been chosen for our research work on harmonic classification. The method utilizes mixture models (McLachlan, 1992) as a representation of the formulated clusters. This research is principally based on the formation of such mixture models (typically based on Gaussian distributions) through a Minimum Message Length (MML) encoding scheme (Wallace & Boulton, 1968). During the formation of such mixture models the various derivative tools (algorithms) allow

Source: Theory and Novel Applications of Machine Learning, Book edited by: Meng Joo Er and Yi Zhou, ISBN 978-3-902613-55-4, pp. 376, February 2009, I-Tech, Vienna, Austria

for the automated selection of the number of clusters and for the calculation of means, variances and relative abundance of the member clusters. In this work a novel technique has been developed using the MML method to determine the optimum number of clusters (or mixture model size) during the clustering process. Once the optimum model size is determined, a supervised learning algorithm is employed to identify the essential features of each member cluster, and to further utilize these in predicting which ideal clusters any new observed data may best described by.

This chapter first describes the design and implementation of the harmonic monitoring program and the data obtained. Results from the harmonic monitoring program using both unsupervised and supervised learning techniques are then analyzed and discussed.

2. Harmonic monitoring program

A harmonic monitoring program (Gosbell et al., 2001); (Robinson, 2003) was installed in a typical 33/11kV MV zone substation in Australia that supplies ten 11kV radial feeders. The zone substation is supplied at 33kV from the bulk supply point of a transmission network. Fig. 1 illustrates the layout of the zone substation and feeder system addressed with this harmonic monitoring program.

Seven monitors were installed; a monitor at each of the residential, commercial and industrial sites (sites 5-7), a monitor at the sending end of the three individual feeders (sites 2-4) and a monitor at the zone substation incoming supply (Site ID 1). Sites 1-4 in Fig. 1 are all within the substation at the sending end of the feeders identified as being of a predominant load type. Site 5 was along the feeder route approximately 2km from the zone substation, feeds residential area. Site 6 supplies a shopping centre with a number of large supermarkets and many small shops. Site 7 supplies factory manufacturing paper products such as paper towels, toilet paper and tissues.

Based on the distribution customer details, it was found that Site 2 comprises 85% residential and 15% commercial, Site 3 comprises 90% commercial and 10% residential and Site 4 comprises 75% industrial, 20% commercial and 5% residential.

The monitoring equipment used is the EDMI Mk3 Energy Meter from Electronic Design and Manufacturing Pty. Ltd. (EDMI, 2000). Three phase voltages and currents at sites 1-4 were recorded at the 11kV zone substation and at the 430V sides of the 11kV/430V distribution transformers at sites 5-7, as shown in Fig. 1. The memory capabilities of the above meters, at the time of purchase limited recordings to the fundamental current and voltage in each phase, the current and voltage Total Harmonic Distortion (THD) in each phase, and three other individual harmonics in each phase.

For the harmonic monitoring program, the harmonics selected for recording were the 3rd, 5th and 7th harmonic currents and voltages at each monitoring site, since these are typically the most significant harmonics. The memory restrictions of the monitoring equipment dictated that the sampling interval would be constrained to 10 minutes. This follows the suggested measurement time interval by the International Electrotechnical Commission (IEC) standard as given in IEC61000-4-30 for harmonic measurements, inter-harmonic and unbalances waveforms. The standard is regarded as best practice for harmonic measurement and it recommends 10 minute aggregation intervals for routine harmonic survey. Each 10 minute data sample represents the aggregate of the 10-cycle rms (root mean squared) magnitudes over the 10 minutes period. A recent study (Elphick, et al., 2007) suggested that statistically, sampling at faster rate will not provide additional significant extra insight.




Fig. 1. Single line diagram illustrating the zone distribution system.

The data retrieved from the harmonic monitoring program spans a period from August 1999 to December 2002. Figs. 2 and 3, show a typical output data from the monitoring equipment of the fundamental, 3rd, 5th and 7th harmonic currents in Phase 'a' at sites 1 and 2, taken on 12 - 19 January 2002 showing a 10-min maximum fundamental current of 1293 Amps and minimum fundamental current of 435 Amps. It is obvious that for the engineers to realistically interpret such large amounts of data, it will be necessary to cluster the data into meaningful segments.




Fig. 2. Zone substation (Site 1) weekly harmonic current data from the monitoring equipment.

3. Minimum Message Length (MML) technique in mixture modelling method

The MML technique and mixture modelling was initially developed by Wallace and Boulton in 1968 through their classification program called Snob (Wallace & Boulton, 1968). The program was successfully used to classify groups of six species of fur seals. Since then, the program has been extended and utilised in different areas, such as psychological science, health science, bioinformatics, protein and image classification (Agusta, 2004). Mixture Modelling Methods using MML technique have also been applied to other real world problems such as human behaviour recognition and the diagnosis of complex issues in industrial furnace control (Zulli & Stirling, 2005).




Fig. 3. Residential feeder (Site 2) weekly harmonic Current data from the monitoring equipment.

The Minimum Message Length inductive inference methodology seeks to identify efficient models by evaluating the size of a hypothetical message that describes each model together with any data which does not fit to the supposed model (exceptions). By evaluating this message length, the algorithm is able to identify, from a sequence of plausible models, those that yield an incrementally improving efficiency, or reducing size. The general concept here is that the most efficient model, describing the data will also be the most compact. Compression methods generally attain high densities by formulating efficient models of the data to be encoded.

The encoded message here consists of two parts. The first of these describes the model and the second describes the observed data given that model. The model parameters and the data values are first encoded using a probability density function (pdf) over the data range and assume a constant accuracy of measurements (Aom) within this range. The total encoded message length for each different model is then calculated and the best model (shortest total message length) is selected. The MML expression is given as:

$$L(D, K) = L(K) + L(D/K) \quad (1)$$

where:

- K : mixture of clusters in model
 L (K) : the message length of model K
 L(D/K) : the message length of the data given the model K
 L (D, K) : the total message length

Initially given a data set D, the range of measurement and the accuracy of measurement for the data set are assumed to be available. The message length of a mixture of clusters each assuming to have Gaussian distributions with their own mean (μ) and variance (σ) can be calculated as follows: (Oliver & Hand, 1994).

$$L(K) = \log_2 \frac{\text{range}_\mu}{AOPV_\mu} + \log_2 \frac{\text{range}_\sigma}{AOPV_\sigma} \quad (2)$$

where:

range_μ : range of possible μ values

range_σ : range of possible σ values

$AOPV_\mu$: accuracy of the parameter value of μ

$$AOPV_\mu = \bar{s} \sqrt{\frac{12}{N}} L(D, K) = L(K) + L(D/K) \quad (3)$$

\bar{s} : unbiased sample standard deviation

$$\bar{s} = \sqrt{\frac{1}{(N-1)} \sum_{i=1}^n (x_i - \bar{x})^2} \quad (4)$$

N : number of data samples

\bar{x} : the sample mean

x_i : data points

$AOPV_\sigma$: accuracy of the parameter value of σ

$$AOPV_\sigma = \bar{s} \sqrt{\frac{6}{N-1}} \quad (5)$$

The message length of the data using Gaussian distribution model can be calculated from the following equation (Oliver & Hand, 1994):

$$L(D/K) = N \log_2 \frac{\bar{s} \sqrt{2\pi}}{Aom} + N \frac{s^2 + \frac{\bar{s}^2}{N}}{2\bar{s}^2} \log_2(e) \quad (6)$$

where:

Aom: accuracy of measurement

s : sample standard deviation

$$s = \sqrt{\frac{1}{N} \sum_{i=1}^n (x_i - \bar{x})^2} \quad (7)$$

An example of how the Mixture Modelling Method using MML technique works, can be illustrated by applying the method to a small data set that contained five distinct distributions of data points (D's) each of which were randomly generated (D1, D2, ..., D5), with its own mean and standard deviation. The generated clusters that were subsequently correctly identified through the MML algorithm are shown in Table 1 and the normal distributions of these clusters are superimposed on the data as shown in Fig. 4.

Cluster	Mean (μ)	SD (σ)
s0	1.021899	0.278162
s1	4.00873	0.616833
s2	7.910658	0.980416
s3	11.86431	1.146317
s4	16.05827	1.446599

Table 1. The parameters (μ and σ) of the five generated clusters.




Fig. 4. Five randomly generated clusters each with its own mean and standard deviation.

This mixture modelling approach using the MML technique was used for harmonics classification to discover similar groups of records in the harmonic database; this included clustering the harmonic data from the test system described in section 2. ACPro, a specialised data mining software tool for the automatic segmentation of databases, was primarily used in this work. The preparation of the harmonic data and clustering process are explained in the next section.

3.1 Data preparation and clustering

The dominant harmonic currents and voltages attributes identified in Section 2 (3rd, 5th, 7th and THD) were selected from the four different sites; Substation (Site 1), residential (Site 5), commercial (Site 6) and industrial (Site 7) — as per Fig. 1. The resulting data set used in this

application is one file of 8064 instances which consists of four combined files (4×2016) from the selected sites taken from 12-25 January 2002 inclusive. This data was normalised by dividing each data point by the typical values of each corresponding attribute. The suggested typical value for the harmonic currents is the maximum value whereas for the harmonic voltage is the average value. The maximum value of the harmonic current attributes and the average value of harmonic voltage after normalisation is one. The normalised attributes were selected as input features to the MML algorithm with a given accuracy of measurement (Aom) for each attribute. The number of clusters obtained was automatically determined based on the significance and confidence placed in the measurements, which can be estimated using the entire set of measured data. Each cluster contains a collection of data instances that have been so assembled according to an inferred (learnt) pattern, and the abundance of each group is calculated over the full data range. The abundance value for each cluster represents the proportion of data that is contained in the cluster in relation to the total data set. If for example, only one cluster was formed then the single cluster abundance value will be 100%. Each generated cluster can therefore be considered as a profile of the twelve variables (being the 3rd, 5th, 7th and THD for each of 3 phases) within an acceptable variance. If new data lies beyond the clusters associated variance, another cluster is created. Using a basic spreadsheet tool the clusters are subsequently ordered inversely proportional to the actual abundance, i.e. the most abundant cluster is seen as, *s0*, and those that are progressively rarer have a high value type numbers.

4. Results and outcomes

The following section provides an array of results and outcomes relating to the mixture modelling afforded by the MML clustering algorithm, as well as other associated techniques. These include the detection of anomalous patterns within the harmonic data and, the simplification or transforming of the mixture model through an abstraction process. Without knowing in advance the appropriate size for a mixture model, i.e. its ideal number of clusters, abstraction to a fewer number of super groups, often assists in perceiving the associated contexts each super group. A range of detail applications illustrates this approach. Subsequent insights arising from these operations have lead to a novel outcome allowing for the prior identification of the correct model size for the harmonic data. Further inspection of interesting clusters or super groups is also facilitated through the use of supervised learning, wherein an essential (or minimal) set of influencing factors behind each is derived in a symbolic form.

4.1 Anomaly detection and pattern recognition

Initially six clusters were specified as input parameters to the MML data mining program, with cluster *s5* having the least abundance at 6%. However, the value (mean) of the fifth harmonic in this cluster is at its maximum for all of the data. This cluster (*s5*) acquires its importance from both the high value of the fifth harmonic current (CT1_Harm_5) and its least number of occurrences. The second highest value of the fifth harmonic current is associated with cluster *s1* at 0.78 of the maximum value an abundance of 22%. This cluster might be as important as *s5* because it has high fifth harmonic current with a high frequent rate nevertheless the fundamental current (CT1_Fund) is very low.

The concept of rare clusters may also be used to identify the most significant distorting loads at different customer sites. Fig. 6 illustrates a mosaic of patterns of the six clusters (see

Fig. 5) over the period of one week at sites 1, 5, 6 and 7 that are represented in Fig. 1. Here, all clusters are represented as a certain shades of grey in proportion to the abundance of each cluster, i.e. the least abundant cluster (s_5) will appear as black and the most abundant cluster (s_0) will be the lightest shade of grey. Noticeable characteristics from Fig. 6 include the two distinctive darker patterns towards the left hand side of the Medium Voltage




Fig. 5. Fundamentals and 5th harmonic current clusters in a single phase.




Fig. 6. Clusters of harmonic emissions from the different customer loads and system overall for a one week period.

(MV) 33/11 kV substation data (Site 1). This indicates that the least abundant occurrences appear during the mornings of the weekend days. Also the commercial site, Site 6, exhibits a recurring pattern of harmonics over each day, noting that the shopping centre is in operation seven days a week. The industrial site (site 7) shows that there is a distinctly different pattern on weekend than during weekdays. The residential customer clusters (site 5) are somewhat more random than the other sites, suggesting that harmonic emission levels in this site follow no well defined characteristics.

4.2 Abstraction of super groups

From the results from the previous section it can be observed that data mining can become a useful tool for identifying additional information from the harmonic monitoring data, beyond that which is obtained from standard reporting techniques.

Further additional information can be retrieved by using the Kullback-Lieber (KL) distance (Duda et al., 2001) which is a measure of similarities and dissimilarities between any two distributions (clusters). A multidimensional scaling algorithm (MDS) is utilised to process the resultant KL distances. This enables the generation a 2D geometric visualization (interpretation) in conjunction with an interactive link analysis, which can ultimately suggest what combinations of clusters, and neighbourhoods of clusters, could be merged to form various (fewer) super-groups.

To explain the concept of super-groups, a subset of the harmonic data described in Section 2 being (3rd, 5th, and 7th) from different sites (1, 5, 6, 7) was used as selected attributes for the MML segmentation. This time ACPro was allowed to determine the number of clusters itself resulting in eleven clusters ($s_0, s_1, s_2... s_{10}$). A detail of the abundances, means and standard deviations of the 5th harmonic current across these 11 clusters is illustrated in Fig. 7. The Kullback-Lieber tool in ACPro is applied on the model to generate the lower triangular 11×11 matrix of KL-distances shown in Table 2.




Fig. 7. Abundance, mean and standard deviation for each cluster of 5th harmonic current in phase 'a'.

s0											
s1	2674										
s2	832	232									
s3	62	3186	1157								
s4	181	2486	941	178							
s5	59	1077	358	185	127						
s6	51	1277	361	173	169	37					
s7	51	2518	871	107	155	58	142				
s8	102	2773	1003	113	169	145	201	39			
s9	450	1486	612	519	649	194	234	471	365		
s10	115	867	332	233	153	34	107	36	70	116	
	s0	s1	s2	s3	s4	s5	s6	s7	s8	s9	s10

Table 2. Kullback-Lieber distances between components of the 11 cluster mixture model.

The highlighted distance values represent the three largest and the three smallest distance values. For example, the distance between $s3$ and $s1$ is given as 3186, which is the largest distance, which suggests that there is a considerable difference between these two clusters, while on the other hand the distance between $s10$ and $s5$ is only 34, which suggests that there is a lot of similarity between these two clusters.

The links between all clusters, based on the KL-distances, were visualized using a multi dimensional scaling (MDS) program (Interlink, 2007), which effectively reduces an 11-dimensional model into a two dimensional representational graph. The resulting super-groups were subsequently formed by removing any link whose distance exceeds a certain threshold. The obtained super-groups (A, B, C, D and E) are shown in Fig. 8.




Fig. 8. Super-group abstraction by MDS.

Most of the super-group abstractions are formed based on the site type, for example supergroup A covers the industrial site, supergroup D covers the substation site, supergroup C and E covers the commercial sites, with supergroup C being separated

because the distances between s_9 with s_2 and s_9 with s_1 are larger than the distance between s_1 with s_2 . Super-group B is formed from clusters containing data from all sites. The residential site does not seem to have a particular supergroup which means that the influence of harmonic emission (or participation) from this site is very low. The concurrences of two or more of these super-groups at different sites indicate that there is a mutual harmonic effect between those sites at that particular time. For example, a temporal correspondence of super-group A at the industrial site can be observed with both super-group D at the substation site and super-group E at the commercial site early in the morning of each day as shown in Fig. 9. The associated pattern of harmonic factors that might exist in the formation of these super-groups can, in future, be extracted using the classification techniques of supervised learning.

4.3 Detection of harmonic events

The number of the clusters in the previous sections was either specified as input parameters to the MML data mining program or automatically generated by the program itself given a data set D and its accuracy of measurement, A_{om} . In this section, however, the message length criterion of the MML is utilized to choose the model (number of clusters) that best represent the data. The smaller the encoded message length the better the model fits the data. Therefore the program was controlled to produce a series of models each with an increasing number of clusters for the same fixed values of A_{om} , and the message lengths of these models have been plotted against the number of clusters as shown in Fig. 10.




Fig. 9. Super-groups in all sites over one week.

In this case, the best model to represent the data was identified as that with six clusters. The reasoning behind selecting this number of clusters is that the decline in the message length

significantly decreases when the model size reaches 6 clusters, and the message length is comparatively constant afterward as shown in Fig. 10. In other words, this can be considered to represent the first point of minimum sufficiency for the model.




Fig. 10. Message length vs. number of generated clusters.

Using a basic spreadsheet tool the clusters are subsequently sorted in ascending order (s_0 , s_1 , s_2 , s_3 , s_4 and s_5) based on the mean value of the fundamental current, such that cluster s_0 is associated with the lighter off peak loads period whilst cluster s_5 related to the heavier on-peak load periods as shown in Fig. 11. The mean value (μ) of the fundamental, 5th and 7th currents along with the standard deviation (σ) and the abundance (π) of each model cluster are detailed in Table 3.




Fig. 11. Clusters obtained superimposed on the phase 'a' fundamental waveform at substation site.

Cluster	Abundance (π)	Fundamental current		5th Harmonic current		7th Harmonic current	
		Mean (μ)	SD (σ)	Mean (μ)	SD (σ)	Mean (μ)	SD (σ)
s0	0.068386	0.096571	0.041943	0.165865	0.130987	0.062933	0.022882
s1	0.155613	0.106102	0.061533	0.445056	0.123352	0.250804	0.127779
s2	0.056779	0.1694	0.093434	0.300385	0.14996	0.115216	0.028599
s3	0.090994	0.35053	0.132805	0.308374	0.120799	0.330834	0.142327
s4	0.342654	0.38735	0.123757	0.524376	0.193181	0.604311	0.18195
s5	0.285559	0.728608	0.095226	0.5218	0.191722	0.516901	0.149544

Table 3. Generated model detailing the abundance value (π) of the six cluster a long with the mean (μ) and standard deviation (σ).

Each generated cluster can therefore be considered as a profile of the three variables (fundamental, 5th and 7th harmonic currents) within an acceptable variance. If new data lies beyond this variance, additional clusters are created until all of the data is enclosed within the generated model as shown in Fig. 12.




Fig. 12. Graphical profile view of model clusters indicating the statistical parameters mean (μ), standard deviation (σ) and abundance (π).

Despite the cluster labels having no specific meaning when initially generated, one can appreciate the benefit of their visual profiles in conjunction with previous sorting process, in particular one can see that cluster *s5* not only has the highest fundamental current, but also the highest 5th harmonic current. This infers that the high 5th harmonic currents are due to an overloading condition. Fig. 12 also highlights that cluster *s2* (and to a lesser extent *s0*) have a very low abundance. These may be viewed as anomalous, and potentially

problematic clusters as described later. Two of these clusters ($s5$, $s2$) are further examined to identify different operating conditions based on the various attributes used in the data (fundamental, 5th and 7th harmonic currents) as follows:

4.3.1 Cluster $s5$ at residential site

Fig. 13 illustrates the difference in harmonic clusters at residential site between the normal weather days and the hot days. In this polar coordinate plot the variable magnitude represented by the length of the radius vector of the circle whereas the angle from the x-axis to the radius vector represents the time of the day. It is evident that the MML has identified $s5$ cluster occurring more often at daytime during the hot period compared to the days when the temperature is relatively mild. It can also be observed from Fig. 13, that there is a period of peak load (cluster $s5$) around midnight, and following discussion with the utility engineer, we were informed that this is related to turning-on of the off-peak water heaters.




Fig. 13. Normal and hot days at residential site (Site 2).

4.3.2 Cluster $s5$ at industrial site

The 5th harmonic current at industrial site (Site 4) in different days of the week is shown in Fig. 14. On Saturday, for example, cluster $s5$ is only present from early morning to early in the afternoon which may indicate that an industrial process that could produce the levels of 5th harmonic current, that characterize this cluster, has been terminated at around 2 pm.




Fig. 14. 5th harmonic current clusters at industrial site for different week days.

On Sunday however, the cluster s_5 has disappeared inferring that these loads were off. These loads were on again during the weekday at day and night time showing the long working hours in this small factory at the weekdays. Similar results of the 5th harmonic current can be seen at the commercial site, see Fig. 15.




Fig. 15. 5th harmonic current clusters at commercial site for two different week days.

4.3.3 Cluster s_2 at substation site.

Generally by examining the behaviour of MML model classifications (based on the recorded data) one is able to attribute further meaning to each of its cluster components (Asheibi, 2006). For example, it is noted that there are several sudden changes to cluster s_2 at particular time instances during the day. It appears from Fig. 16(b) that this is due to sudden changes in the 7th harmonic current. After further investigation of the reactive power (MVar) measurement at the 33kV side of the power system shown in Fig. 16(c), it can be deduced that the second cluster (s_2) is related to a capacitor switching event. Early in the morning, when the system MVar demand is high as shown in Fig. 16(c), the capacitor is switched on in the 33kV side to reduce bus voltage and late at night when the system MVar demand is low, the capacitor is switched off to avoid excessive voltage rise. By just observing the fundamental current, it is

difficult to understand why the second cluster has been generated. The 7th harmonic current and voltage plots as shown in Fig. 16(b) provides a clue that something is happening during cluster *s2*, in that the 7th harmonic current increases rapidly and 7th harmonic voltage decreases, although the reason is still unknown. In this case, the clustering process correctly identified this period as a separate cluster compared to other events, and this can be used to alert the power system operator of the need to understand the reasoning for the generation of such a cluster, particularly when considering the fact that the abundance value for *s2* is quite low (5%). When contacted, the operator identified this period as a capacitor switching event which can be verified from the MVAR plot of the system (which was not used in the clustering algorithm). The capacitor switching operation in the 33kV side can also be detected at the other sites (sites 2, 3 and 4) at the 11kV side.




Fig. 16. Clusters at substation site in two working days (a) Clusters superimposed on the fundamental current waveform, (b) 7th harmonic current and voltage data. (c) MVAR load at the 33kV.

4.4 Determination of the optimum number of clusters in harmonic data

Determining the optimum number of clusters becomes important since overestimating the number of clusters will produce a large number of clusters each of which may not necessarily represent truly unique operating conditions, whereas underestimation leads to only small number of clusters each of which may represent a combination of specific events. A method is developed to determine the optimum number of clusters, each of which represents a unique operating condition. The method is based on the trend of the exponential difference in message length when using the MML algorithm. The MML states

that the best theory or model K is the one that produces the shortest message length of that model and data D given that model. From information theory, minimizing the message length in an MML technique is equivalent to maximizing the posterior probability in Bayesian theory (Oliver, et al. , 1996). This posterior probability of Bayes' theorem is given by:

$$\text{Prob}(D|K) = \frac{\text{Prob}(K)*L(D/K)}{\text{Prob}(D)} \quad (8)$$

Since the minimum message length in (1), is equivalent to the maximum posterior probability in (8), this yields:

$$L(D|K) = \text{Prob}(D|K) \quad (9)$$

This suggests that the message length declines as more clusters are generated and hence the difference between the message lengths of two consecutive mixture models is close to zero as it approaches its optimum value and stays close to zero. A series of very small values of the difference of the message length of two consecutive mixture models can then be used as an indicator that an optimum number of clusters has been found. Further, this difference can be emphasised by calculating the exponential of the change in message length for consecutive mixture models, which in essence represents the probability of the model correctness $\text{prob}(D|K)$. If this value remains constant at around 1 for a series of consecutive mixture models then the first time it reaches this value can be considered to be the optimum number of clusters.

To illustrate the use of the exponential message length difference curve on determining the optimal number of clusters for the harmonic monitoring system described in Section 2, the measured fundamental, 5th and 7th harmonic currents from sites 1, 2, 3 and 4 in Fig.1 (taken on 12 -19 January 2002) were used as the input attributes to the MML algorithm (here ACPro). The trend in the exponential message length difference for consecutive pairs of mixture models is shown in Fig. 17.

Here, the exponential of the message length difference does not remain at 1 after it initially approaches it, but rather oscillates close to 1. This is because the algorithm applies various heuristics in order to avoid any local minima that may prevent it from further improving the message length. Once the algorithm appears to be trapped at the local minima, ACPro tries to split, merge, reclassify and swap the data in the clusters found so far to determine if by doing so it may result in a better (lower) message length. This leads to sudden changes to the message length and more often than not, the software can generate large number of clusters which are generally not optimum.

This results in the exponential, message length difference deviating away from 1 to a lower value, after which it gradually returns back to 1. To cater for this, the optimum number of clusters is chosen when the exponential difference in message length first reaches its highest value. Using this method, it can be concluded that the optimum number of cluster is 16, because this is the first time it reaches its highest value close to 1 at 0.9779. With the help of the operation engineers, the sixteen clusters detected by this exponential method were interpreted as given in Table 4. It is virtually impossible to obtain these 16 unique events by visual observation of the waveforms shown in Fig. 18.




Fig. 17. Exponential curve detect sixteen clusters of harmonic data.

Cluster	Event
s0	5th harmonic loads at Substation due to Industrial site
s1	Off peak load at Substation site
s2	Off peak load at Commercial site
s3	Off peak at load Commercial due to Industrial
s4	Off peak at Industrial site
s5	Off peak at Substation site
s6 and s7	Switching on and off of capacitor at Substation site
s8	Ramping load at industrial site
s9	Switch on harmonic load at Industrial
s10	Ramping load at Residential site
s11	Ramping load at Commercial site
s12	Switching on TV's at Residential site
s13	Switching on harmonic loads at Industrial and Residential
s14	Ramping load at Substation due to Commercial
s15	On peak load at Substation due to Commercial

Table 4. The 16 clusters by the method of exponential difference in message length.

4.5 Classification of the optimal number of clusters in harmonic data

The C5.0 algorithm classification tool was applied to the measured data set and the sixteen generated clusters, obtained from the previous section, as class labels to this data. The C5.0 algorithm is an advanced supervised learning tool with many features that can efficiently induce plausible decision trees and also facilitate the pruning process. The resulting models can either be represented as tree-like structures, or as rule sets, both of which are symbolic and can be easily interpreted. The usefulness of decision trees, unlike neural networks, is that it performs classification without requiring significant training, and its ability to generate a visualized tree, or subsequently expressible and understandable rules.




Fig. 18. Sixteen clusters superimposed on four sites (a) Substation, (b) Residential, (c) Commercial and (d) Industrial.

Two main problems may arise when applying the C5.0 algorithm on continuous attributes with discrete symbolic output classes. Firstly, the resulting decision tree may often be very large for humans to easily comprehend as a whole. The solution to this problem is to transform the class attribute, of several possible alternative values, into a binary set including the class to be characterised as first class and all other classes combined as the second class. Secondly, too many rules might be generated as a result of classifying each data point in the training data set to belong to which recognized cluster. To overcome this problem, the data is split into ranges instead of continuous data. These ranges can be built from the average parameters (mean (μ), standard deviation (σ)) of data distributions as listed in Table 5 and visualised in Fig. 19.

Range	Range Name
$[0 , \mu-2*\sigma]$	Very Low (VL)
$[\mu-2*\sigma , \mu-\sigma]$	Low (L)
$[\mu-\sigma , \mu+\sigma]$	Medium (M)
$[\mu+\sigma , \mu+2*\sigma]$	High (H)
$[\mu+2*\sigma , 1]$	Very High (VH)

Table 5. The continuous data is grouped into five ranges.




Fig. 19. The five regions of Gaussian distribution used to convert the numeric values.

4.6 Rules discovered from the optimum clusters using decision tree

Using the symbolic values (VL, L, M, H and VH) of input attributes (fundamental, 5th and 7th harmonic current) and the binary sets of classes $\{(s0, other), (s1, other) \dots (s15, other)\}$ the C5.0 algorithm has been applied to as much times as the number of clusters (16 times) to uncover and define the minimal expressible and understandable rules behind each of the harmonic-level contexts associated with each of the sixteen cluster described in Section 4.4. Samples of these rules is shown in Table 6 for both *s12* which has been identified as the cluster associated with switching on TV's at the residential site and *s13* which is a cluster encompassing the engagement of other harmonic loads at both industrial and residential sites. The quality measure of each rule is described by two numbers (m, n) shown in Table 6, in brackets, preceding the description of each rules, where:

- m: the number of instances assigned to the rule and
- n: the proportion of correctly classified instances.

For this process some 66% of the data has been used as the training set and the rest (33%) was used as test set, as generally the larger proportion of data used in training the better the result will be, however care needs to be exercised to avoid overtraining. The accuracy of the test data was reasonably close to that of the training data for most of the clusters. The full data set was also tested and resulted in the same accuracy level as sample data. Table 7 shows the accuracy levels for cluster *s7*, *s8*, *s9* and *s10*. The utilization of these rules on new data sets is explained in the next section.

Rules for <i>s12</i> - contains 3 rule(s)		
Rule 1 for <i>s12</i> (513, 0.891)	Rule 2 for <i>s12</i> (523, 0.874)	Rule 3 for <i>s12</i> (10, 0.583)
if Fund_I = M and 5th_I = VH then <i>s12</i>	if 5th_I = VH then <i>s12</i>	if 5th_I = H and 7th_I = VH then <i>s12</i>
Rules for <i>s13</i> - contains 1 rule(s)		
Rule 1 for <i>s13</i> (1,572, 0.622) if Fund_I = M and 5th_I = H then <i>s13</i>		

Table 6. The generated Rules by C 5.0 for clusters 12 and 13.

Cluster ID	Data sets (January-April)		
	Training (66%)	Testing (33%)	Full data
<i>s7</i>	92.52	91.67	90.91
<i>s8</i>	92.11	91.67	91.46
<i>s9</i>	79.04	80.22	79.50
<i>s10</i>	94.55	95.36	94.04

Table 7. Model accuracy levels of training, test data and data sets for the cluster *s7*-*s10*.

4.7 The C5.0 rules for prediction of harmonic future data

The generated rules of the C5.0 algorithm used for classifying the optimum clusters have also been used for prediction. Several available harmonic data from different dates were used for this purpose. Data of the same period from another year (Jan-Apr 2001) and data from different time of the year (May-Aug 2002) were used to test the applicability of the generated rules. The model accuracy (see Fig. 20) for the similar data was considerably high whereas in different period data it was not always the case. This is due to fact that the algorithm performs well when the range of training data and test data are the same, but when these ranges are mismatched then the model will perform poorly and hence the accuracy of the future data (unseen data during training) will be low.




Fig. 20. Prediction Model accuracy levels for the clusters s7-s10 on training and future data.

5. Conclusion

Harmonic data from a harmonic monitoring program in an Australian medium voltage (MV) distribution system containing residential, commercial and industrial customers has been analyzed using data mining techniques. Unsupervised learning, and in particular, cluster analysis using MML, which searches for the best model describing the data using a metric of an encoded message, has been shown to be able to detect anomalies and identify useful patterns within the monitored harmonic data set. The output of the clustering process has to be appropriately displayed and interpreted in relation to the problem domain so that utility engineers can provide the relevant information. The technique presented in this work allows utility engineers to detect unusual harmonic events from monitored sites, using clustering, and then to subsequently characterize the obtained clusters using the classification techniques to infer information about future harmonic performance at the monitored sites.

The C5.0 algorithm has been used to generate expressible and understandable rules characterising each cluster without requiring significant data training. The optimal number of clusters in different types of data sets was investigated using a proposed method based on the trend of the exponential difference in message length between two consecutive mixture models. Testing this method using various two-weekly data sets from the harmonic monitoring data over three year period show that the suggested method is effective in

determining the optimum number of clusters in harmonic monitoring data. The continuous data has been split into ranges to avoid too many rules that might be generated. The C5.0 algorithms were then used to generate considerable number of rules for classification and prediction of the optimum clusters.


6. References

- Agusta, Y. (2004). Minimum Message Length Mixture Modelling for Uncorrelated and Correlated Continuous Data Applied to Mutual Funds Classification, *PhD Thesis*, Monash University, Clayton, Victoria, Australia.
- Asheibi, A., Stirling, D. and Soetanto, D. (2006). *Analyzing Harmonic Monitoring Data Using Data Mining*. In Proc. Fifth Australasian Data Mining Conference (AusDM2006), Sydney, Australia. CRPIT, 61. Peter, C., Kennedy, P.J., Li, J., Simoff, S.J. and Williams, G.J., Eds., ACS. 63-68.
- Cheeseman, P.; Stutz, J. (1996). Bayesian Classification (AUTOCLASS): Theory and Results, In *Advances in Knowledge Discovery and Data Mining*, Fayyad, U.; Piatetsky-Shapiro, G.; Smyth, P.; Uthurusanny, R., eds, pp. 153-180, AAAI press, Menlo Park, California.
- Elphick, S.; Gosbell, V. & Perera, S. (2007). The Effect of Data Aggregation Interval on Voltage Results, *Proceedings of Australasian Universities Power Engineering Conference AUPEC07*, Dec. 2007, Perth, Australia, Paper 15-02
- Gosbell, V.; Mannix, D.; Robinson, D. ; Perera, S. (2001) Harmonic Survey of an MV distribution system, *Proceedings of Australasian Universities Power Engineering Conference*, pp. 338-342, 23-26 September 2001, Perth, Australia.
- Interlink, Knowledge Network Organising Tool (2007), KNOT, 24 August, 2007. <http://www.interlinkinc.net/KNOT.html>,
- Lamedica, R.; Esposito, G.; Tironi, E.; Zaninelli, D. & Prudenzi, A. (2001) A survey on power quality cost in industrial customers. *Proceedings of IEEE PES Winter Meeting*, Vol 2, pp. 938 - 943.
- McLachlan, G. (1992). *Discriminant Analysis and Statistical Pattern Recognition*, Wiley, New York.
- Oliver, J.; Baxter, R. & Wallace, C. (1996). Unsupervised Learning using MML, *Proceedings of the 13th Int. Conf in Machine Learning:(ICML-96)*, pp. 364-372.
- Oliver, J. J. & Hand, D. J. (1994) Introduction to Minimum Encoding Inference, [TR 4-94] Dept. Statistics. Open University. Walton Hall, Milton Keynes, UK.
- Pang, T.; Steinbach, M. & Kumar V. (2006). *Introduction to Data Mining*, Pearson Education, Boston.
- Robinson, D., "Harmonic Management in MV Distribution System" *PhD Thesis*, University of Wollongong, 2003.
- Wallace, C.; Boulton D.M. (1968). An information measure for classification *The Computer Journal*, Vol 11, No 2, August 1968, pp185-194.
- Wallace, C.; Dowe D. (1994). Intrinsic classification by MML - the Snob program, *proceeding of 7th Australian Joint Conf. on Artificial Intelligence*, World Scientific Publishing Co., Armidale, Australia, 1994.
- Wallace, C. (1998). Intrinsic Classification of Spatially Correlated Data, *The Computer Journal*, Vol. 41, No. 8.

Zulli, P.; Stirling, D. (2005) "Data Mining Applied to Identifying Factors Affecting Blast Furnace Stave Heat Loads," *Proceedings of the 5th European Coke and Ironmaking Congress*.

IntechOpen

IntechOpen



Theory and Novel Applications of Machine Learning

Edited by Meng Joo Er and Yi Zhou

ISBN 978-953-7619-55-4

Hard cover, 376 pages

Publisher InTech

Published online 01, January, 2009

Published in print edition January, 2009

Even since computers were invented, many researchers have been trying to understand how human beings learn and many interesting paradigms and approaches towards emulating human learning abilities have been proposed. The ability of learning is one of the central features of human intelligence, which makes it an important ingredient in both traditional Artificial Intelligence (AI) and emerging Cognitive Science. Machine Learning (ML) draws upon ideas from a diverse set of disciplines, including AI, Probability and Statistics, Computational Complexity, Information Theory, Psychology and Neurobiology, Control Theory and Philosophy. ML involves broad topics including Fuzzy Logic, Neural Networks (NNs), Evolutionary Algorithms (EAs), Probability and Statistics, Decision Trees, etc. Real-world applications of ML are widespread such as Pattern Recognition, Data Mining, Gaming, Bio-science, Telecommunications, Control and Robotics applications. This book reports the latest developments and futuristic trends in ML.

How to reference

In order to correctly reference this scholarly work, feel free to copy and paste the following:

Ali Asheibi, David Stirling, Danny Sutanto and Duane Robinson (2009). Clustering, Classification and Explanatory Rules from Harmonic Monitoring Data, Theory and Novel Applications of Machine Learning, Meng Joo Er and Yi Zhou (Ed.), ISBN: 978-953-7619-55-4, InTech, Available from:
http://www.intechopen.com/books/theory_and_novel_applications_of_machine_learning/clustering_classification_and_explanatory_rules_from_harmonic_monitoring_data

INTECH
open science | open minds

InTech Europe

University Campus STeP Ri
Slavka Krautzeka 83/A
51000 Rijeka, Croatia
Phone: +385 (51) 770 447
Fax: +385 (51) 686 166
www.intechopen.com

InTech China

Unit 405, Office Block, Hotel Equatorial Shanghai
No.65, Yan An Road (West), Shanghai, 200040, China
中国上海市延安西路65号上海国际贵都大饭店办公楼405单元
Phone: +86-21-62489820
Fax: +86-21-62489821

© 2009 The Author(s). Licensee IntechOpen. This chapter is distributed under the terms of the [Creative Commons Attribution-NonCommercial-ShareAlike-3.0 License](https://creativecommons.org/licenses/by-nc-sa/3.0/), which permits use, distribution and reproduction for non-commercial purposes, provided the original is properly cited and derivative works building on this content are distributed under the same license.

IntechOpen

IntechOpen