

## A steepest descent algorithm for the optimal control of a cascaded hydropower system

Olalekan Ogunbiyi<sup>1</sup>, Cornelius T. Thomas<sup>2</sup>, Oludare Y. Ogundepo<sup>3</sup>, Isaac O. A. Omeiza<sup>4</sup>, Jimoh Akanni<sup>5</sup>, B. J. Olufeagba<sup>6</sup>

<sup>1</sup>Electrical and Computer Engineering Department, Kwara State University, Nigeria

<sup>2</sup>Electrical and Information Engineering Department, Achievers University, Nigeria

<sup>3</sup>Electrical and Electronic Engineering, Federal University of Petroleum Resources, Nigeria

<sup>4</sup>Electrical and Information Engineering, Landmark University, Nigeria

<sup>5,6</sup>Electrical and Electronics Engineering Department, University of Ilorin, Nigeria

### Article Info

#### Article history:

Received Jan 13, 2019

Revised Feb 12, 2020

Accepted Feb 25, 2020

#### Keywords:

Hydropower

Inflows

Operating head

Performance index

Steepest descent

### ABSTRACT

Optimal power generation along the cascaded Kainji-Jebba hydroelectric power system had been very difficult to achieve. The reservoirs operating heads are being affected by possible variation in impoundments upstream, stochastic factors that are weather-related, availability of the turbo-alternators and power generated at any time. Proposed in this paper, is an algorithm for solving the optimal release of water on the cascaded hydropower system based on steepest descent method. The uniqueness of this work is the conversion of the infinite dimensional control problem to a finite one, the introduction of clever techniques for choosing the steepest descent step size in each iteration and the nonlinear penalty embedded in the procedure. The control algorithm was implemented in an Excel VBA® environment to solve the formulated Lagrange problem within an accuracy of 0.03%. It is recommended for use in system studies and control design for the optimal power generation in the cascaded hydropower system.

Copyright © 2020 Institute of Advanced Engineering and Science.  
All rights reserved.

### Corresponding Author:

Olalekan Ogunbiyi,  
Department of Electrical and Computer Engineering,  
Kwara State University,  
P.M.B 1530, Ilorin, Kwara State, Nigeria.  
Email: biyikan@gmail.com

## 1. INTRODUCTION

Hydropower generation in Nigeria is currently provided at three major locations [1]. Two of these stations are located on the River Niger, operated in cascade. They are the Kainji hydroelectric power station (KHEPS) and the Jebba hydroelectric power station (JHEPS). The KHEPS which is located at  $09^{\circ}51'45''N$ ,  $04^{\circ}36'48''E$  with an install capacity of 760 MW form eight units of turboalternators. The JHEPS is located 103 km downstream of the KHEPS on  $09^{\circ}08'08''N$ ,  $04^{\circ}47'16''E$ . It was commissioned on April 13, 1985, with a rated capacity of 578.4 MW from six (6) fixed blade [2, 3].

The Jebba Reservoir depends on discharge and spill from the KHEPS, this arrangement imposes the need for better water management if the units at Jebba are to operate efficiently all the year. The operators of the JHEPS face serious challenges that involve balancing conflicting needs involving the operational safety of the stations and the demand requirements from an energy-starved electricity grid [2, 4]. Practical observation of operations reveals the serious challenges confronting the JHEPS operators as they try to perform the functions of a regulator that was omitted in the fixed vane designs of the JHEPS turbo alternators [5, 6]. These operational problems are present in each HEPS in one form or the other, and it is only because of the robust nature of the turbo alternators that major catastrophes have not yet occurred [7].

Nonetheless, there is evidence of such problems lurking in the possibilities when one observes that one turbo alternator catastrophically failed at JHEPS and another at KHEPS. Both cases share the feature that no local regulator was included in the initial design. For example, the use of Francis Turbines at a very low head scheme as the KHEPS posed especial problems that meant poor performance and ultimately catastrophic failure. In the JHEPS case, the narrow operating head demanded by the fixed vane Kaplan turbines posed a very serious challenge to the operators [8].

The latter problem, however, lends itself to the application of optimal control methods. Indeed, this is the problem addressed in this research. It is posed as an optimal control problem to determine the inflow into the JHEPS reservoir so that the operating head falls within a specified range [9, 10]. This work considered the determination of optimal control law for the release of water from KHEPS such that the reservoir head at JHEPS remains relatively constant. The optimal control algorithm is to be incorporated into a real-time embedded controller.

Unfortunately, the design of such a system that ensures the optimal use of hydropower resources to maximize power generation within a cascaded system is challenging. The problem must be properly posed in a standard form before it can be solved [11, 12]. Solutions of optimal control problems are often analytically intractable and computationally complex [9, 13].

Due to the complexity of systems and applications, analytical methods are rarely used to compute the solutions to optimal control problems. Numerical solutions are mostly used in determining optimal control [14, 15]. In most cases, the numerical methods are highly sophisticated, and they do task computers [16, 17]. There have been numerous numerical procedures developed over the years, these procedures can be classified into two categories, the direct methods and indirect methods [18]. The direct method of computing optimal control involves the discretization of the state and the control in such a way that the problem is converted to a nonlinear optimization problem or nonlinear programming problem [17, 19, 20]. The indirect method applies calculus of variation to set up necessary conditions that must be satisfied by the optimal control.

## 2. STEEPEST DESCENT SOLUTION OF AN OPTIMAL CONTROL PROBLEM

The steepest descent algorithm is generally used for determining the minimum of a differentiable function and hence, employed as a direct method of solving optimal control problem in this work [21-23]. Given a performance index  $J(h, u)$  that is differentiable, the steepest descent direction is the path opposite  $\nabla J(u)$ . The search starts at a differentiable point  $u^{k=0}(t)$  and decreases after each iteration until it reaches the minimum point with  $u^*(t)$ , such that:

$$\nabla J^* = \frac{\partial J^*}{\partial u^*(t)} \approx 0 \quad (1)$$

Steepest descent algorithm is very fast in moving a solution from any local point within the feasible region to the vicinity of the point of convergence [21, 24, 25]. If a suitable method of solution is unknown, steepest descent is guaranteed to iterate towards the minimum point but characterised by slow convergence. Numerous researches on this method have been on the determination of appropriate step size and means of speeding it up [26].

### 2.1. Statement of the problem

The optimal control solved in this work is the determination of the control signal  $u(t)$  (generated by the control System) to be released from KHEPS (actuator) that will force the operating head  $h(t)$  of JHEPS (Controlled Plant) to follow a predefined trajectory within a given time (*initial time*  $t_0 \rightarrow$  *final time*  $t_f$ ).

The system is the dynamical model for the JHEPS operating head described by the nonlinear differential head 3.1 [8, 27]:

$$\frac{dh(t)}{dt} = -n \frac{A_2}{A_1} \sqrt{2g} h^{1/2}(t) + \frac{1}{A_1} (Q_J(t) - Q_L(t) - Q_S(t)) \quad (2)$$

$$Q_J = q_k + Q_{sk} + Q_{CJ} \quad (3)$$

$$u(t) = Q_J(t) - Q_L(t) - Q_S(t) \quad (4)$$

Hence, the system model can be written in d standard form as;

$$\dot{h}(t) = f(h(t), u(t), t); t_0 \leq t \leq t_f \quad (5)$$

where:

- $t$  : time
- $h$  : Operating head and the state variable
- $u$  : Control signal
- $n$  : Number of operating units (integer number 1 to 6)
- $A_1$  : Effective Surface area of the reservoir
- $A_2$  : Effective area of the scroll casing
- $g$  : Acceleration due to gravity
- $Q_J$  : Inflow into JHEPS
- $Q_L$  : Evaporation loss on JHEPS
- $Q_S$  : Spillway discharge from JHEPS
- $q_k$  : Total discharge from KHEPS tailrace
- $Q_{sk}$  : Spillway discharge from KHEPS
- $Q_{CJ}$  : Inflow from catchment area between KHEPS and JHEPS
- $f$  : Nonlinear function

## 2.2. Performance index 'J'

Performance indices can be selected to reflect the aspect of the system's behaviour that is considered as vital. As a result, a performance index which accommodates and appropriately penalizes deviation from a specified head and ensures that the control does not require values outside the capability of KHEPS was selected. A quadratic performance index was selected consisting of the integral of the square error from the desired operational head and the square deviation from the maximum discharge possible. Given a performance index  $J(h, u, t)$  that is differentiable:

$$I = \min J = \min \int_{t_0}^{t_f} \{K_h (h(t) - h(T))^2\} dt \quad (6)$$

Subject to the system constraints:

$$\dot{h}(t) = f(h(t), u(t), t) ; t_0 \leq t \leq t_f$$

$$h(t_0) = h_0 \quad (7)$$

$$h(t_f) = h(T) \quad (8)$$

$$\text{Nonlinear penalties on : } [u_{min}(t), u_{max}(t)],$$

where  $h(T)$  represents the desired final value for the state and  $K_h$  is a positive weighing scalar constant.

## 2.3. Solution of optimal control using steepest descent algorithm

A solution of the optimal control using steepest descent approach was earlier reviewed. The steepest descent direction is the path opposite  $\nabla J(u)$ . The search starts at a differentiable point  $u^k(t)$  and decreases after each iteration until it reaches the minimum point  $u^*(t)$ . Where:

$$\nabla J^* = \frac{\partial J^*}{\partial u^*(t)} \approx 0 \quad (9)$$

if  $z(u^k)$  is a unit vector along the increasing gradient,

$$z(U^k_{(t)}) = \frac{\left[ \frac{\partial J^k}{\partial U^k(t)} \right]^T}{\left\| \frac{\partial J^k}{\partial U^k(t)} \right\|} \quad (10)$$

then, moving in the direction  $-z(U^k)$ ,

$$U^{k+1}(t) = U^k(t) - \psi^k \mathbf{z}(U^k) \quad (11)$$

$\psi^k$  is the optimum steepest descent step size. An optimum value of  $\psi^k$  must be determined because a larger value of  $\psi^k$  results in the local minimum of  $J$  being overshoot. A smaller value for  $\psi^k$  will require much time and iterations for the search. Hence,  $\psi^k$  must be determined such as to move towards the minimum at the smallest computational time, this is another optimization. As shown in (12) gives an approximate end of the search in the present direction:

$$u^{k+1}(t) = u^k(t) - \psi_{(min)}^k \frac{\frac{\partial J^k}{\partial u^k(t)}}{\left\| \frac{\partial J^k}{\partial u^k(t)} \right\|} \quad (12)$$

An innovative approach to finding the optimum  $\psi^k$  is by using the quadratic approach.

$$J(\psi) = \mathbf{a} + \mathbf{b}\psi + \mathbf{c}\psi^2 \quad (13)$$

$$\frac{dJ}{d\psi_{(min)}^k} = 2\mathbf{c}\psi + \mathbf{b} = 0 \quad (14)$$

$$\psi_{(min)}^k = -\frac{\mathbf{b}}{2\mathbf{c}} \quad (15)$$

Hence,

$$[U^{k+1}(t)]^T = [U^k(t)]^T - \psi_{(min)}^k \frac{\left[ \frac{\partial J^k}{\partial u_1^k(t)}, \frac{\partial J^k}{\partial u_2^k(t)}, \frac{\partial J^k}{\partial u_3^k(t)}, \frac{\partial J^k}{\partial u_4^k(t)} \right]^T}{\sqrt{\left( \frac{\partial J^k}{\partial u_1^k(t)} \right)^2 + \left( \frac{\partial J^k}{\partial u_2^k(t)} \right)^2 + \left( \frac{\partial J^k}{\partial u_3^k(t)} \right)^2 + \left( \frac{\partial J^k}{\partial u_4^k(t)} \right)^2}} \quad (16)$$

The computation was carried out numerically in an EXCEL VBA® programming environment. The Adams-moulton numerical integrator with steepest descent technique was employed in solving the system model and the computation of controls.

#### 2.4. Algorithm for the numerical solution of the optimal control using the steepest descent algorithm

Set up: Declare a control vector  $U^{(k)}(t)$  by using a finite partition of the time interval  $[t_0, t_f]$ .

$$\pi[t_0, t_f] = t_0 < t_1 < t_2 < t_3 < t_f$$

$$U^{(k)}(t) = [u_1^{(k)}(t), u_2^{(k)}(t), u_3^{(k)}(t), u_4^{(k)}(t)]^T$$

Step 1: Let  $k = 0$

Set the initial condition  $h^{(k=0)}(t) = h_0$

Guess values for  $U^{(k=0)}(t)$  from  $t_0 \rightarrow t_f$ .

Step 2: Numerically integrate  $f(h(t), u(t), t)$  from  $t_0 \rightarrow t_f$  to obtain  $h^{(k)}(t)$ . The numerical integration is carried out using an Adams–Moulton technique with Adams–Bashforth as predictor and Runge–Kutta for starting.

Step 3: Compute the performance index  $J^{(k)}$

$$J^{(k)} = J(u_1^{(k)}(t), u_2^{(k)}(t), u_3^{(k)}(t), u_4^{(k)}(t))$$

The Trapezoidal rule was employed in this computation

Step 4: Select a perturbation value  $\Delta u$  and compute  $J_m^{(k)}$ ;  $m = 1, 2, 3, 4$

$$J_1^{(k)} = J(u_1^{(k)}(t) + \Delta u, u_2^{(k)}(t), u_3^{(k)}(t), u_4^{(k)}(t))$$

$$J_2^{(k)} = J(u_1^{(k)}(t), u_2^{(k)}(t) + \Delta u, u_3^{(k)}(t), u_4^{(k)}(t))$$

$$J_3^{(k)} = J(u_1^{(k)}(t), u_2^{(k)}(t), u_3^{(k)}(t) + \Delta u, u_4^{(k)}(t))$$

$$J_4^{(k)} = J(u_1^{(k)}(t), u_2^{(k)}(t), u_3^{(k)}(t), u_4^{(k)}(t) + \Delta u)$$

Step 5: Compute the approximate gradient vector  $\nabla J$ .

$$\nabla J = \frac{\partial J_m^k}{\partial u_m} \approx \frac{J^k - J_m^k}{\Delta u}; \quad m = 1, 2, 3, 4$$

Step 6: Compute the norm of the gradient  $\|\nabla J\|$ .

$$\left\| \frac{\partial J^{(k)}}{\partial U^{(k)}(t)} \right\| = \sqrt{\left( \frac{\partial J^{(k)}}{\partial u_1^{(k)}(t)} \right)^2 + \left( \frac{\partial J^{(k)}}{\partial u_2^{(k)}(t)} \right)^2 + \left( \frac{\partial J^{(k)}}{\partial u_3^{(k)}(t)} \right)^2 + \left( \frac{\partial J^{(k)}}{\partial u_4^{(k)}(t)} \right)^2}$$

Step 7: Compute the unit vector  $z(U^{(k)}(t))$

$$z(U^{(k)}(t)) = \frac{\left[ \frac{\partial J^{(k)}}{\partial U^{(k)}(t)} \right]^T}{\left\| \frac{\partial J^{(k)}}{\partial U^{(k)}(t)} \right\|}$$

Step 8: Determine the optimum step  $\psi_{min}^{(k)}$

Select a set of three Fibonacci numbers  $\psi_1, \psi_2$  and  $\psi_3$  such as to obtain

$$U_{\psi_1}^{(k+1)}(t) = U^{(k)}(t) - \psi_1^{(k)} z(U^{(k)}(t)) \text{ and } J_{\psi_1}^{(k)}$$

$$U_{\psi_2}^{(k+1)}(t) = U^{(k)}(t) - \psi_2^{(k)} z(U^{(k)}(t)) \text{ and } J_{\psi_2}^{(k)}$$

$$U_{\psi_3}^{(k+1)}(t) = U^{(k)}(t) - \psi_3^{(k)} z(U^{(k)}(t)) \text{ and } J_{\psi_3}^{(k)}$$

Step 9: Solve for the constants  $b$  and  $c$

$$\begin{bmatrix} b \\ c \end{bmatrix} = \begin{bmatrix} (\psi_1 - \psi_2) & (\psi_1^2 - \psi_2^2) \\ (\psi_2 - \psi_3) & (\psi_2^2 - \psi_3^2) \end{bmatrix}^{-1} \begin{bmatrix} (J_{\psi_1} - J_{\psi_2}) \\ (J_{\psi_2} - J_{\psi_3}) \end{bmatrix}$$

Step 10: Compute  $\psi_{(min)}$

$$\psi_{(mn)}^{(k)} = -\frac{b}{2c}$$

Step 11: Compute the control vector

$$\left[ U^{(k+1)}(t) \right]^T = \left[ U^{(k)}(t) \right]^T - \psi_{(mn)}^{(k)} \frac{\left[ \frac{\partial J^{(k)}}{\partial u_1^{(k)}(t)}, \frac{\partial J^{(k)}}{\partial u_2^{(k)}(t)}, \frac{\partial J^{(k)}}{\partial u_3^{(k)}(t)}, \frac{\partial J^{(k)}}{\partial u_4^{(k)}(t)} \right]^T}{\sqrt{\left( \frac{\partial J^{(k)}}{\partial u_1^{(k)}(t)} \right)^2 + \left( \frac{\partial J^{(k)}}{\partial u_2^{(k)}(t)} \right)^2 + \left( \frac{\partial J^{(k)}}{\partial u_3^{(k)}(t)} \right)^2 + \left( \frac{\partial J^{(k)}}{\partial u_4^{(k)}(t)} \right)^2}}$$

Step 12: Check if  $\|\nabla J(u^{(k+1)})\| - \|\nabla J(u^{(k)})\| \leq 10^{-n}$  and  $\frac{\partial J^*}{\partial U^*} \approx 0$ , where  $n$  is a positive constant.

If this is true, then  $u^*(t) = u^{(k+1)}(t)$  and output  $h^*(t)$

else

let  $k = k + 1$ ,  $u^{(k)}(t) = u^{(k+1)}(t)$  and return to step 2

### 3. RESULTS AND ANALYSIS

The results obtained from the computation of optimal control using the steepest descent algorithm are presented in case 1 to case 5. A notation is used for specifying operating conditions under a case being considered, the format is as follows: (number of machines, starting head (m), number of days, penalty).

- Case 1: (5, 25.8, 1, *Unpenalized*)

Applying the stated operating conditions into the steepest descent algorithm and assuming a convergence criterion of  $10^{-5}$  for the gradient led to convergence after 15 iterations with  $h(t)$  trajectories as shown in Figure 1. The trajectories exhibit some overshoot because the interval of 6 hrs used to specify the controls prevent the adjustment of the control with the precision that would guarantee the desired terminal value nearly precisely. It is evident that operators using protocols based on this result will be able to more precisely control and manage their plants. The results demonstrate the use of the optimal control approach and provide dependable methods for operations with a negligible deviation of 0.03% of the optimum head  $h^*(t_f)$  from the set value  $h(T)$ .

Figure 2 presents the control that is required to produce the needed head trajectory of Figure 1. The fifteenth iterations produced the desired optimal control. The control law starts with a high inflow in the first 6 hours of the day ( $u_1$ ) and reduces to the minimum value in the second 6 hours of the day ( $u_2$ ). The control increases lightly in the remaining 12 hours to move the head to the optimum level. The input parameters are:  $h(0) = 25.8\text{ m}$ ,  $h(T) = 26.1\text{ m}$ ,  $u_1(0) = u_2(0) = u_3(0) = u_4(0) = 1000\text{ m}^3/\text{s}$ . This generated an output with: *No of Iterations* = 15,  $h^*(t_f) = 26.10869\text{ m}$ ,  $u_1^*(t) = 7127.522\text{ m}^3/\text{s}$ ,  $u_2^*(t) = 470.5617\text{ m}^3/\text{s}$ ,  $u_3^*(t) = 1626.928\text{ m}^3/\text{s}$ ,  $u_4^*(t) = 1714.475\text{ m}^3/\text{s}$ ,  $I(\min J) = 501.4565$ ,  $\|\nabla J\| = 0.042747$  and  $\psi(\min) = 0.0053628$ .




Figure 1. Reservoir head versus time (case 1)




Figure 2. Optimum control (case 1)

Plots showing the performance and characteristics of the steepest descent algorithm are shown in Figures 3 to 6. The plot in Figure 3 presents the successive iterations determined by using a unidirectional search along the descent on the gradient vector to the local minimum. A peculiar feature of this algorithm can be observed by studying  $u_1(t)$  and  $u_2(t)$ . While  $u_1(t)$  kept increasing after every iteration,  $u_2(t)$  only increases for the first two iterations and it decreases till the allowable tolerance level.

A necessary condition for a control to be optimum is that the performance index at the last iteration must be minimum. This can be observed in Figure 4 that the performance index keeps decreasing till the last iteration. If the curve differs from this expected behaviour, then the control is not optimum, and the trajectories may not be as seen in Figure 1. It can be observed that the first three iterations reduce the performance index greatly, this is a unique characteristic of steepest descent method.

Figures 5 and 6 show the variation of the norm of gradient and the steepest descent steps size. The stopping criteria in the algorithm are that the norm of gradient must be approximately zero and the steepest descent step size should also be very small and insignificant. It is only then that the control can be assumed to be optimum. As could be seen during the implementation, the gradient attains the lowest value and the step size became so small that the changes computed were within the error of computation. This means that the head in Figure 1 and control in Figure 2 are optimum.




Figure 3. Control input versus iteration (case 1)




Figure 4. Performance index versus iteration (case 1)




Figure 5. Norm of gradient versus iteration




Figure 6. Steepest descent steps versus iteration

- Case 2: (5, 25.8, 1,  $u_{min} > 0$  and  $u_{max} = 3000 \text{ m}^3/\text{s}$ )

It is possible to modify the problem such that the control is penalized. The penalty is to impose a maximum and minimum value on the control. The control is not allowing to be negative or exceed a value. Different simulation for penalized optimal controls is presented in cases 2 and 3. Figures 7 and 8 presents the results of the case (5, 25.8, 1,  $u_{min} > 0$  and  $u_{max} = 3000 \text{ m}^3/\text{s}$ ). The effect is that the overshoot on the state trajectory is removed, and it takes more iterations. The optimum control looks more appropriate than the results produced with cases where the control is Unpenalized.




Figure 7. Reservoir head versus time (case 2)




Figure 8. Optimum control (case 2)

The input parameters are:  $h(0) = 25.8 \text{ m}$ ,  $h(T) = 26.1 \text{ m}$ ,  $u_1(0) = u_2(0) = u_3(0) = u_4(0) = 1000 \text{ m}^3/\text{s}$ . This generated an output with: *No of Iterations* = 54,  $h^*(t_f) = 26.0905 \text{ m}$ ,  $u_1^*(t) = 3000 \text{ m}^3/\text{s}$ ,  $u_2^*(t) = 3000 \text{ m}^3/\text{s}$ ,  $u_3^*(t) = 3000 \text{ m}^3/\text{s}$  and  $u_4^*(t) = 1148.74767 \text{ m}^3/\text{s}$ .

Case 3:  $(3, 25.8, 1, u_{min} > 0 \text{ and } u_{max} = 3000 \text{ m}^3/\text{s})$

The results in Figures 9 and 10 are for the case with three operating machines while  $u_{min} > 0 \text{ and } u_{max} = 3000 \text{ m}^3/\text{s}$ . The algorithm converges after one iteration and the optimal control reduces gradually after every quarter of time. The input parameters are:  $h(0) = 25.8 \text{ m}$ ,  $h(T) = 26.1 \text{ m}$ ,  $u_1(0) = u_2(0) = u_3(0) = u_4(0) = 1000 \text{ m}^3/\text{s}$ . This generated an output with: *No of Iterations* = 2,  $h^*(t_f) = 26.17741 \text{ m}$ ,  $u_1^*(t) = 3000 \text{ m}^3/\text{s}$ ,  $u_2^*(t) = 2697.7157 \text{ m}^3/\text{s}$ ,  $u_3^*(t) = 1996.9178 \text{ m}^3/\text{s}$  and  $u_4^*(t) = 1312.082816 \text{ m}^3/\text{s}$ .




Figure 9. Reservoir head versus time (case 3)




Figure 10. Optimum control (case 3)

#### 4. CONCLUSION

The work has considered the development of an optimal control procedure for the cascaded KHEPS and JHEPS. There can be numerous optimal control problem, but the problem solved is the Lagrange problem for the optimal release for inflows into JHEPS such that its operating head remains relatively constant at 26.1 m. The control algorithm is based on the steepest descent, a method that ensure the determination of a local optimum for a convex problem. The quadratic line was employed for the determination of optimum steepest descent step size. When the control is penalized, the algorithm converges faster. The control algorithm was implemented in an Excel VBA® environment to ensure that the optimum head falls within 0.03%. It is recommended for use in system studies, decision making and control design for the optimal power generation in the cascaded hydropower system

#### ACKNOWLEDGEMENTS

We acknowledge the Transmission Company of Nigeria (TCN) National control Centre Oshogbo, for providing relevant data used in the courses of this research. We are also grateful to the management of Mainstream Energy solution for granting access the two hydropower stations.

#### REFERENCES

- [1] A. S. Sambo, B. Garba, I. H. Zarma, and M. M. Gaji, "Electricity Generation and the Present Challenges in the Nigerian Power Sector," *Journal Energy Power Engineering*, vol. 6, no. 7, pp. 1–17, 2012.
- [2] M. A. Aminu and U. G. Kangiwa, "Performance Evaluation and Efficiency Improvement for Jebba, Kainji and Shiroro Hydro Power Schemes," *3rd IEEE International Conference on Adaptive Science and Technology (ICAST 2011)*, Abuja, pp. 115–118, 2011.
- [3] C. T. Thomas, M. F. Akorede, O. Ogunbiyi, B. J. Olufeagba, and J. S. Samuel, "A study of energy conversion at the Jebba Hydroelectric power station," *2017 IEEE 3rd International Conference on Electro-Technology for National Development (NIGERCON)*, Owerri, pp. 828–833, 2017.
- [4] O. M. Bamigbola and Y. O. Aderinto, "On Optimal Control Model of Electric Power Generating Systems," *Journal Res. Phys. Sci.*, vol. 5, no. 1, pp. 59–70, 2015.
- [5] T. S. Abdulkadir, A. W. Salami, A. R. Anwar, and A. G. Kareem, "Modelling of Hydropower Reservoir Variables for Energy Generation: Neural Network Approach," *Ethiopian Journal of Environmental Studies and Management*, vol. 6, no. 3, pp. 310–316, May 2013.



- [6] C. T. Thomas, O. Ogunbiyi, M. F. Akorede, and J. B. Olufeagba, "Assessment of Failure and Repair Behaviours of the Jebba Hydroelectric Power Station," *Elektrika Journal of Electrical Engineering*, vol. 17, no. 3, pp. 13–19, Dec. 2018.
- [7] C. T. Thomas, M. F. Akorede, O. Ogunbiyi, B. J. Olufeagba, and J. S. Samuel, "A study of energy conversion at the Jebba Hydroelectric power station," *2017 IEEE 3rd International Conference on Electro-Technology for National Development (NIGERCON)*, Owerri, pp. 828–833, 2017.
- [8] O. Ogunbiyi, C. T. Thomas, I. A. O. Omeiza, J. Akanni, and B. J. Olufeagba, "Dynamical Control Model of the Cascaded Kainji-Jebba Hydropower Operating Head," *FUOYE Journal of Engineering and Technology*, vol. 4, no. 1, pp. 140–144, May 2019.
- [9] S. Guo, X. Li, P. Liu, and F. Guo, "Optimal Operation of Cascade Hydropower Plants," in *2009 Asia-Pacific Power and Energy Engineering Conference*, Wuhan, pp. 1–4, 2009.
- [10] A. Ajayi, *et al.*, "Major Factors Affecting Electricity Generation, Transmission and Distribution in Nigeria," *Ethiop. J. Environ. Stud. Manag.*, vol. 1, no. 3, 2013.
- [11] S. A. A. Moosavian, A. Ghafari, A. Salimi, and N. Abdi, "Non-linear Multiobjective Optimization for Control of Hydropower Plants Network," *2008 IEEE/ASME International Conference on Advanced Intelligent Mechatronics*, Xian, pp. 1278–1283, 2008.
- [12] G. Robert and F. Michaud, "A Simple Multi-Objective Control for Cascaded Hydro Power Plants," in *IFAC Proceedings Volumes*, vol. 44, no. 1, pp. 4960–4963, Jan. 2011.
- [13] A. F. Ribeiro, M. C. M. Guedes, G. V. Smirnov, and S. Vilela, "On the Optimal Control of a Cascade of Hydro-electric Power Stations," *Electric Power Systems Research*, vol. 88, pp. 121–129, Jul. 2012.
- [14] F. R. Paiva, "Numerical Methods for Optimal Control and Model Predictive Control," *Programa Doutoral em Matemática Aplicada*, 2014.
- [15] R. Stengel and O. Contro, "Principles for Optimal Control of Dynamic Systems! Trajectory of the System!," 2015.
- [16] J. L. Schultz, D. G., and Melsa, "State Functions and Linear Control Systems," *McGraw Hill Text; First Edition*, Jan. 1967.
- [17] V. M. Becerra, "Optimal Control," *Scholarpedia*, vol. 3, no. 1, 2008.
- [18] O. Von Stryk, "Numerical Solution of Optimal Control Problems by Direct Collocation," *Optimal Control*, vol. 111, pp. 129–143, 1993.
- [19] S. S. Rao, "Engineering Optimization: Theory and Practice," *Wiley 4 edition*, Jul. 2009.
- [20] J. T. Betts, "Practical Methods for Optimal Control Using Nonlinear Programming," *Society for Industrial and Applied Mathematics*, 2001.
- [21] D. E. Kirk, "Optimal Control Theory: An Introduction," *Dover Publication*, New York, 1998.
- [22] C. Y. T. Ma, D. K. Y. Yau, N. K. Yip, N. S. V. Rao, and J. Chen, "Stochastic Steepest Descent Optimization of Multiple-Objective Mobile Sensor Coverage," *2010 IEEE 30th International Conference on Distributed Computing Systems*, Genova, pp. 96–105, 2010.
- [23] H. Schättler and T. J. Tarn, "Descent Algorithms for Optimal Periodic Output Feedback Control," in *IEEE Transactions on Automatic Control*, vol. 37, no. 12, pp. 1893–1904, Dec. 1992.
- [24] K. S. Srinivas and K. Vaisakh, "Application of Steepest Descent and Differential Evolution Methods for Optimal Control of Power Systems," *Imperial Journal of Interdisciplinary Research (IJIR)*, vol. 3, no. 1, pp. 2257–2263, 2017.
- [25] H. Zhao, Y. Zhang, J. Hu, and Z. Chen, "Estimation of Initial Guess of Steepest Descent Method for Near Field Phase Retrieval," *2017 Asia-Pacific International Symposium on Electromagnetic Compatibility (APEMC)*, Seoul, pp. 306–308, 2017.
- [26] W. J. Grantham, A. O., and Chingcuanco, "Lyapunov Steepest Descent Control of Constrained Linear Systems," *IEEE Transactions on Automatic Control*, vol. 29, no. 8, pp. 740–743, Aug. 1984.
- [27] O. Ogunbiyi, C. T. Thomas, I. O. A. Omeiza, J. Akanni, and B. J. Olufeagba, "A Nonlinear Control Model and Operational Support System for the Kainji Hydroelectric Power System," *Nigerian Journal of Technology*, vol. 38, no. 2, pp. 449–455, 2019.