

Power Factor and Your Electrical Utility Bill in Egypt

M. M. Abdel Aziz, *Member, IEEE*, E. E. Abou El-Zahab, and A. F. Zobaa, *Member, IEEE*

Abstract—Beside being a good neighbor and not causing harmonic voltage for others that are connected to your electrical distribution circuit, complying with the legal requirements of IEEE standards 519, and maintaining safe and economical operating environments for electrical equipment within your physical load, there is another very good reason to maintain a good power factor: saving money on your electrical utility bill. This letter discusses the topic.

Index Terms—Economics, harmonics, power factor.

I. INTRODUCTION

TYPICALLY, both utilities and consumers have incentives for PF improvement. For a utility, PF improvement reduces system losses and increases the portion of generation capacity available for productive uses. In addition, it can help maintain voltage at desired levels. Consequently, utilities often encourage consumers to maintain a high PF by applying tariff clauses, which penalize consumers for low PF .

In Egypt, utilities impose a penalty in the form of higher charges for customers with contracted loads greater than 500 kW whose PF is less 0.9. From the customer's point of view, this penalty should be sufficient to motivate the installation of PF correction equipment. Aside from decreasing the electric bill (or actually resulting in a bonus), other advantages of PF correction include increasing internal electrical distribution system capacity, reducing distributing system losses, and enhancing voltage stability.

The following are the possible benefits that can be achieved by correcting consumer's PF value.

A. Elimination of the PF Penalty

The PF penalty is a multiplier applied to the normal kilowatt hour consumption charges. The penalty is based on an annual average PF , calculated from kilowatt hour and kVAh meters readings as follows:

$$\text{Average annual } PF = \frac{\text{kWh}}{\sqrt{\text{kWh}^2 + \text{kVAh}^2}} \quad (1)$$

When the average annual PF is less than 0.9 but greater or equal to 0.7, the penalty is calculated as follows:

$$\text{Penalty} = (0.9 - PF) * \text{kWh charges} \quad (2)$$

When the average annual PF is less than 0.7, the penalty is

$$\text{Penalty} = \left[(0.9 - 0.7) + \frac{3}{2}(0.7 - PF) \right] \times \text{kWh charges} \quad (3)$$

If the consumer does not correct the PF , the penalty increases after three months to

$$\text{Penalty} = 2 * (0.9 - PF) * \text{kWh charges} \quad (4)$$

The utility also has the right to discontinue service if the consumer does not correct the PF within another six months.

B. Reduction in Contract Demand

The contract demand is the demand that the supplier of electric service agrees to have available for delivery. According to the Egyptian tariff structure, increasing the PF may allow the consumer to reduce his or her contracted power. This results in the use of a different scale for calculating the cost of kilowatt hour consumption. The effect is to use smaller block sizes at higher unit energy costs and larger block sizes for the cheaper rate blocks.

C. Bonus Due to Overcorrected PF

According to the Egyptian tariff structure, a bonus is offered to customers when they maintain an average annual PF higher than 0.92 and up to a maximum of 0.95. This can be calculated by the following:

$$\text{Bonus} = \frac{PF - 0.92}{2} * \text{kWh charges} \quad (5)$$

D. Reduction of Internal Distribution System Losses

With active power (kW) held constant, as PF decreases, the required apparent power (kVA) increases. As a result, the electrical system resistance (I^2R) losses are increased. Although these losses are small (2.5% to 7.5% of a typical industrial load's yearly energy consumption), the effect is much more pronounced on a national scale.

E. Increased Distribution System Capacity

Low PF cuts down distribution system capacity. Similar capacity improvements are possible with cables, circuit breakers, and other electrical equipment. The capacity of all this equipment to provide useful power is reduced by low PF . In effect, increasing PF will result in increased capacity in existing electrical distribution systems. This can help offset or reduce expenses for additional system capacity.

F. Enhanced Voltage Profile

While not a reason in itself for installing PF improvement equipment, better voltage stability is usually an additional benefit of PF correction.

II. PAYBACK PERIOD

Payback period is the period of time required for the profit or other benefits from an investment to equal the cost of the invest-

Manuscript received October 2, 2002.

The authors are with the Electrical Power and Machines Department, Faculty of Engineering, Cairo University, Giza 12613, Egypt.

Digital Object Identifier 10.1109/TPWRD.2003.817535

TABLE I
SIMULATED RESULTS OF THE SYSTEM UNDER STUDY

Criterion	PF _n (%)	P _n (kW)	TCOST (L.E.)
Transmission loss	89.47	4993.24	370866.30
Transmission efficiency	89.77	5049.83	419268.20
Transmission loss	90.00	4900.70	308822.30
constrained by a given cost	95.00	4947.58	352970.20

ment. In all situations, the criterion is to minimize the payback period. The computation of payback period is given by the following equation [1]:

$$\text{Payback period} = \frac{\text{TCOST}}{\text{UAB}} \quad (6)$$

where

TCOST total cost of the compensator;
UAB uniform annual benefit.

III. POWER FACTOR CORRECTION PROJECT ECONOMICS

Total electricity costs for the energy customers consist of three parts: demand charges, energy charges, and *PF* penalties. The contracted power was P_O kW at PF_O . Therefore, the demand charges were $(87.6 \times P_O)$ L.E. according to the Egyptian tariff. The power is P_n kW at PF_n after correction. Therefore, the demand charges are $(87.6 \times P_n)$ L.E. By reducing contracted demand from P_O to P_n , demand charges were reduced by $[87.6 \times (P_O - P_n)]$ L.E. Excluding the possible reduction in contract demand, the total annual savings resulting from the project (S_e) are

$$\begin{aligned} S_e = & (\text{old kWh charges} - \text{new kWh charges}) \\ & + (0.9 - PF_O) * \text{old kWh charges} \\ & + \frac{PF - 0.92}{2} * \text{new kWh charges L.E.} \end{aligned} \quad (7)$$

Including the contract demand reduction, the savings (S_i) are as (7) with the term $[87.6 * (P_O - P_n)]$ is added. Note that the last term, in (7) is used if $PF_n > 0.92$. The total investment required for this project is given by the following equation:

$$\text{TCOST} = U_C S_C + U_L S_L \quad (8)$$

where U_C and U_L are, respectively, the costs of the capacitor and inductor per kilovolt ampere and considered to be constant parameters (60 L.E./kVA). S_C and S_L are, respectively, the volt-amperes ratings of the capacitor and inductor. If the total investment required for this project, using (8), the expected simple payback period for the project is (TCOST/S_i) years including contract demand reduction. Excluding reduction gives a simple payback period of (TCOST/S_e) years.

TABLE II
PROJECT ECONOMICS OF CASE STUDY

PF _n (%)	Payback period (years)	
	Including reduction in contract demand	Excluding reduction in contract demand
89.47	0.1459	0.1464
89.77	0.1690	0.1693
90.00	0.1139	0.1147
95.00	0.1287	0.1293

IV. CASE STUDY

Consider the system under study [2] as: A three-phase load of 5100 kW, and 4965 kVAR is connected to a supply bus with voltage 4160-V (2400 line-to-ground), 60-Hz frequency and 80-MVA short circuit capacity. The contracted power is 5100 kW at 0.5464 PF. According to Egyptian tariff, the annual cost per kilowatt is currently L.E. 87.6. The consumption charge is 0.1535 L.E./kWh. The simulated results using the suggested methods in [3] and [4] are given in Table I.

Using Section III to perform the project economics, the results are given in Table II.

V. CONCLUSIONS

Improving power factor resulted in reduction in all three electricity cost components. By reducing contract demand, demand charges were reduced. Because of the improvement in power factor, the maximum kilovolt amperes will decrease; this will reduce the internal losses and, in turn, the energy consumption. There are four alternatives for the compensator used: (a) Compensator for minimum transmission loss provided that it is greater than or equal 90%; (b) compensator for maximum transmission efficiency provided that it is greater than or equal 90%; (c) compensator for maximum *PF* provided that it is greater than or equal 90% and less than or equal 95%; (d) compensator for minimum transmission loss constrained by a given cost. A simple engineering economic analysis using simple payback period shows that the compensator, which yields most economical *PF*, is not necessarily equal with the compensator, which gives minimum transmission loss.

REFERENCES

- [1] D. G. Newman, *Engineering Economic Analysis*. San Jose, CA 103: Engineering Press, 1980.
- [2] IEEE Recommended Practices and Requirements for Harmonic Control in Electrical Power Systems, 1992.
- [3] M. M. Abdel-Aziz, E. E. Abou El-Zahab, A. M. Ibrahim, and A. F. Zobaa, "Practical considerations on power factor correction for non-linear loads," in *Proc. IEEE Int. Conf. Harmon. Quality Power*, Rio de Janeiro, Brazil, Oct. 6-9, 2002.
- [4] M. M. Abdel-Aziz, E. E. Abou El-Zahab, and A. F. Zobaa, "LC compensators based on cost minimization for nonlinear loads," in *Proc. Large Eng. Syst. Conf. Power Eng.*, Montreal, QC, Canada, May 7-9, 2003, pp. 143-147.