



Research Center
Finance & Information Management



Project Group
Business & Information
Systems Engineering

A Generic Data Model for Describing Flexibility in Power Markets

by

Paul Schott, Johannes Sedlmeir, Nina Strobel¹, Thomas Weber², Gilbert Fridgen, Eberhard Abele³

May 2019

in: *Energies* (2019), 12(10), p. 1893

The final publication is available at:
<https://doi.org/10.3390/en12101893>

¹ PTW TU Darmstadt

² PTW TU Darmstadt

³ PTW TU Darmstadt

University of Augsburg, D-86135 Augsburg
Visitors: Universitätsstr. 12, 86159 Augsburg
Phone: +49 821 598-4801 (Fax: -4899)


University of Bayreuth, D-95440 Bayreuth
Visitors: Wittelsbacherring 10, 95444 Bayreuth
Phone: +49 921 55-4710 (Fax: -844710)

WI-968



Article

A Generic Data Model for Describing Flexibility in Power Markets

Paul Schott ^{1,*} , Johannes Sedlmeir ¹ , Nina Strobel ² , Thomas Weber ², Gilbert Fridgen ³ 
and Eberhard Abele ²

¹ Project Group Business & Information Systems Engineering of the Fraunhofer FIT, 95444 Bayreuth, Germany; johannes.sedlmeir@fit.fraunhofer.de

² Institute of Production Management, Technology and Machine Tools, Technische Universität Darmstadt, 64287 Darmstadt, Germany; n.strobel@ptw.tu-darmstadt.de (N.S.); t.weber@ptw.tu-darmstadt.de (T.W.); abele@ptw.tu-darmstadt.de (E.A.)

³ FIM Research Center, University of Bayreuth Project Group Business & Information Systems Engineering of the Fraunhofer FIT, 95444 Bayreuth, Germany; gilbert.fridgen@fim-rc.de

* Correspondence: paul.schott@fit.fraunhofer.de; Tel.: +49-921-55-4734

Received: 20 April 2019; Accepted: 15 May 2019; Published: 18 May 2019



Abstract: In this article, we present a new descriptive model for industrial flexibility with respect to power consumption. The advancing digitization in the energy sector opens up new possibilities for utilizing and automatizing the marketing of flexibility potentials and therefore facilitates a more advanced energy management. This requires a standardized description and modeling of power-related flexibility. The data model in this work has been developed in close collaboration with several partners from different industries in the context of a major German research project. A suitable set of key figures allows for also describing complex production processes that exhibit interdependencies and storage-like properties. The data model can be applied to other areas as well, e.g., power plants, plug-in electric vehicles, or power-related flexibility of households.

Keywords: demand side management; demand response; generic flexibility data model; flexibility modeling; power system; industrial processes; digitalization

1. Introduction

In the past, only a few large power plants, mainly running on fossil or nuclear fuels, were responsible for the reliable supply of electricity [1]. The continuous expansion of renewable energy sources enables a more sustainable design of the electricity system [2]. At the same time, however, new challenges are emerging [3]. The main challenge is the fluctuating electricity production caused by the weather dependency of wind turbines and photovoltaic plants, which make up a large proportion of renewable energy sources. Moreover, due to the merit order effect, renewable energy sources successively replace conventional power plants [4]. These have so far provided most of the required flexibility [4]. Thus, there is an increasing need for flexibility in the power system to keep ensuring the necessary balance between power generation and consumption. This is called the flexibility gap [5]. In particular, flexibility can address the challenges caused by both foreseeable and unforeseeable fluctuations of renewable energy sources and therefore help to establish an environmentally friendly, decarbonized electricity system [5–7].

Lund [3] and Müller [8] differentiate between four types of flexibility in the electricity system which guarantee security of supply: grid expansion, energy storage, flexibility on the supply side, and flexibility on the demand side. Here, flexibility on the demand side refers to the possibility of deviating from the planned load profile [9]. Typically, such deviations are economically motivated

by price signals. If a third party sends a signal to a flexible consumer, this is called demand response (DR) [9]. Due to high costs for storage systems and grid expansion, flexibility on the demand side will play an important role as it offers flexibility at comparatively low marginal costs [10–12].

The digital transformation of the electricity sector is opening up new opportunities for utilizing and automatizing the marketing of flexibility potentials [13,14]. For example, the use of smart meters enables improved monitoring and control of electricity consumption and therefore a higher automation level of flexible industrial production systems. Hence, the advancing digitalization on the one hand facilitates an efficient and repeated use of flexibility. On the other hand, it also provides digital communications technology to detect and react to local changes in power consumption in the electricity network, the so-called Smart Grid [15]. With these tools at hand, it is possible to tackle the aforementioned flexibility gap from both the perspective of flexibility providers and from a systemic point of view [12]. Since interoperability in a Smart Grid is an essential requirement, the uniform description and modeling of flexibility is of crucial importance for the optimal scheduling and successful use of flexibility [16,17]. The “Smart Grid Architecture Model” [18] is a framework to support the development of the European Smart Grid. It consists of the following five layers: business layer, functional layer, information layer, communication layer, and component layer. The information layer is meant to provide a data model which ensures a common understanding of the exchanged data.

For an electricity system in which conventional power plants provide the main contribution to flexibility, typically a few key figures, such as activation duration (ramp up time), holding duration (length), and power (capacity) characterize a flexibility [19]. However, as already mentioned, in the future electricity system, one will need new participants who provide flexibility [5]. On the demand side, the industrial sector is of particular relevance as it consumes a large part of the electricity in many countries [20]. Already today, some electricity-intensive companies are optimizing their power purchases, taking their available flexibility potential and price fluctuations into account. However, due to various barriers, such as know-how, or technical, economic, environmental, regulatory, and organizational challenges, many industrial companies have not yet exploited their DR potential [5,8,21]. Standardization can improve the exchange of information and foster access to flexibility-related services. Therefore, it can contribute to a substantial decrease of these barriers, in particular these related to know-how, technical, and economic challenges. In this context, a standardized modelling of flexibility, which can be implemented by a generic data model, takes on an essential part [14]. Such a data model should facilitate the description of any flexibility as precisely as possible on the basis of various key figures. At the same time, it has to feature an adequate degree of generality in order to capture all kinds of flexibility providers.

Some contributions in literature already deal with the description of power-related flexibility. For example, Reference [22] designed a taxonomy for modeling flexibility. In order to characterize different types of flexibility, the authors defined the taxonomy “buckets”, “battery”, and “bakery”. These types exhibit various key figures such as power states, energy capacity, energy level at a specific deadline, and minimum runtime. In [23], the authors developed a clustering of flexibility into four groups: load curtailment, load shifting, onsite generation, and utilizing electricity storage systems. Each group is described by various constraints. Based on that, the authors derived a decision-making model for DR aggregators in wholesale electricity markets. However, those forms of flexibility have been modeled in a simplified way and a precise description of the flexibility of industrial processes is not possible with this approach. Additionally, the authors use different key figures for each cluster, making the model rather unwieldy. Finally, based on an in-depth literature review, Reference [24] presents a more generic approach in their work. They define a catalog of features whose generic optimization models must take into account to describe all possible kinds of flexibility (see Section 6). However, our work in a major German research project shows that also this catalog and in particular its implementation exhibit several shortcomings. The following three aspects outline the contribution of our work:

- We propose a generic data model which we developed in the course of a major German research project to model power-related flexibility. The modular structure of the data model allows us to precisely describe different types of flexibility.
- The data model allows transferability among different sectors and hence provides an opportunity for standardization. It therefore constitutes a basis for integrating flexibility into information systems and thus improved information exchange and a higher automation level. This allows for automating the use of flexibility.
- We validate our data model in close collaboration with companies from a major German research project. In the process, it has been demonstrated that the data model is suitable to represent flexibilities with different characteristics of the companies.

The focus of this article is on the description of generic power-related industrial flexibility, although our results are sufficiently generic to also apply to households [25], small-scale industries, trade, services [26], and supply side flexibility. Electric cars will also become increasingly important as novel participants in the electricity system [27,28]. The data model can also be applied to the charging and discharging of electric cars. Usually, flexibility exhibits one or more degrees of freedom and can therefore be regarded as a subset of a multi-dimensional space. In order to describe a specific instance of a flexibility, i.e., an element of this space, we also present a data model for what we will call flexibility measures.

The remainder of this paper is organized as follows. In Section 2, we describe the research project in which we developed and validated our generic data model. Next, in Section 3, we present the proposed data model for industrial flexibility by discussing the involved subcategories. In particular, we explain the need for and limitations of each of the subcategories' key figures. In Section 4, we then derive the corresponding data model for flexibility measures. Afterwards, we present how the data model can be used for different applications by means of two exemplary use cases in Section 5. In Section 6, a discussion compares our data model with existing work. Finally, Section 7 summarizes the main findings and gives an outlook on future research.

2. Empirical Foundations

As already mentioned, the data model was developed in a major German research project, namely "SynErgie". It is part of the program "Kopernikus projects for the Energiewende" which develops technological and economic solutions for the transformation of the energy system. It consists of an interdisciplinary consortium which involves more than 80 partners from science, industry, and civil society. The SynErgie project aims to synchronize the energy demand of industrial production processes with the fluctuating power supply from renewable sources. For this purpose, a highly dynamic meta-platform based on modern information and communication technology is developed in order to connect companies with flexibility markets and supporting services [14]. Consequently, this platform requires a standardized description of companies' flexibilities. In the course of the project, we were able to develop and discuss the data model in close collaboration with our scientific partners as well as companies from the following electricity-intensive sectors: steel and aluminum production, chemical industry, machinery and plant engineering, and paper, food, cement, and car industries. In Germany, these sectors account for approximately 90% of the net industrial electricity demand and 40% of the whole net electricity demand. We conducted several workshops and project meetings with experts from the involved companies. Moreover, we modeled different flexibilities of various project partners and validated them in tests. In particular, the description of these real-world flexibilities guided us through our research and helped to develop and successively improve the data model which we present in the following.

3. Proposed Generic Flexibility Data Model

3.1. Heuristics

Modeling is generally a systematic abstraction of the real world. On the one hand, one has to describe the real world with sufficient accuracy. On the other hand, the model must be as simple as possible, in particular in case it is meant for practical applications. It is therefore necessary to make simplifying assumptions in the right places. After giving an overview of the subcategories of our data model (this Section), we will derive the corresponding key figures, explain why they are necessary, and discuss the underlying assumptions and simplifications in Sections 3.2–3.4.

Our data model for flexibility contains components which can be chosen from three subcategories: flexible loads, dependencies, and storages. We define a **flexibility** as a collection of such components. A flexibility has to contain at least one flexible load. It may, however, exhibit any number of dependencies and storages. Figure 1 schematically visualizes the basic idea of the modular data model based on two exemplary flexibilities. Flexibility 1 exhibits three flexible loads. Moreover, flexible load 1a and 1b are interrelated by a dependency. The reader might consider the following illustrative example for such a constellation: a graphitizing oven exhibits two production phases which are represented by flexible load 1a and flexible load 1b. The second phase (flexible load 1b) always follows the first phase (flexible load 1a). The dependency then can describe that flexible load 1b requires the usage of flexible load 1a some time in advance. Flexible load 1c is an independent production machine, which at the same time exhibits flexibility. Flexibility 2, which can be associated with the same or another company, features two flexible loads, one dependency, and two storages. One storage is linked to two flexible loads, whereas the second storage is linked to only one flexible load. For instance, flexible load 2a and 2b can be two machines that manufacture the same product in different ways and store it in the product warehouse (storage 2a). Dependency 2 then accounts for the fact that the machines must not be operated simultaneously. Moreover, flexible load 2b utilizes the generated waste heat and stores it in a heat reservoir (storage 2b). As Figure 1 illustrates, dependencies and storages always refer to flexible loads among the flexibility. In other words, a flexibility is a *closed* object.




Figure 1. The generic data model enables a uniform and modular description of industrial flexibility.

We regard a power-related flexibility as the opportunity to deviate from the original schedule with a resulting change in power consumption. Typically, a flexibility originates from one or more devices (units, machines). Such devices can exhibit different degrees of freedom regarding how they

may operate, e.g., at different times or energy levels. We call the flexibility associated with an isolated device a **flexible load**. Our modelling of a flexible load will be detailed in Section 3.2. One can take into account the aforementioned degrees of freedom by representing each dimension by an associated key figure. A flexible load therefore parameterizes a set of individual load curves which can be realized by the flexible device. We call a single usage of a specific realization a **flexible load measure**. It can be imagined as a specific choice from the range of each key figure of a flexible load. The corresponding key figures which describe the flexible load measure will be denoted in *italics* with an attached asterisk (*). We will explain flexibility measures and flexible load measures in detail in Section 4. Thus, a filled data model for a flexible load does in general not only contain numbers, but also subsets (ranges) of a corresponding basic set \mathcal{S} . In other words, they are elements of the corresponding power sets $2^{\mathcal{S}} = \mathfrak{P}(\mathcal{S})$. Moreover, the key figures of a flexible load may have intrinsic interrelations. This means that not every key figure can be chosen freely from its associated base set. In other words, the choice of one key figure might restrict the accessible values for another key figure. For instance, some choices of key figures might be functions of the choices of other key figures within a flexible load measure and thus implicitly defined. Of course, we could in principle also define a separate flexible load for any combination of interrelated key figures. However, with the possibility of dependent key figures, the flexibilities can be defined more compactly and the partition of the process into flexible loads is more intuitive. In Section 5, when we will have given a detailed explanation of the key figures, we will give illustrative examples for this property. Imagine that (ignoring units) the value of *key figure 1* may be chosen freely in the interval $\mathcal{S} = [0, 10]$ and *key figure 2* (also ignoring units) always has to be twice the value of *key figure 1*. Then, one would be tempted to write the following:

$$\begin{aligned} \textit{key figure 1} &= [0, 10]; \\ \textit{key figure 2} &= 2 \times (\textit{key figure 1}). \end{aligned}$$

Since *key figure 1* is given by a set, one would interpret the function $f : x \mapsto 2x$ as a set-valued function, the result being the image set of $[0, 10]$ under f and hence *key figure 2* = $[0, 20]$. This would give the impression that the value of *key figure 2*, i.e., *key figure 2**, may be chosen freely within the interval $[0, 20]$, which is clearly not what we intended. What we wanted to say is that for every flexible load measure specified by the corresponding flexible load, the functional relationship between the associated key figures must hold: *key figure 2** = $2 \cdot (\textit{key figure 1}^*)$.

If there are several flexible loads involved in an industrial process, one might expect that one can represent this in our data model by simply moving to product spaces, i.e., arbitrary combinations, of flexible loads. However, we observed that, in reality, we cannot assume that a flexible load is always isolated. Consequently, similar to what we explained for intrinsic interrelations of key figures within a flexible load, also key figures from different flexible loads might be related. Thus, not all of the aforementioned product space is accessible. From our observations in SynErgie, we learned that it is usually sufficient to consider only logical interrelations among pairs of flexible loads. They are typically related to certain requirements on process sequences. We will call the subcategory which describes such interrelations **dependencies**. A dependency thus connects key figures from the two involved flexible loads. This is achieved by defining suitable key figures for dependencies, which in turn refer to key figures of (measures of the) interdependent flexible loads. These will be described in detail in Section 3.3.

Finally, we observed interrelations which can be clustered under the common term **storages**. We will introduce storages in Section 3.4. It is important to keep in mind that batteries are rather an exception in industrial processes. When thinking about storages, one should rather consider stocks for products in batch processes or reservoirs for heat, cold, or chemical products. Unlike dependencies, storages only pose constraints on the energy consumption of the flexible loads which they are connected to. In other words, the energy content of storage must satisfy certain bounds for all times. Moreover, in contrast to dependencies, storages can also cause costs.

As opposed to flexible loads, both dependencies and storages do not add any degrees of freedom to the flexibility. They pose boundary conditions which restrict the admissible combinations of flexible load measures among which we may choose or optimize in a subsequent step. This explains why we did not allow to define a flexibility which does not contain a flexible load: in this case, the flexibility space would be empty and could thus be ignored. Figure 2 illustrates two flexible loads each of which are assumed to exhibit one degree of freedom. The respective degrees of freedom are depicted on the two axes. The flexible loads are further interconnected by a dependency as well as storage. Recall the above example where two machines (flexible loads) are connected by a dependency and supply storage. The degree of freedom results from *key figure 1* for both flexible load 1 and flexible load 2. Figure 2 illustrates that flexible load 2 has more freedom than flexible load 1. The resulting black area in the middle is the remaining, accessible flexibility: Only certain combinations of measures of the two associated flexible loads are accessible. If there were no constraints involved, any combination of measures from flexible load 1 and 2, i.e., the whole rectangle, would be accessible. An optimization (with respect to a certain objective function) will then choose the “best” element among the (accessible) flexibility, i.e., a flexibility measure, which can then be executed.




Figure 2. Our definition of a flexibility, visualized in a setting with two flexible loads with each exhibiting one degree of freedom.

In the following subsections of Section 3, we define the key figures of the three subcategories flexible loads, dependencies, and storages.

3.2. Flexible Loads

Let us consider a non-empty planning horizon $\mathcal{H} \subset \mathbb{R}$. One would imagine a planning horizon as a certain time interval, e.g., from 8:00 a.m. to 6:00 p.m. on a specific day. It is in general given by a subset of the reals. We decide that the unit is seconds, measured with respect to the common reference point 1 January 1970, which is—apart from units—close to what one would regard a date–time from a programming-oriented perspective. As already discussed, a flexible load describes the opportunity of an isolated device to deviate from the scheduled power consumption. Hence, it can be seen as a family of maps $p : \mathcal{H} \rightarrow \mathbb{R}$ which associate with every time t in the planning horizon \mathcal{H} the corresponding change in power consumption $p(t)$. Mathematically, we could consider any subset of $\text{Abb}(\mathcal{H}; \mathbb{R})$, which denotes the set of all functions from \mathcal{H} to \mathbb{R} .

However, in SynErgie, we learned that, for practical purposes, this generality goes too far. In the following, the required key figures for a flexible load are derived from the findings in the project. It turned out quickly that it is not necessary to include arbitrarily complicated families of load curves $p(t)$ into our model. Rather, for applications, it is sufficient and more practical to restrict to families of maps $p : \mathcal{H} \rightarrow \mathbb{R}$ which can be described by means of periods of constant increase or decrease in load (“modulation periods”), and periods of constant load (“holding periods”). Note that although mathematically periods of constant load are a special case of the former with the rate of change (slope) being zero, we distinguish these periods in order to foster intuition and to account for the different characteristics of the physical processes. One can regard our approximation as a specific linearization of load curves. However, it is important to highlight that we do not linearize a fixed function, but rather a collection of functions, and thus preserve the degrees of freedom. Figure 3 illustrates an exemplary flexible load measure, i.e., one special load curve in the family which is meant to be parametrized by the key figures of the corresponding flexible load. In Figure 3, the different phases and their respective durations are depicted.




Figure 3. An exemplary flexible load measure with the corresponding parameters.

Apart from power consumption depending on time, a flexible load also exhibits some other relevant characteristics, such as integration in an IT-system or costs, which have to be included in our data model. With this preliminary work, we are now prepared to discuss all the key figures of the subcategory flexible load.

3.2.1. Flexible Load ID

A company can have a large number of devices which exhibit flexibility. Within a company, production is usually managed and controlled via an IT system, for example an ERP system. To be able to easily manage them, a flexible load thus requires a *flexible load ID*. The available systems must also consider the *flexible load IDs*. The key figure *flexible load ID* is used to uniquely identify a flexible load and hence to address the corresponding device in case it is used. As will become clear in Section 3.3.1, it is explicitly possible that multiple flexible loads with multiple *flexible load IDs* refer to the same device. This key figure is important when execution of a (specific) flexibility measure must be ordered by the IT system of a company.

3.2.2. Reaction Duration

In case the execution of a flexible load measure is ordered, it is highly relevant how long it takes from giving the command to activate until a change in power really starts. For this reason, it is necessary to add the key figure *reaction duration* to our model. In an automated system, this is comparable to the latency time that occurs during the transmission of signals. For processes that still require a lot of manual effort, the *reaction duration* can also refer to other kinds of delay. For example, an employee might need some time in advance in order to prepare a machine accordingly. Therefore, the reaction time can be interpreted as the duration between pulling the trigger and the start time of the flexible load measure. The *reaction duration* is of high relevance especially in time-critical applications. For example, in the case of control power, flexibility must be provided within a short period of time. Of course, we make the assumption that a company can determine the *reaction duration*. This is particularly challenging when the response time is not just given by the latency time of an IT system. The *reaction duration* in our data model has the unit seconds and is given by a real number which by causality is non-negative.

3.2.3. Validity

Flexible loads are usually only available within certain time windows. The reason is that, for companies, compliance with delivery obligations naturally has a higher priority than the utilization of flexibility. Hence, restrictions associated with time of use can depend, for example, on the production plan, since this determines when machines operate and could be switched off. Another reason is that machines may have to be maintained and operated during shift times and are therefore not always available. Moreover, for many electricity-intensive companies, technical restrictions or grid fees pose a central boundary condition regarding time periods of increased electricity consumption. Therefore, the key figure *validity* is an essential part of the data model and serves to consider restrictions with respect to availability over time. We use it to define when flexibilities may be used. Consequently, *validity* is a subset of the planning horizon. As opposed to other key figures, we assume that the *validity* is fixed and does not depend on any other key figure. As for the planning horizon, our unit here is seconds since 1 January 1970. Recalling the example of shift times, we cannot expect that it is usually an interval. In SynErgie, we have investigated a wide range of flexibilities, some of which have quite special temporal characteristics. For example, it is common for some companies to start flexible processes within a certain time window. By contrast, other processes have to be completed at a certain point in time. Another observation was the necessity to define a time window in which the whole execution of a flexible load must be completed. Therefore, we need to define the *validity* with respect to a certain reference. Based on our observations, the following three references are necessary: "start", "total", and "end". The reference "start" indicates that the start time of a flexible load measure must lie within the *validity*. Similarly, the end of a flexible load measure must lie within the defined interval for the reference "end". The reference "total" specifies that the entire load profile of a flexible load measure must lie in the interval specified by the key figure *validity*. This distinction is particularly relevant for flexible loads with many degrees of freedom. For these, start time, end time, and total time can usually not be converted into each other at the level of a flexible load. As already mentioned, these three references were sufficient in order to encompass all the flexible loads which we encountered in SynErgie. However, one could think of special cases which can not be expressed by any of the three proposed references. For example, imagine that the first half of a process must be completed within the *validity* since it must be supervised by an employee. However, note that, by splitting this example into two separate flexible loads and defining suitable dependencies (see Section 3.3), one could even model such cases with our data model.

3.2.4. Power States

As already discussed, industry processes can usually operate at different levels with regard to power consumption. That is why we introduce the key figure *power states*. It defines the admissible power levels of the plateaus, i.e., during holding periods (see Figure 3). Depending on the choice of perspective, both the absolute power values and the deviation from the scheduled load can be defined as *power states*. With *power states*, we describe situations in which devices have a constant power consumption. Of course, these can also be very short periods of time. *Power states* for subsequent holding periods may be different, in fact, this is the case for all variables which need to be specified repeatedly. For the key figure *power states*, both continuous and discrete subsets of the real numbers are possible as basic sets. Continuous *power states* occur, for example, in cooling units. Here, the power consumption can be set almost arbitrarily within a specific interval. On the other hand, there are processes, e.g., electrolysis, in which only discrete *power states* are permitted. The unit for *power states* are chosen to be kW. A positive resp. negative sign represents an increase resp. a decrease in electricity consumption.

In reality, the actual electricity consumption is rarely constant. However, in the energy industry, the time interval of 15 min is established as the shortest observation period. On power markets, for example, the products with the shortest duration are 15-min products. This implies that our assumption of constant consumption in certain segments is practicably as good as an exact modelling. In this case, it is important to keep in mind that the key figure *power state* does not precisely represent the actual physical state.

3.2.5. Holding Durations

As we already mentioned above, the key figure *power states* is related to temporarily constant states. Machines often need electricity for a certain period of time, e.g., to manufacture a product. The durations of *power states* are specified by the key figure *holding durations*. The *holding duration* specifies the range in which the chosen *power state* may be held. As a unit, we choose the SI base unit seconds. Analogous to the *power states*, we adopt the simplified view that the actual duration is known exactly in advance. Of course, in reality, it can happen that processes are completed earlier or later than planned.

3.2.6. Usage Number

In practice, we observed many flexible loads which admit multiple runs within their *validity*. For instance, when manufacturing a product, a production step must be repeated. To avoid the need for defining several identical flexible loads which are mutually exclusive during their time of use, the data model contains the key figure *usage number*. It describes the number of permitted activations (usages) of a flexible load within its *validity*. The *usage number* is given by a subset of the natural numbers (including zero). We want to emphasize that it is not necessary to select identical flexible load measures in repeated usages. For example, if *power state*₁^{*} was selected for the first usage, a different *power state*₂^{*} can be selected for the second use. However, by definition, the corresponding ranges can depend on the usage number^{*}. For instance, in a thermal process, it is likely that multiple usages will require either a smaller *power state* or a shorter *holding duration*. If a company is aware of these relations, the *power states* in this example could be a function of the *usage number*.

3.2.7. Modulation Number

So far, we have had the picture in mind that flexibilities have exactly one holding period, after which the load profile returns to the zero state. However, there are many processes that can adapt their *power state* during one usage several times (see Figure 3). A usage refers to the sequence of: *Power state* is equal to zero, followed by some changes in power consumption, and ends again with a *power state* of zero. As an example, one can think of heating processes, which modulate their *power states*

from time to time. In addition to industrial processes, power plants can also be considered: As soon as these are operated, the *power state* changes several times before the power plant is switched off again. This leads to the key figure *modulation number*. It states the number of modulations (changes of the *power state*) which may take place during one usage of the process. Activation and deactivation are regarded as special cases of a modulation, since the restrictions posed on the initial and final power change are often different from the ones posed on modulations in between. The *modulation number* is given by a subset of the natural numbers.

3.2.8. Activation Gradient, Modulation Gradients, and Deactivation Gradient

With regard to the activation, modulation, and deactivation phases, the intensity or speed of the power change is a relevant parameter. It can, for example, be restricted due to constraints when heating material. Moreover, many devices cannot be switched off at arbitrary speed. We introduce the key figures *activation gradient*, *modulation gradients*, and *deactivation gradient*. The corresponding durations can easily be calculated from the respective gradient and the difference in neighbouring *power states* to be reached. Respecting the units for *power states* and *holding durations*, we define the unit to be $\frac{\text{kW}}{\text{s}}$. All gradients are given by subsets of the extended real numbers, i.e., we also allow plus and minus infinity as legitimate gradients. This makes sense with the convention $\frac{1}{\pm\infty} := 0$, since in an optimization the only relevant quantities are energy consumption and time which are both indirectly proportional to the gradients. The *activation gradient* resp. *deactivation gradient* specifies which slopes the load curve can exhibit during the activation resp. deactivation phase. The key figure *modulation gradients* is the analog for modulation phases. The *activation* and *deactivation gradients* are required in addition to the *modulation gradient* since the speed of activation and deactivation often differ from a modulation. If a machine has already been warmed up, it can usually change its output more quickly. Thus, it is likely that the *modulation gradients* may depend on previous *power states* and the *holding durations*. The *deactivation gradient* is the analog of the *activation gradient* for the deactivation phase. We adopt the convention that a positive gradient for activation, modulation, and deactivation always means that power consumption increases with time. As for *power states* and *holding durations*, we simplify the real world by linearization here.

3.2.9. Regeneration Duration

Often, one has to wait some time after a flexible load measure has been activated until another flexible load measure from the same flexible load may be activated again. This might be necessary for maintenance, chilling, or warming of the corresponding machine or product before reuse. In processes that are not yet highly automated, employees often need to remove the finished product from a machine and load the raw materials into the machine again. This characteristic must be taken into account especially for flexible loads with potentially multiple usages. Therefore, we include the key figure *regeneration duration* into the flexible load data model which specifies the time span in which, after completion of a flexible load measure, the flexible load must not be activated again. In other words, the *regeneration duration* refers to the minimum waiting time in seconds after the end of a flexible load measure. A *regeneration duration* of 0 seconds means that right after a flexible load measure has ended, another flexible load measure from the same flexible load may be activated. In practice, this key figure often depends on the characteristics of other key figures. If, for example, the *regeneration duration* is caused by a cooling process, the *regeneration duration* can probably depend on the previously attained *power states* and *holding durations*. This also goes along with the limitation that these relations must be exactly known in advance in order to be able to model the *regeneration duration* exactly.

3.2.10. Costs

The flexible operation of machines usually causes additional costs. They might stem from higher expenses, e.g., due to higher wear and tear of machines in atypical operation. It is also conceivable that increased personnel hours and associated expenses such as handling and maintenance must be accounted

for here. In addition, for some machines, manufacturers give a warranty covering a certain number of power changes. As soon as this is exceeded due to frequent usage of a flexible load, the warranty for the corresponding machine expires. This circumstance must also be taken into account.

For this reason, the key figure *costs* is also part of the data model. The unit of this key figure is the chosen currency, in our case, Euro. We explicitly do not include electricity costs in this key figure. The reason is that these depend on company-extrinsic parameters such as (expected) electricity price and are not necessarily known in advance. However, from integrating the product $p(t) \cdot \pi(t)$ where $\pi(t)$ denotes the (expected) electricity price at time $t \in \mathcal{H}$, one can easily calculate the (expected) electricity costs. The key figure *costs* is likely to have dependencies on other key figures. For example, high values for *power states* or gradients can influence the degradation of the infrastructure and thus the associated costs. With regard to *costs*, the limitation is that companies must know the relations exactly. Otherwise, if the exact *costs* are unknown, one can define a threshold value to consider an increased risk of wear and tear. In the end, the *costs* decide whether a flexibility is used or not. Therefore, they must be modelled as accurately as possible. However, since most industrial machines are designed for continuous operation, the *costs* incurred are often not known.

3.2.11. Summary: Flexible Loads

Table 1 provides an overview of all presented key figures which we use to describe flexible loads. With regard to the convention of plural or singular key figures, we have defined the following: key figures that can have more than one value during one usage are denoted in the plural, the remaining key figures—apart from *costs*—are in the singular.

Table 1. Key figures for flexible loads.

Key Figure	Type	Unit	Description
<i>Flexible load ID</i>	String	-	An identifier for the flexible load that might be used by an IT system in order to manage it. The <i>flexible load ID</i> serves for fast and easy identification, especially if there is a large number of flexible loads present.
<i>Reaction duration</i>	$2^{\mathbb{R}_0^+}$	s	The time between pulling the trigger and the start of a flexible load measure. This key figure is of interest for correct and timely execution of usage commands.
<i>Validity</i>	$2^{\mathcal{H}} \times \{\text{"start", "total", "end"}\}$	s	The subset of the planning horizon at which the flexible load is available. The three references ("start", "total", and "end") define which parts of the total time of associated flexible load measures must lie in the <i>validity</i> .
<i>Power states</i>	$2^{\mathbb{R}}$	kW	The powers at which the flexible load can run during each of the (<i>modulation number</i> + 1) holding periods. A positive sign means that the flexible load causes an increase of electricity consumption, negative <i>power states</i> represent a decrease in consumption.
<i>Holding durations</i>	$2^{\mathbb{R}}$	s	The lengths of time periods for which the flexible load runs at its <i>power states</i> . Every holding period is the time with constant <i>power state</i> between two consecutive modulations, including activation and deactivation.
<i>Usage number</i>	$2^{\mathbb{N}}$	-	The permitted number of usages of the flexible load in the planning horizon.
<i>Modulation number</i>	$2^{\mathbb{N}}$	-	The number of allowed <i>power state</i> modifications within one usage of a flexible load, excluding the two modulations which correspond to initial activation and final deactivation.
<i>Activation gradient</i>	$2^{\mathbb{R} \cup \{\pm\infty\}}$	kW · s ⁻¹	The rates at which the power curve can change its power at initial activation. If the <i>power state</i> increases, the <i>activation gradient</i> has a positive sign.
<i>Modulation gradients</i>	$2^{\mathbb{R} \cup \{\pm\infty\}}$	kW · s ⁻¹	Analogous to the <i>activation gradient</i> for the modulation periods.
<i>Deactivation gradient</i>	$2^{\mathbb{R} \cup \{\pm\infty\}}$	kW · s ⁻¹	Analogous to the <i>activation gradient</i> for the final deactivation period.
<i>Regeneration duration</i>	$2^{\mathbb{R}_0^+}$	s	The time for which, after the deactivation of a measure from the flexible load is finished, no (other) measure from the same flexible load must be activated.
<i>Costs</i>	$2^{\mathbb{R}}$	€	The <i>costs</i> associated with the use of the flexible load, electricity costs excluded.

3.3. Dependencies

As already mentioned in Section 3.1, we observed that there are often logical constraints among different flexible loads. A dependency describes the impact of an activation of a measure corresponding to a certain flexible load on another measure from a different flexible load. We observed that two logical types, namely implication and exclusion among pairs of flexible loads, are sufficient in order to describe those logical constraints. However, extension to more flexible loads as inputs would be straightforward, but would also make the data model more complicated. In the following, we describe the key figures which specify a dependency.

3.3.1. Trigger Flexible Load, Target Flexible Load, and Logical Type

A dependency always refers to a pair of flexible loads. Therefore, we introduce the two key figures *trigger flexible load* and *target flexible load*. This means that usage of any of the flexible load measures from the *trigger flexible load* poses some constraint on the usage of the *target flexible load*.

In addition, it is necessary to describe the dependency type. By an “implies”-dependency, we mean that, for every usage of a flexible load measure from the *trigger flexible load*, some uniquely associated flexible load measure from the *target flexible load* must be activated. In particular, the usage number* of the *trigger flexible load* in the planning horizon cannot be larger than the usage number* of the *target flexible load*. We realized the need for the “implies”-dependency for the following situations: In several production processes, a certain order of steps needs to be fulfilled. As another example, if the output is reduced at a certain point in time, the production that has to be renounced must be recovered at a later stage by increasing the output.

On the other hand, an “excludes”-dependency states that the usage of some flexible load measure from the *trigger flexible load* forbids usage of any of the flexible load measures in the *target flexible load*. The “excludes”-dependency is necessary, for example, in order to avoid consumption peaks, which are relevant for network charges. Moreover, it can be used to model a device which is involved in very different processes such that the flexibility associated with this device can not be described by only using a single flexible load.

Note that, by combining two dependencies with suitable *trigger flexible loads*, *target flexible loads*, and *logical types*, one can also model further logical interrelations such as “if and only if” and “exclusive or”.

3.3.2. Temporal Type and Applicability Duration

In order to respect the temporal characteristics of the dependencies that we observed in SynErgie, we also introduce the key figures: *Temporal type* and *applicability duration*. The reason is that, for both “implies”- and “excludes”-dependencies, one must be able to specify the period for which these dependencies are valid. The key figure *applicability duration* represents this property. It is given by a subset of the real numbers (typically an interval) and has the unit seconds. In the case of an “implies”-dependency, the *applicability duration* states that within the specified period the *target flexible load* must be activated. Similarly, for an “excludes”-dependency, the *applicability duration* indicates that the *target flexible load* must not be used during this time.

The *applicability duration* can have different reference points. Thus, analogous to our approach for the key figure *validity*, we need to add a time reference. Therefore, we introduce the key figure *temporal type*. Since the reference must be applied to both the *trigger flexible load* and the *target flexible load*, the *temporal type* is given by a tuple, consisting of combinations of “start”, “total”, or “end” in both components. The first component refers to the temporal reference for the *trigger flexible load*, the second to the *target flexible load*. Combining *applicability duration* and *temporal type*, a flexible load measure from the *trigger flexible load* yields an interval in which the flexible load measure of the *target flexible load* must or must not lie.

Figure 4 visualizes some possible combinations of these two key figures. For a specified *trigger flexible load A*, the figure illustrates the accessible times for the usage of the *target flexible load B*. The holding duration of flexible load A is fixed and given as depicted, and the *applicability duration* is given by $[-30\text{ s}, 60\text{ s}]$. The orange bars denote the part of the planning horizon in which—once a measure in flexible load A has been determined and hence in particular the temporal component is specified—a measure from flexible load B may be activated. For simplification, we assume that the temporal component for flexible load B is also fixed. Then, the part of the total usage duration of flexible load B which is coloured in orange must lie within the orange bar.




Figure 4. Logical type, temporal type, and applicability duration.

The following practical examples further illustrate the possibilities of combining dependencies with different *applicability duration* and *temporal type*. The *trigger flexible load* is called “C” and the *target flexible load* is called “D”. Firstly, due to process interdependencies, C and D should not be active at the same time. For this example, *logical type* has the value “excludes”, the *applicability duration* is $[0, 0]$ and the *temporal type* is $\{“total”, “total”\}$. Secondly, as the material has to be replaced in machines after completion of process C, further processing D can be carried out at the earliest 20 s after completion of C. At the same time, D must be completed two minutes after C at the latest. Therefore, two additional dependencies must be defined: One with *logical type* “excludes”, *applicability duration* $[0, 20]$, and *temporal type* $\{“end”, “start”\}$ ensures that D does not start earlier than 20 s after C. The second dependency with *logical type* “implies”, *applicability duration* $[0, 120]$, and *temporal type* $\{“end”, “end”\}$ ensures that D ends two minutes after C at the latest.

Finally, we want to highlight that—strictly speaking—the *regeneration duration* which we defined for flexible loads is a special case of a dependency. In this case, *trigger* and *target flexible load* are identical, and *logical type*, *temporal type*, and *applicability duration* are given by: “excludes”, (“end”, “start”), $[0, \textit{regeneration duration}^*]$. However, the *regeneration duration* can be regarded as an intrinsic property of a flexible load, and only requires the specification of one parameter, which led us to define it as a separate key figure.

3.3.3. Applicability Conditions

In the case of dependencies between two flexible load measures, in SynErgie we have often observed that there are additional conditions which need to be fulfilled. These can be defined in

the key figure *applicability conditions*. Every condition is described by an equation which refers to key figures of the two involved flexible loads. The first resp. second component of the tuple which represents the equation are regarded as left resp. right-hand side of the equation. The *applicability conditions* are regarded to be satisfied if for every $i \in \{1, \dots, n\}$, both components of the i th component of *applicability conditions* have the same value. A constraint posed by a dependency which exhibits *applicability conditions* are not satisfied, the dependency is regarded is only then regarded as fulfilled if the *applicability conditions* are met. In other words, an activation of the *trigger flexible load* implies an associated activation of the *target flexible load*—respecting the constraints given by the other key figures—in a configuration (measure) such that the *applicability conditions* are satisfied.

As an illustrative example, imagine a process in which flexible load A describes the opportunity to reduce power consumption at a given point in time. By means of flexible load B, the energy can then be recovered. For instance, due to losses in efficiency, flexible load B must make up 1.5 times the energy of flexible load A. Therefore, the *applicability condition* is given by the tuple $(\text{energy}_B, -1.5 \times \text{energy}_A)$. The pre-factor of 1.5 means that flexible load B must consume 50% more power due to losses, which enforces the following equation:

$$\text{energy}_B = -1.5 \times \text{energy}_A. \quad (1)$$

Flexible load A has only one *power state* $\{-500 \text{ kW}\}$, but a variable *holding duration* with permitted range $[600 \text{ s}, 3000 \text{ s}]$. The *modulation number* is zero in this case. Flexible load B, on the other hand, has the fixed *holding duration* $\{900 \text{ s}\}$ and a variable *power state* $([0 \text{ kW}, 10,000 \text{ kW}])$. The constraint in Equation (1) specifies that the *power state* of flexible load B must be chosen according to the configuration of flexible load A. The relevant *power state* can be calculated as follows. First, it is necessary to calculate the electricity consumption of flexible load A. For a given *power state*, the power consumption of flexible load A which corresponds to the area of the rectangle (the gradients are assumed to be infinite here) is as follows:

$$\begin{aligned} \text{energy}_A &= \text{power state}_A^* \times \text{holding duration}_A^* \\ &= -500 \text{ kW} \times \text{holding duration}_A^*. \end{aligned} \quad (2)$$

The power consumption of flexible load B is calculated as follows, whereby the *holding duration* is given:

$$\begin{aligned} \text{energy}_B &= \text{power state}_B^* \times \text{holding duration}_B^* \\ &= \text{power state}_B^* \times 900 \text{ s}. \end{aligned} \quad (3)$$

By merging Equations (2) and (3), the additional constraint—which ensures that flexible load 2 catches up 1.5 more electricity than flexible load 1—can now be determined:

$$\text{power state}_B^* \times 900 \text{ s} = 1.5 \times 500 \text{ kW} \times \text{holding duration}_A^*. \quad (4)$$

$$\text{power state}_B^* = \frac{1.5 \times 500 \text{ kW} \times \text{holding duration}_A^*}{900 \text{ s}}. \quad (5)$$

This example illustrates which additional restrictions can be modelled by the key figure *applicability conditions*.

3.3.4. Summary: Dependencies

Table 2 summarizes all key figures of the dependency subcategory including type, unit, and description.

Table 2. Key figures for dependencies.

Key Figure	Type	Unit	Description
<i>Trigger flexible load</i>	String	-	The ID of the flexible load which triggers the dependency.
<i>Target flexible load</i>	String	-	The ID of the flexible load which is affected by the <i>trigger flexible load</i> .
<i>Logical type</i>	{“implies”, “excludes”}	-	Specifies whether a usage of the <i>trigger flexible load</i> requires that the <i>target flexible load</i> is also used (“implies”) or prevents that the <i>target flexible load</i> may be used (“excludes”).
<i>Temporal type</i>	{“start”, “total”, “end”} ²	-	The parts (“start”, “total”, “end”) of the <i>trigger flexible load</i> (first component) and the <i>target flexible load</i> (second component) which are affected by the dependency.
<i>Applicability duration</i>	$2^{\mathbb{R}}$	s	The time period for which, after usage of the <i>trigger flexible load</i> , the <i>target flexible load</i> must be activated at least once (“implies”) resp. not at all (“excludes”). Hereby, one has to keep in mind the relevant <i>temporal type</i> .
<i>Applicability conditions</i>	$(2^{\mathbb{R}} \times 2^{\mathbb{R}})^n$	-	Additional conditions which have to be satisfied such that the dependency is regarded to be fulfilled. In other words, an activation of the <i>trigger flexible load</i> implies an associated activation of the <i>target flexible load</i> in a configuration (measure) such that the <i>applicability conditions</i> are satisfied.

3.4. Storages

Energy storages are classically understood to be electrical storage devices such as batteries that have a certain storage capacity. Apart from these conventional storage systems, industrial processes often have storage potentials that can be described with similar key figures. They usually appear in form of stock for batch processes, thermal inertias, or reserves of intermediate products such as chemicals. The form of energy in a storage device is not limited to electrical energy. All forms of effective energy, e.g., heat, cold, and compressed air, whose provision is connected to a flexible load and any product whose manufacturing (or disposal) requires electrical energy can theoretically be stored. In the following, we present the key figures which are necessary for describing storage.

3.4.1. Storage ID

Just as it is important for flexible loads to have a clear designation (see Section 3.2.1), it is also for storage systems in industrial processes. Therefore, the key figure *storage id* is implemented. This key figure is an identifier for storage in the company’s IT system and assigns a unique name to the respective storage system. This is particularly important if a storage is connected to several flexible loads or if one flexible load can supply different storages (see Figure 1). For example, an intermediate product or raw material warehouse can serve different devices.

3.4.2. Usable Capacity

The indication of capacity is indispensable for the characterization of a storage facility as it limits the quantity of the good resp. energy to be stored. Therefore, the key figure *usable capacity* is part of the data model. However, in the context of energy flexibilization, it is often not the maximum energy content of a storage facility that is relevant, but the proportion available for flexibilization. One example are thermal storages. While, from a physical point of view, one would have to refer to the ambient temperature or the temperature zero point when calculating the energy content, the capacity of interest in the context of energy flexibility is usually limited by the minimum and maximum process temperatures allowed. Batteries are another example. With a nominal storage capacity of 30 kWh,

the *usable capacity* (which in literature is sometimes also-called useful capacity in the context of batteries) might be restricted, for example to extend the lifetime of the battery storage, as this is depending on the depth of charge and discharge cycles [29]. Although not all storage systems directly refer to energy quantities, a representation in the form of energy quantities is reasonable in order to compare different types of storages and suppliers (see Section 3.4.6). For example, the energy content of a thermal storage can be compared with that of a compressed air system. The *usable capacity* is specified as an interval in kWh whose lower bound may never be undershot and whose upper bound may never be exceeded by the energy content of the storage.

3.4.3. Initial Energy Content

It is important to specify the energy content in the storage—the *initial energy content*—at a specific time stamp. For example, a fully charged storage facility cannot be used directly to provide a load increase. If the storage facility is operated over several charging cycles during long planning periods, the *initial energy content* usually has less influence on the result than if only one charging cycle is considered. This key figure is specified in kWh and the corresponding time stamp in seconds.

3.4.4. Target Energy Content

In some cases, a specific energy level must be reached in the storage at a certain point in time. Examples for this are batteries of intralogistics vehicles, which should be fully charged at the beginning of a shift. Another example are product warehouses, which must be full as soon as the delivery date is due. These circumstances can be defined in the key figure *target energy content* with a corresponding time stamp. It is not necessary and expedient to specify an exact *target energy content* in all cases. Often it is sufficient to know which upper and lower limits must not be exceeded for the energy content of the storage (*usable capacity*). In general, the *target energy content* is defined as a subset of the usable capacity. Its unit is kWh and the time stamp is given in seconds.

3.4.5. Energy Loss

Many storage types are characterized by time-dependent losses of the medium to be stored. For example, the temperature of thermal storage tanks adjusts to the ambient temperature over time, which means that the exergy to be stored gets lost. Compressed air reservoirs also lose their pressure level due to leakages of the storage system. In order to take these unavoidable losses into account, the key figure *energy loss* is necessary. It is defined as the share of the current energy content which gets lost every time period in $\frac{\%}{s}$, in the planning horizon.

3.4.6. Suppliers

The linking between flexible loads plays a fundamental role in modeling systems with energy storages. For example, a product warehouse can be filled by different production systems or a compressed air reservoir by different compressors. Depending on the *suppliers* or the storage facility, a specific efficiency is achieved with which the energy storage facility is filled. Thus, two machines which fill the same warehouse can produce the same product with different efficiency. If the product is now considered with an energy equivalent, this results in a different conversion efficiency for the two machines. The same applies to two compressors filling a compressed air reservoir with different degrees of efficiency. Not only is the efficiency of the energy converter relevant, but also the storage type. For example, a 12 bar compressed air storage is charged with a significantly lower degree of efficiency than a 6 bar storage. For this reason, the linking between a flexible load and storage is modelled via an ID of the *supplier* with an associated efficiency description. The degree of efficiency can depend on all key figures of the *supplier*.

3.4.7. Drain

In many cases, unchangeable loads must be served during production. In contrast to *suppliers*, a *drain* does not provide any flexibility and therefore only represents a fixed deterministic demand. In the data model, the *drain* is therefore given by a function $d : \mathcal{H} \rightarrow \mathbb{R}$ which assigns to every time in the planning horizon the power in kW which is flowing off.

3.4.8. Costs

Costs can occur not only during the conversion of energy, i.e., with regard to flexible loads, but also at the time of storage. Certain charging strategies can lead to increased storage wear, which in turn increases costs in the long term. For example, lithium ion batteries do not withstand high power gradients or deep discharges. We assume that the *costs* of storage only depend on its (time-dependent) energy content. It is important to note that this figure only includes storage-related *costs*. *Costs* arising from the flexible operation of the *suppliers* must not be taken into account here since they are already included in the data model for flexible loads.

3.4.9. Summary: Storages

The derived key figures enable the modeling of various storages, e.g., product or electricity storages in industry. Note that the key figures of storage are in general not interrelated with other key figures of flexible loads, dependencies, and storages. However, there are two important exceptions: First, the conversion efficiency associated with a *supplier*, i.e., a flexible load, may depend on key figures of precisely this flexible load. Second, the *costs* induced by storage may only depend on the (time-dependent) energy content of the respective storage. The key figures contained in the data model and the associated types, units, and descriptions are summarized in Table 3.

Table 3. Key figures for storages.

Key Figure	Type	Unit	Description
<i>Storage id</i>	String	-	An identifier for storage in the company's IT system.
<i>Usable capacity</i>	$2^{\mathbb{R}}$	kWh	Usually given by an interval whose lower bound of storage energy content may never be undershot and whose upper bound of energy content may never be exceeded.
<i>Initial energy content incl. time stamp</i>	$\mathbb{R} \times \mathcal{H}$	(kWh, s)	Energy content of the storage at the given time stamp.
<i>Target energy content incl. time stamp</i>	$2^{\mathbb{R}} \times \mathcal{H}$	(kWh, s)	The energy content which the storage has to exhibit at the time stamp (which needs to be contained in the planning horizon).
<i>Energy loss</i>	$[0, 1]$	$\% \cdot s^{-1}$	Share of the energy content which gets lost every time period, e.g., due to exchange with the environment.
<i>Suppliers</i>	$(\text{string} \times 2^{\mathbb{R}})^n$	(kW, -)	A set of flexible loads which supply the storage. With each supplier, there comes an additional parameter, namely conversion efficiency. Note that the conversion efficiency may depend on the key figures of the associated supplier flexible load.
<i>Drain</i>	$\text{Abb}(\mathcal{H}; \mathbb{R})$	$(s \mapsto \text{kW})$	An unchangeable load which must be served during production.
<i>Costs</i>	$\text{Abb}(\text{Abb}(\mathcal{H}; \mathbb{R}); \mathbb{R})$	$((s \mapsto \text{kWh}) \mapsto \text{€})$	<i>Costs</i> associated with the usage of the storage, depending only on the (time-dependent) energy content of the storage.

4. Data Model for Flexible Load Measures

We already mentioned in Section 3.1 that we need an additional data model to describe flexibility measures. Ultimately, the aim of the data model for a flexible load measure is to specify a load curve in concrete terms. On the other hand, since for an optimization we need to assign specific costs to flexibility measures and hence flexible load measures, it is necessary to be able to compute the costs from the realized key figures. This would be complicated if the data model for a flexible load measure is very different from the data model for a flexible load, e.g., by just defining the resulting load curve as a function: in this case, it would be tedious to recover key figures like *gradients** or *holding durations**. However, the costs for flexible loads are in general precisely functions of these key figures.

What we want to emphasize here is that, although the way from a generic data model for flexibilities, which clearly is the focus of this article, to a generic data model for flexibility measures is quite straightforward, it is not completely obvious and potentially leaves ambiguities. Hence, we also provide a standardized model for flexibility measures.

The data model presented in Section 3 is the basis for the description of flexibility, i.e., spaces with degrees of freedom. One might expect that a single element in a flexibility can be specified by a choice for every key figure in every flexible load, dependency, and storage contained in the flexibility. For such instances, which according to Section 3.1 we call flexibility measures, constraints no longer have to be taken into account. Thus, all key figures for dependencies and storages can be neglected.

Hence, the next guess would be that only for the contained flexible loads, choices for the key figures have to be made. However, describing the potentially repeated usages of a flexible load in a single object would be confusing. The announced flexible load measure therefore is only meant to describe a single usage of a flexible load. In other words, for every flexible load contained in a flexibility, a corresponding flexibility measure contains usage number* associated flexible load measures. In order to distinguish key figures which refer to a choice (*) of a value in the data model for flexible loads and key figures for flexible load measures, we denote the key figures which do not occur in the final data model for flexible load measures in roman. Since the latter are not of intrinsic interest but only relevant in a supportive way, we do not provide details of the associated object any further.

In order to develop a data model for flexibility measures, it therefore suffices to specify a data model for flexible load measures. The first idea is to do this based on the key figures of a flexible load, ignoring the key figure *usage number* since this information is already contained in the number of flexible load measures in a flexibility measure. Moreover, we can eliminate the key figure *regeneration duration*, since, as we explained at the end of Section 3.3.2, this is just a further dependency. Additionally, since the usage time for a flexible load measure is fixed, we can simplify the key figure *validity to start time**, and a reference is not needed any more.

Some key figures of a flexible load have to be chosen multiple times in order to fully specify a flexible load measure. These key figures are: *power states*, *holding durations*, and *modulation gradients*. Consequently, the related key figures for flexible load measures which correspond to these three key figures of flexible loads are given by vectors. Moreover, we merge all gradients to one combined key figure, since we no longer have to distinguish activation and deactivation from modulations (see Section 3.2.7). The length of these vectors, in turn, depends on the *modulation number**.

Summarizing, our data model for flexible load measures enables retaining all storage key figures for the measures in order to be able to check the status of the storage or the fulfillment of a dependency, for example. As already mentioned, the length of some vectors depends on the number of modulations. For brevity, we define the exponent m as follows:

$$m = \text{modulation number}^* + 1. \quad (6)$$

The key figures contained in the data model for flexible load measures are summarized in Table 4.

Table 4. Key figures for flexible load measures.

Key Figure	Type	Unit	Description
<i>Flexible load ID*</i>	String	-	The ID is still necessary in order to be able to communicate the measure characteristics to the machine.
<i>Reaction duration*</i>	\mathbb{R}_0^+	s	This key figure must be kept in the described sense.
<i>Start time*</i>	\mathcal{H}	s	Coming from the key figure <i>validity</i> for a flexible lead, <i>start time*</i> gives the time in the planning horizon at which the execution of the flexible load measure begins. In contrast to the <i>validity</i> , no reference (“start”, “total”, “end”) is needed anymore.
<i>Power states*</i>	\mathbb{R}^m	kW	A vector with all <i>power states*</i> . The length depends on the <i>modulation number*</i> .
<i>Holding durations*</i>	\mathbb{R}^m	s	A vector with all <i>holding durations*</i> . The length depends on the <i>modulation number*</i> .
<i>Modulation number*</i>	\mathbb{N}	-	This key figure must be kept in the described sense.
<i>Gradients*</i>	$(\mathbb{R} \cup \{\pm\infty\})^{m+1}$	$\text{kW} \cdot \text{s}^{-1}$	The individual key figures activation gradient*, modulation gradients*, and deactivation gradients* are combined to a common vector, which contains all gradients.
<i>Costs*</i>	\mathbb{R}	€	Costs associated with the use of a flexible load measure, excluding electricity costs.

5. Examples

In the following, we use two examples to illustrate how to describe flexibilities with the presented data model for flexible loads, dependencies, and storages. We refer to two types of flexibility that cover the characteristics of many flexibilities: (1) production processes that can be started variably in time with possible modifications which exhibit dependencies and (2) processes that are connected to storages and also have dependencies. We derived these two categories from the project work, in which we examined a lot of different companies and therefore different flexibilities. Based on the experiences from the SynErgie project, we were able to assign all flexibilities we investigated to one of these types.

5.1. A Flexible Scheduling Process

Scheduling processes which exhibit flexibilities occur in many industries. For instance, in producing industries, electricity is required for the manufacturing of products (e.g., to heat up materials to temperatures which cannot be reached by combustion), whereby often dependencies with subsequent steps must be taken into account. Figure 5 illustrates the simplified load profile of an exemplary oven load curve which results from manufacturing a product. The corresponding heating process consists of two phases, which are directly consecutive and last for two hours. In this case, two trapezes, i.e., load curves without modulations, constitute the entire load profile. In the range between 65 and 70 min, the first phase ends, while the second phase begins. The separate curves are dashed, and the actual total load profile of the process is the sum of the two curves.

In this context, two different types of flexibility are relevant for the oven load curve. Firstly, it has a degree of freedom over time, i.e., the process can be started variably within a certain time window. This flexibility, for example, might result from the fact that the process must run once a day, but it does not matter when it runs. Secondly, it is possible to deviate from the normal oven process (load profile

in Figure 5), e.g., by adjusting the *power state* for a certain time period. For instance, this opportunity exists due to thermal inertia, as the produced material cools down only slowly.




Figure 5. The load profile of the exemplary scheduling process.

For comprehensibility, we first consider only the degree of freedom over time. First, we represent the load curve from Figure 5 in the data model. Based on this, the start time can be optimized, e.g., with regard to electricity costs. In accordance with the illustration in Figure 5, Figure 6 presents the filled data model that defines the two trapezoids of the described load curve. The left part contains the key figures for flexible load 1 (trapezoid 1 in Figure 5); on the right-hand side, there are the key figures for flexible load 2 (trapezoid 2 in Figure 5). In the center, we specify the dependency between flexible load 1 and 2 which ensures that the second trapezoid directly follows the first trapezoid. The key figures *usage number* and *validity* indicate that flexible load 1 must run exactly once. Following the reference “start”, the start time of the process in Figure 5 must be within the corresponding *validity* (12:00 to 14:30). For the other key figures (*reaction duration*, *power states*, *holding durations*, *usage number*, *modulation number*, *activation gradient*, *modulation gradients*, *deactivation gradient*, *regeneration duration*, and *costs*), there are no degrees of freedom in this respect. Flexible load 2 differs in particular with regard to its *validity* and *usage number*. The second part of the process can theoretically be activated between 0 and 5 times throughout the day. However, the key figures of the dependency describe the correlation between the two flexible loads. Here, as soon as flexible load 1 is activated, flexible load 2 must also be activated. Since flexible load 1 is activated exactly once in the period under consideration, flexible load 2 is activated at least once.

1		dependency 1		2	
Flexible load id	"flexible load 1"	Trigger flexible load id	"flexible load 1"	Flexible load id	"flexible load 2"
Reaction duration	{0 s}	Target flexible load id	"flexible load 2"	Reaction duration	{0 s}
Validity	([12:00, 14:30], "start")	Logical type	"implies"	Validity	([00:00, 23:59], "start")
Power states	{1 000 kW}	Temporal type	("start", "start")	Power states	{500 kW}
Holding durations	{3 600 s}	Applicability duration	{3 900 s}	Holding durations	{2 700 s}
Usage number	{1}	Applicability conditions	-	Usage number	{1}
Modulation number	{0}			Modulation number	{0}
Activation gradient	$\left\{ \begin{matrix} 200 \text{ kW} \\ 60 \text{ s} \end{matrix} \right\}$			Activation gradient	$\left\{ \begin{matrix} 100 \text{ kW} \\ 60 \text{ s} \end{matrix} \right\}$
Modulation gradients	-			Modulation gradients	-
Deactivation gradient	$\left\{ \begin{matrix} 200 \text{ kW} \\ 60 \text{ s} \end{matrix} \right\}$			Deactivation gradient	$\left\{ \begin{matrix} -100 \text{ kW} \\ 60 \text{ s} \end{matrix} \right\}$
Regeneration duration	{0 s}			Regeneration duration	{0 s}
Costs	{10 €}			Costs	{3 €}

Figure 6. The data model for the exemplary scheduling process.

Apart from the degree of freedom coming from the timing of flexible loads 1 and 2, it is possible to deviate from the standard process (load profile in Figure 5). Here, we consider a reduction in electricity consumption during the first holding (heating) period (flexible load 3) and an increase in electricity consumption (flexible load 4) during the second phase. For the switch-off during the first phase and the catch-up after the second phase, there are some degrees of freedom, but also certain constraints. The characteristics are described in the following:

- The switch-off with a 500 kW load reduction can take place during the whole first heating phase (flexible load 1), but the *power state** of 1000 kW must be reached before the switch-off may happen.
- Flexible load 3 admits a *holding duration** of 10 to 60 min, but must be completed at the latest when the second heating phase (flexible load 2 in Figure 5) begins.
- The energy that is renounced by flexible load 3 must be made up by flexible load 4 with a factor of 1.5 after the second heating phase.
- Flexible load 4 has a fixed *holding duration** of 15 min, but a possible *power state* of up to 10,000 kW in order to be able to make up for the energy reduction during the first heating period.
- In addition, flexible load 4 always reaches the corresponding *power state* after five minutes. Thus, the *activation* and *deactivation gradient* depend on the *power state* (directly proportional).

Figure 7a illustrates the earliest possible use of the flexible load 3 (top), while the resulting load profile is displayed at the bottom. At the upper right, the flexible load 3 ends at the latest possible time. In addition, for flexible load 3, a larger *holding duration** is selected, which affects the *power state* of flexible load 4, as explained.




Figure 7. Two possible flexibility measures. (a) the flexibility measure for the earliest starting point is depicted on the left-hand side; (b) the profiles for the latest point in time are illustrated on the right-hand side.

Figure 8 represents the data model for flexible loads 3 and 4. Again, the dependencies ensure the temporal sequence. As described above, flexible load 3 has a fixed *power state*, but a variable *holding duration*. By contrast, flexible load 4 has a variable *power state* and a fixed *holding duration*. Thus, the *activation gradient* of flexible load 4 depends on the corresponding *power state*. Moreover, dependency 2 defines an additional restriction in key figure *applicability condition*: Flexible load 4 must make up 1.5 times the energy of the flexible load 3. Section 3.3.3 illustrates how *power state**₄ can be calculated depending on the key figures of flexible load 3 (cf. Equation (5)). Note that here

the gradients must also be taken into account when calculating electricity consumption. In the two examples in Figure 7, flexible load 3 has a *holding duration* of 20 min (Figure 7a) resp. 30 min (Figure 7b). This results in *power states* for flexible load 4 of 937.5 kW and 1312.5 kW.




Figure 8. The data model for flexible load 3 and flexible load 4.

In addition to the dependency between flexible loads 3 and 4, further dependencies are necessary in relation to the flexible loads 1 and 2. For example, the *validity* of flexible load 3 allows a start at any time. However, this flexible load requires the actual oven process. Figure 9 depicts the other necessary dependencies so that flexible loads 3 and 4 can be used correctly. Dependency 3 ensures that both flexibilities can only be activated in combination, which is equal to "if and only if". Dependency 4 and dependency 5 guarantee that the actual oven process must be active so that a switch-off and switch-on can take place at all. The *applicability duration* is also defined for these two dependencies, so that flexible loads 3 and 4 can only be activated in the permitted time periods.




Figure 9. Additional dependencies for flexible loads 1 to 4.

Exemplarily, we also want to illustrate here how to compute the total costs of a flexibility. Of course, since a flexibility exhibits several degrees of freedom, what this means is that we assign costs to every element in the flexibility, i.e., to every flexibility measure. For this, in turn, it suffices to compute the costs of every flexible load measure because the costs of the flexibility measure is just the sum over the costs of all corresponding flexible load measures. We only demonstrate how to compute the costs for flexible load measure 4, leaving the (even easier) remaining flexible load measures to the reader. Let $\pi : \mathcal{H} \rightarrow \mathbb{R}$ denote the electricity price function, i.e., $\pi(t)$ is the electricity price at time t for every

$t \in \mathcal{H}$ (if the prices are not yet known, one has to substitute the expected price or other quantities, of course). From Section 4, we can derive that the power consumption $p_4^*(t)$ of flexible load measure 4 can be expressed by the key figures as follows: The first entry of the vector $gradients^*$ refers to the activation until the first entry of the vector $power\ states^*$ is reached, which is held for a certain time (first entry of $holding\ duration^*$). Since the consumption returns to the reference value at the end, the vector $gradients^*$ has one entry more than the vectors $power\ states^*$ and $holding\ duration^*$. We define

$$\begin{aligned} \text{activation duration}_4^* &:= \frac{power\ state_4^*}{gradients_4^*(0)}, & \text{deactivation duration}_4^* &:= -\frac{power\ state_4^*}{gradients_4^*(1)}, \\ T_0 &:= \text{start time}_4^*, & T_1 &:= T_0 + \text{activation duration}_4^*, \\ T_2 &:= T_1 + \text{holding durations}_4^*, & T_3 &:= T_2 + \text{deactivation duration}_4^*. \end{aligned}$$

Note that activation duration $_4^*$ and deactivation duration $_4^*$ as well as T_i where $i \in \{0, 1, 2, 3\}$ can be computed only from key figures of flexible load measure 4. Moreover, T_1 resp. T_2 denote the start resp. end time of the holding period of flexible load measure, and T_3 is the end of the deactivation period. Then, the load curve for flexible load measure 4 is given by the function $p_4^* : \mathcal{H} \rightarrow \mathbb{R}$ where

$$p_4^*(t) = power\ states_4^* \cdot \begin{cases} \frac{t-T_0}{T_1-T_0}, & T_0 \leq t \leq T_1, \\ 1, & T_1 \leq t \leq T_2, \\ 1 - \frac{t-T_2}{T_3-T_2}, & T_2 \leq t \leq T_3, \\ 0, & \text{else.} \end{cases} \quad (7)$$

The total costs of flexibility measure 4 are the sum of the intrinsic fixed costs, i.e., $costs_4^* = 3 \text{€}$ (see Figure 8) and the electricity costs and therefore given by

$$c_4^* = 3 \text{€} + \int_{\mathcal{H}} p_4^*(t) \cdot \pi(t) dt. \quad (8)$$

5.2. Storage-Like Process with Dependencies

Cooling systems are used in many branches of industry. Figure 10 depicts the modelling of the flexibility of a cooling system as an example for a storage-like flexibility. Two compressors feed a cooling circuit, whereby one of the two compressors has a speed-controlled drive. The cooling circuit is connected to a secondary circuit via a heat exchanger. In this example, the separator in the primary circuit and an ice reservoir in the secondary circuit act as energy storages. As soon as the cooling load is lower than the cooling capacity of the compressors, the storages can be charged. Correspondingly, the compressors can be switched off at a later point in time and the storages will be discharged.




Figure 10. Setup of the energy flexible cooling system.

There is a flexible load associated with each of the two compressors. Moreover, the overall system features two energy storages. In addition, a cooling load has to be covered. The description of this flexibility using the data model presented is depicted in Figure 11.

Instead of a relative deviation, the absolute power consumption of the system is considered here. Both compressors have a *reaction duration* of five seconds. The flexibility of the process can be used in the time period from 10:00 a.m. to 2:30 p.m. This period may result from the forecast quality of the cooling demand or other uncertainties regarding the flexibility of the system. In order not to cycle the compressors too often, the maximum *usage number* is limited to 5 within the *validity interval*. The *usage number* corresponds to the ON and OFF switching processes for the compressor example. However, while compressor 2 can only be switched to operating mode and off, compressor 1 can also achieve any *power state* between 20 and 100 kW due to the built-in frequency inverter. Correspondingly, for both compressors, there are power intervals for the status operating mode and the status off. Due to the frequency inverter, the *power states* of compressor 1 are modelled for the status operating mode from 20 to 100 kW instead of 100 kW as for compressor 2. While for compressor 2 the *modulation number* is obviously zero, for compressor 1, the modulations are not limited. Both compressors must maintain a *power state* for at least 10 min to avoid overstraining the electric motor. This limitation is modelled by the *holding duration*. The inertia of the compressors with $100 \frac{\text{kW}}{\text{min}}$ is represented by the *activation* and *deactivation gradients* for the start up respectively shut down and the *modulation gradient* for the modulation of the compressors in operating mode. Since the *holding duration* of a power change has already been limited, an additional limitation via the *regeneration duration* is not required. For this reason it can be set to 0, so the key figure does not have a restrictive effect. The *costs* of the two flexible loads $i \in \{1, 2\}$ relate to the change in power within the period under consideration:

$$\text{costs}_i^* = c \frac{\text{€}}{\text{kW}} \times \left(\sum_{j=1}^{\text{modulation number}_i^* + 1} |\text{power states}_i^*(j) - \text{power states}_i^*(j-1)| \right). \quad (9)$$

The more power changes are made by the compressors, the higher the associated system wear. This is represented by the absolute change in power multiplied by a cost term c . Remember that energy-related costs are not taken into account here as stated in Section 3.

The storage systems have a *usable capacity* of 30 kWh and 2000 kWh, respectively. Since the energy content is not relevant for the subsequent process, no *target energy content* is required for this example. In order to ensure that this key figure does not have a restrictive effect, the interval limits are selected

exactly like the *usable capacity*. This *target energy content*, which is not a limitation in this case, must be reached by 3:00 p.m.




Figure 11. The data model for the two flexible loads and the two storages.

Accordingly, the energy content at the end of the observation horizon can be selected freely for both storage units. When thermal storage systems are used, the part of the stored useful energy is always lost. This is modelled by the key figure *energy loss*. In order to establish the energy balance of the storage systems, the two flexible loads and the *drain* are additionally required. The *drain* is given by a function:

$$\text{drain} : \mathcal{H} \rightarrow \mathbb{R}, \quad t \mapsto \begin{cases} 0.1 \text{ kW}, & t \in [12:00, 15:00], \\ 0.0 \text{ kW}, & \text{else.} \end{cases} \quad (10)$$

Since the flexible loads are specified in electric energy and the storages in cooling energy, the conversion efficiency of 1.9 of the flexible loads must also be specified.

6. Discussion

As described in Sections 3 and 5, the presented data model can be used for describing a wide variety of flexibilities.

Finally, we want to challenge our data model with the checklist developed by Barth et al. [24]. As already described in Section 1, in their paper, the authors define flexibility features which represent

different attributes of flexibility. Table 5 lists the flexibility properties of Barth et al. [24] and their corresponding descriptions as well as the way these features are covered by our data model.

Table 5. Description of the features of Barth et al. [24] and their representation in our data model.

Flexibility Features	Explanation of the Features in Line with [24]	Representation in Our Data Model
Time frame	Defines whether discrete or continuous time steps are possible with the model.	This is rather a feature of an optimization and not of a data model.
Interruptible jobs	States whether the model allows interruptible loads or production jobs.	The interruption of jobs and the associated variation of power can be modeled by <i>power states</i> . If the load interruption is limited in its duration or its frequency of use the resulting flexible load can be limited by the <i>holding duration</i> or the <i>usage number</i> as well. Moreover, the <i>regeneration duration</i> ensures a resting time between two usages.
Storage	The model enables the use of storage systems.	Besides flexible loads and dependencies, storages are a class of the data model. The key figures for storages allow all relevant characteristics of storage to be modeled.
Interdependent jobs	Dependencies between different flexibilities are considered.	The key figures of the dependency class enable the logical linking of any pair of flexible loads. In this way, dependencies within processes can be modelled in our data model.
Earliest starting time	Jobs can be associated with an earliest start time.	The earliest starting time can be represented by the infimum of the key figure <i>validity</i> when the reference is specified by “start”.
Deadline	Jobs can be associated with a latest ending time.	The deadline in our model is represented by the supremum of the <i>validity</i> with the reference “end”.
Production	The model considers a target production output.	The production output can be modelled by storage and the production target by the key figure <i>target energy content</i> .
Multiple resources	Not only electric energy is considered as a resource.	In our data model, all kinds of production quantities where the production can be expressed in terms of the consumed electric energy can be modelled by storages. The remaining cases are not power-related flexibilities and therefore not the target of our data model.
Base loads	Uncontrollable loads can be modelled.	Although in fact irrelevant for the description of flexibility, uncontrollable loads can be approximated by using multiple flexible loads without any degree of freedom.
Modes	Different <i>power states</i> of the flexibility can be set.	Different power states can be modelled via the key figure <i>power states</i> . In addition, changes in the <i>power states</i> within a usage can be modelled via the key figure <i>modulation number</i> .
Drain, losses	Drains and losses can be considered.	Drains resp. losses can be modelled via the key figures <i>suppliers</i> (flexible) and <i>drain</i> (deterministic) resp. <i>energy loss</i> .
Down-/uptime	Maximum downtime and minimum uptime of a job can be taken into account.	The downtime is captured by the <i>regeneration duration</i> . With the infimum and supremum of <i>holding durations</i> , minimum respective maximum uptime can be modelled.
Multiple runs	Every job can either be scheduled once or multiple times.	This is precisely captured by the <i>usage number</i> .
Ramping	A ramping functions models how resource usage increases resp. decreases when a job starts resp. finishes.	Ramping is modelled with the <i>activation gradient</i> , <i>modulation gradient</i> , and <i>deactivation gradient</i> .

Our detailed analysis demonstrates that all features defined by Barth et al. [24] can be covered with the presented data model. In addition, certain types of flexibility, such as storages, can be modelled more easily and precisely, since they do not have to be mapped via discrete jobs. The reason

for this is the modular structure of our data model. Furthermore, it is possible to describe instances of the so-called job shop scheduling problem (example 1 in Section 5) as well as the conventional unit commitment problem like example 2. This allows a large part of the industrial flexibility to be mapped sufficiently. The industry partners in SynErgie all consider our modeling approach suitable. Therefore, we are convinced that our results are of substantial relevance. It thus fulfills its purpose of the standardized description of flexibility potentials for further use in various applications. Moreover, additional characteristics like the reaction duration or more complex behavior like warm start or cold start of machines can be described via the dependency of different flexible loads. In order to verify the applicability of the data model in industry, numerous rounds of discussions were held with industry representatives and scientists. A wide variety of applications were considered—for example, graphitization, heat pumps, refrigerated warehouses, or paper production.

In the course of the project, we also described flexibilities in close collaboration with companies from the mentioned industries in our generic data model. For this purpose, we used Java to implement the data model and used JSON-files to represent the corresponding flexibilities. With regard to the applicability of our data model, one must distinguish two perspectives: The first question which arises is whether the data model can represent the flexibilities of a company. Secondly, it is also vital that the corresponding users are able to fill the data model. Our discussion suggests that it is indeed possible to represent the relevant flexibilities in our data model. On the other hand, we have observed that, for companies, filling out the data model for the first time is not always intuitive. However, the modularity of the data model also allowed to describe complex processes and provided a guideline to capture an understanding of the flexibility. Since the key figures stay the same for every flexibility, with repeated usage of the data model, it becomes increasingly familiar and comfortable to use.

In our validation, we have focused on the industrial sector. As already mentioned, the characteristics of our data model and our generic approach allow for transferring the model also to other types of power-related flexibility such as plug-in electric vehicles. Note that, in our presented data model, we can represent a plug-in electric vehicles by a flexible load (the plug) and storage (the battery). Costs incurred by charging and discharging (cycling degradation) the electric car can be captured in the key figure *costs* of the subcategory flexible loads [29]. Moreover, costs arising from the use of the battery (depth of discharge) can be modelled in the key figure *costs* of the subcategory storages [29]. By specifying suitable dependencies in our data model, one can even include additional characteristics related to charging infrastructure such as limited numbers of charging stations or grid constraints in certain areas. A detailed analysis of the applicability for all the above-mentioned sectors, however, must still be conducted in future research. It is important to keep in mind that the flexibility provided by electric vehicles also exhibits a stochastic component, namely whether it is in use or connected to the power system? However, the stochastic aspect needs to be part of the load planning and systemic considerations. The data model is meant to describe the actual flexibility, i.e., once it is known that the electric vehicle is plugged in and the earliest departure time (which then defines the *validity*) and the *initial energy content* are known, the corresponding flexibility can be offered in our data model.

7. Conclusions

The focus of this article was the description of generic, power-related flexibilities. The modular structure of our data model allows us to model various flexibilities. We modeled flexibilities as subsets of at least one flexible load. The corresponding constraints were described by the subcategories dependencies and storages. The modular structure enables an efficient description of both simple and complex processes. The data model thus forms the basis for describing flexibility. The two examples which we analyzed in Section 5 illustrate our data model and stand for a multitude of real-world industrial applications which we investigated in the Kopernikus-project SynErgie (see Section 2). As mentioned in the introduction, the information layer of the Smart Grid Architecture Model is intended to ensure standardized communication. The data model presented in this article enables a

standardized description of flexibility in the Smart Grid Architecture Model [17]. Thus, the data model is also relevant for the business layer in order to market the flexibility.

Based on the description of flexibility in the form of the data model, the use of flexibility for different objectives can be investigated. For example, the uncertainties in the feed-in of renewable energy sources can be addressed. This can increase the share of renewable electricity. In the same way, knowledge about flexibility can be used for efficient network operation and can help to minimize network expansion [7,30]. Furthermore, the data model enables flexibility providers to optimize the use of flexibility with regard to financial aspects [6]. Therefore, we are convinced that the presented data model provides an essential basis for the automated use of flexibility. In this way, more flexibility can be exploited in the future to close the emerging flexibility gap [5].

It is relevant for future research to develop a suitable optimization model based on the presented data model. On this basis, the use of flexibility, here we focused on the demand side, can then be optimized. In order to take an integrated view of the electricity system, the feed-in characteristics from renewable energies must be examined in more detail in future research. Accordingly, future research must also deal with a generation model for fluctuating renewable energies.

Author Contributions: P.S. and T.W. significantly conceptualized the data model. J.S. extended the data model and mainly developed the mathematical formulations. P.S. was largely responsible for creating the figures. P.S. and J.S. directed the preparation of the paper, designed the general structure, and wrote large parts of the manuscript. P.S., J.S., and N.S. validated the data model by the application on practical examples. N.S. and T.W. contributed to the passages on the storage model as well as the example of the cold storage and comparison with the criteria of Barth et al. [24] in the discussion. G.F. provided the idea, supervised the work of P.S. and J.S., and helped to conceptualize and review the article. E.A. supervised the work of N.S. and T.W. All authors and supervisors provided critical feedback and helped shape the research, analysis, and manuscript.

Funding: This research was funded by the German Federal Ministry of Education and Research (BMBF) Grant No. 03SFK3G1.

Acknowledgments: The authors gratefully acknowledge the financial support of the Kopernikus-project “SynErgie” by the Federal Ministry of Education and Research (BMBF) and the project supervision of the project management organization Projektträger Jülich (Ptj).

Conflicts of Interest: The funders had no role in the design of the study; in the collection, analyses, or interpretation of data; in the writing of the manuscript, or in the decision to publish the results.

References

1. Moura, P.S.; de Almeida, A.T. Multi-objective optimization of a mixed renewable system with demand-side management. *Renew. Sustain. Energy Rev.* **2010**, *14*, 1461–1468. [\[CrossRef\]](#)
2. Rogelj, J.; Den Elzen, M.; Höhne, N.; Fransen, T.; Fekete, H.; Winkler, H.; Schaeffer, R.; Sha, F.; Riahi, K.; Meinshausen, M. Paris Agreement climate proposals need a boost to keep warming well below 2 C. *Nature* **2016**, *534*, 631. [\[CrossRef\]](#)
3. Lund, P.D.; Lindgren, J.; Mikkola, J.; Salpakari, J. Review of energy system flexibility measures to enable high levels of variable renewable electricity. *Renew. Sustain. Energy Rev.* **2015**, *45*, 785–807. [\[CrossRef\]](#)
4. Sensfuß, F.; Ragwitz, M.; Genoese, M. The merit-order effect: A detailed analysis of the price effect of renewable electricity generation on spot market prices in Germany. *Energy Policy* **2008**, *36*, 3086–3094. [\[CrossRef\]](#)
5. Papaefthymiou, G.; Haesen, E.; Sach, T. Power System Flexibility Tracker: Indicators to track flexibility progress towards high-RES systems. *Renew. Energy* **2018**, *127*, 1026–1035. [\[CrossRef\]](#)
6. Goutte, S.; Vassilopoulos, P. The value of flexibility in power markets. *Energy Policy* **2019**, *125*, 347–357. [\[CrossRef\]](#)
7. Pourakbari-Kasmaei, M.; Mantovani, J.; Rashidinejad, M.; Habibi, M.; Contreras, J. Carbon footprint allocation among consumers and transmission losses. In Proceedings of the 2017 IEEE International Conference on Environment and Electrical Engineering and 2017 IEEE Industrial and Commercial Power Systems Europe (EEEIC/I&CPS Europe), Milan, Italy, 6–9 June 2017; pp. 1–6.
8. Müller, T.; Möst, D. Demand response potential: Available when needed? *Energy Policy* **2018**, *115*, 181–198. [\[CrossRef\]](#)
9. Palensky, P.; Dietrich, D. Demand side management: Demand response, intelligent energy systems, and smart loads. *IEEE Trans. Ind. Inform.* **2011**, *7*, 381–388.

10. Steurer, M. *Analyse von Demand Side Integration im Hinblick auf eine Effiziente und Umweltfreundliche Energieversorgung*; Institut für Energiewirtschaft, Universität Stuttgart: Stuttgart, Germany, 2017.
11. Albadi, M.H.; El-Saadany, E.F. A summary of demand response in electricity markets. *Electr. Power Syst. Res.* **2008**, *78*, 1989–1996. [[CrossRef](#)]
12. Strbac, G. Demand sidemanagement: Benefits and challenges. *Energy Policy* **2008**, *36*, 4419–4426. [[CrossRef](#)]
13. Bauer, D.; Abele, E.; Ahrens, R.; Bauernhansl, T.; Fridgen, G.; Jarke, M.; Keller, F.; Keller, R.; Pullmann, J.; Reiners, R.; et al. Flexible IT-platform to synchronize energy demands with volatile markets. *Procedia CIRP* **2017**, *63*, 318–323. [[CrossRef](#)]
14. Schott, P.; Ahrens, R.; Bauer, D.; Hering, F.; Keller, R.; Pullmann, J.; Schel, D.; Schimmelpfennig, J.; Simon, P.; Weber, T.; et al. Flexible IT platform for synchronizing energy demands with volatile markets. *IT-Inf. Technol.* **2018**, *60*, 155–164. [[CrossRef](#)]
15. Logenthiran, T.; Srinivasan D.; Shun, T.Z. Demand side management in smart grid using heuristic optimization. *IEEE Trans. Smart Grid* **2012**, *3*, 1244–1252. [[CrossRef](#)]
16. Andreadou, N.; Papaioannou, I.; Masera, M. Interoperability Testing Methodology for Smart Grids and Its Application on a DSM Use Case—A Tutorial. *Energies* **2019**, *12*, 8. [[CrossRef](#)]
17. Gottschalk, M.; Franzl, G.; Frohner, M.; Pasteka, R.; Uslar, M. From Integration Profiles to Interoperability Testing for Smart Energy Systems at Connectathon Energy. *Energies* **2018**, *11*, 3375. [[CrossRef](#)]
18. Mandate, S.G. *Standardization Mandate to European Standardisation Organisations (ESOs) to Support European Smart Grid Deployment*; European Commission: Brussels, Belgium, 2011.
19. Petersen, M.; Hansen, L.H.; Mølbak, T. Exploring the value of flexibility: A smart grid discussion. *IFAC Proc. Vol.* **2012**, *45*, 43–48. [[CrossRef](#)]
20. Shoreh, M.H.; Siano, P.; Shafie-khah, M.; Loia, V.; Catalão, J. A survey of industrial applications of Demand Response. *Electr. Power Syst. Res.* **2016**, *141*, 31–49. [[CrossRef](#)]
21. Alcázar-Ortega, M.; Calpe, C.; Theisen, T.; Carbonell-Carretero, J.F. Methodology for the identification, evaluation and prioritization of market handicaps which prevent the implementation of Demand Response: Application to European electricity markets. *Energy Policy* **2015**, *86*, 529–543. [[CrossRef](#)]
22. Petersen, M.K.; Edlund, K.; Hansen, L.H.; Bendtsen, J.; Stoustrup, J. (Eds.) A taxonomy for modeling flexibility and a computationally efficient algorithm for dispatch in smart grids. In Proceedings of the American Control Conference, Washington, DC, USA, 17–19 June 2013; pp. 1150–1156.
23. Parvania, M.; Fotuhi-Firuzabad, M.; Shahidehpour, M. Optimal demand response aggregation in wholesale electricity markets. *IEEE Trans. Smart Grid* **2013**, *4*, 1957–1965. [[CrossRef](#)]
24. Barth, L.; Ludwig, N.; Mengelkamp, E.; Staudt, P. A comprehensive modelling framework for demand side flexibility in smart grids. *Comput.-Sci. Res. Dev.* **2018**, *33*, 13–23. [[CrossRef](#)]
25. Hussain, H.; Javaid, N.; Iqbal, S.; Hasan, Q.; Aurangzeb, K.; Alhusein, M. An efficient demand side management system with a new optimized home energy management controller in smart grid. *Energies* **2018**, *11*, 190. [[CrossRef](#)]
26. Fridgen, G.; Keller, R.; Thimmel, M.; Wederhake, L. Shifting load through space—The economics of spatial demand side management using distributed data centers. *Energy Policy* **2017**, *109*, 400–413. [[CrossRef](#)]
27. Fridgen, G.; Mette, P.; Thimmel, M. The value of information exchange in electric vehicle charging. In Proceedings of the 35th International Conference on Information System (ICIS), Auckland, New Zealand, 14–17 December 2014.
28. Neves, S.; Marques, A.; Fuinhas, J. On the drivers of peak electricity demand: What is the role played by battery electric cars? *Energy* **2018**, *159*, 905–915. [[CrossRef](#)]
29. Ahmadian, A.; Sedghi, M.; Mohammadi-ivatloo, B.; Elkamel, A.; Golkar, M.; Fowler, M. Cost-benefit analysis of V2G implementation in distribution networks considering PEVs battery degradation. *IEEE Trans. Sustain. Energy* **2018**, *9*, 961–970. [[CrossRef](#)]
30. Home-Ortiz, J.M.; Melgar-Dominguez, O.D.; Pourakbari-Kasmaei, M.; Mantovani, J.R.S. A stochastic mixed-integer convex programming model for long-term distribution system expansion planning considering greenhouse gas emission mitigation. *Int. J. Electr. Power Energy Syst.* **2019**, *108*, 86–95. [[CrossRef](#)]

