



Aalborg Universitet

AALBORG UNIVERSITY
DENMARK

Optimal SSSC-based power damping inter-area oscillations using firefly and harmony search algorithms

Naderipour, Amirreza; Abdul-Malek, Zulkurnain; Ramachandaramurthy, Vigna K; Miveh, Mohammad Reza; Moghaddam, Mohammad Jafar Hadidian; Guerrero, Josep M

Published in:
Scientific Reports

DOI (link to publication from Publisher):
[10.1038/s41598-020-69123-7](https://doi.org/10.1038/s41598-020-69123-7)

Creative Commons License
CC BY 4.0

Publication date:
2020

Document Version
Publisher's PDF, also known as Version of record

[Link to publication from Aalborg University](#)

Citation for published version (APA):

Naderipour, A., Abdul-Malek, Z., Ramachandaramurthy, V. K., Miveh, M. R., Moghaddam, M. J. H., & Guerrero, J. M. (2020). Optimal SSSC-based power damping inter-area oscillations using firefly and harmony search algorithms. *Scientific Reports*, 10(1), [12176]. <https://doi.org/10.1038/s41598-020-69123-7>

General rights

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- ? Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- ? You may not further distribute the material or use it for any profit-making activity or commercial gain
- ? You may freely distribute the URL identifying the publication in the public portal ?

Take down policy

If you believe that this document breaches copyright please contact us at vbn@aub.aau.dk providing details, and we will remove access to the work immediately and investigate your claim.



OPEN

Optimal SSSC-based power damping inter-area oscillations using firefly and harmony search algorithms

Amirreza Naderipour^{1,2,3}, Zulkurnain Abdul-Malek³✉, Vigna K. Ramachandramurthy⁴✉, Mohammad Reza Miveh⁵, Mohammad Jafar Hadidian Moghaddam⁶ & Josep. M. Guerrero⁷

The static synchronous series compensator (SSSC) can add a series reactance to the transmission line, and when it is fed using auxiliary signals, it can participate in damping inter-area oscillations by changing the series reactance. In this paper, the effect of the SSSC on small-signal stability is investigated. The design of a controller for damping oscillations is designed and discussed. Moreover, using the firefly and the harmony search algorithms, the optimal parameters controlling SSSC are addressed. The effectiveness of these two algorithms and the rate of SSSC participation in damping inter-area oscillation are also discussed. MATLAB software was used to analyse the models and to perform simulations in the time domain. The simulation results on the sample system, in two areas, indicated the optimal accuracy and precision of the proposed controller.

Inter-area oscillations are common phenomena in the interconnected power systems; therefore, damping of these oscillations have become one of the main difficulties in the power system. To date, this issue has been addressed by the power system stabiliser (PSS). However, the conventional PSS is based on local signals and cannot effectively dampen inter-area oscillations that occur within the power system; therefore, adaptive and robust methods for designing PSS are needed¹. On the other hand, the use of flexible alternating current transmission systems (FACTS), which can control the impedance of the power flow on transmission lines and the bus voltage, is a novel solution². Among different series power electronics-based FACTS controllers, the static synchronous series compensator (SSSC) is one of the best alternative means to improve power oscillation damping. It is based on a voltage source converter connected to a transmission line in series, and it adds the sinusoidal voltage along the q axis into the line current. Thus, the SSSC can use a series reactance with a transmission line, and this reactance can be inductive or capacitive. Using auxiliary signals in the SSSC controller can improve the damping of inter-area oscillations by altering the impedance of the transmission line. In Wang and Du³, an ideal controller is assumed, and the SSSC is used to damp small-signal oscillations based on the Phillips–Heffron model. In Darabian and Jalilvan⁴, the SSSC risk model was applied to use a conventional PSS power stabiliser to eliminate oscillations. In Norouzi and Sharaf⁵, two voltage regulation strategies were compared with the SSSC, and Kumar and Ghosh⁶ proposed a controlling structure for SSSCs. In Bongiorno et al. (2008)⁷, the structure proposed in Kumar and Ghosh⁶ was used, and instead of changing the rotor speed as a control signal, transmission line power variations were used to detect the presence of high influences in wind farms. In Shen et al.⁸, an adaptive neural controller was used to improve the control of damping small-signal oscillations with SSSC.

In Xia et al.⁹, suggested a damping control design for an interline power flow controller (IPFC) comprise two voltage sourced converters (VSCs) to maximize voltage-stability limited power transfer and damp power swings.

¹Institute of Research and Development, Duy Tan University, Da Nang 550000, Vietnam. ²Faculty of Electrical – Electronic Engineering, Duy Tan University, Da Nang 550000, Vietnam. ³Institute of High Voltage & High Current, School of Electrical Engineering, Faculty of Engineering, Universiti Teknologi Malaysia, 81310 Johor Bahru, Malaysia. ⁴Institute of Power Engineering, Department of Electrical Power Engineering, College of Engineering, Universiti Tenaga Nasional, Jalan Ikram-Uniten, 43000 Kajang, Malaysia. ⁵Department of Electrical Engineering, Tafresh University, 39518-79611 Tafresh, Iran. ⁶College of Engineering and Science, Victoria University, Melbourne 3047, Australia. ⁷Institute of Energy Technology, Aalborg University, Aalborg East, Alboorg, Denmark. ✉email: zulkurnain@utm.my; vigna@uniten.edu.my




Figure 1. Single-machine infinite-bus system with SSSC¹⁷.




Figure 2. SSSC voltage regulation diagram¹⁷.

In another major study, Xia et al.¹⁰, offered a new computation method to regulate the dispatchable control modes of the convertible static compensator (CSC) in a power system. Xia et al.¹¹, proposed a stability improvement using VSCs based FACTS device. The paper shows that the FACTS devices have the ability to increase the transient power transfer capability of a transmission system under abnormal conditions.

Xinghao et al.¹², proposed two sensitivity approaches including an injected voltage source formulation and the equivalent impedance formulation in the dispatch and placement of FACTS devices. In Aranya¹³, to mitigate interarea oscillation in large power systems, wide-area damping control using dynamic clustering and TCSC-based redesigns is presented. The method involved coherent clustering using Synchrophasors and designing controllers to attain preferred damping between the clusters. The suggested controller contains three steps. Model reduction, aggregate control and control inversion are these three steps.

In this paper, the effect of SSSC on small-signal stability of a multi-machine power system is investigated, and a control structure is proposed for the SSSC compensator. Modal analysis and time-domain simulation are done on a two-area sample system. Finally, the system, which is located in two areas, is simulated with optimised stabilisers by harmony search and firefly algorithms, and the ability of these two optimisation methods to improve small-signal stability is evaluated.

The remainder of this article is arranged as follows: Part II is dedicated to the SSSC voltage regulator. The effects of the SSSC on the small-signal stability of the power system and the proposed controller are presented in “[SSSC effect on small-signal stability](#)” and “[SSSC damping controller](#)”, respectively. In “[Intelligent random optimisation algorithms](#)”, i.e., the firefly and harmony search algorithms¹⁴, are introduced. In “[two-area system](#)”, optimisation of the proposed controller parameters is performed, and the simulation results on sample systems are shown in “[Optimising SSSC parameters](#)”. The final section presents our conclusions.

Methods

SSSC modeling. In Fig. 1, a single-machine infinite bus system with SSSC is presented. The voltage generated by the SSSC is controlled by the pulse-width modulation (PWM) method to ensure that the voltage is always in line with the q axis relative to the line current¹⁵. Therefore, the SSSC can act as a capacitor or inductor in the system. The magnitude of the PWM controls the degree of compensation, and the phase angle determines the type of compensation: capacitive or inductive¹⁶.

The PWM voltage-generation diagram is shown in Fig. 2. The magnitude of the PWM signal is obtained from multiplying the SSSC-measured AC by the AC generated in the reference reactance. The X_{delta} is calculated using the proposed controller in the fifth section. The phase angle of the PWM is obtained by the synchronous phase angle, and a proportional-integral (PI) controller keeps the DC voltage constant so that the active power exchange between the power system and the SSSC is zero. As a result, the phase angle generated by the diagram

in Fig. 2 ensures that the voltage phasor and flow phasor of the transmission line are perpendicular to each other and that the SSSC behaves like a reactance.

SSSC effect on small-signal stability. The ability of the power system to maintain the synchronism of synchronous generators during small disturbances is called small-signal stability¹⁸. The single-machine infinite-bus system in Fig. 1 is considered for the analysis of small-signal stability in which the dynamics of the synchronous generator stator are ignored⁸. Moreover, to maintain the simplicity, the dampers and resistances of all synchronous generator rotors are ignored. As a result, only a differential equation for the excitation circuit voltage plus two differential equations for the rotational motion of the synchronous generator remain, as expressed in (1).

$$\begin{aligned}
 p\omega_r &= \frac{1}{2H} (T_m - T_e - K_D\omega_r) \\
 p\delta &= \omega_0\omega_r \\
 p\Psi_{fd} &= \frac{\omega_0 R_{fd}}{L_{adu}} E_{fd} - \omega_0 R_{fd} i_{fd}
 \end{aligned} \tag{1}$$

where p is the first-order derivation, $\Delta\omega_r$ is rotor speed variations, H is inertial constant, T_m is mechanical torque, T_e is electromagnetic torque, K_D is mechanical damping coefficient, δ is rotor angle, ω_0 is rated turbine speed, Ψ_{fd} is excitation circuit's flux linkage, R_{fd} is excitation circuit's resistance, E_{fd} is the excitation output voltage, L_{adu} is non-saturation mutual inductance between the rotor and axis d of the stator and i_{fd} is Excitation current.

For a full presentation of the state model, T_e and i_{fd} must be expressed in terms of the state variables. For electromagnetic torque:

$$i_{fd} = \frac{\Psi_{aq} - \Psi_{ad}}{L_{fd}} \tag{2}$$

where Ψ_{ad} and Ψ_{aq} are the flux linkage components between the stator and the rotor on the d and q axes, respectively and i_d and i_q are stator currents. The equation for the flux linkage of the excitation circuit is:

$$\begin{aligned}
 \Psi_{ad} &= -L_{ads}i_d + L_{ads}i_{fd} \\
 \Psi_{aq} &= -L_{aqs}i_q
 \end{aligned} \tag{3}$$

where L_{fd} is the self-inductance of the excitation circuit. Mutual flux linkage relations are also expressed in Eq. (4) such that L_{ads} is the interactive saturation inductance between the rotor and stator.

$$\begin{aligned}
 \Psi_{ad} &= -L_{ads}i_d + L_{ads}i_{fd} \\
 \Psi_{aq} &= -L_{aqs}i_q
 \end{aligned} \tag{4}$$

Stator voltage equations are also described in (5), where e_d and e_q are the voltage components of generator's terminal on the d and q axes, respectively. For the terminal voltage in the rotor synchronous reference frame:

$$\left. \begin{aligned}
 e_d &= L_l i_q - \Psi_{aq} \\
 e_q &= -L_l i_d + \Psi_{ad}
 \end{aligned} \right\} \Rightarrow E_t = e_q + j e_d \tag{5}$$

where L is the stator leakage inductance. Because of how the turbine is connected to the infinite bus, the following relations govern:

$$\begin{aligned}
 e_d &= -X_E i_q + e_{bd} \\
 e_q &= X_E i_d + e_{bq}
 \end{aligned} \tag{6}$$

The variable X_E is the equivalent reactance of the transmission line, and e_{bd} and e_{bq} are infinite bus voltage components. To analyse the small signal, the state equations of the system must be linearised. According to the method presented in¹⁶ and considering the effect of the SSSC on the small-signal stability, the variable ΔX_E , which represents the change in the transmission line reactance, is defined in the linearization of the system. After the linearization of relations (5) and (6); rewriting the relations (2), (3) and (4); and inserting the block of the small-signal stability into (6); the single-machine infinite-bus (SMIB) system is obtained as presented in Fig. 3.

In Fig. 3, the conversion function excitation system between $G_{ex}(s)$ and $G(s)$ is the conversion function of the SSSC damper controller. The K constants are defined as k_1 to k_6 as in 8. If SSSC is responsive to rapid changes in X_{delta} , then the red lines in the block diagram of the system indicate the impact of the SSSC. Coefficients K_{X1} , K_{X2} , and K_{X3} include:

$$\begin{aligned}
 K_{X1} &= (n_3 + n_4)(\psi_{ado} + L_{aqs}i_{do}) - (m_3 + m_4)(L_{ads}i_{qo} + \psi_{aqo}) \\
 K_{X2} &= \frac{L_{adu} L_{ads}}{L_{fd}} (m_3 + m_4) \\
 K_{X3} &= \frac{e_{do}}{E_{to}} (L_l + L_{aqs})(n_3 + n_4) - \frac{e_{qo}}{E_{to}} (L_l + L_{ads})(m_3 + m_4)
 \end{aligned} \tag{7}$$

and the coefficients n_3 , n_4 , m_3 , and m_4 include:

problems such as optimisation, multi-criteria decision making, and robotics. In this section, an algorithm based on the firefly social behaviour has been investigated.

Initialising the fireflies. The FA is initiated by randomly placing an n-member population of fireflies at different points in the search space. Initially, all fireflies have the same amount of luciferin as member 1. Random values must first be selected for the independent variables of the problem. Each replication of the algorithm includes an update phase for luciferin and another for fireflies.

Updating luciferin. The amount of luciferin in each firefly is determined during each iteration, depending on the fitting of its location. Thus, during each iteration, a value is added to the current luciferin of each firefly according to the amount of fitness determined for that firefly. In addition, to model the gradual decrease of the residual value, the amount of current luciferin is reduced by a factor of less than 1. In this way, the relationship between luciferin updates is as follows:

$$\ell_i(t) = (1 - \rho)\ell_i(t - 1) + \gamma J(x_i(t)) \quad (9)$$

where $\ell_i(t)$, $\ell_i(t - 1)$, and $J(x_i(t))$ are the new luciferin value, the previous luciferin value, and location fitness of firefly i in repetition t of the algorithm, and ρ and γ are fixed numbers for modeling the gradual decline and the effect of fitness on luciferin, respectively. At this stage, the fitness of each member of the population must be calculated. Accordingly, the fitness of each member of the algorithm population is the value of the objective function defined for the problem with the values of the independent variables attributed to the fitted firefly.

Firefly motion. During the motion phase, each firefly moves toward one of its neighbours with higher luciferin probabilistically. For each firefly, i probabilities of moving to a brighter neighbour j are defined as follows:

$$p_{ij}(t) = \frac{\ell_j(t) - \ell_i(t)}{\sum_{k \in N_i(t)} \ell_k(t) - \ell_i(t)} \quad (10)$$

where $N_i(t)$ is the set of fireflies neighbouring firefly i at time t , $d_{ij}(t)$ is the Euclidean distance between the firefly i and j at time t , and $r_{di}(t)$ indicates the neighbouring range of the variable related to firefly i at time t . Assuming that firefly j is selected by firefly i (with probability p), the discrete-time equation of the firefly can be written as follows:

$$x_i(t + 1) = x_i(t) + s \left(\frac{x_j(t) - x_i(t)}{\|x_j(t) - x_i(t)\|} \right) \quad (11)$$

where $x_i(t)$ is the m dimension vector of firefly i location at time t , the $\|x_j(t) - x_i(t)\|$ operator shows the Euclidean norm, and s is the hop size.

Updating the neighbourhood range. By assuming R_0 is the initial neighbourhood range for each firefly, the neighbourhood range of each firefly is updated during each iteration of the algorithm as follows:

$$r_i^d(t + 1) = \min \left\{ r_s, \max \left\{ 0, r_i^d(t) + \beta(n_t - |N_i(t)|) \right\} \right\} \quad (12)$$

where β is a constant parameter and n_t is a parameter for controlling the number of neighbours.

Stop criterion. If the stop criterion for the algorithm is not met, then the algorithm will perform another iteration. Of course, the stop criterion can be defined as a fixed number of iterations to reduce the speed and precision of the estimation of K variables. Each firefly with the highest fitness value is considered as the output of the algorithm.

It should be noted here that global optimization approaches have regularly shown improper slow convergence rates because of their random search, particularly near the area of the global optimum. The firefly algorithm may not find the actual optimal if it started from a different initial condition. Consequently, it is needed to investigate the effect of this uncertainty in the damping performance. In this regard, the hybrid algorithms can benefit from the advantages of both methodologies and alleviate their inherent disadvantages are of interest. Future studies on the current topic are therefore recommended. Using this approach, during the initial optimization stages, the hybrid algorithm starts with an algorithm to find a near-optimum solution and accelerate the convergence speed. The searching process is then switched to FA and the best solution found by another algorithm will be taken as the initial starting point for the FA and will be fine-tuned. In this way, the hybrid algorithm may find an optimum solution more quickly and accurately.

Harmony search algorithm. Over the past decade, to overcome the computational deficiencies of mathematical algorithms, evolutionary or metaheuristic algorithms, such as annealing and genetic algorithms, have been invented and simulated. However, searching for more powerful algorithms remains a challenge for engineers. The harmony search (HS) algorithm is a powerful search algorithm for finding the optimal answer²².

In composing music, several musicians collaborate with different instruments. Their goal is to produce beautiful music. During this collaborative process, each musician attempts to choose the best music performance each time to create better music. The beauty of music improves during collaboration. Typically, an attempt is made to evolve the music at each stage so that harmony is created between musicians.

Over time, the musicians produce a musical piece by playing different harmonies. After playing several pieces, the musicians recall the pieces they have played (the harmonies of that piece). Suppose that there are K harmonies composed by n musicians, and it is assumed that the size of each musician's memory (HMS) is equal to K harmony. Therefore, according to the following equation, a matrix with k rows (the number of memorised harmonies) and $n + 1$ columns, in which n is the number of musicians (the number of variables affecting the problem), and a column for the value of that harmony considering the fitness function is considered. The matrix is called the HM, or the harmony memory.

This algorithm consists of five steps:

- (1) Initialising the optimisation problem and initial parameters
- (2) Initialising harmony memory
- (3) Creating a new, improved harmony
- (4) Updating harmony memory
- (5) Repeating steps 3 and 4 until the final condition is satisfied or the desired number of iterations is completed
- (6) Optimising the control parameters of the SSSC damper.

To increase the damping of the studied system, two filters and a pre-phase/post-phase compensator block are located in the designed controller. The coefficients and time constants of the low-pass filter blocks and the washout filters are determined according to the studied frequency domain. Therefore, the cutoff frequency of the low-pass filter is considered as 10 Hz, and the test range in the small-signal stability is 0.2–2 Hz. The time constant of the phase compensator and compensator gain are considered as optimisation parameters. The optimal values of these parameters make it possible for the SSSC damper controller to have the maximum effect in eliminating the low-frequency oscillations of the power system. Thus, the optimisation vector is defined as follows:

$$X_{POP} = [K_e \ T_1 \ T_2] \quad (13)$$

This vector is the input to the optimisation algorithm. A reasonable range for the search space is determined by the change in the variables of the algorithm. By maintaining the integrity of the problem, the following intervals are expressed for the input vector:

$$\begin{aligned} 0 &\leq T_{C1} \leq 1 \\ 0 &\leq T_{C2} \leq 1 \\ 1 &\leq K_e \leq 20 \end{aligned} \quad (14)$$

To increase the damping of the system and reduce inter-area power oscillations, two control signals are considered. The first signal is the rotor angle variation of the generators, and the second signal is the power variation in the inter-area transmission line. Therefore, for each of these control signals, a proportional objective function is defined that ITAE criterion is considered in designing these functions.

$$\begin{aligned} OF_1 &= ITAE = \int_0^t t |\Delta\omega_r| dt \\ OF_2 &= \int_0^t t |\Delta P_{12}| dt \end{aligned} \quad (15)$$

where $\Delta P_{1,2}$ is the inter-area power oscillation in the transmission line²³. The purpose of using intelligent algorithms is to minimise the defined objective functions according to the range of variation in the control variables²⁴, and minimising each objective function equals the maximum damping of the system and the minimum number of small-signal oscillations.

Results and discussion

Two-area system. To investigate stability in the power system, a two-area power system with SSSC is considered. This system, shown in Fig. 5, is simulated in a Matlab-Simulink software environment. Synchronous generators are modelled as a sixth-order model and the SSSC converter.

The system consists of two similar areas connected by a weak transmission line. Each area consists of two interconnected synchronous generators rated at 900 MVA and 20 kV. The voltage of the transmission line system is rated at 230 kV, and in the normal state without the SSSC, 340 MW of active power is transferred from the first to the second area. Synchronous generator No. 3 is considered as the base. The amount of active power of each synchronous generator and the voltage of turbines are given in Table 1.

To check the stability of the power system, 3—Phase-to-earth short circuit fault is placed in the middle of the line, which is released after a period. Figure 6 shows the rotor angle of the turbines, mechanical speed of each turbine rotor, turbine connection bus voltage, and inter-area transitional power oscillation.

During a system failure, the system becomes subject to undamped oscillations. According to the oscillations in turbine velocity shown in the following Figure, the turbines in each area oscillate and divide the system into two areas. However, the unstable inter-area mode that is simulated and exists in the power system is visible in the transmission line power oscillations. These oscillations have 180 degrees of phase difference in the two areas, and their domain increases with time. The frequency of the inter-area oscillations in the two-area system is 0.7 Hz. In




Figure 5. Two-area four-machine system.

Generator	Active Power	Voltage
G ₁	700 MW	1/03
G ₂	700 MW	1/01 ∠0
G ₃	719 MW	1/03
G ₄	700 MW	1/01

Table 1. Synchronous generator parameters.




Figure 6. (a) Rotor angle of the turbines, (b) mechanical speed of each turbine rotor, (c) turbine connection bus voltage, and (d) inter-area transitional power oscillation and (e–h) are oscillations in turbine velocity.

the first scenario, a traditional PSS power stabiliser is added to Area 2, and the system is then re-examined. The signals used in the PSS are $\Delta\omega_3$ and $\Delta\omega_4$. The values of the KSTAB, TW, T1, and T2 parameters are 10, 2.8, 0.024, and 0.34, respectively. The 3-Phase-to-earth short circuit fault is applied as before. In Fig. 7, the oscillations in turbine velocity are shown. The first and the last of the line bus voltages and the transmission power oscillations from the first to the second area are shown. Accordingly, the system is divided into two areas; however, due to the use of a synchronous PSS, the two areas are retained. In Fig. 6h, the signal of PSS applied to the system and




Figure 7. (a) Transient power oscillation signal, (b) signal generated by the proposed damper controller, (c) flow injected into line, (d) turbine velocity, (e) Transmit signal power fluctuation, (f) The signal generated by the proposed damping controller, (g) injected current to the line, (h) Generator speed, (i) Regional signal $\Delta\omega_1$ and (j) Regional signal $\Delta\omega_2$ and (k) power oscillation in the transmission line in dPLine, dw_1 , and dw_3 modes.

Parameters	Value
Nominal voltage and frequency of transmission line	230 kV, 60 Hz
SSSC nominal power	100 MVA
Maximum voltage injection to transmission line	0.1 (p.u)
Series impedance converter	$0.0053 + j0.16$
Dc Link voltage	40kv
DC link capacitor	375 uF
PI controller coefficients for injection voltage	$K_p = 0.00375, K_i = 0.1875$
PI controller coefficients for DC link voltage	$K_p = 0.0001, K_i = 0.02$

Table 2. Parameters of the SSSC added to the transmission line.

the system excitation in the second area are illustrated. In the third scenario, an SSSC is added to the inter-area transmission line. The values of its parameters and the proposed parameters for the damper controller are listed in Tables 2 and 3, respectively.

Firstly, to investigate the damping effect of different signals on inter-area oscillations, three signals; i.e., the transmission line oscillations, the velocity of the first area, and the velocity of the second area, were selected, and the simulation was performed using these three signals. The simulation was conducted using the dPLine signal, which changes the inter-area transmission line power. The 3-Phase-to-earth short circuit fault is applied in the upper line. Figure 7a shows the transient power oscillation signal. In Fig. 7b, the signal generated by the proposed damper controller is shown.

Figure 7c shows the flow injected into the line according to the signal given by the damper controller, and Fig. 7d shows the turbine velocity. The area signals are used by the damper controller to generate the signal that $\Delta\omega_1$ used in Fig. 7e and the signal that $\Delta\omega_3$ used in Fig. 7g, h. To choose the most effective signal to improve damping, the results of these three signals are compared. Figure 7k shows the power oscillation in the transmission line in all three modes. The use of the signal indicating a change in turbine velocity has a greater effect on damping oscillations than the signal from the transmission line. Moreover, the first area signal has higher stability than the second area signal. According to these results, $\Delta\omega_1$ use has been used continuously.

Parameters	Value
K_{stab}	10
T_w	2.8
T_f	0.017
T_1	0.075
T_2	0.45

Table 3. Proposed parameters for the damper controller.

Firefly algorithm			
Optimization variables	nVar = 3	K_{stab}, T_1, T_2	
Search space range	$K_{stab} \in [1, 20]$	$T_1 \in [0.1, 1]$	$T_2 \in [0.01, 1]$
Maximum repetition	30		
Population	10		
α	0.2		
β_0	2		
γ	1		
Harmony search algorithm			
Optimization variables	nVar = 3	K_{stab}, T_1, T_2	
Search space range	$K_{stab} \in [1, 20]$	$T_1 \in [0.1, 1]$	$T_2 \in [0.01, 1]$
Maximum repetition	30		
Population	6		
HMCR	0.9		

Table 4. Firefly algorithm parameters.

Algorithm	K_{stab}	T_1	T_2
HS	14.74	0.71	0.39
FA	11.59	0.81	0.36

Table 5. Results of optimising the two algorithms.

Optimising SSSC parameters. For optimisation, firefly and harmony search algorithms are used. The parameters of each algorithm are shown in Table 4.

The optimisation variables include gain, time constant T_1 , and time constant T_2 . For each of the optimisation variables, a range of values is considered to cover all possible modes. On the other hand, due to the nature of each algorithm, suitable replications and populations were selected. Table 5 shows the results of optimising the two algorithms.

Figure 8a shows the inter-area power oscillations using the SSSC optimised by the HS algorithm or the non-optimised SSSC. Figure 8b indicates the turbine rotor oscillations and Fig. 8c shows the inter-area bus voltages.

Figure 8d shows the inter-area power oscillations using the SSSC optimised by the FA or the non-optimised SSSC. Figure 8e indicates turbine rotor oscillation and Fig. 8f shows the inter-area bus voltage. According to the results obtained from the two optimisation algorithms, the damping rate achieved by each one differs by 0.25%. The firefly algorithm outperformed the harmony search algorithm. Although the solutions produced with each algorithm differ little in performance, the calculation times for each algorithm differ significantly. Given the nature of the FA with the tested population and iterations, the time to obtain the optimal solution was 40 min. In contrast, the HS algorithm reached the optimal solution in significantly less time than FA. Table 6 shows the number of fitness function calls and the optimisation time for each algorithm.

Conclusion

In this paper, the effect of SSSC on the small-signal stability of power system was investigated. The SSSC controller was designed and evaluated for damping power system oscillations. Firefly and harmony search algorithms were used to determine optimal parameters for the SSSC controller, and the capability of the optimised SSSC was evaluated. The effectiveness of two proposed algorithms and the degree of participation of SSSCs in damping inter-area oscillations was investigated. The phase constant of the phase compensator and its gain were considered as optimisation parameters. Determining the optimal compensator parameters will result in the minimum oscillation. To maximise system damping and minimise inter-area power oscillations, control signals from changes in the rotor angle of the turbines and changes in the power of the inter-area transmission line were




Figure 8. (a) Inter-area power oscillations using the SSSC optimised by the HS algorithm or the non-optimised SSSC, (b) Turbine rotor oscillations and (c) inter-area bus voltages, (d) Inter-area power oscillation using the SSSC optimised by the FA or the non-optimised SSSC, (e) turbine rotor oscillations with FA and (f) inter-area bus voltages with FA.

Algorithm	Number of Fit Function Calls	Optimization time
FA	$10 \times 0 \times 0 = 103$	40 min
HS	$6 \times 31 = 186$	17 min

Table 6. Number of calls and optimisation time.

used. The simulation was performed on a power system in two areas. The system turbines were modelled as a 6-order model, and the SSSC converter was modelled as an average model. The two-area system was then studied using PSS and SSSC power system stabilisers. According to the results obtained, the damping rate achieved by the two optimisation algorithms differs by 0.25%. The firefly algorithm outperformed the harmony search algorithm by 0.25%.

Received: 1 April 2020; Accepted: 7 July 2020

Published online: 22 July 2020

References

- Ghosh, S., Folly, K. A. & Patel, A. Synchronized versus non-synchronized feedback for speed-based wide-area PSS: effect of time-delay. *IEEE Trans. Smart Grid* **9**, 3976–3985 (2016).
- Cheng, S., Malik, O. P. & Hope, G. S. Self-tuning stabiliser for a multimachine power system. In *IEE Proceedings C (Generation, Transmission and Distribution)* **133**, 176–185 (IET, 1986).
- Wang, H. & Du, W. *Analysis and Damping Control of Power System Low-Frequency Oscillations* (Springer, Berlin, 2016).
- Darabian, M. & Jalilvand, A. A power control strategy to improve power system stability in the presence of wind farms using FACTS devices and predictive control. *Int. J. Electr. Power Energy Syst.* **85**, 50–66 (2017).
- Norouzi, A. H. & Sharaf, A. M. Two control schemes to enhance the dynamic performance of the STATCOM and SSSC. *IEEE Trans. Power Deliv.* **20**, 435–442 (2005).
- Kumar, L. S. & Ghosh, A. Modeling and control design of a static synchronous series compensator. *IEEE Trans. Power Deliv.* **14**, 1448–1453 (1999).
- Bongiorno, M., Svensson, J. & Angquist, L. On control of static synchronous series compensator for SSR mitigation. *IEEE Trans. Power Electron.* **23**, 735–743 (2008).
- Shen, Y., Yao, W., Wen, J., He, H. & Chen, W. Adaptive supplementary damping control of VSC-HVDC for interarea oscillation using GrHDP. *IEEE Trans. Power Syst.* **33**, 1777–1789 (2017).
- Jiang, X., Fang, X., Chow, J. H., Edris, A.-A. & Uzunovic, E. Regulation and damping control design for interline power flow controllers. In *2007 IEEE Power Engineering Society General Meeting* 1–8 (IEEE, 2007).
- Jiang, X. *et al.* A novel approach for modeling voltage-sourced converter-based FACTS controllers. *IEEE Trans. Power Deliv.* **23**, 2591–2598 (2008).
- Jiang, X., Chow, J. H., Edris, A.-A., Fardanesh, B. & Uzunovic, E. Transfer path stability enhancement by voltage-sourced converter-based FACTS controllers. *IEEE Trans. Power Deliv.* **25**, 1019–1025 (2009).
- Fang, X. *et al.* Sensitivity methods in the dispatch and siting of FACTS controllers. *IEEE Trans. Power Syst.* **24**, 713–720 (2009).
- Chakraborty, A. Wide-area damping control of power systems using dynamic clustering and TCSC-based redesigns. *IEEE Trans. Smart Grid* **3**, 1503–1514 (2012).
- Zhang, T. & Geem, Z. W. Review of harmony search with respect to algorithm structure. *Swarm Evol. Comput.* **48**, 31–43 (2019).
- Enten, A. C., Leipner, M. P. I., Bellavia, M. C., King, L. E. & Sulchek, T. A. Optimizing flux capacity of dead-end filtration membranes by controlling flow with pulse width modulated periodic backflush. *Sci. Rep.* **10**, 1–11 (2020).
- Ojo, O. & Davidson, I. E. PWM-VSI inverter-assisted stand-alone dual stator winding induction generator. *IEEE Trans. Ind. Appl.* **36**, 1604–1611 (2000).
- Su, C. & Chen, Z. Damping inter-area oscillations using static synchronous series compensator (SSSC). In *2011 46th International Universities' Power Engineering Conference (UPEC)* 1–6 (VDE, 2011).
- Li, J. *et al.* A hybrid cable connection structure for wind farms with reliability consideration. *IEEE Access* **7**, 144398–144407 (2019).

19. Chang, B., Yang, R., Guo, C., Ge, S. & Li, L. A new application of optimized random forest algorithms in intelligent fault location of rudders. *IEEE Access* **7**, 94276–94283 (2019).
20. Yang, X.-S. Firefly algorithm, stochastic test functions and design optimisation. *arXiv Prepr. arXiv1003.1409* (2010).
21. Bui, D. T. *et al.* Novel hybrid evolutionary algorithms for spatial prediction of floods. *Sci. Rep.* **8**, 1–14 (2018).
22. Naderipour, A., Zinb, A. A. M., Habibuddinc, M. H., Khokhard, S. & Kazemi, A. *Improved Control of Shunt Active Power Filter Using Harmony Search Algorithm*.
23. Naderipour, A. *et al.* Optimal allocation for combined heat and power system with respect to maximum allowable capacity for reduced losses and improved voltage profile and reliability of microgrids considering loading condition. *Energy* **196**, 117124 (2020).
24. Naderipour, A. *et al.* Optimal designing of static var compensator to improve voltage profile of power system using fuzzy logic control. *Energy* **192**, 116665 (2020).

Acknowledgements

This research was funded by the Universitas Sriwijaya (grant 4B379), Universiti Malaysia Perlis (4B482), Universiti Teknologi Malaysia (Post-Doctoral Fellowship Scheme grant 05E09, and RUG grants 01M44, 02M18, 05G88) and VILLUM FONDEN under the VILLUM Investigator Grant (no. 25920): Center for Research on Microgrids (CROM); <http://www.crom.et.aau.dk>. In addition, the authors wish to thank Duy Tan University for their financial support.

Author contributions

All authors participated in the discussion and wrote the manuscript.

Competing interests

The authors declare no competing interests.

Additional information

Correspondence and requests for materials should be addressed to Z.A.-M. or V.K.R.

Reprints and permissions information is available at www.nature.com/reprints.

Publisher's note Springer Nature remains neutral with regard to jurisdictional claims in published maps and institutional affiliations.



Open Access This article is licensed under a Creative Commons Attribution 4.0 International License, which permits use, sharing, adaptation, distribution and reproduction in any medium or format, as long as you give appropriate credit to the original author(s) and the source, provide a link to the Creative Commons license, and indicate if changes were made. The images or other third party material in this article are included in the article's Creative Commons license, unless indicated otherwise in a credit line to the material. If material is not included in the article's Creative Commons license and your intended use is not permitted by statutory regulation or exceeds the permitted use, you will need to obtain permission directly from the copyright holder. To view a copy of this license, visit <http://creativecommons.org/licenses/by/4.0/>.

© The Author(s) 2020