

Utilisation of Excess Wind Power for Hydrogen Production in Northern Germany

C. Stiller, J. Michalski

This document appeared in

Detlef Stolten, Thomas Grube (Eds.):

18th World Hydrogen Energy Conference 2010 - WHEC 2010

Parallel Sessions Book 3: Hydrogen Production Technologies - Part 2

Proceedings of the WHEC, May 16.-21. 2010, Essen

Schriften des Forschungszentrums Jülich / Energy & Environment, Vol. 78-3

Institute of Energy Research - Fuel Cells (IEF-3)

Forschungszentrum Jülich GmbH, Zentralbibliothek, Verlag, 2010

ISBN: 978-3-89336-653-8

Utilisation of Excess Wind Power for Hydrogen Production in Northern Germany

Christoph Stiller, Jan Michalski, Ludwig-Bölkow-Systemtechnik GmbH, Germany

1 Introduction

With more than 20 GW of installed wind power capacity in Northern Germany and more to come due to the expansion of offshore wind power there are periods when the available wind power exceeds the capacity of the electricity grid or even the electricity demand within reach. This excess wind power could be utilized for the electrolytic production of hydrogen, which can be stored and used as a transportation fuel, as a feedstock for the chemical industry, or even for power production in times of low renewable generation.

This paper will first review the current framework of the German electricity generation. Then, based on the expected electricity generation and demand, the amount of excess power available for hydrogen production will be estimated. This will be followed by a discussion of operation models for hydrogen electrolysis, rounded off by a discussion of required storage demand and possible uses of the hydrogen.

2 General Framework of the German Electricity Generation

Since 1990, electricity production in Germany has only increased by about 0.8% p.a. on average, and almost the entire surplus has been covered by renewable electricity [1].

Due to the age structure of the power plant park and in view of the planned nuclear phase-out, currently a large number of new fossil power plant projects (especially hard coal) are in the planning phase; yet, it needs to be mentioned that partially, the realization is uncertain. In addition, the nuclear phase-out will most likely be postponed by the new German government.

The share of renewables for electricity production in Germany has increased from 10 to 15% in only three years (2005-2008); highest shares being achieved in the North (e.g., in Schleswig-Holstein, renewable energy generation, mainly wind power, exceeds 40% of the electricity demand). Specifically in regions with high intermittent renewable capacities installed, already today grid capacity issues occur and wind turbine power need to be cut off temporarily in order not to cause grid breakdown (regulated in the renewable energy law as "feed-in management") [2]. Further extensive renewable potentials lie within repowering of onshore wind farms and the build-out of offshore wind energy use in the North and Baltic Sea.

By 2020, according to the "Lead scenario 2009" [3], 33 GW from onshore and 9 GW from offshore wind power are expected to be fed into the German grid. The offshore feed-in is expected to grow to 24 GW by 2030. Since all offshore capacity is landed in Northern Germany (mainly in Schleswig-Holstein and Lower Saxony) where also the density of onshore generation is high, this will at times cause massive excess power production. This implies grid reinforcement and extension to transmit the power to neighboring regions;

however, even Germany-wide power production may exceed the demand and export capacities at times of low load and high wind.

Possible remedies are the temporal shift of loads by demand-side management and battery electric vehicles; however, potentials are limited both with respect to quantities and time periods over which the loads can be bridged [4]. Therefore, large-scale electricity storage will be urgently required in order to more easily integrate the further increase in intermittent renewable electricity generation into the grid.

3 Availability of Excess Power for Hydrogen Production

In order to analyse the potentials of hydrogen production from excess renewable electricity, the quantities of power surplus have to be estimated. In this sense “excess power/electricity” will be defined as the portion of power/electricity which cannot be utilised in times of high generation (renewable+fossil+nuclear) and low demand as well as export capacities of a region. In such cases the renewable generation will have to be cut off in order to assure grid stability. The quantity of excess power production depends mainly on the following four factors:

- Installed capacity of intermittent renewables, especially wind power. The feed-in of photovoltaics is less relevant in this context as it provides electricity during daytime with comparatively high demand.
- Installed capacity of conventional power plants, especially base load plants. In particular, lignite and nuclear power plants are operated at high load also in times of high winds increasing the excess power. For example, during the night of October 4th, 2009, high wind volume and low electricity demand resulted in the negative spot market price of -0.50 €/kWh. Since at this time German nuclear power plants still operated at an average load of 77%, lignite at 65%, hard coal at 12% and natural gas at 9% [5] we assume this capacity utilization as the minimum practical part load of conventional plants during situations with excess electricity.
- Electricity demand and demand profile of the region. In general, the excess electricity can be reduced either by demand-side management or by an increased demand for a given level of power supply.
- Export capacity to neighbour regions. This is not only limited by the available transfer capacities, but also by the fact that adjacent regions are meteorologically linked. In this sense, excess wind power generation may occur not only in Northern Germany but also in other regions with own wind parks. In consequence, extension of grid capacity alone is not always effective to reduce excess power.

For the calculation of the excess power, specific assumptions regarding the capacity of energy generation per type and demand curves had to be made. The minimum generation of dispatchable power plants was derived from the estimated available capacity and the minimum part load numbers mentioned above. Onshore wind power curves were based on scaled Germany-wide production curves of the reference year 2008. Wind speed data from FINO platforms in the North and Baltic Sea were used in order to calculate the offshore power curves based on the characteristics of a 5 MW turbine. To estimate the electricity demand, hourly data from 2008 provided by UCTE / ENTSOE [6] were scaled to the

respective future demand. Due to metrological linkages between adjacent regions, electricity export to neighbour countries was not considered as a way to use excess electricity. From the comparison of resulting generation and demand, the excess power generation could be estimated as shown in Figure 1.




Figure 1: Methodology to determine excess power (1 week displayed).

With this methodology, the excess electricity was estimated for different scenarios based on the generation and demand projections of the “Lead scenario 2009” [3]. Two variations from the lead scenario were considered: a scenario where 15 GW nuclear generation capacity would remain online (compensated by lower capacities of hard coal and natural gas), and an extreme scenario where the 2008 values for fossil and nuclear generation capacity and demand were frozen and the onshore and offshore generation capacity ramped up as in the Lead scenario (33 GW onshore + 9 GW offshore by 2020, and 36 GW onshore + 24 GW offshore by 2030). Figure 2 shows the resulting excess power generation per year in Germany until 2030. In the lead scenario, only up to 9 TWh of excess electricity accrue until 2030 due to the consequent phase-out of fossil power plants. Retaining nuclear capacities will strongly increase excess electricity, and assuming that the power plant park of 2008 is retained while ramping up renewables, huge amounts of excess electricity will accrue until 2030. According to this estimation, by 2020 between 1.1 and 13 TWh of electricity (corresponding to 1.1-13% of overall wind power generation) cannot be used when they accrue and will therefore be available for energy storage in the form of hydrogen. For comparison, other authors with similar approaches have concluded that for whole Europe, 16 to 260 TWh excess power would accrue by 2020 [7]. Wietschel et al. [8] found that for Germany, 9 TWh excess power would accrue with 38.3 GW wind power installed, increasing to 28 TWh with 48.3 GW wind power installed.

4 Operation Model for Hydrogen Production

Northern Germany is generally an ideal location for hydrogen production from renewables and large-scale storage due to the high concentration of wind power capacity and the geologic conditions facilitating the construction of underground salt caverns suitable for hydrogen storage. With the aim to develop a sound operation strategy for hydrogen production based on the use of excess electricity while at the same time unstraining the grid in the most economic way, the location of electrolyzers as well as the economics of purchasing electricity (i.e. the connection to the electricity market) are the main criteria to be addressed.

In general there are three major options for the allocation of electrolyzers: directly at the larger on- and offshore wind farms, at the end user location (e.g., an industrial sites or a hydrogen refuelling station) or at grid hubs of the high or ultra-high voltage grid in the areas with the highest wind loads and the heaviest loads on the grid (e.g., along the west coast of Schleswig-Holstein). Placement directly at the wind farms helps to unstrain the electric grid regionally and super-regionally, but hydrogen production is dispersed and the distribution to the consumers is comparatively complex, especially from offshore locations. Placement directly at the consumer site omits the transportation of hydrogen, but does not unstrain the electric grid between the wind farm and the consumer. Furthermore, access to large-scale storage caverns for longer-term storage of hydrogen cannot be provided easily in either of the distributed placement strategies. Therefore we assume that placing larger electrolysis plants at grid hubs in areas with high wind power capacity is most beneficial, since this concept effectively unstrains the electric grid, efficient access to large-scale storage and efficient distribution of the produced hydrogen. The maximum electrolysis capacity installed at the grid hubs should be limited to a certain share of the upstream wind power.




Figure 2: Resulting excess power generation in Germany through 2030.

As a price basis for the required electricity, either the feed-in tariffs for renewable electricity, or the day-ahead spot market hourly price curve of the European Energy Exchange (EEX) are reasonable. The latter can be interpreted either as purchasing the power at the EEX or directly from the wind farm operators, who otherwise would trade at EEX. Today, most wind

power is fed in according to the fixed feed-in tariffs regulated by the German Renewable Energy Law. However, it can be expected that by 2020 most wind power will be directly traded at the spot market due to the declining tariffs. Moreover, the spot market price represents the balance between electricity demand and supply: in times of low demand and high renewable energy generation the spot market price will be low, and vice versa. Hence, taking the spot market price as a base for electricity purchases ensures the operation of electrolyzers in a way which indirectly unstrains the grid by using the excess electricity at low costs. As a simple operation strategy, electrolyzers may be operated at full load during hours when the price is below a certain threshold, and may be kept in warm stand-by mode when the price is above the threshold. The number of operation hours per year and the average electricity price paid then depend on the price threshold set.

Further revenues for hydrogen producers can result from control reserves since electrolyzers represent a controllable load within the power grid. An electrolyzer can be turned off or switched on upon request in order to providing positive or negative control reserve. The provision of the so-called "minute reserve" is tendered jointly by the transmission system operators (TSO) in Germany in 4-hour blocks for the following day. It is important to mention that the pure provision of control power (without actually being called) is already compensated by a per-MW rate. While tendering for control reserve brings additional revenues to the hydrogen production, it also increases the administration effort; since the control reserve is awarded at 10:00 AM for the next day, and the day-ahead spot market auction is at noon, the operator has to rely on a forecast of the spot market price in order to decide whether the electrolyzer should be operated during every 4 hour block (i.e. tender positive control reserve), or not (i.e. tender negative control reserve). Once control reserve has been awarded, the electrolyzer must be operated according to the plan, even if electricity prices differ from the forecast. Therefore and due to the implication to operate in 4-hour blocks, the average electricity price levels will be somewhat higher if control reserve is to be provided.

A further benefit for the hydrogen producers can be achieved by utilising wind power from turbines temporarily cut down under "feed-in management". The opportunity losses for wind parks caused by such incidents have to be fully compensated by the TSO according to the Renewable Energy Law. Provided that there are no grid restrictions between the wind turbines and the electrolyzers, the balance could be used for hydrogen production at marginal costs. However, since the TSOs are obliged to reinforce the power grid in order to avoid such events the potential benefits from this strategy are limited and uncertain.

5 Required Storage Demand and Options for Usage of the Hydrogen

A strategy as described above will lead to varying electrolyzer utilisation with a tendency to higher production in the winter time with high wind power feed-in. In order to optimally level out the seasonal variations in production and facilitate a constant delivery of hydrogen to the end customers we found that a hydrogen storage capacity of approximately 700 full load hours is needed. If the hydrogen consumption can be adapted to the availability (higher consumption in winter than in summer), the storage capacity can be lower; on the other hand, if the hydrogen consumption is inflexible and peaks in summer, the storage capacity

will need to be higher. The economic optimum of design storage capacity will be a trade-off between storage costs and timely flexibility of electrolysis operation (leading to savings in electricity costs). In the case of large-scale storage in salt caverns, the storage only contributes a minor part to the overall costs; however, if storage in e.g. aboveground pressure vessels or liquid hydrogen dewars is chosen, then the costs will be a multiple of the electrolysis costs.

A viable use of the renewable hydrogen is partial or complete substitution of hydrogen generated from natural gas for uses in chemical and process industry. Besides saving fossil primary energy for hydrogen production by reforming, this has the potential to reduce the greenhouse gas emissions of the industries, improving their carbon footprint and avoiding costs of CO₂ certificates.

Hydrogen in road transportation will be an emerging market in the mid term. Offering hydrogen from renewables at the refuelling stations to be erected is an interesting option, especially when considering the fact that the consumers might prefer “green hydrogen” and could also be forced by legislation (California has already implemented a law that 33% of all hydrogen for transportation will need to be renewable).

The hydrogen could further be used for power generation (so-called re-electrification) in combined cycle gas turbines. Co-firing with natural gas at flexible shares is technically feasible. Re-electrification is a way to stabilise the electric grid by not only taking away power in times of excess renewable electricity but also compensate lack of renewable generation, e.g. in times of low wind.

6 Conclusion

The paper showed that due to the ongoing build-out of intermittent renewable generation capacity and limited part-load ability of dispatchable power plants, significant amounts of excess electricity will accrue in the German electricity system in the future. This excess energy may be used to generate hydrogen, which can then be economically stored in large-scale salt caverns and utilized in industry and transportation sector or for electricity generation at times of low feed-in of renewables. An operation model based on central electrolysis plants at grid hubs, the spot market as a price basis for electricity purchases and a threshold-price strategy can yield minimum overall hydrogen production costs and at the same time facilitate effective unstraining of the grid. Northern Germany is an ideal location for storage of hydrogen from renewables in caverns since huge capacities of onshore and offshore wind energy are expected to be installed during the coming decade posing local challenges to the electric grid and furthermore since the geologic conditions are favorable for hydrogen storage in salt caverns.

References

- [1] Arbeitsgemeinschaft Energiebilanzen e.V.: Electricity generation by energy carriers 1990 to 2008 (in TWh) Germany, Status 27 May 2009; <http://www.ag-energiebilanzen.de/viewpage.php?idpage=65>
- [2] Act Revising the Legislation on Renewable Energy Sources in the Electricity Sector and Amending Related Provisions – Renewable Energy Sources Act (EEG 2009) –

- official document, Federal Law Gazette (Bundesanzeiger) 2008 I No. 49, Bonn, 31 October 2008, p. 2074.
- [3] German Federal Ministry for the Environment, Nature Conservation and Nuclear Safety: Lead scenario 2009.
<http://www.bmu.de/files/pdfs/allgemein/application/pdf/leitszenario2009.pdf>
- [4] Klobasa, M.; Nachfrageseitige Regelungsmöglichkeiten im Energiesystem; in: EnInnov 08, 10. Symposium Energieinnovation. Energiewende: 13.-15. Februar 2008; TU Graz: Verlag der TU Graz, 2008; ISBN: 978-3-902465-94-8, S. 89-90
- [5] EEX Transparency data, power plant information (visited October 2009).
<http://www.eex.com/en/Transparency/Power%20plant%20information>
- [6] European Network of Transmission System Operators for Electricity: Hourly load values of a specific country for a specific month;
<http://www.entsoe.eu/index.php?id=92>, visited October 2009
- [7] C. Hoffmann, M. Greiner, L. Von Bremen, K. Knorr, S. Bofinger, M. Speckmann, K. Rohrig: Design of transport and storage capacities for a future European power supply system with a high share of renewable energies. IRES Conference 2008, Berlin, 24-25 November 2008.
- [8] M. Wietschel, U. Hasenauer, N. Juncà Vicens, M. Klobasa, P. Seydel: Ein Vergleich unterschiedlicher Speichermedien für überschüssigen Windstrom. Zeitschrift für Energiewirtschaft 30 (2006) 2, p. 103-114.