

COMPARATIVE ANALYSIS OF ADVANCED CONTROLLERS IN A HEAT EXCHANGER

Mr. P.Sivakumar, Dr.D.Prabhakaran, Dr. T .Kannadasan

*M. Tech Scholar, Department of Chemical Engineering, Coimbatore Institute of Technology.
Associate Professor, Department of Chemical Engineering, Coimbatore Institute of Technology,
Professor and Head, Department of Chemical Engineering, Coimbatore Institute of Technology,*

Abstract: Temperature control of the shell and tube heat exchanger is characteristics of nonlinear, time varying and time lag. Since the temperature control with conventional PID controller cannot meet a wide range of precision temperature control requirement, we design temperature control system of the shell and tube heat exchanger by combining fuzzy and PID control methods in this paper. The simulation and experiments are carried out; making a comparison with conventional PID control showing that fuzzy PID strategy can efficiently improve the performance of the shell and tube heat exchanger.

Keywords: Control algorithm, Fuzzy logic, PID Controller, Tuning

I. INTRODUCTION

In many industrial process and operations Heat exchanger is one of the simplest and important unit [1] for the transfer of thermal energy. There are different types of heat exchangers used in industries; the shell and tube heat exchanger system being most common. The main purpose of exchanger is to maintain specific temperature conditions, which is achieved by controlling the exit temperature of one of the fluids (mainly hot fluid) in response to variations of the operating conditions.

The temperature control of heat exchanger is nonlinear, time varying and time delay system. For these situations, nonlinear control strategies can provide significant improvements over PID control [2], [12]. Control of temperature using PID controllers, compared to other methods, is more effective and economical.

The heat exchangers need to respond to highly non linear features and work well under different operating points. In order to achieve a wide range of high accurate temperature, we combine neuro-fuzzy control and PID control methods. The main design is to assume neuro-fuzzy reasoning control methods according to different error 'e' and error change 'ec' to get self-tuning PID parameter based on conventional PID controller. The simulation of the controller was accomplished carrying out experiments in an actual heat exchanger system.

II. TEMPERATURE CONTROL SYSTEM

A. Principal of temperature control in shell and tube heat exchanger

The control of temperature in a shell-and-tube heat exchanger is demonstrated in figure 1, with cold water flowing on the tube side and steam on the shell side [5] where steam condenses and heats the water in the tubes. The controlled variable is the tube-side outlet temperature, and the manipulated variable is the steam flow rate on the shell-side.

$$M_c C_p (T_{in} - T_{out}) = M_s A \quad (1)$$

where, M_c , M_s , C_p , T_{in} and T_{out} refer to cold water flow rate, steam flow rate, specific heat of water, inlet water temperature, and outlet water temperature respectively.




Fig.1.Shell and Tube heat exchanger

The dynamics of the process are complex because of various nonlinearities introduced into the system. The installed valve characteristic of the steam may not be linear [3]. Dead-time depends on the steam and water flow rates, the location and the method of installation of the temperature-measuring devices. To take into account the non-linearity and the dead-time, gain scheduling features and dead-time compensators have to be added. Also, the process is subjected to various external disturbances such as pressure fluctuations in the steam header, disturbances in the water line, and changes in the inlet steam enthalpy and so on.

B. Mathematical Model of heat exchanger

The total heat in the heat exchanger system can be expressed as equation 2. [5].

$$Q_f = Q_s + \sum_{i=1}^n C_i \rho_i V_i dT_i \tag{2}$$

where, Q_f , Q_s , C , ρ , V and dT refer to total system heat productivity, total system heat dissipating capacity, specific heat capacity, heat transfer medium density, volume, and temperature variation.

Total system heat dissipating capacity Q_s is given by equation 3.

$$Q_s = \sum_{i=1}^n k_i A_i (T_{in} - T_{out}) \tag{3}$$

where, k_i and A_i refer to heat transfer coefficient, heat transfer area of the heat exchanger system.

The heat exchanger equations can be expressed as in equation 4. [12]

$$C_w \rho_w q_w (T_{wo} - T_{wi}) d\tau = C_f \rho_f q_f (T_{fo} - T_{fi}) d\tau \tag{4}$$

where, the subscripts W and f refer to cold and hot water of the heat exchanger system. Therefore considering all above equations, the differential equation of the shell and tube heat exchanger is shown in equation 5.

$$\frac{dT}{d\tau} + FT = N(x - \tau) \tag{5}$$

where,

$$F = \frac{k_i A_i}{C_o \rho_o V} \tag{6}$$

The transfer function of controlled object can be derived from equation 5, it is described as the first-order with pure time delay, expressed as equation 7.

$$G(s) = \frac{K}{1 + Ts} e^{-\tau s} \tag{7}$$

where, T , K and τ refer to time constant, system gain, and delay time.

III. INTELLIGENT CONTROLLERS

A. PID Control of Shell and Tube Heat Exchanger

PID controller is the most popular controller used because it is easy to operate and very robust. Implementation of the latest PID controller is based on a digital design. These digital PID include many algorithms to improve their performance, such as anti wind-up, auto-tuning, adaptive, fuzzy fine-tuning and Neural Networks with the basic operations remaining the same. The performance specifications such as rise

time, overshoot, settling time and error; steady state can be improved by tuning value of parameters K_p , K_i and K_d of the PID controller. The output is mathematically represented as equation 8 and 9.

$$y(t) = K_p[e(t) + T_d \frac{de(t)}{dt} + \frac{1}{T} \int_0^t e(t)dt] \quad (8) \quad y(t) = K_p e(t) + K_p T_d \frac{de(t)}{dt} + \frac{K_p}{T} \int_0^t e(t)dt \quad (9)$$

B. Structure and Parts of Self tuning Fuzzy Controller

Fuzzy logic controller as shown in Figure 2 consists of main four parts fuzzification, rule base, inference engine and de-fuzzification [6], [8].




Fig.2.Main Parts of Fuzzy PID Control

Fuzzy PID Self-tuning Control takes error "e" and Change-in-error "ec" as the input of Fuzzy PID controller. Using fuzzy control rules on-line, PID parameters " K_p ", " K_i ", " K_d " are amended, which constitute a self-tuning fuzzy PID controller, the principle of which is shown in Figure 3. The language variable values of error "e" and the error rate of change "ec" is (NB, NM, NS, ZO, PS, PM, PB) seven fuzzy values. And then setting up the suitable fuzzy control table for K_p , K_i , K_d three parameters tuning separately[8], [9].According to the fuzzy rules table, appropriate vague and ambiguous methods is to be selected to make dynamic tuning for K_p , K_i , K_d .




Fig.3.Structure of Fuzzy PID Control




Fig.4.Input membership function for e and ec

The fuzzy controller takes two inputs (e, and error change ec) and three outputs (K_p , K_i , K_d). When the error is large, it is controlled according to the characteristics of PID control where the output value automatically closes to the given value. When the error becomes smaller to a certain extent, the fuzzy control takes effect. The input error, error change and output membership functions use triangular functions, which are shown in figure 4 and 5.




Fig.5.Output membership function for K_p, K_i, K_d

Larger K_p is chosen to speed up the system response speed. At the same time, in order to avoid the probable differential super-saturation, smaller K_i is chosen. In order to avoid large overshoot, the integral is limited by setting K_d is zero.

TABLE 1 THE FUZZY CONTROL RULE FOR K_p

Δx_i \ e	ec	NB	NM	NS	ZO	PS	PM	PB
NB		PB	PB	PM	PM	PS	ZO	ZO
NM		PB	PB	PM	PS	PS	ZO	NS
NS		PM	PM	PM	PS	ZO	NS	NS
ZO		PM	PM	PS	ZO	NS	NM	NM
PS		PS	PS	ZO	NS	NS	NM	NM
PM		PS	ZO	NS	NM	NM	NM	NB
PB		ZO	ZO	NM	NM	NM	NB	NB

In order to make the overshoot of the system respond relatively small and to ensure the system response speed, K_p is set smaller, and K_i and K_d values are chosen respectively.

TABLE 2 THE FUZZY CONTROL RULE FOR K_i

Δx_i \ e	ec	NB	NM	NS	ZO	PS	PM	PB
NB		NB	NB	NM	NM	NS	ZO	ZO
NM		NB	NB	NM	NS	NS	ZO	ZO
NS		NB	NM	NS	NS	ZO	PS	PS
ZO		NM	NM	NS	ZO	PS	PM	PM
PS		NM	NS	ZO	PS	PS	PM	PB
PM		ZO	ZO	PS	PS	PM	PB	PB
PB		ZO	ZO	PS	PM	PM	PB	PB

In order to make the system have better steady state, K_p and K_i are set larger, and to avoid oscillations near the set point, K_d is set properly. When ec is small, K_d is set middle, and when ec is large, K_d is set small. According to the given rules, the control rule table of PID parameters can be obtained and the control rules for K_p, K_d and K_i is listed in table 1, 2 and 3.

TABLE 3 THE FUZZY CONTROL RULE FOR K_d

Δx_i \ e	ec	NB	NM	NS	ZO	PS	PM	PB
NB		PS	NS	NB	NB	NB	NM	PS
NM		PS	NS	NB	NM	NM	NS	ZO
NS		ZO	NS	NM	NM	NS	NS	ZO
ZO		ZO	NS	NS	NS	NS	NS	ZO
PS		ZO	ZO	ZO	ZO	ZO	ZO	ZO
PM		PB	NS	PS	PS	PS	PS	PB
PB		PB	PM	PM	PM	PS	PS	PB

Defuzzification

In this paper, we use the weighted average method to the fuzzy evaluation to get the precise control value with formula as shown in equation 10.

$$u_0 = \frac{\sum_{i=1}^n \mu(u_i) \cdot u_i}{\sum_{i=1}^n \mu(u_i)} \tag{10}$$

Where u_i is the fuzzy set values, $\mu(u_i)$ is membership degree of fuzzy values and u_0 is evaluation result. After the three parameters are adjusted by the fuzzy controller, the output control parameters are calculated from the equation 9.

C. Neuro- Fuzzy Controller

In the field of artificial intelligence, neuro-fuzzy refers to combinations of artificial neural networks and fuzzy logic. Neuro-fuzzy hybridization results in a hybrid intelligent system by combining the human-like reasoning style of fuzzy systems with the learning and connection structure of neural networks. The drawbacks are the complexity and the darkness of their structures. Industries use the PID technique since it is a crisp control. The self tuning of the P, I, D parameters are quite difficult and the resultant control is with overshoot and with large time constants. To avoid we use the combination of Neuro-Fuzzy PID controllers for controlling the temperature in the process.




Fig.6. Structure of Neuro-Fuzzy PID Control

IV. EXPERIMENTAL RESULTS AND DISCUSSIONS

A. Step Response for the Intelligent Controllers

Comparison between conventional PID, fuzzy PID and Neuro-Fuzzy PID controller's temperature control was performed. According to the analysis fuzzy controller is designed in MATLAB and the fuzzy self-tuning PID control system model is designed by SIMULINK. The step response of the Fuzzy control and conventional control is shown in Figure 7, 8.




Fig.7. Step Response for the Intelligent Controllers

The initial tuning of the PID controller is accomplished based on the Ziegler-Nicholes method, and the gain coefficients are $K_p=1.1$, $K_i=0.003$ and $K_d=52$. Fuzzy PID Controller has a small overshoot, fast response and the steady state error is less than 1%.

B. Response of the Temperature control system

The temperature control experiment is conducted in the actual Shell and tube heat exchanger system. The target outlet temperature of heat exchanger is 60°C and figure 7 shows the response of heat exchanger.

The results suggest that neither the settling time nor control accuracy is satisfied enough when conventional PID controller is used in shell and tube heat exchanger. The steady state error of the PID controller is greater than fuzzy PID. The experimental results shows that fuzzy self-tuning PID control has better dynamic response and steady state error characteristics.




Fig.8.Response of Temperature control

C. Comparison of various parameters

Table 4 shows the comparison of various parameters from the above graph for the various types of Controllers.

TABLE 4 COMPARISON OF PARAMETERS

Parameters	PID	Fuzzy PID	Neuro Fuzzy PID
Rise Time	1.8	2.6	3.2
Peak over shoot	0.68	0.82	1.2
Settling Time	14	5.8	8.6
Peak Time	2.6	4.1	4.2

V. CONCLUSION

In this paper we have discussed the design of a temperature control of a shell and tube heat exchanger based on Neuro-fuzzy PID control by comparing it with PID and Fuzzy PID. The analysis fuzzy controller is designed in MATLAB and the fuzzy self-tuning PID control system model is designed by SIMULINK. The results suggested that self-tuning parameter fuzzy PID controller has a smaller system overshoot, faster response and less steady state error thereby making it stronger than conventional PID controller. It was thus concluded that fuzzy self-tuning PID control has better dynamic response and steady state error characteristics. The control rule table of PID parameters was obtained and the control rules for K_p , K_d and K_i was tabulated. The actual system used obtains a good control effect and can satisfy the requirements of the temperature control system of the shell and tube heat exchanger. support throughout the preparation of this work.

I would like to express my gratitude to Dr.D.Prabhakaran, Associate Professor, Coimbatore Institute of Technology for his motivation and guidance throughout my work.

REFERENCES

- [1] H. Thal-Larsen, Dynamics of heat exchangers and their models, ASME J. Basic Eng. 1960, pp. 489 – 504.
- [2] M.Chidambaram, and Y.S.N. Malleswara rao, Nonlinear Controllers for heat exchangers, J. Proc. Cont., 1992 vol 2(1), pp 17-21.
- [3] A.W.Alsop, and T.F.Edgar, Non-linear heat exchanger control through the use of partially linearised control variables, Chem. Eng. Commn., vol.75, 1998, pp 155 – 170.
- [4] Wang Li-Xin, Adaptive fuzzy systems and control: Design and stability analysis [M], Prentice-Hall Englewood cliffs NewJersey 1994.
- [5] H. Yamashita, R. Izumi, S. Yamaguchi, Analysis of the dynamic characteristics of cross-flow heat exchangers with both fluids unmixed, Bull. JSME, vol. 21 (153), 1978, pp 479-485.
- [6] Hassan B.Kazemian , Development of an intelligent Fuzzy Controller, IEEE International Fuzzy Systems Conference. Vol.1, 2001, pp. 517-520.
- [7] Mann G. K.I., Hu B.G.Gosine R.G, Analysis of direct fuzzy PID controller structures, IEEE Trans on Systems, Man and Cybernetics. Vol.29, 1999, pp. 371-388.
- [8] M. Sugeno, Industrial applications of fuzzy control, Amsterdam, The Netherlands: Elsevier, 1985.
- [9] Li, H.X. & H. Gatland, Conventional fuzzy logic control and its enhancement, IEEE Transactions on Systems, Man and Cybernetics, 26(10), 1996, pp.791-797.
- [10] Jean-Jacques E. Slotine, Weiping Li, applied nonlinear control, Prentice-hall, Inc., London, 1991, pp. 278-282.
- [11] George K. I. Mann, Bao-Gang Hu, and Raymond G. Gosine, Two-level tuning of fuzzy PID controllers, IEEE transactions on systems, man, and cybernetics-part B: cybernetics, Vol. 31, No. 2001, pp. 263-269.
- [12] K. M. Hangos, J. Bokor, and G. Szederkényi, Analysis and control of nonlinear process control systems, Advanced Textbooks in Control and Signal Processing, 1st Edition, Ch. 4, Springer-Verlag London limited, 2004, pp. 55-61.