

University of Wollongong

Research Online

Faculty of Engineering and Information
Sciences - Papers: Part A

Faculty of Engineering and Information
Sciences

1-1-2014

A review on the occurrence of micropollutants in the aquatic environment and their fate and removal during wastewater treatment

Yunlong Luo

University of Technology Sydney

Wenshan Guo

University of Technology Sydney

Huu Hao Ngo

University of Technology Sydney

Long Duc Nghiem

University of Wollongong, longn@uow.edu.au

Faisal Ibney Hai

University of Wollongong, faisal@uow.edu.au

See next page for additional authors

Follow this and additional works at: <https://ro.uow.edu.au/eispapers>



Part of the [Engineering Commons](#), and the [Science and Technology Studies Commons](#)

Recommended Citation

Luo, Yunlong; Guo, Wenshan; Ngo, Huu Hao; Nghiem, Long Duc; Hai, Faisal Ibney; Zhang, Jian; Liang, Shuang; and Wang, Xiaochang C., "A review on the occurrence of micropollutants in the aquatic environment and their fate and removal during wastewater treatment" (2014). *Faculty of Engineering and Information Sciences - Papers: Part A*. 1852.

<https://ro.uow.edu.au/eispapers/1852>

Research Online is the open access institutional repository for the University of Wollongong. For further information contact the UOW Library: research-pubs@uow.edu.au

A review on the occurrence of micropollutants in the aquatic environment and their fate and removal during wastewater treatment

Abstract

Micropollutants are emerging as a new challenge to the scientific community. This review provides a summary of the recent occurrence of micropollutants in the aquatic environment including sewage, surface water, groundwater and drinking water. The discharge of treated effluent from WWTPs is a major pathway for the introduction of micropollutants to surface water. WWTPs act as primary barriers against the spread of micropollutants. WWTP removal efficiency of the selected micropollutants in 14 countries/regions depicts compound-specific variation in removal, ranging from 12.5 to 100%. Advanced treatment processes, such as activated carbon adsorption, advanced oxidation processes, nanofiltration, reverse osmosis, and membrane bioreactors can achieve higher and more consistent micropollutant removal. However, regardless of what technology is employed, the removal of micropollutants depends on physico-chemical properties of micropollutants and treatment conditions. The evaluation of micropollutant removal from municipal wastewater should cover a series of aspects from sources to end uses. After the release of micropollutants, a better understanding and modeling of their fate in surface water is essential for effectively predicting their impacts on the receiving environment.

Keywords

their, removal, treatment, review, fate, occurrence, environment, aquatic, micropollutants, during, wastewater

Disciplines

Engineering | Science and Technology Studies

Publication Details

Luo, Y., Guo, W., Ngo, H. Hao., Nghiem, L. Duc., Hai, F. Ibney., Zhang, J. & Liang, S. (2014). A review on the occurrence of micropollutants in the aquatic environment and their fate and removal during wastewater treatment. *Science of the Total Environment*, 473-474 (March), 619-641.

Authors

Yunlong Luo, Wenshan Guo, Huu Hao Ngo, Long Duc Nghiem, Faisal Ibney Hai, Jian Zhang, Shuang Liang, and Xiaochang C. Wang

A review on the occurrence of micropollutants in the aquatic environment and their fate and removal during wastewater treatment

Yunlong Luo¹, Wenshan Guo^{1*}, Huu Hao Ngo^{1*}, Long Duc Nghiem², Faisal Ibney Hai², Jian

Zhang³, Shuang Liang³

¹*Centre for Technology in Water and Wastewater, School of Civil and Environmental Engineering, University of Technology Sydney, Sydney, NSW 2007, Australia*

²*Strategic Water Infrastructure Laboratory, School of Civil Mining and Environmental Engineering, University of Wollongong, Wollongong, NSW 2522, Australia*

³*Shandong Key Laboratory of Water Pollution Control and Resource Reuse, School of Environmental Science and Engineering, Shandong University, Jinan 250100, China*

Abstract

Micropollutants are emerging as a new challenge to the scientific community. This review provides a summary of the recent occurrence of micropollutants in the aquatic environment including sewage, surface water, groundwater and drinking water. The discharge of treated effluent from WWTPs has been a major pathway for the introduction of micropollutants to surface water. WWTPs act as primary barriers against the spread of micropollutants. WWTP removal efficiency of the selected micropollutants in 14 countries/regions depicts compound-specific variation in removal, ranging from 12.5 to 100%. Biodegradation is a significant removal pathway for some pharmaceuticals and steroid hormones but of minor importance for antibiotics and pesticides. Sorption serves as the main removal mechanism for industrial chemicals and musks. Advanced treatment processes, such as activated carbon adsorption, advanced oxidation processes, reverse osmosis, and membrane bioreactors can achieve higher and more consistent micropollutants removal. However, no matter what technology is employed, the removal of micropollutants depends on physico-chemical properties of micropollutants and the treatment conditions. Additionally, a better monitoring of micropollutants in surface waters is essential for effectively predicting micropollutants' impacts on the receiving environment.

Keywords: Micropollutants, Occurrence, Fate, Removal, WWTP, Advanced treatment.

Abbreviations and symbols: AOP: advanced oxidation process; ASFBFR: aerated submerged fixed bed bioreactor; BAC: biological activated carbon; CAS: conventional activate sludge; DBP: di-butyl phthalate; DEET: N,N-Diethyl-meta-toluamide; DEHP: di-(2-ethylhexyl) phthalate; DMP: di-methyl phthalate; DOM: dissolved organic matters; EDCs: endocrine disrupting compounds; GAC: granule activated carbon; HRT: hydraulic retention time; K_d : solid-water distribution coefficient; k_H : Henry's law constant; K_{ow} : octanol-water partition coefficient; MBR: membrane bioreactor; MBBR: moving bed biofilm reactor; MF: microfiltration; NF: nanofiltration; NSAID: nonsteroidal anti-inflammatory drugs; PAC: powdered activated carbon. PCP: personal care product; pK_a : acid dissociation constant; PNEC: predicted no effect concentrations; PPCP: pharmaceutical and personal care product; RO: reverse osmosis; SBBGR: sequencing batch biofilter granular reactor; SRT: sludge retention time; TCEP: tris(2-chloroethyl)phosphate; TCPP: tris(1-chloro-2-propyl) phosphate; UF: ultrafiltration; WWTP: wastewater treatment plant.

* Correspondence authors:

Email: wguo@uts.edu.au, Tel: +61 (2) 95142739, Fax: + 61(2) 95142633 (Wenshan Guo)

Email: h.ngo@uts.edu.au, Tel: +61 (2) 95142745, Fax: + 61(2) 95142633 (Huu Hao Ngo)

1. Introduction

Over the last few decades, the occurrence of micropollutants in the aquatic environment has become a worldwide issue of increasing environmental concern. Micropollutants, also termed as emerging contaminants, consist of a vast and expanding array of anthropogenic as well as natural substances. These include pharmaceuticals, personal care products, steroid hormones, industrial chemicals, pesticides and many other emerging compounds. Micropollutants are commonly present in waters at trace concentrations, ranging from a few ng/L to several µg/L. The ‘low concentration’ and diversity of micropollutants not only perplexes the associated detection and analysis procedures but also creates challenges for water and wastewater treatment processes.

Current wastewater treatment plants (WWTPs) are not specifically designed to eliminate micropollutants. Thus, many of these micropollutants are able to pass through wastewater treatment processes by virtue of their persistency or/and the continuous introduction. In addition, precautions and monitoring actions for micropollutants have not been well established in most WWTPs (Bolong et al., 2009). Consequently, many of these compounds may end up in the aquatic environment, becoming threats to wildlife and spelling trouble for drinking water industry. The occurrence of micropollutants in the aquatic environment have been frequently associated with a number of negative effects, including short-term and long-term toxicity, endocrine disrupting effects and antibiotic resistance of microorganisms (Fent et al., 2006; Pruden et al., 2006). To date, discharge guidelines and standards do not exist for most micropollutants. To set regulatory limits for micropollutants, further research on

biological responses to these compounds (both short-term and long-term effects) is of particular importance. Furthermore, the scientific and regulatory communities should give insight into not only the impact of individual micropollutant, but also their synergistic and antagonistic effects (Bhandari, 2009).

Several review papers have been published with regard to the occurrence of micropollutants in different water bodies such as wastewater (Deblonde et al., 2011) and groundwater (Lapworth et al., 2012), as well as treatment methods for micropollutant removal (Bolong et al., 2009). In addition, Verlicchi et al. (2012) reviewed the pharmaceutical removal efficiency in conventional activated sludge systems and in MBR fed by municipal wastewater, while Ze-hua Liu et al. (2009) focused on the physical, chemical and biological removal of endocrine disrupting compounds (EDCs). However, no attempt has been made to provide a comprehensive summary of the occurrence of miscellaneous micropollutants in aquatic systems as well as the removal of micropollutants in conventional and advanced treatment processes. In this review, we systematically summarized the recent occurrence of various micropollutants in the aquatic environment and delineated the behaviour and removal of micropollutants during conventional as well as advanced wastewater treatment processes.

2. Occurrence of micropollutants in the aquatic environment

Sources of micropollutants in the environment are diverse and many of these originate from mass-produced materials and commodities. Table 1 summarizes the source categories of some major micropollutants in aquatic ecosystem. Figure 1 illustrates the possible routes for the introduction of micropollutants into the environment.

Table 1

Fig. 1.

The recent occurrence (2008 to date) of the micropollutants in the aquatic environment has been reviewed in terms of their aqueous concentrations in different types of waters, including wastewater, surface waters, groundwater and drinking water. Of all aqueous media, WWTP influent and effluent are comprehensively reviewed. The collected data consist of the studies performed in a number of countries/regions, including Austria, China, EU-wide, France, Germany, Greece, Italy, Korea, Spain, Sweden, Switzerland, Western Balkan Region, UK and US. In general, micropollutants can be divided into six categories namely pharmaceuticals, personal care products (PPCPs), steroid hormones, surfactants, industrial chemicals and pesticides.

2.1 Occurrence of micropollutants in WWTPs

Occurrence data of micropollutants in WWTP influent and effluent from recent studies (2008–present) are summarized in Table 2. As can be noted from the table, the reported concentrations of micropollutants in WWTP influent and effluent reveal significant spatial and temporal variations, which are essentially due to a number of factors, including the rate of production, specific sales and practices, metabolism (excretion rate), water consumption per person and per day, the size of WWTPs, environmental persistence and elimination efficacy of wastewater treatment processes (Petrovic et al., 2009; Jelic et al, 2012).

Table 2

The local production and usage/consumption of products containing micropollutants determine the amount of micropollutants reaching WWTPs. Studies suggested that PPCP concentrations in wastewater correlated well with their production amounts and usage/consumption patterns. Choi et al. (2008a) reported that the occurrence concentrations of acetaminophen, carbamazepine, cimetidine, diltiazem, sulfamethoxazole and trimethoprim followed the same order (from highest to lowest) of their annual production amount in Korea.

High concentrations ($>10 \mu\text{g/L}$) of paracetamol, tramadol, codeine, gabapentin and atenolol were detected at highest levels in raw wastewater in Wales, UK and this could be explained by the high quantities of these pharmaceuticals dispensed (Kasprzyk-Hordern et al., 2009). As orally ingested products containing potential contaminants (e.g. pharmaceuticals) are metabolized in human body and are subsequently excreted via urine and feces, excretion rate plays a role in determining the introduction of pharmaceuticals into raw wastewater. Table 3 presents the excretion rates for some commonly encountered pharmaceuticals. It can be noted that pharmaceutical compounds with low excretion rates (e.g., ibuprofen, carbamazepine, sulfamethoxazole, diclofenac and primidione) are not necessarily present at low levels in the raw wastewater. This is possibly because the low excretion rates are offset by the massive use of these compounds. In addition, local common diseases can induce a higher consumption of specific pharmaceuticals in certain periods. Research showed climatic conditions could cause fluctuating micropollutant input (Kolpin et al., 2004). For instance, the use of pesticides can be seasonal due to the prevalence of pests in different climatic conditions. Another important factor is rainfall, as it affects the flow pattern of wastewater influent when a combined sewer system is employed. Kasprzyk-Hordern et al. (2009) found that the concentrations of most PPCPs in the raw wastewater were doubled when the flow was halved during dry weather conditions, suggesting that rainwater could dilute the concentration of the compounds within the sewage. Other weather conditions, such as temperature and level of sunlight also can affect the discharge of micropollutants from WWTPs.

Table 3

Occurrence levels of some of the most studied compounds in WWTP influent and effluent are presented in Fig. 2. As can be seen in Fig. 2, most micropollutants occurred in WWTP influent in the concentration range from 0.1 to $10 \mu\text{g/L}$, while some pharmaceutical compounds (acetaminophen, caffeine, ibuprofen, naproxen and salicylic acid), a biocide

(triclosan), one surfactant (Nonylphenol) and one industrial chemicals (DEHP) exhibit relatively higher occurrence concentration. Generally, the compounds with the highest concentrations (mean values $> 10 \mu\text{g/L}$) in WWTP influent were ibuprofen, atenolol, caffeine and nonylphenol. For instance, ibuprofen was the most abundant compound detected in the influent of four WWTPs in Spain, with the concentration levels ranging from 3.73 to 603 $\mu\text{g/L}$ (Santos et al., 2009). The particularly high levels could be explained by the high consumption and easy accessibility (over the counter drugs) of the compound (Camacho-Muñoz et al., 2010). Caffeine was detected at the highest levels approaching 50 $\mu\text{g/L}$ on average in raw sewage in three WWTPs in China (Zhou et al., 2010). The abundant presence of caffeine is likely associated with the high consumption of coffee, tea and soft drinks as well as the disposal of these items. Steroid hormones and pesticides generally exhibit lower detected concentrations (mostly less than 1 $\mu\text{g/L}$) as compared with compounds from other groups. The concentrations of most micropollutants in effluent ranged from 0.001 to 1 $\mu\text{g/L}$, which were one to two orders of magnitude lower than those in influent. Some abundant compounds in influent were discharged at relatively high concentrations. For instance, atenolol, caffeine, DEHP, ibuprofen, naproxen, nonylphenol and triclosan were detected in the concentrations higher than 1 $\mu\text{g/L}$ in treated effluent. In contrast, steroid hormones were found in wastewater at much lower levels ($<100 \text{ ng/L}$). However, their occurrence even at low concentrations is a concern because of their high estrogenic effect.

Fig. 2.

2.2 Occurrence of micropollutants in surface water

The release of WWTP effluent into surface water has been considered as a main cause of the presence of micropollutants in surface water in comparison to other sources (Kasprzyk-Hordern et al., 2009). Following treatment processes in WWTPs, micropollutants are

subjected to varying degrees of natural attenuation (e.g., dilution in surface water, sorption onto suspended solids and sediments, direct and indirect photolysis and aerobic biodegradation) (Pal et al., 2010). Due to river water dilution, pharmaceutical compounds may occur at levels at least one order of magnitude lower than effluent levels (Gros et al., 2007). Gómez et al. (2012) found that the natural attenuation of PCPs is more likely to result from river water dilution, or sorption to solids, than from degradation. Furthermore, river water dilution can be affected by rainfall. Consistent increase in micropollutant occurrence levels during dry weather conditions and marked reduction during wet weather conditions have been reported. Wang et al. (2011) indicated that pharmaceuticals in summer water samples showed lower occurrence levels than those in winter. This could be due to 1) promoted biodegradation of pharmaceuticals in warmer temperature, and 2) elevated dilution during wetter summer. However, rainfall did not always reduce the concentration levels of micropollutants released. In some cases, rainfall was identified as a contributor to the emission of micropollutants to surface water. Some studies revealed that the chemicals (e.g., bisphenol A and biocides) used in building material (e.g. pavement materials, facades and roof paintings) were able to leach during precipitation and accumulate to remarkable levels in roof runoff and subsequently ended up in surface water (Sakamoto et al., 2007; Jungnickel et al., 2008; Schoknecht et al., 2009; Singer et al., 2010). In addition, rainfall events could intensify combined sewer overflows, resulting in a higher level of contaminant discharge.

According to Table 4 showing common micropollutants in surface water from different countries, nonsteroidal anti-inflammatory drugs (NSAIDs), carbamazepine, sulfamethoxazole and triclosan were the most frequently reported compounds in surface water. The high concentrations of micropollutants were found in Costa Rica, which mainly resulted from the discharge of hospital effluents and other highly contaminated waters (Spongberg et al., 2011). Notably, ibuprofen, ketoprofen, gemfibrozil and caffeine were detected at alarmingly high

levels, with maximum concentrations of 36.8, 9.8, 17.0 and 1121.4 $\mu\text{g/L}$, respectively. Caffeine was also detected at relatively high concentrations in US (224.8 ng/L) and Taiwan (1813 ng/L). Unlike Costa Rica, the reported caffeine concentrations in US and Taiwan were far below the predicted no effect concentrations (PNECs). Hence, the pollution of emerging contaminants in the natural water bodies of the densely populated regions may be more severe because of the massive usage of these chemicals by the large population. For example, the concentrations of nonylphenol, bisphenol A and triclosan in the surface water of Guangzhou (one of the largest cities in China) were rather high, and nonylphenol was also found at relatively high concentrations in a Greek river, with a maximum of 2704 ng/L . It is noteworthy that the maximum nonylphenol concentrations in China and Greece were well above the reported PNEC for nonylphenol. Besides, population aging has also been linked to the high occurrence levels of pharmaceuticals (Al-Rifai et al., 2007).

Table 4

2.3 Occurrence of micropollutants in groundwater

In comparison to surface water, ground water was found to be less contaminated with micropollutants (Loos et al., 2010; Vulliet and Cren-Olivé, 2011). Hence, the presence of micropollutants in groundwater has been put far less emphasis on. Better characterization of micropollutants in groundwater has been only done regionally (mainly in some parts of Europe and North America). Micropollutant contamination of groundwater mainly results from landfill leachate, groundwater-surface water interaction, infiltration of contaminated water from agricultural land or seepage of septic tanks and sewer systems. Concentrations of micropollutants in landfill leachate and septic tank leakage generally range from 10 to 10^4 ng/L and 10 to 10^3 ng/L , respectively (Lapworth et al., 2012). Micropollutants can also be introduced in groundwater via bank filtration or artificial recharge using reclaimed water

(Stepien et al., 2013). Normally, the processes governing subsurface flow and transport (such as dilution, adsorption to aquifer material, degradation and travel time) can decrease micropollutants' concentrations from the sources (e.g., landfill leachate and septic tank leakage) to groundwater (Teijon et al., 2010). The physicochemical properties of micropollutants are therefore important for the transfer of the compounds to groundwater. For example, Octanol-Water partition coefficient K_{ow} indicates contaminant mobility in the subsurface, where the compounds (e.g. trimethoprim and TCEP) with $K_{ow} < 1.5$ tend to stay in the dissolved phase (more mobility) and are more likely to occur in groundwater (Dougherty et al., 2010; Karnjanapiboonwong et al., 2011). In a study conducted in US, Fram and Belitz (2011) found good correlation of pharmaceutical levels in groundwater and presence of modern water (water recharged since 1953), occurrence of other synthetic contaminants (urban-use herbicides and insecticides and volatile organic compounds) and land application.

For selected countries (Table 5), most of the compounds were detected at less than 100 ng/L in groundwater. NASIDs, carbamazepine, sulfamethoxazole, caffeine and triclosan were of particular research interest. These compounds were also the most commonly detected ones in surface water and wastewater, evidencing a correlation of the presence of micropollutants in different aquatic systems. By comparing the occurrence concentrations of micropollutants with PNEC, most of the compounds were at levels without potential environmental significance. However, considerably high concentrations (2 or 3 orders of magnitude higher than PNEC) of steroid hormones were found in groundwater at a US land application site (Karnjanapiboonwong et al., 2011). The problem probably resulted from the application of wastewater effluent to a portion of the soil. Although the authors did not point out the adverse effects of the high-level steroid hormones, their occurrence would be of potential concern if the groundwater was utilized for direct or indirect potable water reuse.

Table 5

2.4 Occurrence of micropollutants in drinking water

A small mass of is available with regard to the occurrence of micropollutants in drinking water (Vulliet et al., 2011). Some recent studies showed that most micropollutants in finished waters from drinking water treatment were below limit of quantitation or limit of detection (Benotti et al., 2008, Huerta-Fontela et al., 2011, Kleywegt et al. 2011, Wang et al., 2011). Therefore, only the data of the most abundant compounds have been presented in Figure 3. To date, there has been a lack of guidelines for risk assessment for the presence of most micropollutants in drinking water. PNEC values were plotted to superficially describe the potential of negative effects (Figure 3). The occurrence levels of micropollutants in drinking water were dependent on water sources and seasons, with winter water samples showing higher concentrations in comparing to summer water samples. Furthermore, drinking water treatment plays a significant role in eliminating micropollutants from drinking water and has therefore been comprehensively examined (Stackelberg et al., 2004; Westerhoff et al., 2005).

As can be seen in Figure 3, the maximum occurrence concentrations of most micropollutants were reported to be below 100 ng/L, with the exception of carbamazepine and caffeine. Notably, carbamazepine was observed at a concentration exceeding 600 ng/L (a concentration more than 10 times higher than those of most other compounds) in the study conducted by Kleywegt et al. (2011). The high levels of carbamazepine could be explained by its high persistency. Even so, the occurrence level of carbamazepine was far below the PNEC (25000 ng/L). It is also noteworthy that nonylphenol showed a maximum concentration (100 ng/L) most close to PNEC (330 ng/L, less than 1 order of magnitude). Other compounds were all at safe levels, since the PNEC values were 2 to 5 orders of magnitude higher than the their maximum concentrations. Overall, based on the studies

reviewed here, these countries were all able to rule out the adverse impacts of selected micropollutants on drinking water. Nevertheless, since other compounds as well as transformation by-products, which can also pose adverse effects, were not monitored in these studies, the safety of the produced drinking water still needs to be under scrutiny.

Fig. 3.

3. The removal and fate of micropollutants in WWTPs

Municipal WWTPs are designed to control a wide range of substances, such as particulates, carbonaceous substances, nutrients and pathogens. While these substances can be efficiently and consistently removed, the removal of micropollutants is basically under no control. Hence, the evaluation of the fate and removal of micropollutants during wastewater treatment is imperative for the optimization of treatment processes, in order to prevent the release of these potentially harmful micropollutants.

3.1 The fate of micropollutants in WWTPs

Wastewater treatment plants generally employ a primary, a secondary and an optional tertiary treatment process. Tertiary treatment processes are commonly used to produce higher quality of discharged water for certain purposes (e.g. water reuse), which are always associated with high treatment cost. Thus, the requirement for tertiary treatment processes is generally based on public and environmental health objectives.

Primary treatment processes aims to remove suspended solids that enter WWTPs. Micropollutants are removed mainly by sorption on primary sludge, as distribution of a compound into organic (lipophilic) layer is a predominant way of sorption (Ternes et al., 2004). Fragrances (galaxolide and tonalide) were found to be well removed (40%) during primary treatment (aerated grit chamber followed by circular sedimentation tank) due to their

high partition coefficients between the solid and liquid phase (Carballa et al., 2004). Primary treatment (sedimentation tank) was also able to remove some EDCs moderately with removal efficiency ranging from 13% (nonylphenol monoethoxylate) to 43% (Bisphenol A) (Stasinakis et al., 2013). However, primary treatment using aerated grit chamber could cause significant increase of phenolic compounds, such as bisphenol A and nonylphenol, because the compounds originally attached to the grits could be peeled off due to air agitation in grit chamber (Nie et al., 2012). For pharmaceuticals and hormones, removal efficiency in primary treatment ranged up to only 28% (diclofenac and estriol), which suggested that adsorption of investigated compounds to sludge particles was rather limited (Behera et al., 2011). No considerable reduction was also reported for ibuprofen, naproxen, sulfamethoxazol and estrone (Carballa et al., 2004).

In secondary treatment, micropollutants are subjected to a range of processes, including dispersion, dilution, partition, biodegradation and abiotic transformation. The total removal during secondary treatment generally refers to the losses of a parent compound contributed by different mechanisms of chemical and physical transformation, biodegradation and sorption to solids (Jelic et al., 2011). Biodegradation/biotransformation and sorption are the two major removal mechanisms during biological treatment, while volatilisation occurs to a minor degree (Verlicchi et al., 2012).

During secondary treatment, micropollutants are biologically degraded to various degrees, resulting in mineralisation or incomplete degradation (production of by-products). Biodegradation of micropollutants can occur via different mechanisms: 1) single substrate growth of a small subset of specialist oligotrophic organisms, which is less common in WWTPs and more likely to occur in receiving water or sediment (Daughton and Ternes, 1999); 2) co-metabolism, in which micropollutants are decomposed by enzymes generated for other primary substrate degradation (e.g. ammonia monooxygenase (AMO)) and are not

used as carbon and energy source for microbial growth; and 3) mixed substrate growth, in which micropollutants are used as carbon and energy source and become mineralized (Vader et al., 2000). For pharmaceuticals, even if the compounds fall into the same therapeutic group, their biodegradability can show great variability. For example, Salgado et al. 2012 reported, among NSAIDs, diclofenac exhibited low (<25%) biodegradation, whereas ibuprofen and ketoprofen were biodegraded to a much higher extent (>75%). Antibiotics are generally not readily biodegradable (Verlicchi et al., 2012). Regarding polycyclic musk, Clara et al., (2011) indicated biological degradation serves as a minor removal pathway. 15% and 30% of galaxolide and tonalide were found to be eliminated via biological transformation (Salgado et al., 2012). In contrast, Suarez et al., (2010) reported much higher biodegradation of tonalide and galaxolide (>75%). As for steroid hormones, significant biodegradation (>75%) was observed for estrone and estradiol (Suarez et al., 2010). Bisphenol A and triclosan were also found to be susceptible to biodegradation (up to 85% and 81% respectively), while nonylphenol was biologically transformed to a lesser degree (up to 56%) in two WWTPs using activated sludge (Samaras et al., 2013). In the case of pesticide, Stasinakis et al. (2009) found almost 60% of diuron was biodegraded during a activated sludge process.

Sorption of micropollutants mainly occurs by (1) absorption, in which hydrophobic interactions occur between the aliphatic and aromatic groups of a compound and the lipophilic cell membrane of microorganisms as well as the fat fractions of sludge, and (2) adsorption, involving the electrostatic interactions of the positively charged groups with the negatively charged surfaces of the microorganisms and sludge (e.g. amino groups) (Ternes et al., 2004). Verlicchi et al. (2012) found that sorption onto solids is insignificant (<5% in most cases) for most pharmaceuticals. In a study, mefenamic acid showed about 30% sorption (Jelic et al., 2011). In contrast, it was the major removal mechanism for some compounds,

such as diclofenac, galaxolide, tonalide (Clara et al., 2011; Salgado et al., 2012). Nonylphenol (35% to 51%) and triclosan (11% to 41%) were detected to be moderately removed via sorption to solids, while some acidic compounds (e.g., ibuprofen) could not be sorbed because of the charge repulsion between solids and compounds (Samaras et al., 2013). The compounds that tend to be sorbed onto solids are expected to be better eliminated by activated sludge treatment than other low-cost secondary treatments (trickling filter beds, anaerobic lagoon and constructed wet lands) (Camacho-Muñoz et al., 2012). This can be due to the promoted biodegradation under forced aeration during the conventional treatments, together with the enhanced sorption by large amounts of sludge generated in conventional treatment systems.

In WWTPs, there are circumstances where the effluent concentrations of some micropollutants exceed their influent concentrations. This can be explained by the presence of some substances, e.g. human metabolites and/or transformation products in the influent, which can subsequently be transformed back to parent compounds during biological treatment (e.g. diclofenac, carbamazepine, erythromycin, and sulfamethoxazole) (Göbel et al., 2007; Kasprzyk-Hordern et al., 2009). In addition, some pharmaceuticals excreted with feces are probably partly enclosed in feces particles and released during biological treatment. The negative removal has also been ascribed to the daily concentration fluctuations during the sampling period, the analytical uncertainty, or desorption of molecules from sludge and suspended particulate matter (Clara et al., 2004; Köck-Schulmeyer et al., 2013).

3.1 Overall removals of micropollutants in conventional WWTPs

The term “overall removal” generally refers to all the losses of micropollutant parent compounds from aqueous phase. Figure 4 showing the WWTP removal efficiency of the most studied micropollutants in 14 countries/regions (data from Table 2) depicts compound-specific variation in removal (12.5 to 100%). Compounds even in the same usage class were

removed to fairly different degrees. For individual compounds, location-specific large elimination disparities were also displayed. For example, diclofenac was significantly removed (81.4%) in a Korean WWTP (Behera et al., 2011) while it showed minor reduction (5%) in a Spanish WWTP (Rosal et al., 2010). Generally, the removal difference among different compounds in WWTPs could be ascribed to a number of factors such as micropollutant properties and operational conditions.

The most investigated micropollutants in WWTPs were NSAIDs. Ibuprofen, naproxen and ketoprofen exhibited moderate to high removal with average removal efficiency of 91.4%, 75.5% and 51.7%, respectively. In particular, the eliminations of ibuprofen were relatively consistent and commonly higher than 70%. As opposed to other NSAIDs, diclofenac experienced fairly inefficient (average 35.8%) and variable removals. The selected antibiotics showed low (erythromycin, 30.2%) to moderate removal (sulfamethoxazole, 64.6%). Lipid regulators and β -blockers were also not efficiently eliminated (37.6%-73.3%) in WWTPs. Anticonvulsant carbamazepine seemed to be the most persistent pharmaceutical and was averagely reduced by only 32.7%. Among all the reviewed studies, the highest removal of carbamazepine was observed by Choi et al. (2008a), reaching 62.3%. As mentioned above, caffeine was the most abundant compounds present in municipal wastewater. WWTPs proved to be effective in eliminating caffeine with an average removal efficiency of 88.7%. In the case of PCPs, relatively high reductions were exhibited, ranging between 74.2% (DEET) and 87.5% (galaxolide). As for steroid hormones, relatively stable and high removal efficiency was observed, which ranged from 71.9-100%. Two surfactants, nonylphenol and octylphenol, showed removals of 77.5% and 84.2%, respectively. Contradictory results have been reported for the elimination of nonylphenol, ranging from 21.7% (Stasinakis et al., 2008) to 99.0% (Janex-Habibi et al., 2009). The concentrations of bisphenol A were commonly considerably lowered (82%) during wastewater treatment. Other

selected industrial chemicals also showed removal efficiencies exceeding 80%. Due to the fact that pesticides have been typically considered of agricultural rather than of urban origin, few studies have been performed at real plant scale and most of reported plants coincide in showing insufficient removal of pesticides (Köck-Schulmeyer et al., 2013). The selected pesticides, such as atrazine, fluconazole and tebuconazole, were particularly resistant in WWTPs.

It is difficult to draw a firm conclusion on the persistency of each compound, as many compounds showed significantly varied removals in different WWTP. However, a simple classification of these compounds is presented in Table 6.

Fig. 4.

Table 6

3.3 Factors governing the fate of micropollutants in WWTPs

The fate of micropollutants in WWTPs is under the control or influence of ‘internal factors’ and ‘external factors’. Internal factors are micropollutant-related, including the characteristics of micropollutants (e.g. hydrophobicity, biodegradability, and volatility). In general, polar and non-volatile compounds are more likely to escape wastewater treatment processes. External factors are WWTP-specific, which are linked to the treatment conditions of wastewater treatment processes, the mixture of micropollutants that can act as competitors and nature of wastewater (pH and temperature).

3.3.1 Micropollutant-related factors

Sorption of a micropollutant to solids largely depends on the hydrophobicity of the compound. The octanol-water partition coefficient (K_{ow}) is frequently used to predict absorption of micropollutants on solids. Rogers (1996) provided a general rule of thumb for

applying K_{OW} to the estimation of sorption: $\log K_{ow} < 2.5$ indicates low sorption potential, $2.5 < \log K_{ow} < 4$ indicates medium sorption potential, and $\log K_{ow} > 4$ indicates high sorption potential.

Acidity determined by the functional group of a compound can play an important role in chemisorption or/and electrostatic adsorption of micropollutants. Schäfer et al. (2011) indicated that, at the pH above the acid dissociation constant (pK_a), the phenolic hydroxyl group of hormones dissociates and the compounds becomes negatively charged, facilitating the charge repulsion with the negatively charged membrane. Charge repulsion can also be expected to occur between negatively charged compounds and biomass in the activated sludge reactors, thereby impeding the removal of micropollutants.

In activated sludge processes, the solid-water distribution coefficient (K_d) is defined as the partition of a compound between the sludge and the water phase. Taking into consideration both K_{ow} and pK_a , K_d has been proposed as a relative accurate indicator of sorption behaviour (Ternes et al., 2004; Joss et al., 2005). For compounds having a K_d of below 300 L/kg ($\log K_d < 2.48$), the sorption onto secondary sludge can be considered to be insignificant. Additionally, Tadkaew et al. (2011) reported that the studied micropollutants with $\log K_d > 3.2$ (e.g. estrone and nonylphenol) were easily removed (>85%).

As biodegradability of micropollutants depends on their bioavailability, the first phase of the biodegradation process is the uptake of micropollutants by cell, leading to by chance affinity of the compound with the bacterial enzymes (Siegrist et al., 2005). Compound structure also plays an important role in determining resistance of a micropollutant to biodegradation. The biodegradability of a compound intrinsically relies on the complexity of the compound (e.g. monocyclic or polycyclic) and its functional groups (e.g. halogen groups). In general, the easily degraded substances include 1) linear compounds with short side chains, 2) unsaturated aliphatic compounds, and 3) compounds possessing electron donating

functional groups. On the other hand, the persistent micropollutants contain 1) compounds with long, highly branched side chains, 2) saturated or polycyclic compounds, and 3) compounds possessing sulphate, halogen or electron withdrawing functional groups (Jones et al., 2005; Tadkaew et al., 2011). Nevertheless, for some pharmaceutical compounds, there is no obvious relationship among chemical structure, functional groups and the removal. For example, two structurally similar compounds such as ibuprofen and ketoprofen could show different removals, with ibuprofen being eliminated more efficiently (Camacho-Muñoz et al., 2012).

Henry's law constant (k_H) is commonly used to characterize the volatility of a compound. The k_H ranging from 10^{-2} to 10^{-3} mol/(m³·Pa) commonly indicates high tendency of volatilization (Stenstrom et al., 1989). According to Suárez et al. (2008), volatilization of micropollutants is totally negligible for pharmaceuticals and estrogens, nearly negligible for fragrance compounds tonalide and galaxolide and very significant for celestolide. Volatilisation was found to account for up to 16% of celestolide of the compound (Suárez et al., 2010). Furthermore, in activated sludge processes, the volatilization behaviour can be intensified due to the additional air supply.

3.3.2 WWTP-specific factors

Sludge retention time (SRT) controls the size and diversity of a microbial community. Enhanced elimination of micropollutants can be achieved if the treatment processes have extended SRTs, which facilitate the buildup of slowly growing bacteria, such as nitrifying bacteria. In nitrifying conditions, co-metabolism using ammonium monooxygenase enzyme is a possible degradation pathway for micropollutants. Nitrifying biomass have been found to have positive effects on the removal of a range of micropollutants such as ibuprofen, naproxen, fluoxetine, trimethoprim, roxithromycin, erythromycin, galaxolide, tonalide,

ethinylestradiol, bisphenol A and nonylphenol. (Suárez et al., 2010; Fernandez-Fontaina et al., 2012).

Clara et al. (2005) suggested that the SRTs allowing nitrogen removal (nitrification and denitrification) above 10 days can enhance the elimination of some biodegradable compounds (e.g. ibuprofen, bezafibrat, natural estrogens and bisphenol A). In a study, the activated sludge treatment with an elevated SRT of 18 days could achieve considerably higher removal of beta blockers and psycho-activate drugs in comparison with the same treatment with shorter SRT of 0.5 days (Wick et al., 2009). Suárez et al., (2010) identified 10% higher of removal efficiency for fluoxetine, citalopram and ethinylestradiol when prolonged SRT was applied. Enhanced biodegradation was found for 4-n-nonylphenol and triclosan at SRT of 20 days (compared with 3 days and 10 days) (Stasinakis et al., 2010). However, high SRT does not necessarily mean better removal performance. Joss et al. (2005) suggested that variation of the sludge age between 10 and 60-80 days showed no noticeable effects on removal efficiency of the investigated pharmaceuticals. High SRT (20 days) also seemed not to appreciably affect the biodegradation of bisphenol A (Stasinakis et al., 2010). Santos et al. (2009) indicated that application of low SRTs (1.5-5.1 days) had minor effects on the removal of some pharmaceutical compounds (e.g., ibuprofen, diclofenac, naproxen, and carbamazepine).

Hydraulic retention time (HRT) is the amount of time that allows for biodegradation and sorption. The micropollutants having slow/intermediate kinetics such as fluoxetine or some biotics will experience less effective biodegradation at shorter HRTs or increasing loading rates (Fernandez-Fontaina et al., 2012)., Huang et al. (2008) indicated HRT in the range from 5 to 14 h achieved minor removal of DEHP, while higher HRT increased DEHP accumulation in the system and DEHP retention in the waste sludge.

Redox conditions may cause the observed differences by having an effect on certain wastewater or sludge characteristics as well as on the biodiversity of the microbial flora present (Göbel et al., 2007). Qiang et al. (2013) indicated unfavourable redox conditions (anaerobic conditions) could result in inefficient biodegradation of some micropollutants. In another study, naproxen, ethinylestradiol, roxithromycin and erythromycin were found only considerably eliminated under aerobic condition and anoxic removal was much less effective (Suárez et al., 2010). Zwiener and Frimmel (2003) compared short-term biodegradation of clofibric acid, ibuprofen, and diclofenac in oxic and anoxic (denitrification conditions, absence of oxygen while presence of nitrate) biofilm reactor. In oxic biofilm reactor, clofibric acid and diclofenac were not eliminated, with only 1-4% loss of their initial concentration being observed. Ibuprofen was reduced by 64–70%. By contrast, anoxic achieved much lower removal of ibuprofen (17-21%) and higher removal of diclofenac (34%-38%) and clofibric acid (26-30%). Goel et al. (2003) reported removal of the nonylphenol ethoxylate surfactant was higher in the oxic reactors (50 to 70%) compared to the anoxic reactors (30 to 50%). Similarly, di-(2-ethylhexyl) phthalate were removed by 15%, 19% and 62% in anaerobic, anoxic and aerobic reactors (Huang et al., 2008). Anoxic redox conditions were not necessarily less favourable environments for micropollutant removal. For instance, anoxic conditions could lead to improved elimination of iodinated X-ray contrast media, while aerobic environments witnessed minor removal (Drewes et al., 2001). Some persistent substances, diclofenac, sulfamethoxazole, trimethoprim and carbamazepine showed minor removals (<25%) by either biological treatment with neither nitrifying (oxic) or denitrifying bacteria (anoxic) (Suárez et al., 2010).

Wastewater characteristics, such as pH and temperature, may have effects on micropollutant removal. The acidity or alkalinity of an aqueous environment can vary the elimination of micropollutants from wastewater by influencing both the physiology of

microorganisms (pH optima of microbial enzyme activities) and the solubility of micropollutants present in wastewater (Cirja et al., 2007). Kimura et al. (2010) found that modest pH variation had significant effects on the removal of acidic pharmaceuticals (clofibric acid, ibuprofen, ketoprofen, naproxen and mefenamic acid) by the biosolids, which was presumably ascribed to activation of enzymes involved or enhancement of affinity between the biosolids and pharmaceuticals due to protonation of acidic pharmaceuticals. Seasonal variation of temperature may have impact on micropollutant removal in WWTPs. Temperature variation can affect biodegradation and partition (sorption and volatilization) of micropollutants. To eliminate the seasonal effect, alteration of operation parameters can be taken into consideration. For example, a possible strategy to improve EDCs removal in the cold temperature is to increase the mixed liquor suspended solids concentration by raising the SRT (Nie et al., 2012). Generally, enhanced micropollutant removal can be achieved at warmer temperature due to promoted microbial activities (Nie et al., 2012; Qiang et al., 2013). Yet, Hai et al. (2011) found that operation at high temperature levels (45 °C) could lead to lower micropollutant removal. Some other studies showed micropollutant elimination was independent of temperature fluctuation (Suárez et al., 2010).

4. Overview of treatment alternatives for micropollutant removal

No specific treatment is now available to assure the complete removal of various micropollutants due to their diverse properties. Reliable processes that are able to eliminate both bulk substances as well as micropollutants are yet to be developed. An overview of the current treatment options is present in the following sections to reveal the performance of each technique for micropollutant removal and to identify the need for improvement.

4.1 Coagulation-flocculation

Coagulation-flocculation is used for removing particulate matter, colloids as well as some dissolved substances. Table 7 presents some recent literature data regarding the removal of the most studied micropollutants from wastewater by coagulation–flocculation processes. In general, coagulation-flocculation processes yield ineffective elimination of most micropollutants. Matamoros and Salvadó (2013) evaluated the micropollutant removal in a coagulation/flocculation – lamellar clarifier for treating secondary effluent. The removals ranged from imperceptible elimination to 50%, among which the relatively high removals (20-50%) were observed for the compounds with $K_{OW} > 4$ at pH = 7-8 (e.g. galaxolide, tonalide, and octylphenol). Suárez et al. (2009) reported significant reduction (around 80%) of musks (e.g. galaxolide and tonalide) during coagulation-flocculation treatment of hospital wastewater. The other compounds that showed identifiable elimination were diclofenac (max. 46%), naproxen (max. 42%) and ibuprofen (max. 23%). Since landfill leachate has been considered as an important source of some EDCs, Asakura and Matsuto (2009) pointed out that coagulation and sedimentation was not able to remove biphenol A but achieved much higher removals for DEHP and nonylphenol (70% and 90% respectively) through leachate treatment processes.

Table 7

As a whole, most micropollutants, as shown above, have been reported to be poorly removed during coagulation-flocculation processes. Exceptions were some musks, a few pharmaceuticals (e.g. diclofenac) and nonylphenol due to their high K_{OW} (4-6). Besides, neither coagulant dose nor operation temperature influenced the removal of pesticides significantly (Thuy et al., 2008). Despite the minor differences among different types of coagulants at different doses, Suárez et al. (2009) reported that the addition of 25 mg/L $FeCl_3$

achieved optimal results in most cases. Huerta-Fontela et al. (2011) demonstrated that aluminium sulphate was effective in eliminating some hydrophobic pharmaceutical compounds. Composition of wastewater can exert either positive or negative effects on micropollutant removal during coagulation-flocculation treatment. For example, high fat content in water source was reported to improve the removal of hydrophobic compounds (Suárez et al., 2009). Dissolved humic acid could also enhance the elimination of some pharmaceutical compounds, such as diclofenac, ibuprofen and bezafibrate (Vieno et al., 2006). On the contrary, the presence of dissolved organic matters (DOM), especially low-molecular-weight fractions, can possibly inhibit the micropollutant removal due to the preferential removal of DOM through coagulation. Negatively charged DOM could react with positively charged aluminium hydrolysis species, leading to a less amount of coagulant available for elimination of the compounds (Choi et al., 2008b). In addition, the performance of coagulation-flocculation processes can be also governed by several operating conditions including mixing conditions, pH, alkalinity, temperature as well as the presence of divalent cations and concentrations of destabilizing anions (e.g. bicarbonate, chloride, and sulphate) (Alexander et al., 2012).

4.2 Activated carbon adsorption

Adsorption by activated carbons (ACs) is commonly employed for controlling taste and odor in drinking water. This technique also has great potential for treatment of secondary effluent and has proved to be more effective in removing micropollutants in comparison with coagulation-flocculation process (Choi et al., 2008b). Both powdered activated carbon (PAC) and granular activated carbon (GAC) have been widely used in adsorption processes (Table 8), which can be affected by the properties of both adsorbate (K_{OW} , Pk_a , molecular size, aromaticity versus aliphaticity, and presence of specific functional groups) and adsorbent

(surface area, pore size and texture, surface chemistry, and mineral matter content) (Kovalova et al., 2013).

Table 8

4.2.1 PAC

PAC has been considered as an effective adsorbent for treating persistent/non-biodegradable organic compounds. An advantage of employing PAC is that it can provide fresh carbon continuously or can be used seasonally or occasionally when risk of trace organics is present at a high level (Snyder et al., 2007). Kovalova et al. (2013) investigated elimination of micropollutants from a MBR-treated hospital effluent using PAC treatment at a retention time of two days. With PAC doses of 8, 23 and 43 mg/L and retention time of 2 days, the PAC reactor achieved efficient elimination for most of the micropollutants (pharmaceuticals, metabolites and industrial chemicals). The reduction of total load of selected pharmaceuticals and metabolites was around 86%. Batch tests performed by Hernández-Leal et al. (2011) also demonstrated marked removal (>94%) of various micropollutants (personal care products, bisphenol A and nonylphenol) during PAC treatment with initial compound concentrations of 100-1600 µg/L at a dose of 1.25 g/L and a contact time of five minutes.

PAC addition in activated sludge tank or post treatment configurations is a major application of PAC in the full-scale municipal WWTPs. A study was carried out to assess the efficiency of micropollutants (PPCPs) removal by addition of PAC in different flow schemes in municipal wastewater treatment (Boehler et al., 2012). It was found that counter-current use of PAC by recycling waste PAC from post-treatment tank to biological treatment tank could enhance micropollutant removal by 10 to 50% in comparison with the application without recycling. PAC addition in WWTPs was shown to be able to reduce micropollutant

levels by more than 80%. The PAC dosage for adequate treatment of secondary effluent with dissolved organic carbon (DOC) of 5–10 mg/L was 10–20 mg/L, while a higher amount (30–40 g/m³ influent) was required to achieve similar results if direct PAC addition was employed in biology tank.

The performance of PAC in eliminating micropollutants depends upon PAC dose and contact time, the molecular structure and behavior of the targeted compound, as well as the water/wastewater composition (Snyder et al., 2007; Boehler et al., 2012). Either higher dose or longer contact time can probably result in greater removal of micropollutants. Westerhoff et al. (2005) revealed micropollutant removal was improved with higher PAC dosages (20 mg/L) and independent of the initial compound concentrations. Water/wastewater composition also affects the adsorption of micropollutants. The sorption efficiency of PAC could be reduced as the DOC content increases (Boehler et al., 2012). Despite the influence of other contaminants in wastewater, the efficacy of applying PAC to wastewater for micropollutant removal is comparable with that of ozonation. Thus, PAC addition appears an attractive method for upgrading municipal WWTPs for improved micropollutant removal (Bolong et al., 2009).

4.2.2 GAC

Rossner et al. (2009) suggested that GAC dosage typically applied to taste and odour control in drinking water (<10mg/L) was sufficient to provide a 2-log removal for most of various compounds in a lake water. Hernández-Leal et al. (2011) evaluated the effectiveness of GAC in treating two wastewaters: (1) spiked (0.1-10 µg/L) aerobic effluent in a GAC column operated at low flow and (2) aerobic effluent with real concentrations (40 ng/L to 7.9 µg/L) of micropollutants in a GAC column. In the first case, removals for all the compounds were generally high (>67%), particularly for ethyl-, propyl- and butylparaben,

triclosan, caffeine, BP3, PBSA and 4MBC (>90%). In the second case, most compounds were also effectively eliminated. Specifically, the removal efficiency ranged from 50% (tonalide and nonylphenol) to more than 90% (galaxolide and PBSA).

A full-scale granular activated carbon plant treating a WWTP effluent was assessed in terms of the removal efficiency of steroidal estrogens and pharmaceuticals (Grover et al., 2011). Considerable removals of steroidal estrogens from sewage effluent were observed during the GAC tertiary treatment. By comparison, the reduction of pharmaceutical concentrations was more variable. For example, higher removals (84-99%) were observed for mebeverine, indomethacine, and diclofenac, while some compounds (e.g. carbamazepine and propranolol) displayed much less removals (17-23%). In spite of the efficient treatment of sewage effluent, GAC-based removal technology should be carefully operated, as the efficiency will decrease over time due to the saturation of adsorption site.

Similar to PAC, the contact time is a major factor that affects the degree of adsorption. Short contact time is likely to lead to significant lowered adsorption efficiency. As the elimination of the trace contaminants depends largely upon particle-contaminant interactions, the competition for adsorption sites and/or pore blocking (by particle solids) can reduce the removal efficiency of activated carbon (Bolong et al., 2009). Thus, GAC tends to perform poorly if wastewaters are highly contaminated. Snyder et al. (2007) suggested that a steam-treated GAC could be employed to overcome the drawbacks of GAC due to its greater absorption capacity. Regular regeneration of GAC also seemed of vital importance to maintain minimal breakthrough of micropollutants. Furthermore, pore shape/size and volumes of activated carbons, carbon type, surface charge of compounds and operation year were noted to have influence on the removal performances (Choi et al., 2008b; Rossner et al., 2009):

- Broader micropore size distribution of the GAC led to more efficient adsorption of compounds with different shapes and sizes;
- Pore volume was important to adsorption capacity rather than specific area; larger pore volume was commonly associated with greater removal efficiency.
- Negatively charged micropollutants were likely to be poorly adsorbed by the negatively charged carbon and well adsorbed by the positively charged carbon;
- Adsorption capacity reduced with operation year.

From the aforementioned studies, GAC and PAC appear attractive methods for micropollutant removal. In general, efficient removal is potentially achievable when the compounds have non-polar characteristics ($K_{ow} > 2$) as well as matching pore size/shape requirements (Rossner et al., 2009; Verlicchi et al., 2010b). However, activated carbon efficacy might be significantly lowered by presence of natural organic matter which competes for binding sites, thereby resulting in blocked pores. Besides, PAC dose, GAC regeneration as well as contact time play important roles in efficient removal of micropollutants.

4.3 Ozonation and advanced oxidation processes (AOPs)

Due to the refractory nature of some micropollutants, conventional physicochemical and biological treatments are not able to provide adequate elimination of these compounds. To overcome the problem, ozonation and AOPs can be considered. Performance of these processes in micropollutant removal is reported in Table 9. Ozonation and AOPs are efficient redox technologies which demonstrate some superiority over conventional treatments, such as high degradation rates and non-selectivity. Moreover, these processes have disinfecting effects, which are essential for reuse applications that involve direct human contact, e.g., household reuse applications (Hernández-Leal et al., 2011). Ozone can degrade contaminants

directly and indirectly (mainly via formation of stronger and less selective oxidising agent, $\bullet\text{OH}$). Some micropollutants are susceptible to both ozone and AOPs (e.g., naproxen and carbamazepine), whereas some are only subject to $\bullet\text{OH}$ (e.g. atrazine and meprobamate) and some are resistant to both forms of oxidation (e.g. TCEP and TCPP) (Gerrity et al., 2011). The generation of $\bullet\text{OH}$ can be promoted with the presence of H_2O_2 , Fenton reagent and ultraviolet.

Table 9

Hernández-Leal et al. (2011) examined the efficiency of ozonation for the removal of a wide range of micropollutants (UV-filter, fragrance, biocide and surfactant) from biologically treated grey water. In general, all the compounds were significantly removed (>79%) from the biologically treated effluent at an applied ozone dose of 15 mg/L. In another study, lower ozone dose of 5 mg/L also showed high removal efficiency for most of the targeted micropollutants (Sui et al., 2010). The concentrations of carbamazepine, diclofenac, indomethacin, sulpiride and trimethoprim were considerably reduced by more than 95%. The reductions of DEET and metoprolol were modest. By contrast, bezafibrate was very resistant to ozonation and was removed by only 14%.

A study conducted by Gerrity et al. (2011) focused on the application of $\text{O}_3/\text{H}_2\text{O}_2$ for removing a suite of micropollutants (PPCPs and steroid hormones) during water reclamation. The process showed considerable removal efficiency (>90%) for almost all of the target contaminants, except TCEP (13%), TCPP (26%), atrazine (69%), meprobamate (80%), and ibuprofen (83%). They indicated that micropollutants which exhibited the highest levels of oxidation were characterized by high ozone and $\bullet\text{OH}$ rate constants associated with their electron-rich moieties (e.g., phenols, anilines, olefins and activated aromatic). Although the formation of $\bullet\text{OH}$ was enhanced under alkaline conditions, Zhang et al. (2012) reported lower

pH was beneficial for EDCs removal by ozone when treating synthetic secondary effluent. This is because ozone was less reactive to the inorganic and organic matters (non-target compounds) in the synthetic secondary effluent as compared to •OH (generated at high pH) and a greater amount of O₃ could thereby be preserved for the reactions with target compounds. Furthermore, in spite of the fact that suspended sludge particles could lead to higher O₃ consumption, which might reduce the efficiency of ozonation for micropollutant removal, this effect was not significant and had only a minor impact on ozonation as well as oxidation by •OH at low O₃ dosages (Huber et al., 2005; Hernández-Leal et al., 2011).

Kim et al. (2009b) examined the effectiveness of UV (wave length: 254nm)-based processes (UV and UV/H₂O₂) for the elimination of 41 pharmaceutical compounds. UV alone could significantly remove (>90%) only a few compounds (e.g. ketoprofen, diclofenac and antipyrine) while ineffective removals (24%-34%) were observed for macrolides. By contrast, with the addition of H₂O₂ (7.8 mg/L), the process considerably improved its efficacy and removal efficiency increased up to 90% for 39 out of 41 compounds. Treatment of 32 selected micropollutants (pharmaceuticals, corrosion inhibitors and biocides/pesticides) in an effluent coming from a municipal activated sludge WWTP was also investigated using UV (wavelength: 254 nm), UV/H₂O₂, Fenton (Fe^{2+,3+}/H₂O₂) and photo-Fenton (Fe^{2+,3+}/H₂O₂/UV and Fe^{2+,3+}/H₂O₂/simulated sunlight) (De la Cruz et al., 2012). The process with only UV irradiation yielded a global degradation of 46% for the micropollutants after 10min. Four compounds (diclofenac, ketoprofen, memfenamic acid and diuron) were completely removed during the process. In contrast, the concentrations of gabapentin, trimethoprim, metformin, primidone, azithromycin and clarithromycin were unaltered or only slightly reduced (<10%). Comparing with UV treatment alone, UV and H₂O₂ (50 mg/L) exhibited elevated transformation (a total degradation of 81%) of the micropollutants. After 30 min of UV/H₂O₂, the transformation increased further up to 97%. Fenton process (5 mg/L Fe^{2+, 3+}/ 50 mg/L

H₂O₂) achieved 31% degradation. It was able to completely eliminate only one of the micropollutants, norfloxacin, after 30 min, and the concentrations of ten compounds were reduced by less than 15%. When UV was applied to the process (under the same conditions mentioned above), significantly increased global degradation (97%) was observed. For the photo-Fenton process, either increased H₂O₂ dosage or extended reaction time was found to have positive impact on the global degradation. Fenton/UV₂₅₄ (100% degradation after 90 min) displayed much higher degradation efficiency compared with Fenton/sunlight (47% degradation after 90 min). In addition, the presence of dissolved organic matter in the wastewater seemed to enhance the micropollutant removal during all the processes. In another study, Klammerth et al. (2010) reported much higher efficiency of photo-Fenton with solar light for treatment of 52 micropollutants (PPCPs and pesticides) in a WWTP effluent. The process was able to degraded 48 compounds below their limit of detection.

4.4 Membrane processes

Table 10 presents some recent research data concerning the effectiveness of membrane technology in eliminating micropollutants. The retention of micropollutants in membrane processes can generally achieved by size exclusion, adsorption onto membrane, and charge repulsion. These removal mechanisms are largely dependent on a number of factors, such as membrane process type, membrane characteristics, operating conditions, specific micropollutant characteristics and membrane fouling (Schäfer et al., 2011).

Table 10

Although Microfiltration (MF) and Ultrafiltration (UF) are proved processes to efficiently eliminate turbidity, micropollutants are generally poorly removed during UF and MF, as the membrane pore sizes are much larger than the molecular sizes of micropollutants.

However, micropollutants can be removed via adsorption on to membrane polymers, as well as interaction with natural organic matter (NOM) in wastewater. Jermann et al. (2009) examined the fate of ibuprofen and estradiol during an UF process and the effects of fouling by NOM. Without NOM, UF with hydrophilic membrane showed insignificant removal for ibuprofen and low (8%) removal for estradiol, while hydrophobic membrane retain much larger amount of estradiol (up to 80%) and ibuprofen (up to 25%). The higher retention of estradiol was due to the higher Carbon-Water Partitioning Coefficient (K_{oc}) value of the compound. As for the effect of NOM, NOM substances of high molecular weight such as alginate and Aldrich HA showed a greater effect than the lower molecular weight Nordic aquatic humic acid on enhancing micropollutant removal. Due to the low removal efficiency, MF or UF alone is not feasible for micropollutant removal. Hence, the combination of MF or UF with other processes (e.g. NF or RO) is essential for enhanced elimination of different micropollutants. Garcia et al. (2013) combined MF with RO to remove micropollutants for municipal wastewater reuse. MF was found to be able to reduce the concentrations of some compounds, such as bis-(2-ethylhexyl) phthalate, by more than 50%. With the incorporation of RO, the removal efficiency was significantly improved, ranging from 65% to 90% for most micropollutants (except ibuprofen and nonylphenol). Similarly, a tertiary MF/RO treatment process exhibited very efficient retention (>95%) of most of the studied PPCPs, except mefenamic acid and caffeine (Sui et al., 2010).

In comparison with MF and UF, nanaofiltration (NF) and reverse osmosis (RO) have much “tighter” structures. NF and RO are widely used in water reuse industry due to their high contaminant removal efficiency. However, NF and RO membranes are still somewhat permeable to some relatively small micropollutants (Steinle-Darling et al., 2010).

Röhricht et al. (2009) investigated two different types of submerged NF flat sheet modules for the removal of pharmaceuticals from WWTP effluent. Naproxen and diclofenac

(60%) were retained to a greater extent compared with carbamazepine (slight removal). At pH 7 and 8, naproxen and diclofenac (with pKa values of 4.2 and 4.15, respectively) were deprotonated, while carbamazepine (pKa=13.9) was not. Hence, naproxen and diclofenac could be rejected by the negatively charged membrane surface, whereas carbamazepine could not be removed. This was in accordance with the viewpoint indicated by Schäfer et al. (2003) and Nghiem et al. (2005): the speciation of pharmaceuticals may result in a significant change in rejection as a function of pH, with much greater retention occurring for ionized, negatively charged pharmaceuticals. For uncharged pharmaceuticals, intrinsic physicochemical properties of the pharmaceutical molecules play a role in their retention. Apart from electrostatic repulsion, adsorption can serve as the overriding removal mechanism in some cases. This was demonstrated in a study evaluating the removal of a variety of EDC/PPCPs using UF or NF (Yoon et al., 2006). For more polar compounds, the NF membrane (44–93% removals except naproxen of no rejection) was more efficient than the UF membrane with typical removals of less than 40% except a few compounds (triclosan, 87%; oxybenzone, 77%; progesterone, 56%). By contrast, for the less polar compounds, many permeate EDC/PPCP concentrations (14 out of the 25 compounds) were below detection, suggesting high removal efficiency by both NF and UF membranes except for a few compounds (α - and β -BHC, fluoranthene, hydrocodone, metolachlor, and musk ketone). Better performance was also observed for NF.

RO generally shows great potential to partially or significantly remove micropollutants. Sahar et al. (2011) applied RO after CAS-UF and MBR processes and assessed its efficiency in eliminating micropollutants. The two processes, CAS-UF/RO and MBR/RO, showed relatively similar and high elimination efficiencies: >99% for macrolides, pharmaceuticals, cholesterol and BPA, 95% for diclofenac, 97% for SMX, and >93% for both SMZ and TMP. Despite the highly effective RO treatment, 28-223 ng/L residuals of ibuprofen, diclofenac,

salicylic acid, cholesterol, and BPA were detected in the permeates from both units. This elucidated that RO was not an absolute barrier for micropollutants. Yangali-Quintanilla et al. (2011) compared the various micropollutants (pharmaceuticals, pesticides, endocrine disruptors and others) removal by NF and RO. The elimination efficiency of NF membranes was very close to that achieved by RO membranes. The average retention efficiency by tight NF was 82% for neutral contaminants and 97% for ionic contaminants, while RO was able to achieve 85% removal of neutral contaminants and 99% removal of ionic contaminants.

4.5 Membrane bioreactor

Membrane bioreactor (MBR) process combine activated sludge biological treatment and membrane filtration (MF and UF). MBRs possess the following advantages over conventional wastewater treatment in the following aspects (Ngo et al, 2012) such as high effluent quality, excellent microbial separation ability, absolute control of SRTs and HRTs, high biomass content and less sludge bulking problem, low-rate sludge production, small footprint and limited space requirement, and possibilities for a flexible and phased extension of existing wastewater treatment plants (WWTPs).

MBRs are able to effectively remove a wide spectrum of micropollutants including compounds that are resistant to activate sludge processes (Radjenovic et al., 2009). This is because 1) They are able to retain sludge to which many compounds are adhered; 2) The membrane surface can also intercept the compounds; 3) The longer SRT in MBRs may promote microbial degradation of the compounds (Spring et al., 2007). Table 11 summarizes some recent studies involving MBR processes. The removal of micropollutants in MBR can be affected by a number of factors, such as sludge age and concentration, existence of anoxic and anaerobic compartments, composition of the wastewater, operating temperatures, pH and conductivity (Kovalova et al., 2012).

Table 11

Trinh et al. (2012) investigated the micropollutant removal efficiency of a full-scale MBR. High elimination (>90%) was observed for most of the micropollutants. Nevertheless, some compounds were incompletely removed (24-68%), including amitriptyline, carbamazepine, diazepam, diclofenac, fluoxetine, gemfibrozil, omeprazole, sulphamethoxazole and trimethoprim. Hence, these compounds were considered as potential indicators for evaluating the micropollutant removal using MBR processes. Generally, hospitals are the major source of many pharmaceuticals released into the environment (Verlicchi et al., 2010a). A pilot-scale MBR was employed for on-site treatment of hospital effluent (Kovalova et al., 2012). In this study, they elucidated that the concentrations of investigated compounds in the hospital wastewater were considerably different from those in municipal wastewater. For instance, average 32 µg/L of the antibiotic ciprofloxacin and up to 2600 µg/L of iodinated X-ray contrast media were detected in the hospital wastewater, which was around 70-time higher than those observed in the municipal wastewater. In addition, higher concentrations of antibiotics and disinfectants due to large amounts of usage in hospitals could lead to bacterial inhibition during the on-site treatment. The overall recalculation of all pharmaceuticals and metabolites was only 22%, as a large fraction (80%) of the feed was persistent iodinated contrast media. However, if the iodinated contrast media were not taken into account, the reduction would be up to 90%. Full-scale MBR studies for hospital wastewater treatment were also investigated by Beiber et al. (2011), which suggested that separation of rainwater collection and water streams with low pharmaceutical concentrations, and maintenance of sludge age > 100 days should be considered in the design of MBR for hospital wastewater.

Both being cost effective technologies in wastewater treatment, MBR processes and conventional activated sludge (CAS) processes have been frequently compared in terms of their performance in micropollutant removal. Radjenovic et al. (2007) compared the removal of several pharmaceutical products in a laboratory scale MBR and a CAS process. Both systems were effective in removing some compounds (e.g., naproxen, ibuprofen, acetaminophen, hydrochlorothiazide, and paroxetine). However, the results presented that pharmaceuticals showed greater and steadier elimination during MBR process (>80% in most cases). Another comparative investigation of MBR and CAS process was performed by Chen et al. (2008). Similarly, MBR was slightly more efficient in micropollutant removal. The efficiency of elimination in the MBR appeared stable regardless of changes in sludge loading and HRT.

Biological treatment combined with membrane filtration (MF or UF) are also employed for treating wastewater. Sahar et al. (2011) compared the removals of several macrolide, sulphonamide and trimethoprim antibiotics from raw sewage using a full-scale CAS system coupled with a subsequent UF filtration (CAS-UF) and a pilot scale MBR. Antibiotics removal in the MBR system was generally higher than that in the CAS-UF system. The elimination of Trimethoprim, sulfamethoxazole and erythromycin was 99%, 70%, 61% in the MBR system, and 45%, 52% and 71% in the CAS-UF system, respectively. It was assumed that antibiotics removal in both systems was due either to sorption to biomass (rather than biological transformation) or to enmeshment in the membrane biofilm (as the pore size of UF is significantly larger than the antibiotic molecules).

Recently, membranes in conjunction with anaerobic reactors have been gaining popularity due to their intrinsic advantages over aerobic systems, such as low sludge production, net energy generation and a fully enclosed environment (Hu and Stuckey, 2006). The applications of anaerobic MBRs for micropollutant removal have been investigated in

some recent studies (Xu et al., 2008; Abargues et al., 2012). A pilot-scale submerged anaerobic MBR (SAnMBR), a conventional activated sludge (CAS) unit and a pilot-scale aerobic MBR were evaluated for removing some alkylphenols (APs) and hormones (Abargues et al., 2012). The observed concentrations of APs in the SAnMBR effluent were consistently at significantly higher levels than those in the permeates from other units, indicating the ineffective removal of APs by SAnMBR.

During MBR processes, several operational parameters (e.g. SRT, HRT and temperature) can influence the reduction of micropollutants. In general, MBRs have high SRTs, thus diverse microorganisms, including some slow growing bacterial, can reside in the reactors. When biomass is rich in nitrifying bacterial, higher biodegradation efficiency for certain micropollutants can be achieved (Roh et al., 2009). De Gusseme et al. (2009) reported a high elimination (99%) of 17 α -ethinylestradiol (at initial concentration of 83 ng/L¹) when a nitrifier enrichment culture was applied in a MBR. The degradation of micropollutants by nitrifying bacteria has also been evaluated in other types of systems (e.g., activated sludge and fixed bed reactor) (Batt et al., 2006; Forrez et al., 2009; Zhou and Oleszkiewicz, 2010). A general conclusion drawn from these studies is that nitrifying conditions have positive effects on micropollutant removal. Temperature variability has been linked to decrease in bulk water quality parameters and unreliability of system, as microbial growth and activity as well as solubility and other physicochemical properties of organics are significantly affected by temperature (Hai et al., 2011). Effects of temperature variation were explored in a lab-scale MBR treating wastewater containing selected micropollutants (Hai et al., 2011). Both hydrophobic compounds ($\log D > 3.2$) and less hydrophobic compounds ($\log D < 3.2$) showed reduced elimination at 45°C, which was ascribed to disrupted metabolic activity typically linked to such elevated temperature. The removal of hydrophobic compounds was

unaffected in the temperature range of 10–35°C, while a relatively more obvious variation was found in the removals of less hydrophobic compounds.

4.6 Attached growth treatment processes

Attached growth technology is a promising alternative to activate sludge processes for wastewater treatment which involves attached growth on inert carriers either fixed or mobilised in suspension of the reactor. The attached growth processes offer the following advantages over activated sludge processes in wastewater treatment (Guo et al., 2012):

- They have better oxygen transfer, high nitrification rate and higher biomass concentrations;
- They are more effective in organic removal, and can apply for high organic loading rates at relatively shorter HRT;
- They allow the development of microorganisms with relatively low specific growth rates (e.g., methanogens);
- They are less subject to variable or intermittent loadings;
- They are suitable for small reactor size, with space requirement being considerably lower than that for AS; and
- For fixed-bed biofilm processes such as trickling filters and rotating biological contactors (RBCs), the operational costs are lower than that for AS.

The attached growth systems can be grouped into two major groups: fixed bed bioreactors (e.g. biofiltration) and moving bed bioreactors. Table 12 presents the effectiveness of different attached growth processes in micropollutant removal.

Table 12

Biofiltration seems a compelling biological technique for micropollutant removal (Reungoat et al., 2011). Commonly used systems in water and wastewater treatment include trickling filter, sand filtration and biological activated carbon (BAC). A BAC filter is typically composed of a fixed bed of GAC serving as the carrier for bacterial adhesion and growth. Reungoat et al. (2011) evaluated and compared the performance of biofilters with two media, activated carbon and sand, during long-term operation. The results demonstrated that BAC had a great potential for PPCPs (e.g. diclofenac, carbamazepine, sulfamethoxazole and gemfibrozil) removal (> 90%) and reduction of the potential risk of environmental and/or human health impact. On the other hand, sand filters could only achieve limited elimination for PPCPs. Dissolved oxygen was the main factor affecting the performance of BAC filters, while empty-bed contact time (from 30 min to 120 min) did not result in considerable variation in the removals of compounds. In addition, long-term observation indicated that the main mechanism for organic matter and PPCP removal in biofiltration was biodegradation rather than adsorption. Another biofilter, namely sequencing batch biofilter granular reactor (SBBGR), was investigated by Balest et al. (2008) for removing several selected EDCs. The results showed that SBBGR achieved much higher removal efficiency for EDCs removal than the conventional activated sludge process in a municipal WWTP. The removal efficiencies for bisphenol A, estrone, estradiol and 4-tert-octylphenol were 91.8%, 62.2%, 68% and 77.9% for the demonstrative SBBGR system and 71.3%, 56.4% 36.3% and 64.6% for the conventional activated sludge process of the municipal WWTP, respectively. The excellent performance of the SBBGR was attributed to the very high sludge age (about 160 d). Due to the excellent performance, biofiltration was suggested as an efficient treatment method that could be employed in advanced treatment processes for reducing the impact of the effluent discharge into the environment and/or providing water of higher quality for reuse.

The biological removal of 17 α -ethinylestradiol in an aerated submerged fixed bed bioreactor was evaluated with or without ammonium starvation (Forrez et al., 2009). Excellent removal (96%) was obtained at a volumetric loading rate of 11 $\mu\text{g/Ld}$ of 17 α -ethinylestradiol, slightly lower elimination rates (81 and 74% respectively) was reported when increasing the loading rate up to 40 and 143 $\mu\text{g/Ld}$ of 17 α -ethinylestradiol. The authors suggested that implementation of retro-fitting treatment systems, either by employing a post-treatment reactor containing separately grown ammonia-oxidizing bacterial (AOB) or by continuously seeding the WWTP effluent with AOB grown in a dedicated reactor has great potential for the removal of some micropollutants (Forrez et al., 2009). In another study using a fixed film activated sludge (IFAS) to treat effluent estrogenic activities, Kim et al. (2009a) found the effluent estrogenic activities in the IFAS system were 70% lower than those in the control train (conventional activated sludge system), which suggested a high estrogen removal by IFAS.

Falås et al. (2012) conducted a set of batch experiments to evaluate the effectiveness of a hybrid moving bed biofilm – activated sludge process for the removal of various micropollutants. It was indicated that the presence of carriers could enhance the overall biological elimination of some compounds. For example, diclofenac, clofibric acid and mefenamic acid were not eliminated in the activated sludge reactors, while the carrier reactors showed more obvious and rapid removals (at least 60% after 24 h) of the three compounds. In another study, a moving bed biofilm system was investigated in terms of the removal efficiency for bisphenol A, oseltamivir and atrazine from wastewater using carriers made from existing bioplastic-based products (Accinelli et al., 2012). During the experiments with control wastewater samples, mineralization rates for bisphenol A, oseltamivir and atrazine were relatively low, accounting for only 18%, 7% and 3.5% of the initial concentrations, respectively. By contrast, the addition of incubated carriers enhanced the

removals of bisphenol A, oseltamivir and atrazine by 34%, 49% and 66%, respectively. Li et al. (2011) focused their study on simultaneous PAC adsorption within a MBR. During the treatment, PAC could not only act as an adsorbent but also provided support for biomass growth. With a high PAC dosage of 1.0 g/L, enhanced elimination of sulfamethoxazole and carbamazepine was observed in the PAC-amended MBR system (82% and 92% respectively) in comparison with the MBR system alone (both 64%).

As a whole, although attached growth systems have not been applied broadly and specifically to for micropollutant removal, the results from some recent bench-scale or pilot scale studies showed that attached growth treatment processes are promising methods for reducing discharges of micropollutants. By addition of packing/moving carriers, increased microbial community can be maintained in the system, which facilitates the growth of slow-growing microorganisms for micropollutant removal (Serrano et al., 2011). Therefore, micropollutant removal by attached growth processes is a strategy showing possibility of excellence and likely to draw more attention in the future research.

5. Assessment of micropollutant removal from municipal wastewater and recommendation for future research

Micropollutants have been frequently detected in wastewater as well as important drinking water sources, such as rivers, lakes and groundwater. The evaluation of micropollutants from municipal sewage should cover a series of issues from sources to end uses, including selection of micropollutants with high occurrence and ecotoxicological relevance, determination of possible sources, investigation on their occurrence and fate in WWTPs and receiving waters, and estimation of their (eco)-toxicological impacts on aquatic systems and humans.

The major types of wastewater media that convey micropollutants to aquatic systems via WWTPs consist of domestic wastewater, hospital effluents, industrial wastewater and stormwater runoff, rural runoff and manure. Intense efforts have been taken to investigate domestic wastewater, while less focus has been put on other types of wastewaters which may also have significant micropollutant loads. For example, hospitals are a considerable source of various pharmaceuticals, including compounds generated from diagnostic, laboratory and research activities as well as pharmaceutical excretion by patients (Verlicchi et al., 2010b). Industrial practices (e.g. production of various commodities) can probably lead to a remarkable discharge of micropollutants, especially EDCs, due to the use or/and formation of the compounds during the production processes. The assessment of the significance for different sources can be based on the compilation of literature data (Pal et al., 2010). Scale of consumption or production (e.g. annual per capita consumption) of commodities containing micropollutants can also be used as an indicator for micropollutants emission. Zhang et al. (2008) suggested that the worldwide annual per capita consumption of drugs is 15 g and developed countries contribute three to ten times higher (50-150 g).

Since WWTPs are not able to provide a complete barrier for micropollutant removal, establishing optimal removal strategies for micropollutants remains a challenge to environmental engineers in order to minimize their adverse effects on the environment. Conventional treatment processes have been reported to have inadequate removals of many micropollutants. Several potential options are available for improving the elimination of micropollutants, including source controls (e.g. application of micropollutant-free products, source separation, pretreatment of hospital and industrial effluents, etc.), reassessment and optimization of current treatment processes, and end-of-pipe upgrading of WWTPs. As mentioned above, the removal of highly persistent/non-biodegradable/polar micropollutants is commonly low and independent of operating parameters during biological treatment

processes, thereby exceeding the capacity of current treatment processes. Hence, tertiary (e.g. post ozonation, sand filtration, and membrane filtration) or combined treatment processes should be taken into consideration to ensure successful treatment of the variety of micropollutants. Table 13 compares the micropollutant removal efficiency of three types of WWTPs, namely low-cost, conventional and advanced WWTPs. Low-cost treatment processes, such as trickling filter beds, lagooning and constructed wetland, are normally used for decentralized wastewater treatment for small communities and in a few cases applied in centralized WWTPs for large communities. As can be seen in Table 13, WWTPs with low-cost treatment processes exhibit comparatively low efficiency, while WWTPs with tertiary treatments show more efficient and consistent removal of the compounds. Camacho-Muñoz et al. (2012) concluded that most of the pharmaceutical compounds they studied were slightly better removed in conventional treatment processes, which could be attributed to the better aeration condition that led to more effective aerobic degradation. Meanwhile, the lowest removal efficiency for some compounds (carbamazepine, propranolol and estriol) occurred in lagooning compared with other conventional treatments and could be ascribed to the low organic content of wastewater as well as the low amount of solids and poor aeration. Nevertheless, the differences between the mean removal rates in conventional (64%) and low-cost (55%) WWTPs were not significant. RO as a tertiary treatment showed 100% removal for COD and selected EDCs, but the elevated energy consumption is a consistent disadvantage (Balabanič et al., 2012). Salgado et al (2012) assessed a full-scale WWTP employing UV as the post-treatment for PPCP removal. They evaluated the relevance of each removal mechanism for the overall PPCP removal and indicated that the removal fractions from biodegradation, sorption and UV are 45%, 33% and 22% respectively. Although UV only accounted for 22% of the total removal, it was considered as an important effluent polishing process.

Table 13

Table 14 summarizes the advantages and disadvantages of different treatment techniques reviewed. The provided information is based on the recent literature and may be helpful to select suitable techniques for micropollutants treatment. However, the table only gives the qualitative assessment of these techniques. Comprehensive quantitative assessment is needed in future research to better compare different techniques from both economic and technical points of view.

Table 14

Understanding and predicting the fate of micropollutants in WWTPs is helpful in identifying the improvement potential for current treatment configurations. To date, enormous efforts by many researchers have been put into developing accurate and succinct models for micropollutants prediction. Precise models for micropollutant fate are not easy to establish. Modellers should take into account numerous aspects, including possible removal pathways and factors that affect the removal. Pomiès et al. (2013) reviewed different models from the perspective of removal pathways. Sorption and volatilisation can be characterized by partition coefficient K_d and Henry's law constant, both of which can be determined experimentally. Biodegradation modelling is a more complicated process due to the involvement of microorganisms. Two issues have been addressed for the biodegradation of micropollutants. First issue is the lack of conformity in determining biodegradation sites (only in aqueous phase, only in solid phase or in both phases). The other is the incorporation of parent compounds and by-products as well as co-metabolism in the models.

The discharge of micropollutants can contribute to water pollution due to their potentially ecotoxicological impacts on aquatic organisms. Furthermore, human exposure to micropollutants is also harmful and can occur via various routes. According to Figure 1, micropollutants can return to humans via drinking water. Other pathways back to humans include food chain and wastewater reuse for household purposes. Given their adverse effects, effective monitoring strategies and risk assessment should be considered as important components for micropollutants control. Nevertheless, monitoring programmes for micropollutants are far from universal and have only been carried out in sizable rivers, such as Rhine (Sacher et al., 2008) and Han River (Choi et al., 2008a), as those programs are time consuming and costly (Alder et al., 2010). Therefore, the establishment of estimation tools for the concentrations and mass flows of micropollutants in surface waters is of vital importance. Generally, the estimation should be based on the various sources, use/consumption of compounds and their fate in WWTPs as well as receiving waters. Coetsier et al. (2009) indicated predicted environmental concentrations (PECs) offers the possibility to predict pharmaceutical occurrence in surface water. Although the PEC values seemed to be able to properly estimate WWTP wastewater effluents, they are subjected to uncertainties because the differences between predicted and measured values can become significant when applied to local areas with consumption levels being considerably different from assumed average levels.

After discharged into surface waters, micropollutants experience various processes, including dilution and attenuation (biodegradation, sorption, volatilization and photolysis). A comprehensive understanding and modelling of micropollutants fate in surface waters is essential for effectively predicting micropollutants' impacts on the receiving environment. Although integrated urban water system (IUWS) modelling is usually used as a tool for evaluating the quality of the surface water receiving the municipal WWTP discharge

combining sewer overflows and stormwater drainage systems, many micropollutants tend to distribute to more than one environmental compartment (air, water, sediment, soil, groundwater, etc.). Hence, a multimedia fate and transport model (MFTM) was proposed by Keyser et al. (2010) to meaningfully characterize the attenuation and distribution of micropollutants.

6. Conclusion

Enormous research effort has been directed toward the assessment of occurrence of micropollutants in the aquatic environment. In particular cases, the occurrence levels of some micropollutants in surface waters were much higher than their PNECs, which revealed an environmental concern. WWTP effluent has been considered as the primary source of many micropollutants in aquatic systems. Given their diverse properties (e.g., hydrophobicity and biodegradability) and low concentrations, micropollutant removal in current WWTPs is commonly incomplete and variable, ranging from 18.8% to 91.1% for some frequently reported compounds. Hence, optimization of wastewater treatment, in order to create an absolute barrier to micropollutants emission, remains a task of high priority. Biological treatment is commonly unable to remove polar persistent micropollutants. However, its efficacy can be improved under favourable conditions (e.g., extended SRT and HRT, warm temperature, and fine tuning redox conditions). Although advanced treatment technologies, such as adsorption processes, AOPs and membrane processes, have been demonstrated to be promising alternatives for micropollutant removal, there are two issues associated with the applications of advanced treatments: high operation costs and formation of byproducts and concentrated residues. Moreover, to effectively predict the impact of micropollutants on the receiving environment, a comprehensive understanding and modelling of micropollutants fate is needed.

Reference

- Abargues MR, Robles A, Bouzas A, Seco A. Micropollutants removal in an anaerobic membrane bioreactor and in an aerobic conventional treatment plant. *Water Sci Technol* 2012;65:2242–50.
- Accinelli C, Saccà ML, Mencarelli M, Vicari A. Application of bioplastic moving bed biofilm carriers for the removal of synthetic pollutants from wastewater. *Bioresource Technol* 2012;120:180–6.
- Alder AC, Schaffner C, Majewsky M, Klasmeier J, Fenner K. Fate of b-blocker human pharmaceuticals in surface water: Comparison of measured and simulated concentrations in the Glatt Valley Watershed, Switzerland. *Water Res* 2010;44:936–48.
- Alexander JT, Hai FI, Al-aboud, TM. Chemical coagulation-based processes for trace organic contaminant removal: Current state and future potential. *J Environ Manage* 2012;111:195–207.
- Al-Rifai JH, Khabbaz H, Schäfer AI. Removal of pharmaceuticals and endocrine disrupting compounds in a water recycling process using reverse osmosis systems. *Sep Purif Technol* 2011;77:60–7.
- Al-Rifai JH, Gabelish CL, Schäfer AI. Occurrence of pharmaceutically active and non-steroidal estrogenic compounds in three different wastewater recycling schemes in Australia. *Chemosphere* 2007;69:803–15.
- Asakura H, Matsuto T. Experimental study of behavior of endocrine-disrupting chemicals in leachate treatment process and evaluation of removal efficiency. *Waste Manage* 2009;29:1852–9.
- Balabanič D, Hermosilla D, Merayo N, Klemenčič AK, Blanco Á. Comparison of different wastewater treatments for removal of selected endocrine-disruptors from paper mill wastewaters. *J Environ Sci Heal A* 2012;47:1350–63.
- Balest L, Mascolo G, Iaconi CD, Lopez A. Removal of endocrine disrupter compounds from municipal wastewater by an innovative biological technology. *Water Sci Technol* 2008;58:953–6.
- Barnabé S, Beauchesne I, Cooper D, Nicell J. Plasticizers and their degradation products in the process streams of a large urban physicochemical sewage treatment plant. *Water Res* 2008;42:153–62.
- Barnes, KK, Kolpin DW, Furlong ET, Zaugg SD, Meyer MT, Barber LB. A national reconnaissance of pharmaceuticals and other organic wastewater contaminants in the United States—I) Groundwater. *Sci Total Environ* 2008;402:192–200.
- Batt AL, Kim S, Aga DS. Enhanced biodegradation of iopromide and trimethoprim in nitrifying activated sludge. *Environ Sci Technol* 2006;40:7367–73.
- Behera SK, Kim HW, Oh J-E, Park H-S. Occurrence and removal of antibiotics, hormones and several other pharmaceuticals in wastewater treatment plants of the largest industrial city of Korea. *Sci Total Environ* 2011;409:4351–60.
- Beier S, Cramer C, Koster S, Mauer C, Palmowski L, Schroder H, Pinnekamp J. Full scale membrane bioreactor treatment of hospital wastewater as forerunner for hot-spot wastewater treatment solutions in high density urban areas. *Water Sci Technol* 2011; 63:66–71.

- Benotti MJ, Trenholm, RA, Vanderford, BJ, Holady JC, Stanford BD, Snyder SA. Pharmaceuticals and endocrine disrupting compounds in US drinking water. *Environ Sci Technol* 2008;43:597–603.
- Bo L, Urase T, Wang X. Biodegradation of trace pharmaceutical substances in wastewater by a membrane bioreactor. *Front Environ Sci Engin China* 2009;3:236–40.
- Boehler M, Zwicklenpflug B, Hollender J, Ternes T, Joss A, Siegrist H. Removal of micropollutants in municipal wastewater treatment plants by powder-activated carbon. *Water Sci Technol* 2012;66:2115–21.
- Bolong N, Ismail AF, Salim MR, Matsuura T. A review of the effects of emerging contaminants in wastewater and options for their removal. *Desalination* 2009;239:229–46.
- Camacho-Muñoz D, Martín J, Santos JL, Aparicio I, Alonso E. Effectiveness of conventional and low-cost wastewater treatments in the removal of pharmaceutically active compounds. *Water Air Soil Poll* 2012;223:2611–21.
- Campo J, Masiá A, Blasco C, Picó Y. Occurrence and removal efficiency of pesticides in sewage treatment plants of four Mediterranean River Basins. *J Hazard Mater* 2013; 263, Part 1: 146–57.
- Carballa M, Omil F, Lema JM. Removal of cosmetic ingredients and pharmaceuticals in sewage primary treatment. *Water Res* 2005;39:4790–6.
- Carballa M, Omil F, Lema JM, Llompart M, Garcia-Jares C, Rodríguez I, Gomez M, Ternes T. Behavior of pharmaceuticals, cosmetics and hormones in a sewage treatment plant. *Water Res* 2004;38:2918–26.
- Céspedes R, Lacorte S, Ginebreda A, Barceló D. Occurrence and fate of alkylphenols and alkylphenol ethoxylates in sewage treatment plants and impact on receiving waters along the Ter River (Catalonia, NE Spain). *Environ Pollut* 2008;153:384–92.
- Chen J, Huang X, Lee D. Bisphenol A removal by a membrane bioreactor. *Process Biochem* 2008;43:451–6.
- Choi K, Kim Y, Park J, Park CK, Kim M, Kim HS, et al. Seasonal variations of several pharmaceutical residues in surface water and sewage treatment plants of Han River, Korea. *Sci Total Environ* 2008a;405:120–8.
- Choi K-J, Kim S-G, Kim, S-H. Removal of antibiotics by coagulation and granular activated carbon filtration. *J of Hazard Mater* 2008b;151:38–43.
- Cirja M, Ivashechkin P, Schäffer A, Corvini PF. Factors affecting the removal of organic micropollutants from wastewater in conventional treatment plants (CTP) and membrane bioreactors (MBR). *Rev Environ Sci Biotechnol* 2008;7:61–78.
- Clara M, Gans O, Windhofer G, Krenn U, Hartl W, Braun K, et al. Occurrence of polycyclic musks in wastewater and receiving water bodies and fate during wastewater treatment. *Chemosphere* 2011;82:1116–23.
- Clara M, Windhofer G, Hartl W, Braun K, Simon M, Gans O, et al. Occurrence of phthalates in surface runoff, untreated and treated wastewater and fate during wastewater treatment. *Chemosphere* 2010;78:1078–84.
- Clara M, Kreuzinger N, Strenn B, Gans O, Kroiss H. The solids retention time—a suitable design parameter to evaluate the capacity of wastewater treatment plants to remove micropollutants. *Water Res* 2005;39:97–106.
- Clara M, Strenn B, Kreuzinger N. Carbamazepine as a possible anthropogenic marker in the aquatic environment: investigations on the behaviour of carbamazepine in wastewater treatment and during groundwater infiltration. *Water Res* 2004;38:947–54.

- Coetsier CM, Spinelli S, Lin L, Roig B, Touraud E. Discharge of pharmaceutical products (PPs) through a conventional biological sewage treatment plant: MECs vs PECs? *Environ Int* 2009;35:787–92.
- Conner E, Kosjek T, Qualmann S, Kusk KO, Heath E, Revitt DM, Ledin A, Andersen, HR. Ecotoxicity of carbamazepine and its UV photolysis transformation products. *Sci Total Environ* 2013;443:870–6.
- Daughton CG, Ternes TA. Pharmaceuticals and personal care products in the environment: agents of subtle change? *Environ Health Persp* 1999;107:907–38.
- Deblonde T, Cossu-Leguille C, Hartemann P. Emerging pollutants in wastewater: A review of the literature. *Int J Hyg Envir Heal* 2011;214:442–8.
- De Gusseme B, Pycke B, Hennebel T, Marcoen A, Vlaeminck SE, Noppe H, et al. Biological removal of 17 α -ethinylestradiol by a nitrifier enrichment culture in a membrane bioreactor. *Water Res* 2009;43:2493–503.
- De la Cruz N, Giménez J, Esplugas S, Grandjean, de Alencastro LF, Pulgarín C. Degradation of 32 emergent contaminants by UV and neutral photo-fenton in domestic wastewater effluent previously treated by activated sludge. *Water Res* 2012;46:1947–57.
- Dougherty JA, Swarzenski PW, Dinicola RS, Reinhard M. Occurrence of herbicides and pharmaceutical and personal care products in surface water and groundwater around Liberty Bay, Puget Sound, Washington. *J Environ Qual* 2010;39:1173–80.
- Drewes JE, Fox P, Jekel M. Occurrence of iodinated X-ray contrast media in domestic effluents and their fate during indirect potable reuse. *J Environ Sci Heal A* 2001;36:1633–45.
- Falås P, Longrée P, la Cour Jansen J, Siegrist H, Hollender J, Joss A. Micropollutant removal by attached and suspended growth in a hybrid biofilm-activated sludge process. *Water Res* 2013;47: 4498–506.
- Fent K, Weston, AA, Carminada D. Ecotoxicology of human pharmaceuticals. *Aquat Toxicol* 2006;76:122–59.
- Fernandez-Fontaina E, Omil F, Lema JM, Carballa M. Influence of nitrifying conditions on the biodegradation and sorption of emerging micropollutants. *Water Res* 2012;46:5434–44.
- Forrez I, Carballa M, Boon N, Verstraete W. Biological removal of 17 α -ethinylestradiol (EE2) in an aerated nitrifying fixed bed reactor during ammonium starvation. *J Chem Technol Biot* 2009;84:119–25.
- Fram MS, Belitz K. Occurrence and concentrations of pharmaceutical compounds in groundwater used for public drinking-water supply in California. *Sci Total Environ* 2011;409:3409–17.
- Fromme H, Küchler T, Otto T, Pilz K, Müller J, Wenzel A. Occurrence of phthalates and bisphenol A and F in the environment. *Water Res* 2002;36:1429–38.
- Gao D, Li Z, Wen Z, Ren N. Occurrence and fate of phthalate esters in full-scale domestic wastewater treatment plants and their impact on receiving waters along the Songhua River in China. *Chemosphere* 2014;95:24–32.
- Garcia N, Moreno J, Cartmell E, Rodriguez-Roda I, Judd S. The application of microfiltration-reverse osmosis/nanofiltration to trace organics removal for municipal wastewater reuse. *Environmental Technology* 2013; (ahead-of-print):1–7.
- Gerrity D, Gamage S, Holady JC, Mawhinney DB, Quiñones O, Trenholm RA, et al. Pilot-scale evaluation of ozone and biological activated carbon for trace organic contaminant mitigation and disinfection. *Water Res* 2011;45:2155–65.

- Gerrity D, Stanford BD, Trenholm R, Snyder SA. An evaluation of a pilot-scale nonthermal plasma advanced oxidation process for trace organic compound degradation. *Water Res* 2010;44:493–504.
- Ghosh GC, Okuda T, Yamashita N, Tanaka H. Occurrence and elimination of antibiotics at four sewage treatment plants in Japan and their effects on bacterial ammonia oxidation. *Water Sci Technol* 2009;59:779–86.
- Göbel A, McArdell CS, Joss A, Siegrist H, Giger W. Fate of sulfonamides, macrolides, and trimethoprim in different wastewater treatment technologies. *Sci Total Environ* 2007;372:361–71.
- Göbel A, Thomsen A, McArdell CS, Joss A, Giger W. Occurrence and sorption behavior of sulfonamides, macrolides, and trimethoprim in activated sludge treatment. *Environ Sci Technol* 2005;39:3981–9.
- Goel A, Müller MB, Sharma M, Frimmel FH. Biodegradation of nonylphenol ethoxylate surfactants in biofilm reactors. *Acta Hydroch Hydrob* 2003;31:108–19.
- Gómez MJ, Herrera S, Solé D, García-Calvo E, Fernández-Alba AR. Spatio-temporal evaluation of organic contaminants and their transformation products along a river basin affected by urban, agricultural and industrial pollution. *Sci Total Environ* 2012;420:134–45.
- Gracia-Lor E, Sancho JV, Serrano R, Hernández F. Occurrence and removal of pharmaceuticals in wastewater treatment plants at the Spanish Mediterranean area of Valencia. *Chemosphere* 2012;87:453–62.
- Gros M, Petrović M, Barcelo D. Wastewater treatment plants as a pathway for aquatic contamination by pharmaceuticals in the Ebro river basin (northeast Spain). *Environ Toxicol Chem* 2007;26:1553–62.
- Grover DP, Zhou JL, Frickers PE, aReadman JW. Improved removal of estrogenic and pharmaceutical compounds in sewage effluent by full scale granular activated carbon: Impact on receiving river water. *J Hazard Mater* 2011;185:1005–11.
- Guo WS, Ngo HH, Vigneswaran S. Chapter 20: Enhancement of Membrane Processes with Attached Growth Media. In: Zhang TC, Surampalli RY, Vigneswaran S, Tyagi RD, Ong SL, Kao CM, editors. *Membrane Technology and Environmental Applications*. USA: American Society of Civil Engineers (ASCE);2012. p. 603–34.
- Hai FI, Tessmer K, Nguyen LN, Kang J, Price WE, Nghiem LD. Removal of micropollutants by membrane bioreactor under temperature variation. *J Membrane Sci* 2011;383:144–51.
- Hernández-Leal L, Temmink H, Zeeman G, Buisman CJN. Removal of micropollutants from aerobically treated grey water via ozone and activated carbon. *Water Res* 2011;45:2887–96.
- Hijosa-Valsero M, Matamoros V, Martín-Villacorta J, Bécares E, Bayona JM. Assessment of full-scale natural systems for the removal of PPCPs from wastewater in small communities. *Water Res* 2010;44:1429–39.
- Hu A, Stuckey D. Treatment of Dilute Wastewaters using a novel submerged anaerobic membrane bioreactor. *J Environ Eng* 2006;132:190–8.
- Huang M, Li Y, Gu G. The effects of hydraulic retention time and sludge retention time on the fate of di-(2-ethylhexyl) phthalate in a laboratory-scale anaerobic-anoxic-aerobic activated sludge system. *Bioresource Technol* 2008;99:8107–11.
- Huber MM, Canonica S, Park G-Y, von Gunten U. Oxidation of pharmaceuticals during ozonation and advanced oxidation processes. *Environ Sci Technol* 2003;37:1016–24.

- Huerta-Fontela M, Galceran MT, Martin-Alonso J, Ventura F. Occurrence of psychoactive stimulatory drugs in wastewaters in north-eastern Spain. *Sci Total Environ* 2008;397:31–40.
- Huerta-Fontela M, Galceran MT, Ventura F. Occurrence and removal of pharmaceuticals and hormones through drinking water treatment. *Water Res* 2011;45:1432–42.
- Janex-Habibi M-L, Huyard A, Esperanza M, Bruchet A. Reduction of endocrine disruptor emissions in the environment: The benefit of wastewater treatment. *Water Res* 2009;43:1565–76.
- Jelic A, Gros M, Petrović M, Ginebreda A, Barceló D. Occurrence and Elimination of Pharmaceuticals During Conventional Wastewater Treatment. In: Guasch H, Ginebreda A, Geiszinger A, editors. *Emerging and Priority Pollutants in Rivers*. Berlin: Springer; 2012. p. 1–24.
- Jelic A, Gros M, Ginebreda A, Cespedes-Sánchez R, Ventura F, Petrovic M, Barcelo D. Occurrence, partition and removal of pharmaceuticals in sewage water and sludge during wastewater treatment. *Water Res* 2011;45:1165–76.
- Jermann D, Pronk W, Boller M, Schäfer AI. The role of NOM fouling for the retention of estradiol and ibuprofen during ultrafiltration. *J Membrane Sci* 2009;329:75–84.
- Jjemba, PK. Excretion and ecotoxicity of pharmaceutical and personal care products in the environment. *Ecotox Environ Safe* 2006;63:113–30.
- Jones OAH., Voulvoulis N, Lester JN. Human pharmaceuticals in wastewater treatment processes. *Crit Rev Env Sci Tec* 2005;35:401–27.
- Joss A, Keller E, Alder AC, Göbel A, McArdell CS, Ternes TA, et al. Removal of pharmaceuticals and fragrances in biological wastewater treatment. *Water Res* 2005;39:3139–52.
- Jungnickel C, Stock F, Brandsch T, Ranke J. Risk assessment of biocides in roof paint. *Environ Sci Pollut R* 2008;15:258–65.
- Karnjanapiboonwong A, Suski JG, Shah AA, Cai Q, Morse AN, Anderson TA. Occurrence of PPCPs at a wastewater treatment plant and in soil and groundwater at a land application site. *Water Air Soil Poll* 2011;216:257–73.
- Kasprzyk-Hordern B, Dinsdale RM, Guwy AJ. The removal of pharmaceuticals, personal care products, endocrine disruptors and illicit drugs during wastewater treatment and its impact on the quality of receiving waters. *Water Res* 2009;43:363–80.
- Kahle M, Buerge IJ, Hauser A, Müller MD, Poiger T. Azole fungicides: occurrence and fate in wastewater and surface waters. *Environ Sci Technol* 2008;42:7193–200.
- Kim H-s, Pei R, Gunsch C, Gellner JW, Boltz JP, Freudenberg B, et al. Trace organic chemical profiles in nutrient removal systems with and without integrated fixed film activated sludge. *Proceedings of the Water Environment Federation* 2009a;704–11.
- Kim I, Yamashita N, Tanaka H. Performance of UV and UV/H₂O₂ processes for the removal of pharmaceuticals detected in secondary effluent of a sewage treatment plant in Japan. *J Hazard Mater* 2009b;166:1134–40.
- Kim JW, Jang HS, Kim JG, Ishibashi H, Hirano M, Nasu K, et al. Occurrence of pharmaceutical and personal care products (PPCPs) in surface water from Mankyung River, South Korea. *J Health Sci* 2009c;55:249–58.
- Kimura K, Hara H, Watanabe Y. Elimination of selected pharmaceuticals by biosolids from municipal wastewater treatment plants: importance of modest pH change and degree of mineralization. *Water Sci Technol* 2010;62:1084–9.

- Kimura K, Toshima S, Amy G, Watanabe Y. Rejection of neutral endocrine disrupting compounds (EDCs) and pharmaceutical active compounds (PhACs) by RO membranes. *J Membrane Sci* 2004;245:71–8.
- Klamerth N, Malato S, Maldonado MI, Agüera A, Fernández-Alba AR. Application of photo-Fenton as a tertiary treatment of emerging contaminants in municipal wastewater. *Environ Sci Technol* 2010;44:1792–98.
- Klamerth N, Miranda N, Malato S, Agüera A, Fernández-Alba AR, Maldonado MI, et al. Degradation of emerging contaminants at low concentrations in MWTPs effluents with mild solar photo-Fenton and TiO₂. *Catal Today* 2009;144:124–30.
- Kleywegt S, Pileggi V, Yang P, Hao C, Zhao X, Rocks C, et al. Pharmaceuticals, hormones and bisphenol A in untreated source and finished drinking water in Ontario, Canada—occurrence and treatment efficiency. *Sci Total Environ* 2011;409:1481–8.
- Köck M, Farré M, Martínez E, Gajda-Schrantz K, Ginebreda A, Navarro A, et al. Integrated ecotoxicological and chemical approach for the assessment of pesticide pollution in the Ebro River delta (Spain). *J Hydrol* 2010;383:73–82.
- Köck-Schulmeyer M, Villagrasa M, López de Alda M, Céspedes-Sánchez R, Ventura F, Barceló D. Occurrence and behavior of pesticides in wastewater treatment plants and their environmental impact. *Sci Total Environ* 2013;458:466–76.
- Kolpin DW, Skopec M, Meyer MT, Furlong ET, Zaugg SD. Urban contribution of pharmaceuticals and other organic wastewater contaminants to streams during differing flow conditions. *Sci Total Environ* 2004;328:119–30.
- Kovalova L, Siegrist H, von Gunten U, Eugster J, Hagenbuch M, Wittmer A, et al. Elimination of Micropollutants during Post-Treatment of Hospital Wastewater with Powdered Activated Carbon, Ozone, and UV. *Environ Sci Technol* 2013;47:7899–908.
- Kovalova L, Siegrist H, Singer H, Wittmer A, McArdell CS. Hospital wastewater treatment by membrane bioreactor: performance and efficiency for organic micropollutant elimination. *Environ Sci Technol* 2012;46:1536–45.
- Kumar KS, Priya SM, Peck AM, Sajwan KS. Mass loadings of triclosan and triclocarbon from four wastewater treatment plants to three rivers and landfill in Savannah, Georgia, USA. *Arch Environ Con Tox* 2010;58: 275–85.
- Lapworth D, Baran N, Stuart M, Ward R. Emerging organic contaminants in groundwater: A review of sources, fate and occurrence. *Environ Pollut* 2012;163:287–303.
- Lin AY-C, Tsai Y-T, Yu T-H, Wang X-H, Lin C-F. Occurrence and fate of pharmaceuticals and personal care products in Taiwan's aquatic environment. *Desalination and Water Treatment* 2011;32:57–64.
- Lin AY-C, Yu TH, Lin C-F. Pharmaceutical contamination in residential, industrial, and agricultural waste streams: Risk to aqueous environments in Taiwan. *Chemosphere* 2008;74:131–41.
- Liu Z-H, Kanjo Y, Mizutani S. Removal mechanisms for endocrine disrupting compounds (EDCs) in wastewater treatment—physical means, biodegradation, and chemical advanced oxidation: a review. *Sci Total Environ* 2009; 407: 731–48.
- Loos R, Carvalho R, António DC, Comero S, Locoro G, Tavazzi S, et al. EU-wide monitoring survey on emerging polar organic contaminants in wastewater treatment plant effluents. *Water Res* 2013;47:6475–87.
- Loos R, Locoro G, Comero S, Contini S, Schwesig D, Werres F, et al. Pan-European survey on the occurrence of selected polar organic persistent pollutants in ground water. *Water Res* 2010;44:4115–26.

- Loos R, Hanke G, Umlauf G, Eisenreich SJ. LC–MS–MS analysis and occurrence of octyl- and nonylphenol, their ethoxylates and their carboxylates in Belgian and Italian textile industry, waste water treatment plant effluents and surface waters. *Chemosphere* 2007;66:690–9.
- Maeng SK, Ameda E, Sharma SK, Gruetzmacher G, Amy GL. Organic micropollutant removal from wastewater effluent-impacted drinking water sources during bank filtration and artificial recharge. *Water Research* 2010;44:4003–14.
- Martin RS, Esperanza M, Choubert J, Valor I, Budzinski H, Coquery M. On-site evaluation of the efficiency of conventional and advanced secondary processes for the removal of 60 organic micropollutants. *Water Sci Technol* 2010;62:2970–8.
- Matamoros V, Salvadó V. Evaluation of a coagulation/flocculation-lamellar clarifier and filtration-UV-chlorination reactor for removing emerging contaminants at full-scale wastewater treatment plants in Spain. *J Environ Manage* 2013;117:96–102.
- Müller B, Scheytt T, Asbrand M, de Casas AM. Pharmaceuticals as indicators of sewage-influenced groundwater. *Hydrogeol J* 2012;20:1117–29.
- Nghiem, LD, Schäfer AI, Elimelech M. Pharmaceutical Retention Mechanisms by Nanofiltration Membranes. *Environ Sci Technol* 2005;39:7698–705.
- Nghiem LD, Manis A, Soldenhoff K, Schäfer AI. Estrogenic hormone removal from wastewater using NF/RO membranes. *J Membrane Sci* 2004;242: 37–45.
- Ngo HH, Guo WS, Vigneswaran S. Chapter 8: Membrane Processes for Water Reclamation and Reuse. In: Zhang TC, Surampalli RY, Vigneswaran S, Tyagi RD, Ong SL, Kao CM, editors. *Membrane Technology and Environmental Applications*. USA: American Society of Civil Engineers (ASCE);2012. p. 239–275.
- Nie Y, Qiang Z, Zhang H, Ben W. Fate and seasonal variation of endocrine-disrupting chemicals in a sewage treatment plant with A/A/O process. *Sep Purif Technol* 2012;84:9–15.
- Pal A, Gin KYH, Lin AYC, Reinhard M. Impacts of emerging organic contaminants on freshwater resources: review of recent occurrences, sources, fate and effects. *Sci Total Environ* 2010;408:6062–9.
- Peng X, Yu Y, Tang C, Tan J, Huang Q, Wang Z. Occurrence of steroid estrogens, endocrine-disrupting phenols, and acid pharmaceutical residues in urban riverine water of the Pearl River Delta, South China. *Sci Total Environ* 2008;397:158–66.
- Petrovic M, de Alda MJL, Diaz-Cruz S, Postigo C, Radjenovic J, Gros M, et al. Fate and removal of pharmaceuticals and illicit drugs in conventional and membrane bioreactor wastewater treatment plants and by riverbank filtration. *Philos T Roy Soc A* 2009;367:3979–4003.
- Postigo, C, López de Alda MJ, Barceló D, Ginebreda A, Garrido T, Fraile J. Analysis and occurrence of selected medium to highly polar pesticides in groundwater of Catalonia (NE Spain): An approach based on on-line solid phase extraction–liquid chromatography–electrospray-tandem mass spectrometry detection. *J Hydrol* 2010;383:83–92.
- Pothitou P, Voutsas D. Endocrine disrupting compounds in municipal and industrial wastewater treatment plants in Northern Greece. *Chemosphere* 2008;73:1716–23.
- Pomiès M, Choubert JM, Wisniewski C, Coquery M. Modelling of micropollutant removal in biological wastewater treatments: A review. *Sci Total Environ* 2013;443:733–48.
- Pruden A, Pei R, Storteboom H, Carlson KH. Antibiotic resistance genes as emerging contaminants: Studies in Northern Colorado. *Environ Sci Technol* 2006;40:7445–50.

- Qiang Z, Dong H, Zhu B, Qu J, Nie Y. A comparison of various rural wastewater treatment processes for the removal of endocrine-disrupting chemicals (EDCs). *Chemosphere* 2013;92:986–92.
- Radjenovic J, Petrovic M, Barceló D. Fate and distribution of pharmaceuticals in waste-water and sewage sludge of the conventional activated sludge (CAS) and advanced membrane bioreactor (MBR) treatment. *Water Res* 2009;43:831–41.
- Radjenovic J, Petrovic M, Barceló D. Analysis of pharmaceuticals in wastewater and removal using a membrane bioreactor. *Anal Bioanal Chem* 2007;387:1365–77.
- Regnery J, Püttmann W. Occurrence and fate of organophosphorus flame retardants and plasticizers in urban and remote surface waters in Germany. *Water Res* 2010;44:4097–104.
- Reemtsma T, Quintana JB, Rodil R. Organophosphorus flame retardants and plasticizers in water and air I. Occurrence and fate. *TrAC Trends in Anal Chem* 2008; 27:727–37.
- Reinstorf F, Strauch G, Schirmer K, Gläser H-R, Möder M, Wennrich R, et al. Mass fluxes and spatial trends of xenobiotics in the waters of the city of Halle, Germany. *Environ Pollut* 2008;152:452–60.
- Reungoat J, Escher BI, Macova M, Keller J. Biofiltration of wastewater treatment plant effluent: Effective removal of pharmaceuticals and personal care products and reduction of toxicity. *Water Res* 2011;45:2751–62.
- Roh H, Subramanya N, Zhao F, Yu C-P, Sandt J, Chu K-H. Biodegradation potential of wastewater micropollutants by ammonia-oxidizing bacteria. *Chemosphere* 2009;77:1084–9.
- Röhricht M, Krisam J, Weise U, Kraus UR, Düring R-A. Elimination of carbamazepine, diclofenac and naproxen from treated wastewater by nanofiltration. *CLEAN – Soil, Air, Water* 2009;37:638–41.
- Rosal R, Rodríguez A, Perdigón-Melón JA, Petre A, García-Calvo E, Gómez MJ, et al. Occurrence of emerging pollutants in urban wastewater and their removal through biological treatment followed by ozonation. *Water Res* 2010;44:578–88.
- Rossner A, Snyder SA, Knappe DRU. Removal of emerging contaminants of concern by alternative adsorbents. *Water Res* 2009;43:3787–96.
- Sacher F, Ehmann M, Gabriel S, Graf C, Brauch H-J. Pharmaceutical residues in the river Rhine—results of a one-decade monitoring programme. *J Environ Monitor* 2008;10:664–70.
- Sahar E, David I, Gelman Y, Chikurel H, Aharoni A, Messalem R, et al. The use of RO to remove emerging micropollutants following CAS/UF or MBR treatment of municipal wastewater. *Desalination* 2011;273:142–7.
- Sakamoto H, Shoji S, Kaneko H. Leaching characteristics of bisphenol A from epoxy-resin pavement materials. *Toxicological & Environmental Chemistry* 2007;89:191–203.
- Salgado R, Marques R, Noronha JP, Carvalho G, Oehmen A, Reis MAM. Assessing the removal of pharmaceuticals and personal care products in a full-scale activated sludge plant. *Environ Sci Pollut R* 2012;19:1818–27.
- Samaras VG, Stasinakis AS, Mamais D, Thomaidis NS, Lekkas TD. Fate of selected pharmaceuticals and synthetic endocrine disrupting compounds during wastewater treatment and sludge anaerobic digestion. *J Hazard Mater* 2013;244-245:259–67.
- Santos J, Aparicio I, Callejón M, Alonso E. Occurrence of pharmaceutically active compounds during 1-year period in wastewaters from four wastewater treatment plants in Seville (Spain). *J Hazard Mater* 2009;164:1509–16.

- Schaar H, Clara M, Gans O, Kreuzinger N. Micropollutant removal during biological wastewater treatment and a subsequent ozonation step. *Environ Pollut* 2010;158:1399–404.
- Schäfer AI, Akanyeti I, Semião AJC. Micropollutant sorption to membrane polymers: A review of mechanisms for estrogens. *Adv Colloid Interfac* 2011;164:100–17.
- Schäfer AI, Nghiem LD, Waite TD. Removal of natural hormone estrone from aqueous solutions using nanofiltration and reverse osmosis. *Environ Sci Technol* 2003;37:182–8.
- Schoknecht U, Gruycheva J, Mathies H, Bergmann H, Burkhardt M. Leaching of biocides used in facade coatings under laboratory test conditions. *Environ Sci Technol* 2009;43:9321–8.
- Serrano D, Suárez S, Lema JM, Omil F. Removal of persistent pharmaceutical micropollutants from sewage by addition of PAC in a sequential membrane bioreactor. *Water Res* 2011;45:5323–33.
- Singer H, Jaus S, Hanke I, Lück A, Hollender J, Alder AC. Determination of biocides and pesticides by on-line solid phase extraction coupled with mass spectrometry and their behaviour in wastewater and surface water. *Environ Pollut* 2010;158:3054–64.
- Snyder SA, Adham S, Redding AM, Cannon FS, DeCarolis J, Oppenheimer J, et al. Role of membranes and activated carbon in the removal of endocrine disruptors and pharmaceuticals. *Desalination* 2007; 202:156–81.
- Snyder SA, Wert EC, Rexing DJ, Zegers RE, Drury DD. Ozone oxidation of endocrine disruptors and pharmaceuticals in surface water and wastewater. *Ozone-Sci Eng* 2006;28:445–60.
- Spongberg AL, Witter JD, Acuña J, Vargas J, Murillo M, Umaña G, et al. Reconnaissance of selected PPCP compounds in Costa Rican surface waters. *Water Res* 2011;45:6709–17.
- Spring AJ, Bagley DM, Andrews RC, Lemanik S, Yang P. Removal of endocrine disrupting compounds using a membrane bioreactor and disinfection. *J Environ Eng Sci* 2007;6:131–7.
- Stackelberg PE, Furlong ET, Meyer MT, Zaugg SD, Henderson AK, Reissman DB. Persistence of pharmaceutical compounds and other organic wastewater contaminants in a conventional drinking-water-treatment plant. *Sci Total Environ* 2004;329:99–113.
- Stamatis NK, Konstantinou IK. Occurrence and removal of emerging pharmaceutical, personal care compounds and caffeine tracer in municipal sewage treatment plant in Western Greece. *J Environ Sci Heal B* 2013;48:800–13.
- Stamatis N, Hela D, Konstantinou I. Occurrence and removal of fungicides in municipal sewage treatment plant. *J Hazard Mater* 2010;175:829–35.
- Stasinakis AS, Thomaidis NS, Arvaniti OS, Asimakopoulos AG, Samaras VG, Ajibola A, et al. Contribution of primary and secondary treatment on the removal of benzothiazoles, benzotriazoles, endocrine disruptors, pharmaceuticals and perfluorinated compounds in a sewage treatment plant. *Sci Total Environ* 2013;463–464:1067–75.
- Stasinakis AS, Mermigka S, Samaras VG, Farmaki E, Thomaidis NS. Occurrence of endocrine disruptors and selected pharmaceuticals in Aisonas River (Greece) and environmental risk assessment using hazard indexes. *Environ Sci Pollut R* 2012;19:1574–83.
- Stasinakis AS, Kordoutis CI, Tsiouma VC, Gatidou G, Thomaidis NS. Removal of selected endocrine disruptors in activated sludge systems: Effect of sludge retention time on their sorption and biodegradation. *Bioresource Technol* 2010;101:2090–5.
- Stasinakis, AS, Kotsifa S, Gatidou G, Mamais D. Diuron biodegradation in activated sludge batch reactors under aerobic and anoxic conditions. *Water Res* 2009;43:1471–9.

- Stasinakis AS, Gatidou G, Mamais D, Thomaidis NS, Lekkas TD. Occurrence and fate of endocrine disrupters in Greek sewage treatment plants. *Water Res* 2008;42:1796–804.
- Steinle-Darling E, Litwiller E, Reinhard M. Effects of Sorption on the Rejection of Trace Organic Contaminants During Nanofiltration. *Environ Sci Technol* 2010;44:2592–8.
- Stepien D, Regnery J, Merz C, Püttmann W. Behavior of organophosphates and hydrophilic ethers during bank filtration and their potential application as organic tracers. A field study from the Oderbruch, Germany. *Sci Total Environ* 2013;458:150–9.
- Suárez S, Lema JM, Omil F. Removal of pharmaceutical and personal care products (PPCPs) under nitrifying and denitrifying conditions. *Water Res* 2010;44:3214–24.
- Suárez S, Lema JM, Omil F. Pre-treatment of hospital wastewater by coagulation–flocculation and flotation. *Bioresource Technol* 2009;100:2138–46.
- Suárez S, Carballa M, Omil F, Lema J. How are pharmaceutical and personal care products (PPCPs) removed from urban wastewaters? *Rev Environ Sci Biotechnol* 2008;7:125–38.
- Sui Q, Huang J, Deng S, Yu G, Fan Q. Occurrence and removal of pharmaceuticals, caffeine and DEET in wastewater treatment plants of Beijing, China. *Water Res* 2010;44:417–26.
- Tadkaew N, Hai FI, McDonald JA, Khan SJ, Nghiem LD. Removal of trace organics by MBR treatment: The role of molecular properties. *Water Res* 2011;45:2439–51.
- Teijon G, Candela L, Tamoh K, Molina-Díaz A, Fernández-Alba AR. Occurrence of emerging contaminants, priority substances (2008/105/CE) and heavy metals in treated wastewater and groundwater at Depurbaix facility (Barcelona, Spain). *Sci Total Environ* 2010;408:3584–95.
- Ternes TA, Joss A, Siegrist H. Peer Reviewed: Scrutinizing pharmaceuticals and personal care products in wastewater treatment. *Environ Sci Technol* 2004;38:392A–9A.
- Terzić S, Senta I, Ahel M, Gros M, Petrović M, Barcelo D, et al. Occurrence and fate of emerging wastewater contaminants in Western Balkan Region. *Sci Total Environ* 2008;399:66–77.
- Thuy PT, Moons K, Van Dijk JC, Viet Anh N and Van der Bruggen B. To what extent are pesticides removed from surface water during coagulation–flocculation? *Water Environ J* 2008;22:217–23.
- Trinh T, van den Akker B, Stuetz RM, Coleman HM, Le-Clech P, Khan, SJ. Removal of trace organic chemical contaminants by a membrane bioreactor. *Water Sci Technol* 2012;66:1856–63.
- Vader JS, van Ginkel CG, Sperling FMGM, de Jong J, de Boer W, de Graaf JS, et al. Degradation of ethinyl estradiol by nitrifying activated sludge. *Chemosphere* 2000;41:1239–43.
- Verlicchi P, Al Aukidy M, Zambello E. Occurrence of pharmaceutical compounds in urban wastewater: removal, mass load and environmental risk after a secondary treatment—a review. *Sci Total Environ* 2012;429:123–155.
- Verlicchi P, Galletti A, Masotti L. Management of hospital wastewaters: the case of the effluent of a large hospital situated in a small town. *Water Sci Technol* 2010a;61:2507–19.
- Verlicchi P, Galletti A, Petrovic M, Barceló D. Hospital effluents as a source of emerging pollutants: An overview of micropollutants and sustainable treatment options. *J Hydrol* 2010b;389:416–28.
- Vieno N, Tuhkanen T, Kronberg L. Removal of Pharmaceuticals in Drinking Water Treatment: Effect of Chemical Coagulation. *Environ Technol* 2006;27:183–92.
- Vulliet E, Cren-Olivé C. Screening of pharmaceuticals and hormones at the regional scale, in surface and groundwaters intended to human consumption. *Environ Pollut* 2011;159:2929–34.

- Vulliet E, Cren-Olivé C, Grenier-Loustalot M-F. Occurrence of pharmaceuticals and hormones in drinking water treated from surface waters. *Environmental Chemistry Letters* 2011;9:103–14.
- Wang C, Shi H, Adams CD, Gamagedara S, Stayton I, Timmons T, et al. Investigation of pharmaceuticals in Missouri natural and drinking water using high performance liquid chromatography-tandem mass spectrometry. *Water Res* 2011;45:1818–28.
- Westerhoff P, Yoon Y, Snyder S, Wert E. Fate of endocrine-disruptor, pharmaceutical, and personal care product chemicals during simulated drinking water treatment processes. *Environ Sci Technol* 2005;39:6649–63.
- Wick A, Fink G, Joss A, Siegrist H, Ternes TA. Fate of beta blockers and psycho-active drugs in conventional wastewater treatment. *Water Res* 2009;43:1060–74.
- Xu Y, Zhou Y, Wang D, Chen S, Liu J, Wang Z. Occurrence and removal of organic micropollutants in the treatment of landfill leachate by combined anaerobic-membrane bioreactor technology. *J Environ Sci* 2008;20:1281–7.
- Yang X, Flowers RC, Weinberg HS, Singer PC. Occurrence and removal of pharmaceuticals and personal care products (PPCPs) in an advanced wastewater reclamation plant. *Water Res* 2011;45:5218–28.
- Yangali-Quintanilla V, Maeng SK, Fujioka T, Kennedy M, Li Z, Amy G. Nanofiltration vs. reverse osmosis for the removal of emerging organic contaminants in water reuse. *Desalination and Water Treatment* 2011;34:50–6.
- Yoon Y, Westerhoff P, Snyder SA, Wert EC. Nanofiltration and ultrafiltration of endocrine disrupting compounds, pharmaceuticals and personal care products. *J Membrane Sci* 2006;270:88–100.
- Yu C-P, Chu K-H. Occurrence of pharmaceuticals and personal care products along the West Prong Little Pigeon River in east Tennessee, USA. *Chemosphere* 2009;75:1281–6.
- Zhang Z, Zhu H, Wen X, Si X. Degradation behavior of 17 α -ethinylestradiol by ozonation in the synthetic secondary effluent. *J Environ Sci* 2012;24:228–33.
- Zhang Y, Geißen S-U, Gal C. Carbamazepine and diclofenac: Removal in wastewater treatment plants and occurrence in water bodies. *Chemosphere* 2008;73:1151–61.
- Zhou H, Wu C, Huang X, Gao M, Wen X, Tsuno H, et al. Occurrence of selected pharmaceuticals and caffeine in sewage treatment plants and receiving Rivers in Beijing, China. *Water Environ Res* 2010;82:2239–48.
- Zhou X, Oleszkiewicz JA. Biodegradation of oestrogens in nitrifying activated sludge. *Environ Technol* 2010;31:1263–9.
- Zorita S, Mårtensson L, Mathiasson L. Occurrence and removal of pharmaceuticals in a municipal sewage treatment system in the south of Sweden. *Sci Total Environ* 2009;407:2760–70.
- Zuccato E, Castiglioni S, Fanelli R, Reitano G, Bagnati R, Chiabrando C, Pomati F, Rossetti C, Calamari D. Pharmaceuticals in the environment in Italy: causes, occurrence, effects and control. *Environ Sci Pollut R* 2006;13:15–21.
- Zwiener C, Frimmel FH. Short-term tests with a pilot sewage plant and biofilm reactors for the biological degradation of the pharmaceutical compounds clofibrac acid, ibuprofen, and diclofenac. *Sci Total Environ* 2003;309:201–11.

Highlights

- Micropollutants occur in the aquatic environment all over the world.
- There is a large variation in micropollutant removal (12.5 to 100%) in WWTPs.
- Micropollutant removal is dependent on compound- and process- specific factors.
- Advanced treatment technologies achieve better micropollutants removal.

Table captions

Table 1 Sources of micropollutants in the aquatic environment

Table 2 The concentration and removal of micropollutants in WWTPs of different countries

Table 3 Excretion rates of common pharmaceutical compounds

Table 4 Occurrence of common micropollutants in surface water in different countries

Table 5 Occurrence of selected micropollutants in groundwater un different countries

Table 6 Simple classification of micropollutants based on removal efficiency

Table 7 Removals of some micropollutants during coagulation-flocculation processes

Table 8 Removals of some micropollutants during adsorption process

Table 9 Removals of some micropollutants during ozonation and AOPs

Table 10 Removals of some micropollutants during membranae processes

Table 11 Removals of some micropollutants during MBR processes

Table 12 Removals of some micropollutants during attached growth treatment processes

Table 13 Comparison of micropollutants removal effectiveness in different WWTPs

Table 14 Assessment of different treatment processes for micropollutants removal

Table 1
Sources of micropollutants in the aquatic environment

Category	Important subclasses	Major sources	
		Distinct	Nonexclusive
Pharmaceuticals	NSAIDs ^a , lipid regulator, anticonvulsants, antibiotics, β -blockers and stimulants	<ul style="list-style-type: none"> • Domestic wastewater (from excretion) • Hospital effluents • Run-off from CAFOs^b and aquaculture 	
Personal care products	Fragrances, disinfectants, UV filters, and insect repellents	<ul style="list-style-type: none"> • Domestic wastewater (from bathing, shaving, spraying, swimming and etc.) 	
Steroid hormones	Estrogens	<ul style="list-style-type: none"> • Domestic wastewater (from excretion) • Run-off from CAFOs and aquaculture 	Sources that are not exclusive to individual categories include: <ul style="list-style-type: none"> • Industrial wastewater (from product manufacturing discharges) • Landfill leachate (from improper disposal of used, defective or expired items)
Surfactants	Non-ionic surfactants	<ul style="list-style-type: none"> • Domestic wastewater (from bathing, laundry, dishwashing and etc.) • Industrial wastewater (from industrial cleaning discharges) 	
Industrial chemicals	Plasticizers, fire retardants	<ul style="list-style-type: none"> • Domestic wastewater (by leaching out of the material) 	
Pesticides	Organochlorine insecticides, organophosphorus insecticides, herbicides and fungicides	<ul style="list-style-type: none"> • Domestic wastewater (from improper cleaning, run-off from gardens, lawns and roadways and etc.) • Agricultural runoff 	

^a NSAIDs: non-steroidal anti-inflammatory drugs; ^bCAFOs: concentrated animal feeding operations.

Table 2**The concentration and removal of micropollutants in WWPTs of different countries**

Categories	Selected compounds	Sampling sites	Influent (µg/L)	Effluent (µg/L)	Removal (%) ^c	References ^d
Pharmaceutical						
Analgesic and antiinflammatory						
	Acetaminophen	Spain, Korea, WB ^a	1.57-56.94	0-0.03	98.7-100	2, 5, 8, 24, 25 ^e
	Diclofenac	EU-wide ^a , Greece, Korea, Sweden, Switzerland, UK, WB	<0.001-4.2	<0.001-0.69	-105-81.4	2, 8, 11, 14 ^f , 20, 21, 24, 25, 27, 28
	Ibuprofen	China, EU-wide ^a , Greece, Korea, Sweden, UK, US, WB	<0.004-603	ND ^e -55	72-100	2, 8, 11, 14, 19, 21, 24, 25, 26, 28
	Ketoprofen	China, EU-wide ^a , Korea, Spain, UK, WB	<0.004-8.56	<0.003-3.92	11.2-100	2, 8, 11, 14, 19, 25, 27
	Mefenamic acid	EU-wide, Korea, Spain, UK	<0.017-1.27	<0.005-0.39	-387.5-70.2	2, 8, 11, 24
	Naproxen	Greece, Korea, Spain, Sweden, UK, WB	<0.002-52.90	<0.002-5.09	43-95.7	2, 8, 11, 19, 21, 24, 25, 28
	Salicylic acid	Greece, Spain, UK	0.576-63.7	ND-0.50	92.8-100	8, 11, 21
Anticonvulsant						
	Carbamazepine	China, EU-wide, Greece, Korea, Spain, UK, WB	<0.04-3.78	<0.005-4.60	-114.2-62.3	2, 5, 11, 14, 19, 24, 25, 27
Lipid regulator						
	Bezafibrate	EU-wide, Spain, Korea, UK, WB	0.05-1.39	0.03-0.67	9.1-70.5	2, 8, 11, 14, 24, 25
	Clofibric acid	China, EU-wide, Greece, Korea, Spain, Sweden, UK, WB	0-0.74	0-0.33	9.9-93.6	2, 11, 14, 21, 24, 25, 28

	Gemfibrozil	EU-wide, Greece, Korea, Spain, WB	0.10-17.06	<0.0025-5.24	-133.3-92.3	2, 8, 14, 21, 24, 25
	Antibiotic					
	Erythromycin	China, Spain, UK, WB	0.14-10.03	0.02-2.84	-100-82.5	8, 11, 24, 25, 27
	Sulfamethoxazole	EU-wide, France, Korea, Spain, Sweden, Switzerland, UK, WB	<0.003-0.98	<0.003- 1.15	4-91.7	2, 5, 8, 11, 14, 15, 20, 24, 25
	Trimethoprim	China, EU-wide, Korea, Spain, UK	0.06-6.80	<0.01- 3.05	-80->88.1	2, 5, 8, 11, 14, 24, 25, 27
	β -blocker					
	Atenolol	Korea, Spain, Switzerland, UK, WB	0.1-33.106	0.13-7.60	-33.3-83.0	1, 2, 11, 24, 25
	Metoprolol	China, Korea, Spain, Switzerland, UK	0.002-1.52	0.003-0.25	3-83.5	1, 2, 8, 11, 24
	Nervous stimulant					
	Caffeine	Spain, UK, Korea, China, EU-wide, Greek	0.22-209	0-43.50	44-99.8	2, 5, 14, 19, 21, 24, 26, 27
PCP ^a	Musk fragrance					
	Galaxolide	Spain, WB	0.03-24.97	<0.06-2.77	87.8	24, 25
	Tonalide	Spain, WB	<0.05- 1.93	<0.05- 0.32	84.7	24, 25
	Disinfectant					
	Triclosan	Spain, UK, US, Greece, Korea, France, EU-wide	0.03- 23.90	0.01-6.88	60.9-99	2, 13, 14, 15, 17, 21, 23, 24, 26
	Insect repellent					
	DEET ^a	China, EU-wide	2.56-3.19	0.61- 15.80	65.6-79.5	14, 25
	UV-filter					

Steroid hormone	Benzophenone-3	Korea, Spain	<0.079-0.904	<0.79-0121	78.2	2, 24	
	Estrone	China, France, Germany, Italy, Korea, Sweden, US	0.01-0.17	<0.001-0.08	74.8-87.1	2, 9, 16, 28	
	Estradiol	China, France, Germany, Italy, Korea, Sweden, US	0.002-0.05	<0.001-0.007	47-92.6	2, 9, 16, 28	
	17 α -Ethinylestradiol	China, France, Germany, Italy, Sweden, US	0.001-0.003	<0.001-0.002	43.8	9, 16, 28	
	Estriol	China, Korea	0.125 -0.80	0-0	100	2, 16	
Surfactants	Nonylphenol	China, France, Germany, Greece, Italy, Spain, US, WB	<0.03-101.6	<0.03-7.8	21.7-91.4	4, 9, 15, 16, 17, 23, 25	
	Octylphenol	China, France, Germany, Italy, Spain, UK, US	<0.2-8.7	0.004-1.3	80-99.6	4, 9, 11, 15, 16, 17, 25	
Industrial chemicals	Plasticizers						
	Bisphenol A	China, France, Greece, US, WB	<0.013-2.14	<0.03-1.10	60-95.1	11, 15, 16, 17, 23, 25, 26	
	DBP^a	Austria, China	ND-11.81	ND-4.13	73.6-75.5	6, 7	
	DEHP^a	Austria, China, US	0.003-70.0	0.0001-54.0	22.9-97	6, 7, 26	
	DMP^a	Austria, China	ND-6.49	ND-1.52	84.8-93.5	6, 7	
	Fire retardant						
	TCEP^a	EU-wide, Germany	0.06-0.5	0.06-2.4	-105.6- -20.7	14, 18	
	TCPP^a	EU-wide, Germany	0.18-4	0.1-21	-26.2- -50.0	14, 18	
	Pesticide	Herbicide					
		Atrazine	EU-wide, France, Spain, Switzerland, WB	0.02-28	0.004-0.73	<0-50	3, 12, 14, 15, 20, 25
Diuron		EU-wide, France, Spain, Switzerland	0.03-1.96	0.002-2.53	19-61.5	3, 12, 14, 15, 20, 24	
	Insecticide						

Fungicide	Diazinon	EU-wide, Spain	0.684 (max)	0.0007-4.16	-111.3	3, 12, 14
	Clotrimazole	EU-wide, Greece	0.012-0.08	ND-0.005	>80	10, 14, 22
	Tebuconazole	Greece, Spain	ND-1.89	0.0005-0.69	19-57	3, 10, 22

^a WB: Western Balkan Region (including Bosnia and Herzegovina, Croatia and Serbia);

^b ND: not detected;

^c When the removal efficiency was not presented in a study, it was calculated using the following equation, removal efficiency (%) = $(C_{inf} - C_{eff})/C_{inf} \times 100$ (C_{inf} is the influent concentration of a compound and C_{eff} is the effluent concentration of a compound);

^d 1. Alder et al., 2010; 2. Behera et al., 2011; 3. Campo et al., 2013; 4. Céspedes et al., 2008; 5. Choi et al., 2008a; 6. Clara et al., 2010; 7. Gao et al., 2013; 8. Gracia-Lor et al., 2012; 9. Janex-Habibi et al., 2009; 10. Kahle et al., 2008; 11. Kasprzyk-Hordern et al., 2009; 12. Köck-Schulmeyer et al., 2013; 13. Kumar et al., 2010; 14. Loos et al., 2013; 15. Martin et al., 2010; 16. Nie et al., 2012; 17. Pothitou and Voutsas, 2008; 18. Reemtsma et al., 2008; 19. Santos et al., 2009; 20. Singer et al., 2010; 21. Stamatis and Konstantinou, 2013; 22. Stamatis et al., 2010; 23. Stasinakis et al., 2008; 24. Rosal et al., 2010; 25. Terzić et al., 2008; 26. Yu and Chu, 2009; 27. Zhou et al., 2010; 28. Zorita et al., 2009;

^e Only influent concentrations were provided in the study;

^f Only effluent concentrations were provided in the study.

Table 3

Human excretion rates of some common pharmaceutical compounds in the aquatic environment (adapted from Alder, Hirsch et al., 1999; Huschek et al., 2004; Jjemba, 2006; Ternes, 1998; and the range was selected according to Jjemba, 2006)

Excretion rate	Pharmaceutical
Low ($\leq 5\%$)	Aspirin (acetylsalicylic acid), carbamazepine, gemfibrozil, ibuprofen
Moderately low (6-39%)	Diclofenac, metoprolol, primidone, sulfamethoxazole
Relatively high (40-69%)	Bezafibrate, norfloxacin, trimethoprim,
High ($\geq 70\%$)	Amoxicillin, ciprofloxacin, tetracycline

Table 4**Occurrence of common micropollutants in surface water from different regions**

Compound	Concentration (ng/L)											
	Canada ^{a,1}	China ²	Costa Rica ^{a,3}	France ⁴	Germany ^{5,6}	Greece ⁷	Korea ⁸	Spain ^{b,9}	Taiwan ¹⁰	UK ¹¹	US ¹²	PNEC ^b
Ibuprofen	0.98 (79)	ND-1417	5 (36788)	ND-8	-	1-67	<15-414	-	5-280	0.3-100	ND-77	5000
Naproxen	1 (87)	ND-328	-	ND-6.4	-	3-322	-	-	-	0.3-149	-	37000
Ketoprofen	-	-	7 (9808)	ND-22.0	-	0.4-39.5	-	-	10-190	0.5-14	-	15.6×10 ⁶
Diclofenac	-	-	14 (266)	ND-35.0	-	0.8-1043	-	-	-	0.5-261	-	10000
Mefenamic acid	-	-	-	-	-	-	<30-326	-	-	0.3-169	-	-
Carbamazepine	3 (749)	-	1 (82)	ND-31.6	102-1194	-	<4-595	-	-	0.5-684	ND-9.6	25000
Gemfibrozil	-	-	41 (17036)	-	-	-	-	-	1.9-3.5	-	-	100000
Atenolol	-	-	-	ND-34.0	-	-	<100-690	-	-	1-560	-	10×10 ⁶
Sulfamethoxazole	0.2 (284)	-	11 (56)	ND-5.1	-	-	-	-	0.3-60	0.5-4	ND-38	20000
Trimethoprim	-	-	-	-	-	-	-	-	1-2.1	7-122	ND-9.1	1000
Triclosan	0.4 (25)	35-1023	11 (263)	-	124-220	3-39	ND ^c	-	-	5-95	ND-9.8	-
Galaxolide	-	-	-	-	35-1814	-	-	-	-	-	-	-
Tonalide	-	-	-	-	5-273	-	-	-	-	-	-	-
Estrone	-	ND-65	-	-	-	-	3.6-69.1	-	-	-	-	18
Estradiol	-	ND-2	-	-	-	-	1.1-10.1	-	-	-	-	-
Ethinylestradiol	-	ND-1	-	-	-	-	ND-1.9	-	-	-	-	0.02
Estriol	-	ND-1	-	-	-	-	-	-	-	-	-	149
Caffeine	-	-	24 (1121446)	-	-	-	-	-	1-1813	-	ND-225	10×10 ⁵
Nonylphenol	-	36-33231	-	-	-	558-2704	115-336	-	-	-	-	330
Bisphenol A	2.1 (87)	6-881	-	-	192-215	55-162	7.5-334	-	-	6-68	-	1000
TCEP	-	-	-	-	<3-184	-	-	-	-	-	-	-
TCPP	-	-	-	-	<4-379	-	-	-	-	-	-	-
Atrazine	-	-	-	-	-	-	-	11 (39)	-	-	-	2000
Diazinon	-	-	-	-	-	-	-	10(216)	-	-	-	-
Diuron	-	-	-	-	-	-	-	72(408)	-	-	-	1800

a. The data presented here represent median concentration with maximum concentration in the brackets;

b. PNEC: Predicted no effect concentration (Data derived from Fromme et al., 2002, Köck-Schulmeyer et al., 2013; Lin et al., 2008 and Loos et al., 2007);

1. Kleywegt et al., 2011; 2. Peng et al., 2008; 3. Sponberg et al., 2011; 4. Vulliet et al., 2011; 5. Regnery and Püttmann, 2010; 6. Reinstorf et al., 2008; 7. Stasinakis et al., 2012; 8. Kim et al., 2009c; 9. Köck-Schulmeyer et al., 2013; 10. Lin et al., 2011; 11. Kasprzyk-Hordern et al., 2009; 12. Wang et al., 2011.

Table 5

Occurrence of selected micropollutants in groundwater from different regions

Compound	Concentrations (ng/L)					PNEC ^c
	Europe ^{a,1}	France ^{b,2}	Germany ^{c,3,4,5}	Spain ^{d,6,7}	US ^{b,c,8,9,10}	
Ibuprofen	3 (395)	0	-	185 (0-185)	ND, 3110	5000
Naproxen	-	1.2	-	204 (145-263)	-	37000
Ketoprofen	26 (2886)	2.8	-	-	-	15.6 × 10 ⁶
Diclofenac	0 (24)	9.7	3050	256 (35-477)	-	10000
Carbamazepine	12 (390)	10.4	<50, 2325	-	40 (420)	25000
Gemfibrozil	-	-	-	165.3 (12-574)	-	100000
Bezafibrate	-	0	112	-	-	-
Atenolol	-	5.5	-	60.8 (18-106)	-	10 × 10 ⁶
Sulfamethoxazole	2 (38)	3.0	-	47.57 (2-117)	1110, 160 (170)	20000
Trimethoprim	-	1.4	-	-	-	1000
Caffeine	13 (189)	-	-	63.56 (4-505)	130, 170 (290)	10 × 10 ⁵
Triclosan	0 (9)	-	-	39.8 (2-118)	53	-
Nonylphenol	83 (3850)	-	-	-	-	330
Bisphenol A	79 (2299)	-	-	-	2550	1000
Estrone	0 (4)	0.7	-	-	79	18
Estradiol	-	0.4	-	-	147	-
Ethinylestradiol	-	1.2	-	-	230	0.02
Estriol	-	-	-	-	1661	149
TCEP	-	-	4-51	-	-	-
TCPP	-	-	14-355	-	-	-
Atrazine	-	-	-	36 (756)	-	2000
Diazinon	-	-	-	5.3 (30.8)	-	-
Diuron	-	-	-	8.8 (178)	-	1800

a. average concentration with maximum concentration in the brackets;

b. average concentration;

c. maximum concentration;

d. average concentration with minimum and maximum concentrations in the brackets.

e. PNEC: Predicted no effect concentration (Data derived from Fromme et al., 2002, Loos et al., 2007 and Lin et al., 2008).

1. Loos et al., 2010; 2. Vulliet and Cren-Olivé, 2011; 3. Maeng et al., 2010; 4. Müller et al., 2012; 5. Stepien et al., 2013; 6. Postigo et al., 2010; 7. Teijon et al., 2010; 8. Barnes et al., 2008; 9. Fram and Belitz, 2011; 10. Karnjanapiboonwong et al., 201

Table 6

Simple classification of micropollutants based on removal efficiency

Degree of removal	Compounds
Poorly removed (<40%)	carbamazepine, metoprolol, diclofenac
Moderately removed (40-70%)	trimethoprim, ketoprofen, clofibric acid, sulfamethoxazole, atenolol, nonylphenol,
Highly removed (>70%)	estrone, bisphenol A, triclosan, naproxen, gemfibrozil, caffeine, ibuprofen

Table 7**Removals of some micropollutants during coagulation-flocculation processes**

Coagulant	Dosage with pH value presented in the parentheses	Compound	Removal (%)	References
FeCl ₃ /Al ₂ (SO ₄) ₃	25, 50 ppm (7)	Ibuprofen	12.0 ± 4.8	Suárez et al., 2009)
		Diclofenac	21.6 ± 19.4	
		Naproxen	31.8 ± 10.2	
		Carbamazepine	6.3 ± 15.9	
		Sulfamethoxazole	6.0 ± 9.5	
		Tonalide	83.4 ± 14.3	
		Galaxolide	79.2 ± 9.9	
FeCl ₃	100, 200 mg/L (4, 7, 9)	Bisphenol A	20	Asakura and Matsuto, 2009
		DEHP*	70	
		Nonylphenol	90	
Al ₂ (SO ₄) ₃	200 mg/L (7)	Aldrin	46	Thuy et al., 2008
	100 mg/L (7)	Bentazon	15	
Not mentioned	Not mentioned	Ibuprofen	4	Matamoros and Salvadó, 2013
		Ketoprofen	4	
		Carbamazepine	2	
		Tonalide	24	
		Galaxolide	16	
		Celestolide	50	
		Triclosan	24	
		DMP	19	
Octylphenol	50			

Table 8

Removals of some micropollutants during adsorption process

Adsorbent	Dosage (mg/L)	Compound	Removal (%)	References		
PAC	8, 23, 43	Diclofenac	96, 98, 99	Kovalova et al., 2013		
		Carbamazepine	98, 99, 100			
		Propranolol	>91, >94, >94			
		Sulfamethoxazole	2, 33, 62			
GAC	Full scale	Diclofenac	>98	Grover et al., 2011		
		Carbamazepine	23			
		Propranolol	17			
		Estrone	64			
		17 β -estradiol	>43			
		17 α -ethinylestradiol	>43			
	29 g/70.6 mL bed volume	Galaxolide	79	Hernández-Leal et al., 2011		
		Tonalide	67			
		Bisphenol A	66			
		Nonylphenol	84			
		Triclosan	95			
		Full scale, empty bed contact time :15 min	Diclofenac		~100	Yang et al., 2011
			Trimethoprim		90	
Carbamazepine	75					
Caffeine	45					
Primidone	30					
		DEET	15			

Table 9

Removals of some micropollutants during ozonation and AOPs

Treatment	Compound	Removal (%)
O ₃ (5 mg/L): 15 min (Sui et al., 2010)	Carbamazepine	>90
	Diclofenac	>90
	Metoprolol	80-90
	Bezafibrate	0-50
	Trimethoprim	>90
	DEET	50-80
O ₃ (15 mg/L) (Hernández-Leal et al., 2011)	Tonalide	79
	Galaxolide	>87
	Nonylphenol	>79
O ₃ (5 mg/L)+H ₂ O ₂ (3.5 mg/L) (Gerrity et al., 2011)	Ibuprofen	83
	Diclofenac	>99
	Carbamazepine	>99
	Sulfamethoxazole	98
	Triclosan	>99
	Bisphenol A	>78
	Estradiol	>83
	Estrone	>98
UV ₂₅₄ : 10 min (De la Cruz et al., 2012)	Ibuprofen	34
	Diclofenac	100
	Carbamazepine	23
	Sulfamethoxazole	51
	Atrazine	69
UV ₂₅₄ + H ₂ O ₂ (50 mg/L): 10min, 30 min (De la Cruz et al., 2012)	Ibuprofen	100 (10 min), 100 (30 min)
	Diclofenac	100 (10 min), 100 (30 min)
	Carbamazepine	75 (10 min), 100 (30 min)
	Sulfamethoxazole	98 (10 min), 100 (30 min)
	Atrazine	100 (10 min), 100 (30 min)

Table 10

Removals of some micropollutants during membrane processes

Membrane	Water type	Membrane conditions	Compound	Removal (%)	Ref
UF	Synthetic water	PES ^a flat-sheet, 100 kDa; TMP = 0.5 ± 0.01 bar	Ibuprofen	7	Jermann et al., 2009
		RC4 ^a flat-sheet; TMP = 0.5 ± 0.01 bar		Minor	
		PES flat-sheet, 100 kDa; TMP = 0.5 ± 0.01 bar	Estradiol	Up to 80	
		RC4 flat-sheet; TMP = 0.5 ± 0.01 bar		Up to 25	
NF	WWTP effluent	Flat-sheet, area 3.5 m ² ; TMP = 0.3 or 0.7 bar	Diclofenac	60	Röhricht et al., 2009; Yangali-Quintanilla et al., 2011
		Flat-sheet, area 3.5 m ² ; TMP = 0.3 or 0.7 bar	Naproxen	60	
		Flat-sheet, area 3.5 m ² ; TMP = 0.3 or 0.7 bar	Carbamazepine	Minor	
		Filmtec NF90; TMP = 345 kPa		91	
		Filmtec NF200; TMP = 483 kPa	Acetaminophen	23	
		Filmtec NF200; TMP = 483 kPa	EE2 ^a	90	
RO	WWTP effluent	-	Ibuprofen	99	Sahar et al., 2011; Yangali-Quintanilla et al., 2011
	Secondary effluent	Filmtec TW30; TMP = 9.5–10.2 bar	Ibuprofen	>99	
		Filmtec TW30; TMP = 9.5–10.2 bar	Sulfonamides	>93	
		Filmtec TW30; TMP = 9.5–10.2 bar	Diclofenac	95	
		Filmtec TW30; TMP = 9.5–10.2 bar	Macrolides	>99	
		Filmtec TW30; TMP = 9.5–10.2 bar	Bisphenol A	>99	

1. Jermann et al., 2009; 2. Röhricht et al., 2009; 3. Yangali-Quintanilla et al., 2011; 4. Sahar et al., 2011

a PES: polyethersulfone; RC: regenerated cellulose; EE2: 17 α -ethynilestradiol

Table 11
Removals of some micropollutants during MBR processes

Water type	Membrane & experimental conditions	Compounds	Removal (%)	References
Raw wastewater	Full-scale HF (Koch Puron)*; MA [#] 235 m ² ; Pore size 0.1-0.2 µm; SRT: 10-15 d; HRT: 1 d; MLSS: 7.5-8.5 g/L	Ibuprofen	~100	Trinh et al., 2012
		Diclofenac	43	
		Carbamazepine	24	
		Sulfamethoxazole	60	
		Trimethoprim	30	
		Estrone,	~100	
		Estriol	~100	
		BisphenolA	~100	
Synthetic wastewater	Lab-scale Polyvinylidene fluoride HF; MA 0.2 m ² ; Pore size 0.4 µm; HRT: 1 d or 3 d; MLSS: 2.3-4.6 g/L	Ibuprofen	~100	Bo et al., 2009
		Diclofenac	Minor	
		Carbamazepine	Minor	
Synthetic wastewater	Lab-scale Polyethylene hollow fibre; MA 0.2 m ² ; Pore size 0.4 µm; HRT: 8, 6 and 4 h; SRT: 350 d; MLSS: 5.2-13.7 g/L	BisphenolA	>93.7	Chen et al., 2008
Hospital effluent	Pilot-scale Submerged PES UF flat sheet; Area 7 m ² ; Pore size 38 nm; SRT: 30-50 d; MLSS: 2 g/L	Carbamazepine	-6	Kovalova et al., 2012
		Trimethoprim	96	
		Sulfamethoxazole	7	
		Atenolol	99	

Synthetic wastewater	Lab-scale submerged HF UF module; MA 0.047 m ² ; Pore size 0.04 μm; SRT:70 d; HRT: 24 h; MLSS: 8.6-10 g/L	Ibuprofen	96.7 ± 0.7	Tadkaew et al., 2011
		Diclofenac	17.3 ± 4.2	
		Carbamazepine	13.4 ± 4.3	
		Sulfamethoxazole	91.9 ± 0.6	
		17β-estradiol	>99.4	
		17α-ethynylestradiol	93.5 ± 1.2	
		Bisphenol A	90.4 ± 3.1	
		Nonylphenol	99.3 ± 0.2	
		Atrazine	4.4 ± 3.7	
Hospital effluent	Full-scale 5 Kubota EK 400 flat sheet; Q 130 m/d	Ibuprofen	>80	Beier et al., 2011
		Carbamazepine	<20	
		Diclofenac	<20	

*hollow fibre; #MA: membrane area.

Table 12

Removals of some micropollutants during attached growth treatment processes

System	Media and experimental conditions	Compound	Removal (%)	References
BAC ^a filter	Media: GAC; Media height: 80cm; Diameter: 22.5 cm; EBCT: 18 min	Diclofenac	~91	Reungoat et al., 2011
		Carbamazepine	~95	
		Sulfamethoxazole	~90	
		Gemfibrozil	~90	
SBBGR ^a	Media: wheel shaped plastic elements	E1	62.2	Balest et al., 2008
		E2	68	
		Bisphenol A	91.8	
ASFBBR ^a	Media: K1 ^a Volume: 1.4 L HRT: 4.3 d, 1 d, 0.3 d	EE2	96 (4.3 d)	Forrez et al., 2009
		EE2	81 (1 d)	
		EE2	74 (0.3 d)	
MBBR ^a	Media: BMBBC ^a Volume: 2.5 L	Bisphenol A	27 ^b	Accinelli et al., 2012
		OC ^a	~15	
		Atrazine	~8	
	Media: K1 Volume: 5 L Batch experiments for 24 hours	Diclofenac	>80	Falås et al., 2013
		Ibuprofen	~100	
		Naproxen	~100	
		Ketoprofen	~100	
	Memfenamic acid	>80		
	Clofibric acid	>60		

a. BAC: biological activated carbon; SBBGR: sequencing batch biofilter granular reactor; ASFBBR: aerated submerged fixed bed bioreactor; MBBR: moving bed biofilm reactor. K1: A type of plastic carrier rings (model K1, AnoxKaldnes, Sweden); BMBBC: Bioplastic-based moving bed biofilm carriers; OC: oseltamivir carboxylate;

b. In this study, only mineralization of the selected compounds was evaluated. Total removal could be higher due to other removal pathway

Table 13

Comparison of micropollutants removal effectiveness in different WWTPs

Compounds	Removals (%) in different types of WWTPs		
	Conventional ¹	Low-cost ²	Advanced ³
Ibuprofen	71 – 99	38 – 99	>35 – 99
Diclofenac	5 – 81	~0 – 88	78 – >99
Ketoprofen	11 – 94	~0 – 88	83 – 99
Carbamazepine	10 – 59	~0 – 51	68 – 99
Estrone	75 – 87	60 – 78	>50 – >99
Bisphenol A	60 – 95	23 – 73	>58 – >98
Nonylphenol	22 – 93	56 – 85	48 – >99

1. Alder et al., 2010; Behera et al., 2011; Céspedes et al., 2008; Choi K. et al., 2008; Gracia-Lor et al., 2012; Janex-Habibi et al., 2009; Kasprzyk-Hordern et al., 2009; Kumar et al., 2010; Martin et al., 2010; Nie et al., 2012; Pothitou and Voutsas, 2008; Santos et al., 2009; Singer et al., 2010; Stasinakis et al., 2008; Yu and Chu, 2009
2. Camacho-Muñoz et al., 2012; Hijosa-Valsero et al., 2010.
3. Gracia-Lor Rosal et al., 2010; Rosal et al., 2010; Schaar et al., 2010; Sui et al., 2010; Yang et al., 2011; Zhou et al., 2010; Zorita et al., 2009;

Table 14

Assessment of different treatment processes for micropollutants removal

Technique	Common removal efficiency ^a				Major factors		Disadvantage/problems	Residues
	P	PCP	SH	IC	Process-specific	MP-related		
Coagulation	L-M	M-H	L	L-H	<ul style="list-style-type: none"> • Dosage • pH • wastewater composition 	<ul style="list-style-type: none"> • Hydrophobicity • Molecular size 	<ul style="list-style-type: none"> • Ineffective MP removal • Large amount of sludge • Introduction of coagulant salts in the aqueous phase 	Sludge
AC	M-H	M-H	H	M-H	<ul style="list-style-type: none"> • Adsorbent properties • Dosage • Contact time • pH 	<ul style="list-style-type: none"> • Hydrophobicity • Molecular size • Structure • Functional group 	<ul style="list-style-type: none"> • Relatively high financial costs • Lower efficiency in the presence of NOMs • Need for regeneration • Disposal of used carbon 	Used material
Ozonation and AOPs	M-H	M-H	H	M-H	<ul style="list-style-type: none"> • Dosage • pH • interfering ions (e.g., Br⁻) • wastewater composition 	<ul style="list-style-type: none"> • Compound structure 	<ul style="list-style-type: none"> • High energy consumption • Formation of byproducts • Interference of radical scavengers 	Residual oxidants
NF	M-H	H	M-H	M-H	<ul style="list-style-type: none"> • Membrane properties • pH • transmembrane pressure • feed quality 	<ul style="list-style-type: none"> • Hydrophobicity • Molecular size 	<ul style="list-style-type: none"> • High energy demand • Membrane fouling • Disposal of concentrate • Desorption of sorbed chemicals from membrane 	Concentrate

RO	M-H	H	H	H	<ul style="list-style-type: none"> • Membrane properties • pH • transmembrane pressure • feed quality 	<ul style="list-style-type: none"> • Hydrophobicity • Molecular size 	<ul style="list-style-type: none"> • High energy consumption • Disposal of concentrate • Corrosive nature of the finished water 	Concentrate
Activated sludge	L-H	M-H	M-H	L-H	<ul style="list-style-type: none"> • SRT • HRT • Organic loading • Redox conditions 	<ul style="list-style-type: none"> • Hydrophobicity • Biodegradability 	<ul style="list-style-type: none"> • Micropollutants sorbed onto sewage sludge may increase the environmental risk • Disposal of sludge 	Wasted sludge
MBR	L-H	M-H	H	M-H	<ul style="list-style-type: none"> • SRT • HRT • Organic load • Redox conditions 	<ul style="list-style-type: none"> • Hydrophobicity • Biodegradability 	<ul style="list-style-type: none"> • Moderately high energy consumption • Inconsistent removal of polar and resistant compounds • Membrane fouling • Micropollutants tend to sorb less onto the aged MBR sludge 	Wasted sludge
Attached growth	L-H	M-H	M-H	M-H	<ul style="list-style-type: none"> • HRT • Organic loading • Redox conditions 	<ul style="list-style-type: none"> • Hydrophobicity • Biodegradability 	<ul style="list-style-type: none"> • Long start-up time • Difficulty in control of biofilm thickness 	Wasted sludge

a. P: pharmaceutical; PCP: personal care product; SH: steroid hormone; IC: industrial chemical; L: low; M: medium; H: high