

Original citation:

Tamainot-Telto, Zacharie (2016) New approach in adsorption reactor design for refrigeration and heat pump applications. In: Qatar Foundation Annual Research Conference (ARC'16), Qatar , 22-23 Mar 2016. Published in: Qatar Foundation Annual Research Conference Proceedings, 2016 (1). EEP2795.

Permanent WRAP URL:

<http://wrap.warwick.ac.uk/79784>

Copyright and reuse:

The Warwick Research Archive Portal (WRAP) makes this work of researchers of the University of Warwick available open access under the following conditions.

This article is made available under the Creative Commons Attribution 3.0 (CC BY 3.0) license and may be reused according to the conditions of the license. For more details see:

<http://creativecommons.org/licenses/by/3.0/>

A note on versions:

The version presented in WRAP is the published version, or, version of record, and may be cited as it appears here.

For more information, please contact the WRAP Team at: wrap@warwick.ac.uk

ARC '16

مؤتمر مؤسسة قطر
السنوي للبحوث
QATAR FOUNDATION
ANNUAL RESEARCH
CONFERENCE



Towards World-class
Research and Innovation

Energy and Environment Pillar

<http://dx.doi.org/10.5339/qfarc.2016.EEPP2795>

New Approach in Adsorption Reactor Design for Refrigeration and Heat Pumps Applications

Zacharie Tamainot-Telto

University of Warwick - School of Engineering - UK, GB

Email: z.tamainot-telto@warwick.ac.uk

Abstract

Most adsorbents used in reactors of adsorption refrigeration and heat pump systems are often initially manufactured for different applications namely drinking water treatment, waste water treatment, gas storage, gas and liquid filtration or separation in industrial processes, dehumidification process. Furthermore there will be a requirement of mapping of refrigerant specific uptake against operating conditions mainly temperatures and pressure: this will require to a large number of experimental data for the pair studied (adsorbent-refrigerant) characterisation. Therefore, the adsorbents found in the market will not necessary offer optimum performance for adsorption refrigeration and heat pumps applications. In order to address this issue and in the prospect of manufacturing specific activated carbon adsorbent, a research work is carried out at Warwick University with the objective of screening a large number adsorbent models (more than 60,000) and identifying suitable ones with optimum characteristics for three applications: Ice marking (TC=35°C, TE=-5°C), Air conditioning (TC=35°C, TE=15°C) and Heat pump (TC=40°C, TE=5°C). For each application, the driving temperature will range from 90°C to 250°C. The method consists of using Dubinin-Astakhov modified equation [1] and establishing the maximum refrigerant uptake variation for each application. For this purpose the three key parameters of adsorbent-refrigerant will be varied: x_0 (maximum uptake of refrigerant by the adsorbent in kg refrigerant per kg of adsorbent) from 0 to 1; K (energetic affinity characteristic of adsorbent-refrigerant pair) from 1 to 50 and n (characteristic of adsorbent micro-pores size distributions) varies from 0 to 6. Overall, the preliminary simulation results show that for each adsorbent model with each application, the refrigerant uptake variation has an optimum (Figure 1). Furthermore and as expected at high temperature, those optima values are tailed off by the maximum uptake of refrigerant x_0 (Figure 2): it is therefore appropriate and practical to consider 90% to 95% of the value for n and K selection. Figure 3 is an illustration of

Cite this article as: Tamainot-Telto Z. (2016). New Approach in Adsorption Reactor Design for Refrigeration and Heat Pumps Applications. Qatar Foundation Annual Research Conference Proceedings 2016: EEPP2795 <http://dx.doi.org/10.5339/qfarc.2016.EEPP2795>.

specific cooling capacity for Air conditioning application. Future simulation work will also include evaluation of both heat desorption and heat of adsorption therefore the coefficient of performance (COP). Before any attempting of manufacturing any sample of a given model of activated carbon, further additional work will include simulation performance of a full model of adsorption refrigeration and heat pump systems already available [2, 3].

References

- [1] Z. Tamainot-Telto, S.J. Metcalf, R.E. Critoph, Y. Zhong, R.N. Thorpe, "Carbon-Ammonia pairs for adsorption refrigeration applications: ice making, air conditioning and heat pumping", *International Journal of Refrigeration*, 32 (6), pp. 1212–1229, ISSN 0140–7007 (2009).
- [2] Z. Tamainot-Telto, S.J. Metcalf, R.E. Critoph, Novel compact sorption generators car air conditioning, *International Journal of Refrigeration*, 32 (4), pp. 727–733, ISSN 0140–7007 (2009).
- [3] S.J. Metcalf, R.E. Critoph, Z. Tamainot-Telto - Optimal cycle selection in carbon-ammonia adsorption cycles - *International Journal of Refrigeration*, 35 (3), pp. 571–580, ISSN: 0140–7007 (2012).