



Central Solar (District) Heating Plants

Heller, Alfred; Sørensen, Per Alex

Publication date:
2014

Document Version
Publisher's PDF, also known as Version of record

[Link back to DTU Orbit](#)

Citation (APA):

Heller, A., & Sørensen, P. A. (2014). Central Solar (District) Heating Plants. Poster session presented at CITIES Annual Conference, Kgs. Lyngby, Denmark.

DTU Library

Technical Information Center of Denmark

General rights

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain
- You may freely distribute the URL identifying the publication in the public portal

If you believe that this document breaches copyright please contact us providing details, and we will remove access to the work immediately and investigate your claim.

Central Solar (District) Heating Plants

Alfred Heller ¹⁾ Per Alex Sørensen ²⁾

¹⁾Civil Engineering Department, Technical University of Denmark

²⁾PlanEnergi Denmark

Introduction

Denmark has a leading tradition for large-scale solar heating connected to district heating, short CSHP. Such plants can include any type and size of seasonal storage, whereas the pit water storage seems to be the cheapest and most promising thermal storage technology for large-scale applications.

In 2012 a first full scale demonstration was presented in Marstal, Denmark. Today the plant is grown to over 33.000 m² of solar collector and a storage capacity of over 85,000 m³ pit water storage..

District Heating in Denmark

In Denmark, DH has been actively promoted as an important component in the national strategic energy planning. Denmark has 670 CHP plants and 77% of total DH and 55% of electricity come from CHP plants (Fig 2). Over 50% of total heating supply in Denmark comes from DH and around 62% of residential buildings connect with DH.



Fig. 1: Central Solar Heating Plants (CSHP) in Denmark




Fig. 2: CHP plants in Denmark

The overall plant schema

The SUNSTORE Plant in Marstal




Fig. 3: The plant layout, schematically, collector array (loop), storage loop, boiler loop and district heating loop.

The basic configuration of central solar heating systems and its connection to the district heating is shown in (Fig. 3).

The collector field involving anti-freeze liquids. Hence a heat exchanger is necessary to deliver the heat to the district heating loop.



Fig. 4: Examples of solar fields: (a) Terrain mounted, (b) solar field, (c) roof mounted: Source: <http://www.solar-district-heating.eu>

The heat store



Fig. 5: The plant with storage under construction.

World larges pit water storage is present at the Marstal:

- Built 2011-12
- Size: 75,000 m³ water
- Price 2.65 mio. € excl. transmission pipe or 35.5 €/m³ or 0.38 €/kWh
- Temperatures 10 – 90°C
- Capacity: 6,960 MWh
- Charge and discharge capacity: 10.5 MW
- Calculated heat loss: 2,475 MWh/year

The Floating Lid Construction

The insulated lid is floating on the water surface avoiding a static construction and hereby a very cheap solution. (Fig. 6).

PE Foam Insulation and HDPE Liner




Fig. 6: The floating lid construction.



Fig. 7: Pit construction: (a) digging (b) establishing shape (c) lining with plast foil. Source: <http://www.solar-district-heating.eu>

The Heat Pump




Fig. 7: The system layout.




Fig. 8: Efficiency of heat pump.

There are involved 2 heat pumps as shown in (Fig. 7)

	MWh/year
9,000 m ²	3,383
9,300 m ²	3,727
15,000 m ²	6,435
Collectors total	13,545
Propane heat pump	214
CO2 heat pump	1,043
Heat pump total	1,257
ORC	12,023
Scrubber	4,008
Wood chip total	16,031
2,100 m ³	-119
10,000 m ³	-520
75,000 m ³	-2,193
Store losses total	-2,833
Bio oil	4,000
Total	32,001

Fig. 9: Production data – computations.

Heat pumps are utilized for half of the year in winter periods with no seasonal storage, or low temperature in storage.

Energy flow diagram | Year 2013

- Solar fraction: 34 %
- Biomass fraction: 52 %
- RES fraction: 90 %




Fig. 10: The system layout. Source: Schmidt T., "Sunstore 4, Monitoring results 2013.

Energy balance for the year 2013 monitored. The solar share is 34% even with a large-scale seasonal storage. Flexibility opportunities are very large.

Further Information

A European Cooperation with web site: <http://www.solar-district-heating.eu>
Project Sunstore 4: <http://sunstore4.eu/newsroom/events-presentations/>
Web Blog: <http://centralsolarheating.wordpress.com/>

Contact Information

Alfred Heller
Assoc. Prof., Ph.D.
Vice Centre Manager, CITIES

Civil Engineering Department
Technical University of Denmark
Denmark

T: 45 4525 5025
E: alfh@byg.dtu.dk
W: <http://www.byg.dtu.dk/>