

Thermal environment in simulated offices with convective and radiant cooling systems under cooling (summer) mode of operation - DTU Orbit (08/11/2017)

Thermal environment in simulated offices with convective and radiant cooling systems under cooling (summer) mode of operation

The thermal environment in a double office room and in a six-person meeting room obtained with chilled beam (CB), chilled beam with radiant panel (CBR), chilled ceiling with ceiling installed mixing ventilation (CCMV) and four desk partition-mounted local radiant cooling panels with mixing ventilation (MVRC) under summer (cooling) condition was compared. MVRC system was measured only for the office room case. CB provided convective cooling while the remaining three systems (CBR, CCMV and MVRC) provided combined radiant and convective cooling. Solar radiation, office equipment, lighting and occupants were simulated to obtain two different heat load conditions: 38 W/m^2 and 64 W/m^2 in the case of office room, and 71 W/m^2 and 86 W/m^2 in the case of meeting room. Air temperature, globe (operative) temperature, radiant asymmetry, air velocity and turbulent intensity were measured and draught rate calculated. Manikin-based equivalent temperature (MBET) was determined by using two thermal manikins to identify the impact of the local thermal conditions generated by the studied systems on occupants' thermal perception. The results revealed that the differences in the thermal conditions achieved with the four systems were not significant. CB and CBR provided slightly higher velocity level in the occupied zone. The operative temperature in the studied cases with chilled ceiling in operation with mixing ventilation was almost the same as the operative temperature obtained with the active chilled beam (i.e. only convective cooling). The heat load distribution played major role for the airflow pattern in all studied systems.

General information

State: Published

Organisations: Department of Civil Engineering, Section for Indoor Climate and Building Physics, Halton OY, Aalto University

Authors: Mustakallio, P. (Ekstern), Bolashikov, Z. D. (Intern), Kostov, K. (Ekstern), Melikov, A. K. (Intern), Kosonen, R. (Ekstern)

Number of pages: 10

Pages: 82-91

Publication date: 2016

Main Research Area: Technical/natural sciences

Publication information

Journal: Building and Environment

Volume: 100

ISSN (Print): 0360-1323

Ratings:

BFI (2017): BFI-level 1

Web of Science (2017): Indexed yes

BFI (2016): BFI-level 1

Scopus rating (2016): CiteScore 4.51 SJR 2.015 SNIP 2.198

Web of Science (2016): Indexed yes

BFI (2015): BFI-level 1

Scopus rating (2015): SJR 2.093 SNIP 2.49 CiteScore 4.37

Web of Science (2015): Indexed yes

BFI (2014): BFI-level 1

Scopus rating (2014): SJR 1.938 SNIP 2.797 CiteScore 4.14

Web of Science (2014): Indexed yes

BFI (2013): BFI-level 1

Scopus rating (2013): SJR 1.581 SNIP 2.602 CiteScore 3.57

ISI indexed (2013): ISI indexed yes

Web of Science (2013): Indexed yes

BFI (2012): BFI-level 1

Scopus rating (2012): SJR 1.331 SNIP 2.875 CiteScore 3.06

ISI indexed (2012): ISI indexed yes

Web of Science (2012): Indexed yes

BFI (2011): BFI-level 1

Scopus rating (2011): SJR 1.144 SNIP 2.255 CiteScore 2.76

ISI indexed (2011): ISI indexed yes

Web of Science (2011): Indexed yes

BFI (2010): BFI-level 1

Scopus rating (2010): SJR 1.235 SNIP 2.001

Web of Science (2010): Indexed yes

BFI (2009): BFI-level 1

Scopus rating (2009): SJR 1.028 SNIP 1.865

Web of Science (2009): Indexed yes

BFI (2008): BFI-level 1

Scopus rating (2008): SJR 0.924 SNIP 1.38

Web of Science (2008): Indexed yes

Scopus rating (2007): SJR 0.788 SNIP 1.778

Web of Science (2007): Indexed yes

Scopus rating (2006): SJR 1.03 SNIP 1.63

Scopus rating (2005): SJR 0.955 SNIP 1.225

Web of Science (2005): Indexed yes

Scopus rating (2004): SJR 0.548 SNIP 1.266

Scopus rating (2003): SJR 0.948 SNIP 0.921

Web of Science (2003): Indexed yes

Scopus rating (2002): SJR 0.998 SNIP 1.39

Web of Science (2002): Indexed yes

Scopus rating (2001): SJR 0.777 SNIP 1.098

Scopus rating (2000): SJR 0.526 SNIP 1.14

Scopus rating (1999): SJR 0.564 SNIP 1.175

Original language: English

Physical measurements, Chilled beam, Chilled ceiling, Radiant cooling, Convective cooling, Mixing ventilation, Thermal comfort, Office workplace

DOIs:

10.1016/j.buildenv.2016.02.001

Source: FindIt

Source-ID: 2291805300

Publication: Research - peer-review › Journal article – Annual report year: 2016