

archive

COMPUTER OPTIMIZATION OF THE MIT ADVANCED
WET/DRY COOLING TOWER CONCEPT FOR POWER PLANTS

by

Michael Choi
Leon R. Glicksman

Energy Laboratory Report No. MIT-EL 79-035
Heat Transfer Laboratory Report No. 87162-102
September 1979

COMPUTER OPTIMIZATION OF THE MIT ADVANCED WET/DRY
COOLING TOWER CONCEPT FOR POWER PLANTS

by

Michael Choi

Leon R. Glicksman

Energy Laboratory
and
Heat Transfer Laboratory
Department of Mechanical Engineering
Massachusetts Institute of Technology
Cambridge, Massachusetts 02139

Prepared under the support of the
Environmental Control Technology Division
Office of the Assistant Secretary for the Environment

U.S. Department of Energy
Contract No. EY-76-S-02-4114.A001

Energy Laboratory Report No. MIT-EL 79-035
Heat Transfer Laboratory Report No. 87162-102

September 1979

Abstract

There is a projected water shortage problem in the electrical power industry by the end of this century. Dry and wet-dry cooling towers are going to be the solution of this problem. Our previous study on the combination of separate dry and wet cooling towers indicated that wet-dry cooling is an economical choice over all-dry cooling when some water is available but the supply is insufficient for an evaporative tower. An advanced wet-dry cooling tower concept was experimentally studied at MIT's Heat Transfer Laboratory and a computer model was developed for predicting the performance of this cooling concept. This study has determined the cost of the cross-flow type of this cooling concept in conjunction with steam electrical power plants. Aluminum is found to be economically preferable to galvanized steel as the cooling plate material. In our base case study using aluminum plates for a 1094 MWe nuclear plant at Middletown, the MIT advanced cooling concept is comparable to conventional wet-dry towers at water makeups larger than 45% and is slightly more economical at makeup larger than 50%. The incremental costs over the power production cost, 32.3 mills/Kwhr, of zero condenser system are 14, 13 and 12 percent for makeups of 45, 60 and 55 percent, respectively. For an 800 MWe fossil plant at Moline, this cooling concept is more economical than conventional wet-dry towers at water makeups larger than 27%. The incremental costs over 20.8 mills/Kwhr of zero condenser system are 12.2 and 10.6 percent for makeups of 37 and 50 percent, respectively. For these two makeups, going from conventional wet-dry to MIT advanced concept results in 13 and 21 percent, respectively, savings in the incremental cost. When the water makeup exceeds 30%, the MIT advanced wet-dry concept is preferable to conventional wet-dry towers for a 1200 MWe nuclear plant at Moline, Ill. The incremental costs over zero condenser system of 21.1 mills/Kwhr are 12.8 and 11.5 percent for makeups of 40 and 50 percent, respectively. Using the MIT advanced concept instead of conventional wet-dry towers results in 28 and 33 percent reduction of incremental power production cost for these two makeups, respectively.

ACKNOWLEDGMENTS

This report is part of an interdisciplinary effort by the MIT Energy Laboratory to examine issues of power plant cooling system design and operation under environmental constraints. The effort has involved participation by researchers in the R.M. Parsons Laboratory for Water Resources and Hydrodynamics of the Civil Engineering Department and the Heat Transfer Laboratory of the Mechanical Engineering Department. Financial support for this research effort has been provided by the Division of Environmental Control Technology, U.S. Dept. of Energy, under Contract No. EY-76-S-02-4114.A001. The assistance of Dr. William Mott, Dr. Myron Gottlieb and Mr. Charles Grua of DOE/ECT is gratefully acknowledged. Reports published under this sponsorship include:

"Computer Optimization of Dry and Wet/Dry Cooling Tower Systems for Large Fossil and Nuclear Plants," by Choi, M., and Glicksman, L.R., MIT Energy Laboratory Report No. MIT-EL 79-034, February 1979.

"Computer Optimization of the MIT Advanced Wet/Dry Cooling Tower Concept for Power Plants," by Choi, M., and Glicksman, L.R., MIT Energy Laboratory Report No. MIT-EL 79-035, September 1979.

"Operational Issues Involving Use of Supplementary Cooling Towers to Meet Stream Temperature Standards with Application to the Browns Ferry Nuclear Plant," by Stolzenbach, K.D., Freudberg, S.A., Ostrowski, P., and Rhodes, J.A., MIT Energy Laboratory Report No. MIT-EL 79-036, January 1979.

"An Environmental and Economic Comparison of Cooling System Designs for Steam-Electric Power Plants," by Najjar, K.F., Shaw, J.J., Adams, E.E., Jirka, G.H., and Harleman, D.R.F., MIT Energy Laboratory Report No. MIT-EL 79-037, January 1979.

"Economic Implications of Open versus Closed Cycle Cooling for New Steam-Electric Power Plants: A National and Regional Survey," by Shaw, J.J., Adams, E.E., Barbera, R.J., Arntzen, B.C., and Harleman, D.R.F., MIT Energy Laboratory Report No. MIT-EL 79-038, September 1979.

"Mathematical Predictive Models for Cooling Ponds and Lakes," Part B: User's Manual and Applications of MITEMP by Octavio, K.H., Watanabe, M., Adams, E.E., Jirka, G.H., Helfrich, K.R., and Harleman, D.R.F.; and Part C: A Transient Analytical Model for Shallow Cooling Ponds, by Adams, E.E., and Koussis, A., MIT Energy Laboratory Report No. MIT-EL 79-039, December 1979.

"Summary Report of Waste Heat Management in the Electric Power Industry: Issues of Energy Conservation and Station Operation under Environmental Constraints," by Adams, E.E., and Harleman, D.R.F., MIT Energy Laboratory Report No. MIT-EL 79-040, December 1979.

Table of Contents

	<u>Page</u>
Abstract	ii
Acknowledgements	iii
Table of Contents	v
CHAPTER 1	4
1.1 Introduction	4
1.2 Scope of this Study	6
1.3 Outline of Presentation	6
CHAPTER 2	7
2.1 Method of Analysis	7
2.2 Plant Model	7
2.3 Base Economic Factors	7
2.4 Meteorological Condition	7
CHAPTER 3	9
3.1 Method of Analysis	9
3.2 Plant Model	9
3.3 Base Economic Factors	9
3.4 Meteorological Conditions	9
CHAPTER 4 MIT Advanced Wet/Dry Cooling Tower System Model	11
4.1 Introduction	11
4.2 Packing Plates	16
4.3 Evaluation of Off-Design Tower Performance	16
CHAPTER 5 Optimization Procedure	17
5.1 Optimization Procedure	17
CHAPTER 6 Results of Optimization	19
6.1 Results for Middleton using United Engineers Approach and Base Economic Factors	19
6.2 Results of Optimization for the Moline Site	22
6.3 Wet Topping	33
CHAPTER 7 Comparison with United Engineer's Study	34
CHAPTER 8 Sensitivity Study	38
CHAPTER 9 Conclusions and Recommendations	39

	<u>Page</u>
CHAPTER 9 Conclusions and Recommendations	39
9.1 Conclusions	39
9.2 Recommendations	40
9.3 Acknowledgement	40
References	41
Appendix A Plate Cost	42
Appendix B Computer Program Listing	43

Chapter 1

1.1 Introduction

A modern-day fossil-fueled electrical power plant has an efficiency of about 40%; approximately one-half of the heat from the fuel burnt in the boiler is rejected to the circulating water. The efficiency of a Pressurized Water Reactor or Boiling Water Reactor nuclear power plant is about 33%; two-thirds of the nuclear heat generated is rejected as waste heat. Therefore, in the electrical power industry, the amount of waste heat discharged to the environment is enormous, and this must be handled safely, economically and without causing damage to the environment.

For power plants located at a river, ocean or lake where large quantities of water are available, once-through cooling is often employed. In once-through cooling, the hot water from the condenser is discharged into the waterway, resulting in an increase of water temperature which may have adverse effects on the ecology of the water bodies.

Conventionally, when water is not sufficient for once-through cooling, evaporative towers are used. The circulating hot water is broken into small droplets by splashing it down the fill in the cooling tower. More than 75% of the heat rejection is by evaporation. One major disadvantage of evaporative towers is the consumption of a huge amount of water. A 1000 MWe LWR nuclear plant operating at rated load with an evaporative tower requires about 20,000,000 gallons of make-up water every twenty-four hours [6].

Because of high cost, dry cooling towers have not been broadly used by the utility in the United States. By supplementing the dry towers with evaporative towers the cost of all-dry cooling can be significantly reduced. The first wet-

dry towers have been purchased by Public Service Co, of New Mexico for use at their San Juan site. These units, 450 MWe each, are designed to save 60% of the water consumed by evaporative cooling towers.

Several years ago ERDA (now the DOE) sponsored a study by Westinghouse Hanford Co. to determine the regional requirements for dry cooling. The study concluded that there are economic alternatives to dry and wet-dry cooling up to 1990. From 1990 to 2000, the combined effects of restrictions on coastal siting, state regulations of the purchase and transfer of water rights from agriculture or other uses to cooling supply, together with the rapid and continuous growth in electricity demands, will have the potential of bringing wet-dry or dry cooling to increased use. Nationally, a total of 21,000 to 39,000 MWe will require dry or wet-dry cooling at that time [7].

The development of the MIT advanced wet-dry cooling concept is to meet such needs. Although this concept was experimentally studied in the past several years, no cost optimization was done at MIT. United Engineers [2] has performed cost optimization on this MIT concept and reported that this concept is comparable to conventional wet-dry towers only at water makeup of about 50%. However, neither tower performance nor detailed comparison between aluminum and steel were reported. In our present work attempt has been made to compare our results with those of United Engineers. Since it is difficult to compare the results of one study to another if the method of analysis, economic factors and site meteorological conditions differ, effort has been made to use these the same as the United Engineers in our computer program. However, cost algorithms of most cooling components are those originally in our program [1]. In addition, the detailed information of the cost of the cooling plates has now

been added. Aluminum is about 25% more expensive than galvanized steel. Detailed cost data are given in the Appendix A.

1.2 Scope of This Study

The cost optimization of the MIT advanced wet/dry for a LWR nuclear plant at the Middletown site was performed so that comparisons can be made between the results of this study and those reported by United Engineers [2]. In addition, our present work also covers the economic optimization of this cooling concept in both fossil and nuclear power plants at the Moline site. Economics of the advanced MIT wet-dry concept will be compared to conventional wet-dry towers. This is a continuation of our previous study prepared for the Division of Environmental Control Technology, U.S. Department of Energy.

1.3 Outline of Presentation

The material in this report is presented in the following sequence. Chapter 2 is a presentation of power plant model, method of analysis and basic economic factors for the Middletown site. These are reported in Chapter 3 for the Moline site. Chapter 4 presents the MIT advanced wet/dry cooling tower model. The optimization procedures are given in Chapter 5 and the results are reported in Chapter 6. Chapter 7 compares the results of this study with the United Engineers. A sensitivity study of the effect of plate cost on the economic optimization is presented in Chapter 8. Finally, Chapter 9 gives conclusions and recommendations.

Chapter 2

This chapter presents the power plant model, method of analysis and base case economic factors for the Middletown site. These are the same as those used by United Engineers [2].

2.1 Method of Analysis

The method of analysis is a fixed steam source and fixed demand approach. It assumes a constant heat source of 3173 MWT to be coupled to a conventional low back pressure steam turbine and there is a fixed demand of electrical output from the power plant. The reference plant is assumed to operate at 2 inch HgA all year round with an output of 1094 MWe which is then assumed to be the fixed demand. Any deficit between the plant net capacity and the fixed demand is replaced by incremental base load plant. No load profile is scheduled for the power plant. It assumes that the average annual capacity factor is 75%.

2.2 Plant Model

The nuclear power plant assumed for the cooling system evaluation at Middletown is a Light Water Reactor (LWR). As mentioned in the previous section the steam source is fixed and is coupled to a low back pressure turbine. The turbine-generator is a General Electric Tantom Compound Six Flow (TC6F) 38" turbine. The turbine inlet steam condition is 965 psig saturated. The full-load turbine net heat rate vs. exhaust pressure is plotted in Fig. 2.1.

2.3 Base Economic Factors

The base economic factors for the Middletown site are given in Table 2.1. All the costs are in 1985 dollars.

2.4 Meteorological Condition

The dry bulb and wet bulb temperature distributions at the Middletown site are shown in Fig. 2.2.

Table 2.1 Base Case Economic Factors
for Middletown

Year of Pricing	1985
Power Plant Cost	\$600/KW
Fuel Cost	\$1.53/MM BTU
Fixed Charge Rate	18%
Average Annual Capacity Factor	75%
Capacity Penalty (Incremented Base Load Plant)	\$600/KW
Energy Penalty (Base Load Plant Fuel Cost)	\$1.53/MM BTU
Water Cost	27¢/1000 gallons
Indirect Cost	25% of direct capital cost

FIG. 2.1
NET HEAT RATE VS. EXHAUST PRESSURE FOR 3173 MWt NUCLEAR TURBINE





FIG. 2.2

DRY BULB AND WET BULB TEMPERATURE DISTRIBUTIONS AT MIDDLETOWN SITE



Chapter 3

The power plant model, method of analysis and base economic factors for the Moline site are presented in this chapter.

3.1 Method of Analysis

The method of analysis is a constant steam source and fixed demand approach. It assumes a constant heat source to be coupled to a low back pressure turbine. This heat source is 1862 MWt for the fossil plant and 3577 MWt for the nuclear plant. There is a fixed demand of electrical output from the power plant. This is 800 MWe for the fossil plant and is 1200 MWe for the nuclear plant. Any deficit between the net plant capacity and the fixed demand is replaced by gas turbines. There is no load profile scheduled for the power plant. The annual capacity factor is 75%.

3.2 Plant Model

The nuclear plant assumed for the cooling system evaluation is a Boiling Water Reactor (BWR). The turbine-generator is a General Electric TC6F-38 turbine with its full-load net heat rate vs. exhaust pressure shown in Fig. 3.1. The turbine inlet steam condition is 965 psig saturated. The fossil plant is assumed to be coal-fired. Its turbine-generator is a General Electric Cross Compound Six Flow (CC6F) with reheat cycle; its inlet steam conditions are 3500 psig 1000^oF/1000^oF. The full-load net heat rates vs. exhaust pressure of the fossil turbine is shown in Fig. 3.2.

3.3 Base Economic Factors

The base economic factors for the Moline site are given in Table 3.1. All the costs are in 1977 dollars.

3.4 Meteorological Conditions

The dry bulb and wet bulb temperature distributions at Moline are shown in Fig. 3.3.

Table 3.1 Base Economic Factors
for Moline

Year of Pricing	1977
Power Plant Cost:	
Fossil	\$500/KW
Nuclear	\$600/KW
Fuel Cost:	
Fossil (coal)	\$0.90/MM BTU
Nuclear	\$0.47/MM BTU
Fixed Charge Rate	17%
Annual Capacity Factor	75%
Replacement Capacity (gas turbines)	\$160/KW
Replacement Energy (gas turbines)	30 mills/KWhr
Operation and Maintenance	1% of all capital costs
Indirect Cost	20% of direct capital cost
Water Cost	20¢/1000 gallons

NET HEAT RATE VS. EXHAUST PRESSURE FOR 1862 MW FOSIL TURBINE




FIG. 3.1

NET HEAT RATE VS. EXHAUST PRESSURE FOR 3577 MWT NUCLEAR TURBINE





FIG. 3.2

FIG. 3.3

CUMULATIVE DISTRIBUTIONS OF DRY BULB AND WET BULB TEMPERATURES AT MOLINE SITE



Chapter 4

MIT Advanced Wet/Dry Cooling Tower System Model

4.1 Introduction

In this study the MIT advanced wet/dry cooling tower system is taken to be an indirect type with surface condensers and tower heat exchangers are packing plates with V-shape water troughs. The air flow in the cooling tower is mechanically induced by fans. The piping system is considered in detail. The various components of the cooling tower system are shown in Fig. 4.1.

Condensation of turbine exhaust steam takes place at the saturated steam temperatures corresponding to a given turbine exhaust pressure. The condensate is returned to the feedwater circuit. Cooling water entering the condenser at a temperature T_1^W is heated to a temperature T_2^W on leaving the condenser. The difference between the saturated steam temperature and the hot water temperature is the terminal temperature difference (TTD). The temperature difference between T_1^W and T_2^W is the water range. On leaving the condenser, the hot water is circulated through the piping system to the wet/dry tower. The plates are folded at the top to direct water into the V-troughs and prevent water from wetting the fins [4,8]. This is illustrated in Fig. 4.6 on the header plate into the V-shape troughs running from the top to the bottom of the plates. The plates are tilted at 10° to the vertical so that the water flows down the troughs under gravity.

Evaporation takes place at the air-water interface. Furthermore, convective heat transfer takes place on the dry plate surface where air flows across the plate. On the wetted side of the plates, the dry surface is

roughened with flow disturbers which serve two purposes. First, they break up the boundary layers to increase the heat transfer coefficient and second, they direct the air-water mixing at both ends of the plates back to the troughs.

Because the MIT advanced wet/dry tower has only a single structure, no infinite control of water and air flow rates is required. This is an important advantage over the conventional wet-dry towers which consist of separate wet and dry towers.

The difference between the temperature of the hot water entering the cooling tower and the dry bulb temperature of the incoming ambient air is the initial temperature difference (ITD). After cooling, the water is collected in a water basin and returned to the condenser. The difference between the cool water temperature, T_1^w , and the ambient wet bulb temperature is the approach. The temperature relationships are illustrated in Fig. 4.2

The wet/dry towers considered in this study are circular in shape. The cooling plates are arranged around the base of the towers. These are illustrated in Fig. 4.3.

Crossflow is preferable to counterflow because of the water-air mixing above and below the plates in the latter which could increase the water evaporation. Therefore, only the crossflow type of this cooling concept is considered in this study.

Han's correlations [3] are employed in determining the heat transfer coefficient and friction factor for the roughened surface of the cooling

plates. They are the following:

$$e^+ = \frac{e \operatorname{Re}}{D_h \sqrt{2/f}}$$

$$\operatorname{Re}^+ = \frac{1}{\sqrt{2f}} - 2.5 \ln \frac{2e}{D_h} - 3.75$$

$$\operatorname{Re}^+ * \frac{10}{P/e} (\phi/90)^n (\alpha/45)^{0.35} (\alpha/45)^{0.57} = 4.9 (e^+/35)^m$$

$$\text{where } m = \begin{cases} -0.4 & \text{for } e^+ < 35 \\ 0 & \text{for } e^+ \geq 35 \end{cases}$$

$$n = \begin{cases} 0.13 & \text{for } P/e < 10 \\ 0.53 (\alpha/90)^{0.71} & \text{for } P/e \geq 10 \end{cases}$$

and where Re = Reynold's number

ρ = density of air

μ = viscosity of air

V = air velocity

D_h = hydraulic diameter

f = friction faction

e = right height

P = pitch of ribs

α = angle of attack

and ϕ = angle of inclination of ribs

For $e^+ > 35$, then $H^+ = C \left(\frac{e^+}{35}\right)^{0.28}$

where C - constant which depends on the surface characteristics

The Stanton number is given by:

The Nusselt number is given by:

$$Nu = 0.72 St Re$$

Heat transfer coefficient $h = Nu k / D_h$

where k = conductivity of air.

Note that each cooling plate has two distinct sides. On the wetted side, the ribs are the flow separators. On the unwetted side, the protrusions of the V-troughs naturally become ribs themselves. Therefore, there are two different convective heat transfer coefficients, one for each side of the plate. Similarly, this is also true for the friction factor. In this study the overall convective heat transfer coefficient is taken to be the mean value. The friction factor is the mean friction factors.

In the above correlations, we have the following:

$$e = \begin{cases} 0.25 \text{ inch for the wetted side} \\ 0.2706 \text{ inch for the unwetted side} \end{cases}$$

$$\alpha = \begin{cases} 45^\circ \text{ for the wetted side} \\ 90^\circ \text{ for the unwetted side} \end{cases}$$

$$\phi = \begin{cases} 90^\circ \text{ for the wetted side} \\ 60^\circ \text{ for the unwetted side} \end{cases}$$

$$c = \begin{cases} 10. & \text{for the wetted side} \\ 13.6604 & \text{for the unwetted side} \end{cases}$$

For $e^+ < 35$, then $H^+ = C$.

By using these correlations, a comparison between several runs of experimental results [8] and theoretical predictions is made in Table 4.1. In general, good agreement is achieved between the data and the theoretical results.

Table 4.1 Comparison of Experimental and Theoretical Results

	+	(1) *	+	(2) *	+	(3) *	+	(4) *
Air Velocity ft/sec	10.69		10.69		11.09		11.0	
Inlet Air Temperature °F	79.3		78.9		76.8		70.8	
Inlet Air Humidity lb/lb	3.103		2.85		3,849		3,505	
Inlet Water Temperature °F	144.5		129.4		123.4		138.2	
Total Heat Transfer Btu/min	502.4	594.9	371.8	432.8	386.7	407.1	593.0	619.7
Percent Evaporative Heat Transfer	41.	43.2	39.	43.2	45.	39.3	43.	40.5

+ Experimental

* Theoretical

4.2 Packing Plates

As mentioned in the previous section, the cooling plates are folded at the top to direct water into the V-troughs. In manufacturing these plates, a structure of ten of these plates is bolted together to form a fill pack [2]. These fill packs are shipped to the construction site where a number of these fill packs form the necessary number of modules. These cooling modules are supported above the water basin by an "I" beam structure. The plates are held at 10° to the vertical by a wedge-shape structure formed from pipes [2].

4.3 Evaluation of Off-Design Tower Performance

The evaluation of the heat rejection capability of the MIT advanced wet/dry tower at off-design condition is discussed in this section.

At thermodynamical equilibrium the condenser heat load must be equal to the tower heat rejection rate. Also, the condenser heat load is equal to the rate of heat discharged by the turbine. The determination of the condenser equilibrium temperature requires trial and error. The bulky calculation can be readily handled by the computer. To do this, for each ambient condition under consideration, first, a file of tower heat rejection vs. turbine exhaust steam temperature is created. Second, the turbine heat rejection vs. exhaust steam temperature is determined. Then trial and error is used to determine the equilibrium temperature at which the tower heat rejection rate is equal to the turbine heat rejection rate. This is illustrated in Fig. 4.5.

In this study, the performance of the MIT advanced wet/dry tower is evaluated over a yearly cycle of temperature and air humidity.





FIG. 4.1 MIT ADVANCED WET/DRY COOLING TOWER SYSTEM



T_{sat} = SATURATED STEAM TEMPERATURE AT TURBINE OUTLET

TTD = CONDENSER TERMINAL TEMPERATURE DIFFERENCE

ITD = INITIAL TEMPERATURE DIFFERENCE

T_1^w = COOL WATER TEMPERATURE

T_2^w = HOT WATER TEMPERATURE

T_1^a = TEMPERATURE OF AMBIENT AIR ENTERING WET/DRY TOWER

T_2^a = TEMPERATURE OF AIR LEAVING TOWER

FIG. 4.2 TEMPERATURE RELATIONSHIPS




FIG. 4.3




FIG. 4.4




FIG. 4.5





FIG. 4.6

Chapter 5

Optimization Procedure

The optimization program optimizes the plate spacing, plate packing width, plate height, air flow rate and water flow rate. The number of water troughs per plate is varied to give various water makeup requirements. Illustration of the meaning of the above variables has been given in Fig. 4.4.

5.1 Optimization Procedure

With a given plate material, a given turbine heat rate characteristic, a specified net capacity, a given set of economic parameters, a given set of meteorological data and the variables mentioned above, optimization can then be performed. The optimization involves sequentially varying one variable while keeping the others constant. The procedures are as follows:

- (1) Select a design ambient condition and a design turbine exhaust steam saturated temperature. Although these are rather arbitrary, they should be chosen so that they are economical to the utility. By selecting the maximum ambient and the maximum backpressure of a low back pressure turbine, steam throttling can be avoided. In other words, the power plant can run at full-load all year long. The difference between the saturated steam temperature and the design condenser terminal temperature difference gives the hot water temperature.
- (2) Pick a combination of reasonable values of plate spacing, packing width, plate height, air flow mass velocity (V) and water flow rate for a given number of plates.
- (3) Vary the number of troughs per plate to give different water makeup systems.

- (4) Find the power production cost for the various water makeups.
- (5) Change the plate spacing while keeping the other variables constant.
- (6) Plot the power production cost vs. the water makeup for the various spacings.
- (7) Select the rough optimum spacing that gives the least power production cost for a given makeup.
- (8) Repeat the above procedures for the other variables.
- (9) Repeat the above with smaller changes in the variables.
- (10) Use further smaller step sizes if noticeable changes in the cost is observed, This gives the final optimum values.

The computer program listing is given in Appendix B.

Chapter 6

Results of Optimization

This chapter presents the results of optimization for both the Middletown site and the Moline site. They are given in sections 6.1 and 6.2, respectively.

6.1 Results for Middletown Using United Engineers Approach and Base Economic Factors

The power production cost vs. water makeup requirement were plotted in Figs. 6.1 - 6.5 for aluminum plates. In Fig 6.1 we see the effect of plate spacing on the power production cost is quite significant. Bearing in mind that plate spacing should be limited to a minimum of 0.75 inch and to a maximum of 1.5 inches to avoid any manufacturing problems [2], only values within these limits were considered. In this figure we see that for water makeup larger than about 41%, among the three spacings considered, 1 inch is the best. For water makeup less than 41%, 0.75 inch spacing is slightly better than 1 inch. Fig. 6.2 shows the effect of the air velocity. In general, a higher air velocity would result in a higher heat transfer coefficient but a larger pressure drop. Among the three air flow rates considered, a value of 3000 lb/hr/ft^2 is the most economical. It corresponds to a velocity of about 12 ft/sec. Because pressure drop is proportional to the square of the air velocity, a high air velocity gives a very large pressure drop or fan power.

Fig. 6.3 is a plot of power production cost vs. water makeup for three different packing widths. It appears that a packing width of 5 ft. is the best in almost all water makeups. The number of troughs per foot of packing width might be limited to a maximum of eight to avoid any manufacturing problem [2]. If this is the case, then the maximum number of troughs for a 5 ft.

packing width is limited to 40. For packing widths of 7 ft. and 9 ft., the maximum number of troughs are 56 and 72, respectively.

Fig. 6.4 shows the effect of the plate height on the cost. Among the three heights considered, 28 ft. is the most economical. Note that a larger plate height would result in a higher pumping head.

The effect of the water flow rate on the cost can be seen in Fig. 6.5. For makeups larger than about 46%, a water flow rate of 3000 lb/hr/plate is the best. For makeups less than 46%, 2000 lb/hr/plate is the most preferable.

After using smaller changes in the variables, the fine optimum power production cost vs. water makeup curve was plotted in Fig. 6.11.

Using galvanized steel plates, the results were plotted in Figs. 6.6 - 6.10, and the fine optimum curve is also shown in Fig. 6.11.

In employing the Han's correlations, the total heat transfer area should be larger if all the faces of the ribs on the wetted side of the plates were included. It would increase the dry surface area by about 10%. The effect of this increase in surface area can be seen in Fig. 6.11. Because an increase in the heat transfer area results in a higher convective heat transfer, the effect is economically very favorable.

A comparison between aluminum plates and steel plates can be made in Fig. 6.11. Because the thermal conductivity of aluminum is six times that of steel, the fin efficiency of aluminum plates is much higher for low water makeups.

Note that for aluminum plates, although the MIT advanced wet/dry concept is more economical than conventional wet-dry towers only at water makeups

larger than about 50%, it does not differ much in cost from the conventional wet-dry towers at makeups between 40 and 50 percent.

The optimum design parameters for the MIT advanced wet/dry concept using aluminum plates are shown in Table 6.1 for water makeups of 45, 50 and 55 percent. The cost breakdowns are shown in Table 6.2. Note that for these three water makeups, the incremental power production costs over zero-condenser systems are 11.6, 13.2 and 12.4 percent, respectively. Using conventional wet-dry towers, these incremental costs are 13.2, 13.0 and 12.6 percent. Therefore, for makeup between 45 and 55 percent, the cost of the MIT advanced wet/dry concept would be essentially the same as the conventional wet-dry towers.

The heat rejection capabilities of the MIT advanced wet/dry concept are illustrated in Figs. 6.12 - 6.14, with the heat rejection rate vs. condenser saturated steam temperature for various ambient conditions. The tower heat rejection curve intersects the turbine heat rejection curves at the equilibrium condenser steam temperature. Because the turbine is allowed to operate at the maximum allowable back pressure (5 inch HgA) at the maximum ambient temperature, the condenser steam temperature for all makeups is the same at the highest ambient, namely 133.76^oF. Note that for a given condenser steam temperature, the tower heat rejection rate increases as the ambient temperature decreases.

Fig. 6.15 shows how the water makeup rate increases with ambient dry bulb temperature for water makeups of 45, 50 and 55 percent. For a given ambient temperature, the water evaporation rate of a larger makeup system is higher because of less dry surface and more wet surface.

The power plant net capacity vs. ambient dry bulb temperature for three different water makeup cooling systems is shown in Table 6.3. The net capacity is the difference between the gross capacity and the auxiliary power for fans and pumps.

6.2 Results of Optimization for the Moline Site

The results in the previous section are for the Middletown site using the base economic factors presented in Chapter 2. In this section, the results of optimization for the Moline site will be presented separately.

Starting with the optimum values of plate spacing, plate packing width, plate height, air flow rate and water flow rate obtained in the previous section, optimization for the Moline site were similarly performed. The optimum power production cost vs. water makeup curves were plotted in Fig. 6.16 for the fossil plant and in Fig. 6.17 for the nuclear plant. Again, we see that aluminum is significantly advantageous to galvanized steel as the plate material. Using aluminum plates, the MIT advanced wet/dry concept is more economical than conventional wet-dry towers at water makeups larger than 30% for either the fossil or the nuclear plant. Using steel, this is 40% for the fossil plant and 41% for the nuclear plant.

For the fossil plant, the incremental power production costs of this MIT concept using aluminum plates over zero condenser cost system are 14.8, 12.2 and 10.6 percent for water makeups of 25, 37 and 50 percent because the power production cost of the zero-condenser system is 20.8 mills/Kwhr. These incremental costs are 14.4, 14.0 and 13.5 percent for conventional wet-dry towers. Therefore, the savings obtained by using the MIT advanced wet/dry tower are rather significant.

For the nuclear plant, the power production cost of the zero-condenser system is 21.1 mills/Kw-hr. The incremental power production costs for water makeups of 30, 40 and 50 percent are 15.9, 12.8 and 11.5 percent, respectively. These incremental costs are 15.9, 15.2 and 14.8 percent for the conventional wet-dry towers. Again, the savings obtained by using the MIT advanced concept are significant.

The optimum design parameters for these three water makeups are shown in Table 6.4 for the fossil plant and in Table 6.5 for the nuclear plant. The cost breakdowns are given in Tables 6.6 and 6.7. The plant net capacity vs. ambient temperature is presented in Table 6.8 for the fossil plant and in Table 6.9 for the nuclear plant.

TABLE 6.1 - Optimum Design Parameters
of MIT Advanced Wet/Dry Tower for 1094
MWe Nuclear Plant at Middletown

Plate Material is Aluminum

	Makeup (%)		
	<u>45</u>	<u>50</u>	<u>55</u>
Design Ambient Dry Bulb Temperature (°F)	99	99	99
Design Ambient Wet Bulb Temperature (°F)	77	77	77
Design Turbine Back Pressure (inch HgA)	5	5	5
Design Heat Rejection Rate (10 ⁹ Btu/hr)	7.255	7.255	7.255
Design Water Range (°F)	24.3	26.7	28.6
Design Approach (°F)	27.5	25.0	23.1
Plate Spacing (inch)	1.00	1.00	1.00
Packing Width (ft)	5	5	5
Plate Height (ft)	28	28	28
Air Flow Rate (10 ⁹ lb/hr)	0.60	0.54	0.57
Water Flow Rate (10 ⁹ lb/hr)	0.30	0.27	0.25
Number of Troughs per Plate	30	38	45
Total Number of Plates	95256	86316	58776
Evaporative/Convective Heat Transfer at Highest Ambient	61%/39%	65.6%/34.4%	68.7%/31.3%
Gross Output at Pmax (MWe)	1047.1	1047.1	1047.1
Net Output at Pmax (MWe)	1024.3	1026.9	1028.9
Fin Efficiency	0.90	0.94	0.96
Dry Surface Convective Heat Transfer Coefficient (7.68	7.61	7.56
Plate Friction Factor	0.13	0.13	0.12

TABLE 6.2 - Cost breakdown for
 Optimum Design 45%, 50% and 55%
 Water Makeup Tower System for 1094
 BWe Nuclear Plant at Middletown

All costs are in million dollars except the power production cost

	Makeup (%)		
	<u>45</u>	<u>50</u>	<u>55</u>
Cooling System Capital Cost:			
Condenser	15.05	14.27	13.75
Piping	17.64	17.05	15.13
Pumping and Elect. Equip.	6.44	6.24	5.91
Cooling Tower (Plates, Fan, Fan Elect. Equip. Structure and Foundation)	46.80	45.98	42.83
Indirect Cost	19.87	20.88	19.40
Total Capital Cost	111.86	104.42	97.02
Replacement Capacity	41.82	40.25	39.07
Replacement Energy	3.03	2.85	2.69
Annual Fuel Cost	108.86	108.86	108.86
Power Plant Cost	656.4	656.4	656.4
Power Production Cost (mills/Kwhr)	36.89	36.68	36.34

TABLE 6.3 - Plant Net Capacity
vs. Ambient Temperature for 45,
50, 55 Percent Water Makeup
Tower Systems

Ambient Dry Bulb (°F)	<u>Net Capacity (MWE)</u>		
	Makeup (%)		
	<u>45</u>	<u>50</u>	<u>55</u>
20	1070.2	1072.8	1074.8
30	1070.2	1072.8	1074.8
37	1070.2	1072.8	1074.6
42	1070.0	1072.2	1073.9
47	1069.3	1071.5	1073.2
52	1068.4	1070.7	1072.4
57	1067.5	1069.0	1071.0
62	1065.6	1066.4	1067.5
67	1061.9	1063.4	1065.4
72	1058.3	1059.7	1061.7
77	1055.8	1057.1	1057.5
82	1051.2	1051.9	1053.9
87	1044.9	1045.4	1047.5
92	1037.5	1035.7	1037.7
96	1028.0	1030.6	1032.6
98	1024.3	1026.9	1028.9

TABLE 6.4 - Optimum Design Parameters
of 25, 37 and 50 Percent Makeup Tower
Systems for 800 MWe Fossil Plant at
Moline

	Makeup (%)		
	<u>25</u>	<u>37</u>	<u>50</u>
Design Ambient Dry Bulb Temperature (°F)	98	98	98
Design Ambient Wet Bulb Temperature (°F)	84	84	84
Design Turbine Back Pressure (inch HgA)	5	5	5
Design Heat Rejection Rate (10 ⁹ Btu/hr)	3.657	3.657	3.657
Design Water Range (°F)	14.2	20.9	26.1
Design Approach (°F)	30.6	23.9	18.7
Plate Spacing (inch)	1.00	1.00	1.00
Packing Width (ft)	5	5	5
Plate Height (ft)	28	28	28
Air Flow Rate (10 ⁹ lb/hr)	0.52	0.35	0.28
Water Flow Rate (10 ⁹ lb/hr)	0.26	0.17	0.14
Number of Water Troughs per Plate	11	23	40
Total Number of Plates	83154	56112	44744
Evaporative/Convective Heat Transfer at Highest Ambient	39.1%/60.9%	51.4%/48.6%	62.5%/37.5%
Gross Output at Pmax (MWe)	790.2	790.2	790.2
Net Output at Pmax (MWe)	773.9	776.9	780.7
Fin Efficiency	0.57	0.84	0.95
Dry Surface Convective Heat Transfer Coefficient (7.13	7.76	7.58
Plate Friction Factor	0.09	0.14	0.12

TABLE 6.5 - Optimum Design Parameters
of 30, 40 and 50 Percent of Makeup
Tower Systems for 1200 MWe Nuclear
Plant at Moline

	Makeup (%)		
	<u>30</u>	<u>40</u>	<u>50</u>
Design Ambient Dry Bulb Temperature (°F)	98	98	98
Design Ambient Wet Bulb Temperature (°F)	84	84	84
Design Turbine Back Pressure (inch HgA)	5	5	5
Design Heat Rejection Rate (10 ⁹ Btu/hr)	8.187	8.187	8.187
Design Water Range (°F)	17.5	22.6	25.8
Design Approach (°F)	27.2	22.2	18.9
Plate Spacing (inch)	1.00	1.00	1.00
Packing Width (ft)	5	5	5
Plate Height (ft)	28	28	28
Air Flow Rate (10 ⁹ lb/hr)	0.95	0.73	0.64
Water Flow Rate (10 ⁹ lb/hr)	0.47	0.36	0.32
Number of Troughs per Plate	16	28	40
Total Number of Plates	150460	116104	101120
Evaporative/Convective Heat Transfer at Highest Ambient	44.6%/55.4%	55.1%/44.9%	62%/38%
Gross Output at Pmax (MWe)	1160.4	1160.4	1160.4
Net Output at Pmax (MWe)	1139.5	1149.1	1154.6
Fin Efficiency	0.72	0.89	0.95
Dry Surface Convective Heat Transfer Coefficient (7.45	7.70	7.59
Plate Friction Factor	0.11	0.13	0.12

TABLE 6.6 - Cost Breakdown for 25,
37 and 50 Percent Makeup Tower Systems
for 800 MWe Fossil Plant at Moline

All costs are in million dollars except the power production cost

	Makeup (%)		
	<u>25</u>	<u>37</u>	<u>50</u>
Cooling System Capital Cost:			
Condenser	5.57	4.97	4.43
Piping	9.10	5.69	4.33
Pumping and Elect. Equip.	3.43	2.82	2.46
Cooling Tower (Plates, Fan, Fan Elect. Equip. Structure and Foundation)	23.51	17.07	13.44
Indirect Cost	8.51	6.25	5.02
Total Capital Cost	51.01	37.48	30.32
Replacement Capacity (Gas Turbine)	4.18	3.73	3.08
Replacement Energy (Gas Turbine)	0.73	0.52	0.32
Annual Fuel Cost	41.70	41.64	41.52
Power Plant Cost	403.10	403.10	403.10
Power Production Cost (mills/Kwhr)	23.88	23.33	23.01

TABLE 6.7 - Cost Breakdown for 30,
40 and 50 Percent Makeup Tower Systems
for 1200 MWe Nuclear Plant at Moline

	Makeup (%)		
	<u>30</u>	<u>40</u>	<u>50</u>
Cooling System Capital Cost:			
Condenser	11.92	10.37	9.63
Piping	21.46	18.10	17.27
Pumping and Elect. Equip.	6.73	4.68	4.13
Cooling Tower (Plate, Fan, Fan Elect. Equip. Structure and Foundation)	43.81	36.09	31.16
Indirect Cost	27.07	14.08	12.65
Total Capital Cost	102.40	84.47	75.88
Replacement Capacity (Gas Turbine)	9.68	8.14	7.27
Replacement Energy (Gas Turbine)	2.80	1.24	0.92
Annual Fuel Cost	37.67	37.64	37.55
Power Plant Cost	727.4	727.4	727.4
Power Production Cost (mills/Kwhr)	24.45	23.80	23.53

TABLE 6.8 - Net Capacity vs. Ambient
Temperature for 25, 37 and 50 Percent
Makeup Tower Systems for 800 MWE
Fossil Plant at Moline

Ambient Dry Bulb (^o F)	Net Capacity (MWe)		
	Makeup (%)		
	<u>25</u>	<u>37</u>	<u>50</u>
20	800.1	802.9	807.0
30	800.1	802.9	806.6
37	800.1	802.6	806.1
42	799.8	802.2	805.7
47	799.2	801.5	805.2
52	798.7	801.1	804.5
57	798.1	800.5	803.9
62	797.0	799.0	802.4
67	795.9	798.3	801.2
72	793.8	795.6	798.9
77	790.3	791.7	795.0
82	785.8	787.6	789.8
87	782.9	784.7	788.8
92	779.5	782.4	784.4
96	775.0	777.8	781.9
98	773.8	776.7	780.7

TABLE 6.9 - Net Capacity vs. Ambient
Temperature for 30, 40 and 50 Percent
Makeup Tower Systems for 1200 MWe
Nuclear Plant at Moline

Ambient Dry Bulb Temperature (°F)	<u>Net Capacity (MWe)</u>		
	<u>Makeup (%)</u>		
	<u>30</u>	<u>40</u>	<u>50</u>
20	1192.1	1201.7	1207.2
30	1192.1	1207.7	1207.0
37	1192.1	1201.5	1206.8
42	1192.0	1201.2	1206.3
47	1191.4	1200.6	1205.8
52	1190.9	1200.3	1205.2
57	1190.4	1199.4	1204.4
62	1188.8	1197.2	1201.8
67	1186.8	1194.1	1198.2
72	1181.2	1190.1	1194.3
77	1174.3	1182.2	1185.5
82	1165.5	1170.4	1173.5
87	1158.5	1165.7	1171.2
92	1150.7	1156.5	1162.0
96	1142.1	1151.7	1157.2
98	1139.5	1149.1	1154.6

6.3 Wet Topping

From the results in sections 4.1 and 4.2, it can be seen that the cost goes up very rapidly when the plate surface becomes very dry, that is, when the number of troughs on each plate is small such that the fin efficiency becomes very small. Attempt was made to see if there would be any savings by topping this tower with a conventional evaporative tower. The results are shown in Fig. 6.17. Using wet topping there are savings obtained but still are not cost competitive with conventional wet-dry towers.

MIDDLETOWN SITE 1094 MWe NET CAPACITY NUCLEAR PLANT ALUMINUM PLATE




FIG. 6.1




FIG. 6.2

MIDDLETOWN SITE 1094 MWe NET CAPACITY NUCLEAR PLANT ALUMINUM PLATE




FIG. 6.3

MIDDLETOWN SITE 1094 MWe NET CAPACITY NUCLEAR PLANT ALUMINUM PLATE




FIG. 6.4

MIDDLETOWN SITE 1094 MWe NET CAPACITY NUCLEAR PLANT ALUMINUM PLATE





FIG. 6.5



MAKEUP WATER REQUIREMENT (%)

FIG. 6.6

MIDDLETOWN SITE 1094 MWe NET CAPACITY NUCLEAR PLANT STEEL PLATE




FIG. 6.7

MIDDLETOWN SITE 1094 MWe NET CAPACITY NUCLEAR PLANT STEEL PLATE




FIG. 6.8

MIDDLETOWN SITE 1094 MWe NET CAPACITY NUCLEAR PLANT STEEL PLATE




FIG. 6.9




FIG. 6.10

FIG. 6.11
MIDDLETOWN SITE 1094 MWe NET CAPACITY NUCLEAR PLANT
OPTIMUM CURVES




FIG. 6.12
HEAT REJECTION CAPABILITY OF A 45% WATER MAKEUP MIT
ADVANCED WET/DRY TOWER.

MIDDLETOWN SITE 1094 MWe NET CAPACITY NUCLEAR PLANT

ALUMINUM PLATE




FIG. 6.13

HEAT REJECTION CAPABILITY OF A 50% WATER MAKEUP
MIT ADVANCED WET/DRY TOWER.

MIDDLETOWN SITE 1094 MWe NET CAPACITY NUCLEAR PLANT
ALUMINUM PLATE






FIG. 6.14

HEAT REJECTION CAPABILITY OF A 55% WATER MAKEUP MIT
ADVANCED WET/DRY TOWER.

MIDDLETOWN SITE 1094 MWe NET CAPACITY NUCLEAR PLANT
ALUMINUM PLATE





MAKEUP WATER FLOW RATE VS. AMBIENT DRY BULB TEMPERATURE

FIG. 6.15

MOLINE SITE 800 MWe NET CAPACITY FOSSIL PLANT




FIG. 6.16




FIG. 6.17




FIG. 6.18

Chapter 7

Comparison with United Engineer's Study

As mentioned in earlier chapters one major task in this study is to compare our results with those reported by United Engineers. This will be done in this chapter.

According to United Engineers [2], galvanized steel plate is preferable to aluminum. However, the results in our study indicate that aluminum is much more economical than steel, especially for low water makeups. Since they only reported the results of optimization for steel, we are only able to compare these results for the MIT advanced wet/dry tower concept using steel plates.

A comparison of the optimum design parameters for a 50% makeup tower system between these two studies are shown in Table 7.1. Note that the results are rather comparable.

The cost breakdowns are compared in Table 7.2. We see that the capital costs of the condenser and cooling tower in these two studies are close. However, the costs of the water circulating system in our study is much higher because piping design is considered in detail. On the other hand, only main circulating pipe cost was considered in United Engineers' study. Our piping cost included main pipes, tower distribution pipes, risers, as well as all pipe fittings. As a result, our power production cost is higher than United Engineers.

The penalty cost in this study is essentially the same as United Engineers.

In comparing the capital cost of the cooling tower per square foot of

plate area, we see that it is \$1.8/ft² for United Engineers and is \$2.3/ft² for this study. Therefore, it is 30% higher in this study.

TABLE 7.1 - Comparison of Optimum Design Parameters
between United Engineers and this study for Middletown

	United Engineers	This Study
Water Makeup (%)	50	50
Design Ambient Dry Bulb Temperature (°F)	99	99
Design Ambient Wet Bulb Temperature (°F)	77	77
Design Turbine Back Pressure (inch HgA)	5	5
Design Heat Rejection Rate (Btu/hr)	7.25×10^9	7.25×10^9
Plate Spacing (inch)	1.00	1.00
Packing Plate Width (ft)	7	5.86
Plate Height	30	28
Air Flow Rate (lb/hr)	not clear	5.90×10^8
Water Flow Rate (lb/hr)	unknown	2.95×10^8
Number of Water Channels per Plate	not clear	33
Total Number of Plates	78120	93728
Evaporative Heat Transfer/Convective Heat Transfer at Highest Ambient	61%/31%	64.9%/35.1%
Gross Output at Pmax, MWe	1048.4	1047.2
Net Output at Pmax, MWe	1025.4	1025.0
Annual Makeup Water (gall)	21.58×10^8	21.58×10^8
Fan and Pump Power (MWe)	23.03	23.81
Design Water Range (°F)	unknown	24.6
Design Approach (°F)	unknown	27.1

TABLE 7.2 - Comparison of Cost Breakdowns
between United Engineers and this Study for
Middletown for Steel Plate

All the costs are in million dollars except last three items

	<u>50% Water Makeup</u>	
	United Engineers	This Study
Cooling System Capital Cost:		
Condenser	14.74	14.94
Piping and Pumping	11.36 (Elect, Equip. not included)	23.77 (Elect. Equip. not included)
Cooling Tower. (Plates, Fan, Structure and Foundation)	33.91	35.17
Electrical Equipment	4.92 (Fan & Pump)	35.17
Indirect Cost	16.23	20.50
Total Cooling System Capital Cost	81.46	102.50
Penalty Cost:		
Capacity	27.36	27.08
Fan and Pump Power	13.82	14.29
Replacement Energy and Auxiliary Energy	15.69	16.22
Make-up Water	3.20	3.20
Cooling System Maintenance	4.24	5.37
Total Penalty	64.32	66.16
Incremental Power Production Cost (mills/Kwhr)	3.80	4.33
Incremental Power Production Cost (%)	11.7	13.4
Cooling Tower per ft ² of Plate (\$/ft ²)	1.8	2.3

Chapter 8

Sensitivity Study

The cooling plates in the MIT advanced wet/dry concept are not currently offered by manufacturers. Therefore, the cost of these plates is uncertain. In the base case study, the total plate cost is assumed to be twice the plate material cost. However, if the cost changes the results of optimization would also change. Therefore, a sensitivity study of the plate cost is necessary and is given in this chapter.

The sensitivity parameters are 2 and 3 times the base case plate cost for the Moline site. The results are shown in Fig. 8.1 for the fossil plant and in Fig. 8.2 for the nuclear plant using aluminum plates. From these two figures we can see that the MIT advanced wet/dry concept would entirely not be cost competitive with conventional wet-dry towers only when the plate cost is more than two times the base case cost. Although the plate cost is rather uncertain at this step, it is very unlikely that the plate cost would be more than twice the base cost. Hence, this MIT advanced wet/dry concept is economically rather encouraging. Of course, a lower plate cost would make this MIT concept further favorable.

Chapter 9

Conclusions and Recommendations


9.1 Conclusions

This study has determined the cost of the MIT advanced wet/dry cooling concept in both fossil and nuclear power plants. Aluminum is superior to galvanized steel as the cooling plate material. In our base case study for the Middletown site 1094 MWe nuclear plant and using aluminum plates, the MIT concept is slightly more economical than conventional wet-dry towers at water makeups larger than 50%. For a 55% water makeup system, for instance, using the MIT advanced concept reduces the incremental power production cost from the conventional wet-dry towers by about 0.15 mills/Kwhr.

In our base case study at the Moline site, for an 800 MWe fossil plant the MIT advanced wet/dry tower with aluminum plates is more economical than conventional wet-dry towers when water makeup is larger than 27%. For makeups of 25, 37 and 50 percent, the optimum power production costs are 23.88, 23.33 and 23.01 mills/Kwhr, respectively, compared to 23.82, 23.70 and 23.6 mills/Kwhr. for conventional wet-dry towers. When these are compared to 20.8 mills/Kwhr. for zero-condenser system, the incremental costs for makeups of 37 and 50 percent using MIT advanced wet/dry instead of conventional wet-dry would be reduced by 13 and 21 percent, respectively.


For a 1200 MWe nuclear plant the MIT advanced wet/dry tower with aluminum plates is more economical than conventional wet-dry towers when water makeup is larger than 30%. For makeups of 30, 40 and 50 percent, the optimum power production costs are 24.45, 23.80 and 23.53 mills/Kwhr., respectively, compared with 24.95, 24.84 and 24.75 mills/Kwhr. for the conventional wet-dry

FIG. 8.1
 800 MWe NET CAPACITY FOSSIL PLANT



MAKEUP WATER REQUIREMENT (%)

FIG. 8.2
MOLINE SITE 1200 MWe NET CAPACITY NUCLEAR PLANT



towers. When these are compared to 21.1 mills/Kwhr for zero-condenser system, the incremental costs for makeups of 40 and 50 percent using MIT advanced wet/dry instead of conventional wet-dry would be reduced by 28 and 33 percent, respectively.

Our sensitivity study indicates that only when the plate cost is higher than twice the base case cost would the MIT advanced tower entirely not be competitive with conventional wet-dry towers.

Soon the water shortage problem would be common in the electrical power industry. If this is the case, then the MIT advanced wet/dry cooling tower concept provides the utility a useful tool in the heat sink problem.

9.2 Recommendations

Pressure drop measurements were not experimentally done in the previous studies. In future work, this should be performed and compared with theoretical results. The thermal performance of the MIT advanced wet/dry tower presented in the previous chapters have to be verified by operating such a cooling module in existing plants. Finally, the cost of manufacturing the packing plates has to be ascertained before this cooling concept can be recommended for vendors.

9.3 Acknowledgement

This study is supported by the Division of Environmental Technology, U.S. Department of Energy under contract No. EY-76-S-02-4114-A001. It is much appreciated.

References

1. Choi, M.K., "Computer Optimization of Dry and Wet/Dry Cooling Tower Systems for Large Fossil and Nuclear Power Plants", M.S. Thesis, Department of Mechanical Engineering, M.I.T., Cambridge, MA., August 1978.
2. United Engineers, "Preliminary Report on the Cost Evaluation of the MIT Advanced Wet/Dry Concept", 1977.
3. Hon, J.C., Ph.D. Thesis, Department of Mechanical Engineering, M.I.T., Cambridge, MA., 1977.
4. Walker, D., M.S. Thesis, Department of Mechanical Engineering, M.I.T., Cambridge, MA., 1977.
5. Snyder, T., M.S. Thesis, Department of Mechanical Engineering, M.I.T., Cambridge, MA., 1977.
6. Larinoff, M.W. and Fosta, L.L., "Dry and Wet- peaking Tower Cooling Systems for Power Plant Applications", J. Engrg. Power, Trans. ASME, 98 (3), July 1976.
7. Surface, M.O., "System Designs for Dry Cooling Towers", Power Engrg., Sept. 1977, pp. 42-45.
8. Snyder, T. et al, "Advanced Wet-Dry Cooling Tower Concept Cross-Flow Tests", Energy Lab. Report No. MIT-EL-77002, Jan. 1977, Vol I and II.

Appendix A

Plate Cost

In 1979, the material cost of 0.025 inch thick aluminum plates is \$0.45/ft². The total plate cost is assumed to be twice the material cost. It is the sum of plate material, manufacture and erection costs. Therefore, it is \$0.90/ft². Allowing 10% for the contractors profit and 4% for shipping, then the total direct cost is \$1.03/ft². This is \$0.81/ft² for galvanized steel plates of the same thickness. To estimate these costs in years other than 1979, an inflation of 7% per year is allowed. Cost algorithms of other cooling system components are given in Ref. 1.

Appendix B

Computer Program Listing

The computer program with input data for the 1200 MWe nuclear plant at Moline site is given. Also, several samples of the computer output are presented. To execute this program for the 800 MWe fossil plant at Moline, some numerics have to be changed. In the data inputs, turbine heat rates at lines 5 and 6 have to be changed to $\begin{cases} 7777, 7782, 7789, 7809, 7841 \\ 7882, 7930, 7984, 8012, 8040 \end{cases}$. The value of boiler efficiency EFFE in line 22 has to be changed from 1.0 to 0.9. In line 24, the number representing the plant capacity 1200, has to be replaced by 800. In line 25, the numbers 0147, 600 and 200 represent the fuel cost, plant cost, turbine-generator cost and steam-generator cost, respectively, they have to be replaced by 0.90, 500, 167 and 167, respectively. In line 93 to 95, the numbers are turbine heat rates, they have to be replaced by 7770, 7770, 7770, 7770, 7777, 7783, 7789, 7800, 7809, 7825, 7841, 7862, 7882, 7907, 7930, 7955, 7984, 8012, 8040. In the main program, to determine the make-water requirement in the statement $AWLOSS = AWLOSS \times 7.48 \times 100. / (62.4 \times 5.9628E09)$ the number 5.9628E09 has to be replaced by 2.6187E09 because this is the all-evaporative tower annual water makeup.

In subroutine POWER P, in the statement $HEATIN = 3577.5 * 1000. * 3413.$, the number 3577.5 has to be replaced by 1861.8 because this is the heat source. Also, in the statement $PS1 \quad NW = 1212.4$, the number 1212.4 has to be changed to 806.5 because it is the plant capacity at the turbine rating back pressure.

```

DIMENSION AL(5), ANPL(5), ANG(7), AMA(7), AMLIN(7), WPACK(5), VAM(6)
DIMENSION TA(17), AWIN(17), TPER(17), FUELCS(17), CCCST(17), ECCST(17)
DIMENSION WLOSS(17)
DIMENSION TST(3), TTDS(3)
COMMON/DTOW1/ VAS(6), KCONV, JCONS, XDEPA
COMMON/DTOW2/ TICOS, DELPA
COMMON/DTOW3/ TSA1, TID2, TD, WIN
COMMON/COST1/ CSTEAM, CPLN, CPIPE, CCOND, CPUMP, CWDTS, CSTFN, CPLNW,
1ICOSM, CTURB, CFAN, CEEQ, CSCCOOL, CFUEL, CCSYS, CCWQC, OPCWQC
COMMON/DTOW4/ MLOW, AMP1, DIAMT, W3, W4, VAIR,
1QIN, QREJ, HRFAC, T4, NFAN, NLM, FLOSS,
2DPCON, DPPIP, SCPCW, PPOW, FPOW, XNPASS, TLSH, AREAP3, XNTS
COMMON/DTOW6/ CONK
COMMON/DTOW8/ QRJMX(4), POWMX(4)
COMMON/INPUT1/ HRFACB, HRFMIN, HRFMAX, T1MAX, TSMIN, TSMAX, TEF,
1TPO(13), BP1, BP2, BP3
COMMON/INPUT2/ ECCOS, CCCOS, CAPF, FCOS, FCR, PSIZE, PLANC, STEAMC,
1TURBC, PER, PTTURB, CSCCM, CWQCC, CWQCCP, SUPCC, SUPCP
COMMON/INPUT3/ EFFP, EFFF, RFCOV, VELCON, VELW, PFACT, EFFB
COMMON/INPUT5/ THROTT(4), EFFMX(4)
COMMON/INPUT6/ DIST, CU, GCF, CF, CPMPC1, CPMPC2, GMPF, AREAPF,
1TOD, TID, DFAN
COMMON/INPUT7/T11, T11ST
COMMON/PIPING/ TWP(23), DIA(23), CPC1(23), CPC2(23, 2), CPC3(23),
1CRCL(23), CRC2(23, 2), CTC1(23), CTC2(23, 2), CE1C1(23), CE2C1(23),
2CE1C2(23, 2), CE2C2(23, 2), VALCST(23), FLCST(23)
COMMON/INPUT8/ITRACK
COMMON/IN1/ T1T(10), HRIT(10), QTUR(10), TLIN1T(10)
COMMON/IN5/CSFPL, DENSPL
COMMON/IN8/SP
COMMON/DTOW9/ FF1, FF2, FAIR
COMMON/INA/TSTM(21), PSTM(21), HR(19)
ITRACK=0
ID=1
READ(53, 77) (TST(I), I=1, 3)
READ(53, 77) (TTDS(I), I=1, 3)
READ(53, 77) (T1T(I), I=1, 5)
READ(53, 77) (T1T(I), I=6, 10)
READ(53, 76) (HRIT(I), I=1, 5)
READ(53, 76) (HRIT(I), I=6, 10)
READ(53, 67) (TA(I), I=1, 2)
READ(53, 67) (TA(I), I=3, 17)
READ(53, 30) (AWIN(1), J=1, 8)
READ(53, 30) (AWIN(1), J=9, 17)
READ(53, 69) (TPER(I), I=1, 2)
READ(53, 69) (TPER(I), I=3, 10)
READ(53, 69) (TPER(I), I=11, 17)
READ(53, 77) (EFFMX(I), I=1, 3)
READ(53, 77) (THROTT(I), I=1, 3)
READ(53, 77) DIST, CU, GCF, CF, GMPF, AREAPF
READ(53, 77) T11ST
READ(53, 77) TOD, TID, DFAN
READ(53, 45) CPMPC1, CPMPC2
READ(53, 77) VELCON, VELW, PFACT
READ(53, 76) VAS(1), VAS(2), VAS3ST, VAS(4), VAS(5), VAS(6)
READ(53, 77) TEF, EFFP, EFFF, XDEPA, RFCOV, EFFB, CSCCM
READ(53, 70) CWQCC, CWQCCP, SUPCC, SUPCP
READ(53, 77) PSIZE, PER, PTTURB
READ(53, 77) FCOS, FCR, PLANC, STEAMC, TURBC, CCCOS, ECCOS, CAPF
READ(53, 77) TSTAR, TEND, TSATST, TSATEN
READ(53, 77) BP1, BP2, BP3, HRFMIN, HRFMAX, HRFACB
READ(53, 72) (TPO(I), I=1, 8)
READ(53, 72) (TPO(I), I=9, 13)
READ(53, 77) TID2, TIDMX, TSMIN, T1MAX
READ(53, 40) (DIA(I), I=1, 12)
READ(53, 40) (DIA(I), I=13, 23)

```

```
READ (53,41) (TWP(I),I=1,10)
READ (53,41) (TWP(I),I=11,20)
READ (53,41) (TWP(I),I=21,23)
READ (53,42) (CPC3(I),I=1,10)
READ (53,42) (CPC3(I),I=11,20)
READ (53,42) (CPC3(I),I=21,23)
READ (53,42) (CPC1(I),I=1,10)
READ (53,42) (CPC1(I),I=11,20)
READ (53,42) (CPC1(I),I=21,23)
READ (53,42) (CPC2(I,1),I=1,10)
READ (53,42) (CPC2(I,1),I=11,20)
READ (53,42) (CPC2(I,1),I=21,23)
READ (53,42) (CPC2(I,2),I=1,10)
READ (53,42) (CPC2(I,2),I=11,20)
READ (53,42) (CPC2(I,2),I=21,23)
READ (53,43) (CRC1(I),I=1,8)
READ (53,43) (CRC1(I),I=9,16)
READ (53,43) (CRC1(I),I=17,23)
READ (53,43) (CRC2(I,1),I=1,8)
READ (53,43) (CRC2(I,1),I=9,16)
READ (53,43) (CRC2(I,1),I=17,23)
READ (53,43) (CRC2(I,2),I=1,8)
READ (53,43) (CRC2(I,2),I=9,16)
READ (53,43) (CRC2(I,2),I=17,23)
READ (53,43) (CTC1(I),I=1,8)
READ (53,43) (CTC1(I),I=9,16)
READ (53,43) (CTC1(I),I=17,23)
READ (53,43) (CTC2(I,1),I=1,8)
READ (53,43) (CTC2(I,1),I=9,16)
READ (53,43) (CTC2(I,1),I=17,23)
READ (53,43) (CTC2(I,2),I=1,8)
READ (53,43) (CTC2(I,2),I=9,16)
READ (53,43) (CTC2(I,2),I=17,23)
READ (53,43) (CE1C1(I),I=1,8)
READ (53,43) (CE1C1(I),I=9,16)
READ (53,43) (CE1C1(I),I=17,23)
READ (53,43) (CE1C2(I,1),I=1,8)
READ (53,43) (CE1C2(I,1),I=9,16)
READ (53,43) (CE1C2(I,1),I=17,23)
READ (53,43) (CE1C2(I,2),I=1,8)
READ (53,43) (CE1C2(I,2),I=9,16)
READ (53,43) (CE1C2(I,2),I=17,23)
READ (53,43) (CE2C1(I),I=1,8)
READ (53,43) (CE2C1(I),I=9,16)
READ (53,43) (CE2C1(I),I=17,23)
READ (53,43) (CE2C2(I,1),I=1,8)
READ (53,43) (CE2C2(I,1),I=9,16)
READ (53,43) (CE2C2(I,1),I=17,23)
READ (53,43) (CE2C2(I,2),I=1,8)
READ (53,43) (CE2C2(I,2),I=9,16)
READ (53,43) (CE2C2(I,2),I=17,23)
READ (53,43) (FLCST(I),I=1,8)
READ (53,43) (FLCST(I),I=9,16)
READ (53,43) (FLCST(I),I=17,23)
READ (53,43) (VALCST(I),I=1,8)
READ (53,43) (VALCST(I),I=9,16)
READ (53,43) (VALCST(I),I=17,23)
READ (53,30) WIN
READ (53,77) CSFPL,DENSPL
READ (53,77) SP
READ (53,76) (HR(I),I=1,7)
READ (53,76) (HR(I),I=8,14)
READ (53,76) (HR(I),I=15,19)
READ (53,77) (TSTM(I),I=1,8)
READ (53,77) (TSTM(I),I=9,16)
READ (53,77) (TSTM(I),I=17,21)
```



```

READ(53,77) (PSTM(I), I=1,8)
READ(53,77) (PSTM(I), I=9,16)
READ(53,77) (PSTM(I), I=17,21)
IF(11.EQ.1) GO TO 888
WRITE(6,79)
WRITE(6,67) (IA(I), I=1,2)
WRITE(6,67) (IA(I), I=3,17)
WRITE(6,30) (AWIN(I), I=1,8)
WRITE(6,30) (AWIN(I), I=9,17)
WRITE(6,69) (TPER(I), I=1,2)
WRITE(6,69) (TPER(I), I=3,10)
WRITE(6,69) (TPER(I), I=11,17)
WRITE(6,77) (EFFMX(I), I=1,4)
WRITE(6,77) (THROTT(I), I=1,4)
WRITE(6,77) DIST,CU,GCF,CF,GPMPF,AREAPP
WRITE(6,77) TLIST
WRITE(6,77) (TIT(I), I=1,5)
WRITE(6,77) (TIT(I), I=6,10)
WRITE(6,76) (HRIT(I), I=1,5)
WRITE(6,76) (HRIT(I), I=6,10)
WRITE(6,77) TOD,TID,DFAN
WRITE(6,45) CPMPC1,CPMPC2
WRITE(6,77) VELCON,VELW,PFACT
WRITE(6,76) VAS(1),VAS(2),VAS3ST,VAS(4),VAS(5),VAS(6)
WRITE(6,77) IEFF,EFFP,EFFF,XDEPA,FFCOV,EFFB,CSCCM
WRITE(6,70) CWQCC,CWQCCP,SUPCC,SUPCP
WRITE(6,77) PSIZE,PER,PTURB
WRITE(6,77) FCOS,FCR,PLANC,STEAMC,TURBC,CCCOS,ECCOS,CAPP
WRITE(6,77) TSTAR,TEND,TSATST,TSATEN
WRITE(6,77) BP1,BP2,BP3,HRFMIN,HRFMAX,HRFACB
WRITE(6,72) (TPO(I), I=1,8)
WRITE(6,72) (TPO(I), I=9,13)
WRITE(6,77) TTD2,TITDMX,TSMIN,TIMAX
WRITE(6,30) WIN
WRITE(6,77) CSFPL,DENSPL
WRITE(6,77) SP
WRITE(6,76) (HR(I), I=1,7)
WRITE(6,76) (HR(I), I=8,14)
WRITE(6,76) (HR(I), I=15,19)
WRITE(6,77) (TSTM(I), I=1,8)
WRITE(6,77) (TSTM(I), I=9,16)
WRITE(6,77) (TSTM(I), I=17,21)
WRITE(6,77) (PSTM(I), I=1,8)
WRITE(6,77) (PSTM(I), I=9,16)
WRITE(6,77) (PSTM(I), I=17,21)
888 WRITE(6,76) VAS(1),VAS(2),VAS3ST,VAS(4),VAS(5),VAS(6)
40 FORMAT(12F6.0)
41 FORMAT(1JF8.4)
42 FORMAT(1JF8.2)
43 FORMAT(10F8.2)
30 FORMAT(10F8.5)
45 FORMAT(5F16.4)
70 FORMAT(6F10.2)
72 FORMAT(6F10.7)
77 FORMAT(8F10.4)
76 FORMAT(8F10.1)
67 FORMAT(15F5.1)
69 FORMAT(10F10.7)
79 FORMAT('1')
TD=TSTAR
TSAT=TSATST
555 WRITE(6,81) TD
81 FORMAT('DESIGN DRY BULB TEMPERATURE TD =',F8.3,' DEGREE F')
WRITE(6,77) VAS(4)
VAS(3)=VAS3ST
666 WRITE(6,76) VAS(3)

```

```

444 TITD=TSATF-TTD2-4D
121 WRITE(6,181) TITD
181 FORMAT(' DESIGN IID=',F7.3,' DEGREE F')
    TLIN=TSATF-TTD2
    TSAT=ISATF
    CALL POWLRP(VAS(1),VAS(2),VAS(3),VAS(4),VAS(5),VAS(6))
    WRITE(6,77) FF1,FF2,FAIR
    WRITE(6,77) DELPA,FAIR,FLOSS
    CAP1=CCSYS+CSTEAM+CTURB+CPLNNW
    IF(1L.EQ.1) GO TO 999
    WRITE(6,84) NLA,NEAN
64  FORMAT(10X,' NUMBER OF MAIN CIRCULATION LINES=',I3/10X,'NUMBER OF
    1FANS =',I6)
    WRITE(6,85) QPLJ
85  FORMAT(10X,' DESIGN HEAT REJECTION RATE =',E15.5,' BTU/HR')
    WRITE(6,74) FLOW,AMPT
74  FORMAT(10X,' NUMBER OF WET/DRY TOWERS =',I5/10X,
    1' NUMBER OF MODULES PER TOWER =',F6.1)
    WRITE(6,86) DPPIP,DPCON,PPON,FPON
88  FORMAT(10X,' PRESSURE DROP OF PIPING SYSTEM =',F10.3,' FEET H2O'/
    110X,' PRESSURE DROP THROUGH CONDENSER =',F10.3,' FEET H2O'/
    210X,' PUMPING POWER =',E10.3,' MWE'/10X,' FAN POWER =',E10.3,
    3' MWE')
    WRITE(6,97) XNPASS,TLSH,AREAPS,XNTS,W3,W4
97  FORMAT(10X,' NUMBER OF CONDENSER TUBE PASSES =',F10.4/10X,
    1' LENGTH OF CONDENSER SHELL =',F10.4,' FEET'/10X,
    2' HEAT TRANSFER AREA PER CONDENSER SHELL =',E15.5,' FT2'/10X,
    3' NUMBER OF CONDENSER TUBES PER SHELL =',E15.5/10X,
    4' WATER FLOW RATE =',E15.5,' LB/HR'/10X,
    5' AIR FLOW RATE =',E15.5,' LB/HR')
    WRITE(6,82) HRFAC,T4
82  FORMAT(10X,' DESIGN HEAT RATE FACTOR =',F7.4/10X,' TOWER EXIT
    1AIR TEMPERATURE =',F8.3,' DEGREE F')
    WRITE(6,83) VAIR
83  FORMAT(10X,'DESIGN AIR VELOCITY =',F10.3,' FT/SEC')
    WRITE(6,86) CPIPE,CPUMP,CCOND,CWDT5,CSTFN,CFAN,CEEQ
86  FORMAT(10X,' CAPITAL CCST OF PIPING SYSTEM =$',E12.5/10X,
    1' CAPITAL COST OF PUMPING SYSTEM =$',E12.5/10X,
    2' CAPITAL COST OF CONDENSER =$',E12.5/10X,
    3' CAPITAL COST OF HEAT EXCHANGER =$',E12.5/10X,
    4' CAPITAL COST OF TOWER STRUCTURE AND FOUNDATION =$',E12.5/10X,
    5' CAPITAL COST OF FAN SYSTEM =$',E12.5/10X,
    6' CAPITAL COST OF FAN SYSTEM ELECTRICAL EQUIPMENT =$',E12.5)
    WRITE(6,80) CCSYS,CPLNNW,CFUEL,CSTEAM,CTURB
80  FORMAT(10X,' TOTAL DIRFCT AND INDIRFCT COST OF COOLING SYSTEM =$',
    1,E12.5/10X,' POWER PLANT CONSTRUCTION COST =$',E12.5/10X,
    2' FUEL COST AT DESIGN POINT =$',E12.5/10X,
    3' CAPITAL COST OF ADDITIONAL STEAM SUPPLY SYSTEM =$',E12.5/10X,
    4' CAPITAL COST OF EXTRA TURBINE =$',E12.5)
999 WRITE(6,102)
102 FORMAT(5X,' TDB',10X,' TSAT',8X,' TTD',10X,' ITD',2X,' NET POWER'
    1,5X,' FRACTION OF FULL-',2X,' ENERGY CHARGE',10X,' WATER LOSS'/
    268X,' LOAD THROTTLE')
    DO 178 I=1,3
    POWMX(I)=QIN*THROTT(I)*EFFMX(I)/(3413.*1000.)
    QRJMX(I)=QIN*THROTT(I)*(1.-EFFMX(I))
178 CONTINUE
    DO 170 I=1,10
    QTUR(I)=QIN*(1.-3413./HRIT(I))
    TLRIT(I)=TIT(I)-QTUR(I)*CONK
170 CONTINUE
    AFUEL=0.
    ACSEC=J.
    AWLOSS=0.
    T11=T11ST
    DO 3 I=2,17

```

```

CALL PLFORM (TA(1),AWIN(1),TPER(1),ECCST(1),CCCST(1),FUELCS(1),
WLOSS(1))
AFUEL=AFUEL+FUELCS(1)
ACSEC=ACSEC+ECCST(1)
AWLOSS=AWLOSS+WLOSS(1)
3 CONTINUE
CAPAC=CCCST(17)
H2OC=AWLOSS*7.48*100/(62.4*1000.)
ACAPIT=(CAPIT+CAPAC)*FCR
AOPER=COSM+CAPAC*PER+AFUEL+ACSEC+OPCWQC+H2OC
ACAPCS=ACAPIT/(8760.*CAPF*PSIZE)
AOPCS=AOPER/(8760.*CAPF*PSIZE)
ANNCCS=AOPCS+ACAPCS
AWLOSS=AWLOSS*7.48*100/(62.4*5.9628E09)
WRITE(6,87) CAPAC,ACSEC,AFUEL,ANNCCS,AWLOSS
87 FORMAT(10X,' CAPITAL COST OF REPLACEMENT CAPACITY =$',E12.5/10X,
1' REPLACEMENT ENERGY COST =$',E12.5/10X,
2' ANNUAL FUEL COST =$',E12.5/10X,
3' POWER PRODUCTION COST =',F12.4,' MILLS/KW-HR',
410X,' ANNUAL WATER LOSS=',F12.4,' ?')
VAS(3)=VAS(3)+6.
IF(VAS(3).LE.45.) GO TO 666
222 VAS(5)=VAS(5)+100000.
IF(VAS(5).EQ.300000.) GO TO 222
IF(VAS(5).LE.400000.) GO TO 555
TSAT=TSAT+10.
IF(TSAT.LE.TSATEN) GO TO 444
TD=TD+10.
IF(TD.LE.TEND) GO TO 555
STOP
END
SUBROUTINE POWERP(AL,ANPL,ANG,AMA,AMLIN,WPACK)
DIMENSION GPMA(100),NLA(100),VELA(100),DIAA(100),PIPCSA(100),
1VCSA(100),CRCA1(100),CRCA2(100),TWPA(100),CPC3A(100),TCSA(100),
2PIPCA(100),REDCA(100),TCA(100),DPRA(100),DPA(100),EL1CSA(100),
3EL2CSA(100),ELA(100),FLCSA(100)
COMMON/DTOW1/ VAS(6),KCONV,JCONS,XDEPA
COMMON/DTOW2/ TCOS,DELPA
COMMON/DTOW3/ TSAT,TTD2,TD,WIN
COMMON/COST1/ CSTEAM,CPLN,CPIPE,CCOND,CPUMP,CWDT5,CSTFN,CPLNNW,
1COSM,CTURB,CFAN,CEEQ,CSCCOOL,CFUEL,CCSYS,CCWQC,OPCWQC
COMMON/DTOW4/MTCW,AMPT,DIAMT,W3,W4,VAIR,
1QIN,QREJ,HRFAC,T4,NFAN,NLM,FLOSS,
2DPCON,DPPIP,SCPOW,PPOW,FPOW,XNPASS,TL5H,AREAPS,XNTS
COMMON/DTOW6/ CONK
COMMON/INPUT1/ HRFACB,HRFMIN,HRFMAX,T1MAX,TSMIN,TSMAX,TEFF,
1TPO(13),BP1,BP2,BP3
COMMON/INPUT2/ ECCOS,CCOS,CAPF,FCOS,FCR,PSIZE,PLANC,STEAMC,
1TURBC,PER,PTTURB,CSCCM,CWQCC,CWQCOP,SUPCC,SUPCP
COMMON/INPUT3/ EFPF,EFFF,RFCOV,VELCON,VELW,PFACT,EFFB
COMMON/INPUT6/ DIS1,CU,GCF,CF,CPMPC1,CPMPC2,GPMFF,AREAPP,
1TOD,1ID,DFAN
COMMON/INPUT8/ITRACK
COMMON/DTOW9/ FF1,FF2,FAIR
COMMON/IN5/CSFPL,DENSPL
COMMON/IN8/SP
COMMON/INA/ISTM(21),PSTM(21),HR(19)
KCONV=0
CALL TABLE(TSAT,TSTM,PSTM,21,P)
CALL TABLE(P,PSTM,HR,19,HRATE)
HRFAC=HRATE/HR(19)
TEFFM=3413./HRATE
HEATIN=3577.5*1000.*3413.
POUT=HEATIN*TEFFM/(3413.*1000.)
QHEAT=HEATIN
OREJ=QHEAT*(1.-TEFFM)

```

```

TOUT=TSAT-TID2
TLIN=TCUT
58 CALL WDIOW(AL,ANPL,ANG,AMA,TD,WIN,AMLIN,TLIN,WPACK,RANGE,
LQREJM,DMLM,T4,1)
IF(QREJM.EQ.0.) GO TO 10
ANOM=QREJ/QREJM
TWL=ANOM*DMLM
20 TIN=TOUT-RANGE
TMEAN=(TIN+TCUT)/2.
DENM=EXP(-1.3656E-4*TMEAN+4.1413)
IF(RANGE.LE.0.) GO TO 10
W3=QREJ/RANGE.
GPMCON=W3*7.48/(G0.*DENM)
XNSH=2.
GPM5H=GPMCON/XNSH
TDLM=RANGE/ALOG((RANGE+TID2)/TID2)
59 IF(TIN-100.) 60,60,61
60 IF(TIN.LT.75.) GO TO 67
TCF=1.03+0.0028*(TIN-75.)
GO TO 62
67 TCF=-0.19+0.0275*TIN-0.00015*TIN**2
GO TO 62
61 TCF=1.15+0.001888*(TIN-100.)
62 US=CU*SQRT(VELCON)*TCF*GCF*CF
AREAPS=(QREJ/XNSH)/(US*TDLM)
TL=AREAPS*VELCON*GPM5H/(AREAPF*GPM5H)
XNPASS=1.
IF(TL.GT.50.) XNPASS=2.
TL5H=TL/XNPASS
XNTS=XNPASS*AIN(TGPM5H/(VELCON*GPM5H)+0.5)
CALL DELP(TID,VELCON,TMEAN,PCON1,1)
DPCONT=PCONT*TL
DPENT=(-0.0633+0.03766*VELCON+0.01133*VELCON**2+0.0003333*VELCON
1**3)*XNPASS
DPWB=(-0.1434+0.04204*VELCON+0.01733*VELCON**2)*XNPASS
DPCON=DPENT+DPWB+DPCONT
63 CALL SUFCO(TL5H,XNTS,AREAPS,XNSH,CCOND)
SCPOW=SUPCP/1000.
CSCOO=L=SUPCC
21 W4=ANOM*AMA*AL*(ANPL-1.)*SP/12.
GO TO 11
10 KCONV=1
RETURN
11 GPMTOT=W3*7.48/(60.*62.)
CALL PIPE(1,GPMTOT,NLTOT,VELTOT,DIATOT,PIPTOT,VCSTOT,DUMY,DUMMY,
IDUM,DUMM,TCSTOT,EL1TCT,EL2TOT,FLCTOT)
IF(NLTOT.LT.5) GO TO 39
GO TO 10
39 XTOW=2.*NLTOT
40 AMPT=ANOM/XTOW
ELENI=AMPT*SP*(ANPL-1.)/12.
DIAMI=ELENI/3.1416
IF(DIAMI.GT.350.) GO TO 41
IF(DIAMI.GT.30.) GO TO 42
DIAMI=30.
GO TO 42
41 XTOW=XTOW+2.*NLTOT
GO TO 40
42 MTOW=XTOW
43 MTOW=XTOW
44 NXTOW=MTOW/2
DIAMO=DIAMI+2.*WPACK
DIAMT=DIAMI
GPM5M=GPMTOT/NLTOT
NFAN=3.1416*MTOW*DIAMT/(2.*32.)
NLM=NLTOT

```

```

GPMR=GPM/(2*NXTOW)
45 PIPA=0.
DPIPA=0.
RFCSTA=0.
TCSA=0.
ELCSTA=0.
DO 70 I=1,NXTOW
GMA(I)=GPM-2*(I-1)*GPMR
CALL PIPE(1,GMA(I),NLA(I),VELA(I),DIAA(I),PIPCSA(I),VCSA(I),
1CRCA1(I),CRCA2(I),TWPA(I),CPC3A(I),TCSA(I),ELICSA(I),EL2CSA(I),
2FLCSA(I))
PIPCA(I)=PIPCSA(I)*1.5*DIAMT*2
IF(I.GT.1) GO TO 71
REDCA(I)=0.
GO TO 72
71 REDCA(I)=2.*(TWPA(I-1)*CRCA1(I-1)+CRCA2(I-1)+1.67*(1.+DIAA(I-1)
1/DIAA(I))*CPC3A(I-1)*DIAA(I-1))*1.1
72 IF(I.EQ.NXTOW) GO TO 73
ELA(I)=0.
TCA(I)=TCSA(I)*4
GO TO 74
73 TCA(I)=TCSA(I)*2
ELA(I)=EL2CSA(I)*2
74 PIPEA=PIPEA+PIPCA(I)
TCSA=TCSA+TCA(I)
ELCSTA=ELCSTA+ELA(I)
RFCSTA=RFCSTA+REDCA(I)
CALL DELP(DIAA(I),VELA(I),TMEAN,DPIPA(I),2)
DPIPA=DPIPA+DPIPA(I)
DPIPA=DPIPA+DPIPA(I)
70 CONTINUE
IF(NLM-1) 90,90,91
90 ELCSTA=ELCSTA
GO TO 98
91 IF(NLM-2) 92,92,93
92 ELCSTA=ELCSTA+4*ELICSA(1)
GO TO 98
93 IF(NLM-3) 94,94,95
94 ELCSTA=ELCSTA+8*ELICSA(1)/3
GO TO 98
95 IF(NLM-4) 96,96,97
96 ELCSTA=ELCSTA+4*ELICSA(1)+EL2CSA(1)
GO TO 98
97 ELCSTA=ELCSTA+4*ELICSA(1)+0.8*EL2CSA(1)
98 TLR=4*DIAMT*NXTOW/6
CALL PIPE(1,GPMR,NLR,VELR,DIAR,PIPCSR,VCSR,CRCR1,CRCR2,TWPR,
1CPC3R,TCSR,ELICSR,EL2CSR,FLCSR)
PIPCR=PIPCSR*TLR
TCR=TCSR*2*NXTOW*2
CALL DELP(DIAR,VELR,TMEAN,DPRR,2)
DPR=DPRR*DIAMT*2./6.
GPMH=GPMR/4.
CALL PIPE(1,GPMH,NLH,VELH,DIAH,PIPCSH,VCSH,CRCH1,CRCH2,TWPH,
2CPC3H,TCSH,ELICSH,EL2CSH,FLCSH)
PIPCH=PIPCSH*(3.5*DIAMT*2.+AL)*2.*NXTOW
TCH=TCSH*4*4*NXTOW
VCH=VCSH*16*NXTOW
FCH=FLCSH*NXTOW*32
EL1CH=ELICSH*2*4*NXTOW
EL2CH=EL2CSH*24*NXTOW
CALL DELP(DIAH,VELH,TMEAN,DPRH,2)
DPRH=DPRH*(2.*DIAMT+AL)*1.45
DPPIP=DPIPA+DPIPA(I)*2.0*1.45*(DIST-DIAMC)+DPR+DPRH
CPIB=PIPEA+PIPCSA(1)*2.0*(DIST-DIAMC)+PIPCR+PIPCH
CPTOT=NLTOT*CPIB
CRFCE=NLTOT*RFCSTA

```

```

CT=NLTOT*(FCSTA+PCR+TCH)
CELEW=(EL1CH+EL2CH+ELCSTA)*NLTOT
CVALV=VCH*NLTOT
CFLN=FCH*NLTOT
CPIPE=CPTOT+CT+CELEW+CRFCE+CVALV+CFLN
AREAT=3.1416*DIAMO**2/4
AV4AR=(T4+460.)/(TD+460.)
AVMAR=((T4+TD)/2.+460.)/(TD+460.)
DHYD=4.*AL*SP/(2.*(AL+SP/12.))/12.
FAIR=SQRT(0.5*(FF1**2+FF2**2))
AAT=(T4+TD)/2.
VA=53.35*(AAT+460.)/(14.7*144.)
VE=VA*AMA*(ANPL-1.)*AL*SP*AMPT*MTOW*4./(12.*3.1416*
1NFAN*3600.*DFAN**2)
AFRON=AL*SP*(ANPL-1.)/12.
GAIR=AMA
VAIR=GAIR*VA/3600.
DELPA=4.*FAIR*WPACK*VAIR*VAIR/(64.4*VA*DHYD)
SIGMA=1.0
FLOSS=(1.-KFCOV)*VE*VE/(64.*VA)
HPAIR=W4*VA*(DELPA+FLOSS)/(3600.*550.)
FBHP=HPAIR/EEEE
CALL FANSYS (FBHP,NFAN,DFAN,CSTFAN)
CFAN=CSTFAN*NFAN
CALL ELECEQ (FBHP,NFAN,CEQFAN)
HPWAT=(DPPIP+DPCON+AL)*W3/(3600.*550.)
PBHP=HPWAT/EEEE
PPOW=PBHP/1341.
CPUMP=CPMPC1+PPOW*1000.*CPMPC2
CEEQ=CEQFAN
FPOW=FBHP/1341.
QIN=QHEAT
QREJ=QIN*(1.-TEFFM)
CONK=TTD2/QREJ
CFUEL=FCOS*QIN*8760.*CAFF/(EFFB*1000000.)
CSTEAM=(PSIZE+PPOW+FPOW+SCPOW)*HRFAC*(HRFACB-1.)*STEAMC*1000.
1/HRFACB
CTURB=(PSIZE+PPOW+FPOW+SCPOW)*HRFAC*1000.*TURBC*PTTURB/HRFACB
CPLN=PLANC*PSIZE*1000.
PSIZNW=1212.4
CPLNNW=PLANC*PSIZNW*1000.
AREAT=3.1416*DIAMO**2/4.
WTFAN=NFAN*7600.
WTWAT=62.*3.1416*(DIAMO**2-DIAMI**2)/12.
WTPP=1.4*AL*WPACK*0.025*62.4*DENSPL/12.
WTPLT=ANPL*AMPT*WTPP
WIRF=((WTFAN+WTWAT)/(AFRON*AMPT))+40.
CSTFN=(0.2458*AREAT*AL*MTOW*(0.00305*WTRF+0.878)+0.019*(WTPLT+
1WTWAT)+0.82*AREAT*MTOW)*1.1
CCWQC=CWQCC*GPMTOT
OPCWQC=CWQCOP*GPMTOT
CWDTS=CSFPL*AL*(WPACK+ANG*5./12./16.)*ANPL*AMPT*MTOW
CCSYS=CSTFN+CWDTS+CFAN+CEEQ+CCOND+CPIPE+CPUMP+CCWQC+CSCOGL
CCSYS=CCSYS*1.20*CSOCCM
COSM=(CCSYS+CSTEAM+CTURB+CPLNNW)*PER
TCOS=((CCSYS+CSTEAM+CTURB+CPLNNW)*FCR+COSM+
1OPCWQC+CFUEL)/(PSIZE*8760.*CAFF)

```

341 RETURN

END

SUBROUTINE WDTOW(AL,ANPL,ANG,AMA,TD,WIN,AMLIN,TLIN,WPACK,RANGE,
1QREJM,DMLM,T4,IP)

C THIS COMPUTER PROGRAM MODELS THE PERFORMANCE OF THE M.I.T
C CROSSFLOW ADVANCED WET/DRY COOLING TOWER BY MEANS OF A FINITE
C ELEMENT TECHNIQUE.
COMMON/INPUTB/ITRACK
COMMON/IND/PTTCH

```

COMMON/INB/SP
COMMON/INL/HDP,HD
INTEGER AIRHUM,AIRTEM,AIRFLO
REAL OUTAIR(5),OUTHUM(5),OUTLIQ(5),OUTFLO(5),NU
REAL KP,L,NG,NPL,MLIN,MLOUT,DATA(3,3,5),MA,NCMIX
LOGICAL LMIX
DATA YESMIX/' '/,NOMIX/'UN'/
7 LMIX=.FALSE.
PITCH=(WPACK*12.+5./16.)/(ANG+1.)
RIBHT=9.25
L=12.*AL
NPL=ANPL
THETA=10.0
TP=0.025
KP=120.
NG=ANG
MA=AMA*(ANPL-1.)*AL*SP/(60.0*12.)
TIN=TD
MLIN=ANLIN/60.0
P=30.0
PACKW=12.0*WPACK
B=PACKW+NG*(5./16.)
ATOT=2.*B*L
AWET=(5./16.)*NG*L
ADRY=ATOT-2.*AWET+L*(PACKW+5./16.)*2.*0.25/2.5
RATIO=AWET/ADRY
C THE FOLLOWING ARBITRARILY SELECTED INDEX IXX ESTABLISHES THE
C NUMBER OF ROWS AND COLUMNS INTO WHICH THE WHOLE PACKING SECTION
C WILL BE DIVIDED FOR PURPOSES OF ANALYSIS.
206 IXX=5
XX=IXX
C THE NEXT FIVE CARDS DEFINE THE VALUES OF FIVE IDENTIFICATION
C PARAMETERS FOR THE STORING OF INPUT PARAMETERS PER FINITE
C ELEMENT OF PACKING SECTION.
LIQTEM=1
AIRTEM=2
LIQFLO=3
AIRFLO=4
AIRHUM=5
C NEXT CARD CALCULATES THE AREA FOR AIR FLOW INTO FINITE ELEMENT
C OF PACKING.
AFABLK=L*NPL*SP/144./XX
C THE NEXT STATEMENT DEFINES THE REFERENCE TEMPERATURE IN DEGREES
C ABSOLUTE.
T0=TLIN+459.67
C DO LOOP TO ASSIGN THE INLET CONDITIONS OF WATER AND AIR INTO THE
C COOLING TOWER.
DO 11 I=1,IXX
DATA(I,I,LIQTEM)=TLIN+459.67
DATA(I,I,AIRTEM)=TIN+459.67
DATA(I,I,LIQFLO)=MLIN*60./XX
DATA(I,I,AIRFLO)=MA*60./XX
DATA(I,I,AIRHUM)=WIN
11 CONTINUE
C IF STATEMENT TO ESTABLISH IF COOLING TOWER IS OF THE TOTALLY
C DRY KIND.
IF(RATIO.EQ.0.)ABLIQ=0.
C IF STATEMENT TO CALCULATE TOTAL AREA FOR CONVECTIVE HEAT TRANSFER
C FROM WATER TO AIR PER FINITE ELEMENT OF PACKING.
IF(RATIO.GT.0.) ABLIQ=B/(.5/RATIO+1.)*L*NPL/XX**2.
1 /144.
IF(RATIO.EQ.1.) ABLIQ=2.*B*L*NPL/144./XX**2.
C ABDRY IS THE DRY AREA PER FINITE ELEMENT OF PACKING ON THE
C SIDE OF THE WATER CHANNELS ONLY.
ABDRY=L*NPL*B/XX**2./144. -2.*ABLIQ
C STATEMENT TO FIND EQUIVALENT DISTANCE BETWEEN CHANNELS.

```

```

D=ABDRY/L*XX/NG*XX*12./NPL
ABDRY=ABDRY+L*(PACKW+5./16.)*0.25*2.*NPL/(2.5*144.*XX**2.)
SOP=1.0
RIB1=RIBHT
C CALL TO SUBROUTINE HAN TO CALCULATE THE CONVECTIVE HEAT TRANSFER
C COEFFICIENTS FOR SENSIBLE AND EVAPORATIVE HEAT TRANSFER.
CALL HAN (RIB1,SP,L,NPL,P,TIN,MA,HDP1,SOP)
IF(HDP1.GE.0.) GO TO 15
HDP1=.01
15 RIB2=0.2706
SOP=2.0
CALL HAN (RIB2,SP,L,NPL,P,TIN,MA,HDP2,SOP)
IF(HDP2.GE.0.) GO TO 16
HDP2=.01
16 HDP=(HDP1**2+HDP2**2)/(HDP1+HDP2)
IF(HDP.GE.6.5) H=HDP+2.125
IF(HDP.LT.6.5) H=HDP+3.50
IF(HDP.LE.6.0) H=HDP+4.50
C NESTED DO LOOP TO DETERMINE PROPERTIES OF WATER AND AIR AT THE
C INLET AND OUTLET OF EACH FINITE ELEMENT USING SUBROUTINE BLOCK
17 DO 33 J=1,IXX
DO 22 I=1,IXX
II=I+1
JJ=J+1
211 CALL BLOCK(DATA(I,J,AIRTEM),DATA(I,J,LIQTEM),DATA(I,J,AIRHUM),
1DATA(I,J,LIQFLO),DATA(I,JJ,AIRTEM),DATA(II,J,LIQTEM),
2DATA(I,JJ,AIRHUM),DATA(II,J,LIQFLO),IXX,AFABLK,ABLIQ,ABDRY,P,
3DATA(1,1,4),TL,KP,TP,RATIO,NU,H,D)
22 CONTINUE
33 CONTINUE
C OUTAIR,OUTHUM,OUTLIQ,AND OUTFLO.
C OUTLET PROPERTIES OF THE AIR AND WATER ARE STORED ALSO IN ARRAYS
C OUTAIR,OUTHUM,OUTLIQ,AND OUTFLO.
DO 18 I=1,IXX
OUTAIR(I)=DATA(I,IXX+1,AIRTEM)-459.67
OUTHUM(I)=DATA(I,IXX+1,AIRHUM)
OUTLIQ(I)=DATA(IXX+1,I,LIQTEM)-459.67
OUTFLO(I)=DATA(IXX+1,I,LIQFLO)/60.
18 CONTINUE
FL=0.
ATL=0.
C DO LOOP TO FIND TOTAL ATL AND FL.
DO 31 I=1,IXX
ATL=ATL+DATA(IXX+1,I,LIQTEM)
FL=FL+DATA(IXX+1,I,LIQFLO)
31 CONTINUE
C OUTLET WATER MASS FLOW RATE AND OUTLET WATER TEMPERATURE ARE
C COMPUTED.
MLOUT=FL/60.
TLOUT=ATL/XX-459.67
J=IXX+1
C CALL MIX TO FIND AVERAGE OUTLET AIR TEMPERATURE AND AVERAGE
C OUTLET SPECIFIC HUMIDITY.
CALL MIX(DATA,IXX,J,DATA(1,1,4),WOUT,TAV)
TOUT=TAV-459.67
C TOTAL ENERGY TRANSFER FROM WATER.
QTOT=(TLIN-TLOUT)*MLOUT+MA*(WOUT-WIN)*(TLIN-32.)
C TOTAL EVAPORATIVE HEAT TRANSFER FROM WATER.
QEL=(MLIN-MLOUT)*(-.5942*(TLIN+460.))+1370.16
1 -(.240)*(TLIN-TOUT)
C RATIO OF EVAPORATIVE HEAT TRANSFER TO TOTAL HEAT TRANSFER.
QRAT=QEL/QTOT*100.
C NET CHANGE IN AVERAGE AIR TEMPERATURE.
DELT=TOUT-TIN
C NET CHANGE IN AVERAGE WATER TEMPERATURE
DELTL=TLOUT-TLIN

```



```

C      PERCENTAGE OF WATER THAT VAPORIZES.
      FML=(MLIN-MLCUT)/MLIN*100.
      RANGE=TLIN-TLCUT
      QREJM=60.0*QTOT
      DMLM=60.0*(MLIN-MLCUT)
      T4=TCUT
44     OUTMIX=NOMIX
      IF(LMIX)OUTMIX=YESMIX
C      FOLLOWING ARE THE STATEMENTS TO PRINT OUT THE RESULTS OF THE
C      MODELING.
      IF(IP.NE.1) GO TO 100
      WRITE(6,48) H,HDP,HD,NU
48     FORMAT(5X,' H=',F8.2,' HDP=',F8.2,' HD=',F8.2,' NU=',F8.2)
      WRITE(6,50)RATIO,L,E,PACKW,NPL,NG,SP,THETA
      WRITE(6,60)IP,KP,TD,MA,P,TIN,TCUT,WIN,WOUT,MLIN,MLCUT
      WRITE(6,70)TLIN,TLCUT,DELTL,FML,DELT,QTOT,QEL,QRAT
50     FORMAT(2X,'TOWER GEOMETRY' /2X,'WET-DRY SURFACE ',
      *'RATIO=',F6.3 /2X,'PACKING HEIGHT=',F7.2,' IN.' /2X,'TOTAL ',
      *'HEAT TRANSFER SURFACE WIDTH=',F8.2,' IN.' /2X,'PACKING ',
      *'WIDTH=',F7.2,' IN.' /2X,'NUMBER OF PLATES=',F9.0 /2X,'NUMBER',
      *' OF CHANNELS PER PLATE=',F8.2 /2X,'PLATE SPACING=',F5.2
      *,' IN.' /2X,'PLATE ANGLE FROM VERTICAL=',F4.1,' DEGREES'/)
60     FORMAT(2X,'PLATE THICKNESS=',F5.3,' IN.' /2X,'PLATE CONDUCTIVITY
      *=',F7.3,' BTU/HR FT F' / 2X,'REFERENCE TEMPERATURE=',F7.2,
      *' R' / 30X,'INLET',17X,'OUTLET' / 2X,'AIR FLOW RATE',6X,E9.3
      *,' LBM/MIN' / 2X,'AIR PRESSURE',9X,F5.2,' IN. HG' / 2X,
      *'AIR TEMPERATURE',5X,2(F7.2,' F',13X) / 2X,'HUMIDITY',13X,2(F8.6,
      *' LBM/LBM',7X) / 2X,'WATER FLOW RATE',4X,2(E9.3,' LBM/MIN',6X)/)
70     FORMAT(2X,'WATER TEMPERATURE',3X,2(F7.2,' F',14X)/// 2X,'WATER '
      *,'TEMPERATURE CHANGE=',F7.2,' F' / 2X,'PERCENT WATER LOSS=',
      *F8.2,' %' / 2X,'AIR TEMPERATURE CHANGE=',
      *F7.2,' F' / 2X,'TOTAL HEAT TRANSFER=',E11.3,' BTU/MIN'//
      *2X,'EVAPORATIVE HEAT TRANSFER=',E11.3,' BTU/MIN' / 2X,
      *'PERCENT EVAPORATIVE HEAT TRANSFER=',F4.1,' %')
100    RETURN
      END
      SUBROUTINE HAN(RIBHT,SP,L,NPL,P,TIN,MA,HDP,SOP)
C
C      THIS SUBROUTINE CALCULATES THE HEAT TRANSFER COEFFICIENTS BETWEEN
C      THE AIR AND THE DRY AREA OF THE PLATE USING THE J.C. HAN
C      CORRELATIONS FOR RIB-ROUGHENED SURFACES.
C
      COMMON/INPUT8/ITRACK
      COMMON/IND/PITCH
      COMMON/DIOW9/ FF1,FF2,FAIR
      REAL L,NPL,MA,MUA,NUN,K,NLHP
C
      TA=TIN+460.
C
      DH=SP/6.0
C
      AFA=L*NPL*SP/144.
C
      ROA=(70.727*P)/(53.35*TA)
C
      VA=MA/(60.0*ROA*AFA)
C
      MUA=7.42E-07*SQRT(TA)/(1.0+(205.2/TA))
C
      RE=ROA*VA*DH/MUA
C
      IF(SOP.EQ.2.0) GO TO 44
      POE=10.
      IF(POE.LI.10.) RFC=4.9*(10./POE)**0.13

```

```

      IF (POE.GE.10.) RFC=4.9/(10./POE)**0.324
      GO TO 55
44  POE=FITCH/RIBHT
      IF (POE.LT.10.) RFC=4.9*(10./POE)**0.13*0.7763
      IF (POE.GE.10.) RFC=4.9/(10./POE)**0.53*0.7763
55  REP=RFC
      FFF=REP-2.5*ALOG(2.*RIBHT/DH/12.0)-3.75
\c0
      FF=2./(FFF**2)
\c0
      EPLUS=(RIBHT*RE)/(12.0*DH*FFF)
\c0
      IF (EPLUS.GE.35.0) GO TO 20
\c0
      DO 5 J=1,20
\c0
      EPLUS1=EPLUS
\c0
      REP=RFC*((EPLUS1/35.0)**(-.40))
\c0
      FFF=REP-2.5*ALOG(RIBHT/SP)-3.75
\c0
      FF=2.0/(FFF**2)
\c0
      EPLUS2=(RIBHT*RE)/(12.0*DH*FFF)
\c0
      EPLUS=(EPLUS1+EPLUS2)/2.0
\c0
      IF (ABS(EPLUS2-EPLUS1) .GT. 0.50) GO TO 5
      GO TO 20
\c0
5  CONTINUE
\c0
      WRITE(6,10) EPLUS
\c0
10  FORMAT (5X,'EPLUS=',F8.2)
\c0
20  IF (SOP.EQ.1.) CONST=10.00000
\c0
      IF (SOP.EQ.2.) CONST=13.66040
\c0
      NLHP=ALOG(CONST)+0.28*ALOG(EPLUS/35.)
\c0
      IF (EPLUS .LT. 35.0) NLHP=ALOG(CONST)
\c0
      HPLUS=EXP(NLHP)
\c0
      STN=FF/((HPLUS-REP)*SQRT(2.*FF)+2.0)
\c0
      NUN=0.72*STN*RE
\c0
      K=0.0008946*SQRT(TA)/(1.+(205.2/TA))
\c0
      HDP=NUN*K/DH
\c0
      IF (SOP.EQ.1.) FF1=FF
      FF2=FF
30  RETURN
\c0
      END
\c0
      SUBROUTINE BLOCK(TIN,TLIN,WIN,MLIN,TCUT,TLOUT,WOUT,MLOUT,IXX,
\c0
      I AFABLK,ABLIQ,ABDRY,PP,MAG,TD,KP,TP,RATIO,NU,H,D)
      COMMON/INL/HLP,HD
C      THIS SUBROUTINE ANALYSES THE TRANSPORT PROCESSES TAKING PLACE

```

HAN1600

HAN1700

HAN1800

HAN1900

HAN2000

HAN2100

HAN2200

HAN2300

HAN2400

HAN2500

HAN2600

HA

HAN2600

HAN2900

HAN3000

HAN3100

HAN3400

HAN3500

HAN3600

HAN3700

HAN3800

HAN3900

HAN4000

HAN4100

HAN4200

HAN4300

HAN4400

BLOCK10

BLOCK30

\c0	C	INSIDE THE COOLING TOWER PER FINITE ELEMENT OF PACKING.	BLOCK64
\c0	C	REAL K, KP, MAG, MUA, MUL, MV, NU, MLIN, MLOUT, ML	BLOCK65
\c0	C	BELOW THE QUANTITIES NEEDED TO DETERMINE THE INCREMENTAL	BLOCK66
\c0	C	TRANSFERS OF HEAT AND MASS PER FINITE ELEMENT ARE EVALUATED.	BLOCK70
\c0		COMMON/INPUT8/ITRACK	
		IF (TLIN.GT.0.AND.TIN.GT.0.) GO TO 1	
		IF (TLIN.GT.0.) GO TO 2	
		TLIN=460.	
		WRITE (6,55) TLIN	
	55	FORMAT(' TLIN IS DEFAULTED TO',F10.2,' DEG R')	
		2 IF (TIN.GT.0.) GO TO 1	
		TIN=460.	
		WRITE (6,56) TIN	
	56	FORMAT(' TIN IS DEFAULTED TO',F10.2,' DEG R')	
		1 CA=.241	
		CL=1.	BLOCK99
\c0		PR=.72	BLOCK10
\c0		RV=85.775	BLOCK11
\c0		P=PP*70.727	BLOCK12
\c0		RA=53.35	BLOCK13
\c0		HFG0=-.5942*TW+1370.16	BLOCK14
\c0		MV=WIN*MAG	BLOCK15
\c0		ROA=P/((WIN*RV+RA)*TIN)	BLOCK16
\c0		ROV=WIN*ROA	BLOCK17
\c0		IF (TLIN-500.) 3,3,4	BLOCK18
\c0		3 ROL=62.4	BLOCK19
\c0		GO TO 6	BLOCK20
\c0		4 ROL=62.4-2.4792E-04*((TLIN-500.0)**1.8)	BLOCK21
\c0		6 PA=ROA*RA*TIN	BLOCK22
\c0		PV=P-PA	BLOCK23
\c0		HFG=1370.16-0.5942*TLIN	BLOCK24
\c0		PVSAT=1.44E+26*(0.0006369*TLIN+2.0883)*EXP(-12386./TLIN)*	BLOCK25
\c0		1(TLIN**(-5.387))	BLOCK26
\c0		ROVSAT=PVSAT/RV/TLIN	BLOCK27
\c0		ROMIX=(ROA+ROV*WIN)/(1.+WIN)	
\c0	101	K=.0008946*SQRT(TIN)/(1.+(205.2/TIN))	BLOCK29
\c0		CV=((19.86)-(597./SQRT(TIN))+(7500.0/TIN))/18.0	BLOCK30
\c0		CMIX=(CA+CV*WIN)/(1.+WIN)	BLOCK31
\c0	C	CALCULATION OF MASS DIFFUSIVITY COEFFICIENT OF VAPOR INTO AIR.	BLOCK32

```

\c0 REAL DATA(30,30,5) MIX5000
\c0 AIRTEM=2 MIX6000
\c0 AIRHUM=5 MIX7000
\c0 C INITIALIZATION VALUES OF TOTAL ENTHALPY OF MIXTURE AND TOTAL MIX8000
\c0 C SPECIFIC HUMIDITY. MIX9000
\c0 HAIR=0. MIX1000
\c0 WAIR=0. MIX1100
\c0 C DO LOOP TO FIND TOTAL HAIR AND TOTAL WAIR. MIX1200
\c0 DO 1 I=1,IXX MIX1300
\c0 HAIR=HAIR+((.241)+(.45)*DATA(I,J,AIRHUM))*AIRFLO* MIX1400
\c0 1 DATA(I,J,AIRTEM) MIX1500
\c0 1 WAIR=WAIR+DATA(I,J,AIRHUM) MIX1600
\c0 XX=IXX MIX1700
\c0 C AVERAGE OUTLET SPECIFIC HUMIDITY. MIX1800
\c0 WOUT=WAIR/XX MIX1900
\c0 C AVERAGE OUTLET MIXTURE TEMPERATURE. MIX2000
\c0 TOUT=HAIR/XX/AIRFLO/(.241+.45*WOUT) MIX2100
\c0 RETURN MIX2200
\c0 END MIX2300
\c0 SUBROUTINE PEFORM(TAIR,WAIR,TFREQ,ECCST,CCCST,FUELCS,WLOST)
DIMENSION RANGLT(10),QREMIT(10),DMLMIT(10),T4T(10),
1QREJT(10),WLOSS(10)
COMMON/DTOW1/ VAS(6),KCONV,JCONS,XDEPA
COMMON/DTOW2/ TCOS,DELPA
COMMON/DTOW3/ TSAT,TTD2,TD,WIN
COMMON/COST1/ CSTEAM,CPLN,CPIPE,CCOND,CPUMP,CWDTS,CSTFN,CPLNWW,
1COSM,C1URB,CFAN,CEEQ,CSCOO,CFUEL,CCSYS,CCWQC,OPCWQC
COMMON/DTOW4/MICW,AMPT,DIAMT,W3,W4,VAIR,
1QIA,QREJ,HRFAC,T4,NFAN,NLM,FLOSS,
2DPCON,DPPIP,SCPOW,PPOW,FPOW,XNPASS,TLSH,AREAPS,XNTS
COMMON/DTOW6/ CONK
COMMON/INPUT1/ HRFACB,HREMIN,HREMAX,T1MAX,TSMIN,TSMAX,TEFF,
1TPO(13),BP1,BP2,BP3
COMMON/INPUT2/ ECCOS,CCCOS,CAPF,FCOS,FCR,PSIZE,PLANC,STEAMC,
1TURBC,PER,P1TURB,CSCCM,CWQC,CCWQCOP,SUPCC,SUPCP
COMMON/DTOW8/ QRJMX(4),POWMX(4)
COMMON/INPUT5/ THROTT(4),EFFMX(4)
COMMON/INPUT7/ T11,T11ST
COMMON/INPUT8/ITRACK
COMMON/IN1/ T1T(10),HRT(10),QTUR(10),TLIN1T(10)
COMMON/INA/TSTM(21),PSTM(21),HR(19)
1L=1
HRMIN=HR(1)
TEFFMI=3413./HRMIN
T1=T11ST
DO 171 I=1,10

```

```

CALL WDTOW( VAS(1),VAS(2),VAS(3),VAS(4),TAIR,WAIR,VAS(5),
ITLINIT(1),VAS(6),RANGT(1),QREMIT(1),DMLMT(1),T4T(1),2)
QREJT(1)=QREMIT(1)*AMPT*MTOW
WLOSS(1)=DMLMT(1)*AMPT*MTOW
171 CONTINUE
IF(TAIR.EQ.TC) GO TO 1000
1 CALL TABLE(T1,TSTM,PSTM,21,P)
CALL TABLE(P,PSTM,HR,19,HRATE)
TEFFMT=3413./HRATE
HREJT=QIN*(1.-TEFFMT)
TTDT=CONK*HREJT
TWIN=T1-TTDT
CALL TABLE(TWIN,TLINIT,QREJT,10,TQREJ)
IF(ABS((HREJT-TQREJ)/HREJT).LT.0.03) GO TO 4
T1=T1+1.
T11=T1
IF(T1.GT.TSMIN.AND.T1.LT.134.) GO TO 1
4 IF(T11.GT.T1MAX) GO TO 12
IF(T11.GT.TSMIN) GO TO 16
33 HRATE=HRMIN
T11=TSMIN
TEFFMT=TEFFMI
HREJT=QIN*(1.-TEFFMI)
TTDT=HREJT*CONK
TWIN=T11-TTDT
GO TO 16
1000 T1=TSAT
T11=TSAT
TEFFMT=3419./HR(19)
HREJT=QIN*(1.-TEFFMT)
TWIN=T11-TTDT2
GO TO 16
12 IF(TQREJ.GT.HREJT) GO TO 33
T11=T1MAX
CALL WDTOW( VAS(1),VAS(2),VAS(3),VAS(4),TAIR,WAIR,VAS(5),
ITLINIT(10),VAS(6),RANGT,QRMMA,DMLMT,T4TT,2)
QREMAX=QRMMA*AMPT*MTOW
HREJT=QREMAX
TTDT=HREJT*CONK
CALL TABLE(HREJT,QRJMX,THROTT,3,PTTHRO)
CALL TABLE(PTTHRO,THROTT,POWMX,3,POUT)
CSFUEL=CFUEL*PTTHRO
GO TO 17
16 POUT=QIN*TEFFMT/(3413.*1000.)
PTTHRO=THROTT(1)
CSFUEL=CFUEL
17 RANGT=HREJT/W3
TINN=T11-TTDT-RANGT
SUCPOW=SCPOW
IF(TINN.LE.95.) SUCPOW=0.
PGEN=POUT-PCPW-FPOW-SUCPOW
IF(PGEN.GE.PSIZE) GO TO 5
CSTEC=(PSIZE-PGEN)*8760.*CAPF*1000.*ECCOS
CSTCC=(PSIZE-PGEN)*1000.*CCCOS
GO TO 6
5 CSTEC=0.
CSTCC=0.
CSFUEL=CFUEL*PSIZE/PGEN
6 FUELCS=TFREQ*CSFUEL
ECCST=TFREQ*CSTEC
CCCST=CSTCC
TTTDT=T11-TAIR-TTDT
TWIN=T11-TTDT
CALL TABLE(TWIN,TLINIT,WLOSS,10,WLOST)
WLOST=WLOST*TFREQ*8760.*CAPF
BLODN=WLOST*0.40

```

```

WLOST=WLOST+BLODN
IF(1D.EQ.1) GO TO 99
WRITE(6,8) TATR,T11,TTDT,TITDT,PGEN,PTTHRO,ECCST,WLOST
8 FORMAT(F10.2,4X,F10.2,2X,F10.2,4X,F10.2,1X,F10.2,6X,F10.2,10X,
1E12.5,10X,1E12.5)
99 RETURN
END
SUBROUTINE TABLE(X,XA,YA,M,ANSWER)
DIMENSION XA(200),YA(200)
COMMON/INPUT8/ITRACK
IF((XA(1)-X)*(XA(M)-X)) 2,2,1
1 IF(ABS(X-XA(1)).LT.ABS(X-XA(M))) N=1
IF(ABS(X-XA(1)).GT.ABS(X-XA(M))) N=M-2
GO TO 8
2 N=M-1
DO 4 I=1,N
IF(X.NE.XA(I)) GO TO 3
ANSWER=YA(I)
RETURN
3 IF((X.GT.XA(I)).AND.(X.LT.XA(I+1))) GO TO 5
IF((X.LT.XA(I)).AND.(X.GT.XA(I+1))) GO TO 5
4 CONTINUE
N=M-2
GO TO 8
5 IF(I-3) 6,7,7
6 N=1
GO TO 8
7 N=I-1
8 X1=XA(N)
X2=XA(N+1)
X3=XA(N+2)
Y1=YA(N)
Y2=YA(N+1)
Y3=YA(N+2)
X11=X1*X1
X22=X2*X2
X33=X3*X3
DETM=X22*X3-X33*X2-X11*X3+X33*X1+X11*X2-X22*X1
A=(Y2*X3-X2*Y3-Y1*X3+Y3*X1+Y1*X2-Y2*X1)/DETM
B=(X22*Y3-X33*Y2-X11*Y3+X33*Y1+X11*Y2-X22*Y1)/DETM
C=(Y1*(X22*X3-X33*X2)-Y2*(X11*X3-X33*X1)+Y3*(X11*X2-X22*X1))/DETM
ANSWER=A*X*X+B*X+C
RETURN
END
SUBROUTINE DELP(DIA,VEL,TWAT,DPR,IR)
DIMENSION ROUGH(2)
COMMON/INPUT8/ITRACK
DATA ROUGH/0.00006,0.0018/
VISC=7.3283E-4/TWAT
REYN=VEL*DIA/(12.*VISC)
IF(REYN-2000.) 1,2,2
1 F=16./REYN
GO TO 8
2 RELR=DIA/ROUGH(IR)
F1=4.*ALOG10(RELR)+2.28
F2=RELR*F1/REYN
IF(F2-0.01) 7,3,3
3 FTRY=F1
4 FTRY=F1-4.*ALOG10(1.+4.67*RELR*FTRY/REYN)
IF((ABS(FTRY-F1))/F1-0.001) 6,6,5
5 FTRY=F1
GO TO 4
6 F1=FTRY
7 F=1./F1**2
8 DPR=74.594*F*VEL**2/(DIA*100.)
RETURN

```

```

\c0      DV=(144.0*14.696*0.000140*((TIN+TLIN)/2.0)**2.5)/
\c0      1(((TIN+TLIN)/2.0+441.0)*P)
\c0      HD=(H/(ROBIX*CMIX))*((ROBIX*CMIX*DV/K)**(2./3.))
\c0      ML=SQRT((6.0*D*D*HDP)/(KP*TP))
\c0      IF(RATIO.GE.0.) NU=(TANH(ML))/ML
\c0      IF(RATIO.EQ.1.)NU=0.
\c0      IF(RATIO.EQ.0.)NU=.8
\c0      C THE CALCULATIONS BELOW ARE TO FIND THE INCREMENTAL CHANGES OF
\c0      C MASS, TEMPERATURE, HUMIDITY AND ENERGY PER FINITE ELEMENT.
\c0      201 DML=HD*(ROVSAT-ROV)*ABLIQ
\c0      DQCL=H*(TLIN-TIN)*ABLIQ
\c0      DQEL=(HFG+CL*(TLIN-T0))*DML
\c0      DQDP=(NU*HDP*(TLIN-TIN)*ABDRY*2.0)+HDP*(TLIN-TIN)
\c0      1 *ABLIQ*2.
\c0      IF(RATIO.EQ.1.)DQDP=0.
\c0      DQ=DQCL+DQEL+DQDP
\c0      DTL=((DQ+((MLIN-DML)*CL*(TLIN-T0)))/(MLIN*CL))-TLIN+T0
\c0      DMV=DML
\c0      DW=(MV+DMV)/MAG-WIN
\c0      DT=(-DQ-MAG*CA*(TIN-T0)-WIN*MAG*(CV*(TIN-T0)+HFG0)
\c0      1 +(WIN+DW)*MAG*HFG0)/(-MAG*CA-(WIN+DW)*MAG*CV)
\c0      2 -TIN+T0
\c0      C PROPERTIES OF FLUIDS AT THE EXIT OF FINITE ELEMENT.
\c0      MLOUT=MLIN-DML
\c0      TLOUT=TLIN-DTL
\c0      WCUT=WIN+DW
\c0      TOUT=TIN+DT
\c0      301 RETURN
\c0      C END
\c0      SUBROUTINE MIX(DATA,IXX,J,AIRFLO,WCUT,TOUT)
\c0      C THIS SUBROUTINE FINDS THE AVERAGE PROPERTIES OF THE AIR AT
\c0      C THE EXIT OF THE COOLING TOWER.
\c0      COMMON/INPUT8/ITRACK
      INTEGER AIRHUM,AIRTEM

```

BLOCK31
BLOCK34
BLOCK35
BLOCK36
BLOCK37
BLOCK38
BLOCK39
BLOCK40
BLOCK41
BLOCK42
BLOCK43
BLOCK44
BLOCK45
BLOCK46
BLOCK47
BLOCK48
BLOCK50
BLOCK51
BLOCK52
BLOCK53
BLOCK54
BLOCK55
BLOCK56
BLOCK57
BLOCK58
BLOCK59
BLOCK60
BLOCK61
MIX3000
MIX1000
MIX2000
MIX4000

```

END
SUBROUTINE SUFCON(TLA,XIS,AREAS,XNS,COND)
DIMENSION XLCST(2),TULCF(2)
COMMON/INPUT8/ITRACK
DATA TUBOD,IBAC/1.0,18/
DATA ERICST/2.5/
DATA SCC1,SCC2/10.836,102181./
DATA TUCST,WTPFT/1.3,0.510/
DATA XLCST/1.07,1.08/
DATA TULCF/0.0153,0.00042/
DATA SCF1,SCF2/0.0366,0.15/
CAX=0.3*AREAS
TULSUM=TLA*XIS*XNS
IF(TLA-60.) 7,8,8
8 ADLCST=XLCST(2)
GO TO 9
7 IF(TLA-50.) 10,6,6
6 ADLCST=XLCST(1)
GO TO 9
10 ADLCST=1.0
9 TUECST=TULSUM*TUCST*ADLCST*WTPFT*1.1
TUBLCF=(TULCF(1)+TULCF(2))*TLA+0.58
CONSCF=(SCF1*ALOG(XIS)-SCF2)
SHCST=SCC1*XIS+SCC2
SHLCST=(SHCST*(TUBLCF+CONSCF)+CAX)*XNS
FECST=ERICST*AREAS*XNS
COND=(SHLCST*0.88*1.14+TUECST+FECST)*1.10*1.1
21 RETURN
END
SUBROUTINE FANSYS(FBHP,NFAN,DFAN,CSTFAN)
COMMON/INPUT8/ITRACK
DATA XBLADE/8./
DATA CFF/472./
DATA CB1,CB2/25.2,-105./
DATA CSR/25./
DATA CER,WER/0.55,4.6/
DATA CRRS,WRRS/0.55,4.6/
CFAN=XBLADE*(DFAN*CB1+CB2)+CFF
HPFAN=FBHP/NFAN
IF(HPFAN-250.) 1,1,2
1 CE=1000.
CM=26.6
GO TO 3
2 CE=9000.
CM=24.3
3 CFE=HPFAN*(CSR+CM)+HPFAN**1.5+CE
CFPL=1.08*CER*WER*DFAN**2*1.1*1.1
CVRS=2.25*CRRS*WRRS*DFAN**2*1.1*1.1
CSTFAN=(CFAN+CFE+CFPL+CVRS)*1.1*1.1*1.15*1.1
4 RETURN
END
SUBROUTINE ELECEQ(HPX,NX,CSTX)
COMMON/INPUT8/ITRACK
HPXX=HPX/NX
IF(HPXX-250.) 1,1,2
1 CX=((203.-0.38*HPXX)*HPXX*NX)*1.25
GO TO 5
2 IF(HPXX-600.) 3,3,4
3 CX=5450.*HPXX**0.29*NX*1.25
GO TO 5
4 CX=480.*HPXX**0.77*NX*1.25
5 CSTX=CX*1.125*1.05*1.05*1.1
RETURN
END
SUBROUTINE PIPE(J,GPM,NL,VEL,DIAME,PIPCS,VCS,CRCC1,CRCC2,TW,
1CPCC3,TCS,EL1CS,EL2CS,FLCS)

```



```

COMMON/INPUT3/ EFFP, EFFF, RFCCV, VELCON, VELW, PFACT, EFFF
COMMON/PIPING/ TWP(23), DIA(23), CPC1(23), CPC2(23,2), CPC3(23),
1CRC1(23), CRC2(23,2), CTC1(23), CTC2(23,2), CE1C1(23), CE2C1(23),
2CE1C2(23,2), CE2C2(23,2), VALCST(23), FLCST(23)
COMMON/INPUTE/ITRACK
XL=1.0
3 DIAME=0.6391*SQRT((GPM/XL)/VELW)
IF (DIAME-DIA(23)) 1,1,2
2 XL=XL+1.
GO TO 3
1 DO 5 I=1,23
IF (DIAME-DIA(I)) 4,4,5
5 CONTINUE
4 NL=XL
DIAME=DIA(I)
VEL=0.4085*(GPM/XL)/DIAME**2
PIPCS=(TWP(I)*CPC1(I)+CPC2(I,J)+0.684*DIA(I)*CPC3(I))*1.1*1.1
VCS=VALCST(I)*1.1*1.1
TCS=(TWP(I)*CTC1(I)+CTC2(I,J)+5.01*DIA(I)*CPC3(I))*1.1*1.1
CRCC1=CRC1(I)*1.1
CRCC2=CRC2(I,J)*1.1
TW=TWP(I)
CPCC3=CPC3(I)*1.1
EL1CS=(TWP(I)*CE1C1(I)+CE1C2(I,J)+3.34*CPC3(I)*DIA(I))*1.1*1.1
EL2CS=(TWP(I)*CE2C1(I)+CE2C2(I,J)+3.34*CPC3(I)*DIA(I))*1.1*1.1
FLCS=FLCST(I)*1.1*1.1
RETURN
END

```


262.	404.	546.	831.	1117.	1323.	1530.	1934.
2338.	2848.	3359.	3976.	4594.	5163.	5733.	77160.
8600.	9858.	10717.	11358.	12000.	12750.	13500.	15072.
361.	1141.	1921.	2322.	2723.	4753.	6784.	54120.
24960.	28598.	32237.	36600.	40963.	45349.	49736.	1450.
58517.	65077.	71638.	78198.	84759.	91320.	97881.	5041.
110.	210.	310.	469.	620.	895.	1163.	1450.
1773.	2200.	2627.	3074.	3522.	4109.	4697.	5041.
6586.	7417.	8249.	8900.	9550.	9800.	10050.	1203.
164.	245.	326.	466.	607.	795.	983.	4700.
1543.	1871.	2200.	2615.	3031.	3401.	3772.	19007.
5639.	6347.	7055.	7705.	8355.	8955.	9555.	70000.
486.	1622.	2759.	3339.	3920.	6688.	9450.	70000.
29819.	35146.	40474.	59312.	53285.	59312.	65339.	10777.
76034.	87155.	98277.	101277.	104277.	113288.	122300.	28200.
191.	296.	402.	586.	770.	1045.	1320.	20455.
3959.	6473.	8986.	11530.	14073.	17802.	21530.	72221.
23956.	25610.	27264.	31264.	35264.	39132.	43000.	2035.
3966.	5550.	7134.	9815.	12496.	14725.	16954.	10793.
34800.	38120.	41378.	47486.	53593.	60252.	66910.	2035.
77531.	82806.	88081.	93356.	98631.	103906.	109181.	10793.
203.	394.	586.	898.	1210.	1722.	2235.	3218.
3435.	4247.	5059.	5937.	6815.	7930.	9045.	6420.
12542.	14169.	15797.	16898.	18000.	19800.	21600.	
342.	617.	893.	1145.	1398.	1934.	2471.	
2035.	2527.	3020.	3538.	4057.	4604.	5151.	
7690.	8638.	9587.	10543.	11500.	12600.	13700.	
.02220							
0.90	2.6						
1.00							
9902.	9902.	9902.	9902.	9904.	9910.	9914.	
9925.	9943.	9975.	9997.	10030.	10071.	10120.	
10167.	10220.	10270.	10315.	10360.			
58.80	70.43	79.03	85.93	91.72	96.73	101.14	105.09
108.71	112.01	115.06	117.89	120.56	123.05	125.43	128.05
129.78	131.80	133.76	140.78	146.86			
.50	.75	1.00	1.25	1.50	1.75	2.00	2.25
2.50	2.75	3.00	3.25	3.50	3.75	4.00	4.25
4.50	4.75	5.00	6.00	7.00			

r 16:17 0.625 277 level 2

r 16:54 12.393 1654

28.0 10.0 22.0 3000.0 30000.0 5.0

DESIGN DRY BULB TEMPERATURE TD = 98.000 DEGREE F
3000.0000

22.0

DESIGN ITD= 30.760 DEGREE F

H= 9.90 HDP= 7.78 HD= 674.86 NU= 0.83

TOWER GEOMETRY

WET-DRY SURFACE RATIO= 0.052

PACKING HEIGHT= 336.00 IN.

TOTAL HEAT TRANSFER SURFACE WIDTH= 66.88 IN.

PACKING WIDTH= 60.00 IN.

NUMBER OF PLATES= 10.

NUMBER OF CHANNELS PER PLATE= 22.00

PLATE SPACING= 1.00 IN.

PLATE ANGLE FROM VERTICAL=10.0 DEGREES

PLATE THICKNESS=0.025 IN.

PLATE CONDUCTIVITY =120.000 BTU/HR FT F

REFERENCE TEMPERATURE= 588.43 R.

INLET

OUTLET

AIR FLOW RATE	0.105e+04 LBM/MIN	
AIR PRESSURE	30.00 IN. HG	
AIR TEMPERATURE	98.00 F	116.20 F
HUMIDITY	0.022200 LBM/LBM	0.027250 LBM/LBM
WATER FLOW RATE	0.500e+03 LBM/MIN	0.495e+03 LBM/MIN
WATER TEMPERATURE	128.76 F	108.24 F

WATER TEMPERATURE CHANGE= -20.52 F

PERCENT WATER LOSS= 1.06 %

AIR TEMPERATURE CHANGE= 18.20 F

TOTAL HEAT TRANSFER= 0.107e+05 BTU/MIN

EVAPORATIVE HEAT TRANSFER= 0.539e+04 BTU/MIN

PERCENT EVAPORATIVE HEAT TRANSFER=50.6 %

0.0939 0.1796 0.1433

2.6579 0.1433 0.9975

TDB	TSAT	TTD	ITD	NET POWER	FRACTION OF
\cFULL-	ENERGY CHARGE	WATER LOSS			LOAD THROTT

\cLE

CAPITAL COST OF REPLACEMENT CAPACITY =\$ 0.90269e+07

REPLACEMENT ENERGY COST =\$ 0.21163e+07

ANNUAL FUEL COST =\$ 2.37666e+08

POWER PRODUCTION COST = 24.0330 MILLS/KW-HR

ANNUAL WASTE

\cR LOSS= 35.8149 %

DESIGN DRY BULB TEMPERATURE TD = 98.000 DEGREE F

3000.0000

22.0

DESIGN ITD= 30.760 DEGREE F

H= 9.90 HDP= 7.78 HD= 679.02 NU= 0.83

TOWER GEOMETRY

WET-DRY SURFACE RATIO= 0.052

PACKING HEIGHT= 336.00 IN.

TOTAL HEAT TRANSFER SURFACE WIDTH= 66.88 IN.

PACKING WIDTH= 60.00 IN.

NUMBER OF PLATES= 10.

NUMBER OF CHANNELS PER PLATE= 22.00

PLATE SPACING= 1.00 IN.

ANGLE

r 16:58 12.191 1010

26.0 10.0 30.0 3000.0 30000.0 5.0

DESIGN DRY BULB TEMPERATURE TD = 98.000 DEGREE F
3000.0000

30.0

DESIGN ITD= 32.760 DEGREE F

H= 9.80 HDP= 7.60 HD= 665.51 NU= 0.90

TOWER GEOMETRY

WET-DRY SURFACE RATIO= 0.071

PACKING HEIGHT= 336.00 IN.

TOTAL HEAT TRANSFER SURFACE WIDTH= 69.38 IN.

PACKING WIDTH= 60.00 IN.

NUMBER OF PLATES= 10.

NUMBER OF CHANNELS PER PLATE= 30.00

PLATE SPACING= 1.00 IN.

PLATE ANGLE FROM VERTICAL=10.0 DEGREES

PLATE THICKNESS=0.025 IN.

PLATE CONDUCTIVITY =120.000 BTU/HR FT F

REFERENCE TEMPERATURE= 588.43 R

INLET

OUTLET

AIR FLOW RATE 0.105e+04 LBM/MIN

AIR PRESSURE 30.00 IN. HG

AIR TEMPERATURE 98.00 F 115.60 F

HUMIDITY 0.022200 LBM/LBM 0.028586 LBM/LBM

WATER FLOW RATE 0.500e+03 LBM/MIN 0.493e+03 LBM/MIN

WATER TEMPERATURE 128.76 F 105.59 F

WATER TEMPERATURE CHANGE= -23.17 F

PERCENT WATER LOSS= 1.34 %

AIR TEMPERATURE CHANGE= 17.60 F

TOTAL HEAT TRANSFER= 0.121e+05 BTU/MIN

EVAPORATIVE HEAT TRANSFER= 0.682e+04 BTU/MIN

PERCENT EVAPORATIVE HEAT TRANSFER=56.5 %

0.0939 0.1644 0.1338

2.4816 0.1338 0.9909

	TDB	TSAT	TTD	ITD	NET POWER	FRACTION OF
\cFULL-	ENERGY CHARGE		WATER LOSS			LOAD THROTT

\cLE

CAPITAL COST OF REPLACEMENT CAPACITY =\$ 0.80455e+07

REPLACEMENT ENERGY COST =\$ 0.12113e+07

ANNUAL FUEL COST =\$ 0.37635e+08

POWER PRODUCTION COST = 23.7694 MILLS/KW-HR

\cR LOSS= 42.4453 %

ANNUAL WASTE

DESIGN DRY BULB TEMPERATURE TD = 98.000 D

QUIT

r 16:59 18.502 678 level 2

26. 10. 30. 3000. 30000. 5.

Substitution failed.

26. 10. 30. 3000. 30000. 5.

new Fortran 5b
r 17:11 12.274 1594

28.0 15.0 40.0 3000.0 30000.0 5.0

DESIGN DRY BULB TEMPERATURE TD = 98.000 DEGREE F
3000.0000

40.0
DESIGN ITD= 30.760 DEGREE F
H= 9.71 RDP= 7.59 HD= 656.70 NU= 0.95

LOWER GEOMETRY
WET-DRY SURFACE RATIO= 5.095
PACKING HEIGHT= 336.00 IN.
TOTAL HEAT TRANSFER SURFACE WIDTH= 72.50 IN.
PACKING WIDTH= 60.00 IN.
NUMBER OF PLATES= 10.
NUMBER OF CHANNELS PER PLATE= 40.00
PLATE SPACING= 1.00 IN.
PLATE ANGLE FROM VERTICAL=10.0 DEGREES

PLATE THICKNESS=0.025 IN.
PLATE CONDUCTIVITY =120.000 BTU/HR FT F
REFERENCE TEMPERATURE= 588.43 R

	INLET	OUTLET
AIR FLOW RATE	0.105e+04 LBM/MIN	
AIR PRESSURE	30.00 IN. HG	
AIR TEMPERATURE	98.00 F	114.69 F
HUMIDITY	0.022200 LBM/LBM	0.030040 LBM/LBM
WATER FLOW RATE	0.500e+03 LBM/MIN	0.492e+03 LBM/MIN
WATER TEMPERATURE	128.76 F	102.94 F

WATER TEMPERATURE CHANGE= -25.82 F
PERCENT WATER LOSS= 1.65 %
AIR TEMPERATURE CHANGE= 16.69 F
TOTAL HEAT TRANSFER= 0.135e+05 BTU/MIN

EVAPORATIVE HEAT TRANSFER= 0.837e+04 BTU/MIN
PERCENT EVAPORATIVE HEAT TRANSFER=62.0 %

0.0939 0.1513 0.1259
2.3328 0.1259 0.9922

TDB	TSAT	TTD	ITD	NET POWER	FRACTION OF
\cFULL-	ENERGY CHARGE	WATER LOSS			LOAD THROTT

\cLE

CAPITAL COST OF REPLACEMENT CAPACITY =\$ 0.72684e+07
REPLACEMENT ENERGY COST =\$ 0.91658e+06
ANNUAL FUEL COST =\$ 0.37546e+08
POWER PRODUCTION COST = 23.5325 MILLS/KW-HR

\cR LOSS= 49.3704 %

ANNUAL WATE

DESIGN DTEM

QUIT

r 17:13 14.451 979 level 2

MChoi WetDry logged out 08/29/79 1713.9 edt Wed
CPU usage 3 min 5 sec, memory usage 941.1 units.
hangup

x

Work reported in this document was sponsored by the Department of Energy under contract No. EY-76-S-02-4114.A001. This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Department of Energy, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product or process disclosed or represents that its use would not infringe privately owned rights.