

Technical Report No. 72591-74

FORCED-CONVECTION CONDENSATION INSIDE TUBES

by

Donald P. Traviss
Anton B. Baron
Warren M. Rohsenow

Sponsored by:

Technical Committee 1.3

American Society of Heating, Refrigeration, and Air Conditioning Engineers

Contract No: ASHRAE RP63

DSR Project No: 72591-74

July 1, 1971

Heat Transfer Laboratory
Mechanical Engineering Department
Massachusetts Institute of Technology
Massachusetts Avenue, Cambridge, 02139

FORCED-CONVECTION CONDENSATION INSIDE TUBES

by

Donald P. Traviss
Anton G. Baron
Warren M. Rohsenow

Massachusetts Institute of Technology

ABSTRACT

High vapor velocity condensation inside a tube was studied analytically. The von Karman universal velocity distribution was applied to the condensate flow, pressure drops were calculated using the Lockhart-Martinelli method, and heat transfer coefficients were calculated from the momentum and heat transfer analogy. Subsequently, the analysis was reduced to an accurate, but simplified form, to facilitate calculations.

Experimental data for refrigerants R-12 and R-22 condensing in a 0.315 in. I. D. tube were obtained for mass fluxes from 1.2×10^5 to 11.3×10^5 lbm/hr-ft², qualities from 0.02 to 0.96, and saturation temperatures from 75 to 140°F. On the basis of the data and analysis, a simplified non-dimensional presentation of the results evolved. The agreement between the majority of the data and the analysis was within ± 15 percent.

Acknowledgement

The authors are grateful to ASHRAE Technical Committee TC 1.3 for support of this work.

Table of Contents

Abstract.	1
Acknowledgment	2
Table of Contents.	3
Nomenclature.. . . .	4
Introduction	6
Experiment	8
General Description of Test Facility.	8
Test Procedure.	10
Data Reduction.	11
Analysis.	12
Calculation Procedure for Analytical Results.	27
Results.	29
Conclusions.	33
References	34
Figures.	36
Experimental Apparatus.	36
Graph of β vs. δ^+	38
Graph of M_{crit} vs. δ^+	39
Graph of F_2 vs. Re_ℓ	40
Baker Flow Regime Map	41
Comparison of Analysis and Heat Transfer Data	42
Comparison of Analysis and Pressure Gradient Data	59
Appendix 1. Tables of Data.	71
Appendix 2.	99
List of Relevant Variables for Computer Program	99
Computer Program for Calculating Analytical Results	101

Nomenclature

A	cross sectional area ft^2
a	axial acceleration due to external force ft/hr^2
B	buoyancy modulus
c	specific heat $\text{BTU/lbm-}^\circ\text{F}$
D	tube inside diameter ft
E	ratio of eddy conductivity to eddy viscosity
F_0	defined in Eq. (16) $\text{lb/ft}^2\text{-ft}$
F_2	defined in Eq. (28a,b,c)
Fr	Froude number
G	mass velocity $\text{lbm/ft}^2\text{-hr}$
g_0	constant: $4.17 \times 10^8 \text{ lbm-ft/lbf-hr}^2$
h_z	local heat transfer coefficient $\text{BTU/hr-ft}^2\text{-}^\circ\text{F}$
h_{avg}	average heat transfer coefficient $\text{BTU/hr-ft}^2\text{-}^\circ\text{F}$
h_{fg}	latent heat of vaporization BTU/lbm
K	thermal conductivity $\text{BTU/ft-hr-}^\circ\text{F}$
L	total length of condensation ft
M	defined in Eq. (25)
Nu	Nusselt number
dP/dz	pressure gradient $\text{lb/ft}^2\text{-ft}$
Pr	Prandtl number
q/A	heat flux BTU/hr-ft^2
Re	Reynolds number
S	perimeter ft
T	temperature $^\circ\text{F}$

ΔT	difference between vapor and wall temperatures °F
U	mean velocity ft/hr
u_{τ}	friction velocity as defined in Eq. (21) ft/hr
v_z	local axial velocity ft/hr
W	mass flow rate lbm/hr
x	quality
χ_{tt}	Lockhart-Martinelli parameter defined in Eq. (6)
y	radial distance from the wall ft
z	axial distance from condenser inlet ft
α	void fraction
β	ratio of interface velocity to average liquid velocity
δ	thickness of the condensate film ft
ϵ_h	eddy conductivity
ϵ_m	eddy viscosity
μ	absolute viscosity lbm/ft-hr
ν	kinematic viscosity ft ² /hr
ρ	density lbm/ft ³
τ	shear stress lbf/ft ²

SUBSCRIPTS

e	exit
f	friction
g	gravity
l	liquid
v	vapor
z	local value
0	wall

INTRODUCTION

When saturated vapor flows in a tube that is cooled by an exterior fluid, some of the vapor condenses on the tube wall and forms a liquid film. Condensation inside tubes occurs in many applications, particularly in refrigeration condensers. The main resistance to heat transfer for refrigerants and other low-conductivity fluids is the resistance to conduction through the condensate film.

The analysis of Nusselt [1] outlined the basic approach to this problem. At low flow rates and velocities, a laminar condensate film forms on the tube wall; and for a horizontal tube, the liquid accumulates at the bottom. Experimental data for this situation are in good agreement with the results [2], [3], and [4]. A turbulent condensate film evolves at higher flow rates. This problem has been studied by several investigators (for instance: Akers [5], Chen [6], Soliman [7], and Patel [8]), and the resulting correlations have usually relied on empirical methods. Carpenter and Colburn [9] derived a semi-empirical equation of limited application. Rohsenow et al. [10] obtained the heat transfer coefficient for a liquid film on a vertical flat plate by using the momentum and heat transfer analogy. Later papers [11], [12], and [13] employed the same approach. More recent developments by Bae et al. [14] and Kosky and Staub [15] employed variations of the Lockhart-Martinelli pressure drop model.

In ideal annular flow, the condensate forms a film of uniform thickness on the tube wall and the vapor flows in the interior core. In practice, this pattern may be modified by waves, entrainment, and stratification. However, these effects are hard to predict or

analyze, and annular flow is usually assumed to exist in the parametric range of interest. Since the vapor core is very turbulent, radial temperature gradients are neglected. In addition, the temperatures in the vapor core and at the liquid-vapor interface are assumed to be equal to the saturation temperature. Axial heat conduction and subcooling of the liquid film are also neglected.

In the present paper, the momentum and heat transfer analogy is applied to the annular model using the von Karman universal velocity distribution to describe the liquid film. This seems to be the most accurate method for describing the condensate flow and heat transfer. An order of magnitude analysis and non-dimensionalization of this theory result in a simple formulation for the local heat transfer coefficient. The analysis is compared to experimental data and the results are used to obtain a general design equation for forced-convection condensation.

EXPERIMENT

General Description of Test Facility

The basic apparatus is shown schematically in Fig. 1. It consisted of a closed-loop refrigerant flow circuit driven by a mechanical-sealed rotor pump. An electrically heated boiler generated vapor which passed through a flow meter and into the test section. An aftercondenser downstream from the test section condensed any remaining vapor and ensured liquid refrigerant at the pump inlet. The pump was connected to a by-pass loop, and a valve in the by-pass loop was used to regulate the flow rate and pressure in the test section. The return line from the boiler incorporated a filtering-drying element and a commercial sight glass and moisture indicator. Front and rear views of the experimental apparatus are shown in Fig. 2.

The test section was a tube-in-tube heat exchanger: the refrigerant flowed through the inner tube and the water flowed counter-currently in the annulus or jacket. The inner tube was a commercial 3/8 in. O. D. (0.315 in. I. D.), continuous copper tube 16 1/2 ft. long and extended 2 ft upstream from the test section.

Seven brass rings, each incorporating a pressure tap, were soldered to the inner tube at 29 in intervals. These split the annulus lengthwise into six sections. Heat transfer and pressure drop measurements were made in each of these sections. Adjoining sections of the water jacket were connected in series by flexible hoses to ensure mixing. Two differential thermocouples were located at the inlet and outlet of

each water jacket for measuring the temperature rise of the water through each section. In addition, two differential thermocouples were located at the first water inlet and the last water outlet in order to check the overall water temperature rise against the sum of the six individual water temperature rises. At the mid-point of each section two thermocouples were installed: one on the outside wall of the condenser tube and one at the centerline of the tube. The wall temperature thermocouples were soldered flush to the outer surface of the copper tube; and as such, did not project into the boundary layer of the coolant. To install the centerline thermocouples, holes were bored into the copper tube and open-ended stainless steel tubes, 0.035 in. O.D., were soldered in the holes. The tip of the stainless steel tube was $1/64$ in. short of the copper tube centerline. The thermocouples were then inserted so that the thermocouple beads would be at the centerline of the copper tube, subsequently the thermocouples were glued in place with epoxy. All the thermocouples were made of 0.005 in. O.D. nylon-sheathed copper and constantan wire.

Downward-sloping copper tubes connected the pressure taps to a U-tube mercury manometer through a manifold which enabled the measurement of the refrigerant pressure drop through each section. A Bourdon pressure gage, located upstream of the test section, was used to measure the inlet saturation pressure.

Calibrated flowmeters were used to measure the flowrate of the water through the annulus and aftercondenser. Thermocouples were also installed to measure the temperature of the water at the aftercondenser

inlet and outlet, and of the refrigerant at the inlet of the test section and the outlet of the aftercondenser.

All the loop was insulated with fiberglass. The heat loss from the test section to the atmosphere was not measurable within the accuracy of the potentiometer.

Test Procedure

It was desirable to eliminate all possible contaminants before charging the refrigeration loop. The loop was evacuated to 30 in. Hg and filled with dry nitrogen repeatedly to eliminate moisture. Then the system was evacuated and filled with the refrigerant vapor until a pressure of 70 psig. was reached. The refrigerant was then allowed to escape through bleed valves at the aftercondenser, boiler return line, and manometer until the pressure fell to 5 psig. This was repeated twice in order to dilute any traces of non-condensibles in the system. The system was then charged with liquid refrigerant until the sight glass in the boiler showed that the heating elements were covered.

To obtain the desired conditions in the runs, several parameters could be controlled. The temperature of the water entering the annulus and the aftercondenser was controlled by mixing hot and cold feeds. The water temperature, the water flow rates, the by-pass valve setting, and boiler heat input determined the refrigerant temperature, pressure, and flow rate. Data were taken one hour after the system had reached steady state.

Data Reduction

An overall heat balance was performed for each run by comparing the heat gained by the water with the heat lost by the refrigerant in the test section and the aftercondenser. For all runs, the error was less than 7 percent. The heat flux from the refrigerant was obtained by multiplying the water flow rate by the water temperature rise and specific heat. Using the thermal conductivity of the inner tube, dimensions of the inner tube, and heat flux, the temperature drops across the tube wall were calculated. From this information the inside wall temperatures were determined. The refrigerant qualities at the midpoints of the six sections were determined from a heat balance using the thermodynamic properties of the refrigerant, refrigerant flow rate, and heat gain of the water. The condensation heat transfer coefficient was obtained by dividing the average heat flux for a section by the difference between the vapor temperature and inside wall temperature. The pressure gradient was calculated by dividing the pressure drop across one section by the length of that section.

ANALYSIS

The pressure gradient for two-phase flow in a pipe may be expressed as the sum of three components:

$$\left(\frac{dP}{dz}\right) = \left(\frac{dP}{dz}\right)_f + \left(\frac{dP}{dz}\right)_g + \left(\frac{dP}{dz}\right)_m \quad (1)$$

due respectively to friction, external body forces, and momentum change. The components of the total pressure gradient are related to wall shear stress, external acceleration and velocity gradients as follows^[14]:

$$\left(\frac{dP}{dz}\right)_f = -\tau_0 \frac{S}{A} \quad (2)$$

$$\left(\frac{dP}{dz}\right)_g = \frac{a}{g_0} [\alpha \rho_v + (1 - \alpha) \rho_l] \quad (3)$$

$$\left(\frac{dP}{dz}\right)_m = -\frac{1}{g_0 A} \frac{d}{dz} [U_v W_v - U_l W_l] \quad (4)$$

Assuming that condensation does not affect the frictional pressure drop, the isothermal correlations are applied directly as was done by Martinelli and Nelson^[18] for boiling and by Bae^[14] for condensation. Following the method used by Lockhart and Martinelli^[19], the frictional pressure gradient for two-phase flow is related to the pressure gradient for vapor only by:

$$\left(\frac{dP}{dz}\right)_f = \phi_v^2 \left(\frac{dP}{dz}\right)_v \quad (5)$$

where:

$$\chi_{tt} = \frac{\left(\frac{dP}{dz}\right)_\ell}{\left(\frac{dP}{dz}\right)_v} = \left(\frac{\mu_\ell}{\mu_v}\right)^{0.1} \left(\frac{1-x}{x}\right)^{0.9} \left(\frac{\rho_v}{\rho_\ell}\right)^{0.5} \quad (6)$$

and:

$$\left(\frac{dP}{dz}\right)_v = -\frac{4}{D} \left(\frac{0.045}{Re_v}\right) \frac{G^2 x^2}{2g_0} = -0.09 \frac{\mu_v^{0.2} G^{1.8} x^{1.8}}{g_0 \rho_v D^{1.2}} \quad (7)$$

The data of ref. [19] were given in an approximate curve by Soliman et al. [7] as follows:

$$\phi_v = 1 + 2.85 \chi_{tt}^{0.523} \quad (8)$$

combining Equations (5), (6), (7) and (8):

$$\left(\frac{dP}{dz}\right)_f \frac{g_0^D}{G^2 \frac{\rho_v}{\rho_v}} = -0.09 \left(\frac{\mu_v}{G D}\right)^{0.2} \quad (9)$$

$$[1 + 2.85 \left[\left(\frac{\mu_\ell}{\mu_v}\right)^{0.1} \left(\frac{1-x}{x}\right)^{0.9} \left(\frac{\rho_v}{\rho_\ell}\right)^{0.5}\right]^{0.523}]^2$$

The gravity component is re-written as follows:

$$\left(\frac{dP}{dz}\right)_g \frac{g_0^D}{G^2 \frac{\rho_v}{\rho_v}} = \frac{1}{Fr^2} \left[\frac{\rho_\ell}{\rho_v} - B\alpha\right] \quad (10)$$

where:

$$Fr^2 = \frac{\left(\frac{G}{\rho_v}\right)^2}{aD} \quad (11)$$

is the Froude member based on the total flow and:

$$B = \frac{\rho_l - \rho_v}{\rho_v} \quad (12)$$

is the buoyancy modulus. The local void fraction is calculated using Zivi's equation^[20]:

$$\alpha = \frac{1}{1 + \left(\frac{1-x}{x}\right) \left(\frac{\rho_v}{\rho_l}\right)^{\frac{2}{3}}} \quad (13)$$

Combining Eq. (13) with Eq. (4) and performing the indicated operations yields:

$$\begin{aligned} \left(\frac{dP}{dz}\right)_m \frac{g_0 D}{\frac{G}{\rho_v}} = & -D \left(\frac{dx}{dz}\right) \left[2x + (1-2x) \left(\frac{\rho_v}{\rho_l}\right)^{\frac{1}{3}} \right. \\ & \left. + (1-2x) \left(\frac{\rho_v}{\rho_l}\right)^{\frac{2}{3}} - 2(1-x) \left(\frac{\rho_v}{\rho_l}\right) \right] \end{aligned} \quad (14)$$

For most of the tube length the liquid film is thin. At 20% vapor quality the film thickness is less than 10% of the tube radius.

Therefore a flat plate approximation is used for the liquid film.

The momentum equation for an element of the liquid layer yields:

$$\tau_0 = F_0 \delta + \tau_v \quad (15)$$

where F_0 includes pressure, momentum and gravity forces acting on the film.

$$F_0 = - \left(\frac{dP}{dz} \right) + \frac{a}{g_0} \rho_l - \frac{G^2}{g_0 \rho_v} \frac{dx}{dz} \left[\frac{1}{1 - \alpha} \left(\frac{\rho_v}{\rho_l} \right)^{\frac{1}{3}} - \frac{(1 - x)(2 - \beta)}{(1 - \alpha)^2} \left(\frac{\rho_v}{\rho_l} \right) \right] \quad (16)$$

β is the ratio of the vapor-liquid interphase velocity to the average velocity in the liquid film. This was obtained from the universal velocity profile and is a function of δ^+ as shown in Fig. 3. A more detailed description of the F_0 and β terms can be found in Bae^[12].

Assuming that the von Karman momentum-heat transfer analogy is applicable to the liquid layer, the shear stress and heat flux are written as:

$$\tau = \frac{\rho_l}{g_0} (\nu_l + \epsilon_m) \frac{dv_z}{dy} \quad (17)$$

$$\frac{q}{A} = \rho_l c_l (\alpha_l + \epsilon_h) \frac{dT}{dy} \quad (18)$$

E is the ratio of eddy conductivity ϵ_h to eddy viscosity ϵ_m . Some investigators^[10] have^[11] obtained good results with $E = 1.0$. Others have indicated that the ratio ranges from 1.0 to 1.7. Rearranging Eq. (17) and solving for ϵ_m , one obtains:

$$\epsilon_m = \left[\frac{\tau g_0}{\rho_l} \frac{1}{u_\tau^2} \left(\frac{1}{\frac{dv_z^+}{dy^+}} - 1 \right) \right] \nu_l \quad (19)$$

Where:

$$v_z^+ = \frac{v_z}{u_\tau} \quad (20)$$

$$u_\tau = \sqrt{\frac{g_0 \tau_0}{\rho_l}} \quad (21)$$

$$y^+ = \frac{y u_\tau}{\nu_l} \quad (22)$$

The von Karman universal velocity distribution for the liquid layer is:

$$0 < y^+ < 5 \quad v_z^+ = y^+ \quad (23a)$$

$$5 < y^+ < 30 \quad v_z^+ = -3.05 + 5 \ln y^+ \quad (23b)$$

$$30 < y^+ \quad v_z^+ = 5.5 + 2.5 \ln y^+ \quad (23c)$$

Using Eqs. (19) and (23a, b, c), we obtain three expressions for

ϵ_m :

For the laminar zone $\epsilon_m/\nu_\ell \ll 1$ and $\tau/\tau_0 = 1$; hence,

$$0 < y^+ < 5 \quad \underline{\epsilon_m = 0} \quad (24a)$$

For the buffer zone, the eddy viscosity is of the same order of magnitude as the kinematic viscosity and $\tau/\tau_0 \approx 1$; hence,

$$5 < y^+ < 30 \quad \underline{\epsilon_m = (\nu_\ell) \left(\frac{y^+}{5} - 1\right)} \quad (24b)$$

Assuming a linear shear stress variation in the turbulent zone

with $\tau = F_0(\delta - y) + \tau_v$ and $\epsilon_m/\nu_\ell \gg 1$, then: $z_m \approx \left[\frac{E_0}{\rho_\ell} \frac{1}{u_\tau^2} \left(\frac{d u_\tau^+}{d y^+} \right) \right]^{1/2}$

$$30 < y^+ \quad \underline{\epsilon_m = \frac{\nu_\ell}{2.5} \left[y^+ - \frac{M}{\delta^+} (y^+)^2 \right]} \quad (24c)$$

where:

$$M = \frac{F_0 \delta^+ \nu_\ell}{\tau_0 u_\tau} = 1 - \frac{\tau_v}{\tau_0} \quad (25)$$

Since $(q/A) \approx (q/A)_0$, Eq. (18) may be integrated to yield:

$$\underline{\frac{1}{h_z} = \frac{T_\delta - T_0}{(q/A)} = \int_0^{\delta^+} \frac{\nu_\ell}{\rho_\ell c_\ell (\alpha_\ell + E \epsilon_m) u_\tau} dy^+} \quad (26)$$

Substituting Eq. (24) into Eq. (26) and completing the integration:

$$\text{Nu}_z = \frac{h_z D}{k_\ell} = \frac{\rho_\ell c_\ell D u_\tau}{k_\ell F_2} \quad (27)$$

where F_2 is

$$0 < \delta^+ < 5 \quad F_2 = \delta^+ \text{Pr} \quad (28a)$$

$$5 < \delta^+ < 30 \quad F_2 = 5\text{Pr} + \frac{5}{E} \ln(1 + E\text{Pr}(\frac{\delta^+}{5} - 1)) \quad (28b)$$

$$30 < \delta^+ < \infty \quad F_2 = 5\text{Pr} + \frac{5}{E} \ln(1 + 5E\text{Pr}) \quad (28c)$$

$$+ \frac{2.5}{E \sqrt{1 + \frac{10M}{E\delta^+ \text{Pr}}}} \ln \left[\frac{2M-1 + \sqrt{1 + \frac{10M}{E\delta^+ \text{Pr}}}}{2M-1 - \sqrt{1 + \frac{10M}{E\delta^+ \text{Pr}}}} \right]$$

$$\cdot \left[\frac{\frac{60M}{\delta^+} - 1 - \sqrt{1 + \frac{10M}{E\delta^+ \text{Pr}}}}{\frac{60M}{\delta^+} - 1 + \sqrt{1 + \frac{10M}{E\delta^+ \text{Pr}}}} \right]$$

The equations for F_2 in the first two zones are fairly simple. However the third term in Eq. (28c) involves a laborious calculation.

This term can be simplified, since $\delta^+ > 30$, $Pr_\ell > 3$ for refrigerants R-12 and R-22, and $0 \leq M \leq 1$. Therefore:

$$1 + \frac{10M}{EPr \delta^+} < 1 + \frac{(10)(1)}{(3)(30)} = 1.11$$

Hence using a truncated binominal expansion as an approximation of this factor would introduce an error of less than 0.05%, therefore:

$$\sqrt{\frac{10M}{EPr \delta^+} + 1} \approx 1 + \frac{5M}{EPr \delta^+}$$

And the third term of Eq. (28c) becomes:

$$\frac{2.5}{1 + \frac{5M}{EPr \delta^+}} \ln \left[\frac{2M + \frac{5M}{EPr \delta^+}}{2M - 2 - \frac{5M}{EPr \delta^+}} \cdot \frac{\frac{60M}{\delta^+} - 2 - \frac{5M}{EPr \delta^+}}{\frac{60M}{\delta^+} + \frac{5M}{EPr \delta^+}} \right]$$

Which may be simplified and expressed as

$$\frac{2.5}{1 + \frac{5M}{EPr \delta^+}} \left[\ln \left[\frac{\delta^+ EPr + 2.5}{30 EPr + 2.5} \right] + \ln \left[\frac{\frac{M}{\delta^+} (30 - \frac{2.5}{EPr}) - 1}{\frac{M}{\delta^+} (\delta^+ - \frac{2.5}{EPr}) - 1} \right] \right]$$

But since,

$$1 < 1 + \frac{5M}{EPr \delta^+} < 1 + \frac{(5)(1)}{(1)(3)(30)} = 1.0556$$

this factor may also be approximated as

$$1 + \frac{5M}{EPr \delta^+} \cong 1$$

which introduces an error of less than 6 percent in the third term of Eq. (28c) and a much smaller error in F_2 .

$$\text{Also, } \delta^+ EPr \geq 30 EPr \geq 30(1)(30) = 90$$

Hence 2.5 is neglected in comparison to $EPr\delta^+$ and $30 EPr$. Since 2.5 is added to both the numerator and the denominator, the effect of dropping it disappears for all practical purposes.

With these simplifications the third term becomes:

$$2.5 \ln\left[\frac{\delta^+}{30}\right] + 2.5 \ln\left[\frac{\frac{M}{\delta^+} \left(30 - \frac{2.5}{EPr}\right) - 1}{\frac{M}{\delta^+} \left(\delta^+ - \frac{2.5}{EPr}\right) - 1}\right]$$

and Eq. (29c) can be re-written as:

$$\delta^+ > 30$$

$$F_2 = \underbrace{5Pr}_{\text{term 1}} + \underbrace{\frac{5}{E} \ln(1 + 5EPr)}_{\text{term 2}} + \underbrace{2.5 \ln\left(\frac{\delta^+}{30}\right)}_{\text{term 3}} + \underbrace{2.5 \ln\left[\frac{\frac{M}{\delta^+} \left(30 - \frac{2.5}{EPr}\right) - 1}{\frac{M}{\delta^+} \left(\delta^+ - \frac{2.5}{EPr}\right) - 1}\right]}_{\text{term 4}} \quad (29)$$

The fourth term of this expression represents the correction due to the fact that $\tau_0 \neq \tau_v$. This term is negligible when the

quality gradient $(\frac{dx}{dz})$ is not large. The calculation of the heat transfer coefficient is greatly simplified when this term is negligible, since the calculation of M depends on dx/dz which requires a laborious iteration. The effect of M should be included if, in Eq. (29):

$$\text{term 4} \geq 0.05 (\text{term 1} + \text{term 2} + \text{term 3})$$

or:

$$2.5 \ln \left[\frac{\frac{M}{\delta^+} (30 - \frac{2.5}{EPr}) - 1}{\frac{M}{\delta^+} (\delta^+ - \frac{2.5}{EPr}) - 1} \right] \geq 0.25 \left[Pr + \frac{1}{E} \ln(1 + 5EPr) + \frac{1}{2} \ln\left(\frac{\delta^+}{30}\right) \right]$$

Solving this inequality for M, one obtains:

$$M \geq M_{\text{crit}} =$$

$$\frac{(1 + 5EPr)^{\frac{0.1}{E}} \left(\frac{e^{0.1Pr}}{30^{0.05}} (\delta^+)^{1.05} - \delta^+ \right)}{(1 + 5EPr)^{\frac{0.1}{E}} \frac{e^{0.1Pr}}{30^{0.05}} (\delta^+)^{1.05} - \frac{2.5}{EPr} (1 + 5EPr)^{\frac{0.1}{E}} \frac{e^{0.1Pr}}{30^{0.05}} (\delta^+)^{0.05} (30 - \frac{2.5}{EPr})} \quad (30)$$

Equation (30) gives the value of M for which an error of 5 percent results if term 4 of Eq. (29) is dropped. Since the Prandtl number is fixed for a given fluid and temperature, the value of δ^+ determines M_{crit} . To determine whether the fourth term of Eq. (29) may be neglected,

one should calculate a test value of M from Eq. (25) with $\delta^+ > 30$ and compare this value to M_{crit} as determined from Eq. (30) or Fig. 4. Fig. 4 is a plot of M_{crit} versus δ^+ for several Prandtl numbers, with E taken as unity. When the fourth term may be neglected, Eq. (29c) reduces to the following:

$$\delta^+ > 30$$

$$F_2 = 5Pr + \frac{5}{E} \ln(1 + 5EPr) + 2.5 \ln\left(\frac{\delta^+}{30}\right) \quad (31)$$

which is similar to the one presented by Kosky and Staub^[15]. Otherwise, it is best to use Eq. (29) in its entirety.

From the definition of δ^+ and Re_ℓ :

$$\delta^+ = \frac{\delta u_\tau}{\nu} \quad (32)$$

$$Re_\ell = \frac{G(1-x)D}{\mu_\ell} \quad (33)$$

Using continuity of mass the liquid Reynolds number may be written as:

$$Re_\ell = \frac{4}{\mu_\ell} \int_0^\delta \rho_\ell v_z dy = 4 \int_0^{\delta^+} v_z^+ dy^+ \quad (34)$$

Substituting Eq. (23) for v_z^+ into Eq. (34) yields:

$$\delta^+ < 5 \quad \text{Re}_\ell = 2(\delta^+)^2 \quad (35a)$$

$$5 < \delta^+ < 30 \quad \text{Re}_\ell = 50 - 32.2\delta^+ + 20\delta^+ \ln \delta^+ \quad (35b)$$

$$\delta^+ > 30 \quad \text{Re}_\ell = -256 + 12\delta^+ + 10\delta^+ \ln \delta^+ \quad (35c)$$

Equations (35) may be approximated with an error of less than 4 percent by straight line segments on a log-log graph. Using these piecewise linear curve fits one can obtain δ^+ as an explicit function of Re_ℓ :

$$\text{Re}_\ell < 50, \delta^+ = 0.7071 \text{Re}_\ell^{0.5} \quad (36a)$$

$$50 < \text{Re}_\ell < 1125, \delta^+ = 0.4818 \text{Re}_\ell^{0.585} \quad (36b)$$

$$\text{Re}_\ell > 1125, \delta^+ = 0.095 \text{Re}_\ell^{0.812} \quad (36c)$$

Equation (36) may be substituted in Eq. (31) to yield F_2 as a function of two accessible parameters, Re_ℓ and Pr_ℓ :

$$\text{Re}_\ell < 50 \quad F_2 = 0.707 \text{Pr}_\ell \text{Re}_\ell^{0.5} \quad (37a)$$

$$50 < \text{Re}_\ell < 1125 \quad F_2 = 5 \text{Pr}_\ell + 5 \ln [1 + \text{Pr}_\ell (0.09636 \text{Re}_\ell^{0.585} - 1)] \quad (37b)$$

$$\text{Re}_\ell > 1125 \quad F_2 = 5 \text{Pr}_\ell + 5 \ln(1 + 5 \text{Pr}_\ell) + 2.5 \ln(0.00313 \text{Re}_\ell^{0.812}) \quad (37c)$$

Equations (37a, b, c) are also presented graphically in Fig. 5 for ease of calculation.

Substituting Eqs. (2), (9), and (21) into Eq. (27) and solving for h_z :

$$h_z = \frac{1}{F_2} \rho_l c_l u_T = \frac{1}{F_2} \rho_l c_l \left[\frac{g_0 D}{\rho_l} \frac{.090}{g_0} \frac{\mu_v^{0.2} G^{1.8} x^{1.8}}{\rho_v D^{1.2}} \right. \\ \left. [1 + 2.85 \left[\left(\frac{\mu_v}{\mu_l} \right)^{0.1} \left(\frac{1-x}{x} \right)^{0.9} \left(\frac{\rho_v}{\rho_l} \right)^{0.5} \right]^2 \right]^{\frac{1}{2}} \quad (38)$$

or simplifying:

$$h_z = \frac{1}{F_2} 0.15 \sqrt{\frac{\rho_l}{v}} c_l \mu_v^{0.1} \frac{G^{0.9}}{D^{0.1}} x^{0.9} [1 + 2.85 \left[\left(\frac{\mu_l}{\mu_v} \right)^{0.1} \left(\frac{1-x}{x} \right)^{0.9} \left(\frac{\rho_v}{\rho_l} \right)^{0.5} \right]^{0.523}] \quad (39)$$

Equation (39) may be rearranged in a more compact form by algebraic manipulations and the definition of χ_{tt} , Eq. (6), to yield:

$$\frac{Nu}{[\chi_{tt}^{-1} + 2.85 \chi_{tt}^{-0.476}]} = \frac{0.15}{F_2} Pr_l Re_l^{0.9} \quad (40)$$

or equivalently:

$$\frac{Nu F_2}{Pr_l Re_l^{0.9}} = F(\chi_{tt}) \quad (41)$$

$$\rightarrow \text{where } \left[F(\chi_{tt}) \equiv 0.15 [\chi_{tt}^{-1} + 2.85 \chi_{tt}^{-0.476}] \right] \quad (42)$$

Equation (40) is a good working equation since the right side is a function only of Re_ℓ and Pr_ℓ (assuming the fourth term of Eq. (29) may be neglected as previously explained). The value of Eq. (41) is in correlating condensation data for different fluids or conditions. In this case the heat transfer parameter $(NuF_2/Pr_\ell Re_\ell^{0.9})$ may be plotted as a function of only one variable: x_{tt} .

The average overall heat transfer coefficient may be calculated for the case of a constant temperature difference ($T_{\text{vapor}} - T_{\text{wall}}$). If the temperature difference is not constant along the condenser length, as is usually the case, then an average heat transfer coefficient is of little use in determining the overall heat transfer or condenser length since:

$$q/\Lambda)_{\text{avg}} = (h \Delta T)_{\text{avg}} \neq h_{\text{avg}} \Delta T_{\text{avg}}$$

Consider the heat transfer through the liquid layer:

$$dq = - Wh_{fg} dx = h_z \Delta T \pi D dz \quad (43)$$

Rearranging and integrating for constant ΔT yields:

$$\int_{x_e}^1 \frac{dx}{h_z} = \frac{\Delta T \pi D L_e}{Wh_{fg}} \quad (44)$$

Where x_e and L_e are the exit quality and length. By definition:

$$h_{\text{avg}} = \frac{1}{L_e} \int_0^{L_e} h_z dz$$

and $q = h_{\text{avg}} \Delta T \pi D L_e = W h_{fg} (1 - x_e)$ (45)

Combining Eqs. (36) and (37):

$$\frac{1}{h_{\text{avg}}} = \frac{1}{(1 - x_e)} \int_{x_e}^1 \frac{dx}{h_z} \quad (46)$$

Calculation Procedure for Analytical Results

Analytical heat transfer and pressure drop results were calculated and compared with the experimental results with the same refrigerant mass flux, saturation temperature, temperature difference, and tube diameter. The calculations were accomplished in the following manner:

1. Using the computer, the refrigerant properties were evaluated at the average vapor temperature from a piecewise linear curve fit of tabulated property values [16,17].

2. The quality was divided into 5 per cent increments starting at 1.00 and decreasing to 0.05. The heat transfer coefficient and pressure drop were calculated at each increment.

3. X_{tt} and Re_g were calculated from eqs. (6) and (33). F_2 was evaluated using eq. (37) or Fig. 5. (The inherent assumption in eq. (37) that $M = 0$ will be checked later in step 11.)

4. The Nusselt number (Nu) and heat transfer coefficient (h_z) were calculated from eq. (41).

5. The friction pressure gradient was determined from eq. (9).

6. Since the condenser tube was horizontal, the gravity pressure gradient was not calculated. For inclined tubes, the gravity pressure gradient may be determined from eqs. (10) and (13).

7. The quality gradient ($\frac{dx}{dz}$) was calculated from eq. (43):

$$\frac{dx}{dz} = - \frac{h_z \Delta T \pi D}{W h_{fg}}, \text{ using the values of } h_z \text{ from step 4.}$$

8. The momentum pressure gradient was evaluated using eq. (14).
9. The total pressure gradient was determined from eq. (1).
10. δ^+ was calculated from eq. (36).
11. For $\delta^+ > 30$, τ_o and u_τ were determined from eqs. (2) and (21). In addition F_o was calculated from eq. (16) with β obtained from Fig. 3. M was then calculated using eq. (25).
12. M as calculated in step 10 was compared to M_{crit} as obtained from eq. (30) or Fig. 4. If $M > M_{crit}$ then F_2 was recalculated using eq. (29) and (36) instead of eq. (37). The heat transfer coefficient was recalculated using the new value of F_2 in eq. (41).
13. The increment of tube length (Δz) required for a 5 per cent quality change was determined from eq. (43):

$$\Delta z = \frac{W h_{fg} (0.05)}{h_z \Delta T \pi D} .$$

As discussed in the following chapter, the iterative steps 10 through 13 are not required if the quality gradient is small. In particular, these steps were not needed for analytical calculations based on the experimental data. This means that only steps 1 through 4 are needed to calculate the heat transfer coefficient for low to moderate condensation rates.

RESULTS

Sixteen experimental runs were made with refrigerant R-12 and eleven runs were made with refrigerant R-22 for saturation temperatures between 77 to 137°F and mass fluxes between 1.19×10^5 lbm/hr ft² and 1.13×10^6 lbm/hr ft². The absolute value of the maximum heat balance error for all runs was 7 percent. The data are presented in Appendix 1. Figures 9 through 23 show the experimental and analytical heat transfer coefficients while Figures 24 through 35 show the pressure gradient data. Some experimental pressure gradient data (runs 3, 4, 6, and 19) were omitted, because the sum of the individually measured pressure drops differed appreciably (>15 percent) from the total pressure drop. Refrigerant R-12 was used for runs 1 through 16, and refrigerant R-22 was used for runs 17 through 27. Analytical values of the local heat transfer coefficients and pressure gradients were obtained using the procedure outline in the proceeding section. One version of a computer program used for these calculations is presented in Appendix 2.

It is important to know how often term 4 of Eq. (29) which includes the effect of M was used. The ability to neglect this term with minimal inaccuracy greatly simplifies the calculations. The effect of M was important only 8 of the 27 runs, and then only for qualities less than 0.10 where the annular model is not applicable anyway. Previous data obtained by Bae [12] for a 1/2 in. I. D. tube were also checked: the term involving M was even less important for Bae's data. Hence, one can neglect term 4 of Eq. (29) for conditions similar to the experimental runs of Bae and the present authors. For higher condensation rates (higher heat fluxes and quality gradients) this term becomes important and has the ultimate effect of lowering heat transfer coefficient. In these cases,

Eq. (29) should be used in its entirety..

In the derivation of the heat transfer coefficient, no restrictions were placed on the position of the condenser tube. Although in the present work data were determined from measurements with a horizontal tube, this analysis has an applicability to inclined tubes. The value of E (ratio of eddy conductivity to eddy viscosity) was taken to be 1.0 for the curves of Figures 9 through 23. Calculations with E values of 1.1 and 1.4 were also compared to experimental data, but no definite trends were observed.

Since the analysis was developed for annular flow, departures from this flow regime are presently examined. When the mass flux of the refrigerant vapor exceeded $500,000 \text{ lbm/hr ft}^2$ there was appreciable entrainment of liquid in the first portion of the condenser tube. Physically this occurred because the vapor had a sufficiently high velocity to pick liquid up off the wall and transport it as droplets in the vapor core. At these high mass fluxes, the thickness of the liquid layer decreased due to entrainment, and consequently, the heat transfer coefficient increased. Since the present analysis assumes that annular film condensation exists and that all of the liquid is on the tube wall, the analytical predictions were below the experimental data in this misty flow regime. This effect is shown by Figures 15, 16, 17, 22 and 23. Entrainment usually occurs only in the inlet region of the condenser tube, because the vapor velocity progressively decreases as additional condensation occurs. The existence of entrainment was also substantiated by plotting the experimental runs on a Baker flow regime map [21] as shown in Figure 6, and also by high speed photographs through the glass sight tube.

With the exception of high qualities and mass fluxes, the liquid annulus was usually thicker at the bottom of the tube than at the top. However, the analytical predictions compared well with the experimental data, because a compensating effect existed between the increased heat transfer in the upper portion and decreased heat transfer in the lower portion. At qualities of less than 0.10, the flow was observed to be in the slug flow regime. Experimental data obtained at low qualities (runs 1, 6, 8, 10, and 24 on Figures 9, 11, 12, 13, and 22) show good agreement with the analytical predictions in the neighborhood of 0.10 quality. At qualities appreciably below 0.10, a linear extrapolation between the present heat transfer equation (Eqs. 39, 40, or 41) at $x = 0.10$ and a single phase heat transfer equation gives a good estimate of the heat transfer coefficient.

On the basis of Eq. (41), all of the experimental data for refrigerants R-12 and R-22 were reduced using the non-dimensional parameters $Nu F_2 / Pr_\ell Re_\ell^{0.9}$ and $F(\chi_{tt}) \equiv 0.15 [\chi_{tt}^{-1} + 2.85 \chi_{tt}^{-0.476}]$. These data (approximately 160 data points) are presented in Fig. 7 along with the predicted values from the annular flow model (the straight line). Previous data from Bae [12] for R-22 are shown on a similar plot in Fig. 8. As observed from Figures 7 and 8, these non-dimensional parameters correlate a wide range of data very well. The experimental data and analysis are in excellent agreement for $F(\chi_{tt}) < 2$ (or $\chi_{tt} < 0.155$). For $F(\chi_{tt}) > 2$ the data are somewhat higher than the analysis predicts. Consequently, these data are represented better by the dotted line of Fig. 7, which may be expressed as:

$$\frac{Nu F_2}{Pr_\ell Re_\ell} = [F(\chi_{tt})]^{1.15} \quad (47)$$

One of the reasons for the higher value of $\frac{\text{Nu } F_2}{\text{Pr}_\ell \text{Re}_\ell^{0.9}}$ when $\chi_{tt} > 2$ is the entrainment effect previously discussed. Even for $F(\chi_{tt}) > 2$ the non-dimensional parameters correlate the data well. This indicates that the two curves drawn through the data points of Fig. 7 should be a good design criterion for a wide range of conditions and flow regimes.

CONCLUSIONS

1. For the practical range of refrigerant condenser operating conditions the simplified analysis developed here is applicable.

2. Recommended design equations for the local heat transfer coefficient in refrigerant condensers are as follows:

$$0.1 < F(\chi_{tt}) < 1 \quad \frac{\text{Nu } F_2}{\text{Pr}_l \text{Re}_l} = F(\chi_{tt}), \quad \pm 15\%$$

$$1 < F(\chi_{tt}) < 15 \quad \frac{\text{Nu } F_2}{\text{Pr}_l \text{Re}_l} = [F(\chi_{tt})]^{1.15}, \quad \pm 15\%$$

where F_2 , χ_{tt} and $F(\chi_{tt})$ are given by Eqs. (37), (6) and (42).

3. Pressure drop may be calculated by Eq. (1) with Eqs. (9), (10) and (14).

REFERENCES

1. Nusselt, M. "Die Oberflachen Kondensation Des Wasserdampfes,"
Zeitschrift des Vereines Deutscher Ingenieure, Vol. 60, No. 541 (1916).
2. Chaddock, J. B., "Film Condensation of Vapor in Horizontal Tubes,"
Sc. D. Thesis, M. I. T. (1955), also Refrigerating Engineering,
Vol. 65, No. 4, p. 36 (1957).
3. Chato, S. C., "Laminar Condensation Inside Horizontal and Inclined
Tubes," ASHRAE Journal, Vol. 4, No. 2 (1962).
4. Rufer, C. and S. P. Kezios, Analysis of Two-Phase One Component
Stratified Flow with Condensation," Journal of Heat Transfer,
Trans. ASME, Series C, Vol. 88 (1966).
5. Akers, W. W. and H. F. Rosson, "Condensation Inside a Horizontal
Tube," Chemical Engineering Progress, Symposium Series, Heat
Transfer, Storrs, Vol. 56, No. 30 (1960).
6. Chen, C. J., "Condensing Heat Transfer in a Horizontal Tube," M. S.
Thesis, Department of Mechanical Engineering, Kansas State
University (1962).
7. Soliman, M., J. R. Schuster and P. J. Berenson, "A General Heat
Transfer Correlation for Annular Flow Condensation," Trans. ASME,
Journal of Heat Transfer, Series C, Vol. 90, No. 2 (1968).
8. Patel, S. P., "Film Coefficient of Heat Transfer of Freon-12 Conden-
sing inside a Single Horizontal Tube," M. S. Thesis, Kansas State
University (1956).
9. Carpenter, E. F. and A. P. Colburn, "The Effect of Vapor Velocity
on Condensation inside Tubes," Proceedings of the General Discussion
of Heat Transfer, I. Mech. E. and ASME (1951).
10. Rohsenow, W. M., J. H. Webber and A. T. Ling, "Effect of Vapor
Velocity on Laminar and Turbulent-Film Condensation," Trans. ASME,
p. 1637 (1956).
11. Altman, M., F. W. Staub and R. H. Norris, "Local Heat Transfer and
Pressure Drop for Refrigerant-22 Condensing in Horizontal Tubes,"
ASME-AIChE, Heat Transfer Conference, Storrs, Conn. (1959).
12. Bae, S., J. S. Maulbetsch and W. M. Rohsenow, "Refrigerant Forced-
Convection Condensation inside Horizontal Tubes," Rep. No. 79760-64,
Heat Transfer Lab., Mass. Inst. of Tech., Cambridge, Mass., Nov. 1,
1969.
13. Kunz, H. R. and S. Yerazunis, "An Analysis of Film Condensation,
Film Evaporation, and Single-Phase Heat Transfer for Liquid Prandtl
Numbers from 10^{-3} to 10^4 ," Heat Transfer Conference, Seattle, Wash.,
Paper No. 67-HT-1 (1967).

14. Bae, S., J. S. Maulbetsch and W. M. Rohsenow, "Refrigerant Forced-Convection Condensation inside Horizontal Tubes," Rep. No. DSR 72591-71, Heat Transfer Lab., Mass. Inst. of Tech., Cambridge, Mass., Nov. 1, 1970.
15. Koskyk P. G. and F. W. Staub, "Local Condensing Heat Transfer Coefficients in the Annular Flow Regime," presented at AIChE 63rd Annual Meeting, Nov. 1970.
16. "Thermodynamic Properties of Freon-12," DuPont (1956).
17. "Thermodynamic Properties of Freon-22," DuPont (1964).
18. Martinelli, R. C. and D. B. Nelson, "Prediction of Pressure Drop During Forced Circulation Boiling of Water," Trans. ASME, Vol. 70, pp. 652-702 (1948).
19. Lockhart, R. W. and R. C. Martinelli, "Proposed Correlation of Data for Isothermal Two-Phase, Two-Component Flow in Pipes," Chemical Engineering Progress, Vol. 45, No. 1, p. 39 (1949).
20. Zivi, S. M., "Estimation of Steady-State Steam Void-Fraction by Means of the Principle of Minimum Entropy Production," Journal of Heat Transfer, Trans. ASME, Series C, Vol. 86, p. 247 (1964).
21. Baker, O., "Simultaneous Flow of Oil and Gas," The Oil and Gas Journal, Vol. 53, pp. 185-195 (1954).






FIGURE 1 SCHEMATIC DIAGRAM OF APPARTUS



FRONT VIEW



REAR VIEW

FIGURE 2 EXPERIMENTAL APPARATUS




FIGURE 3 GRAPH OF β VERSUS δ^+




FIGURE 4 M_{crit} VERSUS δ^+ AT CONSTANT PRANDTL NUMBER




FIGURE 5 GRAPH OF F_2 VERSUS Re_ℓ AT CONSTANT Pr_ℓ




FIGURE 6 BAKER FLOW REGIME MAP OF R-12 RUNS




FIGURE 7 COMPARISON OF ANALYSIS AND PRESENT CONDENSATION DATA




FIGURE 8 COMPARISON OF ANALYSIS AND BAE'S CONDENSATION DATA





FIGURE 9

QUALITY (%)





FIGURE 10

QUALITY (%)





FIGURE 11





FIGURE 12






FIGURE 13







FIGURE 15

QUALITY (%)






FIGURE 16







FIGURE 18

QUALITY (%)





FIGURE 19

QUALITY (%)






FIGURE 20

QUALITY (%)







FIGURE 22





FIGURE 23

QUALITY (%)





FIGURE 24





FIGURE 25





FIGURE 26





FIGURE 27





FIGURE 28





FIGURE 29





FIGURE 30





FIGURE 31





FIGURE 32





FIGURE 33





FIGURE 34





FIGURE 35

APPENDIX 1
TABLES OF DATA

RUN NO. 1

REFRIGERANT 12

FREON MASS FLUX	3.2063487E 05	WTR TEMP IN	37.50	FREON TEMP IN	80.17
WTR FLOW RATE	621.65	MEAN HT COEF	842.4	HEAT BAL ERROR	0.052

VAPOR TEMP (F)	OUT WALL T (F)	DEL WTR T (F)	P GRAD (LBF/FT3)
79.820	71.170	3.300	55.403
80.040	72.430	2.790	52.487
78.260	68.320	3.130	43.740
79.050	67.140	2.710	32.076
77.180	62.460	2.620	15.746
75.400	57.460	2.370	7.581

IN WALL T (F)	DEL WALL T (F)	HEAT FLUX (BTU/HR-FT2)	H T COEF (BTU/HR-FT2-F)
71.277	8.542	10319.3	1208.0
72.520	7.519	8724.5	1160.3
68.421	9.838	9787.7	994.8
67.228	11.821	8474.3	716.8
62.545	14.634	8192.9	559.8
57.537	17.862	7411.1	414.8

QUALITY	XTT	F(XTT)	NU*F2/PR*(RE**.9)
0.900	3.187E-02	6.911E 00	1.082E 01
0.716	1.009E-01	2.758E 00	4.306E 00
0.542	1.963E-01	1.691E 00	2.470E 00
0.364	3.802E-01	1.071E 00	1.348E 00
0.210	7.435E-01	6.939E-01	8.782E-01
0.068	2.341E 00	3.492E-01	5.665E-01

RUN NO. 2

REFRIGERANT 12

FREON MASS FLUX 4.4146437E 05 WTR TEMP IN 69.74 FREON TEMP IN 101.00
WTR FLOW RATE 966.32 MEAN HT COEF 1067.6 HEAT BAL ERROR 0.007

VAPOR TEMP (F)	OUT WALL T (F)	DEL WTR T (F)	P GRAD (LBF/FT3)
98.740	91.390	2.230	79.315
98.830	91.910	2.040	73.483
97.430	88.390	2.110	62.110
98.170	87.350	2.000	50.446
96.920	84.390	1.910	34.700
95.960	82.520	1.790	21.870

IN WALL T (F)	DEL WALL T (F)	HEAT FLUX (BTU/HR-FT2)	H T COEF (BTU/HR-FT2-F)
91.502	7.237	10839.7	1497.8
92.013	6.816	9916.1	1454.6
88.496	8.933	10256.4	1148.1
87.451	10.718	9721.7	906.9
84.486	12.433	9284.2	746.7
82.610	13.349	8700.9	651.7

QUALITY	XTT	F(XTT)	NU*F2/PR*(RE**.9)
0.922	2.909E-02	7.458E 00	1.247E 01
0.768	9.205E-02	2.959E 00	4.822E 00
0.622	1.711E-01	1.867E 00	2.522E 00
0.472	2.976E-01	1.264E 00	1.502E 00
0.336	4.929E-01	9.029E-01	1.019E 00
0.207	8.872E-01	6.216E-01	7.661E-01

RUN NO. 3

REFRIGERANT 12

FREON MASS FLUX 4.3239100E 05 WTR TEMP IN 86.57 FREON TEMP IN 120.00
WTR FLOW RATE 827.98 MEAN HT COEF 857.2 HEAT BAL ERROR 0.045

VAPOR TEMP (F)	OUT WALL T (F)	DEL WTR T (F)	P GRAD (LBF/FT3)
117.250	109.040	2.360	50.738
117.580	109.460	2.250	42.281
116.480	106.090	2.330	30.909
117.670	104.960	2.260	22.744
116.570	101.740	2.080	14.580
115.500	99.040	1.910	8.747

IN WALL T (F)	DEL WALL T (F)	HEAT FLUX (BTU/HR-FT2)	H T COEF (BTU/HR-FT2-F)
109.142	8.107	9829.2	1212.3
109.557	8.022	9371.1	1168.1
106.191	10.288	9704.3	943.1
105.058	12.611	9412.7	746.3
101.830	14.739	8663.0	587.7
99.122	16.377	7955.0	485.7

QUALITY	XTT	F(XTT)	NU*F2/PR*(RE**.9)
0.925	3.237E-02	6.821E 00	1.039E 01
0.770	1.049E-01	2.679E 00	3.906E 00
0.620	1.988E-01	1.676E 00	2.065E 00
0.463	3.561E-01	1.120E 00	1.219E 00
0.322	6.038E-01	7.919E-01	7.892E-01
0.193	1.106E 00	5.429E-01	5.635E-01

RUN NO. 4

REFRIGERANT 12

FREON MASS FLUX 4.2630031E 05 WTR TEMP IN 108.78 FREON TEMP IN 135.88
WTR FLOW RATE 923.24 MEAN HT COEF 768.0 HEAT BAL ERROR -0.000

VAPOR TEMP (F)	OUT WALL T (F)	DEL WTR T (F)	P GRAD (LBF/FT3)
133.130	125.170	1.860	42.573
133.670	125.210	1.840	38.782
133.000	122.500	1.790	29.743
134.080	121.540	1.720	24.785
133.170	119.540	1.660	18.370
132.670	117.830	1.530	13.413
IN WALL T (F)	DEL WALL T (F)	HEAT FLUX (BTU/HR-FT2)	H T COEF (BTU/HR-FT2-F)
125.260	7.869	8638.1	1097.6
125.299	8.370	8545.2	1020.8
122.586	10.413	8313.0	798.3
121.623	12.456	7987.9	641.2
119.620	13.549	7709.3	568.9
117.904	14.765	7105.5	481.2
QUALITY	XTT	F(XTT)	NU*F2/PR*(RE**.9)
0.930	3.401E-02	6.546E 00	9.957E 00
0.781	1.113E-01	2.561E 00	3.554E 00
0.638	2.092E-01	1.617E 00	1.819E 00
0.495	3.575E-01	1.116E 00	1.101E 00
0.363	5.780E-01	8.143E-01	8.043E-01
0.239	9.885E-01	5.815E-01	5.848E-01

RUN NO. 5

REFRIGERANT 12

FREON MASS FLUX	3.8527143E 05	WTR TEMP IN	67.59	FREON TEMP IN	101.65
WTR FLOW RATE	1047.96	MEAN HT COEF	681.9	HEAT BAL ERROR	-0.035

VAPOR TEMP (F)	OUT WALL T (F)	DEL WTR T (F)	P GRAD (LBF/FT3)
100.570	90.520	2.230	46.655
101.390	88.570	2.000	41.990
100.570	86.520	1.910	27.993
99.570	83.590	1.710	20.995
98.130	79.860	1.500	12.830
95.650	76.960	1.250	8.747

IN WALL T (F)	DEL WALL T (F)	HEAT FLUX (BTU/HR-FT2)	H T COEF (BTU/HR-FT2-F)
90.642	9.927	11755.4	1184.1
88.679	12.710	10543.0	829.4
86.624	13.945	10068.6	722.0
83.683	15.886	9014.2	567.4
79.942	18.187	7907.2	434.7
77.028	18.621	6589.4	353.8

QUALITY	XTT	F(XTT)	NU*F2/PR*(RE**.9)
0.901	3.761E-02	6.025E 00	8.972E 00
0.708	1.240E-01	2.363E 00	2.534E 00
0.534	2.425E-01	1.457E 00	1.487E 00
0.374	4.321E-01	9.843E-01	9.117E-01
0.236	7.767E-01	6.752E-01	5.904E-01
0.123	1.550E 00	4.436E-01	4.285E-01

RUN NO. 6

RFFRIGERANT 12

FREON MASS FLUX 4.1723918E 05 WTR TEMP IN 90.65 FREON TEMP IN 127.92
WTR FLOW RATE 1097.07 MEAN HT COEF 599.0 HEAT BAL ERROR -0.039

VAPOR TEMP (F)	OUT WALL T (F)	DEL WTR T (F)	P GRAD (LBF/FT3)
125.500	113.210	2.391	36.450
126.870	111.380	2.122	25.952
125.920	108.220	2.035	17.495
126.000	104.910	1.730	12.538
123.000	100.960	1.465	8.164
118.220	97.870	1.048	5.540

IN WALL T (F)	DEL WALL T (F)	HEAT FLUX (BTU/HR-FT2)	H T COEF (BTU/HR-FT2-F)
113.347	12.152	13194.8	1085.7
111.502	15.367	11710.3	761.9
108.337	17.583	11230.2	638.6
105.009	20.990	9547.0	454.8
101.044	21.955	8084.6	368.2
97.930	20.289	5783.4	285.0

QUALITY	XTT	F(XTT)	NU*F2/PR*(RE**.9)
0.890	5.006E-02	4.773E 00	6.948E 00
0.674	1.735E-01	1.847E 00	1.942E 00
0.481	3.559E-01	1.120E 00	1.098E 00
0.303	7.035E-01	7.185E-01	6.099E-01
0.165	1.398E 00	4.717E-01	4.248E-01
0.069	3.240E 00	2.905E-01	3.012E-01

RUN NO. 7

REFRIGERANT 12

FREON MASS FLUX 5.2174331E 05 WTR TEMP IN 78.61 FREON TEMP IN 112.17
WTR FLOW RATE 716.50 MEAN HT COEF 1088.5 HEAT BAL ERROR 0.027

VAPOR TEMP (F)	OUT WALL T (F)	DEL WTR T (F)	P GRAD (LBF/FT3)
112.000	106.130	2.601	73.191
112.170	104.780	2.539	40.823
111.430	103.260	2.583	63.568
111.170	100.780	2.728	56.570
109.750	98.130	2.614	43.156
108.570	96.000	2.513	34.408

IN WALL T (F)	DEL WALL T (F)	HEAT FLUX (BTU/HR-FT2)	H T COEF (BTU/HR-FT2-F)
106.227	5.772	9374.5	1624.0
104.875	7.294	9151.0	1254.4
103.357	8.072	9309.6	1153.1
100.882	10.287	9832.2	955.7
98.228	11.521	9421.3	817.6
96.094	12.475	9057.3	726.0

QUALITY	XTT	F(XTT)	NU*F2/PR*(RE**.9)
0.938	2.543E-02	8.350E 00	1.417E 01
0.817	7.732E-02	3.385E 00	4.364E 00
0.698	1.390E-01	2.172E 00	2.629E 00
0.574	2.256E-01	1.533E 00	1.629E 00
0.453	3.453E-01	1.143E 00	1.129E 00
0.337	5.295E-01	8.618E-01	8.534E-01

RUN NO. 8

REFRIGERANT 12

FREON MASS FLUX	1.9431068E 05	WTR TEMP IN	66.41	FREON TEMP IN	94.17
WTR FLOW RATE	625.82	MEAN HT COEF	461.6	HEAT BAL ERROR	0.011

VAPOR TEMP (F)	OUT WALL T (F)	DEL WTR T (F)	P GRAD (LBF/FT3)
93.700	85.260	1.590	16.329
93.650	84.260	1.650	14.580
92.910	82.910	1.780	11.663
93.170	80.700	1.700	6.415
92.300	78.000	1.630	4.665
91.000	75.700	1.270	1.749

IN WALL T (F)	DEL WALL T (F)	HEAT FLUX (BTU/HR-FT2)	H T COEF (BTU/HR-FT2-F)
85.312	8.387	5005.3	596.7
84.314	9.335	5194.2	556.3
82.968	9.941	5603.4	563.6
80.755	12.414	5351.6	431.0
78.053	14.246	5131.2	360.1
75.741	15.258	3997.9	262.0

QUALITY	XTT	F(XTT)	NU*F2/PR*(RE**.9)
0.917	2.984E-02	7.300E 00	9.391E 00
0.748	9.782E-02	2.826E 00	3.441E 00
0.571	2.004E-01	1.667E 00	2.228E 00
0.389	3.901E-01	1.053E 00	1.264E 00
0.218	8.119E-01	6.567E-01	8.595E-01
0.073	2.505E 00	3.359E-01	5.419E-01

RUN NO. 9

REFRIGERANT 12

FREON MASS FLUX 2.7648256E 05 WTR TEMP IN 75.35 FREON TEMP IN 108.91
WTR FLOW RATE 706.71 MEAN HT COEF 503.0 HEAT BAL ERROR -0.037

VAPOR TEMP (F)	OUT WALL T (F)	DEL WTR T (F)	P GRAD (LBF/FT3)
108.830	99.000	1.830	27.993
108.650	97.350	1.860	23.327
107.710	96.040	2.050	16.912
107.880	92.170	2.000	9.914
106.740	88.650	2.080	5.831
104.780	85.740	1.440	2.332

IN WALL T (F)	DEL WALL T (F)	HEAT FLUX (BTU/HR-FT2)	H T COEF (BTU/HR-FT2-F)
99.067	9.762	6505.5	666.3
97.418	11.231	6612.1	588.7
96.115	11.594	7287.6	628.5
92.244	15.635	7109.8	454.7
88.727	18.012	7394.2	410.4
85.793	18.986	5119.0	269.6

QUALITY	XTT	F(XTT)	NU*F2/PR*(RE**.9)
0.920	3.196E-02	6.893E 00	7.967E 00
0.760	1.023E-01	2.731E 00	2.791E 00
0.593	2.048E-01	1.641E 00	1.909E 00
0.418	3.886E-01	1.056E 00	1.020E 00
0.245	7.857E-01	6.703E-01	7.406E-01
0.102	1.998E 00	3.825E-01	4.205E-01

RUN NO. 10

REFRIGERANT 12

FREON MASS FLUX	1.1875593E 05	WTR TEMP IN	48.96	FREON TEMP IN	74.86
WTR FLOW RATE	412.63	MEAN HT COEF	418.9	HEAT BAL ERROR	-0.001

VAPOR TEMP (F)	OUT WALL T (F)	DEL WTR T (F)	P GRAD (LBF/FT3)
72.770	66.640	1.720	0.000
72.410	66.140	1.460	0.000
71.740	65.130	1.590	0.000
72.000	63.680	1.540	0.000
71.700	61.740	1.640	0.000
70.500	58.500	1.220	0.000

IN WALL T (F)	DEL WALL T (F)	HEAT FLUX (BTU/HR-FT2)	H T COEF (BTU/HR-FT2-F)
66.677	6.092	3570.1	585.9
66.171	6.238	3030.4	485.7
65.164	6.575	3300.2	501.8
63.713	8.286	3196.4	385.7
61.775	9.924	3404.0	342.9
58.526	11.973	2532.2	211.4

QUALITY	XTT	F(XTT)	NU*F2/PR*(RE**.9)
0.911	2.654E-02	8.055E 00	1.330E 01
0.743	8.270E-02	3.213E 00	4.540E 00
0.583	1.579E-01	1.978E 00	3.126E 00
0.417	2.897E-01	1.288E 00	1.812E 00
0.250	5.744E-01	8.176E-01	1.303E 00
0.103	1.472E 00	4.574E-01	6.922E-01

RUN NO. 11

REFRIGERANT 12

FREON MASS FLUX	2.8129662E 05	WTR TEMP IN	75.52	FREON TEMP IN	107.42
WTR FLOW RATE	696.57	MEAN HT COEF	475.3	HEAT BAL ERROR	0.003

VAPOR TEMP (F)	OUT WALL T (F)	DEL WTR T (F)	P GRAD (LBF/FT3)
107.380	97.430	2.160	29.160
107.210	95.960	2.140	24.494
107.120	95.000	0.000	23.327
106.830	93.050	2.220	17.495
106.000	89.960	2.060	12.247
105.000	87.960	1.910	5.831

IN WALL T (F)	DEL WALL T (F)	HEAT FLUX (BTU/HR-FT2)	H T COEF (BTU/HR-FT2-F)
97.508	9.871	7568.4	766.7
96.038	11.171	7498.3	671.1
95.000	12.119	0.0	0.0
93.131	13.698	7778.7	567.8
90.035	15.964	7218.0	452.1
88.029	16.970	6692.4	394.3

QUALITY	XTT	F(XTT)	NU*F2/PR*(RE**.9)
0.909	3.600E-02	6.246E 00	8.111E 00
0.730	1.173E-01	2.463E 00	2.835E 00
0.640	1.706E-01	1.870E 00	0.000E 00
0.548	2.404E-01	1.466E 00	1.556E 00
0.372	4.556E-01	9.506E-01	9.396E-01
0.210	9.282E-01	6.045E-01	6.759E-01

82

RUN NO. 12

REFRIGERANT 12

FREON MASS FLUX	6.6783725E 05	WTR TEMP IN	36.96	FREON TEMP IN	81.00
WTR FLOW RATE	1172.11	MEAN HT COEF	1804.1	HEAT BAL ERROR	0.025

VAPOR TEMP (F)	OUT WALL T (F)	DEL WTR T (F)	P GRAD (LBF/FT3)
80.520	72.860	3.080	228.031
78.570	72.820	2.650	222.199
76.870	67.090	2.780	191.872
75.480	65.130	2.510	150.174
73.350	61.870	2.410	120.139
71.260	59.590	2.320	73.774

IN WALL T (F)	DEL WALL T (F)	HEAT FLUX (BTU/HR-FT2)	H T COEF (BTU/HR-FT2-F)
73.049	7.470	18159.6	2430.7
72.982	5.587	15624.4	2796.4
67.260	9.609	16390.8	1705.7
65.284	10.195	14798.9	1451.4
62.018	11.331	14209.3	1253.9
59.732	11.527	13678.7	1186.6

QUALITY	XTT	F(XTT)	NU*F2/PR*(RE**.9)
0.916	2.712E-02	7.910E 00	1.356E 01
0.763	8.001E-02	3.297E 00	6.519E 00
0.619	1.455E-01	2.100E 00	2.667E 00
0.480	2.392E-01	1.471E 00	1.745E 00
0.353	3.743E-01	1.083E 00	1.256E 00
0.234	6.186E-01	7.797E-01	1.031E 00

RUN NO. 13

REFRIGERANT 12

FREON MASS FLUX	7.6344000E 05	WTR TEMP IN	47.41	FREON TEMP IN	94.48
WTR FLOW RATE	890.98	MEAN HT COEF	1989.7	HEAT BAL ERROR	0.039

VAPOR TEMP (F)	OUT WALL T (F)	DEL WTR T (F)	P GRAD (LBF/FT3)
91.700	85.780	3.410	226.864
90.220	85.430	3.080	213.742
87.960	80.610	3.250	174.376
87.700	78.870	3.020	161.254
85.700	75.570	3.160	128.887
83.860	73.350	3.040	89.521

IN WALL T (F)	DEL WALL T (F)	HEAT FLUX (BTU/HR-FT2)	H T COEF (BTU/HR-FT2-F)
85.939	5.760	15283.2	2652.9
85.573	4.646	13804.1	2971.0
80.761	7.198	14566.1	2023.5
79.011	8.688	13535.2	1557.7
75.717	9.982	14162.7	1418.7
73.491	10.368	13624.9	1314.1

QUALITY	XTT	F(XTT)	NU*F2/PR*(RE**.9)
0.939	2.175E-02	9.537E 00	1.724E 01
0.820	6.481E-02	3.886E 00	7.733E 00
0.706	1.130E-01	2.533E 00	3.490E 00
0.590	1.789E-01	1.808E 00	2.028E 00
0.481	2.616E-01	1.382E 00	1.514E 00
0.372	3.848E-01	1.063E 00	1.196E 00

84

RUN NO. 14

REFRIGERANT 12

FREON MASS FLUX	9.0910312E 05	WTR TEMP IN	72.05	FREON TEMP IN	112.48
WTR FLOW RATE	996.25	MEAN HT COEF	1969.4	HEAT BAL ERROR	0.046

VAPOR TEMP (F)	OUT WALL T (F)	DEL WTR T (F)	P GRAD (LBF/FT3)
109.710	103.390	3.160	203.536
108.830	103.610	2.870	212.867
106.870	98.570	3.070	172.044
106.830	97.390	2.970	166.503
105.170	94.570	3.140	134.719
103.430	92.040	3.150	96.227

IN WALL T (F)	DEL WALL T (F)	HEAT FLUX (BTU/HR-FT2)	H T COEF (BTU/HR-FT2-F)
103.555	6.154	15835.9	2572.8
103.759	5.070	14382.6	2836.7
98.730	8.139	15384.9	1890.1
97.545	9.284	14883.8	1603.0
94.733	10.436	15735.7	1507.8
92.204	11.225	15785.8	1406.2

QUALITY	XTT	F(XTT)	NU*F2/PR*(RE**0.9)
0.944	2.258E-02	9.237E 00	1.539E 01
0.834	6.765E-02	3.757E 00	6.716E 00
0.728	1.171E-01	2.466E 00	2.952E 00
0.616	1.854E-01	1.762E 00	1.872E 00
0.508	2.714E-01	1.347E 00	1.429E 00
0.398	3.985E-01	1.038E 00	1.125E 00

RUN NO. 15

REFRIGERANT 12

FREON MASS FLUX	9.1649862E 05	WTR TEMP IN	108.96	FREON TEMP IN	140.38
WTR FLOW RATE	1810.95	MEAN HT COEF	1369.0	HEAT BAL ERROR	-0.028

VAPOR TEMP (F)	OUT WALL T (F)	DEL WTR T (F)	P GRAD (LBF/FT3)
138.250	129.960	1.950	160.380
138.040	128.000	1.860	123.055
136.710	123.580	1.790	92.728
137.500	123.380	1.700	80.190
136.250	121.420	1.650	56.861
135.080	119.460	1.550	31.784

IN WALL T (F)	DEL WALL T (F)	HEAT FLUX (BTU/HR-FT2)	H T COEF (BTU/HR-FT2-F)
130.145	8.104	17763.5	2191.6
128.176	9.863	16943.7	1717.8
123.749	12.960	16306.0	1258.1
123.541	13.958	15486.2	1109.4
121.576	14.673	15030.7	1024.3
119.607	15.472	14119.7	912.5

QUALITY	XTT	F(XTT)	NU*F2/PR*(RE**.9)
0.931	3.464E-02	6.448E 00	1.055E 01
0.790	1.090E-01	2.603E 00	3.241E 00
0.659	1.973E-01	1.685E 00	1.575E 00
0.528	3.242E-01	1.193E 00	1.054E 00
0.409	4.954E-01	8.999E-01	8.052E-01
0.297	7.690E-01	6.794E-01	6.190E-01

RUN NO. 16

REFRIGERANT 12

FREON MASS FLUX 1.1296822E 06 WTR TEMP IN 95.91 FREON TEMP IN 124.62
WTR FLOW RATE 1843.07 MEAN HT COEF 2011.8 HEAT BAL ERROR -0.059

VAPOR TEMP (F)	OUT WALL T (F)	DEL WTR T (F)	P GRAD (LBF/FT3)
122.670	116.130	1.926	274.687
121.710	114.290	1.804	233.280
120.080	111.710	1.757	193.622
118.910	109.710	1.687	96.227
117.500	108.170	1.639	157.463
115.880	106.430	1.583	122.472

IN WALL T (F)	DEL WALL T (F)	HEAT FLUX (BTU/HR-FT2)	H T COEF (BTU/HR-FT2-F)
116.316	6.353	17856.1	2810.2
114.464	7.245	16725.0	2308.2
111.879	8.200	16289.3	1986.4
109.872	9.037	15640.3	1730.6
108.328	9.171	15195.3	1656.7
106.582	9.297	14676.1	1578.5

QUALITY	XTT	F(XTT)	NU*F2/PR*(RE**.9)
0.947	2.420E-02	8.710E 00	1.433E 01
0.840	7.199E-02	3.579E 00	4.665E 00
0.741	1.230E-01	2.377E 00	2.670E 00
0.646	1.834E-01	1.775E 00	1.783E 00
0.555	2.556E-01	1.405E 00	1.407E 00
0.468	3.449E-01	1.144E 00	1.155E 00

RUN NO. 17

REFRIGERANT 22

FREQN MASS FLUX	2.5736990F 05	WTR TEMP IN	80.35	FREON TEMP IN	96.88
WTR FLOW RATE	1250.82	MEAN HT COEF	754.0	HEAT BAL ERROR	-0.065

VAPOR TEMP (F)	OUT WALL T (F)	DEL WTR T (F)	P GRAD (LBF/FT3)
95.480	89.780	0.950	20.411
95.960	89.610	0.870	26.243
95.430	88.170	0.870	20.411
96.120	87.740	0.910	20.411
95.300	86.700	0.740	14.580
93.910	85.700	0.780	10.205

IN WALL T (F)	DEL WALL T (F)	HEAT FLUX (BTU/HR-FT2)	H T COEF (BTU/HR-FT2-F)
89.842	5.637	5977.3	1060.2
89.667	6.292	5473.9	869.8
88.227	7.202	5473.9	759.9
87.799	8.320	5725.6	688.1
86.748	8.551	4656.0	544.4
85.751	8.158	4907.7	601.5

QUALITY	XTT	F(XTT)	NU*F2/PR*(RE**.9)
0.943	2.373E-02	8.855E 00	1.414E 01
0.832	7.080E-02	3.626E 00	4.678E 00
0.728	1.232E-01	2.375E 00	2.715E 00
0.618	1.942E-01	1.704E 00	1.852E 00
0.520	2.771E-01	1.328E 00	1.206E 00
0.432	3.774E-01	1.077E 00	1.154E 00

88

RUN NO. 18

REFRIGERANT 22

FREON MASS FLUX	2.4756590E 05	WTR TEMP IN	60.77	FREON TEMP IN	85.09
WTR FLOW RATE	1089.37	MEAN HT COEF	764.8	HEAT BAL ERROR	0.025

VAPOR TEMP (F)	OUT WALL T (F)	DEL WTR T (F)	P GRAD (LBF/FT3)
83.270	76.610	1.460	24.202
84.090	76.130	1.320	24.202
83.230	73.740	1.450	20.995
84.170	72.960	1.180	17.204
82.910	70.960	1.280	12.247
84.130	69.350	1.180	7.581

IN WALL T (F)	DEL WALL T (F)	HEAT FLUX (BTU/HR-FT2)	H T COEF (BTU/HR-FT2-F)
76.693	6.576	8000.5	1216.5
76.205	7.884	7233.3	917.4
73.822	9.407	7945.7	844.6
73.027	11.142	6466.2	580.3
71.033	11.876	7014.1	590.5
69.417	14.712	6466.2	439.5

QUALITY	XTT	F(XTT)	NU*F2/PR*(RE**.9)
0.924	2.844E-02	7.601E 00	1.291E 01
0.777	8.870E-02	3.045E 00	3.944E 00
0.632	1.660E-01	1.907E 00	2.385E 00
0.492	2.810E-01	1.315E 00	1.249E 00
0.365	4.432E-01	9.680E-01	1.053E 00
0.232	7.994E-01	6.631E-01	6.684E-01

RUN NO. 19

REFRIGERANT 22

FREON MASS FLUX 2.5346834E 05 WTR TEMP IN 78.43 FREON TEMP IN 100.04
WTR FLOW RATE 879.57 MEAN HT COEF 820.4 HEAT BAL ERROR 0.045

VAPOR TEMP (F)	OUT WALL T (F)	DEL WTR T (F)	P GRAD (LBF/FT3)
98.700	93.430	1.430	24.202
99.260	93.220	1.310	19.828
98.590	91.220	1.440	15.746
99.300	90.430	1.300	14.580
98.260	88.740	1.390	14.580
97.780	87.090	1.350	9.331

IN WALL T (F)	DEL WALL T (F)	HEAT FLUX (BTU/HR-FT2)	H T COEF (BTU/HR-FT2-F)
93.495	5.204	6326.9	1215.7
93.280	5.979	5796.0	969.2
91.286	7.303	6371.2	872.3
90.489	8.810	5751.8	652.8
88.804	9.455	6150.0	650.3
87.152	10.627	5973.0	562.0

QUALITY	XTT	F(XTT)	NU*F2/PR*(RE**.9)
0.937	2.672E-02	8.009E 00	1.520E 01
0.817	7.995E-02	3.299E 00	4.922E 00
0.697	1.440E-01	2.116E 00	2.901E 00
0.576	2.329E-01	1.499E 00	1.635E 00
0.461	3.508E-01	1.131E 00	1.328E 00
0.343	5.454E-01	8.454E-01	9.702E-01

RUN NO. 20

REFRIGERANT 22

FREON MASS FLUX	2.2254859E 05	WTR TEMP IN	98.35	FREON TEMP IN	118.26
WTR FLOW RATE	558.51	MEAN HT COEF	614.3	HEAT BAL ERROR	-0.056

VAPOR TEMP (F)	OUT WALL T (F)	DEL WTR T (F)	P GRAD (LBF/FT3)
116.610	112.500	1.170	11.955
117.210	112.350	1.220	13.121
116.830	111.580	1.260	11.955
117.420	110.260	1.300	10.205
116.740	108.830	1.440	8.747
116.260	107.540	1.430	6.123

IN WALL T (F)	DEL WALL T (F)	HEAT FLUX (BTU/HR-FT2)	H T COEF (BTU/HR-FT2-F)
112.534	4.075	3287.0	806.4
112.385	4.824	3427.5	710.4
111.616	5.213	3539.9	679.0
110.298	7.121	3652.2	512.8
108.872	7.867	4045.6	514.1
107.581	8.678	4017.5	462.9

QUALITY	XTT	F(XTT)	NU*F2/PR*(RE**.9)
0.960	2.003E-02	1.023E 01	1.718E 01
0.879	6.027E-02	4.116E 00	5.862E 00
0.794	1.058E-01	2.662E 00	3.588E 00
0.706	1.629E-01	1.934E 00	2.004E 00
0.614	2.351E-01	1.489E 00	1.593E 00
0.518	3.341E-01	1.169E 00	1.186E 00

RUN NO. 21

REFRIGERANT 22

FREON MASS FLUX	1.3886631F 05	WTR TEMP IN	75.17	FREON TEMP IN	93.43
WTR FLOW RATE	589.97	MEAN HT COEF	533.6	HEAT BAL ERROR	-0.064

VAPOR TEMP (F)	OUT WALL T (F)	DEL WTR T (F)	P GRAD (LBF/FT3)
93.260	88.900	1.050	8.164
93.700	88.740	1.000	8.164
93.220	87.300	1.130	6.706
93.570	86.430	1.150	6.415
92.700	84.960	1.150	4.957
92.390	83.680	1.130	3.790

IN WALL T (F)	DEL WALL T (F)	HEAT FLUX (BTU/HR-FT2)	H T COEF (BTU/HR-FT2-F)
88.932	4.327	3116.0	720.0
88.770	4.929	2967.6	602.0
87.334	5.885	3353.4	569.8
86.465	7.104	3412.8	480.3
84.995	7.704	3412.8	442.9
83.714	8.675	3353.4	386.5

QUALITY	XTT	F(XTT)	NU*F2/PR*(RE**.9)
0.944	2.275E-02	9.179E 00	1.637E 01
0.836	6.779E-02	3.751E 00	5.527E 00
0.725	1.225E-01	2.384E 00	3.382E 00
0.605	2.008E-01	1.664E 00	2.101E 00
0.486	3.076E-01	1.236E 00	1.552E 00
0.367	4.759E-01	9.238E-01	1.136E 00

RUN NO. 22

REFRIGERANT 22

FREON MASS FLUX	1.4703040E 05	WTR TEMP IN	74.46	FREON TEMP IN	93.22
WTR FLOW RATE	485.72	MEAN HT COEF	568.2	HEAT BAL ERROR	-0.070

VAPOR TEMP (F)	OUT WALL T (F)	DEL WTR T (F)	P GRAD (LBF/FT3)
92.260	88.900	1.130	8.164
92.570	88.610	1.020	9.331
92.260	87.390	1.120	9.331
92.700	86.780	1.180	8.164
92.090	85.700	1.220	8.164
91.870	84.570	1.260	6.706

IN WALL T (F)	DEL WALL T (F)	HEAT FLUX (BTU/HR-FT2)	H T COEF (BTU/HR-FT2-F)
88.928	3.331	2760.9	828.7
88.635	3.934	2492.1	633.4
87.418	4.841	2736.4	565.2
86.810	5.889	2883.0	489.4
85.731	6.358	2980.8	468.7
84.602	7.267	3078.5	423.5

QUALITY	XTT	F(XTT)	NU*F2/PR*(RE**.9)
0.954	1.878E-02	1.081E 01	2.108E 01
0.866	5.420E-02	4.479E 00	6.562E 00
0.780	9.337E-02	2.927E 00	3.845E 00
0.685	1.451E-01	2.105E 00	2.470E 00
0.589	2.107E-01	1.609E 00	1.887E 00
0.488	3.029E-01	1.249E 00	1.418E 00

RUN NO. 23

REFRIGERANT 22

FREON MASS FLUX	1.5033075E 05	WTR TEMP IN	49.68	FREON TEMP IN	82.87
WTR FLOW RATE	544.99	MEAN HT COEF	507.8	HEAT BAL ERROR	-0.028

VAPOR TEMP (F)	OUT WALL T (F)	DEL WTR T (F)	P GRAD (LBF/FT3)
78.870	72.000	1.640	0.000
79.550	71.830	1.410	0.000
78.830	69.520	2.000	0.000
79.410	68.410	2.040	0.000
78.130	65.610	2.050	0.000
76.170	61.830	1.720	0.000

IN WALL T (F)	DEL WALL T (F)	HEAT FLUX (BTU/HR-FT2)	H T COEF (BTU/HR-FT2-F)
72.046	6.823	4495.9	658.9
71.870	7.679	3865.4	503.3
69.577	9.252	5482.8	592.5
68.468	10.941	5592.5	511.1
65.668	12.461	5619.9	450.9
61.879	14.290	4715.2	329.9

QUALITY	XTT	F(XTT)	NU*F2/PR*(RE**.9)
0.932	2.444E-02	8.637E 00	1.158E 01
0.801	7.460E-02	3.481E 00	3.599E 00
0.656	1.450E-01	2.105E 00	2.678E 00
0.482	2.782E-01	1.324E 00	1.639E 00
0.311	5.275E-01	8.639E-01	1.136E 00
0.157	1.146E 00	5.314E-01	7.004E-01

RUN NO. 24

REFRIGERANT 22

FREON MASS FLUX	7.3864387E 05	WTR TEMP IN	36.57	FREON TEMP IN	81.83
WTR FLOW RATE	1508.44	MEAN HT COEF	2062.5	HEAT BAL ERROR	0.028

VAPOR TEMP (F)	OUT WALL T (F)	DEL WTR T (F)	P GRAD (LBF/FT3)
79.050	71.220	3.190	183.707
79.050	72.050	2.620	189.540
77.460	67.410	2.850	148.716
77.820	65.430	2.500	134.135
76.090	62.410	2.770	119.555
74.640	55.320	2.360	43.740

IN WALL T (F)	DEL WALL T (F)	HEAT FLUX (BTU/HR-FT2)	H T COEF (BTU/HR-FT2-F)
71.472	7.577	24205.1	3194.2
72.257	6.792	19880.0	2926.6
67.635	9.824	21625.2	2201.1
65.627	12.192	18969.5	1555.8
62.628	13.461	21018.2	1561.4
55.506	19.133	17907.2	935.9

QUALITY	XTT	F(XTT)	NU*F2/PR*(RE**.9)
0.925	2.714E-02	7.904E 00	1.362E 01
0.785	8.119E-02	3.259E 00	5.154E 00
0.656	1.434E-01	2.123E 00	2.605E 00
0.527	2.334E-01	1.496E 00	1.408E 00
0.405	3.575E-01	1.117E 00	1.162E 00
0.287	5.652E-01	8.262E-01	5.975E-01

RUN NO. 25

REFRIGERANT 22

FREON MASS FLUX	5.9624675E 05	WTR TEMP IN	53.05	FREON TEMP IN	96.42
WTR FLOW RATE	1491.60	MEAN HT COEF	1422.4	HEAT BAL ERROR	0.029

VAPOR TEMP (F)	OUT WALL T (F)	DEL WTR T (F)	P GRAD (LBF/FT3)
93.910	84.090	2.770	110.807
94.480	84.570	2.590	99.143
93.170	79.640	2.720	72.900
94.170	77.820	2.460	55.403
92.480	73.700	2.320	34.991
91.000	70.550	2.050	21.870

IN WALL T (F)	DEL WALL T (F)	HEAT FLUX (BTU/HR-FT2)	H T COEF (BTU/HR-FT2-F)
84.306	9.603	20783.6	2164.1
84.772	9.707	19433.0	2001.8
79.852	13.317	20408.5	1532.4
78.012	16.157	18457.6	1142.3
73.881	18.598	17407.2	935.9
70.710	20.289	15381.4	758.0

QUALITY	XTT	F(XTT)	NU*F2/PR*(RE**.9)
0.915	3.444E-02	6.479E 00	1.021E 01
0.748	1.110E-01	2.568E 00	3.764E 00
0.586	2.143E-01	1.589E 00	1.889E 00
0.423	3.902E-01	1.053E 00	1.064E 00
0.280	6.808E-01	7.336E-01	7.217E-01
0.151	1.361E 00	4.791E-01	5.074E-01

RUN NO. 26

REFRIGERANT 22

FREON MASS FLUX	5.8922237E 05	WTR TEMP IN	36.33	FREON TEMP IN	89.04
WTR FLOW RATE	1569.60	MEAN HT COEF	1384.4	HEAT BAL ERROR	0.063

VAPOR TEMP (F)	OUT WALL T (F)	DEL WTR T (F)	P GRAD (LBF/FT3)
85.780	74.730	3.430	77.274
86.700	74.550	2.830	94.770
85.000	68.320	3.050	64.152
86.520	65.870	3.030	42.281
84.090	59.860	2.330	24.785
81.520	54.140	1.770	11.663

IN WALL T (F)	DEL WALL T (F)	HEAT FLUX (BTU/HR-FT2)	H T COEF (BTU/HR-FT2-F)
75.012	10.767	27081.5	2515.0
74.782	11.917	22344.2	1874.9
68.570	16.429	24081.2	1465.7
66.119	20.400	23923.3	1172.6
60.051	24.038	18396.4	765.2
54.285	27.234	13975.0	513.1

QUALITY	XTT	F(XTT)	NU*F2/PR*(RE**.9)
0.892	4.135E-02	5.574E 00	9.624E 00
0.689	1.360E-01	2.206E 00	2.951E 00
0.504	2.709E-01	1.349E 00	1.551E 00
0.304	5.851E-01	8.080E-01	9.344E-01
0.140	1.388E 00	4.737E-01	5.087E-01
0.020	8.808E 00	1.687E-01	3.045E-01

RUN NO. 27

REFRIGERANT 22

FREON MASS FLUX	6.8991512E 05	WTR TEMP IN	82.91	FREON TEMP IN	113.04
WTR FLOW RATE	1153.34	MEAN HT COEF	1726.8	HEAT BAL ERROR	0.031

VAPOR TEMP (F)	OUT WALL T (F)	DEL WTR T (F)	P GRAD (LBF/FT3)
111.460	106.170	2.180	108.475
111.680	105.790	2.080	102.643
110.740	103.040	2.260	86.896
111.230	101.910	2.220	79.315
109.830	100.000	2.350	67.651
109.120	98.220	2.360	48.988

IN WALL T (F)	DEL WALL T (F)	HEAT FLUX (BTU/HR-FT2)	H T COEF (BTU/HR-FT2-F)
106.301	5.158	12647.5	2451.9
105.915	5.764	12067.3	2093.4
103.176	7.563	13111.6	1733.5
102.044	9.185	12879.6	1402.1
100.142	9.687	13633.8	1407.2
98.362	10.757	13691.8	1272.7

QUALITY	XTT	F(XTT)	NU*F2/PR*(RE**.9)
0.952	2.324E-02	9.014E 00	1.692E 01
0.857	6.850E-02	3.721E 00	5.742E 00
0.762	1.197E-01	2.426E 00	3.081E 00
0.662	1.871E-01	1.750E 00	1.851E 00
0.564	2.691E-01	1.355E 00	1.494E 00
0.462	3.868E-01	1.059E 00	1.129E 00

98

APPENDIX 2

LIST OF RELEVANT VARIABLES FOR THEORETICAL PROGRAM

TSAT	refrigerant temperature entering test section
DET	difference between vapor temperature and inside wall temperature
G	refrigerant flow rate
E	ratio of eddy conductivity to eddy viscosity
GR	gravitational constant
A	axial acceleration due to external forces
DDXDZ	$D(dx/dz)$
UL,UV	liquid and vapor viscosities
KL	liquid thermal conductivity
CL	liquid specific heat
ROL,ROV	liquid and vapor densities
RU	ratio of liquid to vapor viscosities
RRO	ratio of vapor to liquid densities
PR	Prandtl number
XL	x minus quality
X	quality
DPF	frictional pressure gradient
V	void fraction
DPG	gravitational pressure gradient
RE	Reynolds number
DPM	momentum pressure gradient
DPT	total pressure gradient
DP	delta plus
TAO	wall shear stress

BT	β
FO	F_0
M	M
MUSED	indicator showing if M term was used in the calculation of F_2
F2	F_2
K	indicator showing number of iterations to obtain correct $D(dx/dz)$
YDIS	right term of Eq. (31)
HZ	local heat transfer coefficient
L	total length of condensation
DDD	new value of $D(dz/dz)$ for iteration
HM	mean heat transfer coefficient

PAGE 1 TRAVISS

// JOB T 1130 1131 1131 1131 TRAVISS

LOG DRIVE	CART SPEC	CART AVAIL	PHY DRIVE
0000	1130	1130	0001
0001	1131	1131	0000

V2 M09 ACTUAL 8K CONFIG 8K

// FOR

*IGCS (CARD,1403 PRINTER)

* LIST SCURCE PROGRAM

```
REAL L,M,KL
DIMENSION SH(19)
DATA D/.0265/
READ (2,10) N
10  FORMAT (I6)
DC 21 II=1,N
READ (2,11) TSAT,DET,G,E
11  FORMAT (4F8.0)
GR=4.17E8
C   GRAVITY FCRCE
A=0.0
C   QUALITY GRADIENT
CCXDZ=-.001
C   PHYSICAL PROPERTIES
UL=0.673-(0.00135*TSAT)
UV=0.028+((0.5*TSAT)/10000.)
KL=0.0699-((0.235*TSAT)/10000.)
RCL=86.056-(.149*TSAT)
IF(TSAT-100) 5,5,6
5   RCV=(.05*TSAT)-1.1115
HFG=98.363-(0.255*TSAT)
CL=.255+.6*TSAT/1000.
GC TC 7
6   RCV=.0665*TSAT-2.6593
```

```

HFG=101.6-(0.288*TSAT)
CL=.24+.75*TSAT/1000.
7  RL=UL/UV
   RRC=RCV/RCL
   PR=UL*CL/KL
   WRITE(5,12) TSAT,G,D,DET,E
12  FORMAT(1H1,5X'FRECN 22 AT ',F5.1,5X'G= ',F9.1,5X'D= ',
1F6.4,5X,'DET='F4.1,5X,'E='F4.1/)
   WRITE(5,13) UV,UL
13  FORMAT(5X'VAPOR VISCOSITY',F8.4,5X'LIQUID VISCOSITY',F7.3/)
   WRITE(5,14) RCV,RCL
14  FORMAT(5X'VAPOR DENSITY',F10.4,5X'LIQUID DENSITY',F9.3/)
   WRITE(5,15) KL,CL,HFG,PR
15  FORMAT(5X'CONDUCTIVITY',F8.4,3X'SPECIFIC HEAT',F7.3,
13X'LATENT HEAT',F8.3,3X'PR',F6.2//)
   WRITE(5,16)
16  FORMAT(2X,'X',5X,'DPF',10X,'DPM',7X,'DPT',8X,'RE',11X,'FZ',7X,
1'FM',9X,'L',13X,'M',11X,'DP',5X,'MUSED'/)
   DC 21 I=1,19
   XL=.05*I
   X=1-XL
   A1=G*G/(GR*RCV*D)
   A2=0.09*((UV/(G*D))**.2)
   A3=X**1.8
   A4=5.7*(RL**.0523)*(XL**.47)*(X**1.33)*(RRC**.261)
   A5=8.11*(RU**.105)*(XL**.94)*(X**.86)*(RRC**.522)
   DPF=-(A1*A2*(A3+A4+A5))
C   VCID FRACTICN
   V=1/(1+(XL*RRC**.667)/X)
C   GRAVITY PRESSURE DRCP
   DPG=((V*RCV+(1-V)*RCL)*A)/GR
   RE=(XL*G*D)/UL
C   MOMENTUM PRESSURE DRCP
   B1=2*X
   B2=(1-2*X)*(RRC**.333)

```


PAGE 3 TRAVISS

```
B3=(1-2*X)*(RRC**.667)
P4=2*XL*RRC
1 DPM=-(A1*CDXDZ*(B1+B2+B3+B4))
C TCTAL PRESSURE DRCP
DPT=DPF+DPM+DPG
C DELTA PLUS
IF(RE-50.) 30,30,31
30 DP=.7071*RE**.5
GC TC 36
31 IF(RE-1125.) 32,32,33
32 DP=.4818*RE**.585
GC TC 36
33 DP=.095*RE**.812
36 TAC=- (DPF*D/4.)
C CALCULATE BETA
IF(DP-90.) 37,37,38
37 BT=2.368-.259*ALOG(DP)
CC TC 39
38 PI=1.2
C CALCULATE FC
39 G1=RRC**.333/(1.-V)
G2=(XL*(2.-BT)*RRC)/((1.-V)*(1.-V))
FC=-DPT+(A/GR)*RCL-(A1*CDXDZ*(G1-G2))
C CALCULATE F2
M=(FC*DP*LL)/(TAC*SQRT(GR*TAC*RCL))
MLSED=0
IF(EP-5.) 40,40,41
40 F2=DP*PR
K=0
GC TC 44
41 IF(DP-30) 42,42,43
42 F2=5.*PR+5.*ALCG(1.+E*PR*(DP/5.-1.))/E
K=0
GC TC 44
43 Y1=((1+PR)**.1*(2.71828**(.1*PR)))/30.
YDIS=(Y1*(DP**1.05)-DP)/((Y1*(DP**1.05))-2.5*Y1*(DP**.05)/PR-30
```

PAGE 4 TRAVISS

```
1+2.5/PR)-M
IF(YDIS) 60,60,61
60 C1=SQRT(1.+10.*M/(PR*DP*E))
C2=60.*M/DP-1.-C1
C3=60.*M/DP-1.+C1
C4=2.*M-1.+C1
C5=2.*M-1.-C1
F2=5.*PR+5.*ALCG(1.+5.*E*PR)/E+(2.5*ALCG((C4*C2)/(C5*C3)))/(C1*E)
MLSED=1
GC TC 62
61 F2=5*PR+5*(ALCG(1+5*PR*E))/E+2.5*(ALCG(DP/30))
62 K=1
C LOCAL HEAT TRANSFER COEFFICIENT
44 FZ=CL*SQRT(GR*TAD*RGL)/F2
L=.05*HFG*G*D/(4.*FZ*DFT)
IF(K) 3,3,4
4 DDD=.025*D/L
C NEW QUALITY GRADIENT
S=ABS((DDD+DDXDZ)/DDXDZ)-.01
IF(S) 3,3,2
2 DDXDZ=-DDD
WRITE(5,50) DDD
50 FORMAT (10X,E14.8)
GC TC 1
C MEAN HEAT TRANSFER COEFFICIENT
3 IF(I-1) 19,19,20
19 HM=FZ
SH(I)=1/HZ
GC TC 23
20 IR=I-1
RH=1/FZ
SH(I)=RH+SH(IR)
HM=I/SH(I)
23 WRITE(5,17) X,DPF,DPM,DPT,RE,FZ,HM,L,M,DP,MLSED
17 FORMAT(F4.2,F9.3,F14.3,F9.3,E14.5,2F9.1,2E14.5,F9.3,I6)
```

PAGE 5 TRAVISS

21 CCNTINUE
END