

ORLANDO WEST FIRE STATION



ARCH 5226
SPRING 2021

HONORS THESIS

REBECCA DEMPEWOLF

PRELIMINARY DESIGN

PROJECT INTRODUCTION 02

DESIGN APPROACH 03

STRUCTURE 04

CODE COMPLIANCE 05

 BUILDING 05

 ENVIRONMENTAL 06

FINAL DESIGN

ARCHITECTURAL DESIGN 07

 EXTERIOR PERSPECTIVE 08

 INTERIOR PERSPECTIVE 09

SYSTEMS DESIGN 10

 HVAC 10

 LIGHTING 11

 DAYLIGHTING 12

 GRAVITY LOADS 13

STRUCTURAL DESIGN 13

 WIND LOAD 14

 SEISMIC LOAD 16

 STRUCTURAL CALCULATIONS 18

 RISA ANALYSIS 19

CONSTRUCTION DOCUMENTATION

GENERAL NOTES 20

SITE PLAN 21

GROUND FLOOR PLAN - ARCH 22

BASEMENT FOUNDATION PLAN 23

FOUNDATION PLAN 24

FRAMING PLAN 25

WALL SECTION 26

FOUNDATION DETAILS 27

FLOOR DETAILS 28

ROOF DETAILS 29

LFRS DETAILS 30

SCHEDULES 31

WIND DIAGRAMS 32

SEISMIC DIAGRAMS 33

STRUCTURAL AXONOMETRIC 34

PROJECT INTRODUCTION

THE JOHANNESBURG EMERGENCY MANAGEMENT DEPARTMENT IS SEEKING A DESIGN FOR A NEW FIRE STATION IN ORLANDO WEST, SOWETO, SOUTH AFRICA.

SERVING INFORMAL AND FORMAL SETTLEMENTS THE STATION WILL SERVE THE DIVERSE POPULATION OF THE AREA WHICH LARGELY HAS POOR RELATIONSHIPS WITH GOVERNMENTAL ORGANIZATIONS. THIS STRAIN DUE TO THE APARTHEID, WHICH HAS ONLY RECENTLY BEEN ABOLISHED, ALSO CONTRIBUTED TO THE STARK POLARIZATION OF WEALTH IN THE AREA.

WHILE THE APARTHEID HAS BEEN ABOLISHED, INFORMAL SETTLEMENTS STILL REMAIN AND POSE MANY DANGERS TO THOSE LIVING IN THEM, ESPECIALLY FIRE HAZARDS. THE FLAMMABLE BUILDING MATERIALS USED, DENSELY POPULATED SPACES UNREACHABLE BY FIRE FIGHTERS, AND UNSAFE METHODS OF COOKING ALL CREATE GREAT RISKS THAT CAN DESTROY ENTIRE SETTLEMENTS AND DISPLACE THOUSANDS OF PEOPLE IF FIRE STARTS. FURTHERMORE, RELATIONSHIPS BETWEEN THOSE LIVING IN INFORMAL SETTLEMENTS AND FIRE FIGHTERS HAS BEEN STRAINED, SO COOPERATION WITH OFFICIALS IS NOT COMMON AND DETRIMENTAL TO A RAPID EXTINGUISHING OF A FIRE.



THIS PROPOSAL FOR THE ORLANDO WEST FIRE STATION SEEKS TO BUILD CONNECTIONS BETWEEN THE COMMUNITY AND THE FIRE FIGHTERS THROUGH A CONTEXTUALLY INSPIRED DESIGN THAT CATERS TO THE NEEDS OF THE COMMUNITY, ENSURES A HEALTHY ENVIRONMENT FOR THE FIRE FIGHTERS, AND SERVES AS A NODE OF INTERACTION BETWEEN THE COMMUNITY AND FIRE FIGHTERS.

DESIGN APPROACH




UPON CONTEXTUAL RESEARCH AND SITE EXPLORATION, LARGE TESSELLATED PATTERNS BECAME A CONTEXTUAL MOTIF, EVEN VISIBLE IN THE SITE'S HISTORIC INFORMAL SETTLEMENT. THE NODES WITHIN THESE PATTERNS BECAME AN INSPIRATION FOR PATHS CONVERGING AND DIVERGING, AN INTERSECTION OF TWO THINGS DISTINCT THAT LEAVE THE NODE AND ARE CHANGED BECAUSE OF THE INTERACTION THAT OCCURRED THERE.


FROM THIS INSPIRATION THE FORM OF THE BUILDING WAS MOLDED BY PLACING THE NODES WITHIN HISTORIC SITE PATHS AND MASSAGING THE RESULT TO CREATE AN EFFICIENT YET UNIQUE LAYOUT THAT RESPONDED TO PROGRAMMATIC NEEDS AND IN SITU DEMANDS. REFLECTING THE DESIGN GOAL OF INTERACTION AND INTERSECTION, MULTIPLE STRUCTURAL MATERIALS AND SYSTEMS WERE CHOSEN TO INTERACT THROUGHOUT THE DESIGN TO VISUALLY ENTICE OR EXEMPLIFY SUCH CONNECTIONS.



STRUCTURE



structural scheme : steel



structural scheme : steel+concrete


DURING PRELIMINARY DESIGN, THREE STRUCTURAL SYSTEMS WERE EXPLORED.

STEEL : WIDE FLANGE COLUMNS AND BEAMS WORKING WITH DIAGONAL X BRACING SUPPORTING LOW SLOPE ROOF TRUSSES.

STEEL AND CONCRETE : CONCRETE BEAMS AND COLUMNS WITH STEEL ROOF JOISTS TO SPAN LONGER DISTANCES AT SHORTER DEPTHS.

STEEL AND MASONRY (SELECTED SYSTEM) : MASONRY SHEAR AND LOAD BEARING WALLS WORKING WITH THE STEEL FRAMING, ROOF JOISTS, AND A SPACE FRAME AIM TO RELATE TO CONVERGING PATHS IN THE INTERSECTING MATERIALS AND TO DEFINE SPACES THROUGH MATERIALITY.

THE SPACE FRAME WAS INSPIRED BY THE DESIRE FOR A LIGHT UNIFORM STRUCTURE CONNECTING THE TWO ADJACENT FORMS ABOVE THE ENTRANCE NODE. THE FACT THAT THE SPACE FRAME MEMBERS MEET AT NODES WAS FURTHER DESIGN MOTIVATION.



structural scheme : steel+masonry

CODE COMPLIANCE BUILDING

Floor Plan for Fire Code Check
Rebecca Dempewolf
March 05, 2021

Steel and Masonry Construction Sprinklered

Occupant Load
Utilizing 2018 IBC Table 1004.1.2
Total = 213 occupants

Common Egress Path Distances
Utilizing 2018 IBC Table 1006.2.1

Minimum Number of Exits
Utilizing 2018 IBC Table 1006.3.2
Occupant load <500
Min # exits = 2
Provided # exits = 9
(In spaces with occupant loads over those in Table 1006.2.1 two exits are provided.)

Distance Between Exits
Utilizing 2018 IBC 1007
Spaces with two exits are spaced at a distance at the minimum of 1/3 the room diagonal applying exception 2.

Required Plumbing Fixtures
Utilizing 2018 IBC Table 2902.1


Assembly 1 fixt./200occ.
+
Business 1 fixt./40occ.
2 Male, 2 Female, 1 Unisex provided.

Congregate living
1 fixt./16occu.
2 Unisex provided.

1 service sink required by all and provided in janitor's closet.

DURING DESIGN, COMPLIANCE WITH THE IBC 2018 WAS CHECKED.

OCCUPANCY LOADS WERE CALCULATED TO DETERMINE REQUIRED EXITS, EGRESS WIDTHS, TRAVEL DISTANCES, NUMBER OF PLUMBING FIXTURES, AND MORE.






Egress Widths
Utilizing IBC 1005.3.1, 1005.3.1, 1011.2, 1020.2, 1010.1.1)
Min stair width= 44"
(IBC 1011.2=44" or 0.3inches*213occupants/2stairs=11inches)
Prov. min stair width= 48"

Min corridor width= 44"
(IBC 1020.2=44" or 0.2 inches*92 occupants/2exits =9.2inches)
Prov. min corridor width= 77"

Min door width= 32"
(IBC 1010.1.1=32" or 0.2 inches*92 occupants/2exits =9.2inches)
Prov. door width= 36"

ENVIRONMENTAL



DURING DESIGN, COMPLIANCE WITH THE IECC 2021 WAS ENSURED THROUGH THE USE OF MULTIPLE SOFTWARES.

COVETOOL WAS UTILIZED TO ANALYZE THE DAYLIGHTING AND GLARE POTENTIAL IN THE BUILDING, AS WELL AS DETERMINE BASELINE ENERGY USAGES BASED ON ENVELOPE PROPERTIES AND MECHANICAL SYSTEM SELECTIONS. COMPARED TO BASELINE, THIS DESIGN REDUCES CO2 EMISSIONS BY 51% AND IS 9% MORE ENERGY EFFICIENCY THAN BASELINE CONDITIONS.

EQUEST HELPED DETERMINE PERIMETER AND INTERIOR THERMAL ZONE LOADS BASED ON DIFFERENT SHADING, VOLUME, AND MATERIAL PROPERTIES INPUTS. COMPARED TO BASELINE, THIS DESIGN REDUCES THE PERIMETER THERMAL LOAD BY OVER 40%

DETAILED CALCULATIONS FOR ENVELOPE R AND U VALUES WAS ACCOMPLISHED FOR USE IN THESE PREDICTIVE MODELING SOFTWARES.

Envelope Compliance Dempewolf
All other, Climate Zone 3A, Orlando West Fire Station



Code	approx.	Outside Air (R or R/in)	total	Exterior Finish (R)	thick-ness	total	Continuous Rigid Insulation (R/in)	thick-ness	total	Sheathing (R)	total	Cavity Insulation (R)	total	Interior Finish board (R)	total	Interior Air Film	total	Total R	Total U
Roof	R-25ci U-0.039	15mph summer 0.25	0.25	Standing Seam Metal Roof 0		0	Extruded Polystyrene 5	5	25	Structural Decking 0	0	0	0	0	0	horizontal surface downward heat flow 0.92	0.92	26.17	0.038
Wall	R-13+R-7.5ci U-0.064	15mph summer 0.25	0.25	4" Clay Face Brick 0.24	3.68	0.88	Extruded Polystyrene Board 5	1.5	7.5	Plywood 3/4" 0.93	0.93	Rockwool Batt Insulation 5" 19	19	7.03	0.59	Vertical surface, horiz heat flow 0.68	0.68	29.832	0.056
Wall Below Grade	C - calculation NR C-1.14	soil 0.041	0.04	12" CMU 1.28		1.28	Extruded Polystyrene Board 5	2	10	0	0	0	0	0	0	Vertical surface, horiz heat flow 0.68	0.68	12.0005	0.084
Slab	U/F - calculation NR F-0.73	soil 0.021	0.02				Extruded Polystyrene Board from perimeter insulation 5	2	10	0	0	0	0	0	0	horizontal surface upward heat flow 0.61	0.61	10.631	0.560

*f-factor from ASHRAE 90.1 Table A6.3.1 for Unheated slab with R-10 @ 24" vertical

Code	approx.	Glazing	Compliance?
Skylight	U - 0.55 SHGC - 0.35	0.55 0.35	Yes
Windows	U - 0.46 SHGC - 0.30	0.46 0.30	Yes

Insulation Compliance

Code	approx.	Compliance?
Wall above grade: R13+7.5ci	**Wall Cavity insulation = 19 **Wall ci = 7.5 **Wall U = 0.0560	Yes
Roof: R-25ci, U-0.039	*Roof ci = 25 *Roof U = 0.0382	Yes
Walls below grade: R-NR, C-1.14	*Wall ci = 10 *Wall C = 0.0836	Yes
Slab on grade: NR, F-0.73	*Slab Perimeter ci = 10 *Slab F = 0.5600	Yes




ARCHITECTURAL DESIGN

FINAL ARCHITECTURAL DESIGN OF THE FIRE STATION INCORPORATED REVISIONS FROM PRELIMINARY DESIGN, UPDATES FROM ENERGY ANALYSIS, AND CODE UPDATES.

FURTHERMORE, STRUCTURE AND BUILDING SYSTEMS HAVE BEEN INTEGRATED TO ENSURE SYSTEMS DO NOT CLASH.

MATERIALITY AND PROGRAM SPACES HAVE BEEN REVISITED TO MEET NEEDS AND DESIGN GOALS.

FINAL DESIGN



① Main Floor Plan
3/32" = 1'-0"



EXTERIOR PERSPECTIVE



INTERIOR PERSPECTIVE



SYSTEMS DESIGN

HVAC

UTILIZING A VRF HEAT PUMP SYSTEM, ONLY FRESH AIR IS NEEDED TO BE SUPPLIED TO EACH SPACE BASED ON AREA AND OCCUPANCY. DUE TO VRF'S LIMITATIONS, DUCTWORK NEEDS TO BE CLOSER TO THE GROUND PLANE TO ENSURE THE AIR WILL EFFICIENTLY MIX WITH THE NEARBY WATER PIPES OF THE AUXILLARY VRF COMPONENTS. HOWEVER, WITH EXPOSED CEILING PLANES IN A GABLED FORM,


THE DUCTWORK IS RUN ALONG THE WALLS OF THE IMPORTANT SPACES, OR NODES. THIS WORKED WELL IN COMBINATION WITH THE MASONRY AND STEEL STRUCTURE BECAUSE FEWER LARGE DUCTS CUT THROUGH THE WALL PLANES.

IN THE CONTAMINATED ZONES OF THE FIRE STATION, SEPARATE SYSTEMS ARE USED TO SUPPLY FRESH AIR AND REMOVE EXHAUST. EXHAUST FROM KITCHEN AND WATER CLOSETS WAS INCLUDED.







THE VRF VARIABLE REFRIGERANT FLOW SYSTEM IS TYPICALLY A MORE ENERGY EFFICIENT SYSTEM DUE TO THE CONTROL OVER THE REFRIGERANT DELIVERED TO EACH TERMINAL SUPPLYING THE ZONES DIFFERING DEMANDS EFFECTIVELY.

LIGHTING



RCP - Focus Space
1/8" = 1'-0"

-  RENNA SUSPENDED SQUARE LED FIXTURE
-  RETURN AIR GRILL AND DUCT
-  SUPPLY AIR DUCT AND SPOT DIFFUSER
-  FIRE SPRINKLER SYSTEM (THROW @ 10' O.C.)

IN A SELECTED FOCUS SPACE, THE SYSTEM DESIGN WAS DEVELOPED FURTHER AND INCORPORATED THE FIRE SUPPRESSION SYSTEMS AND LIGHTING DESIGN WITH THE HVAC SYSTEM.

THE REFLECTED CEILING PLAN SHOWS THESE SYSTEMS COORDINATED.

THE LUMEN METHOD WORKSHEET SHOWS THE LIGHTING DESIGN WHICH PROVIDES THE DESIRED LUMINANCE AT 30% MORE EFFICIENT THAN CODE.

AVERAGE ILLUMINANCE WORKSHEET-ELECTRIC LIGHTING (LUMEN METHOD-SIMPLIFIED)


Designer: Space type:

PHOTOMETRIC DATA

IESNA Illuminance category: ...P
 IESNA Recommended illuminance (average): ...27 (fc)
 [Refer to IESNA tables]
 Lamp type: RNNAD 90CRI TUWH PROR 40K 700LMF 4FT SQ_30
 Recommended spacing ratio: 0 @ 1.23; 90 @ 1.24
 Lumen output from one lamp (initial): 2861.4 (lumens)
 Number of lamps per luminaire: 4 (lamps)
 Fixture efficiency: 100 (%)
 Lumen output from one luminaire: 11,445.6 (lumens)

ROOM DESIGN

L = 45 (ft)
 W = 30 (ft)
 H = 18 (ft)
 Ceiling cavity reflectance = CCR = 80 (%)
 Room cavity reflectance (walls) = RCR = 70 (%)
 Assumed floor cavity reflectance = FCR = 20 (%)



$h_{cc} = 7.5$ (average) (ft)
 $h_{rc} = 9$ (ft)
 $h_{fc} = 2.5$ (ft)

SIZING OF THE SYSTEM

a. Effect of room geometry: Determine equivalent-square room length (W_{sq}), and the Room Cavity Ratio (RCR).

$$W_{sq} = W + [(L-W) / 3] = 35 \text{ ft}$$

$$RCR = (10 \times h_{rc}) / W_{sq} = 2.57$$

From manufacturer's data, obtain the Coefficient of Utilization (CU) of this luminaire in this space.

$$CU = 0.97$$

b. Effect of maintenance conditions of the space and the system (includes ballast factor): Estimate LLF.

Light Loss Factor = LLF = Good conditions **0.65** (Circle one)
 Average conditions = 0.55
 Poor conditions = 0.45

c. Calculate useful lumens from one luminaire (on the workplane):

$$\text{Useful lumens from one luminaire} = \text{Lumen output from one luminaire} \times CU \times LLF$$

$$= 7216.45 \text{ lumens/luminaire}$$

d. Determine total lumens needed on the workplane:

$$\text{Total lumens needed on the workplane} = \text{Recommended illuminance} \times \text{area}$$

$$= 27 \text{ fc} \times 45 \text{ ft} \times 30 \text{ ft} = 36450$$

e. Determine needed number of luminaires:

$$\text{Number of luminaires} = \text{Total lumens needed on the workplane} / \text{useful lumens from one luminaire}$$

$$\text{Number of luminaires} = 36450 / 7216.45 = 5.05 \Rightarrow 6$$

$$\text{Actual illumination level provided} = 27 \times (6/5.05) = 32.07$$


$$\text{Light load} = 6 \text{ luminaires} \times 4 \text{ lamps} \times 29 \text{ watts} / (45 \text{ ft} \times 30 \text{ ft}) = 0.5156 \text{ W/sf} \ll 0.85 \text{ for code compliance -good!}$$

$$\text{Light load index} = (0.5156 \text{ W/sf}) / 32.07 \text{ fc} = 0.0161 \text{ W/sf*fc}$$

$$\text{Area covered per luminaire} = (45 \text{ ft} \times 30 \text{ ft}) / 6 \text{ luminaires} = 225 \text{ sf}$$

$$\text{System's overall efficiency} = 100 \times 0.97 \times 0.65 = 63.05\% \text{ efficiency}$$

DAYLIGHTING



Daylighting Calculations

$$I_{L_{predicted}} = I_{L_{standard}} \times DF \times V_{t_{glass}} \times M_{glass}$$


$I_{L_{standard}}$	1239 fc
DF	5%
$V_{t_{glass}}$	23%
M_{glass}	85%

$$I_{L_{predicted}} = 11.77211 \text{ fc}$$


NUMEROUS STUDIES OF A SPACE IN THE BUILDING WERE CONDUCTED IN THE DAYLIGHTING LAB WHICH INFLUENCED SHADING DESIGN AND GLARE REDUCTION MEASURES. UNEVEN DISTRIBUTION OF DAYLIGHT WITHIN THE SPACE WAS ALSO ADDRESSED THROUGH EXTENDED OVERHANGS AND CANOPY COVER.

DAYLIGHTING LAB TRIALS


#1




#2



#3



#4 - FINAL



STRUCTURAL DESIGN

GRAVITY LOADS

ROOFING SYSTEM: 8 PSF

STANDING SEAM = 2PSF

INSULATION = 6 PSF

STRUCTURE: 8 PSF

BEAMS/GIRDERS/SPACE FRAME = 6 PSF

STRUCTURAL DECK = 2 PSF

ROOF LIVE: 20 PSF

SPRINKLERS: 3 PSF

MEP: 4 PSF

DIFFUSERS
DUCTS
VRF
ELECTRICAL

FLOOR DEAD: 65 PSF

CONCRETE/DECK = 45 PSF
STRUCTURE = 7 PSF
FLOORING = 3 PSF
MECH = 4PSF
SPRINKLERS 3 PSF
COLLATERAL = 3 PSF

FACADE: 55 PSF

6" METAL STUD = 4 PSF
SHEATHING & GYP = 5 PSF
INSULATION = 2 PSF
FACE BRICK = 42 PSF
COLLATERAL = 2 PSF

GLASS = 15 PSF

ROOF COLLATERAL: 3 PSF

FLOOR LIVE: 100 PSF



Dead Loads

Roof Dead Load:

HSS Structure	9.0 psf
Roofing System	8.0
Mech, Elec, Plumb	4.0
Sprinklers	3.0
Collateral	3.0
Total	27.0 psf
Adjusted for slope :	35.2 psf

Space Frame	8.0
Roofing System	8.0
Mech, Elec, Plumb	4.0
Sprinklers	3.0
Collateral	3.0
Total	26.0 psf

Floor Dead Load:

Con/Metal Decking (2" conc on 3" deck)	45.0 psf
Structure	7.0
Finish Flooring	3.0
Mech, Elec, Plumb	4.0
Sprinklers	3.0
Collateral	3.0
Total	65.0 psf

Façade Dead Load:

Wall Framing	
6" Metal Stud @ 16" O.C.	4.0
Sheathing and Gypsum	5.0
Insulation	2.0
Collateral	2.0
Total	13.0 psf

Face brick with wall framing	42.0 psf
	55.0 psf

Glass	15.0 psf
-------	----------

Live Loads from ASCE 7-10

Roof Live Load:

Roof live on horizontal:	20.0 psf
--------------------------	----------

Floor Live Load:

R (private) room =	40.0 psf
R (public) room =	100.0 psf
Rec. rooms=	100.0 psf
Floor live load:	100.0 psf

WIND LOAD

Wind Calculations	
Location	Orlando West, South Africa
Importance	IV
Exposure	B
Basic Wind Speed	120 mph

Variables:	
WW & LW	WW
$p=qGC_p$	$C_p = 0.8$
Canopy	$p=q_nGC_n$

Controlling variables in green	
Roof	$p=qGC_p - q_i(GC_{pi})$

Building Region	B (ll gable)	L (gable)	L/B	h_{roof}	z_{walls}	θ_{max}	h/L	$d_{min, ridge}$ from WW
A (ne-sw)	72	34	0.472	20	24	62	0.588	12
A (nw-se)	34	72	2.118	20	24	40	0.278	30
B	70	53	0.757	15	13	2	0.283	70
C (n-s)	188	42	0.223	20	22	24	0.476	15
C (e-w)	42	188	4.476	17	22	67	0.090	50
Canopy	35	53	1.514	16	-	24	0.302	12

Building Region	Walls		Roof gable		Roof ll gable, C_p			
	WW, C_p	LW, C_p	C_{p+}	C_{p-}	0-h/2*	h/2-h	h-2h	2h<
A (ne-sw)	0.8	-0.5	0.62	-0.6	-1.17	-0.7	-0.7	-0.7
A (nw-se)	0.8	-0.3	0.4	-0.6	-0.9	-0.9	-0.5	-0.3
B	0.8	-0.5	-0.3	-0.3	-0.9	-0.9	-0.5	-0.3
C (n-s)	0.8	-0.5	0.25	-0.6	-0.9	-0.9	-0.5	-0.3
C (e-w)	0.8	-0.2	0.67	-0.6	-0.9	-0.9	-0.5	-0.3
Canopy			$C_n (+/-)$		$C_n (+/-)$			
			1.3	0.3	0.8	0.8	0.6	0.3

* A(ne-sw) 0-h/2 uses area reduction of 0.9

Windward Walls	
$q = .00256K_zK_{zt}K_dV^2$	
V=	120
$K_z =$ varies see below	
$K_{zt} =$	1.000137
$K_d =$	0.85

Topographical Factor, Figure 26.8-1&2			
K1	0.75	z	12
Y	2.5	μ	4
x	7	LH	3.5
K2	0.5		
K3	0.000182		

Terrain Exposure, Table 26.9-1	
α	z_g
7	1200

G=	0.85	section 26.9.4
$C_p =$	0.8	figure 27-4.1

Velocity Exposure Coefficients		
h	K_h	K_z
0-15	0.57	0.57
20	0.62	0.62
22	0.636	0.64
24	0.652	0.66
25	0.66	0.67
30	0.7	0.70

Table 27.3-1
Exposure B →

Velocity Pressure Calculated		
$q = 31.33868 * K_z$		
0-15	$qz_{@h} =$	18.01
20		19.55
22		20.09
24		20.60
25		20.84
30		21.96

$p_z = qGC_p = q_z * 0.68$		Net Design Pressure
Height (ft)		P_{ww}
0-15		12.24744901
20		13.29665565
22		13.66371841
24		14.00766139
25		14.17199522
30		14.92980757


Leeward Walls	
$p = qGC_p$	G= 0.85

Building Region	From figure 27.4-1		$q_h = .00256K_zK_{zt}K_dV^2$	Net Design Pressure	
	$C_{p_{trans}}$	$C_{p_{long}}$		$P_{(LW-trans)}$	$P_{(LW-Long)}$
A	-0.5	-0.3	19.55	-8.31041	-4.986246
B	-0.5	-0.43	18.01	-7.654656	-6.583004
C	-0.5	-0.2	19.55	-8.31041	-3.324164

Roof		Canopy	
$p = q_hGC_p - q_i(GC_{pi})$	$q = .00256K_zK_{zt}K_dV^2$	$p = q_nGC_n$	
	G= 0.85	G= 0.85	
	$GC_{pi} = 0.18$		





Table 26.11-1

Building Region	Net Design Pressure (psf)							
	q_h	Wind to roof gable			Wind ll to roof gable			
		$P_{(+)}$	$P_{(-)}$	$P_{ovh} = 0.75P_{(+)}$	$P_{0-h/2}$	$P_{h/2-h}$	P_{h-2h}	$P_{2h<}$
A	19.55	7.31	-12.96	-9.72	-22.44	-14.63	-14.63	-14.63
B	18.01	-7.35	-7.35	-5.51	-16.53	-16.53	-10.41	-7.35
C	19.55	8.14	-12.96	-9.72	-17.95	-17.95	-11.30	-7.98






THE FIRE STATION WAS DESIGN AS IMPORTANCE IV WITH TERRAIN EXPOSURE B AND A BASIC WIND SPEED OF 120 MPH. THE WIND WAS APPLIED IN THE WORST CASE DIRECTION BASED ON THE LOCAL AXES OF THE BUILDING'S REGION. (IE. PERPENDICULAR TO TRANSVERSE FACE OF REGION, LONGITUDINAL FACE OF REGION, AND AT CORNERS).

Windward and Leeward Wind forces
In relative +X (transverse) and +Y (longitudinal) directions



THESE WIND LOAD DIAGRAMS SHOW THE CHANGE OF WIND LOAD BASED ON THE REGION OF THE STRUCTURE, ITS HEIGHT, AND THE DIRECTION OF THE WIND.

Windward and Leeward Wind Forces
In relative -X (transverse) and -Y (longitudinal) directions



SEISMIC LOAD

Location Orlando West, South Africa
 Importance IV
 Site Class D - Stiff Soil

Basic Parameters:

S _s	0.263
S ₁	0.077
S _{MS}	0.418
S _{M1}	0.185
S _{DS}	0.279
S _{D1}	0.123

Additional Information:

SDC	C	Seismic design category
F _a	1.59	Site amplification factor at 0.2s
F _v	2.4	Site amplification factor at 1.0s
C _{RS}	0.859	Coefficient of risk (0.2s)
C _{R1}	0.882	Coefficient of risk (1.0s)
I _e	1.5	ASCE 7-10, Table 1.5-2

Table 12.6-1: Equivalent Lateral Force Analysis Permitted

SEISMIC LOAD WAS NOT CONTROLLING EXCEPT WHERE THE CENTER OF MASS AND CENTER OF RIGIDITY WERE DISTANT FROM EACH OTHER WHICH INDUCED A LARGE TORSIONAL MOMENT, AS OCCURRED IN THE WEST REGION OF THE STRUCTURE.

SEISMIC DESIGN CATEGORY C WAS UTILIZED WITH IMPORTANCE IV AND SITE CLASS D.

THE SEISMIC WEIGHTS WERE BROKEN UP BY THE BUILDING REGIONS AND C_s VARIED BASED ON THE LATERAL FORCE RESISTING SYSTEM OF THE REGION.

Ord. Steel Cantilevered Columns (Region B & Canopy)	Ord. Reinf. Masonry Shear Walls (Region A & C)
ASCE 7-10, Table 12.2-1, G - detail req. in 14.1 R= 1.25 NL $T = C_u T_a$ $T_a = C_t h_n^x$	ASCE 7-10, Table 12.2-1, A - detail req. in 14.4 R= 2 NL $T = C_u T_a$ $T_a = C_t h_n^x$
ASCE 7-10, Table 12.8-2 C _t = 0.02 h _n = 24 x= 0.75 T _a = 0.2	ASCE 7-10, Table 12.8-2 C _t = 0.02 h _n = 24 x= 0.75 T _a = 0.2
ASCE 7-10, Table 12.8-1 C _u = 1.6877 T= 0.366002	ASCE 7-10, Table 12.8-1 C _u = 1.6877 T= 0.366002
ASCE 7-10, Figure 22-12 T _L = 12 T ≤ T _L Use corresponding C _s upper limit	ASCE 7-10, Figure 22-12 T _L = 12 T ≤ T _L Use corresponding C _s upper limit
C _s Calculated ASCE 7-10, 12.8.1 $C_s = \frac{S_{DS}}{R I_e}$ C _s = 0.3348	C _s Calculated ASCE 7-10, 12.8.1 $C_s = \frac{S_{DS}}{R I_e}$ C _s = 0.20925
C _s Upper Limit $C_{sup} = \frac{S_{DS}}{T \cdot \frac{R}{I_e}}$ C _s = 0.403276	Check C _s Upper Limit $C_{sup} = \frac{S_{DS}}{T \cdot \frac{R}{I_e}}$ C _s = 0.252048
Check C _s Lower Limit $C_{slow} = 0.044 \cdot S_{DS} \cdot I_e \geq 0.01$ C _{slow} = 0.018414	Check C _s Lower Limit $C_{slow} = 0.044 \cdot S_{DS} \cdot I_e \geq 0.01$ C _{slow} = 0.018414
Use C _s = 0.335	Use C _s = 0.209

Seismic Weight

Façade Weights and Loads

Level	Region A 20 ft			Region B 14 ft			Region C 20 ft		
	Roof	Framing	Found.	Roof	Framing	Found.	Roof	Framing	Found.
VenBrick	-	510.00	510.00	-	-	-	-	510.00	510.00
VenStud	550.00	-	550.00	220.00	-	550.00	550.00	-	550.00
Clerestory	-	230	550.00	-	-	-	-	390	550.00
Curtain wall	-	-	-	220.00	-	150.00	550.00	-	150.00
Roof Dead Load	35.246 psf								

Total Dead Load

Load	Dead	Façade	Floor	Total
Region A	120.7914	87.67	-	208.46 k
Region B	66.95	18.10	-	85.05 k
Region C	412.5191	251.33	64.35	728.20 k
TOTAL Dead Load				2,043.40 k

Cantilevered Columns (Region B & Canopy)	Ord. Reinf. Masonry Shear Walls (Region A & C)
Region B Base Shear $V = C_s \cdot W$ V= 28.47 kips	Region A Base Shear $V = C_s \cdot W$ V= 43.62 kips
Vertical Distribution ASCE 7-10, Equation 12.8-12 $C_{vx} = \frac{w_x h_x^k}{\sum w_i h_i^k}$	
ASCE 7-10, 12.8.3 (T<0.5) or 2 (T>2.5) interpolate for k if 0.5<T<2.5 else, k = 1	interpolate for k if 0.5<T<2.5 else, k = 1 (T<0.5) or 2 (T>2.5)
T k 0.5 1 0.366002 0.933001 2.5 2 k= 1	T k 0.5 1 0.366002 0.933001 2.5 2 k= 1
Level W _x h _x w _x (h _x ^k) C _{vx} Roof 66.95 14 937.3 1 Σw _i h _i ^k = 937.3	Level W _x h _x w _x (h _x ^k) C _{vx} Roof 208.46 20 4169.162 1 Σw _i h _i ^k = 4169.162
Cantilevered Columns $F_x = C_{vx} \cdot V$ Level F _x Roof 28.47307 k	Ord. Reinf. Masonry Shear Walls $F_x = C_{vx} \cdot V$ Level F _x Roof 43.62 k
ρ= 1 ASCE 12.3.4.1 Level E _h E _v Roof 28.47 3.73581 k	ρ= 1 ASCE 12.3.4.1 Level E _h E _v Roof 43.62 11.631962 k
Canopy Base Shear $V = C_s \cdot W$ V= 14.36 kips	Region C Base Shear $V = C_s \cdot W$ V= 152.37 kips
Level W _x h _x w _x (h _x ^k) C _{vx} Roof 0 17 0 0 Σw _i h _i ^k = 0	Level W _x h _x w _x (h _x ^k) C _{vx} Roof 663.85 20 13,276.92 1.00 Floor 64.35 0 - Σw _i h _i ^k = 13,276.92
Cantilevered Columns $F_x = C_{vx} \cdot V$ Level F _x Roof 0 k	Ord. Reinf. Masonry Shear Walls $F_x = C_{vx} \cdot V$ Level F _x Roof 43.61986 k
ρ= 1 ASCE 12.3.4.1 Level E _h E _v Roof - 0 k	ρ= 1 ASCE 12.3.4.1 Level E _h E _v Roof 43.62 37.04 k
Vertical Seismic Load Effect - E _v [12.4.2.2] requires that a vertical load effect equal to 0.2 S _{ds} be applied to dead load. It is applied as a Dead Load Factor adjustment and may act downward or upward. No I _e , I _p , nor Rho is applied to E _v . (NCSEA, "...Common errors in Seismic...")	
EV Factor 0.0558	

Lateral Force Resisting System Plan


☆ Center of Mass (COM)

Region A:
x=17, y=36
Region B:
x=25, y=24
Region C:
x=22.5, y=94
Canopy:

★ Center of Rigidity (COR)

Region A:
x=16.37, y=62.67
Region B:
x=24.625, y=34.5
Region C:
x=30.62, y=95.125
Canopy:


● Cantilever Column - Region B and Canopy
■ Masonry Shear Walls - Region A and C



SEISMIC LOADS ARE APPLIED TO A REGION OF A STRUCTURE BASED ON THE WEIGHT OF THE STRUCTURE IN THAT AREA. FACADE AND FLOOR STRIP PLANS EXPRESS THE VARIOUS WEIGHT CONDITIONS THAT WERE CONSIDERED.


LATERAL FORCE RESISTING ELEMENTS TRANSFER LOADS TO THE FOUNDATION. THE LOCATION OF THESE ELEMENTS AND THEIR STIFFNESSES AFFECTS THE RIGIDITY OF THE STRUCTURE AND ITS NATURAL TENDENCY TO ROTATE UNDER LATERAL LOADS.

THE CENTER OF RIGIDITY WAS USED TO CALCULATE THE INHERENT TORSION DUE TO THE SEPARATION BETWEEN THE CENTER OF MASS AND CENTER OF RIGIDITY THAT OCCURS DURING LATERAL LOADING.



STRUCTURAL CALCULATIONS


COMPOSITE BEAMS, EXAMPLE SUMMARY



MASONRY SHEAR AND LOAD BEARING WALLS, EXAMPLE SUMMARY

	1	2	3
P (k/ft)	1.27	1.69	0.70 k
M (k*in/ft)	55.50	16.83	8.02 k-in

Point	Label	P (k/ft)	M (k*in/ft)	Point	Label	P (k/ft)	M (k*in/ft)
Pure Axial	1	43.15	0	k=25kd	5	-8.67	-49.35
Pure Moment	2	0	54.11	Balanced Cond.	3	-8.16	-9.92
Balanced Cond.	3	(8.16)	-9.92292277	k=.5kd	4	0.07	0.39
k=.5kd	4	0.07	0.387029282	Pure Moment	2	0.00	54.11
k=.25kd	5	(8.67)	-49.3536602	kd=d	6	16.88	77.51
kd=d	6	16.88	77.50921119	kd=.75h	7	29.81	95.95
kd=.75h	7	29.81	95.95	kd=h	8	37.77	124.37
kd=h	8	37.77	124.37	kd=2h	9	58.17	55.51
kd=2h	9	58.17	55.51	Pure Axial	1	43.15	0.00



Required Load falls within Interaction Diagram - Design works

HAND CALCULATIONS WERE UTILIZED TO DESIGN SPECIAL MEMBERS UNABLE TO BE DESIGNED THROUGH SOFTWARE.

Space Frame Cantilever Columns

Space Frame System Forces

Horizontal forces

Wind 11 k
Seismic 27 k

distributing 2/3 total lateral load to individual column for max condition approximation

Vertical Forces

Wind Uplift -16.5 psf
DL 26 psf
LL 20 psf

330 ft² per column
15 ft avg column height

Factored Loads

1.2 D + 1.6 L
20.856 k

1.2 D + 1.6 L + 0.5 W
gravity 15.411 k
lateral 3.66666667 k
M from lat 55 k-ft

1.2 D + 1W + 1L
gravity 11.451 k
lateral 7.33333333 k
M from lat 110 k-ft

1.2 D + 1E + L
gravity 16.896 k
lateral 18 k
M from lat 270 k-ft

0.9 D + 1W
gravity 2.277 k
lateral 7.333333 k
M from lat 110 k-ft

0.9 D + 1W
gravity 7.722 k
lateral 18 k
M from lat 270 k-ft

Maximum Forces

gravity 20.856 k
lateral 18 k
Moment from lat 270 k-ft

Round HSS 14x0.5 AISC Tables
Flexure 294 k-ft
Tension 820 k
Compressic 745 k

Chapter H
Pr/Pc 0.027994631 less than 1 assuming half moment goes x axis half goes to y axis

unity equation 0.932365 < 1

HSS14x0.5 works

SPACE FRAME MEMBER CAPACITY

Round HSS

Fy 46 ksi E 29000 ksi
L 42 in r 0.543 in2
D 1.66 in Ag 0.635 in2
t 0.13 in

Compression

Section E3
D/t (slenderness) 12.76923 < Slenderness limit 69.35 B4.1a
Member is nonslender: good
Lc/r = 77.34807 < Effective slenderness limit 118.26 (Fy/Fe)
Use Fcr = 0.685(Fy) + Fy

Fe 47.84 ksi
Fcr 31.97 ksi
 $\Phi P = \Phi Fcr \cdot Ag$ 18.27 kips

Tension

Table 5-7
 ΦPn yeild 25.90 k
 ΦPn rupture 21.8 k

HSS 1.66X0.14

$\Phi Pn =$ 18.27 k (compression)
21.80 k (tension)

Slab on Grade w = 12 in_{strip}

6" TYP. U.N.O. h = 6 in

CRSI Design Method

F_{roughness} = 1.5 Typ.
L = 20 ft_{max}
w = 100 psf_{occupancy live load}
fs = 40000 psi_{2/3fy}

As = 0.0375 in²/ft

Temperature and Cracking

As_{temp} = 0.0018 * h * w = 0.1296 in²/ft

	A _{bar}	S _{max}	S _{controlling}	As/ft
#3 bars	0.11	10.18519	10.18519	0.1296
#4 bars	0.2	18.51852	18	0.133333

Max spacing 5h or 18in
Use 18

Design Summary:
As_{temp} Controls Design 0.1296 in²/ft
Use #3 bars @ 10 in O.C. E.W.
w/ As = 0.132 in²/ft
or W6.5xW6.5 @ 6 in O.C.
w/ As = 0.13 in²/ft

Spread footing Design

Square Base Plate	B X N	HSS6x6x4 HSS9x9x4 HSS8x8x4			in
		12	15	14	
t		0.5	0.5	0.5	in
Square Footing	ft, B X L	4	4	4	ft
	height (in)	16	16	16	in
each way:	w/	4	4	4	bars
	sizr	#6 bar	#6 bar	#6 bar	
bar spacing		14	14	14	in, with 3" cc.

Stem Wall Design

Wall thickness	12 12 8			in	
	d	10.75	10.75		6.75
h	12	12	8	in	
Wall height	10	6	3.5	ft	
each way:	# bars	1	1	1	bars
	size	#5 bar	#5 bar	#4 bar	
db	0.625	0.625	0.5		
bar spacing	12	12	12	in, with 3" cc.	
As =	0.31	0.31	0.2	in ² /ft	

Strip Footing Design

h	16	12	12	inches
d	13.5	9.5	9.5	inches
L square	4	4	4	ft
#bars	#4 bars	#4 bars	#4 bars	@
spacing	8	11	11	inches O.C. EW


RISA ANALYSIS

THE STEEL STRUCTURE WAS ANALYZED AND DESIGN USING RISA 3D, A STRUCTURAL MODELING SOFTWARE. THE MASONRY WALLS AND FOUNDATIONS WERE DESIGN FROM LOADS RECEIVED FROM PLACE HOLDERS WITHIN THE RISA MODEL.


THE STEEL FRAME SYSTEM WAS MODELED SEPARATELY FROM THE SPACE FRAME SYSTEM DUE TO THE COMPLEXITY OF THE SPACE FRAME SYSTEM.

THE SPACE FRAME WAS PRELIMINARILY DESIGNED AND WILL BE COMPLETED BY A SPECIALTY ENGINEER.


THE RESULTS OF THE DESIGN FROM RISA AND HAND CALCULATIONS IS COMPILED IN THE CONSTRUCTION DOCUMENTS FOLLOWING.



RISA MODEL



REVIT MODEL




No.	Description	Date

**ORLANDO WEST
FIRE STATION
SITE**

Project number	5226
Date	Issue Date
Drawn by	Author
Checked by	Checker

A101

Scale



1 Main Floor Plan
3/32" = 1'-0"




No.	Description	Date

ORLANDO WEST FIRE STATION GROUND FLOOR PLAN

Project number	5226
Date	Issue Date
Drawn by	Author
Checked by	Checker

A102

Scale	3/32" = 1'-0"
-------	---------------



① Service Level
3/32" = 1'-0"

FOUNDATION PLAN NOTES

- FINISH FLOOR ELEVATION IS 100'-0" (RELATIVE TO DATUM 100'-0")
- TOP OF CONCRETE SLAB IS FINISH FLOOR UNLESS SHOWN OTHERWISE
- TYPICAL CONCRETE SLAB THICKNESS IS 6". REINFORCED W6.5X26.5 @ 6in O.C. E.W. UNLESS NOTED OTHERWISE
- SHEET INDEX:


GENERAL STRUCTURAL NOTES	000
FOOTING SCHEDULE	S601
COLUMN SCHEDULE	S601
BEAM SCHEDULE	S601
TYPICAL DETAILS	S601

No.	Description	Date

**ORLANDO WEST
FIRE STATION
BASEMENT
FOUNDATION PLAN**

Project number	5226
Date	Issue Date
Drawn by	Author
Checked by	Checker
S101	
Scale	3/32" = 1'-0" 23





- FOUNDATION PLAN NOTES**
1. FINISH FLOOR ELEVATION IS 100'-0" (RELATIVE TO DATUM 100'-0").
 2. TOP OF CONCRETE SLAB IS FINISH FLOOR UNLESS SHOWN OTHERWISE.
 3. TYPICAL CONCRETE SLAB THICKNESS IS 6". REINFORCED W/ 6x6 @ 6 in O.C. E/W UNLESS NOTED OTHERWISE.
 4. SHEET INDEX:

GENERAL STRUCTURAL NOTES	000
FOOTING SCHEDULE	S601
COLUMN SCHEDULE	S601
BEAM SCHEDULE	S601
TYPICAL DETAILS	S501, S502, S503

- FLOOR FRAMING PLAN NOTES**
1. TOP OF SLAB ELEVATION (RELATIVE TO DATUM 100'-0") IS:
 - REGION B ROOF HEIGHT 115'-0"
 - REGION A AND C ROOF HEIGHT 120'-0"
 2. TOP OF CONCRETE SLAB IS FINISH FLOOR UNLESS SHOWN OR NOTED OTHERWISE.
 3. SLAB THICKNESS IS 2" NORMAL WEIGHT CONCRETE REINFORCED WITH ONE LAYER OF W14/W14 @ 6x6 IN O.C. ON 3' COMPOSITE DECK UNLESS NOTED OTHERWISE.
 4. SHEET INDEX:

GENERAL STRUCTURAL NOTES	000
SCHEDULES	S601
TYPICAL DETAILS	S501, S502, S503

1 Foundation Plan
3/32" = 1'-0"

No.	Description	Date

**ORLANDO WEST
FIRE STATION
FOUNDATION PLAN**


Project number 5226
Date Issue Date
Drawn by Author
Checked by Checker

S102

Scale As indicated



4/30/2021 4:17:59 PM



- ROOF FRAMING PLAN NOTES**
1. TOP OF ROOF STRUCTURE IS SLOPED FOR DRAINAGE. SEE ELEVATIONS NOTED ON PLAN.
 2. UNLESS NOTED OTHERWISE, STEEL FRAMING SHALL BE CENTERED ON AND EQUALLY SPACED BETWEEN COLUMN CENTERLINES.
 3. GABLE FRAMING AND SPACE FRAME SYSTEMS ARE SEPARATED WITH DISTINCT LFRS.
 4. SHEET INDEX:

GENERAL STRUCTURAL NOTES	000
SCHEDULES	S501, S502,
TYPICAL DETAILS	S503

1 Framing Plan
3/32" = 1'-0"

No.	Description	Date


**ORLANDO WEST
FIRE STATION
ROOF FRAMING
PLAN**

Project number	5226
Date	Issue Date
Drawn by	Author
Checked by	Checker

S103

Scale	3/32" = 1'-0"
-------	---------------





No.	Description	Date

**ORLANDO WEST
FIRE STATION
WALL SECTION**


Project number 5226
 Date Issue Date
 Drawn by Author
 Checked by Checker

S401


Scale 3/4" = 1'-0"

1 Wall Section
3/4" = 1'-0"


4/5/2021 4:18:02 PM




1 COLUMN TO BASE PLATE DETAIL
1" = 1'-0"



2 FOUNDATION AT INTERIOR LOAD BEARING WALL
1" = 1'-0"



3 STEM WALL AT CURTAIN WALL
1" = 1'-0"



4 SLAB THICKNESS TRANSITION
1" = 1'-0"


No.	Description	Date

ORLANDO WEST
FIRE STATION
FOUNDATION
DETAILS


Project number 5226
 Date Issue Date
 Drawn by Author
 Checked by Checker

S501


Scale 1" = 1'-0"




1 COMPOSITE BEAM TO MASONRY WALL
1" = 1'-0"



2 COMPOSITE SLAB TO SLAB ON GRADE
DETAIL
1" = 1'-0"



3 COMPOSITE SLAB TO MASONRY WALL
1" = 1'-0"



4 INTERIOR RETAINING WALL DETAIL
1" = 1'-0"

No.	Description	Date


ORLANDO WEST FIRE STATION FLOOR DETAILS

Project number	5226
Date	Issue Date
Drawn by	Author
Checked by	Checker


S502

Scale 1" = 1'-0"



- NOTES:
- 1 BOLTS ARE ASTM A325N AND WELDS E70xx U.N.O.
 - 2 BEAM CONNECTIONS ARE STANDARD UNLESS DENOTED BY AN ASTERISK (*) ON PLAN ELEMENTS ARE SPLICED DURING FABRICATION TO ENSURE ACCURACY.




1 SIMPLE SPLICE CONNECTION
1" = 1'-0"



2 SIMPLE FIN CONNECTION
1" = 1'-0"



3 BEAM RIGID CONNECTION
1" = 1'-0"



4 MOMENT CONNECTION WITH THERMAL BREAK
1" = 1'-0"


No.	Description	Date

ORLANDO WEST FIRE STATION ROOF DETAILS


Project number	5226
Date	Issue Date
Drawn by	Author
Checked by	Checker

S503


Scale	1" = 1'-0"
-------	------------



1 N. ELEVATION SHEAR WALLS
1/8" = 1'-0"



3 BEAM TO SHEAR WALL CONNECTION
1" = 1'-0"



2 N. ELEVATION SHEAR WALLS - Callout 1
1/4" = 1'-0"

No.	Description	Date

ORLANDO WEST
FIRE STATION
LFRS DETAILS

Project number	5226
Date	Issue Date
Drawn by	Author
Checked by	Checker

S504
Scale As indicated

4/20/2024 4:16:05 PM

SLAB SCHEDULE				
MARK	DEPTH	FEXURAL REINFORCING	TEMPERATURE REINFORCING	NOTES
S1	6"	NA	W6.5X6.5 @ 6in O.C.	
S2	8"	NA	W9XW9 @ 6 in O.C.	
S3	2"	NA	W1.4XW.14 @ 6in O.C.	COMPOSITE

- Notes:
- 1) Slabs are designed for one layer of reinforcing
 - 2) Refer to S501 foundation details for placement of reinforcing in slab
 - 3) Refer to details for reinforcement transition between slabs

COLUMN AND FOOTING SCHEDULE					
ELEMENT	COLUMN	BASE PLATE DIMENSIONS	FOOTING DIMENSIONS	REINFORCEMENT	DEPTH OF FOUNDATION
C1	HSS6X6X4	12"x12"x1/2"	4'-0" X 4'-0" X 1'-4"	#6 @ 14" o.c.	2'-6"
C2	HSS8X8X4	14"x14"x1/2"	4'-0" X 4'-0" X 1'-4"	#6 @ 14" o.c.	2'-6"
C3	HSS9X9X4	15"x15"x1/2"	4'-0" X 4'-0" X 1'-4"	#6 @ 14" o.c.	2'-6"
C4	HSS14X0.5	20"x20"x0.5"	6'-0" X 6'-0" X 2'-0"	#8 @ 9" o.c.	3'-6"
C5					

- Notes:
- 1) Refer to S501 for Foundation Details

WALL AND STRIP FOOTING SCHEDULE						
ELEMENT	MASONRY WALL	STEM WALL WIDTH	REINFORCEMENT	FOOTING DIMENSIONS	REINFORCEMENT	DEPTH OF FOUNDATION
W1	12" CLAY BRICK #6 bars and groutig @16" o.c.	12"	#5 @ 12" o.c.	4'-0" X 1'-4"	#4 @ 8" o.c.	14'-10"
W2	12" CLAY BRICK #6 bars and groutig @16" o.c.	12"	#5 @ 12" o.c.	4'-0" X 1'-0"	#4 @ 11" o.c.	9'-6"
W3	8" CLAY BRICK #5 bars and groutig @32" o.c.	12"	#5 @ 12" o.c.	4'-0" X 1'-4"	#4 @ 8" o.c.	14'-10"
W4	8" CLAY BRICK #5 bars and groutig @32" o.c.	8"	#4 @ 12" o.c.	4'-0" X 1'-0"	#4 @ 11" o.c.	4'-6"
W5	-	8"	#4 @ 12" o.c.	4'-0" X 1'-0"	#4 @ 11" o.c.	4'-6"
W6	-	12"	#5 @ 12" o.c.	4'-0" X 1'-4"	#4 @ 8" o.c.	14'-10"

- Notes:
- 1) Refer to S501 for Foundation Details
 - 2) W4 at slab perimeter where there is no exterior structural wall
 - 3) W6 basement wall below slab on grade with no structural wall above

DEVELOPMENT LENGTH (in)				
BAR		#4 BAR	#5 BAR	#6 BAR
DEV. LENG.	ld	11.4	14.8	29
DEV. HOOK	ldh	7.6	9.9	15
HOOK DIA	dh	3	3.9	6
HOOK EXT.	l _{ext}	2.5	2.6	9

No.	Description	Date


**ORLANDO WEST
FIRE STATION
SCHEDULES**

Project number	5226
Date	Issue Date
Drawn by	Author
Checked by	Checker



S601

Scale _____

Windward and Leeward Wind forces
In relative +X (transverse) and +Y (longitudinal) directions



Windward and Leeward Wind Forces
In relative -X (transverse) and -Y (longitudinal) directions



No.	Description	Date



ORLANDO WEST FIRE STATION WIND DIAGRAMS

Project number: 5226
 Date: Issue Date
 Drawn by: Author
 Checked by: Checker

S602

Scale: _____

4/30/2021 4:18:06 PM




ORLANDO WEST FIRE STATION SEISMIC DIAGRAMS

Project number	5226
Date	Issue Date
Drawn by	Author
Checked by	Checker

S603

Scale



ROOF FORM IS AN ASYMETRIC GABLE ROOF WITH INTERSECTING PERPENDICULAR ASYMETRIC GABLES

No.	Description	Date

**ORLANDO WEST
FIRE STATION
STRUCTURAL
AXONOMETRIC**

Project number	5226
Date	Issue Date
Drawn by	RDempewolf
Checked by	Checker

S901

Scale