

FPE 596 Culminating Project
Warren J. Baker Center for Science and Mathematics
California Polytechnic State University, San Luis Obispo Campus

Matthew Hudson



Disclaimer

This project report is a result of a class assignment; it has been graded and accepted as fulfillment of the course requirements. Acceptance of this report in fulfillment of the course requirements does not imply technical accuracy or reliability. Any use of information in this report is done at the risk of the user. These risks may include, but may not be limited to, catastrophic failure of the device or infringement of patent or copyright laws. California Polytechnic State University at San Luis Obispo and its staff cannot be held liable for any use or misuse of the project.

Key words:

Warren J. Baker Center for Science and Mathematics, California Polytechnic State University, San Luis Obispo, Cal Poly, Fire Protection Engineering, life safety, sprinkler system, fire suppression, fire alarm, structural fire protection, smoke control, performance based design, design fire, NFPA 13, NFPA 14, NFPA 20, NFPA 25, NFPA 70, NFPA 72.

Index

| | |
|--|-----|
| Abstract | 4 |
| Introduction | 6 |
| Background | 6 |
| Layout | 7 |
| Prescriptive Analysis | 14 |
| Life Safety | 15 |
| Fire Suppression | 21 |
| Fire Alarm System | 33 |
| Structural Fire Protection | 41 |
| Smoke Control System | 46 |
| Performance Based Review | 49 |
| Design Fire 1 | 51 |
| Design Fire 2 | 59 |
| Recommendations | 66 |
| Conclusion | 67 |
| References | 68 |
| Appendix A - Life Safety Drawings | 69 |
| Appendix B - Hydraulic Egress Calculations | 76 |
| Appendix C - Hydraulic Calculations | 78 |
| Appendix D - Sprinkler System Drawings | 278 |
| Appendix E - Fire Alarm Drawings | 307 |
| Appendix F - Smoke Extraction Calculations | 331 |

Abstract

The purpose of this report is to analyze the Warren J Baker Center for Science and Math on the California Polytechnic State University, San Luis Obispo campus. Baker Science is primarily used for classroom and laboratory instruction of college students, with study spaces, faculty offices, and assembly spaces. There are mechanical, electrical, and storage spaces ancillary to the main building functions. The building comprises six floors that are between 23,000 and 44,000 ft². The first floor contains classrooms, faculty offices, mechanical/electrical spaces, and an auditorium with fixed seating. An atrium connects floors two through five. There are walkways running down the center of the atrium with openings on both sides. These floors all contain a mix of classrooms, laboratories, faculty offices, study spaces, and supporting mechanical, electrical, and storage rooms.

The prescriptive analysis of the Baker Science building determines if the building construction complies with the applicable codes and standards. These codes and standards cover life safety, fire suppression, fire alarm and detection, and structural requirements. The life safety section analyzes the ability of the building to safely evacuate occupants in a timely manner. This is accomplished with code-specified stair and door widths, exit locations, and exit fire rating requirements. The building is protected throughout with an automatic wet pipe sprinkler system, fed from a fire pump on the first floor. The fire pump is supplied from a city water loop to the north of the building. All sprinklers in the building are quick response K-5.6 sprinklers. The fire suppression system activates the fire alarm system in the event of a fire. The alarm system can also be activated with smoke alarms, heat alarms, and manual pull stations. The generation of any part of the fire alarm system in the atrium will activate the passive smoke control system. This system opens roof vents that allow smoke to escape, and also opens doors at the bottom of the atrium to provide makeup air. Doors to the wings of the building are released and closed to reduce the travel of smoke to the east and west wings. The structural fire protection codes provide occupancy separation requirements, and limit building height and area based on construction type.

The performance based analysis seeks to determine how well the building systems can handle a real-life fire scenario, with a focus on building occupants being able to safely evacuate the building in the event of a fire. The ability to safely exit the building is based upon the requirement for tenability to be maintained in the egress route for the entire time it takes for evacuation to be completed. The performance analysis in this report centers around two design fires: one in the atrium, and one in the lobby outside the assembly space. The design fires represent scenarios that would challenge the fire protection capabilities of the building, while still having a probability of occurring. Small fires or fires in unoccupied spaces were not analyzed since they would be unlikely to test the limits of the building's fire protection systems. The design fire in the atrium exposed occupants to smoke and combustion products, and activated the atrium smoke control system. The smoke venting was inadequate to remove the smoke created by this design fire, resulting in smoke accumulation that limited the visibility of occupants egressing on the sixth floor. The available safe egress time is 3.23 min after ignition, based on the minimum visibility of 4 m being lost on the sixth floor, while that floor has a required safe egress time of 3.96 min. The design fire in the lobby outside the auditorium also exposed occupants to smoke, limiting visibility. The available safe egress time in the lobby is 2.00 min, at which point the 13 m visibility limit is

no longer maintained. The required safe egress time is 8.64 min from the time of ignition, significantly longer than the time available to occupants.

Prescriptive analysis of the Baker Science building determined that the building was adequately built to the relevant life safety and fire codes. The performance based analysis discovered some shortcomings in the building design. These faults were primarily centered around tenability time for evacuating occupants in the building. On the sixth floor in the atrium, occupants experienced reduced visibility that could impede their ability to safely find the exits and safely escape. The cause of the reduced visibility was the buildup of smoke from the fire, which in turn was caused by inadequate smoke removal by the smoke control system. As a passive system without fans, the smoke can only be removed at a limited rate. One solution to this would be to install additional passive smoke vents. A better solution would be to install powered smoke vents with a rating capable of evacuating adequate smoke from a challenging design fire. Inadequate visibility was also the conclusion of the second design fire. The tall ceiling outside the auditorium filled with smoke, limiting the visibility of evacuating occupants. Installing smoke control capability in the lobby could remedy this deficiency. An easier solution would be to install doors in the auditorium that do not egress into the lobby. This would allow auditorium occupants to avoid the smoke entirely, while reducing the congestion in the lobby for people evacuating from other parts of the first floor. The Baker Science building serves as an example of properly executed code implementation, with failings that can be exposed with demanding design fires.

Introduction

The goal of this report is to perform an analysis of the fire protection systems in the Baker Science building on the Cal Poly campus. Various aspects of building construction and design will be evaluated for prescriptive design, including life safety, fire suppression, fire alarm, and structural design. The building construction documents will be compared to applicable building and fire protection codes to determine if the requirements are achieved. Additionally, a performance based analysis will be conducted with two design fires to determine how well the building would achieve life safety goals in the event of real fire scenarios. This report will present a summary of relevant code sections and how the building complies with them, performance based analysis scenarios and conclusions, and recommendations based on these.

Background

The Warren J. Baker Center for Science and Mathematics (Building 180) was constructed in 2013 to serve the expanding needs of the Cal Poly campus. The building contains classrooms, lecture halls, science laboratories, faculty offices, study spaces, and mechanical/electrical rooms. The new building was necessary to replace Building 52, also known as the “spider building,” which was built in the 1940’s. Building 52 was not large enough for a growing campus, and lacked modern technology commonly used in science labs today. Figures 1 and 2 show different views of the exterior of the building.



Figure 1. West side of Baker Science with first floor entrance.



Figure 2. South side of Baker Science.

Layout

Baker Science has six separate floors, although no part of the building is more than five stories tall, due to being built on a hill. The first floor of the building has a large auditorium, some classrooms, and faculty offices. There are also mechanical/electrical spaces on the first floor. The first floor has one main entrance with three double doors, the vast majority of the traffic into and out of the first floor is through here. Design Fire 2 was chosen due to the proximity to the primary exit and to a large occupancy auditorium. A large fire near a familiar exit would force people to find secondary exits. The ceiling above the lobby in this space is 37 ft tall, extending to the third floor. The height of the ceiling would delay the time to sprinkler activation, allowing the fire to grow larger than a fire in a smaller space.

Floors two through six are connected by a two-sided atrium that is split by a walkway. This atrium is a major fire concern for this building, and is the focus of Design Fire 1. There are two major exits to the second floor on opposite sides of the atrium. Halls extend east and west from the main lobby, providing additional ground-level exits.

The third floor has a similar footprint as the second floor, but has a walkway separating the two sides of the atrium, and no ground level exits. There are two exit stairs in the atrium: the southern one is enclosed by walls, and the northern one is open to the atrium. Floors three through six all have stairs on the east wing. The third floor has two stairs on the west wing and the fourth floor has one stair on the west wing. There is no west wing for floors five and six. Floors four through six have comparable layouts to the third floor, except each subsequent floor does not extend as far to the west (above the first floor). The smaller footprints of the higher floors keep any part of the building from being greater than five stories tall. Floor layouts are shown in Figures 3 through 9, with more detail of occupancy and exits shown in Appendix A. Exit doors in these images are circled in red and stairways are highlighted in red.




Figure 3. First floor.




Figure 4. Second floor.




Figure 5. Third floor.




Figure 6. Fourth floor.




Figure 7. Fifth floor.




Figure 8. Sixth floor.




Figure 9. Roof.

Prescriptive Analysis

Codes Used

The following codes were used for the construction of this building:

- CBC, California Building Code, 2007
- NFPA 13, Standard for Installation of Sprinkler Systems, 2007
- NFPA 14, Standpipe and Hose Systems, 2004
- NFPA 20, Stationary Pumps for Fire Protection, 2003
- NFPA 25, Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems, 2002
- NFPA 70, National Electric Code, 2005
- NFPA 72, National Fire Alarm and Signaling Code, 2007

Life Safety

Exit Considerations

Each space and floor is required to have an egress capacity greater than the rated occupancy. To calculate egress capacity, exit door and stair widths need to be known. Occupancy rating is based on occupancy load factor and area of each space. For an entire floor of a building the occupancy rating for each space is added to arrive at the total occupancy for the floor. The exits for each floor in the building and the calculated egress capacity are listed below. CBC 1005.3.1 requires an egress capacity for stairs of 0.2" of width per occupant in a sprinklered building with an emergency voice/alarm system. CBC 1005.3.2 gives an egress capacity for components other than stairs (such as doors) of 0.15" per occupant in a sprinklered building with an emergency voice/alarm system. Stairs 1, 2, 4, and 5 have a tread width of 3' 11", and stair 3 has a width of 3' 6". Stair 2 is not included as an exit, as it is exposed to the atrium and does not comply with the requirements of a protected means of egress. All doors leading to and from the stairs are 36" wide, with a clear width of 33.5". An example egress calculation for each is shown below for Stair 1:

$$\text{Stair: } C = \frac{47''}{.2''/\text{person}} = 235 \text{ people}$$

$$\text{Door: } C = \frac{33.5''}{.15''/\text{person}} = 223 \text{ people}$$

For stairs 1, 4, and 5, the door is the more limiting factor, with 223 people. For stair 3, the narrower stair is the more limiting means of egress, with a capacity of 210 people. The more limiting value is always used to calculate egress capacity where there are two or more implements of egress in a row. Formula 7.3.3.1 will be used for doors of all widths for the building. The exit data calculation results are summarized below.

1st floor

Independent exit path, not connected to other floors except elevators.

Main exit, 3x63"

Stairway exit door, 34.5"

95" doors by mechanical room

Egress capacity for the floor: 1928

2nd floor

Atrium: 4x70", north and south

Two 69" exits on north side of east wing

69" exit on south side of west wing

Two 33.5" doors to stairways in west wing

34.5" door from 261

Egress capacity for the floor: 2878

3rd floor

34.5" door to 47" stair on east, center, and two to the west

Egress capacity for the floor: 720

4th floor

34.5" door to 47" stair on east, center, and west

Egress capacity for the floor: 680

5th floor

34.5" door to 47" stair on east and center

Egress capacity for the floor: 453

6th floor

34.5" door to 47" stair on east and center

Egress capacity for the floor: 453

Roof

34.5" door to 47" stair

Egress capacity for the floor: 235

Color-coded map

Submitted with this report is a color-coded map of the various spaces, shown in Appendix A. A campus PDF map was obtained, then highlighted to show the use assigned to each space in the building. Exit doors were circled in red. A legend for the color-coded occupancy uses is shown in Figure 10.



Figure 10. Map color legend.

Occupancy and Exit Capacity

The main uses of the building are classroom, lab, storage, office, and assembly. Table 1 summarizes occupancy, floor exit capacity, and number of exits for each floor of the building. Notice that the exit capacity of each floor exceeds the rated occupancy. The egress data for each individual space was also calculated, and every room and space in the building has adequate egress capacity for its occupancy.

Table 1. Summary of area, use, occupancy, exit capacity, and number of exits.

| Floor | Area (ft ²) | Uses | Occupancy | Exit capacity | No of exits | Req no of exits |
|-------|-------------------------|------------------------------|-----------|---------------|-------------|-----------------|
| 1 | 23146 | Assembly, mech/elec, storage | 639 | 1982 | 5 | 3 |
| 2 | 43458 | Business, storage, assembly | 524 | 3840 | 8 | 3 |
| 3 | 43209 | Business, storage, assembly | 701 | 879 | 4 | 3 |
| 4 | 33307 | Business, storage, assembly | 464 | 656 | 3 | 2 |
| 5 | 25294 | Business, storage, assembly | 263 | 433 | 2 | 2 |
| 6 | 19958 | Business, storage, assembly | 251 | 433 | 2 | 2 |
| Roof | 20236 | Mech/elec | 6 | 223 | 1 | 1 |

Arrangements of Exits

Business and assembly spaces or rooms with greater than 49 occupants must have more than one exit, from CBC Table 1006.2.1. CBC Table 1006.3.1 requires storeys with occupancy up to 500 to have two exits, occupancy between 501 and 1000 to have three exits, and greater than 1000 to have four exits. Table 1 above shows the required and actual number of exits for each floor of the building. Baker Science was designed with an adequate number of exits for all spaces and floors. Per CBC 1007.1.1, the minimum separation distance between exits (in a sprinklered space) shall not be less than one third the maximum diagonal distance of the space. For all of the spaces that require more than one exit, the exits are arranged to exceed the minimum required distance of one third the building diagonal measurement. This minimum spacing is achieved for all individual rooms, such as the auditorium on the first floor, all labs and classrooms, and the entire stories as a whole. A summary of storey diagonal distance, required exit spacing, and actual spacing is shown in Table 2.

Table 2. Exit spacing data.

| Floor | Diagonal Distance (ft) | 1/3 Diagonal distance (ft) | Exit spacing (ft) |
|-------|------------------------|----------------------------|-------------------|
| 1 | 248 | 83 | 160 |
| 2 | 481 | 160 | 413 |
| 3 | 481 | 160 | 451 |
| 4 | 407 | 136 | 344 |
| 5 | 248 | 83 | 220 |
| 6 | 248 | 83 | 220 |

Dead Ends and Travel Distances

Per CBC Table 1017.2, the total travel distance limit for a sprinklered business occupancy is 300 ft. This limit is not reached anywhere in the building. Table 1006.2.1 provides limits for common paths of travel. In a sprinklered business occupancy, the limit is 100 ft. This limit is approached (~96 ft) on the fourth, fifth, and sixth floors near the office areas, but is not exceeded. The maximum dead end travel distance in sprinklered business occupancies is 50 ft, from CBC 1020.4. This limit is exceeded by 3' on the east side of the second floor, as shown in Figure 11.




Figure 11. Dead end travel distance is exceeded on the second floor.

Fire Ratings

This building has fire rated walls to meet a variety of code requirements. The east and west wings of the building are separated from the atrium with horizontal exits. These horizontal exits create control areas, which require 2 hour fire separation, per CBC 414.2.4. The vertical exit enclosures require two hour fire ratings, in accordance with CBC 1020.1, since Baker Science is more than four storeys tall. Examples of these fire ratings are shown in Figure 12 with the horizontal exits highlighted in red and the vertical exit highlighted in green. Individual occupancies need to be separated from adjacent occupancies per CBC Table 508.3.3. A one hour fire rating is required between business, assembly, storage, and high hazard group occupancies. Baker Science complies with all required fire rating requirements for exits and occupancy separation.




Figure 12. Example of fire ratings separating control areas (red) and area of refuge (green).

Exit Signs

Marking of means of egress is required by CBC 1013.1. Placement of exit signs is important to help people unfamiliar with the building safely escape during a fire, and for people trying to find a safe exit path in heavy smoke. This section of the code states that an exit sign must be visible from 100 ft or less in an exit passageway. These exit signs must be illuminated at all times. The farthest distance from an

exit sign is in the east wings of floors three and six. Two exit signs in the corridors are 173 ft apart, so standing halfway between the signs is 86.5 ft from the nearest sign.

Occupancy Characteristics

This building will serve students and faculty in lab, classroom, and office settings. There are also storage, mechanical, electrical, and service spaces. These spaces will primarily be used by the building staff. The people who use the building will likely be familiar with the layout, aiding in their ability to evacuate efficiently if necessary.

Since most of the capacity consists of classrooms and labs, students are expected to comprise most of the people in the building. If a fire were to occur, they would likely be led to evacuate by a professor. Many of the students would take the time to pick up their notes, computers, and backpacks. Cluttered aisles between desks could create tripping hazards and slow egress slightly. The laboratories could have open flames or experiments with dangerous chemicals. Students and faculty may need to place their work in a safe condition prior to leaving the room. This is another factor that could delay egress time by a minute or two.

Students or faculty working on computers may take time to save work to a flash drive or the internet prior to evacuating. This is due to experience with false fire alarms, and perceived value for their work. Saving work prior to leaving could delay a person by a couple of minutes.

Pre-movement Response

There are many ways occupants could be alerted to a fire. The way most occupants of a building would be alerted would be audible, in the form of a fire alarm. Other audible methods would be hearing someone shout "fire" if they were the one to discover it. A large number of people evacuating would cause a commotion that could likely be heard. The fire alarm system also includes strobes that would provide visual cues for people who are hard of hearing or listening to headphones. Another way occupants could discover the fire would be through heat or smell. These would likely occur if the fire started in an unoccupied space.

Once it has been established that there is a fire, people in the building need to evacuate. In some buildings (such as a movie theater) occupants only enter through one door. As a result, they are more likely to use the same door to exit. In a school building, students and professors know that there are multiple entrances/exits, and likely use different ones depending on where they are traveling from or to. This increases the odds that people exiting will use the closest unobstructed exit instead of leaving through a main exit they typically use.

Egress Time

A reliable estimation of egress time is necessary to determine if tenability will be maintained in occupied spaces for a given design fire. A second order hydraulic calculation was performed to determine the time occupants would need to egress from the Baker Science building when it was at rated occupancy. For this calculation it was assumed the occupants would exit through the stairway in the section of the building where they were when the alarm sounded. The building is separated into three sections: the west wing, the atrium, and the east wing. An egress calculation was performed for each section since

this calculation assumes the egress of each will occur separately. A summary of egress times is shown in Table 3, with a detailed hydraulic egress calculation provided in Appendix B. Some parts of the table are left blank where that floor of the building does not have that section of the building. Also note that floors 2 and 3 for the east wing, and the first floor of the west wing are independent of egress from higher floors, yielding a lower egress time. The time for the entire building to be evacuated is 13.62 minutes.

Table 3. Summary of egress times from different parts of Baker Science.

| | West Wing | | Atrium | | East Wing | |
|-----|------------------|--------------------------|------------------|--------------------------|------------------|--------------------------|
| | Time to evacuate | Time to reach next floor | Time to evacuate | Time to reach next floor | Time to evacuate | Time to reach next floor |
| 6th | | | 1.79 | 2.12 | 4.56 | 4.93 |
| 5th | | | 3.18 | 3.51 | 8.64 | 9.02 |
| 4th | 4.46 | 4.84 | 4.51 | 4.85 | 13.25 | 13.62 |
| 3rd | 7.71 | 8.09 | 7.74 | 8.08 | 5.40 | |
| 2nd | 9.52 | 10.04 | 8.66 | | 2.61 | |
| 1st | 5.07 | | | | | |

Egress time is calculated starting when occupants begin to move. To determine the time from ignition of the fire to total evacuation, time to alarm and pre-movement time must also be included. Time to alarm is dependent on the specific fire scenario, and the SFPE Handbook can provide an estimate of pre-movement time. The SFPE Handbook provides estimated pre-movement times for various types of buildings. The building type that most closely represents Baker Science is a high-rise office building. While Baker Science narrowly misses the definition of a high-rise building, the occupants would be familiar with the building, and it would typically be occupied during working hours. Table 64.4 provides a pre-movement time of 1.2 minutes for a high-rise building.

The primary purpose of the life safety analysis is to ensure occupants can safely exit the building in the case of an emergency. In order to accomplish this, occupants must be able to find and traverse through exits in a timely manner. The Baker Science building can be completely evacuated in less than 14 minutes in the event of a fire. Exit signage will efficiently lead people to the nearest exit, which needs to have sufficient capacity, based on door and stair width. Baker Science meets or exceeds the life safety requirements of the California Building Code. Proper quantity and locations of exits will allow egress to occur in a timely manner. Safe egress time can be extended by reducing growth rate and size of a fire through automatic suppression.

Fire Suppression

System Description

The Baker Science building contains wet pipe sprinklers throughout the entire building. The whole building is sprinklered from a single wet pipe sprinkler riser which is fed from a fire pump. NFPA 13 8.2.1 gives a maximum floor area limit that can be protected by one sprinkler zone of 52,000 ft² for light and ordinary hazard occupancies. The second floor has the greatest area at 43,458 ft², allowing the building

to be served by a single sprinkler riser. Four standpipes, located in the egress stairwells, deliver water to the upper floors. A fire pump, located on the first floor, is provided due to the height of the building.

Water Supply

The fire protection water supply comes from a looped domestic water main to the north of the building. There were two hydrant flow tests performed, one with flow from hydrant #63 and static pressure from hydrant #64, and another test with flow from hydrant #64 and static pressure from #63. The locations of the fire loop and hydrants #63 and #64 are shown in red on Figure 13, with the Baker Science Building outlined in Blue. The results of the flow tests are shown in Figures 14 and 15. Hydrant #63 is located much closer to the supply main for Building 180 and was selected for the hydraulic calculations as a result. Figure 16 shows the city water supply curve for the building, adjusted for the height of the pump inlet. In order to be conservative, the test pressures were reduced by 10% when performing sprinkler system calculations.




Figure 13. Location of test hydrants.

| Flowing Hydrant(s) | Concurrent Flow | | | Residual Hydrant | |
|-------------------------|-----------------|---------|---------|-------------------------|-----------|
| | # 1 | # 2 | # 3 | | |
| Hydrant # | 64 | | | Hydrant # | 63 |
| Static Pressure (psi) | 63 | | | Static Pressure (psi) | 60 |
| Test Gauge # | 2 | | | Residual Pressure (psi) | 55 |
| Pitot Pressure (psi) | 35 | | | Test Gauge # | 1 |
| Test Gauge # | 1a | | | Tested by | R.Ellison |
| Nozzle Size (inches) | 2.5 | | | | |
| Nozzle Coefficient | | | | | |
| Hydrant Flow (gpm) | 914 | | | | |
| Tested by | R.Ellison | | | | |
| Projected Flow @ 20 psi | 2270.288 | #DIV/0! | #DIV/0! | | |

Figure 14. Hydrant flow test, hydrant #63.

| Flowing Hydrant(s) | Concurrent Flow | | | Residual Hydrant | |
|-------------------------|-----------------|---------|---------|-------------------------|-----------|
| | # 1 | # 2 | # 3 | | |
| Hydrant # | 63 | | | Hydrant # | 64 |
| Static Pressure (psi) | 64 | | | Static Pressure (psi) | 63 |
| Test Gauge # | 2 | | | Residual Pressure (psi) | 58 |
| Pitot Pressure (psi) | 40 | | | Test Gauge # | 1 |
| Test Gauge # | 1a | | | Tested by | R.Ellison |
| Nozzle Size (inches) | 2.5 | | | | |
| Nozzle Coefficient | | | | | |
| Hydrant Flow (gpm) | 974 | | | | |
| Tested by | R.Ellison | | | | |
| Projected Flow @ 20 psi | 2862.1147 | #DIV/0! | #DIV/0! | | |

Figure 15. Hydrant flow test, hydrant #64.




Figure 16. Building water supply curve.

The domestic water loop connects to the building with an 8" cement lined ductile iron pipe. The fire water system is separated from the city water main with a backflow preventer. NFPA 13 requires fire water systems to be isolated from the water main to prevent contamination of drinking water. This sprinkler system uses a Wilkins 350ADA double check detector assembly. This consists of two check valves with isolation valves on either side. The isolation valves are 8" OS&Y valves, and have tamper monitor switches that connect to the fire alarm system. The tamper monitors activate a supervisory condition at the fire alarm control unit if either of the isolation valves is moved from the open position. This is important since one of these valves being shut would prevent the sprinkler system from operating in the event of a fire. One design consideration when using backflow preventers is the pressure loss across the check valves. This is dependent on the system waterflow and the size of the backflow preventer. This pressure loss needs to be included in the hydraulic calculations in order for them to provide an accurate representation of available system flow. Figure 17 is the double check assembly installed in the building water supply, and Figure 18 is the double check assembly pressure loss graph. This double check assembly is installed above ground due to the moderate temperatures experienced in San Luis Obispo. In a climate with freezing weather the backflow preventer would most likely be installed in the building, in a heated space.




Figure 17. Double check assembly.




Figure 18. Pressure loss based on flow for Wilkins 350ADA backflow preventer.

Fire pump

The height of the building combined with the available water supply necessitates a fire pump. The pump is located on the first floor in the fire riser room. The pump is a Peerless 6PVF10 electric fire pump. Each storey in the Baker Science building is 16 ft, meaning the 6th floor ceiling is 80 ft higher than the 1st floor ceiling. In order to supply water to the sixth floor, an additional 34.6 psi is required to supply water compared to the first floor. $P = \left(\frac{80 \text{ ft}}{0.433 \text{ psi/ft}} \right) = 34.6 \text{ psi}$. When a sprinkler opens, releasing water, a pressure switch at the discharge of the pump senses the difference in pressure and activates the fire pump. To maintain pressure at the discharge of the fire pump a pressure maintenance pump, commonly called a “jockey pump,” is provided in parallel to the fire pump. Small decreases in pressure due to system leaks will trigger the pressure maintenance pump to activate and increase the pressure in the sprinkler piping. The pressure maintenance pump has a much smaller capacity than the fire pump and can activate and deactivate itself with the pressure switch. The jockey pump activates at 155 psi and deactivates at 165 psi, but the fire pump does not activate until pressure reaches 150 psi. This ensures pressure in the sprinkler piping is normally maintained by the jockey pump. The fire pump deactivates at 191 psi to ensure the piping does not become overpressurized. The Peerless pump curve is shown in Figure 19, and a summary of pump pressure settings is provided in Figure 20.




Figure 19. Peerless pump flow curve.

FIRE PUMP SETTINGS :

- FIRE PUMP MAXIMUM CHURN = 191 PSI
- JOCKEY PUMP STOP = 165 PSI
- JOCKEY PUMP START = 155 PSI
- FIRE PUMP START = 150 PSI

Figure 20. Fire pump and pressure maintenance pump setpoints.

Standpipes

Standpipes are provided in this building in accordance with NFPA 14, Standard for Installation of Sprinkler Systems. A standpipe is installed in each egress stairway, with a fire hose valve on each landing of the egress stair. The standpipe in stair 1 has a 6" pipe, and has a fire hose valve on the roof of Baker Science. Stair 3 is fully enclosed and also has a 6" standpipe. There is also a fire hose connection valve in the roof dog house at the top of stair 3. Stair 4 has a 4" standpipe with a hose valve on the roof, even with level 5. Stair 5 is not enclosed, and has a 4" standpipe. It does not extend to the roof. Figure 21 shows the locations of the standpipes in Baker Science. The standpipe system is capable of supplying a total of 1000 gpm, with 500 gpm at 100 psi at the highest outlets. A plot of standpipe demand pressure

is shown in Figure 22, where the fire pump supplies 1000 gpm at 143.7 psi. Hydraulic calculations were performed for the standpipes and are shown in Appendix C.



Figure 21. Building layout with standpipes.




Figure 22. Standpipe pressure demand plot for calculation #5, highlighted in red.

Commodity Classification

The biggest hazard in this building are the laboratories with chemicals in them. Chapter 22 of NFPA 13 determines the hazard classification of labs based on the laboratory class as defined in NFPA 45. NFPA 45 4.2.2.2 states that educational laboratory units shall be classified as Class D. NFPA 13 22.8.1 (2) says that Class C and D laboratories shall be classified as ordinary hazard (Group 1). The design criteria for ordinary hazard (Group 1) is 0.15 gpm/ft² over 1500 ft², from Figure 11.2.3.1.1 of NFPA 13. The quick response sprinklers used in this building allow for a reduction of area in accordance with 11.2.3.2.3.1 of NFPA 13. The reduction is 40% for ceilings 10 ft tall, giving a design area of $1500 \text{ ft}^2 * 60\% = 900 \text{ ft}^2$.

System Design Area

The sprinkler system designers used many different design areas to show the water supply was adequate for the sprinkler systems in this building. Many of the calculated design areas are on the sixth floor.

The highest calculated demand area, labeled 6-4, is in the atrium outside the faculty offices. The calculated area is 1500 ft² and light hazard, 0.10 gpm/ft². The total demand for this area is 347 gpm at 117 psi at the base of the riser. The sprinkler designers did not use the ceiling height area reduction for design area 6-4, although this would be permitted. An outline of area 6-4 is shown in Figure 23 and a summary of the hydraulic information is shown in Figure 24. Appendix D contains drawings with sprinkler pipe layouts. The fire pump will have the most difficulty providing water to the highest floor in

the building. The design area has fourteen Tyco TY-FRB K-5.6 quick response sprinklers with 155°F ratings. The spec sheet is provided in Appendix C. Each sprinkler in the design area has a maximum area of 112 ft². This requires 16.8 gpm per sprinkler, giving a minimum supply pressure of

$$P = \left(\frac{Q}{K}\right)^2 = \left(\frac{16.8}{5.6}\right)^2 = 9 \text{ psi}.$$




Figure 23. Atrium design area.

| CALCULATION DESIGN INFORMATION | |
|--------------------------------|-------------------|
| AREA: | "6-4" |
| OCCUPANCY: | OFFICE / LOBBY |
| HAZARD: | LIGHT HAZARD |
| DENSITY: | 0.10 GPM / SQ.FT. |
| AREA OF OPERATION: | 1567 SQ. FT. |
| AREA PER HEAD: | 210 SQ.FT. (MAX.) |
| HOSE STREAM ALLOWANCE: | |
| INSIDE: | 100 |
| OUTSIDE: | |
| SYSTEM DEMAND | |
| PSI REQ. AT BASE OF RISER: | 116.86 |
| GPM REQ. AT BASE OF RISER: | 347.3 |
| PSI REQ. AT SOURCE: | 39.09 |
| GPM REQ. AT SOURCE: | 447.3 |
| PSI AVAILABLE AT SOURCE: | 52.66 |
| TOTAL PSI SAFETY FACTOR: | 13.57 |

Figure 24. Design area 6-4 hydraulic summary.

Baker Science connects to the school's domestic water loop with an 8" underground supply line. The sprinkler system is fed from a pump rated for 750 gpm at 113 psi. Figure 25 shows an elevation view of the pump and riser room. The product data sheet for the pump is provided in Appendix C. The discharge of the pump feeds 6" mains that supply water to four 6" standpipes, located in the stairwells. The mains on the floors are 2½" with 1" or 1¼" branch lines supplying the sprinklers.




Figure 25. Elevation view of pump and riser room.

Hydraulic Calculations

A program called Hydracalc was used to perform hydraulic calculations for this system. Details about each part of the sprinkler system were put into the program. The sprinklers and branch lines were input in the system, then connected to the main on the sixth floor. Each pipe length, number and type of fittings, material, and elevation are included, as this information is required for an accurate calculation of pressure and flow for a system. The flowing sprinklers are included, and the program runs calculations to balance flow between them as would occur if the system were really activated.

Hydracalc uses the Hazen-Williams formula to calculate pressure loss through a pipe. The factors that influence pressure loss are flow, pipe roughness coefficient, inside pipe diameter, and length of pipe. Pipe elbows, valves, and other fittings also contribute to pressure loss. This is accounted for with an “equivalent length” of pipe. An equivalent length represents the length of pipe that could be installed in a pipe segment that would create the same pressure loss as the fitting. This information can be found on data sheets for the fittings, and allows for easier pressure loss calculations.

The Hazen-Williams formula is shown below. The output of the formula is the pressure loss per length (psi/ft) for a section of pipe. This is multiplied by the length of pipe, including equivalent lengths of fittings, to calculate the total pressure loss for a pipe section. The hydraulic calculations are provided in Appendix C. The Hazen-Williams formula is provided in NFPA 13, 23.4.2.1.1:

$$p = \frac{4.52Q^{1.85}}{C^{1.85}d^{4.87}}$$

p = frictional resistance (psi/ft of pipe)

Q = flow (gpm)

C = friction loss coefficient

d = actual internal diameter of pipe (in)

Multiple design areas are calculated in Hydracalc, as an engineer may not immediately be able to determine what the most hydraulically remote area is at first glance. In the hydraulic calculations for Baker Science, area 6-4 was the most hydraulically remote. This remote area is located on the sixth floor, has an area of operation of 1567 ft² with a density of 0.10 gpm/ft², and requires 347 gpm at 117 psi. Figure 26 shows a plot with pressure vs flow for the city water supply (green), the pump discharge pressure (red), and the most remote area demand (blue). The most remote area includes the 100 gpm hose demand. The demand for the most remote area is below the pump pressure curve, indicating the supply is adequate to protect the most remote area. Other remote areas were calculated, and all required less pressure and flow than area 6-4.




Figure 26. Pressure vs flow plot with city water pressure (green), pump discharge pressure (red) and most remote area (blue).

Inspection, Testing, and Maintenance

The inspection, testing, and maintenance requirements for the fire suppression system are outlined in NFPA 25. Systems must be tested in accordance with original acceptance tests when a component or subsystem is adjusted, repaired, or replaced. Any sprinkler found to not be in compliance must be repaired or replaced to comply with code requirements. Table 5.1.1.2 in NFPA 25 provides frequencies for inspection, testing, and maintenance for different types of sprinkler equipment. Pressure gauges, waterflow switches, and valve supervisory signal devices must be inspected quarterly. Sprinklers must be visually inspected annually from the floor level annually for leakage, corrosion, damage, paint, or other factors that could be detrimental to sprinkler operation. Representative samples of the quick response sprinklers must be tested after 20 years, and ten years thereafter. Compliance with the inspection, testing, and maintenance requirements from NFPA 25 will help ensure proper operation of the fire suppression system.

The fire suppression system in Baker Science is adequately designed and sized, capable of providing 347 gpm of water to the most remote sprinkler design area, with a pressure of 117 psi at the base of the riser. There is also enough capacity to supply the standpipes with 100 gpm of hose demand. The fire suppression system is connected to another vital safety system, the fire alarm and notification

equipment. Upon activation of a sprinkler, the fire alarm system would activate, alerting occupants and emergency services that a fire had occurred.

Fire Alarm System

System Description

Baker Science is protected throughout with an automatic fire detection and alarm system in accordance with NFPA 72. The purpose of the system is to detect a fire, and notify occupants to evacuate and emergency personnel to respond to the building. The fire alarm system also activates or deactivates building equipment in response to detection of a fire.

Fire Alarm Control Unit

The Baker Science building has a central fire alarm control unit that can take a variety of input signals and send the appropriate output signals. The fire alarm control unit is a Notifier NSF2-640, shown in Figure 27. This report will use the phrase “fire alarm control unit” and “FACU” to match the nomenclature of NFPA 72, although the construction documents use “fire alarm control panel” and “FACP.” The fire alarm control unit is located on the first floor, in the Main Electrical/Transformer Room, Room 122. Figure 28 shows the location of the FACU (labeled FACP) on the first floor. The unit is a Notifier NSF2-640, and takes alarm signals from throughout the building, and provides appropriate output signals. The sequence of operations matrix is shown below, in Figure 29. This matrix shows what signal outputs the FACU creates for all possible alarm inputs. The FACU alerts the receiving station of conditions in the building in order to get emergency response, as well as activate notification devices to alert occupants to evacuate. The receiving station is the campus police station, and is monitored at all times. Upon receiving a signal, the campus police will dispatch the local fire department to the building. There are three main classes of signals the FACU can create: alarm, supervisory, and trouble signals.



Figure 27. Notifier NSF2-640 Fire Alarm Control Unit.




Figure 28. Location of fire alarm control unit in main electrical room.

| EVENT | ACTION | | | | | | | | | | | |
|--|-------------------------------|---------------------------|-------------------------|--|---------------------------------|------------------------|------------------------|--------------------------|--|--|---|---|
| | SUPERVISORY CONDITION AT FACU | TROUBLE CONDITION AT FACU | ALARM CONDITION AT FACU | ACTIVATE FIRE ALARM AUDIO/VISUAL DEVICES | DISPLAY TEXT ON LCD ANNUNCIATOR | SHUTDOWN HANDLING UNIT | SHUTDOWN HANDLING UNIT | ACTIVATE ELEVATOR RESCAL | DEACTIVATE INDIVIDUAL ASSOCIATED TAMPERS | ACTIVATE SUPERVISORY SIGNAL TO RECEIVING STATION (CAMPUS POLICE) | BYPASS ALL ATRM OUTPUTS (NO NOTIFICATION STATION (CAMPUS POLICE)) | ACTIVATE ATRM PASSIVE SMOKE EVACUATION SYSTEM |
| FIRE ALARM CONTROL UNIT | | | | | | | | | | | | |
| PANEL SUPERVISORY CONDITION (TEST BYPASS) ON ACM-24 AT | X | | | X | | | | | | X | | X |
| PANEL TROUBLE CONDITION (AC POWER FAIL, LOW BATTERY, OPEN CIRCUIT, GROUND FAULT, ETC.) | | X | | X | | | | | | X | | |
| PANEL ALARM CONDITION | | | X | X | X | X | | X | | X | | |
| MANUAL PULL STATION ACTIVATION | | | X | X | X | | | X | | X | | |
| SPOT SMOKE DETECTOR ACTIVATION | | | X | X | X | | | X | | X | | |
| DUCT SMOKE DETECTOR ACTIVATION | | | X | X | X | | X | X | | X | | |
| AR HANDLING UNIT DUCT SMOKE DETECTOR ACTIVATION | | | X | X | X | X | | | | X | | |
| SPRINKLER TAMPER SWITCH | X | | | | X | | | | X | | X | |
| SPRINKLER WATER FLOW ACTIVATION | | | X | X | X | | | X | | X | | |
| FIRE PUMP RUNNING | | | X | X | X | | | X | | X | | |
| FIRE PUMP LOSS OF PHASE | X | | | | X | | | | X | | X | |
| FIRE PUMP PHASE REVERSAL | X | | | | X | | | | X | | X | |
| HEAT DETECTOR ACTIVATION (ELEVATOR EQUIPMENT) | | | X | X | X | X | | X | | X | | |
| ELEVATOR LOBBY ENR SMOKE / ELEVATOR HOISTWAYS | | | X | X | X | | X | X | | X | | |
| SHUNT TRIP POWER SUPERVISION | X | | | | X | | | | X | | | |
| GENERAL ALARM (ANYWHERE WITHIN THE BUILDING) | | | X | X | X | X | | X | | X | | |
| ATRIM SMOKE CONTROL SYSTEM ALARM | | | X | X | X | | | X | | X | X | X |
| BEAM SMOKE DETECTION WITHIN ATRIM | | | X | X | X | | | X | | X | X | X |
| PULL STATION WITHIN ATRIM | | | X | X | X | | | X | | X | X | X |
| SPRINKLER WATER FLOW WITHIN ATRIM | | | X | X | X | | | X | | X | X | X |

Figure 29. Fire alarm action matrix.

NFPA 72 defines an alarm condition as “an abnormal condition that poses an immediate threat to life, property, or mission” (3.3.58.1.1). The alarm signals that can activate this are water flow alarms, fire pump running or phase reversal signal, manual pull stations, heat detectors, and beam/duct/spot smoke alarms. An alarm signal will activate audio/visual devices, alerting occupants to evacuate the building.

A supervisory condition is “an abnormal condition in connection with the supervision of other systems, processes, or equipment” (NFPA 72 3.3.58.1.3). A supervisory signal is generated by activation of a sprinkler tamper switch, fire pump loss of phase or phase reversal, shunt trip power supervision.

A trouble condition is defined as “an abnormal condition in a system due to a fault” (NFPA 72 3.3.58.1.4). A trouble condition is activated when there is an AC power failure, low battery signal, open circuit, or a ground fault.

Alarm Activation Devices

Fire alarm activation in the Baker Science building is accomplished through a variety of devices: different types of smoke and heat detectors, fire pump running signal, fire riser flow switch, and manual pull stations. The building is fully sprinklered, so the primary fire detection in most of the building is through activation of a sprinkler. Once heat from a fire breaks the bulb of a sprinkler, water flows out. This flow of water activates a waterflow switch in the fire riser, sending an alarm signal to the FACU. The decrease in pressure at the output of the pump would also trigger the pump to run, activating the fire pump running signal, which also activates an alarm on the FACU.

In addition to sprinklers throughout the building, there are also smoke detectors in the HVAC ducting, the elevator shaft, elevator lobbies, and heat detectors in the elevator machinery room. Photoelectric smoke detectors are installed above vital fire alarm equipment such as the FACU and RNPS and in elevator lobbies and machinery rooms. The spot smoke detectors installed in Baker Science are Notifier

FSP-851, while the heat detectors are FST-851. An example of a Notifier smoke detector is shown in Figure 30.



Figure 30. Notifier FSP-851 photoelectric smoke detector, with base.

Duct smoke detectors are installed in HVAC systems to send a signal to shut down associated air handling equipment to prevent the spread of smoke from one space to another. NFPA 90A requires duct smoke detectors in any ventilation system that flows greater than 2000 cfm and is capable of spreading smoke to another space. The duct detectors installed in Baker Science are System Sensor DNR.

Additionally, there are manual pull stations at the exits of the building, and next to stairway entrances. This allows an evacuating occupant to activate the fire alarm system as they leave. This would be helpful when a small fire starts, but does not activate smoke detectors or a sprinkler system. The manual pull stations used in this building are Notifier NBG-12LX, and are a dual-acting design. This means that two movements are required to activate the alarm. The pull stations are addressable, which means the exact pull station that was activated is identified for emergency personnel to respond to. An example of a pull station is shown in Figure 31.



Figure 31. Example of manual pull station.

The passive smoke venting system in the atrium can be activated in three different ways. There are beam smoke detectors at all levels of the atrium, waterflow switches dedicated to the atrium sprinklers, and manual pull stations in the atrium that all activate the passive smoke control system. This allows a fire in the atrium to be detected without the delay of the smoke reaching six stories up to the top of the

atrium. The beam detectors in the atrium consist of an emitter (Xtralis OSE-SPW) and an imager (Xtralis OSI-90). One imager can receive inputs from up to seven emitters, although no imager receives more than three emitter signals. This configuration is used on the south side of the atrium on floors 4, 5, and 6. The Xtralis beam detectors use two wavelengths (IR and UV) to distinguish between smoke and dust. An Xtralis imager is shown in Figure 32, the emitter looks similar.



Figure 32. Xtralis OSI-90 beam smoke detection imager.

Alarm Notification Appliances

Notification in the Baker Science building is accomplished with visual and audible devices. The visual devices are strobes, while the audible devices are speakers. System Sensor SPSWL speaker/strobe combinations are used throughout the building. Speaker only and strobe only devices are also installed where required for adequate audible and visual coverage. The strobes have adjustable candela settings to provide adequate visual coverage for their space. In smaller spaces a lower candela setting can be used to reduce the required current when the device is activated.

All notification devices in this building are wall mounted. The strobes are placed in hallways, classrooms, labs, and bathrooms. NFPA 72 does not require visual coverage in spaces that are not normally occupied by more than one person. Examples of spaces where strobes are omitted are single offices, mechanical/electrical rooms, and storage rooms. One of the general notes states "Wall mount audio/visual devices shall be mounted 80" AFF to bottom of the strobe lens." This complies with the lower limit for strobe mounting height given in Chapter 18 of NFPA 72, but the drawing does not mention the 96" upper limit that is also required. The speakers are used for the voice evacuation system. There is also a water motor gong near the fire department connection outside the building.

There are a number of rooms in Baker Science that do not have adequate visual coverage of notification devices. Most of the spaces have an adequate device, but it is not centrally aligned. Moving the devices to the center of their space would provide adequate coverage. The following is a list of spaces that do not comply with code: Lecture room (CLA 05), Integrated studio (265), Intro teaching lab (276), Mineral/maps/geology (233), Teaching lab (237), GIS room (230), Chem stock (232), Teaching lab (461).

Voltage Drop Calculations

Voltage drop calculations are performed to ensure adequate voltage for signaling device circuits. The nominal voltage rating for the system is 24 VDC, but NFPA 72 10.3.5 requires equipment to function at 85% of its rated voltage. A voltage drop calculation is performed for each notification circuit in the building. The drop in voltage occurs because of resistance in the wiring to the notification devices. To calculate the voltage drop, the engineer sums the current draw for all notification devices on each segment of a circuit. The notification device data sheets provide the current draw based on candela and decibel settings for each appliance. The wiring length for the circuit is measured and multiplied by the resistance per length for the wiring, typically listed in Ohms per 1000 ft. Note that the length of wire is twice the distance between each notification device in order for there to be a path back for the current to travel through. This product of resistance per length and total circuit length gives the total resistance for the circuit, which can be multiplied by the current drawn by the appliances, yielding the total voltage drop. Figure 33 shows a voltage drop calculation for one of the circuits in Baker Science. UL listed devices will have an operating voltage of 16 VDC. A 24 VDC system at 85% (20.4 VDC) can have a total voltage drop of 4.4 VDC. If the voltage drop is excessive, appliances can be moved to another circuit, or a heavier gauge wire with less resistance per 1000 ft can be selected. All of the signaling line circuits have a voltage drop of less than 4.4 V, which complies with the NFPA 72 requirements. Full voltage drop calculations for all signaling lines circuits are provided in Appendix E.

| Fire Alarm Voltage Drop Calculations | | | | | | | | | |
|---|-------------------------------|---|------------------|--------------|------------------|----------------|-----|-------------|----------------|
| Project Name | | Cal Poly Building 52: Computer Math and Science | | | | | | | |
| Panel / Circuit # | | Notifier FACP- Circuit 1V1 | | | | | | | |
| Area Covered | | 1st Floor West | | | | | | | |
| Nominal System Voltage | | 24 | | | | | | | |
| Minimum Device Voltage | | 20 | | | | | | | |
| Total Circuit Current | | 1.016 | | Wire Gauge | | Ohm's Per 1000 | | | |
| Distance from source to 1st device | | 30 | | 14 | | 3.07 | | | |
| Wire Gauge for balance of circuit | | | | 14 | | 3.07 | | | |
| Device Number | Distance from previous device | Voltage | | | Current in amps. | Device Model # | | Device Type | Candela Rating |
| | | At Device | Drop from source | Percent Drop | | | | | |
| 1V101 | 30 | 23.81 | 0.187 | 0.78% | 0.066 | System Sensor | SCR | ST | 15 |
| 1V102 | 20 | 23.70 | 0.304 | 1.27% | 0.066 | System Sensor | SCR | ST | 15 |
| 1V103 | 30 | 23.53 | 0.467 | 1.94% | 0.066 | System Sensor | SCR | ST | 15 |
| 1V104 | 50 | 23.28 | 0.718 | 2.99% | 0.066 | System Sensor | SCR | ST | 15 |
| 1V105 | 50 | 23.05 | 0.949 | 3.95% | 0.210 | System Sensor | SCR | ST | 115 |
| 1V106 | 35 | 22.93 | 1.065 | 4.44% | 0.094 | System Sensor | SCR | ST | 30 |
| 1V107 | 30 | 22.85 | 1.148 | 4.78% | 0.158 | System Sensor | SCR | ST | 75 |
| 1V108 | 35 | 22.79 | 1.210 | 5.04% | 0.066 | System Sensor | SCR | ST | 15 |
| 1V109 | 40 | 22.74 | 1.265 | 5.27% | 0.066 | System Sensor | SCR | ST | 15 |
| 1V110 | 35 | 22.70 | 1.299 | 5.41% | 0.158 | System Sensor | SCR | ST | 75 |
| END | | 22.70 | 1.299 | 5.41% | 0.000 | | | | |
| END | | 22.70 | 1.299 | 5.41% | 0.000 | | | | |
| END | | 22.70 | 1.299 | 5.41% | 0.000 | | | | |
| Totals | 355 | End of Line Voltage | | 22.70 | 1.016 | | | | |
| Point to Point Method | | | | | | | | | |
| CIRCUIT IS WITHIN LIMITS | | | | | | | | | |
| Totals | | Voltage Drop | | | | | | | |
| Current | Distance | 1.30 | | | | | | | |
| 1.016 | 355 | | | | | | | | |
| End of Line Voltage | | 22.70 | | | | | | | |
| Percent Drop | | 5.41% | | | | | | | |
| Standard Wire Resistance in Ohms per 1000 feet. | | | | | | | | | |
| 18=7.77 16=4.89 14=3.07 12=1.98 10=1.24 | | | | | | | | | |
| 18-14 Awg = Solid Conductors 12-10 Awg = Stranded Conductors | | | | | | | | | |
| Notes: | | | | | | | | | |
| Wire resistance is doubled in the calculations for two wires (Positive and Negative) | | | | | | | | | |
| The voltage calculated to the last device must not be lower than the manufactures listed minimum operating voltage (IE: rated operating voltage 20-32 VDC). | | | | | | | | | |

Figure 33. Voltage drop calculation for circuit 1V1.

Secondary Power Supply

Fire alarm systems require a primary and secondary power supply. The primary supply is standard 120 V electricity from the grid. The secondary power is supplied with batteries. Appliances such as the fire alarm control unit and smoke detectors use power at all times, requiring standby current. Appliances like speakers and strobes only use current during alarm conditions. NFPA 72 10.6.7.2.1.2 requires an EVACS system to operate in standby for 24 hours and in alarm for an additional 15 minutes. 10.6.7.2.1.1 requires an additional 20 percent safety margin in battery capacity. Based on these requirements, the batteries are sized to provide 24 hours of standby current and 15 minutes of alarm current, with an additional 20 percent safety margin. To calculate this the engineer needs to know standby and alarm currents for all devices as well as the quantity of each device. The FACU cannot power all the notification

devices in the building, so there are many remote notification power supplies in the building. Each of these has its own secondary power supply and associated battery calculation. An example of battery sizing calculations is shown in Figure 34. Note that each type of appliance that uses electric power is listed, along with the quantity, standby current, and alarm current. The total standby current is multiplied by 24 hours, and the total amount of alarm current is multiplied by 0.25 hours (for the 15 minute requirement). These two amp-hour values are combined, then increased by 20 percent to determine the required battery capacity for the panel being calculated. The FACU and all remote notification power supplies each have their own battery backups, and associated amp-hour calculations.

| Fire Alarm Control Panel Battery Calculation | | | | | | | | | | | | |
|--|-----------------------------|-------------------------------------|---|---------------------------------------|----------|--------------------------------|-----------------------------------|-----------------------------------|------------------------------|---------------------------------------|--|--|
| Battery Calculations for: | | FACP Notifier NFS-640 | | | Project: | | Cai Poly Building 52 | | | | | |
| ITEM | DESCRIPTION | STANDBY CURRENT PER UNIT (AMPS) | | QTY | | TOTAL STANDBY CURRENT PER ITEM | ALARM CURRENT PER UNIT (AMPS) | | TOTAL ALARM CURRENT PER ITEM | | | |
| FACP | Fire Alarm Control Unit | 0.2850 | X | 1 | = | 0.2850 | 0.2850 | X | 0.2850 | | | |
| UDACT | Universal Dialer | 0.0400 | X | 1 | = | 0.0400 | 0.1000 | X | 0.1000 | | | |
| FDU-80 | Remote Annunciator | 0.0643 | X | 2 | = | 0.1286 | 0.0643 | X | 0.1286 | | | |
| APS-6 | Power Supply Amp | 0.0000 | X | 1 | = | 0.0000 | 0.0250 | X | 0.0250 | | | |
| OSE-SPW | Beam Smoke Emitter | 0.0035 | X | 10 | = | 0.0350 | 0.0035 | X | 0.0350 | | | |
| OSI-90 | Beam Smoke Imager | 0.0310 | X | 10 | = | 0.3100 | 0.0310 | X | 0.3100 | | | |
| PULL | Manual Pull (addressable) | 0.0004 | X | 29 | = | 0.0116 | 0.0004 | X | 0.0116 | | | |
| FRM-1 | Relay Module | 0.0017 | X | 9 | = | 0.0153 | 0.0022 | X | 0.0198 | | | |
| FSP-851 | Smoke Detector | 0.0003 | X | 16 | = | 0.0048 | 0.0003 | X | 0.0048 | | | |
| FDM-1 | Dual Monitor Module | 0.0008 | X | 18 | = | 0.0144 | 0.0064 | X | 0.1152 | | | |
| SPK | Speaker Only | 0.0000 | X | 3 | = | 0.0000 | 0.0008 | X | 0.0024 | | | |
| SR | Strobe Only 15CD | 0.0000 | X | 7 | = | 0.0000 | 0.0660 | X | 0.4620 | | | |
| SR | Strobe Only 30CD | 0.0000 | X | 6 | = | 0.0000 | 0.0940 | X | 0.5640 | | | |
| SR | Strobe Only 75CD | 0.0000 | X | 2 | = | 0.0000 | 0.1580 | X | 0.3160 | | | |
| FTM-1 | Fire Fighter Phone Jack | 0.0075 | X | 12 | = | 0.0900 | 0.0075 | X | 0.0900 | | | |
| XP6-R | Six Relay Control Module | 0.0015 | X | 1 | = | 0.0015 | 0.0320 | X | 0.0320 | | | |
| XP10-M | 10-Input Monitor Module | 0.0035 | X | 1 | = | 0.0035 | 0.0550 | X | 0.0550 | | | |
| SPSR | Speaker Strobes 15CD | 0.0000 | X | 3 | = | 0.0000 | 0.0710 | X | 0.2130 | | | |
| SPSR | Speaker Strobes 30CD | 0.0000 | X | 14 | = | 0.0000 | 0.0960 | X | 1.3440 | | | |
| SPSR | Speaker Strobes 75CD | 0.0000 | X | 14 | = | 0.0000 | 0.1530 | X | 2.1420 | | | |
| SPSR | Speaker Strobes 95CD | 0.0000 | X | 3 | = | 0.0000 | 0.1760 | X | 0.5280 | | | |
| SPSR | Speaker Strobes 115CD | 0.0000 | X | 16 | = | 0.0000 | 0.2050 | X | 3.2800 | | | |
| FST-851 | Heat Detector (addressable) | 0.0004 | X | 4 | = | 0.0016 | 0.0004 | X | 0.0016 | | | |
| FMM-1 | Monitor Module | 0.0037 | X | 19 | = | 0.0703 | 0.0037 | X | 0.0703 | | | |
| FDRM-1 | Dual Relay/Monitor Module | 0.0013 | X | 64 | = | 0.0832 | 0.0240 | X | 1.5360 | | | |
| DNR | Duct Smoke Detectors | 0.0003 | X | 64 | = | 0.0192 | 0.0003 | X | 0.0192 | | | |
| TOTAL SYSTEM STANDBY CURRENT (AMPS) | | | | | | 1.1140 | TOTAL SYSTEM ALARM CURRENT (AMPS) | | | | | |
| REQUIRED STANDBY TIME (HRS) | | TOTAL SYSTEM STANDBY CURRENT (AMPS) | | REQUIRED STANDBY CAPACITY (AMP-HOURS) | | REQUIRED ALARM TIME (HOURS) | | TOTAL SYSTEM ALARM CURRENT (AMPS) | | REQUIRED ALARM CAPACITY (AMP-HOURS) | | |
| 24 | | 1.1140 | | = 26.7348 | | 0.250 | | 11.6905 | | = 2.9226 | | |
| REQUIRED STANDBY CAPACITY (AMP-HOURS) | | REQUIRED ALARM CAPACITY (AMP-HOURS) | | TOTAL CAPACITY (AMP-HOURS) | | TOTAL CAPACITY (AMP-HOURS) | | SAFETY FACTOR (%) | | ADJUSTED BATTERY CAPACITY (AMP-HOURS) | | |
| 26.73 | | + 2.9226 | | = 29.6574 | | 29.6574 | | + 20% | | = 35.6 | | |

Figure 34. Battery sizing calculation for the FACU.

Emergency Communication System

The Baker Science building provides an emergency voice/alarm communication system. Speakers are distributed throughout the building for voice communication in the case of an emergency. Standard, prerecorded evacuation messages are programmed for certain alarm conditions from the fire alarm control panel. Live voice messages can also be broadcast from the building's FACP or from a remote location. Emergencies such as an active shooter may necessitate building occupants to shelter in place with specific instructions that could be provided for that specific situation.

Inspection and Test Requirements

Inspection and testing of the fire alarm equipment is important to ensure the system operates as intended in the case of emergency. To verify everything is operating properly the system components are inspected with specific frequency. Details of these requirements are found in Chapter 14 of NFPA 72. Inspections of fuses, power supplies, and trouble signals for all fire alarm systems are performed annually. Batteries are inspected semiannually to ensure they are not expired. The battery connections are checked for tightness and to be free of corrosion and leakage. Building notification appliances such as speakers and strobes are inspected semiannually.

The fire alarm and notification system in Baker Science is designed to detect a fire and notify both occupants and emergency personnel. Fire detection is accomplished with waterflow switches, smoke and heat detection, and manual pull stations. The detection activates voice and visual notification for occupants to evacuate. With the exception of some visual notification deficiencies noted previously, the fire alarm and notification requirements are achieved to comply with the requirements of the code. Prompt detection of a fire will allow firefighters to respond to fight the fire, limiting permanent damage to the interior finishes and the structure.

Structural Fire Protection

Required Occupancy Separation

Bakes Science is type 1B construction, CBC Table 601. Type 1B construction requires 2 hour fire resistance rating for the primary structural frame, interior and exterior walls, and floor construction and associated members. Roof construction and associated members have a 1 hour fire resistance rating requirement, and nonbearing walls have no requirement. CBC Table 705.8 provides allowable area limits for exterior wall openings, based on fire separation distance and whether or not the building is sprinklered. Baker Science has a fire separation distance of 20'-25' to the centerline of N Poly View Dr, which means the allowable area for exterior wall openings is unlimited. This building does not qualify as a high-rise building because no floor used for human occupancy is more than 75 ft above the lowest floor having building access. While Baker Science is a six storey building, the first floor only comprises the western half of the building footprint. The sixth floor is only on the eastern half of the building, so no part of the structure is more than four floors above the ground access below it. With each floor 16 ft above the floor below it, the sixth floor is 64 ft above the second floor. At no point in the building is the sixth floor directly above any part of the first floor.

Table 504.3 provides height limits based on occupancy classification, construction type, and if the building is sprinklered. For business occupancies of Type 1B construction, a building is limited to a height of 180 ft above the grade plane. Baker Science is 112 ft from the grade plane to the highest roof surface, well below the 180 ft limit. The limit to the number of storeys is shown in Table 504.4 of the CBC. For Baker Science's construction type, occupancy, and sprinkler system, the limit is 12 storeys above grade plane. Baker Science is six storeys tall, well below the limit. The next consideration for building limits is building area. Table 506.2 states these limits, again based on occupancy, construction type, and whether the building is sprinklered. The building area for Baker Science is unlimited.

CBC Table 803.5.5 provides required occupancy separations between different occupancy types. A summary of separation is shown in Figure 35. No portion of the building requires greater than 1 hour fire rating separating different occupancy types.

| | |
|-------------|------------------------|
| B TO A-3: | 1-HOUR |
| B TO H-3: | 1-HOUR |
| B TO S-1: | NO SEPARATION REQUIRED |
| B TO S-2: | 1-HOUR |
| S-1 TO H-3: | 1-HOUR |
| S-1 TO S-2: | 1-HOUR |

Figure 35. Required separation of occupancies.

Part of the Baker Science building juts out and is about 32 ft from the next building. CBC Table 602 requires 30 ft to a separating line between buildings in order for the exterior to not be fire rated. These two buildings are closer than that to the separating line, so the exterior of Baker Science has a two hour fire rating where the buildings are the closest. The nearby building is shown in Figure 36.




Figure 36. A building near Baker Science to the east.

Interior Finishes

Baker Science contains A-3, B, S-1, and S-2 occupancies. Per CBC Table 803.5, each occupancy group has an interior finish requirement for exit enclosures, corridors, and rooms/enclosed spaces. Since this entire building is sprinklered the interior finish requirements are less restrictive than they would be in an unsprinklered building. Most of the building has Class C interior finish requirements. The exception to this is in places where large groups of people may need to egress, such as exit enclosures and corridors serving many occupants. The requirements for interior finishes are shown in Figure 37.

The interior finish class is based on the flame spread index of the materials used. Class A has a flame spread index of 0-25, but is not required in this building. Class B interior finish materials have a flame spread index 26-75, and Class C materials have a flame spread index of 76-200. All three finish classes have a smoke developed index of 0-450.

| GROUP | EXIT ENCLOSURES AND EXIT PASSAGEWAYS SPRINKLER | CORRIDORS SPRINKLED | ROOMS AND ENCLOSED SPACES SPRINKLED |
|-------|--|---------------------|-------------------------------------|
| A-3 | B | B | C |
| B | B | C | C |
| S-1 | C | C | C |
| S-2 | C | C | C |

Figure 37. Interior finish requirements based on occupancy and room type.

Enclosed Areas of Refuge

The Baker Science building employs enclosed areas of refuge. The egress stairways are enclosed areas of refuge, per CBC 1007.6. Stair 3 has a two hour fire rating, highlighted in green. The separation between the atrium and the east and west wings is highlighted in red, shown in Figure 38 below.




Figure 38. Examples of fire rating enclosed areas of refuge.

Fire Resistance Analysis

This building uses steel construction with wide-flange steel beams. These beams are used for horizontal and vertical support. Common sizes are W24x207 and W24x250, as shown in Figure 39.




Figure 39. Beam details from C/S3.10.

The floor assemblies are concrete and metal deck, which is supported by the steel beam. A detail view of the concrete and metal deck is shown in Figure 40. The stories at ground-level have concrete slabs as floors.




Figure 40. Floor detail, 11/S4.02.

The joints between the columns are welded and bolted. Detailed views are given for various ways of joining beams, along with schedules for the number of bolts and weld sizes for each connection type, see Figure 41 and Figure 42.




Figure 41. Beam joining detail.

| SIMPLE BEAM CONNECTION SCHEDULE | | | |
|---------------------------------|------------------------|-----------|-------------|
| SHEAR PL CONNECTION | | | |
| MEMBER (DEPTH) | # OF BOLTS 1"Ø A325 | CONN PL t | WELD SIZE A |
| < 8" | 2 | 3/8" | 1/4" |
| 8" - 10" | 2 | 3/8" | 1/4" |
| 12" - 14" | 3 | 3/8" | 1/4" |
| 15" - 16" | 4 | 1/2" | 5/16" |
| 18" | 5 | 1/2" | 5/16" |
| 20" & 21" | 5 | 1/2" | 3/8" |
| 24" | 6 | 5/8" | 3/8" |
| 27" | 7 | 5/8" | 3/8" |
| 30" & 33" | 8 | 5/8" | 3/8" |
| 36" | 10 | 5/8" | 3/8" |
| 40" | 11 (2 ROWS) | 3/4" | CJP |

Figure 42. Beam connection schedule.

Fire Resistance Requirements

The Baker Science building contains a variety of occupancy classifications: business, assembly, storage, and hazard 3. Table 508.4 of the CBC, shown in Figure 43, shows the required separation of occupancies, with highlighted fields between relevant occupancies. Appendix A shows occupancy classifications of the different rooms in Baker science, along with fire resistance requirements between rooms. A red line represents a 1 hour fire rating. Where a line is omitted there is no fire resistance requirement.

TABLE 508.4
REQUIRED SEPARATION OF OCCUPANCIES (HOURS)¹

| OCCUPANCY | A, E | | I-1 ^a , I-3, I-4 | | I-2 | | R ^a | | F-2, S-2 ^b , U | | B ^a , F-1, M, S-1 | | H-1 | | H-2 | | H-3, H-4 | | H-5 | |
|------------------------------|------|----|-----------------------------|----|-----|----|----------------|----|---------------------------|----------------|------------------------------|----|-----|----|-----|----|----------------|----|-----|----|
| | S | NS | S | NS | S | NS | S | NS | S | NS | S | NS | S | NS | S | NS | S | NS | S | NS |
| A, E | N | N | 1 | 2 | 2 | NP | 1 | 2 | N | 1 | 1 | 2 | NP | NP | 3 | 4 | 2 | 3 | 2 | NP |
| I-1 ^a , I-3, I-4 | — | — | N | N | 2 | NP | 1 | NP | 1 | 2 | 1 | 2 | NP | NP | 3 | NP | 2 | NP | 2 | NP |
| I-2 | — | — | — | — | N | N | 2 | NP | 2 | NP | 2 | NP | NP | NP | 3 | NP | 2 | NP | 2 | NP |
| R ^a | — | — | — | — | — | — | N | N | 1 ^c | 2 ^c | 1 | 2 | NP | NP | 3 | NP | 2 | NP | 2 | NP |
| F-2, S-2 ^b , U | — | — | — | — | — | — | — | — | N | N | 1 | 2 | NP | NP | 3 | 4 | 2 | 3 | 2 | NP |
| B ^a , F-1, M, S-1 | — | — | — | — | — | — | — | — | — | — | N | N | NP | NP | 2 | 3 | 1 | 2 | 1 | NP |
| H-1 | — | — | — | — | — | — | — | — | — | — | — | — | N | NP | NP | NP | NP | NP | NP | NP |
| H-2 | — | — | — | — | — | — | — | — | — | — | — | — | — | N | NP | 1 | NP | 1 | NP | NP |
| H-3, H-4 | — | — | — | — | — | — | — | — | — | — | — | — | — | — | — | — | 1 ^d | NP | 1 | NP |
| H-5 | — | — | — | — | — | — | — | — | — | — | — | — | — | — | — | — | — | — | N | NP |

Figure 43. CBC occupancy separation requirements.

The Baker Science building complies with the structural fire protection requirements. Many of these requirements will be implemented on the architectural and structural engineering drawings. It is important for a fire protection engineer to be familiar with these requirements, and check the drawings from other disciplines to verify the fire protection requirements are achieved. In addition to verifying structural code compliance, the fire protection engineer will also have input on building configuration related to other systems, such as smoke control.

Smoke Control System

The Baker Science building has a large atrium extending from the second floor to the sixth floor. Walkways connecting the east and west wings extend through the middle of the atrium. The north side opening has an exposed stairway, and the south side has a stairway enclosed in fire rated walls. With such a tall ceiling (~75'), a fire in the atrium may not set off sprinklers and be suppressed with water. The smoke will continue to build up, reducing tenability time in the top floors of the atrium and making egress more difficult.

To combat this, the building has a passive smoke control system installed. The main function of this system is a "night purge," used for temperature control. When the temperature in the building exceeds the outside temperature by 3°F or greater, vents at the top of the atrium and windows lower in the atrium open to allow the warm, buoyant air to naturally exhaust, being replaced by cooler outside air. The dampers stay open until the atrium temperature setpoint is reached, when all the dampers close. There is an interlock to prevent operation when it is raining. There are four vents at the top of the atrium, two on the north side and two on the south side. The brand is Greenheck, and all four dampers are 60"x120". The vents are at the top of elevated roof sections. The elevated roof sections provide space for smoke to build up before the smoke extends into the egress paths on the top floor of the atrium. A construction drawing of the smoke control vents is shown in Figure 44, and a satellite view of the vents is shown in Figure 45.




Figure 44. North atrium smoke control vents.



Figure 45. Smoke control vents highlighted in satellite view.

The night purge system uses the same principles to vent smoke in the case of a fire. If a fire is detected in the atrium the roof dampers and the atrium doors open to allow smoke to vent out of the top of the atrium, increasing the time occupants have to egress the atrium without smoke overwhelming them. When the smoke control system activates all the doors to the east and west wings close. This is accomplished by the fire alarm system stopping power to the magnetic door holders. This allows the makeup air to be supplied from the outside through the bottom of the atrium. The smoke control system can be activated by a waterflow switch for sprinklers in the atrium, a manual pull station in the atrium, or a beam smoke detector in the atrium. Detection in other parts of the building do not trigger the smoke control system.

Design fire 1 takes place in the atrium, and was designed to activate the smoke control system. Figure 46 shows a vector slice file at the smoke control vents above the fire. The colored vectors indicate the smoke is escaping at about 2.5 m/s. With each vent having an area of 4.62 m², the vents on this side are venting approximately 23.1 m³/s of smoke.

There is a night purge system installed in the tall ceiling in the first floor lobby, however it is not connected to the fire alarm system to act as a smoke control system. This is not necessary since occupants will not evacuate through the fire plume above the fire in the event of an emergency.




Figure 46. Vector slice file of velocity of venting smoke.

Utilizing the night purge function for smoke control was an upgrade to the Baker Science building that required little additional equipment to achieve some benefit. Since this type of system needs to be

specific to the building in which it is installed, the California Building Code does not dictate how a smoke control system needs to be sized and configured. In order to verify adequate smoke venting capability, the engineer must know the required safe egress time as well as the characteristics of a design fire, including smoke production. With this information, a performance based review can be conducted in order to properly size the smoke control system.

Performance Based Review

Design Fire Goals

The goal of the performance based review is to verify the tenability time for occupants in Baker Science exceeds the evacuation time, for the selected design fires. The design fires were chosen to represent challenging, but plausible, fires that could occur in the building. Each design fire will have specified parameters, such as heat release rate, growth rate, fuel source, and toxic gas production. These values will be based on materials that are likely to be in the building and published fire data for the materials. These variables will be used to model the fire outputs, such as temperature, sprinkler activation time, toxic gas concentration, radiant flux, detector activation time, and occupant visibility. The model outputs will be used to determine the tenability time for occupants. The amount of time that occupants can safely egress through the building is also called the available safe egress time, or ASET. This is compared to the required safe egress time, or RSET. The goal is for the available safe egress time to exceed the required safe egress time. RSET starts at ignition time and consists of time to detection, time to alarm after detection, the premovement time, and the travel time. Occupants will not know to evacuate until an alarm is activated. After this occurs, there is premovement time while the occupants gather belongings and decide to evacuate. For a building like Baker Science, this is about 1.2 minutes, from the SFPE Handbook, 64.4. Figure 47 shows a visual comparison of ASET and RSET.




Figure 47. Comparison of ASET and RSET for tenability time.

How to analyze design fires

In order to accurately find the tenability time for occupants given likely fire scenarios, a number of steps must be followed. The building must be analyzed to determine where a fire is most likely to negatively impact building egress. This will be based on where occupants are concentrated, and the paths they will take when evacuating the building in case of an emergency. Consideration must also be given to fuels that are likely to be found in the building, and their locations. A fire that occurs in a building space that could expose egressing occupants to heat, smoke, or toxic gasses may justify a design fire.

Once the location of the fire is determined, the next step is to define the fire. Potential fuel loading for the space must be found, both to find the type and amount of fuel. The type of flammable substance will determine the products of combustion. Both pieces of data will be used to estimate the heat release rate, growth rate, and how long the fire will burn. A plausible ignition source should be identified. Since fires are typically low probability, but high consequence, some creativity may be used when finding an ignition source.

PyroSim Model Creation

A PyroSim model is created to match the size and shape of the structure. PyroSim is a program that provides the user with an interface for Fire Dynamics Simulator (FDS), to make it easier to create and analyze models. Construction documents are used to make a floor plan similar to the space being analyzed. Walls, floors, and ceilings are assigned realistic material properties to accurately reflect how heat and fire would interact with the boundaries of the space. Heat capacity, thermal conductivity, reflectivity, and thickness are some of the considerations when building the boundaries.

The design fire must also be defined in PyroSim. The location, size, and shape are input to the model. The fire characteristics such as growth and decay rates, maximum heat release rate, and burn time are included in the fire information. The type of material burning is also specified, along with products of combustion. The products of combustion will be used in later analysis when finding visibility and toxicity for the egressing occupants.

A PyroSim model works by creating a mesh of imaginary blocks of space in the model. Each block interacts with the blocks next to it. Model outputs such as air and smoke flow, temperature, and radiation are calculated for each block of the mesh. Determining the correct mesh size is important for the model to provide accurate outputs in a reasonable amount of time. A coarse mesh, with too few blocks, will not provide adequate resolution for the model, yielding potentially inaccurate results. A fine mesh, with too many blocks, will take too long to calculate without providing better model outputs. FDS is computationally intensive, with a full-size model taking many hours to complete. Reducing mesh dimensions by half doubles the number of nodes in the X, Y, and Z dimensions, drastically increasing computation time. A coarse mesh is often used to test the model and provide outputs with less calculation time, and an adequately fine mesh is used to create the final output for analysis. Multiple mesh sizes can be used throughout the model. A finer mesh can be specified for areas of higher activity or interest in the model. For example, the space directly above the fire and near the ceiling where the smoke will collect may justify a finer mesh for the analysis. Air/smoke movement in these areas will be increased, and higher resolution for the output would be justified, at the expense of a longer calculation

time. Areas farther from the fire, or where smoke and heat effects will be minimal can be calculated with a more coarse mesh in order to reduce calculation time.

There are dozens of outputs available in a PyroSim model. The ones most valuable for analyzing ASET are temperature, visibility, toxic gas concentration, and radiation. Air flow rate was also used in this report to measure required smoke evacuation capability of the smoke control system. The model can be programmed to output points where relevant data is measured, as well as slices with a color-coded visual representation of a plane in the model. Additionally, there are spreadsheets to show how a parameter (such as temperature) changed over time at a given point. All of this is useful when determining how long occupants have to evacuate a space.

Once the PyroSim model has been analyzed to determine how long occupants have to safely egress before being exposed to untenable conditions, this information is compared to the required safe egress time that was calculated with the hydraulic egress calculations. If the available safe egress time is less than the required safe egress time, the building does not provide adequate protection to the occupants.

Tenability Criteria

A primary concern for occupants as they escape a burning building is tenability time. Many factors can make a building untenable: temperature, visibility, carbon monoxide, and heat flux. These are the tenability criteria that will be explored in this report. There are other criteria, such as different toxic gasses, but the analysis methods demonstrated can be applied to other tenability measurements. The SFPE Handbook provides limits for the tenability criteria. The SFPE Handbook provides tolerance times for exposures to hot air in Table 63.17. For dry air the tolerance time is 25 minutes for a temperature of 110°C. Figure 63.28 shows a graph of the temperature limit based on exposure time for both dry and humid air. If the 110 °C limit is reached, this graph can be used to determine if tenability is exceeded for the given temperature conditions. SFPE Handbook Table 61.3 provides two thresholds for visibility limits, depending on the familiarity of the occupant with the building. An occupant familiar with the building is considered to be capable of safely escaping a building with 4 m of visibility, while an occupant unfamiliar with the building will need 13 m of visibility to safely evacuate. For carbon monoxide exposure, a limit of 30,000 ppm-min is considered to be the incapacitation limit for light activity, from SFPE Handbook Table 63.9. Heat flux exposure is limited to 2.5 kW/m² for exposure greater than 5 minutes, as outlined in Table 63.20.

Design Fire 1

The first design fire takes place in the atrium on the second floor, which is the lowest storey of the atrium. To make this fire more challenging, the flammable material is not located under a sprinklered ceiling, but closer to the center of the atrium with the tall ceiling above it. This is a fire scenario that necessitates the beam smoke detectors that were installed in the atrium. With such a tall atrium, smoke venting and occupant egress of higher floors are major concerns. Smoke at the top of a five storey atrium will not be hot enough to set off sprinklers and suppress the fire. The basis of this design fire assumes sprinklers do not locally suppress the fire, due to the fact that the fire does not occur directly under the sprinklered walkway. Since the fire will continue to burn, the smoke will likely need to be exhausted from the space to maintain tenability at the higher floors. Figure 48 shows the location of the

fire in the atrium. Figure 49 indicates the location of the fire on the map. Note the highlighted yellow areas where the atrium extends upward.



Figure 48. North side of the atrium where design fire 1 occurs.



Figure 49. Location of atrium fire on map.

A fire on the north side of the atrium was selected since the stairway is exposed on that side. The stair on the south side of the atrium is enclosed and protected from smoke and heat. A fire on the north part of the atrium would prevent use of the north atrium stairway and the north exit of the main lobby. Upon the fire alarm sounding, occupants of the building may see the smoke in the atrium and select exits at the ends of the wings of the building. With fewer people using the main staircases, the other exit paths would need to accommodate more people. The fire could have been placed on the south side of the atrium, limiting egress from the south stairway to the south atrium door, but then occupants likely would have used the exposed north stairway for egress. A fire on either side of the atrium creates unique egress problems.

The fuel source of this design fire is polyurethane foam decorations for a concrete canoe. Cal Poly competes in concrete canoe design competitions, and the canoes are often displayed in buildings on campus. The concrete canoe in Figure 48 above does not have any artistic additions, but Figure 50 shows an example of a canoe with foam on the supports. For the purpose of this design fire, the canoe and foam artwork are illuminated with lights for display. The ignition source for the fire would be a failure of the lights, setting the foam on fire.



Figure 50. Example of a concrete canoe with foam decorations.

The foam burns as an at^2 fire with a growth constant of $\alpha_g=0.052 \text{ kW/s}^2$, a fast burning fire. The SFPE Handbook Table 38.2 lists growth times for various fuels to reach 1000 kW, and classifies the growth as slow, medium, fast, or ultra-fast. The fast fire growth rate applies to cartons on pallets and some furniture, and has an equivalent growth constant of $\alpha_g=0.044 \text{ kW/s}^2$. "Heat Release Rates of Burning Items in Fires" by Kim and Lilley gives growth constants and maximum heat release rates for numerous types of foam furniture. The values vary greatly, but many of them are in the range of a fast growth fire. A growth constant slightly faster than a fast growth fire was selected to ensure a challenging design fire. A chair would be approximately the same size as the foam bases of the canoe, so the heat release rate

was set to be similar to the burning chairs listed by Kim and Lilley. The maximum heat release rate is 1500 kW, achieved after 170 s of fire growth. A graph of heat release vs time is shown in Figure 51.

HRR vs time




Figure 51. Heat release rate of polyurethane foam vs time.

Floors three through six all have walkways that overlook the atrium on both sides. Each side of the atrium has a raised ceiling section for smoke to accumulate prior to the smoke venting. Figure 52 shows the high ceiling of the atrium with the smoke venting area outlined in red.



Figure 52. Smoke extraction system, highlighted in red.

As the fire burns, the plume will rise to the ceiling, expanding as it does so. Once it reaches the ceiling, the smoke layer will begin to lower as smoke fills the highest sections of the roof. In order to prevent

smoke from filling the atrium of the higher floors, smoke must be vented from the building. To ensure the smoke layer does not continue to lower to the level where people would be, the same amount of smoke that is produced would need to be vented. There are three common methods to calculate the volume of smoke produced by the fire: Zukoski, Heskestad, and McCaffrey. The Heskestad method uses a virtual origin based on the size of the fuel being burned. For this design fire the fuel is 1 m in diameter. This virtual origin simulates if the fuel were at a point above or below the floor, depending on the size of the fuel. For this design fire, the virtual origin is approximately 0.5 m above the floor. A larger fire would yield a virtual origin below ground level. The smoke extraction required by the three methods is summarized in Table 4. Detailed calculations are provided in Appendix F. Makeup air must also be supplied in order for the smoke to be exhausted. This is accomplished with motorized door openers that open the atrium doors when the smoke control system is activated. With two pairs of double doors at the north and south ends of the atrium, makeup air will not limit the rate of smoke evacuation.

Table 4. Required smoke extraction for three methods.

| | m ³ /s |
|-----------|-------------------|
| Zukoski | 184 |
| Heskestad | 150 |
| McCaffrey | 187 |

This design fire was deliberately located away from sprinklers that would effectively suppress the fire. This was to provide a challenging fire that could test the capabilities of the smoke control system. A fire such as this would need to be extinguished by emergency response crews or allowed to burn out on its own. While there are sprinklers at the top of the atrium (seen in Figure 52 above), the smoke at the high ceiling will not reach the 155°C required to activate them. The smoke control system can be activated by a waterflow switch for sprinklers in the atrium, a manual pull station in the atrium, or a beam smoke detector in the atrium. Of these methods, the beam detectors are the most likely to be activated for this design fire.

Beam detector activation can be estimated with calculated smoke output and beam detector setpoint. The Xtralis beam detectors are set to trip at 25% light obscuration. The Lambert-Beer Law is used to correlate light attenuation to smoke mass concentration (equation below). Once enough smoke is present to notably diminish light received from the detector source, the alarm is activated.

$$\frac{I_r}{I_o} = e^{-\kappa CL}$$

Where I_o is initial light intensity, I_r is final light intensity, κ is smoke extinction coefficient, C is smoke mass concentration, and L is optical length. The 25% smoke obscuration is the ratio of final light intensity to initial light intensity. Using a common smoke extinction coefficient and optical length, the smoke mass concentration can be calculated. Iteration is used to determine smoke density at different times during the burning of the fire. According to the calculation, the alarm is tripped at 210 s, at which point the smoke vents and exterior atrium doors would open to remove smoke from the space and supply makeup air. The Lambert-Beer calculation does not align very closely with the PyroSim model. This is likely due to

the calculation taking place where smoke collects at the top, while the PyroSim model is tripped by a lower beam detector that passes through the smoke plume, reaching the alarm setpoint sooner.

The required safe time egress for the atrium and design fire 1 is 10.81 minutes. This consists of 58 seconds until a beam smoke detector on the sixth floor alarms in PyroSim, 1.2 minutes pre-movement time from the SFPE Handbook, and 8.66 minutes for the atrium to be fully evacuated once occupants begin moving from the egress calculations. This egress model assumes occupants egress through the same section of the building that they start in. The entire building will take longer to evacuate, 15.77 minutes from time of ignition. The occupants in the east and west wings do not have direct exposure to the smoke or fire, and are afforded more time to escape.

Tenability

Due to the high ceiling and large volume, the plume temperatures in occupied spaces never exceed tenability conditions. Figure 53 below shows a cut section from PyroSim with temperature at the 6th floor, where the highest temperatures are experienced. The temperature never exceeds that of a warm day and will not have an effect of tenability.




Figure 53. Temperature on the sixth floor.

Visibility is another concern for this sort of fire. The smoke plume extends up to the upper floors, obscuring occupant vision. The SFPE Handbook provides a minimum visibility limit of 4 m for occupants familiar with the building, and a limit of 13 m for occupants not familiar with the building. Figure 54 below shows when visibility limits are exceeded for both 13 m and 4 m, which occur at burn time of 94 s and 190 s, respectively. Note that ignition happens 10 s into the simulation, so timestamps in the images are not aligned with burn time. With 58 s until alarm activation, and 1.2 minutes of pre-movement time, this does not provide enough egress time for occupants of the upper floors to leave without losing

visibility. The sixth floor requires 3.96 min of tenable conditions to get into the stairwell, and this is not achieved near the offices on the north side.




Figure 54. PyroSim visibility plots, 13 m (left) and 4 m (right).

Another concern for occupants trying to evacuate the building is toxic gas inhalation. Carbon monoxide is a common product of combustion, and prolonged exposure can incapacitate a person, preventing them from safely leaving the building.

Haber's Rule was used to determine CO tenability. Haber's Rule is a guideline that provides a limit for the product of concentration of a toxin and time of exposure. Since carbon monoxide builds up in a person's blood, and takes hours to recover from, this rule assumes a short exposure time. A person is estimated to be incapacitated at 30,000 ppm-min CO. From the PyroSim model, the highest concentration of CO for this design fire is 40 ppm. Figure 55 shows a slice file at head height on the sixth floor. Concentration is highest in the plume directly above the fire, and lower on the walkway where occupants would evacuate. The longest egress in the building is less than 20 minutes, so the worst exposure is 800 ppm min, far below the level required for incapacitation. The carbon monoxide concentration takes time to build up to 40 ppm, but this conservative calculation illustrates that the CO limit is never approached. Tenability is not limited by CO.

The method of using Haber's Rule for estimating tenability time based on toxic gas concentration can be used for other toxic combustion products. Each toxic gas will have a short term exposure limit, measured in ppm-min, that should not be exceeded. The combustion output of each toxic gas can be programmed into PyroSim, and slice files or gas detectors can be placed in the model to measure the gas concentration.




Figure 55. Sixth floor slice file with carbon monoxide concentration.

Radiant heat flux is another factor that could prevent safe egress of occupants. A limit of 2.5 kW/m^2 is provided as an upper limit for safe egress of occupants. Multiple heat flux detectors were placed throughout the Baker Science building to see where heat flux was the most limiting. The highest heat flux experienced at head level in the building occurred on the sixth floor, which aligns with the results of the previously discussed potentially limiting factors. As the fire plume rises to the ceiling, the smoke, heat, and combustion products spread out and begin to fill the sixth floor. Figure 56 shows a graph of radiant heat flux over time at the highest measured spot on the sixth floor. The baseline value is greater than zero since the building and all objects in it radiate heat due to being above absolute zero. The heat flux experienced by an occupant is less than 0.50 kW/m^2 . This is below the limit of 2.5 kW/m^2 , and half of what is experienced outside on a sunny day, about 1.0 kW/m^2 . Radiant heat flux is not a limiting factor for evacuating occupants in design fire 1.

Radiative flux vs. Time




Figure 56. Radiant heat flux over time.

The Baker Science building was unable to provide adequate safe egress time for occupants on the sixth floor in regards to visibility. All other tenability factors did not approach limiting factors. Visibility would be improved with an adequately-sized smoke control system. The smoke control system is not likely to be replaced, but there are other options to improve egress of occupants when exposed to smoke. Additional illuminated signs could be installed every 2 m in the egress path from the sixth floor offices, meaning occupants would not require a full 4 m of visibility.

Another option would be to paint lines with egress directions on the floor to guide occupants to safety. A person could look at the ground 2 m ahead and safely follow the lines to safety. In this case visibility could be reduced to 2 m, which would not be exceeded in the egress time.

Design Fire 2

The second design fire takes place in the lobby of the first floor, outside the large auditorium. Figures 57 and 54 show the location of design fire 2 in the lobby outside the auditorium. The entrance of the lobby has a tall ceiling that extends up to be even with the ceiling of the third floor. In the event of a fire, this space would collect smoke from below. The red outline in Figure 58 indicates the shape of the ceiling above the lobby that can collect smoke. The area of this space is approximately 68 m². The two zone model can be used to calculate the time the fire takes to fill the space with smoke to the level of the regular first floor ceiling.



Figure 57. Location of fire outside auditorium.




Figure 58. Location of lobby fire on first floor.

A fire outside the first floor auditorium creates a number of unique problems. The auditorium has fixed seating, and is the room in this building most likely to have occupants unfamiliar with the layout. Also, the density of occupants is the greatest in the building. This means egress will not be as efficient as other spaces in the building. The high ceiling in the space would delay the time to activation for the sprinklers, allowing the fire to grow larger than it would in a space with a lower ceiling.

The fuel source of this design fire is a large couch. California Technical Bulletin 133 (TB 133) provides limits for the maximum heat release rate and total energy released in the first ten minutes for upholstered furniture in public spaces. The limits are a maximum heat release rate of 80 kW and total energy release in the first ten minutes of 25 MJ. However, this technical bulletin has been repealed, meaning public buildings in California no longer need to use TB 133 compliant furniture. For this design fire, a non-TB 133 couch is placed on the first floor, next to the auditorium. The couch burns as an αt^2 fire with a growth constant of $\alpha_g = 0.05 \text{ kW/s}^2$, a fast burning fire. The maximum heat release rate is 3000 kW. This heat release rate is significantly higher than what would be allowed by TB 133 compliant furniture and constitutes a worst-case scenario. The couch is ignited by a laptop placed on the couch cushion while the owner steps away for some time. The laptop fan is blocked, allowing heat to build up and eventually start a fire.

The values for growth constant and heat release rate were taken from “Heat Release Rates of Burning Items in Fires” by Kim and Lilley. The fuel source specified for this fire would reach maximum heat release rate at just over four minutes (245 s). The couch maintains 3 MW for one minute, then decays to nothing at just under ten minutes. A decay constant of $\alpha_d = 0.04 \text{ kW/s}^2$. A graph of heat release vs time is shown in Figure 59.

HRR vs. Time




Figure 59. HRR of foam couch (loveseat) vs time.

There are other exits for this floor of the building, but a majority of people only use the three double doors at the front. With a fire in the main lobby, these doors could be compromised, pushing people to unfamiliar exits. Figure 60 shows a ground-level view of the fire location, along with a visual of how smoke would fill the ceiling space. Note that the flame is used to represent the fuel source, the art on the wall is not what is burning.



Figure 60. Location of design fire 3 and ceiling area that smoke would fill.

While the couch burns, smoke will collect in the space above the lobby, which is three stories tall. A hallway in the third floor of the building has windows that overlook the first floor lobby, as shown in Figure 61, note the sprinklers above the first floor lobby.



Figure 61. Third floor overlooks the first floor lobby.

The space with the red outline has an area of about 68 m^2 , yielding a volume of 788 m^3 until smoke extends to the rest of the first floor with the shorter ceiling. The portion of the ceiling even with the second and third floors will fill up with smoke in 85 s given the constraints of this design fire. This is calculated using the two zone model, based on the smoke output of the fire. As the at^2 fire grows, the

smoke output also grows. An iterative model can calculate the mass and temperature of smoke produced. My model used 5 s increments for iteration, and calculated power, mass of entrained air, smoke temperature, smoke density, mass of collected smoke, and height of smoke. Each of these pieces of data is calculated in 5 s increments.

The PyroSim model estimates that the fire sets off a sprinkler at 142 s, triggering alarm and beginning pre-movement time, which again is estimated at 1.2 min. The egress time for the first floor after movement is started is 5.07 minutes, giving a total egress time of 8.64 minutes from the moment of ignition.

Tenability

The first factor to be considered for tenability is temperature. For design fire 2, occupants in the auditorium will exit through doors that pass near the fuel source. Since the doors are not blocked by the fuel source, people will be able to exit into the lobby, and through the doors to get outside to safety. The temperature limit for egressing occupants is 110°C, with a limit of 25 minutes. This limit is intermittently reached at head height near one of the lobby doors. 115°C is never reached at head height, and Figure 63.28 from the SFPE Handbook shows that people can be exposed to that temperature in humid air for 8 minutes, longer than it takes to egress the first floor. Tenability is not exceeded based on temperature exposure. Figure 62 shows a temperature slice file for the first floor of Baker Science. Notice the small black band where temperature slightly exceeds the 110°C limit.




Figure 62. Temperature plot of first floor lobby.

Visibility is also a primary concern for occupants trying to evacuate a burning building. The visibility limits for this fire should be at 13 m since the large auditorium near the lobby is likely to be filled with occupants who are unfamiliar with the building. The 4 m visibility limit for the offices on the sixth floor was justified since each office is assigned to a staff member. A fixed seating auditorium will frequently be used by people unfamiliar with the building. Visibility drops below 13 meters 120 s after ignition, before any of the sprinklers even activate. This is partially due to the high ceiling allowing the smoke plume to entrain cooler air before reaching the sprinklers, delaying activation. Figure 63 is a slice file of visibility at head height in the lobby.




Figure 63. Lobby visibility at 120 s after ignition.

If the ceiling continues to fill up with smoke, 68.3°C will be reached 155 s after the fire starts, activating the sprinklers. It is likely that all of the sprinklers would activate within a short period of time, unlike a fire with a smoke jet crossing a single sprinkler. This is due to the fact that the entire space fills up with smoke at once, surrounding all sprinklers. With all sprinklers activated, the couch would be unlikely to reach its maximum heat release rate.

With building occupants evacuating through the room where the fire occurs, exposure to toxic gases is a concern. Carbon monoxide begins to build up in the lobby as the fire burns. To calculate the accumulated exposure occupants would experience during egress Haber's rule was used again. A device was placed in the PyroSim model to measure CO concentration. After the model was complete, the output file with CO concentration was used to calculate the incremental exposure to CO by multiplying

the concentration at a time by the time step. These products were sequentially added, then graphed on a plot with time as the X axis. This graph is shown in Figure 64. It indicates that carbon monoxide exposure gradually increases shortly after 200 s. As the CO concentration stabilizes around 400 s, the graph increases linearly. Sixteen minutes into the model, the calculated concentration of CO is still below 8000 ppm-min. This is far below the limit of 30,000 ppm-min CO. Carbon monoxide concentration does not limit tenability for this design fire.

ppm-min CO vs time




Figure 64. Accumulated carbon monoxide in first floor lobby vs time.

Radiant heat flux is another factor that could prevent safe egress of occupants. A limit of 2.5 kW/m² is provided as an upper limit for safe egress of occupants. As in design fire 1, multiple heat flux detectors were placed throughout the first floor lobby to see where heat flux was the most limiting. The part of the lobby exposed to the highest heat flux at head level was near the fuel source. This is logical since the detector would receive heat flux from the hot gasses at the ceiling as well as the plume rising from the burning fuel. Figure 65 shows a graph of radiant heat flux over time. The heat flux experienced by an occupant is less than 0.85 kW/m². Again, this is below the limit of 2.5 kW/m². Radiant heat flux is not a limiting factor for evacuating occupants in design fire 2.

Radiative flux vs time




Figure 65. Radiative heat flux vs time in first floor lobby.

The egress for the first floor of Baker Science is mostly separated from the egress of the rest of the building. The time to evacuate the first floor when at full capacity is 7.22 minutes.

Other Possible Design Fires

Other fires were also considered for this report. The mechanical/electrical room on the first floor would be of concern due to the value of equipment and the higher probability of a fire in the space. This design fire was ultimately not selected due to the low occupancy of a machinery space, and the fire rating of the room would likely prevent the fire from spreading. Like the mechanical space on the first floor, the equipment on the roof could also catch fire. This fire was not selected for the same reason as the machinery room fire. Baker Science also has chemical storage rooms to supply the chemistry labs. While a fire in a chemical storage room could grow quickly, egress from the storage room would be nearly immediate, providing less of a risk to life safety.

Recommendations

The Baker Science Center has room for improvement in its design. The smoke venting is not adequate to maintain visibility for the design fire investigated in the atrium. Larger vents, or a greater number of them could possibly improve this. Another option would be to install a powered smoke control system with fans rated at an adequate capacity.

The design fire outside the auditorium on the first floor created untenable visibility conditions before egress could be completed. This creates an especially high danger in a space that is likely to be occupied by people unfamiliar with the building. Since both of the auditorium exits lead to the lobby, this creates a danger if a fire occurs in the lobby. One possible method to increase visibility in the lobby would be to

configure the lobby night purge function to a smoke venting system, similar to the smoke venting in the atrium. Another solution to this is to install an additional egress door in the auditorium, one that does not force occupants into a smoke-filled lobby. It could either egress occupants into the stairwell to the east, or directly to the outside to the west. Possible locations for the additional exits are shown in Figure 66.




Figure 66. Suggested locations for additional exits from first floor auditorium.

This building is built with fire rated walls separating the atrium from the east and west wings. To decrease the egress time for one area of the building, voice messages could direct occupants out of and away from the section of the building where a fire occurs. The current fire alarm system does not utilize horizontal exits, but this could easily be implemented to increase evacuation speed.

Conclusion

Baker Science was intended to meet the needs of a growing, modern campus. This building achieves these goals by providing a variety of uses, including laboratories, offices, study areas, and assembly spaces. This building design has a few unique design considerations, such as a five storey atrium and a smoke control system.

The life safety design is capable of evacuating the maximum rated building capacity of 2848 occupants in 13.62 minutes after egress has started. The 13.62 minutes is for the east wing, while the west wing would only need 10.04 minutes, and the atrium would take 8.66 minutes. Fire suppression is supplied from a city water loop and pressurized with a fire pump capable of supplying the most remote sprinkler design area with 347 gpm pressurized to 117 gpm at the pump discharge. The entire building is protected with K-5.6 quick response sprinklers that would activate the fire alarm system in the event of a fire. The fire alarm and voice notification system alerts the occupants and emergency personnel when a

fire occurs. Fire detection is provided throughout the building with sprinklers, heat detectors, beam smoke detectors, and spot smoke detectors. The building's type 1B construction and sprinkler system allows it to be six storeys tall with more than 44,000 ft² on some floors.


The performance based design analysis for Baker Science revealed shortcomings that were not apparent based on the prescriptive design. The egress capabilities of the building were adequate from a code standpoint, but the visibility was reduced prior to a full evacuation for both of the design fires selected. The atrium fire produced smoke that limited ASET for the sixth floor to 3.23 min, based on 4 m minimum visibility. This is inadequate compared to the RSET of 3.96 min for that storey. The recommendation to improve this problem is to increase smoke extraction in the atrium. The lobby fire exceeded the visibility limit of 13 m, yielding an ASET of 2.00 min, far less than the RSET of 8.64 min for the first floor. The way to solve this issue is to install additional exits in the auditorium. The lesson is to consider possible fire scenarios during building design, in order to anticipate deficiencies overlooked by application of the code. Viewing a building as a whole, and not just a sum of different design disciplines, will allow an engineer to produce a superior design.

References

1. CBC, California Building Code, 2007 edition.
2. NFPA 13, Standard for Installation of Sprinkler Systems, 2007 edition.
3. NFPA 14, Standpipe and Hose Systems, 2004 edition.
4. NFPA 20, Stationary Pumps for Fire Protection, 2003 edition.
5. NFPA 25, Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems, 2002 edition.
6. NFPA 70, National Electric Code, 2005 edition.
7. NFPA 72, National Fire Alarm and Signaling Code, 2007 edition.
8. SFPE Handbook, 5th Edition, 2016.
9. Kim, Hyeong-Jin, and Lilley, David G., Heat Release Rates of Burning Items in Fires, 2000.

Appendix A - Life Safety Drawings

- Electrical
- Lab
- Storage
- Offices
- Stairs
- Restrooms
- Student study space
- Halls, egress
- Terrace
- Elevators
- Assembly
- Mechanical
- Lecture



LOCAL FIRE AUTHORITY – ACCESS & WATER FLOW REVIEW

Project: _____
 CSFM File Number: _____

Pursuant to Title 19, California Code of Regulations, Article 3, Section 3.05, Fire Department Access and Egress, we would appreciate your input relative to fire department access and water-flow for the above project. It is important to us, as the plan review authority, that these issues are addressed to your satisfaction.

Please return this form with all sections filled in completely. Without this form, California State Fire Marshal approval may be delayed. If you have any questions, please contact the California State Fire Marshal Plan Review Unit at (626) 305-1908.

The local fire authority is to consider the following items,


| ACCEPTABLE | YES | NO |
|---|-----|----|
| Location of fire department connection if provided. | | |
| Number, location and size of fire hydrants. | | |
| Fire department access. | | |

Local Fire Authority: _____
 Address: _____
 City/State/ZIP: _____
 Approval issued by: _____
 Rank/Title: _____
 Phone Number: _____
 Signature: _____

CONSERVATION IS WISE—KEEP CALIFORNIA GREEN AND GOLDEN

| TYPE OF LIQUID | Class | MAXIMUM ALLOWABLE QUANTITY PER CONTROL AREA (gallons) | | | | |
|------------------------------------|-------|---|-------------|----------|--------------------|-------------------|
| | | Organic Store | Vault Store | Gen Chem | Haz Waste/gen chem | Haz waste/Organic |
| Class 1A | | | | | | |
| Acetonitrile | 1A | 4 | 8 | 0 | | |
| Diethyl ether | 1A | 20 | 90 | 1 | | |
| Petroleum Ether | 1A | 20 | 60 | 0 | | |
| Subtotal (liters) | | 44 | 158 | 1 | | |
| Subtotal (gallons) (liter x 0.264) | | 12 | 42 | 0 | | 60 |
| Class 1B, 1C, II AND IIIA | | | | | | |
| Acetone | 1B | 40 | 100 | 2 | | |
| Butanol | 1C | 5 | 8 | 0 | | |
| Cyclohexane | 1B | 4 | 25 | 1 | | |
| Ethanol | 1B | 8 | 40 | 1 | | |
| Ethyl Acetate | 1B | 20 | 44 | 4 | | |
| Hexane | 1B | 20 | 44 | 0 | | |
| isopropanol | 1B | 10 | 24 | 2 | | |
| methanol | 1B | 20 | 28 | 0 | | |
| Tetrahydrofuran | 1B | 8 | 16 | 0 | | |
| Toluene | 1B | 20 | 20 | 0 | | |
| Xylenes | 1C | 4 | 28 | 0 | | |
| Heptane | 1B | 4 | 20 | 0 | | |
| Subtotal (liters) | | 163 | 397 | 10 | | |
| Subtotal (gallons) (liter x 0.264) | | 43 | 105 | 3 | | 7,500 |
| Class IIIB | | | | | | |
| Other flammables: | IIIB | 4 | 5 | 5 | 12 L | 100 |
| Subtotal (liters) | | 4 | 5 | 5 | 12 | 20 |
| Subtotal (gallons) (liter x 0.264) | | 1 | 1 | 1 | 3 | 5 |

- Electrical
- Lab
- Storage
- Offices
- Stairs
- Restrooms
- Student study space
- Halls, egress
- Terrace
- Elevators
- Assembly
- Mechanical
- Lecture



STAIR NO. 4
ENCLOSED
EXIT STAIR
AREA OF REFUGE
(CBC 1007.6)

SEE 1
A0.10
FOR
LIFE SAFETY SITE
PLAN
EXIT DISCHARGE
TO PUBLIC WAY

SEE 1
A0.10
FOR
LIFE SAFETY SITE
PLAN
EXIT DISCHARGE
TO PUBLIC WAY

SEE 1
A0.10
FOR
LIFE SAFETY SITE
PLAN
EXIT DISCHARGE
TO PUBLIC WAY

SEE 1
A0.10
FOR
LIFE SAFETY SITE
PLAN
EXIT DISCHARGE
TO PUBLIC WAY

ELEVATOR NO. 1 & 2
LEVELS 3-5: NOT A COMPONENT
OF THE ACCESSIBLE MEANS OF EGRESS
LEVEL 6: COMPONENT OF THE ACCESSIBLE MEANS
OF EGRESS W/ AREA OF REFUGE
(CBC 1007.2.1 AND 1007.6)

CONTROL AREA 2

CONTROL AREA 1


STAIR NO. 3
ENCLOSED EXIT
AREA OF REFUGE
(CBC 1007.6)

ELEVATOR NO. 3
(NOT A COMPONENT OF THE
ACCESSIBLE MEANS OF EGRESS)

STAIR NO. 5
EXTERIOR
EXIT STAIR
EXTERIOR AREA OF
ASSISTED RESCUE
(CBC 1007.8)



- Electrical
- Lab
- Storage
- Offices
- Stairs
- Restrooms
- Student study space
- Halls, egress
- Terrace
- Elevators
- Assembly
- Mechanical
- Lecture



STAIR NO. 4
ENCLOSED
EXIT STAIR
AREA OF REFUGE
(CBC 1007.6)

STAIR #4
160132 148

STAIR NO. 3
ENCLOSED EXIT
AREA OF REFUGE
(CBC 1007.6)

STAIR #3
160132 148

ELEVATOR NO. 3
(NOT A COMPONENT OF THE
ACCESSIBLE MEANS OF EGRESS)

CONTROL AREA 1

CONTROL AREA 2

STAIR NO. 5
EXTERIOR
EXIT STAIR
EXTERIOR AREA OF
ASSISTED RESCUE
(CBC 1007.8)

STAIR #5
160137 148

STAIR NO. 1
EXTERIOR
EXIT STAIR
EXTERIOR AREA OF
ASSISTED RESCUE
(CBC 1007.8)

SEE 1
A0.10

FOR LIFE SAFETY PLAN
EXIT DISCHARGE
TO PUBLIC WAY


EXIT DOOR
160124 136

- TECH 95 SF B 100 1
- TECH 96 SF B 100 1
- TECH 100 SF B 100 1
- TECH 95 SF B 100 1

ELEVATOR NO. 1 & 2
LEVELS 3-5: NOT A COMPONENT
OF THE ACCESSIBLE MEANS OF EGRESS
LEVEL 6: COMPONENT OF THE ACCESSIBLE MEANS
OF EGRESS W/ AREA OF REFUGE
(CBC 1007.2.1 AND 1007.6)



- Electrical
- Lab
- Storage
- Offices
- Stairs
- Restrooms
- Student study space
- Halls, egress
- Terrace
- Elevators
- Assembly
- Mechanical
- Lecture



CONTROL AREA 1

CONTROL AREA 2


ELEVATOR NO. 1 & 2
LEVELS 3-5: NOT A COMPONENT
OF THE ACCESSIBLE MEANS OF EGRESS
LEVEL 6: COMPONENT OF THE ACCESSIBLE MEANS
OF EGRESS W/ AREA OF REFUGE
(CBC 1007.2.1 AND 1007.6)

ELEVATOR NO. 3
(NOT A COMPONENT OF THE
ACCESSIBLE MEANS OF EGRESS)

STAIR NO. 5
EXTERIOR
EXIT STAIR
EXTERIOR AREA OF
ASSISTED RESCUE
(CBC 1007.8)



- Electrical
- Lab
- Storage
- Offices
- Stairs
- Restrooms
- Student study space
- Halls, egress
- Terrace
- Elevators
- Assembly
- Mechanical
- Lecture



ELEVATOR NO. 1 & 2
LEVELS 3-5: NOT A COMPONENT
OF THE ACCESSIBLE MEANS OF EGRESS
LEVEL 6: COMPONENT OF THE ACCESSIBLE MEANS
OF EGRESS W/ AREA OF REFUGE
(CBC 1007.2.1 AND 1007.6)



- Electrical
- Lab
- Storage
- Offices
- Stairs
- Restrooms
- Student study space
- Halls, egress
- Terrace
- Elevators
- Assembly
- Mechanical
- Lecture




ELEVATOR NO. 1 & 2
 LEVELS 3-5: NOT A COMPONENT
 OF THE ACCESSIBLE MEANS OF EGRESS
 LEVEL 6: COMPONENT OF THE ACCESSIBLE MEANS
 OF EGRESS W/ AREA OF REFUGE
 (CBC 1007.2.1 AND 1007.6)

CONTROL AREA 1



- Electrical
- Lab
- Storage
- Offices
- Stairs
- Restrooms
- Student study space
- Halls, egress
- Terrace
- Elevators
- Assembly
- Mechanical
- Lecture



1 LIFE SAFETY PLAN - UPPER ROOF
 A0.17 SCALE: 1/16" = 1'-0"

21,227 SF
 (-) 991 SHAFTS =
 20,236 SF

2 LIFE SAFETY PLAN - ROOF
 A0.17 SCALE: 1/16" = 1'-0"



Appendix B

Example hydraulic egress calculation, Atrium 3rd floor

Density in egress route

$$D = \frac{P}{A} = \frac{155 \text{ people}}{920 \text{ ft}^2} = 0.168 \frac{\text{people}}{\text{ft}^2}$$

$$D = \text{density, } \frac{\text{people}}{\text{ft}^2}$$

$$A = \text{area, } \text{ft}^2$$

$$P = \text{number of people}$$

Speed of occupants in egress route

$$S = k - akD = 275 - 2.86 * 275 * 0.168 = 142.5 \text{ ft/min}$$

$$k_1 = 275 \text{ for flat corridor}$$

$$a = 2.86$$

Time to travel egress route to door

$$t = \frac{d}{S} = \frac{117}{142.5} = 0.82 \text{ min}$$

Specific flow, corridor

$$F_s = (1 - aD)kD$$

$$F_s = (1 - 2.86 * 275) 275 * 0.168 = 24.0 \text{ person}/(\text{min ft})$$

Calculated flow, corridor

$$F_{c, \text{corridor}} = (1 - aD)kDW_e = (1 - 2.86 * 0.168) 275 * 0.168 * 7 = 168.0 \text{ person}/\text{min}$$

Specific flow, door

$$F_{s, \text{door}} = \frac{F_{s, \text{corridor}} W_{e, \text{corridor}}}{W_{e, \text{door}}} = \frac{168.0 * 7}{2} = 84.0 \text{ person}/(\text{min ft})$$

Use $F_{sm} = 24 \text{ person}/(\text{min ft})$ from Table 59.5

Flow rate, door

$$F_{c, \text{door}} = F_{s, \text{door}} W_{e, \text{door}} = 84.0 * 2.0 = 168.0 \text{ person}/\text{min}$$

Queuing rate

$$Q_{\text{door}} = F_{c, \text{corridor}} - F_{c, \text{door}} = 168 - 48 = 120 \text{ people}/\text{min}$$

Specific flow, stair

$$F_{s, \text{stair}} = \frac{F_{s, \text{door}} W_{e, \text{door}}}{W_{e, \text{stair}}} = \frac{84.0 * 2.0}{3.2} = 52.5 \text{ per}/(\text{min ft})$$

From Table 59.5, $F_s = 18.5 \text{ persons}/(\text{min ft})$ after stair flows merge

Flow rate, stair

$$F_{c, stair} = F_{s, stair} W_{e, stair} = 15.0 * 3.2 = 48.0 \text{ person/min}$$

Stair density

$$\text{From Figure 59.8, } D_{stair} = 0.98 \text{ persons/ft}^2$$

Stair speed

$$S = k - akD$$

$$S = 212 - 2.86 * 212 * 0.098 = 152.5 \text{ ft/min}$$

$$k_1 = 212 \text{ for 7/11 stairs}$$

Stair travel time

$$t_{stair to next floor} = \frac{d}{S} = \frac{50.6}{152.5} = 0.33 \text{ min}$$

People in stair

$$P_{stair} = F_{c, stair} * t_{stair to next floor} = 48.0 * 0.33 = 16 \text{ people}$$

Flow rate, door

$$F_{c, door} = F_{s, door} W_{e, door} = 24 * 2 = 48.0 \text{ person/min}$$

People queued at door

$$P_{queued} = P_{floor} - P_{stair} = 155 - 16 = 139 \text{ people}$$

Time to egress previous floor

$$t_{egress previous floor} = 4.85 \text{ min}$$

Time to egress queued

$$t_{egress queued} = \frac{F_{c, door}}{P_{queued}} = \frac{48.0}{139} = 2.90 \text{ min}$$

Time to evacuate floor

$$t_{evacuate floor} = t_{egress queued} + t_{egress previous floor} + t_{stair to next floor} = 2.90 + 4.85 + 0.33 = 8.08 \text{ min}$$

HYDRAULIC CALCULATIONS SUBMITTAL

SECTION:

DIVISION 21 – FIRE SUPPRESSION

21 0500 ; 21 1200 ; 21 1300 ; 21 3000

PROJECT:

CAL POLY CENTER FOR SCIENCE
1 GRAND AVE., BUILDING #70
SAN LUIS OBISPO, CA 93407

FOR THE:

GILBANE BUILDING COMPANY
1 GRAND AVE., BUILDING #70
SAN LUIS OBISPO, CA 93407

AS PRESENTED BY:



Aero Automatic Sprinkler Company

21605 North Central Ave.

Phoenix, AZ 85024

623-580-7800 623-434-3420 (fax)

This submittal has been reviewed by Aero Automatic Sprinkler Co. and approved with respect to the means, methods, techniques, sequences, and procedures of construction, and safety precautions and programs incidental thereto. Aero Automatic Sprinkler Co. also warrants that this submittal complies with the Contract Documents and comprises no variation to.

By: *Neal Larsen*

Date: 9-29-2011

Gilbane

Cal Poly Center for Science
Gilbane Project #: 174338010

REVIEWED

Building Name/#: Cal Poly CFS
Bid Package No: 21A
Submittal No: 003
Spec. Section: 21 05 00
Reviewed By: Scott Gurley
Date: 10/3/11

This review does not constitute nor does it assume design responsibility nor does it relieve the trade contractor/supplier from complying with the contract requirements, coordinating their work with other trade contractors and verifying field dimensions.

Gilbane

Cal Poly Center for Science
Gilbane Project #: 174338010

REVIEWED

Building Name/#: Cal Poly CFS
Bid Package No: 21A
Submittal No: 002
Spec. Section: 21 12 00
Reviewed By: Scott Gurley
Date: 10/3/11

This review does not constitute nor does it assume design responsibility nor does it relieve the trade contractor/supplier from complying with the contract requirements, coordinating their work with other trade contractors and verifying field dimensions.

Gilbane

Cal Poly Center for Science
Gilbane Project #: 174338010

REVIEWED

Building Name/#: Cal Poly CFS
Bid Package No: 21A
Submittal No: 002
Spec. Section: 21 13 00
Reviewed By: Scott Gurley
Date: 10/3/11

This review does not constitute nor does it assume design responsibility nor does it relieve the trade contractor/supplier from complying with the contract requirements, coordinating their work with other trade contractors and verifying field dimensions.

Gilbane

Cal Poly Center for Science
Gilbane Project #: 174338010

REVIEWED

Building Name/#: Cal Poly CFS
Bid Package No: 21A
Submittal No: 002
Spec. Section: 21 30 00
Reviewed By: Scott Gurley
Date: 10/3/11

This review does not constitute nor does it assume design responsibility nor does it relieve the trade contractor/supplier from complying with the contract requirements, coordinating their work with other trade contractors and verifying field dimensions.

This page intentionally left blank.

HYDRAULIC CALCULATIONS

PROJECT:

CAL POLY CENTER FOR SCIENCE
1 GRAND AVE., BUILDING #70
SAN LUIS OBISPO, CA 93407

FOR THE:

GILBANE BUILDING COMPANY
1 GRAND AVE., BUILDING #70
SAN LUIS OBISPO, CA 93407

AS PRESENTED BY:



Aero Automatic Sprinkler Company

21605 North Central Ave.

Phoenix, AZ 85024

623-580-7800

623-434-3420 fax

—SECTION 210500—
COMMON WORK
RESULTS FOR FIRE
SUPPRESSION

PART 1 GENERAL
1.8.3 SHOP DRAWINGS

—SECTION 211200—
FIRE SUPPRESSION
STANDPIPES


PART 1 GENERAL
1.4.3 SHOP DRAWINGS

—SECTION 211300—
FIRE SUPPRESSION
SPRINKLER SYSTEMS

PART 1 GENERAL
1.4.3 SHOP DRAWINGS

—SECTION 213000—
FIRE PUMP


PART 1 GENERAL
1.4.3 SHOP DRAWINGS



This page intentionally left blank.


HYDRAULIC CALCULATION TABLE OF CONTENTS

| | |
|---|---|
| 1 | FLOW TEST, FIRE PUMP CURVE, PRESSURE REDUCING VA. (1 ST. FLOOR ONLY), DBL. DETECTOR ASSEMBLY |
| 2 | LEVEL 1 R/A # 1 & 2 |
| 3 | LEVEL 3 R/A # 1 & 2 |
| 4 | LEVEL 6 R/A # 1,2,3 &4 |
| 5 | STANDPIPE # 1 [1000 & 750] |
| 6 | STANDPIPE # 4 [1000] |
| 7 | STANDPIPE # 5 [1000] |
| 8 | STANDPIPE STATIC & FLOW FOR PRESSURE REDUCING VALVE SETTING 'E' |
| | |
| | |



Aero Automatic Sprinkler Company
21605 North Central Ave.
Phoenix, AZ 85024
623-580-7800 623-434-3420 fax

This page intentionally left blank.



FLOW TEST, FIRE PUMP CURVE, PRESSURE
REDUCING VA. (1 ST. FLOOR ONLY), DBL.
DETECTOR ASSEMBLY


This page intentionally left blank.

FLUID RESOURCE MANAGEMENT FIRE HYDRANT FLOW TEST WORKSHEET

WATER SYSTEM Cal Poly Math and Science

DATE 8/19/2011

TIME 9:12am



| Flowing Hydrant(s) | Concurrent Flow | | | Residual Hydrant | |
|-------------------------|-----------------|---------|---------|------------------|--|
| | # 1 | # 2 | # 3 | Hydrant # | |
| Hydrant # | 64 | | | 63 | |
| Static Pressure (psi) | 63 | | | 60 | |
| Test Gauge # | 2 | | | 55 | |
| Pitot Pressure (psi) | 35 | | | 1 | |
| Test Gauge # | 1a | | | R.Ellison | |
| Nozzle Size (Inches) | 2.5 | | | | |
| Nozzle Coefficient | | | | | |
| Hydrant Flow (gpm) | 914 | | | | |
| Tested by | R.Ellison | | | | |
| Projected Flow @ 20 psi | 2270.288 | #DIV/0! | #DIV/0! | | |


Comments :

FLUID RESOURCE MANAGEMENT FIRE HYDRANT FLOW TEST WORKSHEET

WATER SYSTEM Cal Poly Math and Science

DATE August 19, 2011

TIME 9:28am



| Flowing Hydrant(s) | Concurrent Flow | | | Residual Hydrant | |
|-------------------------|-----------------|---------|---------|-------------------------|-----------|
| | # 1 | # 2 | # 3 | Hydrant # | |
| Hydrant # | 63 | | | 64 | |
| Static Pressure (psi) | 64 | | | 63 | |
| Test Gauge # | 2 | | | Residual Pressure (psi) | 58 |
| Pilot Pressure (psi) | 40 | | | Test Gauge # | 1 |
| Test Gauge # | 1a | | | Tested by | R.Ellison |
| Nozzle Size (inches) | 2.5 | | | | |
| Nozzle Coefficient | | | | | |
| Hydrant Flow (gpm) | 974 | | | | |
| Tested by | R.Ellison | | | | |
| Projected Flow @ 20 psi | 2862.1147 | #DIV/0! | #DIV/0! | | |

Comments :



Approved Fire Pumps


1151 N. Pomona Rd., Ste. B Corona, Ca 92882
 Dens Mueller
 Phone 951-738-9100
 Fax 951-7389191

Project : Cal Poly Center for Science
Quote Ref. : UK-999999-1

Page No : 1 **Date :** Monday, February 28, 2011

Type: PG - In-Line Close Coupled Fire
Pump Model: 6PVF10
Pump Op. Speed: 3550 RPM, 60 Hz Electric
Impeller Dia.: 8.24 inch
Curve No.: 3116186
Market : FM/UL/ULC Listed Fire Pump

Item : 1
Impeller No.: 2699332
Liquid: Water
Temperature: 59 °F
Viscosity: 1.14 cSt
Sp. Gravity: 1.00
Your Ref. :



| | |
|----------------------|------------|
| Rated Flow | 750 US gpm |
| Rated Head | 113 psi |
| Imp. Dia. | 8.24 inch |
| Rated Power Required | 58.1 hp |
| Rated Efficiency | 85.3 % |

| | |
|-----------------------|-------------|
| NFPA Limits: | |
| 140% Head at shutoff | 158.2 psi |
| 65% Head at 150% flow | 73.4 psi |
| Flow at 150% | 1125 US gpm |
| Head at 150 | 89 psi |
| Power Req. at 150% | 69.3 hp |
| Efficiency at 150% | 84.5 % |
| Peak Power | 75.4 hp |
| Closed Valve Pressure | 125.2 psi |
| Approval | UL |

Comments
 Performance curve represents typical performance. NPSH data is

| Flow (US gpm) | Head (psi) | Pump Efficiency (%) | Power Required (hp) | NPSH Required (ft) |
|---------------|------------|---------------------|---------------------|--------------------|
| 0.0 | 125.2 | 0.0 | 34.7 | |
| 197.6 | 125.2 | 36.6 | 39.5 | |
| 395.1 | 124.2 | 62.8 | 45.7 | |
| 592.7 | 119.6 | 78.8 | 52.6 | |
| 790.2 | 110.9 | 86.2 | 59.5 | |
| 987.8 | 98.9 | 87.0 | 65.7 | |
| 1185.3 | 84.4 | 82.8 | 70.7 | |
| 1382.9 | 67.9 | 74.2 | 74.0 | |
| 1580.4 | 48.2 | 59.1 | 75.4 | |

This page intentionally left blank.



FIELD ADJUSTABLE PRESSURE REDUCING

Field Adjustable Pressure Reducing (URFA)

Elkhart's URFA valve is a true pressure reducing valve, operated automatically by inner hydraulic controls. While the valves are preset at the factory, they are field adjustable — allowing you to tailor the pressure to your needs. They feature manual valve open and close, as well as pressure adjustment — all of which require extremely low torque to change due to the patent pending design. Inlet pressure up to 400 psi (27.58 bar) is controlled under all flow and no-flow conditions.

Valve size and weight permit installation in significantly tighter areas and smaller hose cabinets (those used for 1½" or 2½" valves) — allowing savings of both space and money. The URFA also functions as a floor control valve in automatic sprinkler systems as well as a standpipe valve or hose valve for Class I and Class III systems.

INDUSTRIAL VALVES




9-1



| INLET SIZE | OUTLET SIZES | TYPE | | CERT. | DIMENSIONS (INCHES) | | | | | | | | Integral Superv. Switch | FINISH | | | Wt. (Lbs.) | MODEL | FIGURE |
|------------|--------------------|--------|----------|-----------|---------------------|----------------------------------|------|-----|----|----|---|----|-------------------------|--------|-----|--------|------------|--------------|--------|
| | | | | | Closed | | Open | | C | D | E | F | | Brass | | Chrome | | | |
| | | | | | A | B | A | B | | | | | | Cast | Pol | Pol | | | |
| 2½" F NPT* | 2½" F(NPT)* M(NHT) | Angled | Straight | UL Listed | 13⅞ | 11⅞ | 14¼ | 12¼ | 2⅞ | 3¼ | 5 | 4¼ | o | s | o | o | 18½ | URFA-20-2.5 | 1 |
| • | • | • | • | • | 13⅞ | 11⅞ | 14¼ | 12¼ | 2⅞ | 3⅞ | 5 | 4¼ | o | s | o | o | 18½ | URFA-25-2.5 | 2 |
| • | • | • | • | • | 14½ | 11 ²⁹ / ₃₂ | 15⅞ | 12¼ | 3½ | 4 | 5 | 4¼ | o | s | o | o | 26½ | URFA-20S-2.5 | 3 |

KEY s = standard o = option

* Grooved connection available for inlet or outlet use — add 1.44" per connection.



PRODUCT HIGHLIGHTS

URFA features include:

- Manual open-close requires less than 15 lbs. of torque
- Pressure rated up to 400 psi (27.58 bar)
- Flow rated up to 500 gpm (1893 lpm)
- Open-Close indication from 2 view directions
- Color-coded pressure reduction label
- Tapped for pressure gauge on both inlet and outlet side of valve
- Tamper-resistant protection
- UL Listed as a check valve for use in dual riser systems
- Optional integral supervisory switch (alarm) mounts directly to valve with no bracket required
- Optional integral supervisory switch (alarm) is available either "OPEN TO SIGNAL" or "CLOSE TO SIGNAL"
 - With the valve in the open position, to close an electrical circuit and send the signal is defined as "OPEN TO SIGNAL"
 - With the valve in the closed position, to close an electrical circuit and send a signal is defined as "CLOSE TO SIGNAL"

ADDITIONAL INFORMATION

Includes adjustment rod.

THREADS

- Valve inlet information is NPT unless otherwise specified. Special threads available through adapter use.
- See index T-12 for alternative outlet thread options.



Elkhart Brass


Fire Fighting Equipment

URFA -20S-2.5"

URFA-20-2.5"


URFA-25-2.5"

INSTALLATION AND OPERATING INSTRUCTIONS FOR FIELD ADJUSTABLE PRESSURE REDUCING/ CONTROLLING VALVES



(URFA-20-2.5 MODEL SHOWN)

URFA VALVE MAJOR COMPONENTS



SPECIFICATIONS

- Pressure rated up to 400 psi.
- Flow rated up to 500 GPM
- Open-Close indication from 2 view directions
- Pressure reduction can be field adjusted
- Pressure reduction adjustment can be easily determined by indication label
- Pressure reduction adjustment has tamper resistant feature
- Low-torque manual close handwheel
- Built-in automatic check valve
- Regulates pressure under both flow and no-flow conditions
- Tapped for pressure gauge on both inlet and outlet side of valve
- Optional integral supervisory switch (For Indoor Use Only)

INLET – OUTLET CONNECTIONS

| VALVE MODEL | INLET THREAD | OUTLET THREAD |
|------------------------|------------------------------|------------------------------|
| URFA-20-2.5 | 2-1/2" FEMALE NPT | 2-1/2" FEMALE NPT |
| URFA-20S-2.5 | 2-1/2" FEMALE NPT | 2-1/2" FEMALE NPT |
| URFA-25-2.5 | 2-1/2" FEMALE NPT | 2-1/2" MALE HOSE |

APPLICATION

A. AUTOMATIC SPRINKLER SYSTEMS

The models URFA-20S-2.5 and URFA-20-2.5 valves are most commonly used in automatic sprinkler systems as floor control valves in high-rise buildings where supply riser pressures exceed 175 psi. The URFA valves are Listed by Underwriters Laboratories as “Special System Water Control Valves – Pressure Reducing and Pressure Control Type (VLMT)”, and also meet the listing requirements for indicating valves. Installation requirements for pressure reducing valves in automatic sprinkler systems are given in Section 4-6.1.2 of NFPA 13, Standard for the installation of Sprinkler Systems, 1999 Edition. When designing URFA pressure reducing valves into a sprinkler system a maximum flow rate of 400 GPM should be observed.

URFA Pressure Reducing Valves are also listed as checking devices, which eliminates the need for a separate check valve. When sprinklers on a given floor are fed from dual risers, the URFA valve acts as a check valve to prevent loss of sprinkler water supply in the event of one riser sustaining damage.

Requirements for Alarm Attachments are given in Section 5-15.1.6 of NFPA 13, Standard for the installation of Sprinkler Systems, 1999 Edition. An integral, listed supervisory alarm switch is available on URFA pressure reducing valves as option number “01” when ordering.

B. STANDPIPE SYSTEM

The models URFA-25-2.5 and URFA-20-2.5 valves are most commonly used in standpipe systems. The URFA-25-2.5 valves have a male hose thread outlet for connecting to fire suppression hose. When hose racks are used, the URFA-20-2.5 can be utilized along with a special hose nipple for support of the rack. The URFA valves are Listed by Underwriters Laboratories as Standpipe Equipment Pressure Reducing Devices (VUTX). Requirements for installation of pressure reducing valves in standpipe systems are given in Section 5-8 of NFPA-14, Standard for the Installation of Standpipe Hose Systems, 1993 Edition.

INSTALLATION REQUIREMENTS

A. AUTOMATIC SPRINKLER SYSTEM

1. To permit easy replacement or repair of valve, pipe unions or rubber gasket mechanical couplings should be installed immediately upstream or downstream of each URFA valve.
2. A relief valve of not less than ½ inch size is to be installed on the downstream side of each URFA valve
3. Pressure gauges are to be installed on the inlet and outlet side of each pressure-reducing valve
4. Valve adjustment setting should be selected to provide an outlet pressure not exceeding 165 psi at the maximum inlet pressure
5. Upon system completion, each Valve must be tested under both flow and no-flow conditions to verify that static residual outlet pressures and flow rates satisfy system design requirements. See Section 8-2.5 NFPA 13 for more information on mandatory flow and no-flow test requirements.

B. STANDPIPE SYSTEM

1. The URFA-25-2.5 can be used for both Class I and Class III service.
2. NFPA 14 requires that hose valve outlet pressures for Class I and Class III service be no greater than 175 psi. and no less than 100 psi. When permitted by the authority having jurisdiction, pressures less than 100 psi may be allowed, but in no cases shall the valve discharge pressure be less than 65 psi
3. Upon system completion, each valve must be tested under both flow and no-flow conditions to verify that static and residual outlet pressures and flow rates satisfy system design requirements. See Section 8-5.5 of NFPA 14 for more information on required flow and no-flow testing.

CONSTRUCTION & OPERATING PRINCIPLE

The URFA is a field adjustable pressure-reducing valve, which utilizes a hydraulic piston and cylinder assembly within the valve lower bonnet to allow the valve to self-throttle in response

to the pressure on the downstream side of the valve. Because the piston, main stem and valve seat float freely from the manual valve stem and handwheel assembly, the valve is able to self-close under static conditions and maintains a reduced pressure both under no-flow and flowing conditions. Valve discharge pressure is transmitted to the top side of the piston through pressure passages in the main stem. The presence of the piston results in a net area differential, which produces a hydraulic balancing force in the closed direction. The magnitude of this balancing force is in direct proportion to the hydraulic area of the piston.

The Field Adjustable feature of the valve is controlled by a spring within the valve upper bonnet. The spring adds an opening force to the main stem so that pressure reduction may be changed as the spring force is changed. This feature allows for the valve to satisfy all expected inlet/outlet pressure ratios. The Field Adjustable feature allows for one type of valve to be specified for all locations in a structure. Once installed the valves can be adjusted to the correct pressure reduction ratio based on their locations.

The URFA valves feature a patent pending manual close design that allows for extremely low torque of the handwheel while manually opening and closing the valve. The unique design allows for the independent operation of the valve stem from the manual close push-rod; this allows for the operator to bypass the large torque required to overcome the stiffness of the adjustment spring.

INSTALLATION OF VALVE

- The valve should first be plumbed into the system
- The upper bonnet may be rotated for optimized access to adjustment window
 - Loosen Bonnet Nut
 - Rotate Upper Bonnet to desired location of adjustment window
 - Apply service removable thread lock to the Bonnet Nut threads
 - Tighten the Bonnet Nut firmly
- See wire diagram for proper installation of supervisory switch
- The system should be slowly filled with water and purged of air
- The system should then be flushed to remove any debris

VALVE SETTING SELECTION

The URFA valves have settings of A, B, C, D, and E. Each valve setting corresponds to a pressure reduction graph located at the end of this manual. The valve setting is determined by where the top of the adjustment cylinder lines up on the Adjustment Identification Label located on the main stem (refer to Figure 1). To determine the correct setting for each URFA valve in the system design please use the following step.

1. Determine the standpipe or sprinkler riser residual pressure for each valve location. This is the inlet pressure at each valve under design flow conditions. In order to accurately determine these pressures, complete water supply data will be required, including results of municipal supply, flow test, and the pump performance curve. The URFA inlet pressure will be equal to the sum of the pump discharge pressure and the

municipal supply pressure at the design flow rate, less piping friction loss and elevation loss.

2. Turn to the appropriate valve performance chart. The valve model and flow range for each graph is indicated in the title at the top of the graph. Be sure to use the correct graph for the designed flow rate through the valve.
3. Locate the valve inlet residual pressure on the vertical axis of the chart and draw a line from the pressure horizontally across the chart.
4. Locate the desired valve outlet residual pressure on the chart horizontal axis and draw a vertical line from this pressure across the chart
5. From the intersection of the inlet and outlet pressure lines constructed in (3) and (4) above, move horizontally to the nearest valve performance curve (actually straight diagonal lines). This will be the appropriate valve setting for the chosen location.
6. Determine the valve static inlet pressure. This will be the sum of the municipal supply static pressure plus the pump churn pressure, less the elevation loss.
7. To determine the valve static outlet pressure, refer to the appropriate static chart. Locate the valve static inlet pressure on the vertical axis of the chart. Follow across to the appropriate valve curve and drop down to the horizontal axis to read valve outlet static pressure.
8. If static outlet pressure is found to exceed the maximum outlet pressure allowed by NFPA 13 or NPFA 14, it will be necessary to re-select a valve setting to the left of the originally chosen type.




Figure - 1

SETTING PRESSURE REDUCTION

1. Remove the tamper-resistant screw from the clear cover by means of tamper-resistant Allen wrench provided with valve.
2. Insert adjustment tool provided with valve through the slot in the clear cover into the hole in the adjustment cylinder.
3. Rotate adjustment cylinder until the top of the adjustment cylinder is aligned with desired mark on the Indication Label (refer to Figure 1).
4. Once rotation limit is reached during adjustment remove the adjustment tool from the adjustment cylinder hole and re-insert the adjustment tool into the next available hole.


5. Once the proper adjustment is obtained verify the outlet pressure is correct with pressure gauges both upstream and downstream of the valve during both flow and no-flow pressure testing; make adjustments as needed. See Section 8-2.5 of NFPA 13 for more details on required flow and no-flow testing.
6. Once the valve is properly adjusted replace the tamper-resistant screw that was removed in step 2.
7. A tamper-resistant allen wrench and adjustment tool should be stored in a special location for Fire Department use.

NOTE: Rotating the adjustment cylinder clockwise will increase outlet pressure. Conversely, rotating the adjustment cylinder counter-clockwise will decrease outlet pressure.

SUPERVISORY SWITCH

Pressure reducing/controlling valves that are to be used as part of a sprinkler system should include a supervisory switch to signal when a valve is not manually in the fully opened position (refer to NFPA 13 for more details on supervisory requirements). An optional supervisory switch assembly with UL approval for use with URFA valves is available on all models. The supervisory switch may be mounted to either side of the upper bonnet in the 3/4 inch tapped holes provided. A cap plug is secured in the upper bonnet tapped holes when the supervisory switch is not installed. A UL Listed conduit elbow is utilized as a water-resistant enclosure for the electronic switch. The conduit elbow provides an opening for fastening conduit to the enclosure, and a lid may be removed to gain access for wiring connections. The lid is attached with two pin-in-hex security screws. A key is provided for installation access into the conduit enclosure. Two switch options are available for the supervisory switch assembly. The first, part number 64040001, will provide a closed circuit when the valve hand wheel is in the full open position. The second option, part number 65755001, will provide an open circuit when the valve hand wheel is in the full open position. Please specify the required switch configuration when ordering. Figure 2 describes wiring details. The two switch options have different colored leads for easy identification. Part number 64040001, the closed circuit switch, has blue and green wire leads. Part number 65755001, the open circuit switch, has yellow and orange wire leads. The solid colored wires act as a primary wiring configuration and the striped wires act as a secondary or back up wiring configuration.

Figure - 2



Note: Supervisory switch rated for Indoor Use Only.

The supervisory switch enclosure may be positioned with the conduit enclosure at various angles so to better meet space requirements (see Figure 3). To reposition the conduit enclosure angle, hold rotation on the hex adaptor fastened to the upper bonnet with the use of an open box wrench. While insuring the hex adaptor remains fully threaded against the upper bonnet, position the conduit enclosure to the desired angle. When completed the hex adaptor **MUST** be fully threaded against the upper bonnet to insure proper function. If the hex adaptor becomes unthreaded the supervisory switch will send an opened signal. Also ensure that the manual handwheel may be fully closed without interference from the supervisory switch assembly.




Figure - 3

VALVE CARE & MAINTENANCE



URFA valves require minimal maintenance. However, a routine inspection and test program is essential for any fire protection system to insure that it is in proper operating condition. NFPA 25, standard for the Inspection, Testing and Maintenance of Water-Based Fire Protection Systems should be consulted for a determination of required test frequency and methods.



Below is a summary of the required frequency of inspections and testing for pressure reducing valves:



| Valve Application | Inspection | Flow Test |
|--|-------------------|------------------|
| Sprinkler System Pressure Regulating Control Valve | Quarterly | Annually |
| Hose Connection and Hose Rack Assembly Pressure Regulating Valve | Quarterly | 5-Years |



Quarterly inspections should verify that the tamper-resistant cover is properly secured and compare actual valve adjustment settings to documented correct adjustment settings for each valve. If a valve is found to have incorrect valve setting it should be reset to the proper setting and undergo flow and no-flow testing to verify proper pressure reduction is obtained.



Flow test results should be compared to previous test results, and to system performance criteria. If the valve adjustment settings match the original and correct settings for each valve then no significant variance should occur from the original flow testing data.
































STATIC PRESSURE REDUCTION





Elkhart Brass

Fire Fighting Equipment

Elkhart Brass Mfg. Co., Inc.

Mailing Address:

P.O. Box 1127

Elkhart, IN 46515 USA

Shipping Address:

1302 W. Beardsley Ave.

Elkhart, IN 46514 USA

Tel. 1-574-295-8330

1-800-346-0250

Fax 1-574-293-9914

e-mail: info@elkhartbrass.com

www.elkhartbrass.com

Elkhart Brass

Fire Fighting Equipment

URFA Valve Calculator

Project Name Cal Poly Center for Science
 Floor Location First Floor
 Static Inlet Pressure (PSI) * 183
 Residual Inlet Pressure (PSI) * 174.5
 Design Static Outlet Pressure
 Design Residual Outlet Pressure
 Flow Rate (GPM) * 250
 Valve Body Style URFA-20S-2.5 (IN-LINE BODY)

| Indicator Setting | Static Outlet Pressure (PSI) | Residual Outlet Pressure (PSI) |
|-------------------|------------------------------|--------------------------------|
| A | 56.40 | 43.77 |
| B | 85.56 | 55.34 |
| C | 107.90 | 69.71 |
| D | 135.24 | 96.64 |
| E | 163.20 | 113.60 |

PRESSURE LOSS ACROSS VALVE IS

$$174.5 \text{ PSI} - 113.6 \text{ PSI} = 60.9 \text{ PSI}$$

⊙ 250 GPM

This page intentionally left blank.

Elkhart Brass

Fire Fighting Equipment

URFA Valve Calculator

Project Name Cal Poly Center for Science
 Floor Location First Floor [R/A=2]
 Static Inlet Pressure (PSI) * 183
 Residual Inlet Pressure (PSI) * 169
 Design Static Outlet Pressure
 Design Residual Outlet Pressure
 Flow Rate (GPM) * 328
 Valve Body Style URFA-20S-2.5 (IN-LINE BODY)

| Indicator Setting | Static Outlet Pressure (PSI) | Residual Outlet Pressure (PSI) |
|-------------------|------------------------------|--------------------------------|
| A | 56.40 | 36.38 |
| B | 85.56 | 45.66 |
| C | 107.90 | 54.23 |
| D | 135.24 | 83.89 |
| E | 163.20 | 98.86 |

PRESSURE LOSS ACROSS VALVE IS

$$169 \text{ PSI} - 98.86 \text{ PSI} = 70.14 \text{ PSI}$$

@ 328 GPM


This page intentionally left blank.



Model 350ADA

Double Check Detector Assembly

SPECIFICATION SUBMITTAL SHEET



- FEATURES**
- Sizes: 2 1/2" 3" 4" 6" 8" 10"
- Maximum working water pressure: 175 PSI
- Maximum working water temperature: 140°F
- Hydrostatic test pressure: 350 PSI
- End connections (Grooved for steel pipe): AWWA C606
- (Flanged): ANSI B16.1 Class 125

*2 1/2" & 3" sizes use 4" body & reducer couplings

OPTIONS

- (Suffixes can be combined)
- with flanged end OS & Y gate valves (standard)
 - L - less shut-off valves (grooved body connections)
 - LM - less water meter
 - with remote reading meter
 - with gpm meter (standard)
 - with cu ft/min meter
 - G - with grooved end OS&Y gate valves
 - FG - with flanged inlet gate connection and grooved outlet gate connection
 - PI - with Post Indicator Gate Valves (4"-10")
 - BGVIC - with grooved end butterfly valves

ACCESSORIES

- Repair kit (rubber only)
- Thermal expansion tank (Model XT)
- OS & Y Gate valve tamper switch (OSY-40)
- Test Cock Lock (Model TCL24)

DIMENSIONS & WEIGHTS (do not include pkg.)

| MODEL 350ADA SIZE | WEIGHT | | | | | | | | |
|-------------------|---------------|------|-----------------------|------|-----------------------|------|-----------------------------|-------|-------|
| | WITHOUT GATES | | WITH OS&Y GATES (GXF) | | WITH OS&Y GATES (GXG) | | WITH BUTTERFLY VALVES (GXG) | | |
| in. | mm | lbs. | kg | lbs. | kg | lbs. | kg | lbs. | kg |
| 2 1/2 | 65 | 105 | 47.5 | 207 | 94 | 139 | 63.3 | 123.0 | 56.2 |
| 3 | 80 | 104 | 47 | 224 | 101.5 | 214 | 97 | 124.4 | 56.5 |
| 4 | 100 | 91 | 41.3 | 245 | 111 | 219 | 99.4 | 120 | 55.0 |
| 6 | 150 | 141 | 64 | 377 | 171 | 347 | 158 | 183 | 87.0 |
| 8 | 200 | 302 | 137 | 778 | 353.2 | 754 | 342.3 | 410 | 188 |
| 10 | 250 | 355 | 161 | 1040 | 472.7 | 810 | 410.5 | 527 | 239.9 |

APPLICATION

Designed for installation on potable water lines connections in fire sprinkler systems to protect against both backsiphonage and backpressure of polluted water into the potable water supply. Model 350ADA shall provide protection where a potential health hazard does not exist. Incorporates metered by-pass to detect leaks and unauthorized water use.

STANDARDS COMPLIANCE (HORIZONTAL & VERTICAL)


- ASSE® Listed 1048
- AWWA Compliant C510 (with gates only)
- CSA® Certified (4" - 8")
- UL® Classified
- C-UL® Classified
- FM® Approved
- Approved by the Foundation for Cross Connection Control and Hydraulic Research at the University of Southern California
- NYC MEA 221-04M-2 (2 1/2" - 8")

MATERIALS

- Main valve body: Ductile Iron ASTM A 536 Grade 4
- Access covers: Ductile Iron ASTM A 536 Grade 4
- Coatings: FDA Approved electrostatic epoxy finish
- Internals: Stainless steel, 300 Series NORYL™, NSF Listed
- Fasteners & springs: Stainless Steel, 300 Series
- Elastomers: EPDM (FDA approved)
- Polymers: Buna Nitrile (FDA approved) NORYL™, NSF Listed

MODEL 350ADA with OS&Y option

MODEL 350ADA with BGVIC option



| MODEL 350 ADA SIZE | DIMENSION (approximate) | | | | | | | | | | | | | | | | | | | | |
|--------------------|-------------------------|--------|-------------------------|--------|--------------------|--------|-----|-------|-----|--------|-------------|--------|---------------|--------|-------------------------|----------|-----|-------|-----|-------|-----|
| | A | | A WITH BUTTERFLY VALVES | | B LESS GATE VALVES | | C | | D | | E OS&Y OPEN | | E OS&Y CLOSED | | E WITH BUTTERFLY VALVES | | F | | G | | |
| in. | mm | in. | mm | in. | mm | in. | mm | in. | mm | in. | mm | in. | mm | in. | mm | in. | mm | in. | mm | in. | mm |
| 2 1/2 | 65 | 35 1/8 | 892 | 32 1/8 | 818 | 20 1/8 | 511 | 4 1/2 | 114 | 9 | 229 | 18 3/8 | 416 | 13 7/8 | 352 | 8 | 203 | 8 | 152 | 7 1/4 | 184 |
| 3 | 80 | 33 1/8 | 818 | 33 | 838 | 20 1/8 | 511 | 4 1/2 | 114 | 9 | 229 | 18 7/8 | 470 | 15 5/8 | 397 | 8 | 203 | 6 | 152 | 7 1/4 | 184 |
| 4 | 100 | 33 1/4 | 872 | 33 1/4 | 845 | 19 7/8 | 505 | 4 1/2 | 114 | 9 | 229 | 22 3/4 | 578 | 16 1/4 | 404 | 9 1/8 | 232 | 6 | 152 | 8 | 203 |
| 6 | 150 | 47 1/4 | 1200 | 46 1/4 | 1022 | 25 7/8 | 657 | 5 1/2 | 140 | 10 1/2 | 267 | 30 1/8 | 765 | 23 3/4 | 603 | 10 1/8 | 257 | 7 | 178 | 10 | 254 |
| 8 | 200 | 62 | 1575 | 55 | 1397 | 38 1/2 | 978 | 10 | 254 | 12 | 305 | 37 3/4 | 959 | 29 1/4 | 743 | 11 15/16 | 303 | 8 1/2 | 216 | 11 | 279 |
| 10 | 250 | 64 5/8 | 1642 | 58 1/2 | 1485 | 30 1/2 | 978 | 10 | 254 | 12 | 305 | 45 3/4 | 1162 | 35 3/8 | 899 | 13 5/16 | 336 | 8 1/2 | 216 | 12 | 305 |

Attention: Model 350ADA (grooved body) and Model 350DA (flange body) have different lay lengths.


(Patent No. 5,913,331)

DOCUMENT # BF-350ADA


REVISION: 1/11

FLOW CHARACTERISTICS

MODEL 350ADA 2 1/2", 3" & 4" (STANDARD & METRIC)



MODEL 350ADA 6", 8" & 10" (STANDARD & METRIC)




◇ Rated Flow (Established by approval agencies)


TYPICAL INSTALLATION

Local codes shall govern installation requirements. Unless otherwise specified, the assembly shall be mounted at a minimum of 12" (305mm) and a maximum of 30" (762mm) above adequate drains with sufficient side clearance for testing and maintenance. The installation shall be made so that no part of the unit can be submerged.

| Capacity thru Schedule 40 Pipe (GPM) | | | | |
|--------------------------------------|----------|------------|----------|-----------|
| Pipe size | 5 ft/sec | 7.5 ft/sec | 10ft/sec | 15 ft/sec |
| 2 1/2" | 75 | 112 | 149 | 224 |
| 3" | 115 | 173 | 230 | 340 |
| 4" | 198 | 298 | 397 | 595 |
| ← 6" | 450 | 675 | 900 | 1354 |
| 8" | 780 | 1169 | 1559 | 2339 |
| 10" | 1229 | 1843 | 2458 | 3687 |
| 12" | 1783 | 2644 | 3525 | 5288 |



MODEL 350ADABGV (VERTICAL INSTALLATION)




MODEL 350ADA (OUTDOOR INSTALLATION)

SPECIFICATIONS

The Double Check Detector Backflow Prevention Assembly shall be ASSE® Listed 1048, and supplied with full port gate valves. The main body and access cover shall be epoxy coated ductile iron (ASTM A 536 Grade 4), the seat ring and check valve shall be Noryl™ (NSF Listed), the stem shall be stainless steel (ASTM A 276) and the seat disc elastomers shall be EPDM. The first and second check valves shall be accessible for maintenance without removing the device from the line. The Double Check Detector Backflow Prevention Assembly shall be a WILKINS Model 350ADA.

WILKINS a Zurn company, 1747 Commerce Way, Paso Robles, CA 93446 Phone: 805/238-7100 Fax: 805/238-5766
 IN CANADA: ZURN INDUSTRIES LIMITED, 3544 Nashua Dr., Mississauga, Ontario L4V 1L2 Phone: 905/405-8272 Fax: 905/405-1292
 Product Support Help Line: 1-877-BACKFLOW (1-877-222-5356) • Website: <http://www.zurn.com>

2



LEVEL 1 R/A # 1 & 2

This page intentionally left blank.



**AUTOMATIC
SPRINKLER CO.**

21605 North Central Ave. 623.580.7800
Phoenix, Arizona 85024 Fax 623.434.3154

AZ-L16-234798 CA-C16-901529
AZ-C16-234797 NV-C41-69370
UT-S370-6690455-5501 NM-MS 12-354807



Fire Protection by Computer Design

Aero Automatic Sprinkler Co.
21605 N. Central Ave.
Phoenix, Arizona 85024
623-580-7800

Job Name : Cal Poly Center for Science LVL 1 [R/A=1]
Building : FP-6.01W
Location : San Luis Obispo, Ca.
System : 1-1
Contract : 10034
Data File : Cal Poly CFS LVL 1-1.WXF

HYDRAULIC CALCULATIONS
for

Project name: Cal Poly Center For Science
Location: San Luis Obispo, Ca.
Drawing no: FP-6.01W
Date: 9-25-2011

Design

Remote area number: 1-1
Remote area location: 1 st. Floor Lecture
Occupancy classification: Light Hazard
Density: 0.10 - Gpm/SqFt
Area of application: 1500 - SqFt
Coverage per sprinkler: 168 - SqFt
Type of sprinklers calculated: Tyco; Mod. TY-FRB; 1/2"; 1/2";K=5.6; 155 Deg
No. of sprinklers calculated: 12
In-rack demand: N/A - GPM
Hose streams: 100 - GPM
Total water required (including hose streams): 350.6 - GPM @ 7.27 - Psi
Type of system: WET
Volume of dry or preaction system: N/A - Gal

Water supply information

Date: 8-19-2011
Location: N. Poly View Drive
Source: Fluid Resource Management

Name of contractor: Aero Automatic Sprinkler Co.
Address: 21605 N. Central Ave. Phoenix, Az. 85024
Phone number: 623-580-7847
Name of designer: Neal Larsen
Authority having jurisdiction: C.S.F.M.


Notes: (Include peaking information or gridded systems here.) Flow Test Information :
Hydrant # 63; Static = 60 psi; Res.= 55 psi {Elev.=351.0'}
Hydrant # 64; Flow = 914 gpm
FLOW TEST USED IN HYD. CALCS REDUCED BY 10 % [STATIC=54psi; RES.=49psi]

Water Supply Curve (C)

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 1 [R/A=1]

Page 2
 Date 9-25-11

| | | |
|---|--|---|
| City Water Supply: C1 - Static Pressure : 54 C2 - Residual Pressure: 49 C2 - Residual Flow : 914 City Water Adjusted to Pump Inlet for Pf - Elev - Hose Flow A1 - Adjusted Static: 51.872 A2 - Adj Resid : 49.314 @ 790.2 A3 - Adj Resid : 40.224 @ 1382.9 | Pump Data: P1 - Pump Churn Pressure : 125.2 P2 - Pump Rated Pressure : 110.9 P2 - Pump Rated Flow : 790.2 P3 - Pump Pressure @ Max Flow : 67.9 P3 - Pump Max Flow : 1382.9 City Residual Flow @ 0 = 3307.91 City Residual Flow @ 20 = 2576.03 City Water @ 150% of Pump = 43.24 | Demand: D1 - Elevation : -1.083 D2 - System Flow : 250.608 D2 - System Pressure : 130.164 Hose (Adj City) : _____ Hose (Demand) : 100 D3 - System Demand : 350.608 Safety Margin : 45.876 |
|---|--|---|



Fittings Used Summary

Aero Automatic Sprinkler Co.
Cal Poly Center for Science LVL 1 [R/A=1]

Page 3
Date 9-25-11

Fitting Legend

| Abbrev. | Name | ½ | ¾ | 1 | 1¼ | 1½ | 2 | 2½ | 3 | 3½ | 4 | 5 | 6 | 8 | 10 | 12 | 14 | 16 | 18 | 20 | 24 |
|---------|-------------------------|--|---|------|-----|-----|-----|----|----|-----|-----|-----|----|-----|-----|----|----|----|----|-----|-----|
| B | Generic Butterfly Valve | 0 | 0 | 2.25 | 2 | 2.5 | 6 | 7 | 10 | 0 | 12 | 9 | 10 | 12 | 19 | 21 | 0 | 0 | 0 | 0 | 0 |
| C | Generic Check Vlv | 4 | 5 | 5 | 7 | 9 | 11 | 14 | 16 | 19 | 22 | 27 | 32 | 45 | 55 | 65 | 76 | 87 | 98 | 109 | 130 |
| E | 90' Standard Elbow | 2 | 2 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 10 | 12 | 14 | 18 | 22 | 27 | 35 | 40 | 45 | 50 | 61 |
| G | Generic Gate Valve | 0 | 0 | 0 | 1 | 0 | 1 | 1 | 1 | 1 | 2 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 10 | 11 | 13 |
| H | 45' Ell Grvd-Vic #11 | 0 | 0 | 1 | 1.5 | 2 | 2 | 3 | 3 | 3.5 | 3.5 | 4.5 | 5 | 6.5 | 8.5 | 10 | 18 | 20 | 23 | 25 | 30 |
| I | 90' Ell Grvd-Vic #10 | 0 | 0 | 2 | 3 | 4 | 3.5 | 6 | 5 | 8 | 7 | 8.5 | 10 | 13 | 17 | 20 | 23 | 25 | 33 | 36 | 40 |
| T | 90' Flow Thru Tee | 3 | 4 | 5 | 6 | 8 | 10 | 12 | 15 | 17 | 20 | 25 | 30 | 35 | 50 | 60 | 71 | 81 | 91 | 101 | 121 |
| Zic | Wilkins 350ADA | Fitting generates a Fixed Loss Based on Flow | | | | | | | | | | | | | | | | | | | |

Units Summary

Diameter Units Inches
Length Units Feet
Flow Units US Gallons per Minute
Pressure Units Pounds per Square Inch

Pressure / Flow Summary - STANDARD

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 1 [R/A=1]

Page 4
 Date 9-25-11

| Node No. | Elevation | K-Fact | Pt Actual | Pn | Flow Actual | Density | Area | Press Req. |
|----------|-----------|--------|-----------|----|-------------|---------|------|------------|
| S101 | 10.5 | 5.6 | 9.0 | na | 16.8 | 0.1 | 168 | 7.0 |
| S102 | 10.5 | 5.6 | 10.12 | na | 17.81 | 0.1 | 168 | 7.0 |
| S103 | 10.5 | 5.6 | 14.14 | na | 21.05 | 0.1 | 168 | 7.0 |
| S104 | 10.5 | 5.6 | 23.3 | na | 27.03 | 0.1 | 168 | 7.0 |
| S105 | 10.5 | 5.6 | 9.1 | na | 16.89 | 0.1 | 168 | 7.0 |
| S106 | 10.5 | 5.6 | 10.23 | na | 17.91 | 0.1 | 168 | 7.0 |
| S107 | 10.5 | 5.6 | 14.29 | na | 21.17 | 0.1 | 168 | 7.0 |
| S108 | 10.5 | 5.6 | 23.55 | na | 27.18 | 0.1 | 168 | 7.0 |
| S109 | 10.5 | 5.6 | 9.46 | na | 17.23 | 0.1 | 168 | 7.0 |
| S110 | 10.5 | 5.6 | 10.64 | na | 18.26 | 0.1 | 168 | 7.0 |
| S111 | 10.5 | 5.6 | 14.84 | na | 21.58 | 0.1 | 168 | 7.0 |
| S112 | 10.5 | 5.6 | 24.45 | na | 27.69 | 0.1 | 168 | 7.0 |
| L101 | 12.167 | | 8.62 | na | | | | |
| L102 | 13.167 | | 9.77 | na | | | | |
| L103 | 13.167 | | 14.08 | na | | | | |
| L104 | 13.167 | | 23.89 | na | | | | |
| L105 | 12.167 | | 8.73 | na | | | | |
| L106 | 13.167 | | 9.89 | na | | | | |
| L107 | 13.167 | | 14.24 | na | | | | |
| L108 | 13.167 | | 24.16 | na | | | | |
| L109 | 12.167 | | 9.1 | na | | | | |
| L110 | 13.167 | | 10.32 | na | | | | |
| L111 | 13.167 | | 14.84 | na | | | | |
| L112 | 13.167 | | 25.12 | na | | | | |
| M101 | 13.167 | | 25.82 | na | | | | |
| M102 | 13.167 | | 26.11 | na | | | | |
| M103 | 13.167 | | 27.13 | na | | | | |
| M104 | 13.167 | | 41.43 | na | | | | |
| M105 | 13.167 | | 51.6 | na | | | | |
| TR01 | 13.167 | | 60.33 | na | | | | |
| BR01 | 3.0 | | 126.68 | na | | | | |
| SPC1 | 12.667 | | 125.17 | na | 100.0 | | | |
| SPC2 | 12.667 | | 125.36 | na | | | | |
| PO | 1.833 | | 130.16 | na | | | | |
| PI | 1.75 | | 51.68 | na | | | | |
| POC | 6.75 | | 49.6 | na | | | | |
| BF1 | 13.0 | | 46.98 | na | | | | |
| BF2 | 13.0 | | 53.01 | na | | | | |
| SRC | 13.0 | | 53.15 | na | | | | |

The maximum velocity is 21.19 and it occurs in the pipe between nodes L111 and M103

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 1 [R/A=1]

Page 5
 Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|------------------------------|------------------|-----------|----------------|------------|-----------------------|-------------------|-------------------------|----------------|---------------------------|-------|-----------------|-------------|
| *FLOWING SPRINKLER R/A # 1 # | | | | | | | | | | | | |
| S101 to L101 | 10.500 12.167 | 5.60 | 16.80 16.8 | 1 1.049 | 1E | 2.0 0.0 0.0 | 1.667 2.000 3.667 | 120 | 9.000 -0.722 0.346 | | | Vel = 6.24 |
| L101 | | | 0.0 16.80 | | | | | | 8.624 | | K Factor = 5.72 | |
| S102 to L102 | 10.500 13.167 | 5.60 | 17.81 17.81 | 1 1.049 | 1T | 5.0 0.0 0.0 | 2.667 5.000 7.667 | 120 | 10.119 -1.155 0.805 | | | Vel = 6.61 |
| L102 | | | 0.0 17.81 | | | | | | 9.769 | | K Factor = 5.70 | |
| S103 to L103 | 10.500 13.167 | 5.60 | 21.05 21.05 | 1 1.049 | 1T | 5.0 0.0 0.0 | 2.667 5.000 7.667 | 120 | 14.135 -1.155 1.097 | | | Vel = 7.81 |
| L103 | | | 0.0 21.05 | | | | | | 14.077 | | K Factor = 5.61 | |
| S104 to L104 | 10.500 13.167 | 5.60 | 27.03 27.03 | 1 1.049 | 1T | 5.0 0.0 0.0 | 2.667 5.000 7.667 | 120 | 23.303 -1.155 1.742 | | | Vel = 10.03 |
| L104 | | | 0.0 27.03 | | | | | | 23.890 | | K Factor = 5.53 | |
| S105 to L105 | 10.500 12.167 | 5.60 | 16.89 16.89 | 1 1.049 | 1E | 2.0 0.0 0.0 | 1.667 2.000 3.667 | 120 | 9.100 -0.722 0.349 | | | Vel = 6.27 |
| L105 | | | 0.0 16.89 | | | | | | 8.727 | | K Factor = 5.72 | |
| S106 to L106 | 10.500 13.167 | 5.60 | 17.91 17.91 | 1 1.049 | 1T | 5.0 0.0 0.0 | 2.667 5.000 7.667 | 120 | 10.231 -1.155 0.813 | | | Vel = 6.65 |
| L106 | | | 0.0 17.91 | | | | | | 9.889 | | K Factor = 5.70 | |
| S107 to L107 | 10.500 13.167 | 5.60 | 21.17 21.17 | 1 1.049 | 1T | 5.0 0.0 0.0 | 2.667 5.000 7.667 | 120 | 14.288 -1.155 1.109 | | | Vel = 7.86 |
| L107 | | | 0.0 21.17 | | | | | | 14.242 | | K Factor = 5.61 | |
| S108 to L108 | 10.500 13.167 | 5.60 | 27.18 27.18 | 1 1.049 | 1T | 5.0 0.0 0.0 | 2.667 5.000 7.667 | 120 | 23.551 -1.155 1.759 | | | Vel = 10.09 |
| L108 | | | 0.0 27.18 | | | | | | 24.155 | | K Factor = 5.53 | |
| S109 to L109 | 10.500 12.167 | 5.60 | 17.23 17.23 | 1 1.049 | 1E | 2.0 0.0 0.0 | 1.667 2.000 3.667 | 120 | 9.464 -0.722 0.362 | | | Vel = 6.40 |
| L109 | | | 0.0 17.23 | | | | | | 9.104 | | K Factor = 5.71 | |
| S110 to L110 | 10.500 13.167 | 5.60 | 18.26 18.26 | 1 1.049 | 1T | 5.0 0.0 0.0 | 2.667 5.000 7.667 | 120 | 10.637 -1.155 0.843 | | | Vel = 6.78 |

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 1 [R/A=1]

Page 6
 Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|-----------------------|------------------|-----------|--------------|------------|-----------------------|-------------------|---------------------------|----------------|---------------------------|-------|------------------|-------|
| L110 | | | 0.0 18.26 | | | | | | 10.325 | | K Factor = 5.68 | |
| S111 to L111 | 10.500 13.167 | 5.60 | 21.58 | 1 | 1T | 5.0 0.0 0.0 | 2.667 5.000 7.667 | 120 | 14.844 -1.155 1.148 | | Vel = 8.01 | |
| L111 | | | 0.0 21.58 | | | | | | 14.837 | | K Factor = 5.60 | |
| S112 to L112 | 10.500 13.167 | 5.60 | 27.69 | 1 | 1T | 5.0 0.0 0.0 | 2.667 5.000 7.667 | 120 | 24.448 -1.155 1.822 | | Vel = 10.28 | |
| L112 | | | 0.0 27.69 | | | | | | 25.115 | | K Factor = 5.53 | |
| *BRANCH LINES R/A # 1 | | | | | | | | | | | | |
| L101 to L102 | 12.167 13.167 | | 16.80 | 1 | 2E | 4.0 0.0 0.0 | 12.750 4.000 16.750 | 120 | 8.624 -0.433 1.578 | | Vel = 6.24 | |
| L102 to L103 | 13.167 13.167 | | 17.81 | 1 | | 0.0 0.0 0.0 | 12.000 0.0 12.000 | 120 | 9.769 0.0 4.308 | | Vel = 12.85 | |
| L103 to M101 | 13.167 13.167 | | 21.06 | 1 | 1T | 5.0 0.0 0.0 | 8.583 5.000 13.583 | 120 | 14.077 0.0 11.745 | | Vel = 20.67 | |
| M101 | | | 0.0 55.67 | | | | | | 25.822 | | K Factor = 10.96 | |
| L104 to M101 | 13.167 13.167 | | 27.03 | 1 | 1T | 5.0 0.0 0.0 | 3.500 5.000 8.500 | 120 | 23.890 0.0 1.932 | | Vel = 10.03 | |
| M101 | | | 0.0 27.03 | | | | | | 25.822 | | K Factor = 5.32 | |
| L105 to L106 | 12.167 13.167 | | 16.89 | 1 | 2E | 4.0 0.0 0.0 | 12.750 4.000 16.750 | 120 | 8.727 -0.433 1.595 | | Vel = 6.27 | |
| L106 to L107 | 13.167 13.167 | | 17.91 | 1 | | 0.0 0.0 0.0 | 12.000 0.0 12.000 | 120 | 9.889 0.0 4.353 | | Vel = 12.92 | |
| L107 to M102 | 13.167 13.167 | | 21.17 | 1 | 1T | 5.0 0.0 0.0 | 8.583 5.000 13.583 | 120 | 14.242 0.0 11.864 | | Vel = 20.78 | |
| M102 | | | 0.0 55.97 | | | | | | 26.106 | | K Factor = 10.95 | |
| L108 to M102 | 13.167 13.167 | | 27.18 | 1 | 1T | 5.0 0.0 0.0 | 3.500 5.000 8.500 | 120 | 24.155 0.0 1.951 | | Vel = 10.09 | |
| M102 | | | 0.0 27.18 | | | | | | 26.106 | | K Factor = 5.32 | |
| L109 to L110 | 12.167 13.167 | | 17.23 | 1 | 2E | 4.0 0.0 0.0 | 12.750 4.000 16.750 | 120 | 9.104 -0.433 1.654 | | Vel = 6.40 | |

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 1 [R/A=1]

Page 7
 Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|--------------------------|------------------|-----------|------------------|--------------|-----------------------|----------------------|----------------------------|----------------|----------------------------|-------------|-------------------|-------|
| L110 to L111 | 13.167 13.167 | | 18.26 35.49 | 1 1.049 | | 0.0 0.0 | 12.000 0.0 | 120 0.3760 | 10.325 0.0 4.512 | | | |
| | | | | | | | | | | Vel = 13.17 | | |
| L111 to M103 | 13.167 13.167 | | 21.58 57.07 | 1 1.049 | 1T | 5.0 0.0 | 8.583 5.000 | 120 0.9053 | 14.837 0.0 12.297 | | | |
| | | | | | | | | | | Vel = 21.19 | | |
| M103 | | | 0.0 57.07 | | | | | | 27.134 | | K Factor = 10.96 | |
| L112 to M103 | 13.167 13.167 | | 27.69 27.69 | 1 1.049 | 1T | 5.0 0.0 | 3.500 5.000 | 120 0.2375 | 25.115 0.0 2.019 | | | |
| | | | | | | | | | | Vel = 10.28 | | |
| M103 | | | 0.0 27.69 | | | | | | 27.134 | | K Factor = 5.32 | |
| *FEED MAIN | | | | | | | | | | | | |
| M101 to M102 | 13.167 13.167 | | 82.70 82.7 | 2.5 2.635 | | 0.0 0.0 | 14.000 0.0 | 120 0.0203 | 25.822 0.0 0.284 | | | |
| | | | | | | | | | | Vel = 4.87 | | |
| M102 to M103 | 13.167 13.167 | | 83.15 165.85 | 2.5 2.635 | | 0.0 0.0 | 14.000 0.0 | 120 0.0734 | 26.106 0.0 1.028 | | | |
| | | | | | | | | | | Vel = 9.76 | | |
| M103 to M104 | 13.167 13.167 | | 84.76 250.61 | 2.5 2.635 | 1T | 16.474 0.0 | 74.250 16.474 | 120 0.1576 | 27.134 0.0 14.299 | | | |
| | | | | | | | | | | Vel = 14.74 | | |
| M104 to M105 | 13.167 13.167 | | 0.0 250.61 | 2.5 2.635 | 1H 1T | 4.119 16.474 | 43.917 20.593 | 120 0.1576 | 41.433 0.0 10.168 | | | |
| | | | | | | | | | | Vel = 14.74 | | |
| M105 to TR01 | 13.167 13.167 | | 0.0 250.61 | 3 3.26 | 4I 1T | 26.879 20.159 | 109.083 47.038 | 120 0.0559 | 51.601 0.0 8.727 | | | |
| | | | | | | | | | | Vel = 9.63 | | |
| TR01 to BR01 | 13.167 3 | | 0.0 250.61 | 3 3.26 | 1I | 6.72 0.0 | 10.167 6.720 | 120 0.0559 | 60.328 65.403 0.944 | | * Fixed loss = 61 | |
| | | | | | | | | | | Vel = 9.63 | | |
| BR01 to SPC1 | 3 12.667 | | 0.0 250.61 | 3 3.26 | 2I 1T | 13.44 20.159 | 14.333 33.599 | 120 0.0559 | 126.675 -4.187 2.680 | | | |
| | | | | | | | | | | Vel = 9.63 | | |
| SPC1 to SPC2 | 12.667 12.667 | H100 | 100.00 350.61 | 6 6.065 | 1T | 30.0 0.0 | 7.833 30.000 | 120 0.0051 | 125.168 0.0 0.192 | | | |
| | | | | | | | | | | Vel = 3.89 | | |
| SPC2 to PO | 12.667 1.833 | | 0.0 350.61 | 8 7.981 | 1I 1B 1C | 13.0 12.0 45.0 | 14.750 70.000 84.750 | 120 0.0013 | 125.360 4.692 0.112 | | | |
| | | | | | | | | | | Vel = 2.25 | | |
| PO | | | 0.0 350.61 | | | | | | 130.164 | | K Factor = 30.73 | |
| System Demand Pressure | | | | | | 130.164 | | | | | | |
| Safety Margin | | | | | | 45.876 | | | | | | |
| Continuation Pressure | | | | | | 176.040 | | | | | | |
| Pressure @ Pump Outlet | | | | | | 176.040 | | | | | | |
| Pressure From Pump Curve | | | | | | -124.362 | | | | | | |
| Pressure @ Pump Inlet | | | | | | 51.678 | | | | | | |

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 1 [R/A=1]

Page 8
 Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|----------------------|----------------|-----------|---------------|------------|-----------------------|-----------------|-------------------------|----------------|------------------|-------|------------------------------------|-------|
| PI to POC | 1.750 6.750 | | 0.0 350.61 | 8 7.981 | 1G 1I | 4.0 13.0 | 14.000 52.000 | 120 0.0013 | 51.678 -2.166 | | Vel = 2.25 | |
| POC to BF1 | 6.750 13 | | 0.0 350.61 | 8 8.27 | 2E | 56.936 0.0 | 41.000 56.936 | 140 0.0008 | 49.600 -2.707 | | Vel = 2.09 | |
| BF1 to BF2 | 13 13 | | 0.0 350.61 | 8 7.981 | 1Zic | 0.0 0.0 | 4.000 0.0 | 120 0.0012 | 46.976 6.031 | | * Fixed loss = 6.031 Vel = 2.25 | |
| BF2 to SRC | 13 13 | | 0.0 350.61 | 8 8.27 | 2E 1G | 56.936 6.326 | 46.000 118.616 | 140 0.0008 | 53.012 0.0 | | Vel = 2.09 | |
| SRC | | | 0.0 350.61 | | | | | | 53.150 | | K Factor = 48.09 | |

This page intentionally left blank.



**AUTOMATIC
SPRINKLER CO.**

21605 North Central Ave. 623.580.7800
Phoenix, Arizona 85024 Fax 623.434.3154

AZ-L16-234798 CA-C16-901529
AZ-C16-234797 NV-C41-69370
UT-S370-6690455-5501 NM-MS 12-354807



Fire Protection by Computer Design

Aero Automatic Sprinkler Co.
21605 N. Central Ave.
Phoenix, Arizona 85024
623-580-7800

Job Name : Cal Poly Center for Science LVL 1 [R/A=2]
Building : FP-6.01W
Location : San Luis Obispo, Ca.
System : 1-2
Contract : 10034
Data File : Cal Poly CFS LVL 1-2.WXF

HYDRAULIC CALCULATIONS
for

Project name: Cal Poly Center For Science
Location: San Luis Obispo, Ca.
Drawing no: FP-6.01W
Date: 9-25-2011

Design

Remote area number: 1-2
Remote area location: 1 st. Floor Lecture
Occupancy classification: Light Hazard
Density: 0.10 - Gpm/SqFt
Area of application: 1500 - SqFt
Coverage per sprinkler: 163 - SqFt
Type of sprinklers calculated: Tyco; Mod. TY-FRB; 1/2"; 1/2";K=5.6; 155 Deg
No. of sprinklers calculated: 16
In-rack demand: N/A - GPM
Hose streams: 100 - GPM
Total water required (including hose streams): 428.4 - GPM @ 45.59 - Psi
Type of system: WET
Volume of dry or preaction system: N/A - Gal

Water supply information

Date: 8-19-2011
Location: N. Poly View Drive
Source: Fluid Resource Management

Name of contractor: Aero Automatic Sprinkler Co.
Address: 21605 N. Central Ave. Phoenix, Az. 85024
Phone number: 623-580-7847
Name of designer: Neal Larsen

Authority having jurisdiction: C.S.F.M.


Notes: (Include peaking information or gridded systems here.) Flow Test Information :
Hydrant # 63; Static = 60 psi; Res.= 55 psi {Elev.=351.0'}
Hydrant # 64; Flow = 914 gpm
FLOW TEST USED IN HYD. CALCS REDUCED BY 10 % [STATIC=54psi; RES.=49psi]

Water Supply Curve (C)

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 1 [R/A=2]

Page 2
 Date 9-25-11

| | | |
|---|--|---|
| City Water Supply: C1 - Static Pressure : 54 C2 - Residual Pressure: 49 C2 - Residual Flow : 914 City Water Adjusted to Pump Inlet for Pf - Elev - Hose Flow A1 - Adjusted Static: 51.872 A2 - Adj Resid : 49.314 @ 790.2 A3 - Adj Resid : 40.224 @ 1382.9 | Pump Data: P1 - Pump Churn Pressure : 125.2 P2 - Pump Rated Pressure : 110.9 P2 - Pump Rated Flow : 790.2 P3 - Pump Pressure @ Max Flow : 67.9 P3 - Pump Max Flow : 1382.9 City Residual Flow @ 0 = 3307.91 City Residual Flow @ 20 = 2576.03 City Water @ 150% of Pump = 43.24 | Demand: D1 - Elevation : 9.420 D2 - System Flow : 328.401 D2 - System Pressure : 167.582 Hose (Adj City) : _____ Hose (Demand) : 100 D3 - System Demand : 428.401 Safety Margin : 7.179 |
|---|--|---|



Fittings Used Summary

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 1 [R/A=2]

Page 3
 Date 9-25-11

Fitting Legend

| Abbrev. | Name | ½ | ¾ | 1 | 1¼ | 1½ | 2 | 2½ | 3 | 3½ | 4 | 5 | 6 | 8 | 10 | 12 | 14 | 16 | 18 | 20 | 24 |
|---------|-------------------------|--|---|------|-----|-----|-----|----|----|-----|-----|-----|----|-----|-----|----|----|----|----|-----|-----|
| B | Generic Butterfly Valve | 0 | 0 | 2.25 | 2 | 2.5 | 6 | 7 | 10 | 0 | 12 | 9 | 10 | 12 | 19 | 21 | 0 | 0 | 0 | 0 | 0 |
| C | Generic Check Vlv | 4 | 5 | 5 | 7 | 9 | 11 | 14 | 16 | 19 | 22 | 27 | 32 | 45 | 55 | 65 | 76 | 87 | 98 | 109 | 130 |
| E | 90' Standard Elbow | 2 | 2 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 10 | 12 | 14 | 18 | 22 | 27 | 35 | 40 | 45 | 50 | 61 |
| G | Generic Gate Valve | 0 | 0 | 0 | 1 | 0 | 1 | 1 | 1 | 1 | 2 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 10 | 11 | 13 |
| H | 45' Ell Grvd-Vic #11 | 0 | 0 | 1 | 1.5 | 2 | 2 | 3 | 3 | 3.5 | 3.5 | 4.5 | 5 | 6.5 | 8.5 | 10 | 18 | 20 | 23 | 25 | 30 |
| I | 90' Ell Grvd-Vic #10 | 0 | 0 | 2 | 3 | 4 | 3.5 | 6 | 5 | 8 | 7 | 8.5 | 10 | 13 | 17 | 20 | 23 | 25 | 33 | 36 | 40 |
| T | 90' Flow Thru Tee | 3 | 4 | 5 | 6 | 8 | 10 | 12 | 15 | 17 | 20 | 25 | 30 | 35 | 50 | 60 | 71 | 81 | 91 | 101 | 121 |
| Zic | Wilkens 350ADA | Fitting generates a Fixed Loss Based on Flow | | | | | | | | | | | | | | | | | | | |

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Pressure / Flow Summary - STANDARD

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 1 [R/A=2]

Page 4
 Date 9-25-11

| Node No. | Elevation | K-Fact | Pt Actual | Pn | Flow Actual | Density | Area | Press Req. |
|----------|-----------|--------|-----------|----|-------------|---------|------|------------|
| S121 | 34.75 | 5.6 | 7.0 | na | 14.82 | 0.1 | 117 | 7.0 |
| S122 | 34.75 | 5.6 | 7.93 | na | 15.77 | 0.1 | 124 | 7.0 |
| S123 | 34.75 | 5.6 | 11.11 | na | 18.67 | 0.1 | 124 | 7.0 |
| S124 | 34.75 | 5.6 | 12.56 | na | 19.84 | 0.1 | 124 | 7.0 |
| S125 | 28.833 | 5.6 | 10.5 | na | 18.15 | 0.1 | 143 | 7.0 |
| S126 | 28.833 | 5.6 | 11.19 | na | 18.73 | 0.1 | 143 | 7.0 |
| S127 | 28.833 | 5.6 | 14.14 | na | 21.06 | 0.1 | 143 | 7.0 |
| S128 | 25.833 | 5.6 | 11.6 | na | 19.07 | 0.1 | 143 | 7.0 |
| S129 | 25.833 | 5.6 | 12.13 | na | 19.5 | 0.1 | 143 | 7.0 |
| S130 | 25.833 | 5.6 | 15.36 | na | 21.95 | 0.1 | 143 | 7.0 |
| S131 | 22.833 | 5.6 | 13.67 | na | 20.71 | 0.1 | 143 | 7.0 |
| S132 | 22.833 | 5.6 | 14.36 | na | 21.22 | 0.1 | 163 | 7.0 |
| S133 | 22.833 | 5.6 | 18.06 | na | 23.8 | 0.1 | 163 | 7.0 |
| S134 | 19.833 | 5.6 | 17.51 | na | 23.43 | 0.1 | 143 | 7.0 |
| S135 | 19.833 | 5.6 | 19.32 | na | 24.61 | 0.1 | 114 | 7.0 |
| S136 | 19.833 | 5.6 | 23.35 | na | 27.06 | 0.1 | 114 | 7.0 |
| L121 | 36.917 | | 6.37 | na | | | | |
| L122 | 36.917 | | 7.59 | na | | | | |
| L123 | 36.917 | | 11.0 | na | | | | |
| L124 | 36.917 | | 12.54 | na | | | | |
| L125 | 36.0 | | 8.4 | na | | | | |
| L126 | 36.0 | | 10.01 | na | | | | |
| L127 | 36.0 | | 13.44 | na | | | | |
| L128 | 34.5 | | 9.12 | na | | | | |
| L129 | 34.5 | | 10.59 | na | | | | |
| L130 | 34.5 | | 14.36 | na | | | | |
| L131 | 33.0 | | 11.38 | na | | | | |
| L132 | 33.0 | | 12.71 | na | | | | |
| L133 | 33.0 | | 17.08 | na | | | | |
| L134 | 31.5 | | 16.04 | na | | | | |
| L135 | 31.5 | | 17.74 | na | | | | |
| L136 | 31.5 | | 22.43 | na | | | | |
| M121 | 36.917 | | 14.67 | na | | | | |
| M122 | 36.0 | | 15.16 | na | | | | |
| M123 | 34.5 | | 16.22 | na | | | | |
| M124 | 33.0 | | 19.23 | na | | | | |
| M125 | 31.5 | | 24.65 | na | | | | |
| M105 | 13.167 | | 71.73 | na | | | | |
| TR01 | 13.167 | | 86.12 | na | | | | |
| BR01 | 3.0 | | 162.22 | na | | | | |
| SPC1 | 12.667 | | 162.45 | na | 100.0 | | | |
| SPC2 | 12.667 | | 162.73 | na | | | | |
| PO | 1.833 | | 167.58 | na | | | | |
| PI | 1.75 | | 51.42 | na | | | | |
| POC | 6.75 | | 49.38 | na | | | | |
| BF1 | 13.0 | | 46.8 | na | | | | |
| BF2 | 13.0 | | 52.57 | na | | | | |
| SRC | 13.0 | | 52.77 | na | | | | |

The maximum velocity is 19.32 and it occurs in the pipe between nodes M125 and M105

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 1 [R/A=2]

Page 5
 Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|----------------------------|------------------|-----------|----------------|------------|-----------------------|------------|-------------------------|----------------|------------------|------------|-------|-------|
| *FLOWING SPRINKLER R/A # 2 | | | | | | | | | | | | |
| S121 to L121 | 34.750 36.917 | 5.60 | 14.82 14.82 | 1 1.049 | 1E | 2.0 0.0 | 2.167 2.000 | 120 | 7.000 -0.939 | | | |
| | | | 0.0 | | | | 4.167 | 0.0749 | 0.312 | Vel = | 5.50 | |
| L121 | | | 14.82 | | | | | | 6.373 | K Factor = | 5.87 | |
| S122 to L122 | 34.750 36.917 | 5.60 | 15.77 15.77 | 1 1.049 | 1T | 5.0 0.0 | 2.167 5.000 | 120 | 7.930 -0.939 | | | |
| | | | 0.0 | | | | 7.167 | 0.0840 | 0.602 | Vel = | 5.85 | |
| L122 | | | 15.77 | | | | | | 7.593 | K Factor = | 5.72 | |
| S123 to L123 | 34.750 36.917 | 5.60 | 18.67 18.67 | 1 1.049 | 1T | 5.0 0.0 | 2.167 5.000 | 120 | 11.113 -0.939 | | | |
| | | | 0.0 | | | | 7.167 | 0.1147 | 0.822 | Vel = | 6.93 | |
| L123 | | | 18.67 | | | | | | 10.996 | K Factor = | 5.63 | |
| S124 to L124 | 34.750 36.917 | 5.60 | 19.84 19.84 | 1 1.049 | 1T | 5.0 0.0 | 2.167 5.000 | 120 | 12.555 -0.939 | | | |
| | | | 0.0 | | | | 7.167 | 0.1284 | 0.920 | Vel = | 7.37 | |
| L124 | | | 19.84 | | | | | | 12.536 | K Factor = | 5.60 | |
| S125 to L125 | 28.833 36 | 5.60 | 18.15 18.15 | 1 1.049 | 1E | 2.0 0.0 | 7.167 2.000 | 120 | 10.504 -3.104 | | | |
| | | | 0.0 | | | | 9.167 | 0.1088 | 0.997 | Vel = | 6.74 | |
| L125 | | | 18.15 | | | | | | 8.397 | K Factor = | 6.26 | |
| S126 to L126 | 28.833 36 | 5.60 | 18.73 18.73 | 1 1.049 | 1E 1T | 2.0 5.0 | 9.667 7.000 | 120 | 11.192 -3.104 | | | |
| | | | 0.0 | | | | 16.667 | 0.1153 | 1.921 | Vel = | 6.95 | |
| L126 | | | 18.73 | | | | | | 10.009 | K Factor = | 5.92 | |
| S127 to L127 | 28.833 36 | 5.60 | 21.06 21.06 | 1 1.049 | 1E 1T | 2.0 5.0 | 9.750 7.000 | 120 | 14.144 -3.104 | | | |
| | | | 0.0 | | | | 16.750 | 0.1432 | 2.399 | Vel = | 7.82 | |
| L127 | | | 21.06 | | | | | | 13.439 | K Factor = | 5.74 | |
| S128 to L128 | 25.833 34.500 | 5.60 | 19.07 19.07 | 1 1.049 | 1E | 2.0 0.0 | 8.667 2.000 | 120 | 11.601 -3.754 | | | |
| | | | 0.0 | | | | 10.667 | 0.1192 | 1.271 | Vel = | 7.08 | |
| L128 | | | 19.07 | | | | | | 9.118 | K Factor = | 6.32 | |
| S129 to L129 | 25.833 34.500 | 5.60 | 19.50 19.5 | 1 1.049 | 1E 1T | 2.0 5.0 | 10.833 7.000 | 120 | 12.127 -3.754 | | | |
| | | | 0.0 | | | | 17.833 | 0.1242 | 2.215 | Vel = | 7.24 | |
| L129 | | | 19.50 | | | | | | 10.588 | K Factor = | 5.99 | |
| S130 to L130 | 25.833 34.500 | 5.60 | 21.95 21.95 | 1 1.049 | 1E 1T | 2.0 5.0 | 10.833 7.000 | 120 | 15.361 -3.754 | | | |
| | | | 0.0 | | | | 17.833 | 0.1546 | 2.757 | Vel = | 8.15 | |

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 1 [R/A=2]

Page 6
 Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|-----------------------|------------------|-----------|--------------|------------|-----------------------|------------|-------------------------|----------------|------------------|-------|------------------|-------|
| L130 | | | 0.0 21.95 | | | | | | 14.364 | | K Factor = 5.79 | |
| S131 to L131 | 22.833 33 | 5.60 | 20.71 | 1 | 1T | 5.0 0.0 | 10.167 5.000 | 120 | 13.674 -4.403 | | | |
| | | | 20.71 | 1.049 | | 0.0 | 15.167 | 0.1388 | 2.105 | | Vel = 7.69 | |
| L131 | | | 0.0 20.71 | | | | | | 11.376 | | K Factor = 6.14 | |
| S132 to L132 | 22.833 33 | 5.60 | 21.22 | 1 | 1E 1T | 2.0 5.0 | 11.917 7.000 | 120 | 14.362 -4.403 | | | |
| | | | 21.22 | 1.049 | | 0.0 | 18.917 | 0.1452 | 2.747 | | Vel = 7.88 | |
| L132 | | | 0.0 21.22 | | | | | | 12.706 | | K Factor = 5.95 | |
| S133 to L133 | 22.833 33 | 5.60 | 23.80 | 1 | 1E 1T | 2.0 5.0 | 12.083 7.000 | 120 | 18.057 -4.403 | | | |
| | | | 23.8 | 1.049 | | 0.0 | 19.083 | 0.1794 | 3.424 | | Vel = 8.84 | |
| L133 | | | 0.0 23.80 | | | | | | 17.078 | | K Factor = 5.76 | |
| S134 to L134 | 19.833 31.500 | 5.60 | 23.44 | 1 | 1E 1T | 2.0 5.0 | 13.500 7.000 | 120 | 17.512 -5.053 | | | |
| | | | 23.44 | 1.049 | | 0.0 | 20.500 | 0.1745 | 3.577 | | Vel = 8.70 | |
| L134 | | | 0.0 23.44 | | | | | | 16.036 | | K Factor = 5.85 | |
| S135 to L135 | 19.833 31.500 | 5.60 | 24.61 | 1 | 1T | 5.0 0.0 | 13.167 5.000 | 120 | 19.319 -5.053 | | | |
| | | | 24.61 | 1.049 | | 0.0 | 18.167 | 0.1911 | 3.471 | | Vel = 9.14 | |
| L135 | | | 0.0 24.61 | | | | | | 17.737 | | K Factor = 5.84 | |
| S136 to L136 | 19.833 31.500 | 5.60 | 27.06 | 1 | 1T | 5.0 0.0 | 13.167 5.000 | 120 | 23.350 -5.053 | | | |
| | | | 27.06 | 1.049 | | 0.0 | 18.167 | 0.2276 | 4.135 | | Vel = 10.05 | |
| L136 | | | 0.0 27.06 | | | | | | 22.432 | | K Factor = 5.71 | |
| *BRANCH LINES R/A # 2 | | | | | | | | | | | | |
| L121 to L122 | 36.917 36.917 | | 14.82 | 1 | 1E | 2.0 0.0 | 14.333 2.000 | 120 | 6.373 0.0 | | | |
| | | | 14.82 | 1.049 | | 0.0 | 16.333 | 0.0747 | 1.220 | | Vel = 5.50 | |
| L122 to L123 | 36.917 36.917 | | 15.77 | 1 | | 0.0 0.0 | 11.917 0.0 | 120 | 7.593 0.0 | | | |
| | | | 30.59 | 1.049 | | 0.0 | 11.917 | 0.2856 | 3.403 | | Vel = 11.36 | |
| L123 to M121 | 36.917 36.917 | | 18.67 | 1 | 1T | 5.0 0.0 | 0.333 5.000 | 120 | 10.996 0.0 | | | |
| | | | 49.26 | 1.049 | | 0.0 | 5.333 | 0.6895 | 3.677 | | Vel = 18.29 | |
| M121 | | | 0.0 49.26 | | | | | | 14.673 | | K Factor = 12.86 | |
| L124 to M121 | 36.917 36.917 | | 19.84 | 1 | 1T | 5.0 0.0 | 11.667 5.000 | 120 | 12.536 0.0 | | | |
| | | | 19.84 | 1.049 | | 0.0 | 16.667 | 0.1282 | 2.137 | | Vel = 7.37 | |

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 1 [R/A=2]

Page 7
 Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|----------------------|------------------|-----------|--------------|------------|-----------------------|-----|-------------------------|----------------|----------------|-------|-----------------|-------|
| M121 | | | 0.0 19.84 | | | | | | 14.673 | | K Factor = 5.18 | |
| L125 to L126 | 36 36 | | 18.15 | 1 | | 0.0 | 14.833 | 120 | 8.397 | | | |
| | | | | | | 0.0 | 0.0 | | 0.0 | | | |
| L126 to M122 | 36 36 | | 18.15 | 1.049 | | 0.0 | 14.833 | 0.1087 | 1.612 | | Vel = 6.74 | |
| | | | | | | 5.0 | 7.750 | 120 | 10.009 | | | |
| | | | | | | 0.0 | 5.000 | | 0.0 | | | |
| | | | 36.88 | 1.049 | | 0.0 | 12.750 | 0.4038 | 5.148 | | Vel = 13.69 | |
| M122 | | | 0.0 36.88 | | | | | | 15.157 | | K Factor = 9.47 | |
| L127 to M122 | 36 36 | | 21.06 | 1 | 1T | 5.0 | 7.000 | 120 | 13.439 | | | |
| | | | | | | 0.0 | 5.000 | | 0.0 | | | |
| | | | 21.06 | 1.049 | | 0.0 | 12.000 | 0.1432 | 1.718 | | Vel = 7.82 | |
| M122 | | | 0.0 21.06 | | | | | | 15.157 | | K Factor = 5.41 | |
| L128 to L129 | 34.500 34.500 | | 19.07 | 1 | | 0.0 | 12.333 | 120 | 9.118 | | | |
| | | | | | | 0.0 | 0.0 | | 0.0 | | | |
| L129 to M123 | 34.500 34.500 | | 19.07 | 1.049 | | 0.0 | 12.333 | 0.1192 | 1.470 | | Vel = 7.08 | |
| | | | | | | 5.0 | 7.833 | 120 | 10.588 | | | |
| | | | | | | 0.0 | 5.000 | | 0.0 | | | |
| | | | 38.58 | 1.049 | | 0.0 | 12.833 | 0.4387 | 5.630 | | Vel = 14.32 | |
| M123 | | | 0.0 38.58 | | | | | | 16.218 | | K Factor = 9.58 | |
| L130 to M123 | 34.500 34.500 | | 21.95 | 1 | 1T | 5.0 | 7.000 | 120 | 14.364 | | | |
| | | | | | | 0.0 | 5.000 | | 0.0 | | | |
| | | | 21.95 | 1.049 | | 0.0 | 12.000 | 0.1545 | 1.854 | | Vel = 8.15 | |
| M123 | | | 0.0 21.95 | | | | | | 16.218 | | K Factor = 5.45 | |
| L131 to L132 | 33 33 | | 20.71 | 1 | | 0.0 | 9.583 | 120 | 11.376 | | | |
| | | | | | | 0.0 | 0.0 | | 0.0 | | | |
| L132 to M124 | 33 33 | | 20.71 | 1.049 | | 0.0 | 9.583 | 0.1388 | 1.330 | | Vel = 7.69 | |
| | | | | | | 5.0 | 7.750 | 120 | 12.706 | | | |
| | | | | | | 0.0 | 5.000 | | 0.0 | | | |
| | | | 41.93 | 1.049 | | 0.0 | 12.750 | 0.5118 | 6.526 | | Vel = 15.57 | |
| M124 | | | 0.0 41.93 | | | | | | 19.232 | | K Factor = 9.56 | |
| L133 to M124 | 33 33 | | 23.80 | 1 | 1T | 5.0 | 7.000 | 120 | 17.078 | | | |
| | | | | | | 0.0 | 5.000 | | 0.0 | | | |
| | | | 23.8 | 1.049 | | 0.0 | 12.000 | 0.1795 | 2.154 | | Vel = 8.84 | |
| M124 | | | 0.0 23.80 | | | | | | 19.232 | | K Factor = 5.43 | |
| L134 to L135 | 31.500 31.500 | | 23.44 | 1 | | 0.0 | 9.750 | 120 | 16.036 | | | |
| | | | | | | 0.0 | 0.0 | | 0.0 | | | |
| L135 to M125 | 31.500 31.500 | | 23.44 | 1.049 | | 0.0 | 9.750 | 0.1745 | 1.701 | | Vel = 8.70 | |
| | | | | | | 5.0 | 5.500 | 120 | 17.737 | | | |
| | | | | | | 0.0 | 5.000 | | 0.0 | | | |
| | | | 48.05 | 1.049 | | 0.0 | 10.500 | 0.6586 | 6.915 | | Vel = 17.84 | |

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 1 [R/A=2]

Page 8
 Date 9-25-11


| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|--------------------------|------------------|-----------|---------------|------------|-----------------------|----------------------|----------------------------|----------------|---------------------------|-------|----------------------|------------|
| M125 | | | 0.0 48.05 | | | | | | 24.652 | | K Factor = 9.68 | |
| L136 to M125 | 31.500 31.500 | | 27.06 | 1 | 1T | 5.0 0.0 | 4.750 5.000 | 120 | 22.432 0.0 | | | |
| M125 | | | 27.06 | 1.049 | | 0.0 | 9.750 | 0.2277 | 2.220 | | Vel = 10.05 | |
| M125 | | | 0.0 27.06 | | | | | | 24.652 | | K Factor = 5.45 | |
| *FEED MAIN | | | | | | | | | | | | |
| M121 to M122 | 36.917 36 | | 69.10 | 2.5 | | 0.0 0.0 | 6.000 0.0 | 120 | 14.673 0.397 | | | |
| M122 | | | 69.1 | 2.635 | | 0.0 | 6.000 | 0.0145 | 0.087 | | Vel = 4.07 | |
| M122 to M123 | 36 34.500 | | 57.94 | 2.5 | | 0.0 0.0 | 9.167 0.0 | 120 | 15.157 0.650 | | | |
| M123 | | | 127.04 | 2.635 | | 0.0 | 9.167 | 0.0448 | 0.411 | | Vel = 7.47 | |
| M123 to M124 | 34.500 33 | | 60.52 | 2.5 | 1T | 16.474 0.0 | 9.167 16.474 | 120 | 16.218 0.650 | | | |
| M124 | | | 187.56 | 2.635 | | 0.0 | 25.641 | 0.0922 | 2.364 | | Vel = 11.03 | |
| M124 to M125 | 33 31.500 | | 65.73 | 2.5 | 1H 1T | 4.119 16.474 | 9.083 20.593 | 120 | 19.232 0.650 | | | |
| M125 | | | 253.29 | 2.635 | | 0.0 | 29.676 | 0.1607 | 4.770 | | Vel = 14.90 | |
| M125 to M105 | 31.500 13.167 | | 75.11 | 2.5 | 2T 3I | 32.948 24.711 | 92.917 57.659 | 120 | 24.652 7.940 | | | |
| M105 | | | 328.4 | 2.635 | | 0.0 | 150.576 | 0.2599 | 39.134 | | Vel = 19.32 | |
| M105 to TR01 | 13.167 13.167 | | 0.0 | 3 | 4I 1T | 26.879 20.159 | 109.083 47.038 | 120 | 71.726 0.0 | | | |
| TR01 | | | 328.4 | 3.26 | | 0.0 | 156.121 | 0.0922 | 14.391 | | Vel = 12.62 | |
| TR01 to BR01 | 13.167 3 | | 0.0 | 3 | 1I | 6.72 0.0 | 10.167 6.720 | 120 | 86.117 74.543 | | * Fixed loss = 70.14 | |
| BR01 | | | 328.4 | 3.26 | | 0.0 | 16.887 | 0.0922 | 1.557 | | Vel = 12.62 | |
| BR01 to SPC1 | 3 12.667 | | 0.0 | 3 | 2I 1T | 13.44 20.159 | 14.333 33.599 | 120 | 162.217 -4.187 | | | |
| SPC1 | | | 328.4 | 3.26 | | 0.0 | 47.932 | 0.0922 | 4.419 | | Vel = 12.62 | |
| SPC1 to SPC2 | 12.667 12.667 | H100 | 100.00 | 6 | 1T | 30.0 0.0 | 7.917 30.000 | 120 | 162.449 0.0 | | | |
| SPC2 | | | 428.4 | 6.065 | | 0.0 | 37.917 | 0.0073 | 0.278 | | Vel = 4.76 | |
| SPC2 to PO | 12.667 1.833 | | 0.0 | 8 | 1I 1B 1C | 13.0 12.0 45.0 | 14.750 70.000 84.750 | 120 | 162.727 4.692 0.163 | | | |
| PO | | | 0.0 428.40 | | | | | | 167.582 | | K Factor = 33.09 | |
| System Demand Pressure | | | | | | 167.582 | | | | | | |
| Safety Margin | | | | | | 7.179 | | | | | | |
| Continuation Pressure | | | | | | 174.761 | | | | | | |
| Pressure @ Pump Outlet | | | | | | 174.761 | | | | | | |
| Pressure From Pump Curve | | | | | | -123.339 | | | | | | |
| Pressure @ Pump Inlet | | | | | | 51.422 | | | | | | |
| PI to POC | 1.750 6.750 | | 0.0 | 8 | 1G 1I 1T | 4.0 13.0 35.0 | 14.000 52.000 66.000 | 120 | 51.422 -2.166 0.127 | | | Vel = 2.75 |

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 1 [R/A=2]

Page 9
 Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|----------------------|----------------|-----------|---------------|------------|-----------------------|---------------------------|-----------------------------------|----------------|---------------------------|-------|------------------------------------|-------|
| POC to BF1 | 6.750 13 | | 0.0 428.4 | 8 8.27 | 2E | 56.936 | 41.000 0.0 56.936 97.936 | 140 0.0012 | 49.383 -2.707 0.120 | | Vel = 2.56 | |
| BF1 to BF2 | 13 13 | | 0.0 428.4 | 8 7.981 | 1Zic | 0.0 | 4.000 0.0 0.0 4.000 | 120 0.0018 | 46.796 5.766 0.007 | | * Fixed loss = 5.766 Vel = 2.75 | |
| BF2 to SRC | 13 13 | | 0.0 428.4 | 8 8.27 | 2E 1G 1T | 56.936 6.326 55.354 | 46.000 118.616 164.616 | 140 0.0012 | 52.569 0.0 0.200 | | Vel = 2.56 | |
| SRC | | | 0.0 428.40 | | | | | | 52.769 | | K Factor = 58.97 | |



LEVEL 3 R/A # 1 & 2

This page intentionally left blank.



**AUTOMATIC
SPRINKLER CO.**

21605 North Central Ave. 623.580.7800
Phoenix, Arizona 85024 Fax 623.434.3154

AZ-L16-234798 CA-C16-901529
AZ-C16-234797 NV-C41-69370
UT-S370-6690455-5501 NM-MS 12-354807



Fire Protection by Computer Design

Aero Automatic Sprinkler Co.
21605 N. Central Ave.
Phoenix, Arizona 85024
623-580-7800

Job Name : Cal Poly Center for Science LVL 3 [R/A=1]
Building : FP-6.03W
Location : San Luis Obispo, Ca.
System : 3-1
Contract : 10034
Data File : Cal Poly CFS LVL 3-1.WXF

HYDRAULIC CALCULATIONS
for

Project name: Cal Poly Center For Science
Location: San Luis Obispo, Ca.
Drawing no: FP-6.03W
Date: 9-25-2011

Design

Remote area number: 3-1
Remote area location: 3 rd. Floor Laboratory
Occupancy classification: Ordinary Hazard Gr. 1
Density: 0.15 - Gpm/SqFt
Area of application: 967 - SqFt
Coverage per sprinkler: 120 - SqFt
Type of sprinklers calculated: Tyco; Mod. TY-FRB; 1/2"; 1/2";K=5.6; 155 Deg
No. of sprinklers calculated: 12
In-rack demand: N/A - GPM
Hose streams: 250 - GPM
Total water required (including hose streams): 502.75 - GPM @ -0.88 - Psi
Type of system: WET
Volume of dry or preaction system: N/A - Gal

Water supply information

Date: 8-19-2011
Location: N. Poly View Drive
Source: Fluid Resource Management

Name of contractor: Aero Automatic Sprinkler Co.
Address: 21605 N. Central Ave. Phoenix, Az. 85024
Phone number: 623-580-7847
Name of designer: Neal Larsen
Authority having jurisdiction: C.S.F.M.


Notes: (Include peaking information or gridded systems here.) Flow Test Information :
Hydrant # 63; Static = 60 psi; Res.= 55 psi {Elev.=351.0'}
Hydrant # 64; Flow = 914 gpm
FLOW TEST USED IN HYD. CALCS REDUCED BY 10 % [STATIC=54psi; RES.=49psi]
NOTE : REMOTE AREA REDUCED BY 39.25% [Q.R HEADS & C.H.=10'-6"] 912 SQ.FT. MIN.

Water Supply Curve (C)

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 3 [R/A=1]

Page 2
 Date 9-25-11

| | | |
|---|--|---|
| City Water Supply: C1 - Static Pressure : 54 C2 - Residual Pressure: 49 C2 - Residual Flow : 914 City Water Adjusted to Pump Inlet for Pf - Elev - Hose Flow A1 - Adjusted Static: 51.696 A2 - Adj Resid : 47.866 @ 790.2 A3 - Adj Resid : 37.967 @ 1382.9 | Pump Data: P1 - Pump Churn Pressure : 125.2 P2 - Pump Rated Pressure : 110.9 P2 - Pump Rated Flow : 790.2 P3 - Pump Pressure @ Max Flow : 67.9 P3 - Pump Max Flow : 1382.9 City Residual Flow @ 0 = 3307.91 City Residual Flow @ 20 = 2576.03 City Water @ 150% of Pump = 43.24 | Demand: D1 - Elevation : 12.776 D2 - System Flow : 252.757 D2 - System Pressure : 121.999 Hose (Adj City) : 150 Hose (Demand) : 100 D3 - System Demand : 352.757 Safety Margin : 53.231 |
|---|--|---|



Fittings Used Summary

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 3 [R/A=1]

Page 3
 Date 9-25-11

Fitting Legend

| Abbrev. | Name | ½ | ¾ | 1 | 1¼ | 1½ | 2 | 2½ | 3 | 3½ | 4 | 5 | 6 | 8 | 10 | 12 | 14 | 16 | 18 | 20 | 24 |
|---------|-------------------------|--|---|------|----|-----|-----|----|----|----|----|-----|----|----|----|----|----|----|----|-----|-----|
| B | Generic Butterfly Valve | 0 | 0 | 2.25 | 2 | 2.5 | 6 | 7 | 10 | 0 | 12 | 9 | 10 | 12 | 19 | 21 | 0 | 0 | 0 | 0 | 0 |
| C | Generic Check Vlv | 4 | 5 | 5 | 7 | 9 | 11 | 14 | 16 | 19 | 22 | 27 | 32 | 45 | 55 | 65 | 76 | 87 | 98 | 109 | 130 |
| E | 90' Standard Elbow | 2 | 2 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 10 | 12 | 14 | 18 | 22 | 27 | 35 | 40 | 45 | 50 | 61 |
| G | Generic Gate Valve | 0 | 0 | 0 | 1 | 0 | 1 | 1 | 1 | 1 | 2 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 10 | 11 | 13 |
| I | 90' Ell Grvd-Vic #10 | 0 | 0 | 2 | 3 | 4 | 3.5 | 6 | 5 | 8 | 7 | 8.5 | 10 | 13 | 17 | 20 | 23 | 25 | 33 | 36 | 40 |
| T | 90' Flow Thru Tee | 3 | 4 | 5 | 6 | 8 | 10 | 12 | 15 | 17 | 20 | 25 | 30 | 35 | 50 | 60 | 71 | 81 | 91 | 101 | 121 |
| Zic | Wilkens 350ADA | Fitting generates a Fixed Loss Based on Flow | | | | | | | | | | | | | | | | | | | |

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Pressure / Flow Summary - STANDARD

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 3 [R/A=1]

Page 4
 Date 9-25-11

| Node No. | Elevation | K-Fact | Pt Actual | Pn | Flow Actual | Density | Area | Press Req. |
|----------|-----------|--------|-----------|----|-------------|---------|------|------------|
| S301 | 42.5 | 5.6 | 10.33 | na | 18.0 | 0.15 | 120 | 7.0 |
| S302 | 42.5 | 5.6 | 11.14 | na | 18.7 | 0.15 | 120 | 7.0 |
| S303 | 42.5 | 5.6 | 14.18 | na | 21.09 | 0.15 | 120 | 7.0 |
| S304 | 42.5 | 5.6 | 21.23 | na | 25.81 | 0.15 | 120 | 7.0 |
| S305 | 42.5 | 5.6 | 10.42 | na | 18.08 | 0.15 | 120 | 7.0 |
| S306 | 42.5 | 5.6 | 11.24 | na | 18.78 | 0.15 | 120 | 7.0 |
| S307 | 42.5 | 5.6 | 14.31 | na | 21.18 | 0.15 | 120 | 7.0 |
| S308 | 42.5 | 5.6 | 21.42 | na | 25.92 | 0.15 | 120 | 7.0 |
| S309 | 42.5 | 5.6 | 10.69 | na | 18.31 | 0.15 | 120 | 7.0 |
| S310 | 42.5 | 5.6 | 11.53 | na | 19.01 | 0.15 | 120 | 7.0 |
| S311 | 41.5 | 5.6 | 14.93 | na | 21.64 | 0.15 | 120 | 7.0 |
| S312 | 42.5 | 5.6 | 21.98 | na | 26.25 | 0.15 | 120 | 7.0 |
| L301 | 43.083 | | 10.68 | na | | | | |
| L302 | 43.083 | | 11.53 | na | | | | |
| L303 | 43.083 | | 14.73 | na | | | | |
| L304 | 43.083 | | 22.14 | na | | | | |
| L305 | 43.083 | | 10.77 | na | | | | |
| L306 | 43.083 | | 11.64 | na | | | | |
| L307 | 43.083 | | 14.86 | na | | | | |
| L308 | 43.083 | | 22.34 | na | | | | |
| L309 | 43.083 | | 11.05 | na | | | | |
| L310 | 43.083 | | 11.94 | na | | | | |
| L311 | 43.083 | | 15.24 | na | | | | |
| L312 | 43.083 | | 22.93 | na | | | | |
| MN30 | 44.0 | | 28.7 | na | | | | |
| MN31 | 44.0 | | 28.95 | na | | | | |
| MN32 | 44.0 | | 29.74 | na | | | | |
| MN35 | 43.083 | | 88.29 | na | | | | |
| TOR3 | 43.083 | | 92.48 | na | | | | |
| BOR3 | 36.0 | | 102.61 | na | | | | |
| HV1 | 99.75 | | 76.68 | na | | | | |
| HV2 | 99.75 | | 76.68 | na | | | | |
| SPRF | 99.75 | | 78.43 | na | | | | |
| SP16 | 85.0 | | 84.82 | na | | | | |
| SP15 | 69.0 | | 91.75 | na | | | | |
| SP14 | 53.0 | | 98.68 | na | | | | |
| SP13 | 37.0 | | 105.61 | na | | | | |
| HV3 | 101.0 | | 75.51 | na | | | | |
| SPR3 | 101.0 | | 77.26 | na | | | | |
| SP36 | 85.0 | | 84.19 | na | | | | |
| SP35 | 69.0 | | 91.12 | na | | | | |
| SP34 | 53.0 | | 98.05 | na | 50.0 | | | |
| SP33 | 37.0 | | 104.98 | na | 50.0 | | | |
| SP32 | 21.0 | | 112.1 | na | | | | |
| SP05 | 29.167 | | 108.57 | na | | | | |
| SP01 | 45.0 | | 102.14 | na | | | | |
| SP02 | 27.917 | | 109.54 | na | | | | |
| SP03 | 29.167 | | 109.0 | na | | | | |
| SP04 | 28.083 | | 109.81 | na | | | | |
| SPC1 | 12.667 | | 117.0 | na | | | | |
| SPC2 | 12.667 | | 117.19 | na | | | | |
| PO | 1.833 | | 122.0 | na | | | | |
| PI | 1.75 | | 50.88 | na | | | | |
| POC | 6.75 | | 48.8 | na | | | | |
| BF1 | 13.0 | | 46.18 | na | | | | |
| BF2 | 13.0 | | 52.21 | na | | | | |
| SRC | 13.0 | | 52.35 | na | 150.0 | | | |

The maximum velocity is 21.89 and it occurs in the pipe between nodes L311 and L312

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 3 [R/A=1]

Page 5
 Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|----------------------------|------------------|-----------|----------------|------------|-----------------------|-------------------|-------------------------|----------------|---------------------------|-------|-----------------|-------|
| *FLOWING SPRINKLER R/A # 1 | | | | | | | | | | | | |
| S301 to L301 | 42.500 43.083 | 5.60 | 18.00 18.0 | 1 1.049 | 1T | 5.0 0.0 0.0 | 0.583 5.000 5.583 | 120 | 10.332 -0.252 0.597 | | Vel = 6.68 | |
| L301 | | | 0.0 18.00 | | | | | | 10.677 | | K Factor = 5.51 | |
| S302 to L302 | 42.500 43.083 | 5.60 | 18.70 18.7 | 1 1.049 | 1T | 5.0 0.0 0.0 | 0.583 5.000 5.583 | 120 | 11.145 -0.252 0.641 | | Vel = 6.94 | |
| L302 | | | 0.0 18.70 | | | | | | 11.534 | | K Factor = 5.51 | |
| S303 to L303 | 42.500 43.083 | 5.60 | 21.09 21.09 | 1 1.049 | 1T | 5.0 0.0 0.0 | 0.583 5.000 5.583 | 120 | 14.184 -0.252 0.801 | | Vel = 7.83 | |
| L303 | | | 0.0 21.09 | | | | | | 14.733 | | K Factor = 5.49 | |
| S304 to L304 | 42.500 43.083 | 5.60 | 25.80 25.8 | 1 1.049 | 1T | 5.0 0.0 0.0 | 0.583 5.000 5.583 | 120 | 21.234 -0.252 1.163 | | Vel = 9.58 | |
| L304 | | | 0.0 25.80 | | | | | | 22.145 | | K Factor = 5.48 | |
| S305 to L305 | 42.500 43.083 | 5.60 | 18.08 18.08 | 1 1.049 | 1T | 5.0 0.0 0.0 | 0.583 5.000 5.583 | 120 | 10.424 -0.252 0.602 | | Vel = 6.71 | |
| L305 | | | 0.0 18.08 | | | | | | 10.774 | | K Factor = 5.51 | |
| S306 to L306 | 42.500 43.083 | 5.60 | 18.78 18.78 | 1 1.049 | 1T | 5.0 0.0 0.0 | 0.583 5.000 5.583 | 120 | 11.244 -0.252 0.646 | | Vel = 6.97 | |
| L306 | | | 0.0 18.78 | | | | | | 11.638 | | K Factor = 5.50 | |
| S307 to L307 | 42.500 43.083 | 5.60 | 21.18 21.18 | 1 1.049 | 1T | 5.0 0.0 0.0 | 0.583 5.000 5.583 | 120 | 14.309 -0.252 0.807 | | Vel = 7.86 | |
| L307 | | | 0.0 21.18 | | | | | | 14.864 | | K Factor = 5.49 | |
| S308 to L308 | 42.500 43.083 | 5.60 | 25.92 25.92 | 1 1.049 | 1T | 5.0 0.0 0.0 | 0.583 5.000 5.583 | 120 | 21.416 -0.252 1.173 | | Vel = 9.62 | |
| L308 | | | 0.0 25.92 | | | | | | 22.337 | | K Factor = 5.48 | |
| S309 to L309 | 42.500 43.083 | 5.60 | 18.31 18.31 | 1 1.049 | 1T | 5.0 0.0 0.0 | 0.583 5.000 5.583 | 120 | 10.686 -0.252 0.617 | | Vel = 6.80 | |
| L309 | | | 0.0 18.31 | | | | | | 11.051 | | K Factor = 5.51 | |
| S310 to L310 | 42.500 43.083 | 5.60 | 19.01 19.01 | 1 1.049 | 1T | 5.0 0.0 0.0 | 0.583 5.000 5.583 | 120 | 11.526 -0.252 0.661 | | Vel = 7.06 | |

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 3 [R/A=1]

Page 6
 Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|-----------------------|------------------|-----------|--------------|------------|-----------------------|-------------------|--------------------------|----------------|---------------------------|-------|------------------|-------|
| L310 | | | 0.0 19.01 | | | | | | 11.935 | | K Factor = 5.50 | |
| S311 to L311 | 41.500 43.083 | 5.60 | 21.64 | 1 | 1T | 5.0 0.0 0.0 | 1.583 5.000 6.583 | 120 | 14.930 -0.686 0.992 | | Vel = 8.03 | |
| L311 | | | 0.0 21.64 | | | | | | 15.236 | | K Factor = 5.54 | |
| S312 to L312 | 42.500 43.083 | 5.60 | 26.25 | 1 | 1T | 5.0 0.0 0.0 | 0.583 5.000 5.583 | 120 | 21.978 -0.252 1.202 | | Vel = 9.74 | |
| L312 | | | 0.0 26.25 | | | | | | 22.928 | | K Factor = 5.48 | |
| *BRANCH LINES R/A # 1 | | | | | | | | | | | | |
| L301 to L302 | 43.083 43.083 | | 18.00 | 1 | | 0.0 0.0 0.0 | 8.000 0.0 8.000 | 120 | 10.677 0.0 0.857 | | Vel = 6.68 | |
| L302 to L303 | 43.083 43.083 | | 18.70 | 1 | | 0.0 0.0 0.0 | 8.000 0.0 8.000 | 120 | 11.534 0.0 3.199 | | Vel = 13.62 | |
| L303 to L304 | 43.083 43.083 | | 21.09 | 1 | | 0.0 0.0 0.0 | 8.000 0.0 8.000 | 120 | 14.733 0.0 7.412 | | Vel = 21.45 | |
| L304 to MN30 | 43.083 44 | | 25.80 | 1.25 | 1E 1T | 3.0 6.0 0.0 | 5.417 9.000 14.417 | 120 | 22.145 -0.397 6.955 | | Vel = 17.93 | |
| MN30 | | | 0.0 83.59 | | | | | | 28.703 | | K Factor = 15.60 | |
| L305 to L306 | 43.083 43.083 | | 18.08 | 1 | | 0.0 0.0 0.0 | 8.000 0.0 8.000 | 120 | 10.774 0.0 0.864 | | Vel = 6.71 | |
| L306 to L307 | 43.083 43.083 | | 18.78 | 1 | | 0.0 0.0 0.0 | 8.000 0.0 8.000 | 120 | 11.638 0.0 3.226 | | Vel = 13.68 | |
| L307 to L308 | 43.083 43.083 | | 21.18 | 1 | | 0.0 0.0 0.0 | 8.000 0.0 8.000 | 120 | 14.864 0.0 7.473 | | Vel = 21.55 | |
| L308 to MN31 | 43.083 44 | | 25.92 | 1.25 | 1E 1T | 3.0 6.0 0.0 | 5.417 9.000 14.417 | 120 | 22.337 -0.397 7.011 | | Vel = 18.01 | |
| MN31 | | | 0.0 83.96 | | | | | | 28.951 | | K Factor = 15.60 | |
| L309 to L310 | 43.083 43.083 | | 18.31 | 1 | | 0.0 0.0 0.0 | 8.000 0.0 8.000 | 120 | 11.051 0.0 0.884 | | Vel = 6.80 | |
| L310 to L311 | 43.083 43.083 | | 19.01 | 1 | | 0.0 0.0 0.0 | 8.000 0.0 8.000 | 120 | 11.935 0.0 3.301 | | Vel = 13.85 | |

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 3 [R/A=1]

Page 7
 Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|----------------------|------------------|-----------|-----------------|--------------|-----------------------|------------------------|------------------------------|----------------|----------------------------|-------|-------|--------------------------------|
| L311 to L312 | 43.083 43.083 | | 21.64 58.96 | 1 1.049 | | 0.0 0.0 | 8.000 0.0 | 120 0.9615 | 15.236 0.0 7.692 | | | Vel = 21.89 |
| L312 to MN32 | 43.083 44 | | 26.25 85.21 | 1.25 1.38 | 1E 1T | 3.0 6.0 | 5.417 9.000 14.417 | 120 0.4998 | 22.928 -0.397 7.206 | | | Vel = 18.28 |
| MN32 | | | 0.0 85.21 | | | | | | 29.737 | | | K Factor = 15.63 |
| *FEED MAIN | | | | | | | | | | | | |
| MN30 to MN31 | 44 44 | | 83.59 83.59 | 2.5 2.635 | | 0.0 0.0 | 12.000 0.0 | 120 0.0207 | 28.703 0.0 0.248 | | | Vel = 4.92 |
| MN31 to MN32 | 44 44 | | 83.96 167.55 | 2.5 2.635 | | 0.0 0.0 | 10.500 0.0 | 120 0.0749 | 28.951 0.0 0.786 | | | Vel = 9.86 |
| MN32 to MN35 | 44 43.083 | | 85.21 252.76 | 2.5 2.635 | 6I 2T | 49.423 32.948 | 280.833 82.371 363.204 | 120 0.1601 | 29.737 0.397 58.157 | | | Vel = 14.87 |
| MN35 to TOR3 | 43.083 43.083 | | 0.0 252.76 | 2.5 2.635 | 2I | 16.474 0.0 | 9.667 16.474 26.141 | 120 0.1601 | 88.291 0.0 4.186 | | | Vel = 14.87 |
| TOR3 to BOR3 | 43.083 36 | | 0.0 252.76 | 2.5 2.635 | 1C 1B 1I | 19.22 9.61 8.237 | 7.083 37.067 44.150 | 120 0.1601 | 92.477 3.068 7.069 | | | Vel = 14.87 |
| BOR3 to SP33 | 36 37 | | 0.0 252.76 | 2.5 2.635 | 1T | 16.474 0.0 | 1.000 16.474 17.474 | 120 0.1601 | 102.614 -0.433 2.798 | | | Vel = 14.87 |
| SP33 | | | 0.0 252.76 | | | | | | 104.979 | | | K Factor = 24.67 |
| *S/P # 1 | | | | | | | | | | | | |
| HV1 to SPRF | 99.750 99.750 | .0 | 0.0 0.0 | 2.5 2.469 | 1T | 12.0 0.0 | 0.250 12.000 12.250 | 120 0 | 76.680 1.750 0.0 | | | * Fixed loss = 1.75 Vel = 0 |
| SPRF | | | 0.0 0.0 | | | | | | 78.430 | | | K Factor = 0 |
| HV2 to SPRF | 99.750 99.750 | .0 | 0.0 0.0 | 2.5 2.469 | 1T | 12.0 0.0 | 0.250 12.000 12.250 | 120 0 | 76.680 1.750 0.0 | | | * Fixed loss = 1.75 Vel = 0 |
| SPRF to SP16 | 99.750 85 | .0 | 0.0 0.0 | 6 6.065 | 4I | 40.0 0.0 | 30.000 40.000 70.000 | 120 0 | 78.430 6.388 0.0 | | | Vel = 0 |
| SP16 to SP15 | 85 69 | .0 | 0.0 0.0 | 6 6.065 | | 0.0 0.0 | 16.000 0.0 16.000 | 120 0 | 84.818 6.930 0.0 | | | Vel = 0 |
| SP15 to SP14 | 69 53 | .0 | 0.0 0.0 | 6 6.065 | | 0.0 0.0 | 16.000 0.0 16.000 | 120 0 | 91.747 6.930 0.0 | | | Vel = 0 |

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 3 [R/A=1]

Page 8
 Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|----------------------|------------------|-----------|------------------|--------------|-----------------------|----------------------|----------------------------|----------------|---------------------------|-------|------------------|--------------------------------|
| SP14 to SP01 | 53 45 | .0 | 0.0 0.0 | 6 6.065 | 1T | 30.0 0.0 | 8.500 30.000 | 120 0 | 98.677 3.465 0.0 | | | Vel = 0 |
| SP01 | | | 0.0 0.0 | | | | | | 102.142 | | K Factor = 0 | |
| SP13 to SP01 | 37 45 | .0 | 0.0 0.0 | 6 6.065 | 1T | 30.0 0.0 | 7.500 30.000 | 120 0 | 105.607 -3.465 0.0 | | | Vel = 0 |
| SP01 | | | 0.0 0.0 | | | | | | 102.142 | | K Factor = 0 | |
| *S/P # 3 | | | | | | | | | | | | |
| HV3 to SPR3 | 101 101 | .0 | 0.0 0.0 | 2.5 2.469 | 2E 1T | 12.0 12.0 | 1.750 24.000 | 120 0 | 75.508 1.750 0.0 | | | * Fixed loss = 1.75 Vel = 0 |
| SPR3 to SP36 | 101 85 | .0 | 0.0 0.0 | 6 6.065 | | 0.0 0.0 | 16.000 0.0 | 120 0 | 77.258 6.930 0.0 | | | Vel = 0 |
| SP36 to SP35 | 85 69 | .0 | 0.0 0.0 | 6 6.065 | | 0.0 0.0 | 16.000 16.000 | 120 0 | 84.188 6.930 0.0 | | | Vel = 0 |
| SP35 to SP34 | 69 53 | .0 | 0.0 0.0 | 6 6.065 | | 0.0 0.0 | 16.000 16.000 | 120 0 | 91.118 6.930 0.0 | | | Vel = 0 |
| SP34 to SP33 | 53 37 | H50 | 50.00 50.0 | 6 6.065 | | 0.0 0.0 | 16.000 16.000 | 120 0.0001 | 98.047 6.930 0.002 | | | Vel = 0.56 |
| SP33 to SP05 | 37 29.167 | H50 | 302.76 352.76 | 6 6.065 | 1T | 30.0 0.0 | 8.417 30.000 | 120 0.0051 | 104.979 3.392 0.197 | | | Vel = 3.92 |
| SP05 | | | 0.0 352.76 | | | | | | 108.568 | | K Factor = 33.86 | |
| SP32 to SP05 | 21 29.167 | .0 | 0.0 0.0 | 6 6.065 | 1T | 30.0 0.0 | 7.583 30.000 | 120 0 | 112.105 -3.537 0.0 | | | Vel = 0 |
| SP05 to SP03 | 29.167 29.167 | | 352.76 352.76 | 6 6.065 | 1I 1B 1T | 10.0 10.0 30.0 | 34.167 50.000 84.167 | 120 0.0051 | 108.568 0.0 0.431 | | | Vel = 3.92 |
| SP03 | | | 0.0 352.76 | | | | | | 108.999 | | K Factor = 33.79 | |
| *STANDPIPE FEED | | | | | | | | | | | | |
| SP01 to SP02 | 45 27.917 | .0 | 0.0 0.0 | 6 6.065 | 1B 6I | 10.0 60.0 | 34.417 70.000 | 120 0 | 102.142 7.399 0.0 | | | Vel = 0 |
| SP02 to SP03 | 27.917 29.167 | .0 | 0.0 0.0 | 6 6.065 | 2I | 20.0 0.0 | 235.417 20.000 | 120 0 | 109.540 -0.541 0.0 | | | Vel = 0 |
| SP03 to SP04 | 29.167 28.083 | | 352.76 352.76 | 6 6.065 | 4I | 40.0 0.0 | 27.500 40.000 | 120 0.0051 | 108.999 0.469 0.346 | | | Vel = 3.92 |

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 3 [R/A=1]

Page 9
 Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|--------------------------|------------------|-----------|------------------|------------|-----------------------|---------------------------|------------------------------|----------------|---------------------------|-------|----------------|--------|
| SP04 to SPC1 | 28.083 12.667 | | 0.0 352.76 | 6 6.065 | 2I | 20.0 0.0 | 79.330 20.000 | 120 0.0051 | 109.814 6.677 | | | |
| | | | | | | 0.0 | 99.330 | | 0.508 | Vel = | 3.92 | |
| SPC1 to SPC2 | 12.667 12.667 | | 0.0 352.76 | 6 6.065 | 1T | 30.0 0.0 | 7.833 30.000 | 120 0.0051 | 116.999 0.0 | | | |
| | | | | | | 0.0 | 37.833 | | 0.194 | Vel = | 3.92 | |
| SPC2 to PO | 12.667 1.833 | | 0.0 352.76 | 8 7.981 | 1I 1B 1C | 13.0 12.0 45.0 | 14.750 70.000 84.750 | 120 0.0013 | 117.193 4.692 0.114 | | | |
| | | | | | | | | | | Vel = | 2.26 | |
| PO | | | 0.0 352.76 | | | | | | 121.999 | | K Factor = | 31.94 |
| System Demand Pressure | | | | | | 121.999 | | | | | | |
| Safety Margin | | | | | | 53.231 | | | | | | |
| Continuation Pressure | | | | | | 175.230 | | | | | | |
| Pressure @ Pump Outlet | | | | | | 175.230 | | | | | | |
| Pressure From Pump Curve | | | | | | -124.353 | | | | | | |
| Pressure @ Pump Inlet | | | | | | 50.877 | | | | | | |
| PI to POC | 1.750 6.750 | | 0.0 352.76 | 8 7.981 | 1G 1I 1T | 4.0 13.0 35.0 | 14.000 52.000 66.000 | 120 0.0013 | 50.877 -2.166 0.089 | | | |
| | | | | | | | | | | Vel = | 2.26 | |
| POC to BF1 | 6.750 13 | | 0.0 352.76 | 8 8.27 | 2E | 56.936 0.0 | 41.000 56.936 | 140 0.0008 | 48.800 -2.707 0.083 | | | |
| | | | | | | 0.0 | 97.936 | | 0.083 | Vel = | 2.11 | |
| BF1 to BF2 | 13 13 | | 0.0 352.76 | 8 7.981 | 1Zic | 0.0 0.0 | 4.000 0.0 | 120 0.0015 | 46.176 6.024 0.006 | | * Fixed loss = | 6.024 |
| | | | | | | 0.0 | 4.000 | | 0.006 | Vel = | 2.26 | |
| BF2 to SRC | 13 13 | | 0.0 352.76 | 8 8.27 | 2E 1G 1T | 56.936 6.326 55.354 | 46.000 118.616 164.616 | 140 0.0009 | 52.206 0.0 0.140 | | | |
| | | | | | | | | | | Vel = | 2.11 | |
| SRC | | | 150.00 502.76 | | | | | | 52.346 | | Qa = | 150.00 |
| | | | | | | | | | | | K Factor = | 69.49 |



**AUTOMATIC
SPRINKLER CO.**

21605 North Central Ave. 623.580.7800
Phoenix, Arizona 85024 Fax 623.434.3154

AZ-L16-234798 CA-C16-901529
AZ-C16-234797 NV-C41-69370
UT-S370-6690455-5501 NM-MS 12-354807



Fire Protection by Computer Design

Aero Automatic Sprinkler Co.
21605 N. Central Ave.
Phoenix, Arizona 85024
623-580-7800

Job Name : Cal Poly Center for Science LVL 3 [R/A=2]
Building : FP-6.03E
Location : San Luis Obispo, Ca.
System : 3-2
Contract : 10034
Data File : Cal Poly CFS LVL 3-2.WXF

HYDRAULIC CALCULATIONS
for

Project name: Cal Poly Center For Science

Location: San Luis Obispo, Ca.

Drawing no: FP-6.03E

Date: 9-25-2011

Design

Remote area number: 3-2

Remote area location: 3 rd. Floor Laboratory

Occupancy classification: Ordinary Hazard Gr. 1

Density: 0.15 - Gpm/SqFt

Area of application: 1135 - SqFt

Coverage per sprinkler: 130 - SqFt

Type of sprinklers calculated: Tyco; Mod. TY-FRB; 1/2"; 1/2";K=5.6; 155 Deg

No. of sprinklers calculated: 10

In-rack demand: N/A - GPM

Hose streams: 250 - GPM

Total water required (including hose streams): 483.54 - GPM @ 3.22 - Psi

Type of system: WET

Volume of dry or preaction system: N/A - Gal

Water supply information

Date: 8-19-2011

Location: N. Poly View Drive

Source: Fluid Resource Management

Name of contractor: Aero Automatic Sprinkler Co.

Address: 21605 N. Central Ave. Phoenix, Az. 85024

Phone number: 623-580-7847

Name of designer: Neal Larsen

Authority having jurisdiction: C.S.F.M.

Notes: (Include peaking information or gridded systems here.) Flow Test Information :

Hydrant # 63; Static = 60 psi; Res.= 55 psi {Elev.=351.0'}

Hydrant # 64; Flow = 914 gpm


FLOW TEST USED IN HYD. CALCS REDUCED BY 10 % [STATIC=54psi; RES.=49psi]

Water Supply Curve (C)

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 3 [R/A=2]

Page 2
 Date 9-25-11

| | | |
|---|--|---|
| City Water Supply: C1 - Static Pressure : 54 C2 - Residual Pressure: 49 C2 - Residual Flow : 914 City Water Adjusted to Pump Inlet for Pf - Elev - Hose Flow A1 - Adjusted Static: 51.696 A2 - Adj Resid : 47.866 @ 790.2 A3 - Adj Resid : 37.967 @ 1382.9 | Pump Data: P1 - Pump Churn Pressure : 125.2 P2 - Pump Rated Pressure : 110.9 P2 - Pump Rated Flow : 790.2 P3 - Pump Pressure @ Max Flow : 67.9 P3 - Pump Max Flow : 1382.9 City Residual Flow @ 0 = 3307.91 City Residual Flow @ 20 = 2576.03 City Water @ 150% of Pump = 43.24 | Demand: D1 - Elevation : 12.776 D2 - System Flow : 233.543 D2 - System Pressure : 126.159 Hose (Adj City) : 150 Hose (Demand) : 100 D3 - System Demand : 333.543 Safety Margin : 49.232 |
|---|--|---|



Fittings Used Summary

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 3 [R/A=2]

Page 3
 Date 9-25-11

Fitting Legend

| Abbrev. | Name | ½ | ¾ | 1 | 1¼ | 1½ | 2 | 2½ | 3 | 3½ | 4 | 5 | 6 | 8 | 10 | 12 | 14 | 16 | 18 | 20 | 24 |
|---------|-------------------------|--|---|------|----|-----|-----|----|----|----|----|-----|----|----|----|----|----|----|----|-----|-----|
| B | Generic Butterfly Valve | 0 | 0 | 2.25 | 2 | 2.5 | 6 | 7 | 10 | 0 | 12 | 9 | 10 | 12 | 19 | 21 | 0 | 0 | 0 | 0 | 0 |
| C | Generic Check Vlv | 4 | 5 | 5 | 7 | 9 | 11 | 14 | 16 | 19 | 22 | 27 | 32 | 45 | 55 | 65 | 76 | 87 | 98 | 109 | 130 |
| E | 90' Standard Elbow | 2 | 2 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 10 | 12 | 14 | 18 | 22 | 27 | 35 | 40 | 45 | 50 | 61 |
| G | Generic Gate Valve | 0 | 0 | 0 | 1 | 0 | 1 | 1 | 1 | 1 | 2 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 10 | 11 | 13 |
| I | 90' Ell Grvd-Vic #10 | 0 | 0 | 2 | 3 | 4 | 3.5 | 6 | 5 | 8 | 7 | 8.5 | 10 | 13 | 17 | 20 | 23 | 25 | 33 | 36 | 40 |
| T | 90' Flow Thru Tee | 3 | 4 | 5 | 6 | 8 | 10 | 12 | 15 | 17 | 20 | 25 | 30 | 35 | 50 | 60 | 71 | 81 | 91 | 101 | 121 |
| Zic | Wilkens 350ADA | Fitting generates a Fixed Loss Based on Flow | | | | | | | | | | | | | | | | | | | |

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Pressure / Flow Summary - STANDARD

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 3 [R/A=2]

Page 4
 Date 9-25-11

| Node No. | Elevation | K-Fact | Pt Actual | Pn | Flow Actual | Density | Area | Press Req. |
|----------|-----------|--------|-----------|----|-------------|---------|------|------------|
| S321 | 42.5 | 5.6 | 10.33 | na | 18.0 | 0.15 | 120 | 7.0 |
| S322 | 42.5 | 5.6 | 11.35 | na | 18.86 | 0.15 | 120 | 7.0 |
| S323 | 42.5 | 5.6 | 15.18 | na | 21.82 | 0.15 | 120 | 7.0 |
| S324 | 42.5 | 5.6 | 24.25 | na | 27.58 | 0.15 | 120 | 7.0 |
| S325 | 42.5 | 5.6 | 29.12 | na | 30.22 | 0.15 | 120 | 7.0 |
| S326 | 42.5 | 5.6 | 10.44 | na | 18.09 | 0.15 | 120 | 7.0 |
| S327 | 42.5 | 5.6 | 11.46 | na | 18.96 | 0.15 | 120 | 7.0 |
| S328 | 42.5 | 5.6 | 15.33 | na | 21.93 | 0.15 | 120 | 7.0 |
| S329 | 42.5 | 5.6 | 24.49 | na | 27.71 | 0.15 | 120 | 7.0 |
| S330 | 42.5 | 5.6 | 29.41 | na | 30.37 | 0.15 | 120 | 7.0 |
| L321 | 43.083 | | 10.68 | na | | | | |
| L322 | 43.083 | | 11.75 | na | | | | |
| L323 | 43.083 | | 15.78 | na | | | | |
| L324 | 43.083 | | 25.32 | na | | | | |
| L325 | 43.083 | | 30.43 | na | | | | |
| L326 | 43.083 | | 10.79 | na | | | | |
| L327 | 43.083 | | 11.87 | na | | | | |
| L328 | 43.083 | | 15.94 | na | | | | |
| L329 | 43.083 | | 25.56 | na | | | | |
| L330 | 43.083 | | 30.73 | na | | | | |
| MN40 | 44.0 | | 47.34 | na | | | | |
| MN41 | 44.0 | | 47.8 | na | | | | |
| MN35 | 43.083 | | 94.54 | na | | | | |
| TOR3 | 43.083 | | 98.16 | na | | | | |
| BOR3 | 36.0 | | 107.33 | na | | | | |
| HV1 | 99.75 | | 80.95 | na | | | | |
| HV2 | 99.75 | | 80.95 | na | | | | |
| SPRF | 99.75 | | 82.7 | na | | | | |
| SP16 | 85.0 | | 89.09 | na | | | | |
| SP15 | 69.0 | | 96.02 | na | | | | |
| SP14 | 53.0 | | 102.95 | na | | | | |
| SP13 | 37.0 | | 109.88 | na | | | | |
| HV3 | 101.0 | | 79.84 | na | | | | |
| SPR3 | 101.0 | | 81.59 | na | | | | |
| SP36 | 85.0 | | 88.52 | na | | | | |
| SP35 | 69.0 | | 95.45 | na | | | | |
| SP34 | 53.0 | | 102.38 | na | 50.0 | | | |
| SP33 | 37.0 | | 109.32 | na | 50.0 | | | |
| SP32 | 21.0 | | 116.42 | na | | | | |
| SP05 | 29.167 | | 112.88 | na | | | | |
| SP01 | 45.0 | | 106.42 | na | | | | |
| SP02 | 27.917 | | 113.81 | na | | | | |
| SP03 | 29.167 | | 113.27 | na | | | | |
| SP04 | 28.083 | | 114.05 | na | | | | |
| SPC1 | 12.667 | | 121.19 | na | | | | |
| SPC2 | 12.667 | | 121.36 | na | | | | |
| PO | 1.833 | | 126.16 | na | | | | |
| PI | 1.75 | | 50.96 | na | | | | |
| POC | 6.75 | | 48.87 | na | | | | |
| BF1 | 13.0 | | 46.24 | na | | | | |
| BF2 | 13.0 | | 52.33 | na | | | | |
| SRC | 13.0 | | 52.46 | na | 150.0 | | | |

The maximum velocity is 25.11 and it occurs in the pipe between nodes L330 and MN41

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 3 [R/A=2]

Page 5
 Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|----------------------------|------------------|-----------|----------------|------------|-----------------------|-------------------|-------------------------|----------------|---------------------------|-------|-----------------|-------|
| *FLOWING SPRINKLER R/A # 2 | | | | | | | | | | | | |
| S321 to L321 | 42.500 43.083 | 5.60 | 18.00 18.0 | 1 1.049 | 1T | 5.0 0.0 0.0 | 0.583 5.000 5.583 | 120 | 10.332 -0.252 0.597 | | Vel = 6.68 | |
| L321 | | | 0.0 18.00 | | | | | | 10.677 | | K Factor = 5.51 | |
| S322 to L322 | 42.500 43.083 | 5.60 | 18.86 18.86 | 1 1.049 | 1T | 5.0 0.0 0.0 | 0.583 5.000 5.583 | 120 | 11.348 -0.252 0.652 | | Vel = 7.00 | |
| L322 | | | 0.0 18.86 | | | | | | 11.748 | | K Factor = 5.50 | |
| S323 to L323 | 42.500 43.083 | 5.60 | 21.82 21.82 | 1 1.049 | 1T | 5.0 0.0 0.0 | 0.583 5.000 5.583 | 120 | 15.181 -0.252 0.853 | | Vel = 8.10 | |
| L323 | | | 0.0 21.82 | | | | | | 15.782 | | K Factor = 5.49 | |
| S324 to L324 | 42.500 43.083 | 5.60 | 27.58 27.58 | 1 1.049 | 1T | 5.0 0.0 0.0 | 0.583 5.000 5.583 | 120 | 24.251 -0.252 1.316 | | Vel = 10.24 | |
| L324 | | | 0.0 27.58 | | | | | | 25.315 | | K Factor = 5.48 | |
| S325 to L325 | 42.500 43.083 | 5.60 | 30.22 30.22 | 1 1.049 | 1T | 5.0 0.0 0.0 | 0.583 5.000 5.583 | 120 | 29.121 -0.252 1.559 | | Vel = 11.22 | |
| L325 | | | 0.0 30.22 | | | | | | 30.428 | | K Factor = 5.48 | |
| S326 to L326 | 42.500 43.083 | 5.60 | 18.09 18.09 | 1 1.049 | 1T | 5.0 0.0 0.0 | 0.583 5.000 5.583 | 120 | 10.438 -0.252 0.603 | | Vel = 6.72 | |
| L326 | | | 0.0 18.09 | | | | | | 10.789 | | K Factor = 5.51 | |
| S327 to L327 | 42.500 43.083 | 5.60 | 18.96 18.96 | 1 1.049 | 1T | 5.0 0.0 0.0 | 0.583 5.000 5.583 | 120 | 11.464 -0.252 0.658 | | Vel = 7.04 | |
| L327 | | | 0.0 18.96 | | | | | | 11.870 | | K Factor = 5.50 | |
| S328 to L328 | 42.500 43.083 | 5.60 | 21.93 21.93 | 1 1.049 | 1T | 5.0 0.0 0.0 | 0.583 5.000 5.583 | 120 | 15.333 -0.252 0.861 | | Vel = 8.14 | |
| L328 | | | 0.0 21.93 | | | | | | 15.942 | | K Factor = 5.49 | |
| S329 to L329 | 42.500 43.083 | 5.60 | 27.71 27.71 | 1 1.049 | 1T | 5.0 0.0 0.0 | 0.583 5.000 5.583 | 120 | 24.490 -0.252 1.327 | | Vel = 10.29 | |
| L329 | | | 0.0 27.71 | | | | | | 25.565 | | K Factor = 5.48 | |
| S330 to L330 | 42.500 43.083 | 5.60 | 30.37 30.37 | 1 1.049 | 1T | 5.0 0.0 0.0 | 0.583 5.000 5.583 | 120 | 29.406 -0.252 1.572 | | Vel = 11.27 | |

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 3 [R/A=2]

Page 6
 Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|-----------------------|----------------|-----------|----------|------------|-----------------------|--------|-------------------------|----------------|----------------|-------|------------|-------|
| | | | 0.0 | | | | | | | | | |
| L330 | | | 30.37 | | | | | | 30.726 | | K Factor = | 5.48 |
| *BRANCH LINES R/A # 2 | | | | | | | | | | | | |
| L321 | 43.083 | | 18.00 | 1 | | 0.0 | 10.000 | 120 | 10.677 | | | |
| to | | | | | | 0.0 | 0.0 | | 0.0 | | | |
| L322 | 43.083 | | 18.0 | 1.049 | | 0.0 | 10.000 | 0.1071 | 1.071 | Vel = | 6.68 | |
| L322 | 43.083 | | 18.86 | 1 | | 0.0 | 10.000 | 120 | 11.748 | | | |
| to | | | | | | 0.0 | 0.0 | | 0.0 | | | |
| L323 | 43.083 | | 36.86 | 1.049 | | 0.0 | 10.000 | 0.4034 | 4.034 | Vel = | 13.68 | |
| L323 | 43.083 | | 21.82 | 1 | | 0.0 | 10.000 | 120 | 15.782 | | | |
| to | | | | | | 0.0 | 0.0 | | 0.0 | | | |
| L324 | 43.083 | | 58.68 | 1.049 | | 0.0 | 10.000 | 0.9533 | 9.533 | Vel = | 21.78 | |
| L324 | 43.083 | | 27.58 | 1.25 | | 0.0 | 10.000 | 120 | 25.315 | | | |
| to | | | | | | 0.0 | 0.0 | | 0.0 | | | |
| L325 | 43.083 | | 86.26 | 1.38 | | 0.0 | 10.000 | 0.5113 | 5.113 | Vel = | 18.50 | |
| L325 | 43.083 | | 30.22 | 1.25 | 1E | 3.0 | 10.417 | 120 | 30.428 | | | |
| to | | | | | 1T | 6.0 | 9.000 | | -0.397 | | | |
| MN40 | 44 | | 116.48 | 1.38 | | 0.0 | 19.417 | 0.8913 | 17.306 | Vel = | 24.99 | |
| | | | 0.0 | | | | | | | | | |
| MN40 | | | 116.48 | | | | | | 47.337 | | K Factor = | 16.93 |
| L326 | 43.083 | | 18.09 | 1 | | 0.0 | 10.000 | 120 | 10.789 | | | |
| to | | | | | | 0.0 | 0.0 | | 0.0 | | | |
| L327 | 43.083 | | 18.09 | 1.049 | | 0.0 | 10.000 | 0.1081 | 1.081 | Vel = | 6.72 | |
| L327 | 43.083 | | 18.96 | 1 | | 0.0 | 10.000 | 120 | 11.870 | | | |
| to | | | | | | 0.0 | 0.0 | | 0.0 | | | |
| L328 | 43.083 | | 37.05 | 1.049 | | 0.0 | 10.000 | 0.4072 | 4.072 | Vel = | 13.75 | |
| L328 | 43.083 | | 21.93 | 1 | | 0.0 | 10.000 | 120 | 15.942 | | | |
| to | | | | | | 0.0 | 0.0 | | 0.0 | | | |
| L329 | 43.083 | | 58.98 | 1.049 | | 0.0 | 10.000 | 0.9623 | 9.623 | Vel = | 21.89 | |
| L329 | 43.083 | | 27.72 | 1.25 | | 0.0 | 10.000 | 120 | 25.565 | | | |
| to | | | | | | 0.0 | 0.0 | | 0.0 | | | |
| L330 | 43.083 | | 86.7 | 1.38 | | 0.0 | 10.000 | 0.5161 | 5.161 | Vel = | 18.60 | |
| L330 | 43.083 | | 30.36 | 1.25 | 1E | 3.0 | 10.417 | 120 | 30.726 | | | |
| to | | | | | 1T | 6.0 | 9.000 | | -0.397 | | | |
| MN41 | 44 | | 117.06 | 1.38 | | 0.0 | 19.417 | 0.8995 | 17.466 | Vel = | 25.11 | |
| | | | 0.0 | | | | | | | | | |
| MN41 | | | 117.06 | | | | | | 47.795 | | K Factor = | 16.93 |
| *FEED MAIN | | | | | | | | | | | | |
| MN40 | 44 | | 116.48 | 2.5 | | 0.0 | 12.000 | 120 | 47.337 | | | |
| to | | | | | | 0.0 | 0.0 | | 0.0 | | | |
| MN41 | 44 | | 116.48 | 2.635 | | 0.0 | 12.000 | 0.0382 | 0.458 | Vel = | 6.85 | |
| MN41 | 44 | | 117.06 | 2.5 | 4I | 32.948 | 252.667 | 120 | 47.795 | | | |
| to | | | | | 3T | 49.423 | 82.371 | | 0.397 | | | |
| MN35 | 43.083 | | 233.54 | 2.635 | | 0.0 | 335.038 | 0.1383 | 46.348 | Vel = | 13.74 | |
| MN35 | 43.083 | | 0.0 | 2.5 | 2I | 16.474 | 9.667 | 120 | 94.540 | | | |
| to | | | | | | 0.0 | 16.474 | | 0.0 | | | |
| TOR3 | 43.083 | | 233.54 | 2.635 | | 0.0 | 26.141 | 0.1383 | 3.616 | Vel = | 13.74 | |

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 3 [R/A=2]

Page 7
 Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|----------------------|------------------|-----------|---------------|--------------|-----------------------|------------------------|----------------------------|----------------|----------------------------|-------|--------------------------------|-------|
| TOR3 to BOR3 | 43.083 36 | | 0.0 233.54 | 2.5 2.635 | 1C 1B 1I | 19.22 9.61 8.237 | 7.083 37.067 44.150 | 120 0.1383 | 98.156 3.068 6.107 | | Vel = 13.74 | |
| BOR3 to SP33 | 36 37 | | 0.0 233.54 | 2.5 2.635 | 1T | 16.474 0.0 0.0 | 1.000 16.474 17.474 | 120 0.1383 | 107.331 -0.433 2.417 | | Vel = 13.74 | |
| SP33 | | | 0.0 233.54 | | | | | | 109.315 | | K Factor = 22.34 | |
| *S/P # 1 | | | | | | | | | | | | |
| HV1 to SPRF | 99.750 99.750 | .0 | 0.0 0.0 | 2.5 2.469 | 1T | 12.0 0.0 0.0 | 0.250 12.000 12.250 | 120 0 | 80.954 1.750 0.0 | | * Fixed loss = 1.75 Vel = 0 | |
| SPRF | | | 0.0 0.0 | | | | | | 82.704 | | K Factor = 0 | |
| HV2 to SPRF | 99.750 99.750 | .0 | 0.0 0.0 | 2.5 2.469 | 1T | 12.0 0.0 0.0 | 0.250 12.000 12.250 | 120 0 | 80.954 1.750 0.0 | | * Fixed loss = 1.75 Vel = 0 | |
| SPRF to SP16 | 99.750 85 | .0 | 0.0 0.0 | 6 6.065 | 4I | 40.0 0.0 0.0 | 30.000 40.000 70.000 | 120 0 | 82.704 6.388 0.0 | | Vel = 0 | |
| SP16 to SP15 | 85 69 | .0 | 0.0 0.0 | 6 6.065 | | 0.0 0.0 0.0 | 16.000 0.0 16.000 | 120 0 | 89.092 6.930 0.0 | | Vel = 0 | |
| SP15 to SP14 | 69 53 | .0 | 0.0 0.0 | 6 6.065 | | 0.0 0.0 0.0 | 16.000 0.0 16.000 | 120 0 | 96.021 6.930 0.0 | | Vel = 0 | |
| SP14 to SP01 | 53 45 | .0 | 0.0 0.0 | 6 6.065 | 1T | 30.0 0.0 0.0 | 8.500 30.000 38.500 | 120 0 | 102.951 3.465 0.0 | | Vel = 0 | |
| SP01 | | | 0.0 0.0 | | | | | | 106.416 | | K Factor = 0 | |
| SP13 to SP01 | 37 45 | .0 | 0.0 0.0 | 6 6.065 | 1T | 30.0 0.0 0.0 | 7.500 30.000 37.500 | 120 0 | 109.881 -3.465 0.0 | | Vel = 0 | |
| SP01 | | | 0.0 0.0 | | | | | | 106.416 | | K Factor = 0 | |
| *S/P # 3 | | | | | | | | | | | | |
| HV3 to SPR3 | 101 101 | .0 | 0.0 0.0 | 2.5 2.469 | 2E 1T | 12.0 12.0 0.0 | 1.750 24.000 25.750 | 120 0 | 79.844 1.750 0.0 | | * Fixed loss = 1.75 Vel = 0 | |
| SPR3 to SP36 | 101 85 | .0 | 0.0 0.0 | 6 6.065 | | 0.0 0.0 0.0 | 16.000 0.0 16.000 | 120 0 | 81.594 6.930 0.0 | | Vel = 0 | |
| SP36 to SP35 | 85 69 | .0 | 0.0 0.0 | 6 6.065 | | 0.0 0.0 0.0 | 16.000 0.0 16.000 | 120 0 | 88.524 6.930 0.0 | | Vel = 0 | |
| SP35 to SP34 | 69 53 | .0 | 0.0 0.0 | 6 6.065 | | 0.0 0.0 0.0 | 16.000 0.0 16.000 | 120 0 | 95.454 6.930 0.0 | | Vel = 0 | |

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 3 [R/A=2]

Page 8
 Date 9-25-11


| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|--------------------------|------------------|-----------|------------------|------------|-----------------------|----------------------|------------------------------|----------------|---------------------------|-------|-------|------------------|
| SP34 to SP33 | 53 37 | H50 | 50.00 50.0 | 6 6.065 | | 0.0 0.0 | 16.000 0.0 | 120 0.0001 | 102.383 6.930 0.002 | | | Vel = 0.56 |
| SP33 to SP05 | 37 29.167 | H50 | 283.54 333.54 | 6 6.065 | 1T | 30.0 0.0 | 8.417 30.000 38.417 | 120 0.0046 | 109.315 3.392 0.178 | | | Vel = 3.70 |
| SP05 | | | 0.0 333.54 | | | | | | 112.885 | | | K Factor = 31.39 |
| SP32 to SP05 | 21 29.167 | .0 | 0.0 0.0 | 6 6.065 | 1T | 30.0 0.0 | 7.583 30.000 37.583 | 120 0 | 116.422 -3.537 0.0 | | | Vel = 0 |
| SP05 to SP03 | 29.167 29.167 | | 333.54 333.54 | 6 6.065 | 1I 1B 1T | 10.0 10.0 30.0 | 34.167 50.000 84.167 | 120 0.0046 | 112.885 0.0 0.388 | | | Vel = 3.70 |
| SP03 | | | 0.0 333.54 | | | | | | 113.273 | | | K Factor = 31.34 |
| *STANDPIPE FEED | | | | | | | | | | | | |
| SP01 to SP02 | 45 27.917 | .0 | 0.0 0.0 | 6 6.065 | 1B 6I | 10.0 60.0 | 34.417 70.000 104.417 | 120 0 | 106.416 7.399 0.0 | | | Vel = 0 |
| SP02 to SP03 | 27.917 29.167 | .0 | 0.0 0.0 | 6 6.065 | 2I | 20.0 0.0 | 235.417 20.000 255.417 | 120 0 | 113.814 -0.541 0.0 | | | Vel = 0 |
| SP03 to SP04 | 29.167 28.083 | | 333.54 333.54 | 6 6.065 | 4I | 40.0 0.0 | 27.500 40.000 67.500 | 120 0.0046 | 113.273 0.469 0.312 | | | Vel = 3.70 |
| SP04 to SPC1 | 28.083 12.667 | | 0.0 333.54 | 6 6.065 | 2I | 20.0 0.0 | 79.330 20.000 99.330 | 120 0.0046 | 114.054 6.677 0.458 | | | Vel = 3.70 |
| SPC1 to SPC2 | 12.667 12.667 | | 0.0 333.54 | 6 6.065 | 1T | 30.0 0.0 | 7.833 30.000 37.833 | 120 0.0046 | 121.189 0.0 0.175 | | | Vel = 3.70 |
| SPC2 to PO | 12.667 1.833 | | 0.0 333.54 | 8 7.981 | 1I 1B 1C | 13.0 12.0 45.0 | 14.750 70.000 84.750 | 120 0.0012 | 121.364 4.692 0.103 | | | Vel = 2.14 |
| PO | | | 0.0 333.54 | | | | | | 126.159 | | | K Factor = 29.70 |
| System Demand Pressure | | | | | | 126.159 | | | | | | |
| Safety Margin | | | | | | 49.232 | | | | | | |
| Continuation Pressure | | | | | | 175.391 | | | | | | |
| Pressure @ Pump Outlet | | | | | | 175.391 | | | | | | |
| Pressure From Pump Curve | | | | | | -124.434 | | | | | | |
| Pressure @ Pump Inlet | | | | | | 50.957 | | | | | | |
| PI to POC | 1.750 6.750 | | 0.0 333.54 | 8 7.981 | 1G 1I 1T | 4.0 13.0 35.0 | 14.000 52.000 66.000 | 120 0.0012 | 50.957 -2.166 0.081 | | | Vel = 2.14 |
| POC to BF1 | 6.750 13 | | 0.0 333.54 | 8 8.27 | 2E | 56.936 0.0 | 41.000 56.936 97.936 | 140 0.0008 | 48.872 -2.707 0.075 | | | Vel = 1.99 |

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 3 [R/A=2]

Page 9
 Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|----------------------|----------------|-----------|------------------|------------|-----------------------|---------------------------|------------------------------|----------------|------------------------|-------|-----------------------------------|-------|
| BF1 to BF2 | 13 13 | | 0.0 333.54 | 8 7.981 | 1Zic | 0.0 | 4.000 | 120 | 46.240 6.090 | | * Fixed loss = 6.09 Vel = 2.14 | |
| BF2 to SRC | 13 13 | | 0.0 333.54 | 8 8.27 | 2E 1G 1T | 56.936 6.326 55.354 | 46.000 118.616 164.616 | 140 | 52.335 0.0 0.126 | | Vel = 1.99 | |
| SRC | | | 150.00 483.54 | | | | | | 52.461 | | Qa = 150.00 K Factor = 66.76 | |



LEVEL 6 R/A # 1,2,3 &4

This page intentionally left blank.



**AUTOMATIC
SPRINKLER CO.**

21605 North Central Ave. 623.580.7800
Phoenix, Arizona 85024 Fax 623.434.3154

AZ-L16-234798 CA-C16-901529
AZ-C16-234797 NV-C41-69370
UT-S370-6690455-5501 NM-MS 12-354807



Fire Protection by Computer Design

Aero Automatic Sprinkler Co.
21605 N. Central Ave.
Phoenix, Arizona 85024
623-580-7800

Job Name : Cal Poly Center for Science LVL 6 [R/A=1]
Building : FP-6.06E
Location : San Luis Obispo, Ca.
System : 6-1
Contract : 10034
Data File : Cal Poly CFS LVL 6-1.WXF

HYDRAULIC CALCULATIONS
for

Project name: Cal Poly Center For Science
Location: San Luis Obispo, Ca.
Drawing no: FP-6.06E
Date: 9-25-2011

Design

Remote area number: 6-1
Remote area location: 6 th. Floor Laboratory
Occupancy classification: Ordinary Hazard Gr. 1
Density: 0.15 - Gpm/SqFt
Area of application: 940 - SqFt
Coverage per sprinkler: 130 - SqFt
Type of sprinklers calculated: Tyco; Mod. TY-FRB; 1/2"; 1/2";K=5.6; 155 Deg
No. of sprinklers calculated: 10
In-rack demand: N/A - GPM
Hose streams: 250 - GPM
Total water required (including hose streams): 483.15 - GPM @ 12.35 - Psi
Type of system: WET
Volume of dry or preaction system: N/A - Gal

Water supply information

Date: 8-19-2011
Location: N. Poly View Drive
Source: Fluid Resource Management

Name of contractor: Aero Automatic Sprinkler Co.
Address: 21605 N. Central Ave. Phoenix, Az. 85024
Phone number: 623-580-7847
Name of designer: Neal Larsen
Authority having jurisdiction: C.S.F.M.


Notes: (Include peaking information or gridded systems here.) Flow Test Information :
Hydrant # 63; Static = 60 psi; Res.= 55 psi {Elev.=351.0'}
Hydrant # 64; Flow = 914 gpm
FLOW TEST USED IN HYD. CALCS REDUCED BY 10 % [STATIC=54psi; RES.=49psi]
NOTE : REMOTE AREA REDUCED BY 39.25% [Q.R HEADS & C.H.=10'-6"] 912 SQ.FT. MIN.

Water Supply Curve (C)

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 6 [R/A=1]

Page 2
 Date 9-25-11

| | | |
|---|--|---|
| City Water Supply: C1 - Static Pressure : 54 C2 - Residual Pressure: 49 C2 - Residual Flow : 914 City Water Adjusted to Pump Inlet for Pf - Elev - Hose Flow A1 - Adjusted Static: 51.696 A2 - Adj Resid : 47.866 @ 790.2 A3 - Adj Resid : 37.967 @ 1382.9 | Pump Data: P1 - Pump Churn Pressure : 125.2 P2 - Pump Rated Pressure : 110.9 P2 - Pump Rated Flow : 790.2 P3 - Pump Pressure @ Max Flow : 67.9 P3 - Pump Max Flow : 1382.9 City Residual Flow @ 0 = 3307.91 City Residual Flow @ 20 = 2576.03 City Water @ 150% of Pump = 43.24 | Demand: D1 - Elevation : 33.565 D2 - System Flow : 233.159 D2 - System Pressure : 135.285 Hose (Adj City) : 150 Hose (Demand) : 100 D3 - System Demand : 333.159 Safety Margin : 40.106 |
|---|--|---|



Fittings Used Summary

Aero Automatic Sprinkler Co.
Cal Poly Center for Science LVL 6 [R/A=1]

Page 3
Date 9-25-11

Fitting Legend

| Abbrev. | Name | ½ | ¾ | 1 | 1¼ | 1½ | 2 | 2½ | 3 | 3½ | 4 | 5 | 6 | 8 | 10 | 12 | 14 | 16 | 18 | 20 | 24 |
|---------|-------------------------|--|---|------|----|-----|-----|----|----|----|----|-----|----|----|----|----|----|----|----|-----|-----|
| B | Generic Butterfly Valve | 0 | 0 | 2.25 | 2 | 2.5 | 6 | 7 | 10 | 0 | 12 | 9 | 10 | 12 | 19 | 21 | 0 | 0 | 0 | 0 | 0 |
| C | Generic Check Vlv | 4 | 5 | 5 | 7 | 9 | 11 | 14 | 16 | 19 | 22 | 27 | 32 | 45 | 55 | 65 | 76 | 87 | 98 | 109 | 130 |
| E | 90' Standard Elbow | 2 | 2 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 10 | 12 | 14 | 18 | 22 | 27 | 35 | 40 | 45 | 50 | 61 |
| G | Generic Gate Valve | 0 | 0 | 0 | 1 | 0 | 1 | 1 | 1 | 1 | 2 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 10 | 11 | 13 |
| I | 90' Ell Grvd-Vic #10 | 0 | 0 | 2 | 3 | 4 | 3.5 | 6 | 5 | 8 | 7 | 8.5 | 10 | 13 | 17 | 20 | 23 | 25 | 33 | 36 | 40 |
| T | 90' Flow Thru Tee | 3 | 4 | 5 | 6 | 8 | 10 | 12 | 15 | 17 | 20 | 25 | 30 | 35 | 50 | 60 | 71 | 81 | 91 | 101 | 121 |
| Zic | Wilkens 350ADA | Fitting generates a Fixed Loss Based on Flow | | | | | | | | | | | | | | | | | | | |

Units Summary

Diameter Units Inches
Length Units Feet
Flow Units US Gallons per Minute
Pressure Units Pounds per Square Inch

Pressure / Flow Summary - STANDARD

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 6 [R/A=1]

Page 4
 Date 9-25-11

| Node No. | Elevation | K-Fact | Pt Actual | Pn | Flow Actual | Density | Area | Press Req. |
|----------|-----------|--------|-----------|----|-------------|---------|------|------------|
| S601 | 90.5 | 5.6 | 12.12 | na | 19.5 | 0.15 | 130 | 7.0 |
| S602 | 90.5 | 5.6 | 13.07 | na | 20.25 | 0.15 | 130 | 7.0 |
| S603 | 90.5 | 5.6 | 16.6 | na | 22.81 | 0.15 | 130 | 7.0 |
| S604 | 90.5 | 5.6 | 24.77 | na | 27.87 | 0.15 | 130 | 7.0 |
| S605 | 90.5 | 5.6 | 12.24 | na | 19.6 | 0.15 | 130 | 7.0 |
| S606 | 90.5 | 5.6 | 13.2 | na | 20.34 | 0.15 | 130 | 7.0 |
| S607 | 90.5 | 5.6 | 16.76 | na | 22.92 | 0.15 | 130 | 7.0 |
| S608 | 90.5 | 5.6 | 25.01 | na | 28.0 | 0.15 | 130 | 7.0 |
| S609 | 90.5 | 5.6 | 20.5 | na | 25.35 | 0.15 | 130 | 7.0 |
| S610 | 90.5 | 5.6 | 22.4 | na | 26.5 | 0.15 | 130 | 7.0 |
| L601 | 91.0 | | 12.59 | na | | | | |
| L602 | 91.0 | | 13.58 | na | | | | |
| L603 | 91.0 | | 17.29 | na | | | | |
| L604 | 91.0 | | 25.88 | na | | | | |
| L605 | 91.0 | | 12.72 | na | | | | |
| L606 | 91.0 | | 13.72 | na | | | | |
| L607 | 91.0 | | 17.46 | na | | | | |
| L608 | 91.0 | | 26.13 | na | | | | |
| L609 | 91.0 | | 21.59 | na | | | | |
| L610 | 91.0 | | 23.61 | na | | | | |
| MN01 | 92.0 | | 35.21 | na | | | | |
| MN02 | 92.0 | | 35.21 | na | | | | |
| MN03 | 92.0 | | 35.41 | na | | | | |
| MN04 | 92.0 | | 35.54 | na | | | | |
| MN05 | 92.0 | | 36.08 | na | | | | |
| MN06 | 92.0 | | 36.45 | na | | | | |
| MN07 | 92.0 | | 37.52 | na | | | | |
| MN08 | 92.0 | | 37.69 | na | | | | |
| MN09 | 92.0 | | 39.17 | na | | | | |
| MN10 | 92.0 | | 39.34 | na | | | | |
| MN11 | 92.0 | | 41.0 | na | | | | |
| MN12 | 93.333 | | 65.62 | na | | | | |
| MN13 | 93.333 | | 73.55 | na | | | | |
| MN14 | 91.083 | | 82.72 | na | | | | |
| TOR6 | 91.083 | | 86.32 | na | | | | |
| BOR6 | 84.0 | | 95.48 | na | | | | |
| HV1 | 99.75 | | 90.08 | na | | | | |
| HV2 | 99.75 | | 90.08 | na | | | | |
| SPRF | 99.75 | | 91.83 | na | | | | |
| SP16 | 85.0 | | 98.22 | na | | | | |
| SP15 | 69.0 | | 105.15 | na | | | | |
| SP14 | 53.0 | | 112.08 | na | | | | |
| SP13 | 37.0 | | 119.01 | na | | | | |
| HV3 | 101.0 | | 88.77 | na | | | | |
| SPR3 | 101.0 | | 90.52 | na | | | | |
| SP36 | 85.0 | | 97.45 | na | 50.0 | | | |
| SP35 | 69.0 | | 104.44 | na | 50.0 | | | |
| SP34 | 53.0 | | 111.44 | na | | | | |
| SP33 | 37.0 | | 118.44 | na | | | | |
| SP32 | 21.0 | | 125.55 | na | | | | |
| SP05 | 29.167 | | 122.01 | na | | | | |
| SP01 | 45.0 | | 115.54 | na | | | | |
| SP02 | 27.917 | | 122.94 | na | | | | |
| SP03 | 29.167 | | 122.4 | na | | | | |
| SP04 | 28.083 | | 123.18 | na | | | | |
| SPC1 | 12.667 | | 130.32 | na | | | | |
| SPC2 | 12.667 | | 130.49 | na | | | | |
| PO | 1.833 | | 135.28 | na | | | | |
| PI | 1.75 | | 50.96 | na | | | | |
| POC | 6.75 | | 48.87 | na | | | | |
| BF1 | 13.0 | | 46.24 | na | | | | |
| BF2 | 13.0 | | 52.34 | na | | | | |

Flow Summary - Standard

Aero Automatic Sprinkler Co.
Cal Poly Center for Science LVL 6 [R/A=1]

Page 5
Date 9-25-11

| Node No. | Elevation | K-Fact | Pt Actual | Pn | Flow Actual | Density | Area | Press Req. |
|----------|-----------|--------|-----------|----|-------------|---------|------|------------|
| SRC | 13.0 | | 52.46 | na | 150.0 | | | |

The maximum velocity is 23.34 and it occurs in the pipe between nodes L607 and L608

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 6 [R/A=1]

Page 6
 Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|------------------------------|----------------|-----------|----------------|------------|-----------------------|-------------------|-------------------------|----------------|---------------------------|-------|-----------------|-------------|
| *FLOWING SPRINKLER R/A # 1 # | | | | | | | | | | | | |
| S601 to L601 | 90.5 91 | 5.60 | 19.50 19.5 | 1 1.049 | 1T | 5.0 0.0 0.0 | 0.500 5.000 5.500 | 120 | 12.125 -0.217 0.684 | | | Vel = 7.24 |
| L601 | | | 0.0 19.50 | | | | | | 12.592 | | K Factor = 5.50 | |
| S602 to L602 | 90.5 91 | 5.60 | 20.24 20.24 | 1 1.049 | 1T | 5.0 0.0 0.0 | 0.500 5.000 5.500 | 120 | 13.070 -0.217 0.732 | | | Vel = 7.51 |
| L602 | | | 0.0 20.24 | | | | | | 13.585 | | K Factor = 5.49 | |
| S603 to L603 | 90.5 91 | 5.60 | 22.81 22.81 | 1 1.049 | 1T | 5.0 0.0 0.0 | 0.500 5.000 5.500 | 120 | 16.598 -0.217 0.913 | | | Vel = 8.47 |
| L603 | | | 0.0 22.81 | | | | | | 17.294 | | K Factor = 5.49 | |
| S604 to L604 | 90.5 91 | 5.60 | 27.87 27.87 | 1 1.049 | 1T | 5.0 0.0 0.0 | 0.500 5.000 5.500 | 120 | 24.772 -0.217 1.323 | | | Vel = 10.35 |
| L604 | | | 0.0 27.87 | | | | | | 25.878 | | K Factor = 5.48 | |
| S605 to L605 | 90.5 91 | 5.60 | 19.60 19.6 | 1 1.049 | 1T | 5.0 0.0 0.0 | 0.500 5.000 5.500 | 120 | 12.245 -0.217 0.690 | | | Vel = 7.28 |
| L605 | | | 0.0 19.60 | | | | | | 12.718 | | K Factor = 5.50 | |
| S606 to L606 | 90.5 91 | 5.60 | 20.34 20.34 | 1 1.049 | 1T | 5.0 0.0 0.0 | 0.500 5.000 5.500 | 120 | 13.198 -0.217 0.739 | | | Vel = 7.55 |
| L606 | | | 0.0 20.34 | | | | | | 13.720 | | K Factor = 5.49 | |
| S607 to L607 | 90.5 91 | 5.60 | 22.92 22.92 | 1 1.049 | 1T | 5.0 0.0 0.0 | 0.500 5.000 5.500 | 120 | 16.758 -0.217 0.922 | | | Vel = 8.51 |
| L607 | | | 0.0 22.92 | | | | | | 17.463 | | K Factor = 5.48 | |
| S608 to L608 | 90.5 91 | 5.60 | 28.00 28.0 | 1 1.049 | 1T | 5.0 0.0 0.0 | 0.500 5.000 5.500 | 120 | 25.008 -0.217 1.335 | | | Vel = 10.39 |
| L608 | | | 0.0 28.00 | | | | | | 26.126 | | K Factor = 5.48 | |
| S609 to L609 | 90.5 91 | 5.60 | 25.35 25.35 | 1 1.049 | 1T | 5.0 0.0 0.0 | 1.500 5.000 6.500 | 120 | 20.496 -0.217 1.312 | | | Vel = 9.41 |
| L609 | | | 0.0 25.35 | | | | | | 21.591 | | K Factor = 5.46 | |
| S610 to L610 | 90.5 91 | 5.60 | 26.50 26.5 | 1 1.049 | 1T | 5.0 0.0 0.0 | 1.500 5.000 6.500 | 120 | 22.401 -0.217 1.425 | | | Vel = 9.84 |

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 6 [R/A=1]

Page 7
 Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** | |
|-----------------------|----------------|-----------|----------------|--------------|-----------------------|------------|-------------------------|----------------|------------------|------------------|-------|-------------|--|
| | | | 0.0 | | | | | | | | | | |
| L610 | | | 26.50 | | | | | | 23.609 | K Factor = 5.45 | | | |
| *BRANCH LINES R/A # 1 | | | | | | | | | | | | | |
| L601 to L602 | 91 91 | | 19.50 19.5 | 1 1.049 | | 0.0 0.0 | 8.000 0.0 | 120 0.1241 | 12.592 0.0 | | | Vel = 7.24 | |
| L602 to L603 | 91 91 | | 20.24 39.74 | 1 1.049 | | 0.0 0.0 | 8.000 8.000 | 120 0.4636 | 13.585 3.709 | | | Vel = 14.75 | |
| L603 to L604 | 91 91 | | 22.82 62.56 | 1 1.049 | | 0.0 0.0 | 8.000 8.000 | 120 1.0730 | 17.294 8.584 | | | Vel = 23.22 | |
| L604 to MN02 | 91 92 | | 27.87 90.43 | 1.25 1.38 | 1E 1T | 3.0 6.0 | 8.500 9.000 | 120 0.5580 | 25.878 -0.433 | | | Vel = 19.40 | |
| MN02 | | | 0.0 | | | | | | 35.210 | K Factor = 15.24 | | | |
| L605 to L606 | 91 91 | | 19.60 19.6 | 1 1.049 | | 0.0 0.0 | 8.000 8.000 | 120 0.1252 | 12.718 1.002 | | | Vel = 7.28 | |
| L606 to L607 | 91 91 | | 20.34 39.94 | 1 1.049 | | 0.0 0.0 | 8.000 8.000 | 120 0.4679 | 13.720 3.743 | | | Vel = 14.83 | |
| L607 to L608 | 91 91 | | 22.93 62.87 | 1 1.049 | | 0.0 0.0 | 8.000 8.000 | 120 1.0829 | 17.463 8.663 | | | Vel = 23.34 | |
| L608 to MN04 | 91 92 | | 28.00 90.87 | 1.25 1.38 | 1E 1T | 3.0 6.0 | 8.500 9.000 | 120 0.5630 | 26.126 -0.433 | | | Vel = 19.49 | |
| MN04 | | | 0.0 | | | | | | 35.545 | K Factor = 15.24 | | | |
| L609 to L610 | 91 91 | | 25.35 25.35 | 1 1.049 | | 0.0 0.0 | 10.000 10.000 | 120 0.2018 | 21.591 0.0 | | | Vel = 9.41 | |
| L610 to MN06 | 91 92 | | 26.51 51.86 | 1 1.049 | 1E 1T | 2.0 5.0 | 10.500 7.000 | 120 0.7583 | 23.609 -0.433 | | | Vel = 19.25 | |
| MN06 | | | 0.0 | | | | | | 36.447 | K Factor = 8.59 | | | |
| *FEED MAIN | | | | | | | | | | | | | |
| MN01 to MN02 | 92 92 | .0 | 0.0 | 2.5 | | 0.0 0.0 | 3.833 0.0 | 120 0 | 35.210 0.0 | | | Vel = 0 | |
| MN02 to MN03 | 92 92 | | 90.43 | 2.5 | | 0.0 0.0 | 8.167 0.0 | 120 | 35.210 0.0 | | | Vel = 5.32 | |
| MN03 to MN04 | 92 92 | | 90.43 | 2.635 | | 0.0 0.0 | 8.167 5.833 | 0.0240 120 | 0.196 35.406 | | | Vel = 5.32 | |

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 6 [R/A=1]

Page 8
 Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|----------------------|------------------|-----------|-----------------|--------------|-----------------------|------------------------|---------------------------|----------------|--------------------------|-------------|--------------------------------|-------|
| MN04 to MN05 | 92 92 | | 90.87 181.3 | 2.5 2.635 | | 0.0 0.0 | 6.167 0.0 | 120 0.0866 | 35.545 0.0 | | | |
| | | | | | | 0.0 | 6.167 | | 0.534 | Vel = 10.67 | | |
| MN05 to MN06 | 92 92 | | 0.0 181.3 | 2.5 2.635 | | 0.0 0.0 | 4.250 0.0 | 120 0.0866 | 36.079 0.0 | | | |
| | | | | | | 0.0 | 4.250 | | 0.368 | Vel = 10.67 | | |
| MN06 to MN07 | 92 92 | | 51.86 233.16 | 2.5 2.635 | | 0.0 0.0 | 7.750 0.0 | 120 0.1379 | 36.447 0.0 | | | |
| | | | | | | 0.0 | 7.750 | | 1.069 | Vel = 13.72 | | |
| MN07 to MN08 | 92 92 | | 0.0 233.16 | 2.5 2.635 | | 0.0 0.0 | 1.250 0.0 | 120 0.1376 | 37.516 0.0 | | | |
| | | | | | | 0.0 | 1.250 | | 0.172 | Vel = 13.72 | | |
| MN08 to MN09 | 92 92 | | 0.0 233.16 | 2.5 2.635 | | 0.0 0.0 | 10.750 0.0 | 120 0.1380 | 37.688 0.0 | | | |
| | | | | | | 0.0 | 10.750 | | 1.483 | Vel = 13.72 | | |
| MN09 to MN10 | 92 92 | | 0.0 233.16 | 2.5 2.635 | | 0.0 0.0 | 1.250 0.0 | 120 0.1376 | 39.171 0.0 | | | |
| | | | | | | 0.0 | 1.250 | | 0.172 | Vel = 13.72 | | |
| MN10 to MN11 | 92 92 | | 0.0 233.16 | 2.5 2.635 | | 0.0 0.0 | 12.000 0.0 | 120 0.1379 | 39.343 0.0 | | | |
| | | | | | | 0.0 | 12.000 | | 1.655 | Vel = 13.72 | | |
| MN11 to MN12 | 92 93.333 | | 0.0 233.16 | 2.5 2.635 | 2I 1T | 16.474 16.474 | 149.750 32.948 | 120 | 40.998 -0.577 | | | |
| | | | | | | 0.0 | 182.698 | 0.1379 | 25.197 | Vel = 13.72 | | |
| MN12 to MN13 | 93.333 93.333 | | 0.0 233.16 | 2.5 2.635 | 1I 1T | 8.237 16.474 | 32.833 24.711 | 120 | 65.618 0.0 | | | |
| | | | | | | 0.0 | 57.544 | 0.1379 | 7.936 | Vel = 13.72 | | |
| MN13 to MN14 | 93.333 91.083 | | 0.0 233.16 | 2.5 2.635 | 2I 1T | 16.474 16.474 | 26.417 32.948 | 120 | 73.554 0.974 | | | |
| | | | | | | 0.0 | 59.365 | 0.1379 | 8.188 | Vel = 13.72 | | |
| MN14 to TOR6 | 91.083 91.083 | | 0.0 233.16 | 2.5 2.635 | 2I | 16.474 0.0 | 9.667 16.474 | 120 | 82.716 0.0 | | | |
| | | | | | | 0.0 | 26.141 | 0.1379 | 3.605 | Vel = 13.72 | | |
| TOR6 to BOR6 | 91.083 84 | | 0.0 233.16 | 2.5 2.635 | 1C 1B 1I | 19.22 9.61 8.237 | 7.083 37.067 44.150 | 120 | 86.321 3.068 6.088 | | | |
| | | | | | | 0.0 | 17.474 | 0.1379 | 2.410 | Vel = 13.72 | | |
| BOR6 to SP36 | 84 85 | | 0.0 233.16 | 2.5 2.635 | 1T | 16.474 0.0 | 1.000 16.474 | 120 | 95.477 -0.433 | | | |
| | | | | | | 0.0 | 17.474 | 0.1379 | 2.410 | Vel = 13.72 | | |
| SP36 | | | 0.0 233.16 | | | | | | 97.454 | | K Factor = 23.62 | |
| *S/P # 1 | | | | | | | | | | | | |
| HV1 to SPRF | 99.750 99.750 | .0 | 0.0 | 2.5 | 1T | 12.0 0.0 | 0.250 12.000 | 120 0 | 90.082 1.750 0.0 | | * Fixed loss = 1.75 Vel = 0 | |
| SPRF | | | 0.0 0.0 | | | | | | 91.832 | | K Factor = 0 | |

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 6 [R/A=1]

Page 9
 Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|----------------------|------------------|-----------|---------------|------------|-----------------------|----------------------|----------------------------|----------------|-------------------------|-------|---------------------|-------|
| HV2 to SPRF | 99.750 99.750 | .0 | 0.0 | 2.5 | 1T | 12.0 0.0 | 0.250 12.000 | 120 | 90.082 1.750 | | * Fixed loss = 1.75 | |
| | | | 0.0 | 2.469 | | 0.0 | 12.250 | 0 | 0.0 | | Vel = 0 | |
| SPRF to SP16 | 99.750 85 | .0 | 0.0 | 6 | 4I | 40.0 0.0 | 30.000 40.000 | 120 | 91.832 6.388 | | | |
| | | | 0.0 | 6.065 | | 0.0 | 70.000 | 0 | 0.0 | | Vel = 0 | |
| SP16 to SP15 | 85 69 | .0 | 0.0 | 6 | | 0.0 0.0 | 16.000 0.0 | 120 | 98.220 6.930 | | | |
| | | | 0.0 | 6.065 | | 0.0 | 16.000 | 0 | 0.0 | | Vel = 0 | |
| SP15 to SP14 | 69 53 | .0 | 0.0 | 6 | | 0.0 0.0 | 16.000 0.0 | 120 | 105.150 6.930 | | | |
| | | | 0.0 | 6.065 | | 0.0 | 16.000 | 0 | 0.0 | | Vel = 0 | |
| SP14 to SP01 | 53 45 | .0 | 0.0 | 6 | 1T | 30.0 0.0 | 8.500 30.000 | 120 | 112.080 3.465 | | | |
| | | | 0.0 | 6.065 | | 0.0 | 38.500 | 0 | 0.0 | | Vel = 0 | |
| SP01 | | | 0.0 0.0 | | | | | | 115.545 | | K Factor = 0 | |
| SP13 to SP01 | 37 45 | .0 | 0.0 | 6 | 1T | 30.0 0.0 | 7.500 30.000 | 120 | 119.009 -3.465 | | | |
| | | | 0.0 | 6.065 | | 0.0 | 37.500 | 0 | 0.0 | | Vel = 0 | |
| SP01 | | | 0.0 0.0 | | | | | | 115.544 | | K Factor = 0 | |
| *S/P # 3 | | | | | | | | | | | | |
| HV3 to SPR3 | 101 101 | .0 | 0.0 | 2.5 | 2E 1T | 12.0 12.0 | 1.750 24.000 | 120 | 88.774 1.750 | | * Fixed loss = 1.75 | |
| | | | 0.0 | 2.469 | | 0.0 | 25.750 | 0 | 0.0 | | Vel = 0 | |
| SPR3 to SP36 | 101 85 | .0 | 0.0 | 6 | | 0.0 0.0 | 16.000 0.0 | 120 | 90.524 6.930 | | | |
| | | | 0.0 | 6.065 | | 0.0 | 16.000 | 0 | 0.0 | | Vel = 0 | |
| SP36 to SP35 | 85 69 | H50 | 283.16 | 6 | | 0.0 0.0 | 16.000 0.0 | 120 | 97.454 6.930 | | | |
| | | | 283.16 | 6.065 | | 0.0 | 16.000 | 0.0034 | 0.054 | | Vel = 3.14 | |
| SP35 to SP34 | 69 53 | H50 | 50.00 | 6 | | 0.0 0.0 | 16.000 0.0 | 120 | 104.438 6.930 | | | |
| | | | 333.16 | 6.065 | | 0.0 | 16.000 | 0.0046 | 0.074 | | Vel = 3.70 | |
| SP34 to SP33 | 53 37 | | 0.0 | 6 | | 0.0 0.0 | 16.000 0.0 | 120 | 111.442 6.930 | | | |
| | | | 333.16 | 6.065 | | 0.0 | 16.000 | 0.0046 | 0.073 | | Vel = 3.70 | |
| SP33 to SP05 | 37 29.167 | | 0.0 | 6 | 1T | 30.0 0.0 | 8.417 30.000 | 120 | 118.445 3.392 | | | |
| | | | 333.16 | 6.065 | | 0.0 | 38.417 | 0.0046 | 0.177 | | Vel = 3.70 | |
| SP05 | | | 0.0 333.16 | | | | | | 122.014 | | K Factor = 30.16 | |
| SP32 to SP05 | 21 29.167 | .0 | 0.0 | 6 | 1T | 30.0 0.0 | 7.583 30.000 | 120 | 125.551 -3.537 | | | |
| | | | 0.0 | 6.065 | | 0.0 | 37.583 | 0 | 0.0 | | Vel = 0 | |
| SP05 to SP03 | 29.167 29.167 | | 333.16 | 6 | 1I 1B 1T | 10.0 10.0 30.0 | 34.167 50.000 84.167 | 120 | 122.014 0.0 0.388 | | | |
| | | | 333.16 | 6.065 | | 30.0 | 84.167 | 0.0046 | 0.388 | | Vel = 3.70 | |

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 6 [R/A=1]

Page 10
 Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|--------------------------|----------------|-----------|----------|------------|-----------------------|----------|-------------------------|----------------|----------------|---------------------------------|-------|-------|
| | | | 0.0 | | | | | | | | | |
| SP03 | | | 333.16 | | | | | | | | | |
| | | | | | | | | | 122.402 | K Factor = 30.11 | | |
| *STANDPIPE FEED | | | | | | | | | | | | |
| SP01 | 45 | .0 | 0.0 | 6 | 1B | 10.0 | 34.417 | 120 | 115.544 | | | |
| to | | | | | 6I | 60.0 | 70.000 | | 7.399 | | | |
| SP02 | 27.917 | | 0.0 | 6.065 | | 0.0 | 104.417 | 0 | 0.0 | Vel = 0 | | |
| SP02 | 27.917 | .0 | 0.0 | 6 | 2I | 20.0 | 235.417 | 120 | 122.943 | | | |
| to | | | | | | 0.0 | 20.000 | | -0.541 | | | |
| SP03 | 29.167 | | 0.0 | 6.065 | | 0.0 | 255.417 | 0 | 0.0 | Vel = 0 | | |
| SP03 | 29.167 | | 333.16 | 6 | 4I | 40.0 | 27.500 | 120 | 122.402 | | | |
| to | | | | | | 0.0 | 40.000 | | 0.469 | | | |
| SP04 | 28.083 | | 333.16 | 6.065 | | 0.0 | 67.500 | 0.0046 | 0.311 | Vel = 3.70 | | |
| SP04 | 28.083 | | 0.0 | 6 | 2I | 20.0 | 79.330 | 120 | 123.182 | | | |
| to | | | | | | 0.0 | 20.000 | | 6.677 | | | |
| SPC1 | 12.667 | | 333.16 | 6.065 | | 0.0 | 99.330 | 0.0046 | 0.457 | Vel = 3.70 | | |
| SPC1 | 12.667 | | 0.0 | 6 | 1T | 30.0 | 7.833 | 120 | 130.316 | | | |
| to | | | | | | 0.0 | 30.000 | | 0.0 | | | |
| SPC2 | 12.667 | | 333.16 | 6.065 | | 0.0 | 37.833 | 0.0046 | 0.174 | Vel = 3.70 | | |
| SPC2 | 12.667 | | 0.0 | 8 | 1I | 13.0 | 14.750 | 120 | 130.490 | | | |
| to | | | | | 1B | 12.0 | 70.000 | | 4.692 | | | |
| PO | 1.833 | | 333.16 | 7.981 | 1C | 45.0 | 84.750 | 0.0012 | 0.103 | Vel = 2.14 | | |
| | | | 0.0 | | | | | | | | | |
| PO | | | 333.16 | | | | | | | | | |
| | | | | | | | | | 135.285 | K Factor = 28.64 | | |
| System Demand Pressure | | | | | | 135.285 | | | | | | |
| Safety Margin | | | | | | 40.106 | | | | | | |
| Continuation Pressure | | | | | | 175.391 | | | | | | |
| Pressure @ Pump Outlet | | | | | | 175.391 | | | | | | |
| Pressure From Pump Curve | | | | | | -124.435 | | | | | | |
| Pressure @ Pump Inlet | | | | | | 50.956 | | | | | | |
| PI | 1.750 | | 0.0 | 8 | 1G | 4.0 | 14.000 | 120 | 50.956 | | | |
| to | | | | | 1I | 13.0 | 52.000 | | -2.166 | | | |
| POC | 6.750 | | 333.16 | 7.981 | 1T | 35.0 | 66.000 | 0.0012 | 0.081 | Vel = 2.14 | | |
| POC | 6.750 | | 0.0 | 8 | 2E | 56.936 | 41.000 | 140 | 48.871 | | | |
| to | | | | | | 0.0 | 56.936 | | -2.707 | | | |
| BF1 | 13 | | 333.16 | 8.27 | | 0.0 | 97.936 | 0.0008 | 0.075 | Vel = 1.99 | | |
| BF1 | 13 | | 0.0 | 8 | 1Zic | 0.0 | 4.000 | 120 | 46.239 | | | |
| to | | | | | | 0.0 | 0.0 | | 6.093 | * Fixed loss = 6.093 | | |
| BF2 | 13 | | 333.16 | 7.981 | | 0.0 | 4.000 | 0.0012 | 0.005 | Vel = 2.14 | | |
| BF2 | 13 | | 0.0 | 8 | 2E | 56.936 | 46.000 | 140 | 52.337 | | | |
| to | | | | | 1G | 6.326 | 118.616 | | 0.0 | | | |
| SRC | 13 | | 333.16 | 8.27 | 1T | 55.354 | 164.616 | 0.0008 | 0.125 | Vel = 1.99 | | |
| | | | 150.00 | | | | | | | | | |
| SRC | | | 483.16 | | | | | | | | | |
| | | | | | | | | | 52.462 | Qa = 150.00 K Factor = 66.71 | | |

This page intentionally left blank.



**AUTOMATIC
SPRINKLER CO.**

21605 North Central Ave. 623.580.7800
Phoenix, Arizona 85024 Fax 623.434.3154

AZ-L16-234798 CA-C16-901529
AZ-C16-234797 NV-C41-69370
UT-S370-6690455-5501 NM-MS 12-354807



Fire Protection by Computer Design

Aero Automatic Sprinkler Co.
21605 N. Central Ave.
Phoenix, Arizona 85024
623-580-7800

Job Name : Cal Poly Center for Science LVL 6 [R/A=2]
Building : FP-6.06E
Location : San Luis Obispo, Ca.
System : 6-2
Contract : 10034
Data File : Cal Poly CFS LVL 6-2.WXF

HYDRAULIC CALCULATIONS
for

Project name: Cal Poly Center For Science
Location: San Luis Obispo, Ca.
Drawing no: FP-6.06E
Date: 9-25-2011

Design

Remote area number: 6-2
Remote area location: 6 th. Cooridor
Occupancy classification: Light Hazard
Density: 0.10 - Gpm/SqFt
Area of application: 5 Heads - SqFt
Coverage per sprinkler: 225 - SqFt
Type of sprinklers calculated: Tyco; Mod. TY-FRB; 1/2"; 1/2";K=5.6; 155 Deg
No. of sprinklers calculated: 5
In-rack demand: N/A - GPM
Hose streams: 100 - GPM
Total water required (including hose streams): 213.09 - GPM @ -51.52 - Psi
Type of system: WET
Volume of dry or preaction system: N/A - Gal

Water supply information

Date: 8-19-2011
Location: N. Poly View Drive
Source: Fluid Resource Management

Name of contractor: Aero Automatic Sprinkler Co.
Address: 21605 N. Central Ave. Phoenix, Az. 85024
Phone number: 623-580-7847
Name of designer: Neal Larsen
Authority having jurisdiction: C.S.F.M.


Notes: (Include peaking information or gridded systems here.) Flow Test Information :
Hydrant # 63; Static = 60 psi; Res.= 55 psi {Elev.=351.0'}
Hydrant # 64; Flow = 914 gpm
FLOW TEST USED IN HYD. CALCS REDUCED BY 10 % [STATIC=54psi; RES.=49psi]

Water Supply Curve (C)

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 6 [R/A=2]

Page 2
 Date 9-25-11

| City Water Supply: | | Pump Data: | | Demand: | |
|--|-------------------|-------------------------------|-----------|----------------------|-----------|
| C1 - Static Pressure | : 54 | P1 - Pump Churn Pressure | : 125.2 | D1 - Elevation | : 33.132 |
| C2 - Residual Pressure | : 49 | P2 - Pump Rated Pressure | : 110.9 | D2 - System Flow | : 113.099 |
| C2 - Residual Flow | : 914 | P2 - Pump Rated Flow | : 790.2 | D2 - System Pressure | : 71.563 |
| City Water Adjusted to Pump Inlet for Pf - Elev - Hose Flow | | P3 - Pump Pressure @ Max Flow | : 67.9 | Hose (Adj City) | : _____ |
| A1 - Adjusted Static | : 51.872 | P3 - Pump Max Flow | : 1382.9 | Hose (Demand) | : 100 |
| A2 - Adj Resid | : 49.314 @ 790.2 | City Residual Flow @ 0 | = 3307.91 | D3 - System Demand | : 213.099 |
| A3 - Adj Resid | : 40.224 @ 1382.9 | City Residual Flow @ 20 | = 2576.03 | Safety Margin | : 105.185 |
| | | City Water @ 150% of Pump | = 43.24 | | |



Fittings Used Summary

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 6 [R/A=2]

Page 3
 Date 9-25-11

Fitting Legend

| Abbrev. | Name | ½ | ¾ | 1 | 1¼ | 1½ | 2 | 2½ | 3 | 3½ | 4 | 5 | 6 | 8 | 10 | 12 | 14 | 16 | 18 | 20 | 24 |
|---------|-------------------------|--|---|------|----|-----|-----|----|----|----|----|-----|----|----|----|----|----|----|----|-----|-----|
| B | Generic Butterfly Valve | 0 | 0 | 2.25 | 2 | 2.5 | 6 | 7 | 10 | 0 | 12 | 9 | 10 | 12 | 19 | 21 | 0 | 0 | 0 | 0 | 0 |
| C | Generic Check Vlv | 4 | 5 | 5 | 7 | 9 | 11 | 14 | 16 | 19 | 22 | 27 | 32 | 45 | 55 | 65 | 76 | 87 | 98 | 109 | 130 |
| E | 90' Standard Elbow | 2 | 2 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 10 | 12 | 14 | 18 | 22 | 27 | 35 | 40 | 45 | 50 | 61 |
| G | Generic Gate Valve | 0 | 0 | 0 | 1 | 0 | 1 | 1 | 1 | 1 | 2 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 10 | 11 | 13 |
| I | 90' Ell Grvd-Vic #10 | 0 | 0 | 2 | 3 | 4 | 3.5 | 6 | 5 | 8 | 7 | 8.5 | 10 | 13 | 17 | 20 | 23 | 25 | 33 | 36 | 40 |
| T | 90' Flow Thru Tee | 3 | 4 | 5 | 6 | 8 | 10 | 12 | 15 | 17 | 20 | 25 | 30 | 35 | 50 | 60 | 71 | 81 | 91 | 101 | 121 |
| Zic | Wilkens 350ADA | Fitting generates a Fixed Loss Based on Flow | | | | | | | | | | | | | | | | | | | |

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Pressure / Flow Summary - STANDARD

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 6 [R/A=2]

Page 4
 Date 9-25-11

| Node No. | Elevation | K-Fact | Pt Actual | Pn | Flow Actual | Density | Area | Press Req. |
|----------|-----------|--------|-----------|----|-------------|---------|------|------------|
| S621 | 89.5 | 5.6 | 16.14 | na | 22.5 | 0.1 | 225 | 7.0 |
| S622 | 89.5 | 5.6 | 16.16 | na | 22.51 | 0.1 | 225 | 7.0 |
| S623 | 89.5 | 5.6 | 16.24 | na | 22.56 | 0.1 | 225 | 7.0 |
| S624 | 89.5 | 5.6 | 16.39 | na | 22.67 | 0.1 | 225 | 7.0 |
| S625 | 89.5 | 5.6 | 16.65 | na | 22.85 | 0.1 | 225 | 7.0 |
| MN01 | 92.0 | | 16.68 | na | | | | |
| MN02 | 92.0 | | 16.69 | na | | | | |
| MN03 | 92.0 | | 16.7 | na | | | | |
| MN04 | 92.0 | | 16.74 | na | | | | |
| MN05 | 92.0 | | 16.78 | na | | | | |
| MN06 | 92.0 | | 16.84 | na | | | | |
| MN07 | 92.0 | | 16.95 | na | | | | |
| MN08 | 92.0 | | 16.98 | na | | | | |
| MN09 | 92.0 | | 17.23 | na | | | | |
| MN10 | 92.0 | | 17.28 | na | | | | |
| MN11 | 92.0 | | 17.71 | na | | | | |
| MN12 | 93.333 | | 23.74 | na | | | | |
| MN13 | 93.333 | | 25.82 | na | | | | |
| MN14 | 91.083 | | 28.95 | na | | | | |
| TOR6 | 91.083 | | 29.89 | na | | | | |
| BOR6 | 84.0 | | 34.56 | na | | | | |
| HV1 | 99.75 | | 26.95 | na | | | | |
| HV2 | 99.75 | | 26.95 | na | | | | |
| SPRF | 99.75 | | 28.7 | na | | | | |
| SP16 | 85.0 | | 35.09 | na | | | | |
| SP15 | 69.0 | | 42.02 | na | | | | |
| SP14 | 53.0 | | 48.94 | na | | | | |
| SP13 | 37.0 | | 55.88 | na | | | | |
| HV3 | 101.0 | | 26.08 | na | | | | |
| SPR3 | 101.0 | | 27.82 | na | | | | |
| SP36 | 85.0 | | 34.76 | na | 50.0 | | | |
| SP35 | 69.0 | | 41.7 | na | 50.0 | | | |
| SP34 | 53.0 | | 48.67 | na | | | | |
| SP33 | 37.0 | | 55.63 | na | | | | |
| SP32 | 21.0 | | 62.64 | na | | | | |
| SP05 | 29.167 | | 59.1 | na | | | | |
| SP01 | 45.0 | | 52.41 | na | | | | |
| SP02 | 27.917 | | 59.81 | na | | | | |
| SP03 | 29.167 | | 59.27 | na | | | | |
| SP04 | 28.083 | | 59.87 | na | | | | |
| SPC1 | 12.667 | | 66.75 | na | | | | |
| SPC2 | 12.667 | | 66.83 | na | | | | |
| PO | 1.833 | | 71.56 | na | | | | |
| PI | 1.75 | | 51.9 | na | | | | |
| POC | 6.75 | | 49.77 | na | | | | |
| BF1 | 13.0 | | 47.1 | na | | | | |
| BF2 | 13.0 | | 53.61 | na | | | | |
| SRC | 13.0 | | 53.66 | na | | | | |

The maximum velocity is 8.48 and it occurs in the pipe between nodes S625 and MN09

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 6 [R/A=2]

Page 5
 Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|----------------------------|----------------|-----------|----------------|--------------|-----------------------|-------------------|--------------------------|----------------|---------------------------|-------|-----------------|-------|
| *FLOWING SPRINKLER R/A # 2 | | | | | | | | | | | | |
| S621 to MN01 | 89.500 92 | 5.60 | 22.50 22.5 | 1 1.049 | 1E 1T | 2.0 5.0 0.0 | 3.000 7.000 10.000 | 120 0.1619 | 16.143 -1.083 1.619 | | Vel = 8.35 | |
| MN01 | | | 0.0 22.50 | | | | | | 16.679 | | K Factor = 5.51 | |
| S622 to MN03 | 89.500 92 | 5.60 | 22.51 22.51 | 1 1.049 | 1E 1T | 2.0 5.0 0.0 | 3.000 7.000 10.000 | 120 0.1620 | 16.163 -1.083 1.620 | | Vel = 8.36 | |
| MN03 | | | 0.0 22.51 | | | | | | 16.700 | | K Factor = 5.51 | |
| S623 to MN05 | 89.500 92 | 5.60 | 22.56 22.56 | 1 1.049 | 1E 1T | 2.0 5.0 0.0 | 3.000 7.000 10.000 | 120 0.1627 | 16.235 -1.083 1.627 | | Vel = 8.37 | |
| MN05 | | | 0.0 22.56 | | | | | | 16.779 | | K Factor = 5.51 | |
| S624 to MN07 | 89.500 92 | 5.60 | 22.67 22.67 | 1 1.049 | 1E 1T | 2.0 5.0 0.0 | 3.000 7.000 10.000 | 120 0.1641 | 16.389 -1.083 1.641 | | Vel = 8.42 | |
| MN07 | | | 0.0 22.67 | | | | | | 16.947 | | K Factor = 5.51 | |
| S625 to MN09 | 89.500 92 | 5.60 | 22.85 22.85 | 1 1.049 | 1E 1T | 2.0 5.0 0.0 | 3.000 7.000 10.000 | 120 0.1666 | 16.650 -1.083 1.666 | | Vel = 8.48 | |
| MN09 | | | 0.0 22.85 | | | | | | 17.233 | | K Factor = 5.50 | |
| *FEED MAIN | | | | | | | | | | | | |
| MN01 to MN02 | 92 92 | | 22.50 22.5 | 2.5 2.635 | | 0.0 0.0 0.0 | 3.833 0.0 3.833 | 120 0.0018 | 16.679 0.0 0.007 | | Vel = 1.32 | |
| MN02 to MN03 | 92 92 | | 0.0 22.5 | 2.5 2.635 | | 0.0 0.0 0.0 | 8.167 0.0 8.167 | 120 0.0017 | 16.686 0.0 0.014 | | Vel = 1.32 | |
| MN03 to MN04 | 92 92 | | 22.51 45.01 | 2.5 2.635 | | 0.0 0.0 0.0 | 5.833 0.0 5.833 | 120 0.0067 | 16.700 0.0 0.039 | | Vel = 2.65 | |
| MN04 to MN05 | 92 92 | | 0.0 45.01 | 2.5 2.635 | | 0.0 0.0 0.0 | 6.167 0.0 6.167 | 120 0.0065 | 16.739 0.0 0.040 | | Vel = 2.65 | |
| MN05 to MN06 | 92 92 | | 22.57 67.58 | 2.5 2.635 | | 0.0 0.0 0.0 | 4.250 0.0 4.250 | 120 0.0141 | 16.779 0.0 0.060 | | Vel = 3.98 | |
| MN06 to MN07 | 92 92 | | 0.0 67.58 | 2.5 2.635 | | 0.0 0.0 0.0 | 7.750 0.0 7.750 | 120 0.0139 | 16.839 0.0 0.108 | | Vel = 3.98 | |
| MN07 to MN08 | 92 92 | | 22.67 90.25 | 2.5 2.635 | | 0.0 0.0 0.0 | 1.250 0.0 1.250 | 120 0.0240 | 16.947 0.0 0.030 | | Vel = 5.31 | |

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 6 [R/A=2]

Page 6
 Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|----------------------|------------------|-----------|----------------|--------------|-----------------------|------------------------|---------------------------|----------------|--------------------------|----------------|-------|-------|
| MN08 to MN09 | 92 92 | | 0.0 90.25 | 2.5 2.635 | | 0.0 0.0 | 10.750 0.0 | 120 0.0238 | 16.977 0.0 | | | |
| | | | | | | 0.0 | 10.750 | | 0.256 | Vel = | 5.31 | |
| MN09 to MN10 | 92 92 | | 22.85 113.1 | 2.5 2.635 | | 0.0 0.0 | 1.250 0.0 | 120 0.0360 | 17.233 0.0 | | | |
| | | | | | | 0.0 | 1.250 | | 0.045 | Vel = | 6.65 | |
| MN10 to MN11 | 92 92 | | 0.0 113.1 | 2.5 2.635 | | 0.0 0.0 | 12.000 0.0 | 120 0.0362 | 17.278 0.0 | | | |
| | | | | | | 0.0 | 12.000 | | 0.434 | Vel = | 6.65 | |
| MN11 to MN12 | 92 93.333 | | 0.0 113.1 | 2.5 2.635 | 2I 1T | 16.474 16.474 | 149.750 32.948 | 120 0.0362 | 17.712 -0.577 | | | |
| | | | | | | 0.0 | 182.698 | | 6.608 | Vel = | 6.65 | |
| MN12 to MN13 | 93.333 93.333 | | 0.0 113.1 | 2.5 2.635 | 1I 1T | 8.237 16.474 | 32.833 24.711 | 120 0.0362 | 23.743 0.0 | | | |
| | | | | | | 0.0 | 57.544 | | 2.081 | Vel = | 6.65 | |
| MN13 to MN14 | 93.333 91.083 | | 0.0 113.1 | 2.5 2.635 | 2I 1T | 16.474 16.474 | 26.417 32.948 | 120 0.0362 | 25.824 0.974 | | | |
| | | | | | | 0.0 | 59.365 | | 2.148 | Vel = | 6.65 | |
| MN14 to TOR6 | 91.083 91.083 | | 0.0 113.1 | 2.5 2.635 | 2I | 16.474 0.0 | 9.667 16.474 | 120 0.0362 | 28.946 0.0 | | | |
| | | | | | | 0.0 | 26.141 | | 0.946 | Vel = | 6.65 | |
| TOR6 to BOR6 | 91.083 84 | | 0.0 113.1 | 2.5 2.635 | 1C 1B 1I | 19.22 9.61 8.237 | 7.083 37.067 44.150 | 120 0.0361 | 29.892 3.068 1.596 | | | |
| | | | | | | 0.0 | 1.000 | | 34.556 | Vel = | 6.65 | |
| BOR6 to SP36 | 84 85 | | 0.0 113.1 | 2.5 2.635 | 1T | 16.474 0.0 | 1.000 16.474 | 120 0.0362 | 34.556 -0.433 | | | |
| | | | | | | 0.0 | 17.474 | | 0.632 | Vel = | 6.65 | |
| SP36 | | | 0.0 113.10 | | | | | | 34.755 | K Factor = | 19.18 | |
| *S/P # 1 | | | | | | | | | | | | |
| HV1 to SPRF | 99.750 99.750 | .0 | 0.0 0.0 | 2.5 2.469 | 1T | 12.0 0.0 | 0.250 12.000 | 120 0 | 26.948 1.750 | | | |
| | | | | | | 0.0 | 12.250 | | 0.0 | * Fixed loss = | 1.75 | |
| | | | | | | | | | 0.0 | Vel = | 0 | |
| SPRF | | | 0.0 0.0 | | | | | | 28.698 | K Factor = | 0 | |
| HV2 to SPRF | 99.750 99.750 | .0 | 0.0 0.0 | 2.5 2.469 | 1T | 12.0 0.0 | 0.250 12.000 | 120 0 | 26.948 1.750 | | | |
| | | | | | | 0.0 | 12.250 | | 0.0 | * Fixed loss = | 1.75 | |
| | | | | | | | | | 0.0 | Vel = | 0 | |
| SPRF to SP16 | 99.750 85 | .0 | 0.0 0.0 | 6 6.065 | 4I | 40.0 0.0 | 30.000 40.000 | 120 0 | 28.698 6.388 | | | |
| | | | | | | 0.0 | 70.000 | | 0.0 | Vel = | 0 | |
| SP16 to SP15 | 85 69 | .0 | 0.0 0.0 | 6 6.065 | | 0.0 0.0 | 16.000 0.0 | 120 0 | 35.086 6.930 | | | |
| | | | | | | 0.0 | 16.000 | | 0.0 | Vel = | 0 | |
| SP15 to SP14 | 69 53 | .0 | 0.0 0.0 | 6 6.065 | | 0.0 0.0 | 16.000 0.0 | 120 0 | 42.016 6.930 | | | |
| | | | | | | 0.0 | 16.000 | | 0.0 | Vel = | 0 | |

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 6 [R/A=2]

Page 7
 Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|----------------------|------------------|-----------|-----------------|--------------|-----------------------|----------------------|------------------------------|----------------|--------------------------|-------|-------|--------------------------------|
| SP14 to SP01 | 53 45 | .0 | 0.0 0.0 | 6 6.065 | 1T | 30.0 0.0 0.0 | 8.500 30.000 38.500 | 120 0 | 48.945 3.465 0.0 | | | Vel = 0 |
| SP01 | | | 0.0 | | | | | | 52.410 | | | K Factor = 0 |
| SP13 to SP01 | 37 45 | .0 | 0.0 0.0 | 6 6.065 | 1T | 30.0 0.0 0.0 | 7.500 30.000 37.500 | 120 0 | 55.875 -3.465 0.0 | | | Vel = 0 |
| SP01 | | | 0.0 | | | | | | 52.410 | | | K Factor = 0 |
| *S/P # 3 | | | | | | | | | | | | |
| HV3 to SPR3 | 101 101 | .0 | 0.0 0.0 | 2.5 2.469 | 2E 1T | 12.0 12.0 0.0 | 1.750 24.000 25.750 | 120 0 | 26.075 1.750 0.0 | | | * Fixed loss = 1.75 Vel = 0 |
| SPR3 to SP36 | 101 85 | .0 | 0.0 0.0 | 6 6.065 | | 0.0 0.0 0.0 | 16.000 0.0 16.000 | 120 0 | 27.825 6.930 0.0 | | | Vel = 0 |
| SP36 to SP35 | 85 69 | H50 | 163.10 163.1 | 6 6.065 | | 0.0 0.0 0.0 | 16.000 0.0 16.000 | 120 0.0012 | 34.755 6.930 0.019 | | | Vel = 1.81 |
| SP35 to SP34 | 69 53 | H50 | 50.00 213.1 | 6 6.065 | | 0.0 0.0 0.0 | 16.000 0.0 16.000 | 120 0.0020 | 41.704 6.930 0.032 | | | Vel = 2.37 |
| SP34 to SP33 | 53 37 | | 0.0 213.1 | 6 6.065 | | 0.0 0.0 0.0 | 16.000 0.0 16.000 | 120 0.0020 | 48.666 6.930 0.032 | | | Vel = 2.37 |
| SP33 to SP05 | 37 29.167 | | 0.0 213.1 | 6 6.065 | 1T | 30.0 0.0 0.0 | 8.417 30.000 38.417 | 120 0.0020 | 55.628 3.392 0.078 | | | Vel = 2.37 |
| SP05 | | | 0.0 213.10 | | | | | | 59.098 | | | K Factor = 27.72 |
| SP32 to SP05 | 21 29.167 | .0 | 0.0 0.0 | 6 6.065 | 1T | 30.0 0.0 0.0 | 7.583 30.000 37.583 | 120 0 | 62.635 -3.537 0.0 | | | Vel = 0 |
| SP05 to SP03 | 29.167 29.167 | | 213.10 213.1 | 6 6.065 | 1I 1B 1T | 10.0 10.0 30.0 | 34.167 50.000 84.167 | 120 0.0020 | 59.098 0.0 0.169 | | | Vel = 2.37 |
| SP03 | | | 0.0 213.10 | | | | | | 59.267 | | | K Factor = 27.68 |
| *STANDPIPE FEED | | | | | | | | | | | | |
| SP01 to SP02 | 45 27.917 | .0 | 0.0 0.0 | 6 6.065 | 1B 6I | 10.0 60.0 0.0 | 34.417 70.000 104.417 | 120 0 | 52.410 7.399 0.0 | | | Vel = 0 |
| SP02 to SP03 | 27.917 29.167 | .0 | 0.0 0.0 | 6 6.065 | 2I | 20.0 0.0 0.0 | 235.417 20.000 255.417 | 120 0 | 59.809 -0.541 0.0 | | | Vel = 0 |
| SP03 to SP04 | 29.167 28.083 | | 213.10 213.1 | 6 6.065 | 4I | 40.0 0.0 0.0 | 27.500 40.000 67.500 | 120 0.0020 | 59.267 0.469 0.137 | | | Vel = 2.37 |

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 6 [R/A=2]

Page 8
 Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|--------------------------|------------------|-----------|---------------|------------|-----------------------|---------------------------|------------------------------|----------------|---------------------------|-------|------------------------------------|-------|
| SP04 to SPC1 | 28.083 12.667 | | 0.0 213.1 | 6 6.065 | 2I | 20.0 0.0 | 79.330 20.000 | 120 0.0020 | 59.873 6.677 | | | |
| SPC1 to SPC2 | 12.667 12.667 | | 0.0 213.1 | 6 6.065 | 1T | 30.0 0.0 | 7.833 30.000 | 120 0.0020 | 66.750 0.0 | | Vel = 2.37 | |
| SPC2 to PO | 12.667 1.833 | | 0.0 213.1 | 8 7.981 | 1I 1B 1C | 13.0 12.0 45.0 | 14.750 70.000 84.750 | 120 0.0005 | 66.826 4.692 0.045 | | Vel = 1.37 | |
| PO | | | 0.0 213.10 | | | | | | 71.563 | | K Factor = 25.19 | |
| System Demand Pressure | | | | | | 71.563 | | | | | | |
| Safety Margin | | | | | | 105.185 | | | | | | |
| Continuation Pressure | | | | | | 176.748 | | | | | | |
| Pressure @ Pump Outlet | | | | | | 176.748 | | | | | | |
| Pressure From Pump Curve | | | | | | -124.845 | | | | | | |
| Pressure @ Pump Inlet | | | | | | 51.903 | | | | | | |
| PI to POC | 1.750 6.750 | | 0.0 213.1 | 8 7.981 | 1G 1I 1T | 4.0 13.0 35.0 | 14.000 52.000 66.000 | 120 0.0005 | 51.903 -2.166 0.035 | | Vel = 1.37 | |
| POC to BF1 | 6.750 13 | | 0.0 213.1 | 8 8.27 | 2E | 56.936 0.0 | 41.000 56.936 | 140 0.0003 | 49.772 -2.707 0.033 | | Vel = 1.27 | |
| BF1 to BF2 | 13 13 | | 0.0 213.1 | 8 7.981 | 1Zic | 0.0 0.0 | 4.000 0.0 | 120 0.0005 | 47.098 6.507 0.002 | | * Fixed loss = 6.507 Vel = 1.37 | |
| BF2 to SRC | 13 13 | | 0.0 213.1 | 8 8.27 | 2E 1G 1T | 56.936 6.326 55.354 | 46.000 118.616 164.616 | 140 0.0003 | 53.607 0.0 0.055 | | Vel = 1.27 | |
| SRC | | | 0.0 213.10 | | | | | | 53.662 | | K Factor = 29.09 | |

This page intentionally left blank.



**AUTOMATIC
SPRINKLER CO.**

21605 North Central Ave. 623.580.7800
Phoenix, Arizona 85024 Fax 623.434.3154

AZ-L16-234798 CA-C16-901529
AZ-C16-234797 NV-C41-69370
UT-S370-6690455-5501 NM-MS 12-354807



Fire Protection by Computer Design

Aero Automatic Sprinkler Co.
21605 N. Central Ave.
Phoenix, Arizona 85024
623-580-7800

Job Name : Cal Poly Center for Science LVL 6 [R/A=3]
Building : FP-6.06E
Location : San Luis Obispo, Ca.
System : 6-3
Contract : 10034
Data File : Cal Poly CFS LVL 6-3.WXF

HYDRAULIC CALCULATIONS
for

Project name: Cal Poly Center For Science
Location: San Luis Obispo, Ca.
Drawing no: FP-6.06E
Date: 9-25-2011

Design

Remote area number: 6-3
Remote area location: 6 th. Floor Laboratory
Occupancy classification: Ordinary Hazard Gr. 1
Density: 0.15 - Gpm/SqFt
Area of application: 920 - SqFt
Coverage per sprinkler: 130 - SqFt
Type of sprinklers calculated: Tyco; Mod. TY-FRB; 1/2"; 1/2";K=5.6; 155 Deg
No. of sprinklers calculated: 12
In-rack demand: N/A - GPM
Hose streams: 250 - GPM
Total water required (including hose streams): 523.39 - GPM @ 26.71 - Psi
Type of system: WET
Volume of dry or preaction system: N/A - Gal

Water supply information

Date: 8-19-2011
Location: N. Poly View Drive
Source: Fluid Resource Management

Name of contractor: Aero Automatic Sprinkler Co.
Address: 21605 N. Central Ave. Phoenix, Az. 85024
Phone number: 623-580-7847
Name of designer: Neal Larsen
Authority having jurisdiction: C.S.F.M.


Notes: (Include peaking information or gridded systems here.) Flow Test Information :
Hydrant # 63; Static = 60 psi; Res.= 55 psi {Elev.=351.0'}
Hydrant # 64; Flow = 914 gpm
FLOW TEST USED IN HYD. CALCS REDUCED BY 10 % [STATIC=54psi; RES.=49psi]
NOTE : REMOTE AREA REDUCED BY 39.25% [Q.R HEADS & C.H.=10'-6"] 912 SQ.FT. MIN.

Water Supply Curve (C)

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 6 [R/A=3]

Page 2
 Date 9-25-11

| | | |
|---|--|---|
| City Water Supply: C1 - Static Pressure : 54 C2 - Residual Pressure: 49 C2 - Residual Flow : 914 City Water Adjusted to Pump Inlet for Pf - Elev - Hose Flow A1 - Adjusted Static: 51.696 A2 - Adj Resid : 47.866 @ 790.2 A3 - Adj Resid : 37.967 @ 1382.9 | Pump Data: P1 - Pump Churn Pressure : 125.2 P2 - Pump Rated Pressure : 110.9 P2 - Pump Rated Flow : 790.2 P3 - Pump Pressure @ Max Flow : 67.9 P3 - Pump Max Flow : 1382.9 City Residual Flow @ 0 = 3307.91 City Residual Flow @ 20 = 2576.03 City Water @ 150% of Pump = 43.24 | Demand: D1 - Elevation : 33.565 D2 - System Flow : 273.395 D2 - System Pressure : 149.546 Hose (Adj City) : 150 Hose (Demand) : 100 D3 - System Demand : 373.395 Safety Margin : 25.499 |
|---|--|---|



Fittings Used Summary

Aero Automatic Sprinkler Co.
Cal Poly Center for Science LVL 6 [R/A=3]

Page 3
Date 9-25-11

Fitting Legend

| Abbrev. | Name | ½ | ¾ | 1 | 1¼ | 1½ | 2 | 2½ | 3 | 3½ | 4 | 5 | 6 | 8 | 10 | 12 | 14 | 16 | 18 | 20 | 24 |
|---------|-------------------------|--|---|------|----|-----|-----|----|----|----|----|-----|----|----|----|----|----|----|----|-----|-----|
| B | Generic Butterfly Valve | 0 | 0 | 2.25 | 2 | 2.5 | 6 | 7 | 10 | 0 | 12 | 9 | 10 | 12 | 19 | 21 | 0 | 0 | 0 | 0 | 0 |
| C | Generic Check Vlv | 4 | 5 | 5 | 7 | 9 | 11 | 14 | 16 | 19 | 22 | 27 | 32 | 45 | 55 | 65 | 76 | 87 | 98 | 109 | 130 |
| E | 90' Standard Elbow | 2 | 2 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 10 | 12 | 14 | 18 | 22 | 27 | 35 | 40 | 45 | 50 | 61 |
| G | Generic Gate Valve | 0 | 0 | 0 | 1 | 0 | 1 | 1 | 1 | 1 | 2 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 10 | 11 | 13 |
| I | 90' Ell Grvd-Vic #10 | 0 | 0 | 2 | 3 | 4 | 3.5 | 6 | 5 | 8 | 7 | 8.5 | 10 | 13 | 17 | 20 | 23 | 25 | 33 | 36 | 40 |
| T | 90' Flow Thru Tee | 3 | 4 | 5 | 6 | 8 | 10 | 12 | 15 | 17 | 20 | 25 | 30 | 35 | 50 | 60 | 71 | 81 | 91 | 101 | 121 |
| Zic | Wilkens 350ADA | Fitting generates a Fixed Loss Based on Flow | | | | | | | | | | | | | | | | | | | |

Units Summary

Diameter Units Inches
Length Units Feet
Flow Units US Gallons per Minute
Pressure Units Pounds per Square Inch

Pressure / Flow Summary - STANDARD

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 6 [R/A=3]

Page 4
 Date 9-25-11

| Node No. | Elevation | K-Fact | Pt Actual | Pn | Flow Actual | Density | Area | Press Req. |
|----------|-----------|--------|-----------|----|-------------|---------|------|------------|
| S631 | 90.5 | 5.6 | 12.12 | na | 19.5 | 0.15 | 130 | 7.0 |
| S632 | 90.5 | 5.6 | 13.07 | na | 20.25 | 0.15 | 130 | 7.0 |
| S633 | 90.5 | 5.6 | 16.6 | na | 22.81 | 0.15 | 130 | 7.0 |
| S634 | 90.5 | 5.6 | 24.77 | na | 27.87 | 0.15 | 130 | 7.0 |
| S635 | 90.5 | 5.6 | 12.23 | na | 19.58 | 0.15 | 130 | 7.0 |
| S636 | 90.5 | 5.6 | 13.18 | na | 20.33 | 0.15 | 130 | 7.0 |
| S637 | 90.5 | 5.6 | 16.74 | na | 22.91 | 0.15 | 130 | 7.0 |
| S638 | 90.5 | 5.6 | 24.97 | na | 27.99 | 0.15 | 130 | 7.0 |
| S639 | 90.5 | 5.6 | 12.6 | na | 19.88 | 0.15 | 130 | 7.0 |
| S640 | 90.5 | 5.6 | 13.58 | na | 20.64 | 0.15 | 130 | 7.0 |
| S641 | 90.5 | 5.6 | 17.24 | na | 23.25 | 0.15 | 130 | 7.0 |
| S642 | 90.5 | 5.6 | 25.7 | na | 28.39 | 0.15 | 130 | 7.0 |
| L631 | 91.0 | | 12.59 | na | | | | |
| L632 | 91.0 | | 13.58 | na | | | | |
| L633 | 91.0 | | 17.29 | na | | | | |
| L634 | 91.0 | | 25.88 | na | | | | |
| L635 | 91.0 | | 12.7 | na | | | | |
| L636 | 91.0 | | 13.7 | na | | | | |
| L637 | 91.0 | | 17.44 | na | | | | |
| L638 | 91.0 | | 26.09 | na | | | | |
| L639 | 91.0 | | 13.09 | na | | | | |
| L640 | 91.0 | | 14.12 | na | | | | |
| L641 | 91.0 | | 17.96 | na | | | | |
| L642 | 91.0 | | 26.86 | na | | | | |
| MN01 | 92.0 | | 35.21 | na | | | | |
| MN02 | 92.0 | | 35.21 | na | | | | |
| MN03 | 92.0 | | 35.21 | na | | | | |
| MN04 | 92.0 | | 35.21 | na | | | | |
| MN05 | 92.0 | | 35.21 | na | | | | |
| MN06 | 92.0 | | 35.21 | na | | | | |
| MN07 | 92.0 | | 35.21 | na | | | | |
| MN08 | 92.0 | | 35.21 | na | | | | |
| MN09 | 92.0 | | 35.47 | na | | | | |
| MN10 | 92.0 | | 35.5 | na | | | | |
| MN11 | 92.0 | | 36.54 | na | | | | |
| MN12 | 93.333 | | 69.78 | na | | | | |
| MN13 | 93.333 | | 80.44 | na | | | | |
| MN14 | 91.083 | | 92.4 | na | | | | |
| TOR6 | 91.083 | | 97.24 | na | | | | |
| BOR6 | 84.0 | | 108.49 | na | | | | |
| HV1 | 99.75 | | 104.1 | na | | | | |
| HV2 | 99.75 | | 104.1 | na | | | | |
| SPRF | 99.75 | | 105.85 | na | | | | |
| SP16 | 85.0 | | 112.24 | na | | | | |
| SP15 | 69.0 | | 119.17 | na | | | | |
| SP14 | 53.0 | | 126.1 | na | | | | |
| SP13 | 37.0 | | 133.02 | na | | | | |
| HV3 | 101.0 | | 102.61 | na | | | | |
| SPR3 | 101.0 | | 104.36 | na | | | | |
| SP36 | 85.0 | | 111.29 | na | 50.0 | | | |
| SP35 | 69.0 | | 118.29 | na | 50.0 | | | |
| SP34 | 53.0 | | 125.31 | na | | | | |
| SP33 | 37.0 | | 132.33 | na | | | | |
| SP32 | 21.0 | | 139.48 | na | | | | |
| SP05 | 29.167 | | 135.94 | na | | | | |
| SP01 | 45.0 | | 129.56 | na | | | | |
| SP02 | 27.917 | | 136.96 | na | | | | |
| SP03 | 29.167 | | 136.42 | na | | | | |
| SP04 | 28.083 | | 137.27 | na | | | | |
| SPC1 | 12.667 | | 144.51 | na | | | | |
| SPC2 | 12.667 | | 144.73 | na | | | | |
| PO | 1.833 | | 149.55 | na | | | | |

Flow Summary - Standard

Aero Automatic Sprinkler Co.
Cal Poly Center for Science LVL 6 [R/A=3]

Page 5
Date 9-25-11

| Node No. | Elevation | K-Fact | Pt Actual | Pn | Flow Actual | Density | Area | Press Req. |
|----------|-----------|--------|-----------|----|-------------|---------|------|------------|
| PI | 1.75 | | 50.78 | na | | | | |
| POC | 6.75 | | 48.72 | na | | | | |
| BF1 | 13.0 | | 46.1 | na | | | | |
| BF2 | 13.0 | | 52.06 | na | | | | |
| SRC | 13.0 | | 52.22 | na | 150.0 | | | |

The maximum velocity is 23.67 and it occurs in the pipe between nodes L641 and L642

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 6 [R/A=3]

Page 6
 Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|----------------------------|----------------|-----------|----------------|------------|-----------------------|------------|-------------------------|----------------|------------------|------------|-------|-------|
| *FLOWING SPRINKLER R/A # 3 | | | | | | | | | | | | |
| S631 to L631 | 90.5 91 | 5.60 | 19.50 19.5 | 1 1.049 | 1T | 5.0 0.0 | 0.500 5.000 | 120 | 12.125 -0.217 | | | |
| | | | 0.0 | | | | | | 0.684 | Vel = | 7.24 | |
| L631 | | | 19.50 | | | | | | 12.592 | K Factor = | 5.50 | |
| S632 to L632 | 90.5 91 | 5.60 | 20.24 20.24 | 1 1.049 | 1T | 5.0 0.0 | 0.500 5.000 | 120 | 13.070 -0.217 | | | |
| | | | 0.0 | | | | | | 0.732 | Vel = | 7.51 | |
| L632 | | | 20.24 | | | | | | 13.585 | K Factor = | 5.49 | |
| S633 to L633 | 90.5 91 | 5.60 | 22.81 22.81 | 1 1.049 | 1T | 5.0 0.0 | 0.500 5.000 | 120 | 16.598 -0.217 | | | |
| | | | 0.0 | | | | | | 0.913 | Vel = | 8.47 | |
| L633 | | | 22.81 | | | | | | 17.294 | K Factor = | 5.49 | |
| S634 to L634 | 90.5 91 | 5.60 | 27.87 27.87 | 1 1.049 | 1T | 5.0 0.0 | 0.500 5.000 | 120 | 24.772 -0.217 | | | |
| | | | 0.0 | | | | | | 1.323 | Vel = | 10.35 | |
| L634 | | | 27.87 | | | | | | 25.878 | K Factor = | 5.48 | |
| S635 to L635 | 90.5 91 | 5.60 | 19.58 19.58 | 1 1.049 | 1T | 5.0 0.0 | 0.500 5.000 | 120 | 12.228 -0.217 | | | |
| | | | 0.0 | | | | | | 0.689 | Vel = | 7.27 | |
| L635 | | | 19.58 | | | | | | 12.700 | K Factor = | 5.49 | |
| S636 to L636 | 90.5 91 | 5.60 | 20.33 20.33 | 1 1.049 | 1T | 5.0 0.0 | 0.500 5.000 | 120 | 13.180 -0.217 | | | |
| | | | 0.0 | | | | | | 0.738 | Vel = | 7.55 | |
| L636 | | | 20.33 | | | | | | 13.701 | K Factor = | 5.49 | |
| S637 to L637 | 90.5 91 | 5.60 | 22.91 22.91 | 1 1.049 | 1T | 5.0 0.0 | 0.500 5.000 | 120 | 16.736 -0.217 | | | |
| | | | 0.0 | | | | | | 0.920 | Vel = | 8.50 | |
| L637 | | | 22.91 | | | | | | 17.439 | K Factor = | 5.49 | |
| S638 to L638 | 90.5 91 | 5.60 | 27.99 27.99 | 1 1.049 | 1T | 5.0 0.0 | 0.500 5.000 | 120 | 24.974 -0.217 | | | |
| | | | 0.0 | | | | | | 1.333 | Vel = | 10.39 | |
| L638 | | | 27.99 | | | | | | 26.090 | K Factor = | 5.48 | |
| S639 to L639 | 90.5 91 | 5.60 | 19.88 19.88 | 1 1.049 | 1T | 5.0 0.0 | 0.500 5.000 | 120 | 12.601 -0.217 | | | |
| | | | 0.0 | | | | | | 0.708 | Vel = | 7.38 | |
| L639 | | | 19.88 | | | | | | 13.092 | K Factor = | 5.49 | |
| S640 to L640 | 90.5 91 | 5.60 | 20.64 20.64 | 1 1.049 | 1T | 5.0 0.0 | 0.500 5.000 | 120 | 13.580 -0.217 | | | |
| | | | 0.0 | | | | | | 0.758 | Vel = | 7.66 | |

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 6 [R/A=3]

Page 7
 Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|-----------------------|----------------|-----------|--------------|------------|-----------------------|-------------------|--------------------------|----------------|---------------------------|-------|------------------|-------|
| | | | 0.0 20.64 | | | | | | 14.121 | | K Factor = 5.49 | |
| S641 to L641 | 90.5 91 | 5.60 | 23.25 | 1 | 1T | 5.0 0.0 0.0 | 0.500 5.000 5.500 | 120 | 17.235 -0.217 0.946 | | Vel = 8.63 | |
| | | | 0.0 23.25 | | | | | | 17.964 | | K Factor = 5.49 | |
| S642 to L642 | 90.500 91 | 5.60 | 28.39 | 1 | 1T | 5.0 0.0 0.0 | 0.500 5.000 5.500 | 120 | 25.705 -0.217 1.369 | | Vel = 10.54 | |
| | | | 0.0 28.39 | | | | | | 26.857 | | K Factor = 5.48 | |
| *BRANCH LINES R/A # 3 | | | | | | | | | | | | |
| L631 to L632 | 91 91 | | 19.50 | 1 | | 0.0 0.0 0.0 | 8.000 0.0 8.000 | 120 | 12.592 0.0 0.993 | | Vel = 7.24 | |
| L632 to L633 | 91 91 | | 20.24 | 1 | | 0.0 0.0 0.0 | 8.000 0.0 8.000 | 120 | 13.585 0.0 3.709 | | Vel = 14.75 | |
| L633 to L634 | 91 91 | | 22.82 | 1 | | 0.0 0.0 0.0 | 8.000 0.0 8.000 | 120 | 17.294 0.0 8.584 | | Vel = 23.22 | |
| L634 to MN08 | 91 92 | | 27.87 | 1.25 | 1E 1T | 3.0 6.0 0.0 | 8.500 9.000 17.500 | 120 | 25.878 -0.433 9.765 | | Vel = 19.40 | |
| | | | 0.0 90.43 | | | | | | 35.210 | | K Factor = 15.24 | |
| L635 to L636 | 91 91 | | 19.58 | 1 | | 0.0 0.0 0.0 | 8.000 0.0 8.000 | 120 | 12.700 0.0 1.001 | | Vel = 7.27 | |
| L636 to L637 | 91 91 | | 20.33 | 1 | | 0.0 0.0 0.0 | 8.000 0.0 8.000 | 120 | 13.701 0.0 3.738 | | Vel = 14.82 | |
| L637 to L638 | 91 91 | | 22.91 | 1 | | 0.0 0.0 0.0 | 8.000 0.0 8.000 | 120 | 17.439 0.0 8.651 | | Vel = 23.32 | |
| L638 to MN10 | 91 92 | | 27.99 | 1.25 | 1E 1T | 3.0 6.0 0.0 | 8.500 9.000 17.500 | 120 | 26.090 -0.433 9.840 | | Vel = 19.48 | |
| | | | 0.0 90.81 | | | | | | 35.497 | | K Factor = 15.24 | |
| L639 to L640 | 91 91 | | 19.88 | 1 | | 0.0 0.0 0.0 | 8.000 0.0 8.000 | 120 | 13.092 0.0 1.029 | | Vel = 7.38 | |
| L640 to L641 | 91 91 | | 20.64 | 1 | | 0.0 0.0 0.0 | 8.000 0.0 8.000 | 120 | 14.121 0.0 3.843 | | Vel = 15.04 | |

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 6 [R/A=3]

Page 8
 Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|----------------------|------------------|-----------|-----------------|--------------|-----------------------|------------------|-------------------------|----------------|------------------|-------------|------------------|-------------|
| L641 to L642 | 91 91 | | 23.24 63.76 | 1 1.049 | | 0.0 0.0 | 8.000 0.0 | 120 0 | 17.964 0.0 | | | |
| | | | | | | 0.0 | 8.000 | 1.1116 | 8.893 | Vel = 23.67 | | |
| L642 to MN11 | 91 92 | | 28.40 92.16 | 1.25 1.38 | 1E 1T | 3.0 6.0 | 8.500 9.000 | 120 0.5778 | 26.857 -0.433 | | | Vel = 19.77 |
| | | | 0.0 92.16 | | | | | | 36.536 | | K Factor = 15.25 | |
| *FEED MAIN | | | | | | | | | | | | |
| MN01 to MN02 | 92 92 | .0 | 0.0 0.0 | 2.5 2.635 | | 0.0 0.0 | 3.833 0.0 | 120 0 | 35.210 0.0 | | | Vel = 0 |
| | | | | | | 0.0 | 3.833 | 0 | 0.0 | Vel = 0 | | |
| MN02 to MN03 | 92 92 | .0 | 0.0 0.0 | 2.5 2.635 | | 0.0 0.0 | 8.167 8.167 | 120 0 | 35.210 0.0 | | | Vel = 0 |
| | | | | | | 0.0 | 8.167 | 0 | 0.0 | Vel = 0 | | |
| MN03 to MN04 | 92 92 | .0 | 0.0 0.0 | 2.5 2.635 | | 0.0 0.0 | 5.833 5.833 | 120 0 | 35.210 0.0 | | | Vel = 0 |
| | | | | | | 0.0 | 5.833 | 0 | 0.0 | Vel = 0 | | |
| MN04 to MN05 | 92 92 | .0 | 0.0 0.0 | 2.5 2.635 | | 0.0 0.0 | 6.167 6.167 | 120 0 | 35.210 0.0 | | | Vel = 0 |
| | | | | | | 0.0 | 6.167 | 0 | 0.0 | Vel = 0 | | |
| MN05 to MN06 | 92 92 | .0 | 0.0 0.0 | 2.5 2.635 | | 0.0 0.0 | 4.250 4.250 | 120 0 | 35.210 0.0 | | | Vel = 0 |
| | | | | | | 0.0 | 4.250 | 0 | 0.0 | Vel = 0 | | |
| MN06 to MN07 | 92 92 | .0 | 0.0 0.0 | 2.5 2.635 | | 0.0 0.0 | 7.750 7.750 | 120 0 | 35.210 0.0 | | | Vel = 0 |
| | | | | | | 0.0 | 7.750 | 0 | 0.0 | Vel = 0 | | |
| MN07 to MN08 | 92 92 | .0 | 0.0 0.0 | 2.5 2.635 | | 0.0 0.0 | 1.250 1.250 | 120 0 | 35.210 0.0 | | | Vel = 0 |
| | | | | | | 0.0 | 1.250 | 0 | 0.0 | Vel = 0 | | |
| MN08 to MN09 | 92 92 | | 90.43 90.43 | 2.5 2.635 | | 0.0 0.0 | 10.750 10.750 | 120 0.0239 | 35.210 0.257 | | | Vel = 5.32 |
| | | | | | | 0.0 | 10.750 | 0.0239 | 0.257 | Vel = 5.32 | | |
| MN09 to MN10 | 92 92 | | 0.0 90.43 | 2.5 2.635 | | 0.0 0.0 | 1.250 1.250 | 120 0.0240 | 35.467 0.030 | | | Vel = 5.32 |
| | | | | | | 0.0 | 1.250 | 0.0240 | 0.030 | Vel = 5.32 | | |
| MN10 to MN11 | 92 92 | | 90.81 181.24 | 2.5 2.635 | | 0.0 0.0 | 12.000 12.000 | 120 0.0866 | 35.497 1.039 | | | Vel = 10.66 |
| | | | | | | 0.0 | 12.000 | 0.0866 | 1.039 | Vel = 10.66 | | |
| MN11 to MN12 | 92 93.333 | | 92.16 273.4 | 2.5 2.635 | 2I 1T | 16.474 16.474 | 149.750 32.948 | 120 0.1851 | 36.536 -0.577 | | | Vel = 16.09 |
| | | | | | | 0.0 | 182.698 | 0.1851 | 33.825 | Vel = 16.09 | | |
| MN12 to MN13 | 93.333 93.333 | | 0.0 273.4 | 2.5 2.635 | 1I 1T | 8.237 16.474 | 32.833 24.711 | 120 0.1851 | 69.784 0.0 | | | Vel = 16.09 |
| | | | | | | 0.0 | 57.544 | 0.1851 | 10.654 | Vel = 16.09 | | |
| MN13 to MN14 | 93.333 91.083 | | 0.0 273.4 | 2.5 2.635 | 2I 1T | 16.474 16.474 | 26.417 32.948 | 120 0.1852 | 80.438 0.974 | | | Vel = 16.09 |
| | | | | | | 0.0 | 59.365 | 0.1852 | 10.992 | Vel = 16.09 | | |

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 6 [R/A=3]

Page 9
 Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|----------------------|------------------|-----------|---------------|--------------|-----------------------|------------------------|---------------------------|----------------|----------------------------|-------------|------------------|---------------------|
| MN14 to TOR6 | 91.083 91.083 | | 0.0 273.4 | 2.5 2.635 | 2I | 16.474 0.0 | 9.667 16.474 | 120 | 92.404 0.0 | | | |
| | | | | | | 0.0 | 26.141 | 0.1851 | 4.840 | Vel = 16.09 | | |
| TOR6 to BOR6 | 91.083 84 | | 0.0 273.4 | 2.5 2.635 | 1C 1B 1I | 19.22 9.61 8.237 | 7.083 37.067 44.150 | 120 | 97.244 3.068 8.174 | | | Vel = 16.09 |
| BOR6 to SP36 | 84 85 | | 0.0 273.4 | 2.5 2.635 | 1T | 16.474 0.0 | 1.000 16.474 | 120 | 108.486 -0.433 3.235 | | | Vel = 16.09 |
| SP36 | | | 0.0 273.40 | | | | | | 111.288 | | K Factor = 25.92 | |
| *S/P # 1 | | | | | | | | | | | | |
| HV1 to SPRF | 99.750 99.750 | .0 | 0.0 | 2.5 | 1T | 12.0 0.0 | 0.250 12.000 | 120 | 104.098 1.750 | | | * Fixed loss = 1.75 |
| | | | 0.0 | 2.469 | | 0.0 | 12.250 | 0 | 0.0 | Vel = 0 | | |
| SPRF | | | 0.0 | | | | | | 105.848 | | K Factor = 0 | |
| HV2 to SPRF | 99.750 99.750 | .0 | 0.0 | 2.5 | 1T | 12.0 0.0 | 0.250 12.000 | 120 | 104.098 1.750 | | | * Fixed loss = 1.75 |
| | | | 0.0 | 2.469 | | 0.0 | 12.250 | 0 | 0.0 | Vel = 0 | | |
| SPRF to SP16 | 99.750 85 | .0 | 0.0 | 6 | 4I | 40.0 0.0 | 30.000 40.000 | 120 | 105.848 6.388 | | | Vel = 0 |
| | | | 0.0 | 6.065 | | 0.0 | 70.000 | 0 | 0.0 | | | |
| SP16 to SP15 | 85 69 | .0 | 0.0 | 6 | | 0.0 0.0 | 16.000 0.0 | 120 | 112.236 6.930 | | | Vel = 0 |
| | | | 0.0 | 6.065 | | 0.0 | 16.000 | 0 | 0.0 | | | |
| SP15 to SP14 | 69 53 | .0 | 0.0 | 6 | | 0.0 0.0 | 16.000 0.0 | 120 | 119.166 6.930 | | | Vel = 0 |
| | | | 0.0 | 6.065 | | 0.0 | 16.000 | 0 | 0.0 | | | |
| SP14 to SP01 | 53 45 | .0 | 0.0 | 6 | 1T | 30.0 0.0 | 8.500 30.000 | 120 | 126.096 3.465 | | | Vel = 0 |
| | | | 0.0 | 6.065 | | 0.0 | 38.500 | 0 | 0.0 | | | |
| SP01 | | | 0.0 | | | | | | 129.561 | | K Factor = 0 | |
| SP13 to SP01 | 37 45 | .0 | 0.0 | 6 | 1T | 30.0 0.0 | 7.500 30.000 | 120 | 133.025 -3.465 | | | Vel = 0 |
| | | | 0.0 | 6.065 | | 0.0 | 37.500 | 0 | 0.0 | | | |
| SP01 | | | 0.0 | | | | | | 129.560 | | K Factor = 0 | |
| *S/P # 3 | | | | | | | | | | | | |
| HV3 to SPR3 | 101 101 | .0 | 0.0 | 2.5 | 2E 1T | 12.0 12.0 | 1.750 24.000 | 120 | 102.608 1.750 | | | * Fixed loss = 1.75 |
| | | | 0.0 | 2.469 | | 0.0 | 25.750 | 0 | 0.0 | Vel = 0 | | |
| SPR3 to SP36 | 101 85 | .0 | 0.0 | 6 | | 0.0 0.0 | 16.000 0.0 | 120 | 104.358 6.930 | | | Vel = 0 |
| | | | 0.0 | 6.065 | | 0.0 | 16.000 | 0 | 0.0 | | | |
| SP36 to SP35 | 85 69 | H50 | 323.40 | 6 | | 0.0 0.0 | 16.000 0.0 | 120 | 111.288 6.930 | | | Vel = 3.59 |
| | | | 323.4 | 6.065 | | 0.0 | 16.000 | 0.0043 | 0.069 | | | |

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 6 [R/A=3]

Page 10
 Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|--------------------------|------------------|-----------|-----------------|------------|-----------------------|----------------------|------------------------------|----------------|---------------------------|-------|-------|------------------|
| SP35 to SP34 | 69 53 | H50 | 50.00 373.4 | 6 6.065 | | 0.0 0.0 | 16.000 0.0 | 120 0.0057 | 118.287 6.930 0.091 | | | Vel = 4.15 |
| SP34 to SP33 | 53 37 | | 0.0 373.4 | 6 6.065 | | 0.0 0.0 | 16.000 0.0 | 120 0.0056 | 125.308 6.930 0.090 | | | Vel = 4.15 |
| SP33 to SP05 | 37 29.167 | | 0.0 373.4 | 6 6.065 | 1T | 30.0 0.0 | 8.417 30.000 | 120 0.0057 | 132.328 3.392 0.219 | | | Vel = 4.15 |
| SP05 | | | 0.0 373.40 | | | | | | 135.939 | | | K Factor = 32.03 |
| SP32 to SP05 | 21 29.167 | .0 | 0.0 0.0 | 6 6.065 | 1T | 30.0 0.0 | 7.583 30.000 37.583 | 120 0 | 139.476 -3.537 0.0 | | | Vel = 0 |
| SP05 to SP03 | 29.167 29.167 | | 373.40 373.4 | 6 6.065 | 1I 1B 1T | 10.0 10.0 30.0 | 34.167 50.000 84.167 | 120 0.0057 | 135.939 0.0 0.479 | | | Vel = 4.15 |
| SP03 | | | 0.0 373.40 | | | | | | 136.418 | | | K Factor = 31.97 |
| *STANDPIPE FEED | | | | | | | | | | | | |
| SP01 to SP02 | 45 27.917 | .0 | 0.0 0.0 | 6 6.065 | 1B 6I | 10.0 60.0 | 34.417 70.000 104.417 | 120 0 | 129.560 7.399 0.0 | | | Vel = 0 |
| SP02 to SP03 | 27.917 29.167 | .0 | 0.0 0.0 | 6 6.065 | 2I | 20.0 0.0 | 235.417 20.000 255.417 | 120 0 | 136.959 -0.541 0.0 | | | Vel = 0 |
| SP03 to SP04 | 29.167 28.083 | | 373.40 373.4 | 6 6.065 | 4I | 40.0 0.0 | 27.500 40.000 67.500 | 120 0.0057 | 136.418 0.469 0.384 | | | Vel = 4.15 |
| SP04 to SPC1 | 28.083 12.667 | | 0.0 373.4 | 6 6.065 | 2I | 20.0 0.0 | 79.330 20.000 99.330 | 120 0.0057 | 137.271 6.677 0.564 | | | Vel = 4.15 |
| SPC1 to SPC2 | 12.667 12.667 | | 0.0 373.4 | 6 6.065 | 1T | 30.0 0.0 | 7.833 30.000 37.833 | 120 0.0057 | 144.512 0.0 0.215 | | | Vel = 4.15 |
| SPC2 to PO | 12.667 1.833 | | 0.0 373.4 | 8 7.981 | 1I 1B 1C | 13.0 12.0 45.0 | 14.750 70.000 84.750 | 120 0.0015 | 144.727 4.692 0.127 | | | Vel = 2.39 |
| PO | | | 0.0 373.40 | | | | | | 149.546 | | | K Factor = 30.53 |
| System Demand Pressure | | | | | | 149.546 | | | | | | |
| Safety Margin | | | | | | 25.499 | | | | | | |
| Continuation Pressure | | | | | | 175.045 | | | | | | |
| Pressure @ Pump Outlet | | | | | | 175.045 | | | | | | |
| Pressure From Pump Curve | | | | | | -124.263 | | | | | | |
| Pressure @ Pump Inlet | | | | | | 50.782 | | | | | | |
| PI to POC | 1.750 6.750 | | 0.0 373.4 | 8 7.981 | 1G 1I 1T | 4.0 13.0 35.0 | 14.000 52.000 66.000 | 120 0.0015 | 50.782 -2.166 0.099 | | | Vel = 2.39 |

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 6 [R/A=3]

Page 11
 Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|----------------------|----------------|-----------|------------------|------------|-----------------------|---------------------------|-----------------------------------|----------------|---------------------------|-------|------------------------------------|-------|
| POC to BF1 | 6.750 13 | | 0.0 373.4 | 8 8.27 | 2E | 56.936 | 41.000 0.0 56.936 97.936 | 140 0.0009 | 48.715 -2.707 0.093 | | Vel = 2.23 | |
| BF1 to BF2 | 13 13 | | 0.0 373.4 | 8 7.981 | 1Zic | 0.0 | 4.000 0.0 0.0 4.000 | 120 0.0015 | 46.101 5.955 0.006 | | * Fixed loss = 5.955 Vel = 2.39 | |
| BF2 to SRC | 13 13 | | 0.0 373.4 | 8 8.27 | 2E 1G 1T | 56.936 6.326 55.354 | 46.000 118.616 164.616 | 140 0.0009 | 52.062 0.0 0.155 | | Vel = 2.23 | |
| SRC | | | 150.00 523.40 | | | | | | 52.217 | | Qa = 150.00 K Factor = 72.43 | |



**AUTOMATIC
SPRINKLER CO.**

21605 North Central Ave. 623.580.7800
Phoenix, Arizona 85024 Fax 623.434.3154

AZ-L16-234798 CA-C16-901529
AZ-C16-234797 NV-C41-69370
UT-S370-6690455-5501 NM-MS 12-354807



Fire Protection by Computer Design

Aero Automatic Sprinkler Co.
21605 N. Central Ave.
Phoenix, Arizona 85024
623-580-7800

Job Name : Cal Poly Center for Science LVL 6 [R/A=4]
Building : FP-6.06E
Location : San Luis Obispo, Ca.
System : 6-4
Contract : 10034
Data File : Cal Poly CFS LVL 6-4.WXF

HYDRAULIC CALCULATIONS
for

Project name: Cal Poly Center For Science
Location: San Luis Obispo, Ca.
Drawing no: FP-6.06E
Date: 9-25-2011

Design

Remote area number: 6-4
Remote area location: 6 th. Floor Office/Lobby
Occupancy classification: Light Hazard
Density: 0.10 - Gpm/SqFt
Area of application: 1500 - SqFt
Coverage per sprinkler: 210 - SqFt
Type of sprinklers calculated: Tyco; Mod. TY-FRB; 1/2"; 1/2";K=5.6; 155 Deg
No. of sprinklers calculated: 14
In-rack demand: N/A - GPM
Hose streams: 100 - GPM
Total water required (including hose streams): 447.28 - GPM @ 39.09 - Psi
Type of system: WET
Volume of dry or preaction system: N/A - Gal

Water supply information

Date: 8-19-2011
Location: N. Poly View Drive
Source: Fluid Resource Management

Name of contractor: Aero Automatic Sprinkler Co.
Address: 21605 N. Central Ave. Phoenix, Az. 85024
Phone number: 623-580-7847
Name of designer: Neal Larsen
Authority having jurisdiction: C.S.F.M.


Notes: (Include peaking information or gridded systems here.) Flow Test Information :
Hydrant # 63; Static = 60 psi; Res.= 55 psi {Elev.=351.0'}
Hydrant # 64; Flow = 914 gpm
FLOW TEST USED IN HYD. CALCS REDUCED BY 10 % [STATIC=54psi; RES.=49psi]

Water Supply Curve (C)

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 6 [R/A=4]

Page 2
 Date 9-25-11

| City Water Supply: | | Pump Data: | | Demand: | |
|--|-------------------|-------------------------------|-----------|----------------------|-----------|
| C1 - Static Pressure | : 54 | P1 - Pump Churn Pressure | : 125.2 | D1 - Elevation | : 33.565 |
| C2 - Residual Pressure: | 49 | P2 - Pump Rated Pressure | : 110.9 | D2 - System Flow | : 347.282 |
| C2 - Residual Flow | : 914 | P2 - Pump Rated Flow | : 790.2 | D2 - System Pressure | : 160.618 |
| City Water Adjusted to Pump Inlet for Pf - Elev - Hose Flow | | P3 - Pump Pressure @ Max Flow | : 67.9 | Hose (Adj City) | : _____ |
| A1 - Adjusted Static: | 51.872 | P3 - Pump Max Flow | : 1382.9 | Hose (Demand) | : 100 |
| A2 - Adj Resid | : 49.314 @ 790.2 | City Residual Flow @ 0 | = 3307.91 | D3 - System Demand | : 447.282 |
| A3 - Adj Resid | : 40.224 @ 1382.9 | City Residual Flow @ 20 | = 2576.03 | Safety Margin | : 13.576 |
| | | City Water @ 150% of Pump | = 43.24 | | |



Fittings Used Summary

Aero Automatic Sprinkler Co.
Cal Poly Center for Science LVL 6 [R/A=4]

Page 3
Date 9-25-11

Fitting Legend

| Abbrev. | Name | ½ | ¾ | 1 | 1¼ | 1½ | 2 | 2½ | 3 | 3½ | 4 | 5 | 6 | 8 | 10 | 12 | 14 | 16 | 18 | 20 | 24 |
|---------|-------------------------|--|---|------|----|-----|-----|----|----|----|----|-----|----|----|----|----|----|----|----|-----|-----|
| B | Generic Butterfly Valve | 0 | 0 | 2.25 | 2 | 2.5 | 6 | 7 | 10 | 0 | 12 | 9 | 10 | 12 | 19 | 21 | 0 | 0 | 0 | 0 | 0 |
| C | Generic Check Vlv | 4 | 5 | 5 | 7 | 9 | 11 | 14 | 16 | 19 | 22 | 27 | 32 | 45 | 55 | 65 | 76 | 87 | 98 | 109 | 130 |
| E | 90' Standard Elbow | 2 | 2 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 10 | 12 | 14 | 18 | 22 | 27 | 35 | 40 | 45 | 50 | 61 |
| G | Generic Gate Valve | 0 | 0 | 0 | 1 | 0 | 1 | 1 | 1 | 1 | 2 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 10 | 11 | 13 |
| I | 90' Ell Grvd-Vic #10 | 0 | 0 | 2 | 3 | 4 | 3.5 | 6 | 5 | 8 | 7 | 8.5 | 10 | 13 | 17 | 20 | 23 | 25 | 33 | 36 | 40 |
| T | 90' Flow Thru Tee | 3 | 4 | 5 | 6 | 8 | 10 | 12 | 15 | 17 | 20 | 25 | 30 | 35 | 50 | 60 | 71 | 81 | 91 | 101 | 121 |
| Zic | Wilkens 350ADA | Fitting generates a Fixed Loss Based on Flow | | | | | | | | | | | | | | | | | | | |

Units Summary

Diameter Units Inches
Length Units Feet
Flow Units US Gallons per Minute
Pressure Units Pounds per Square Inch

Pressure / Flow Summary - STANDARD

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 6 [R/A=4]

Page 4
 Date 9-25-11

| Node No. | Elevation | K-Fact | Pt Actual | Pn | Flow Actual | Density | Area | Press Req. |
|----------|-----------|--------|-----------|----|-------------|---------|------|------------|
| S651 | 90.5 | 5.6 | 7.06 | na | 14.88 | 0.1 | 112 | 7.0 |
| S652 | 90.5 | 5.6 | 7.0 | na | 14.82 | 0.1 | 143 | 7.0 |
| S653 | 90.5 | 5.6 | 9.47 | na | 17.23 | 0.1 | 112 | 7.0 |
| S654 | 90.5 | 5.6 | 11.3 | na | 18.82 | 0.1 | 154 | 7.0 |
| S655 | 90.5 | 5.6 | 13.46 | na | 20.55 | 0.1 | 112 | 7.0 |
| S656 | 90.5 | 5.6 | 14.84 | na | 21.57 | 0.1 | 180 | 7.0 |
| S657 | 90.5 | 5.6 | 18.84 | na | 24.3 | 0.1 | 112 | 7.0 |
| S658 | 90.5 | 5.6 | 20.38 | na | 25.28 | 0.1 | 150 | 7.0 |
| S659 | 90.5 | 5.6 | 33.1 | na | 32.22 | 0.1 | 112 | 7.0 |
| S660 | 90.5 | 5.6 | 27.64 | na | 29.44 | 0.1 | 168 | 7.0 |
| S661 | 90.5 | 5.6 | 28.46 | na | 29.87 | 0.1 | 112 | 7.0 |
| S662 | 90.5 | 5.6 | 34.26 | na | 32.78 | 0.1 | 210 | 7.0 |
| S663 | 90.5 | 5.6 | 36.85 | na | 33.99 | 0.1 | 210 | 7.0 |
| S664 | 90.5 | 5.6 | 31.71 | na | 31.53 | 0.1 | 168 | 7.0 |
| L651 | 92.417 | | 6.93 | na | | | | |
| L653 | 92.417 | | 9.84 | na | | | | |
| L654 | 92.417 | | 11.88 | na | | | | |
| L655 | 92.417 | | 14.28 | na | | | | |
| L656 | 92.417 | | 16.2 | na | | | | |
| L657 | 92.417 | | 20.26 | na | | | | |
| L658 | 92.417 | | 21.99 | na | | | | |
| L660 | 92.417 | | 30.93 | na | | | | |
| MN01 | 92.0 | | 59.45 | na | | | | |
| MN02 | 92.0 | | 59.45 | na | | | | |
| MN03 | 92.0 | | 59.45 | na | | | | |
| MN04 | 92.0 | | 59.45 | na | | | | |
| MN05 | 92.0 | | 59.45 | na | | | | |
| MN06 | 92.0 | | 59.45 | na | | | | |
| MN07 | 92.0 | | 59.45 | na | | | | |
| MN08 | 92.0 | | 59.45 | na | | | | |
| MN09 | 92.0 | | 59.45 | na | | | | |
| MN10 | 92.0 | | 59.45 | na | | | | |
| MN11 | 92.0 | | 59.45 | na | | | | |
| MN40 | 92.417 | | 35.2 | na | | | | |
| MN41 | 92.417 | | 35.21 | na | | | | |
| MN42 | 92.417 | | 35.7 | na | | | | |
| MN43 | 92.417 | | 38.45 | na | | | | |
| MN44 | 92.417 | | 43.22 | na | | | | |
| MN45 | 92.417 | | 48.23 | na | | | | |
| MN12 | 93.333 | | 58.87 | na | | | | |
| MN13 | 93.333 | | 75.45 | na | | | | |
| MN14 | 91.083 | | 93.54 | na | | | | |
| TOR6 | 91.083 | | 101.07 | na | | | | |
| BOR6 | 84.0 | | 116.86 | na | | | | |
| HV1 | 99.75 | | 114.66 | na | | | | |
| HV2 | 99.75 | | 114.66 | na | | | | |
| SPRF | 99.75 | | 116.41 | na | | | | |
| SP16 | 85.0 | | 122.8 | na | | | | |
| SP15 | 69.0 | | 129.73 | na | | | | |
| SP14 | 53.0 | | 136.66 | na | | | | |
| SP13 | 37.0 | | 143.59 | na | | | | |
| HV3 | 101.0 | | 112.79 | na | | | | |
| SPR3 | 101.0 | | 114.54 | na | | | | |
| SP36 | 85.0 | | 121.47 | na | 50.0 | | | |
| SP35 | 69.0 | | 128.5 | na | 50.0 | | | |
| SP34 | 53.0 | | 135.56 | na | | | | |
| SP33 | 37.0 | | 142.61 | na | | | | |
| SP32 | 21.0 | | 149.85 | na | | | | |
| SP05 | 29.167 | | 146.31 | na | | | | |
| SP01 | 45.0 | | 140.12 | na | | | | |
| SP02 | 27.917 | | 147.52 | na | | | | |
| SP03 | 29.167 | | 146.98 | na | | | | |

Flow Summary - Standard

Aero Automatic Sprinkler Co.
Cal Poly Center for Science LVL 6 [R/A=4]

Page 5
Date 9-25-11

| Node No. | Elevation | K-Fact | Pt Actual | Pn | Flow Actual | Density | Area | Press Req. |
|----------|-----------|--------|-----------|----|-------------|---------|------|------------|
| SP04 | 28.083 | | 147.98 | na | | | | |
| SPC1 | 12.667 | | 155.45 | na | | | | |
| SPC2 | 12.667 | | 155.75 | na | | | | |
| PO | 1.833 | | 160.62 | na | | | | |
| PI | 1.75 | | 51.35 | na | | | | |
| POC | 6.75 | | 49.32 | na | | | | |
| BF1 | 13.0 | | 46.74 | na | | | | |
| BF2 | 13.0 | | 52.45 | na | | | | |
| SRC | 13.0 | | 52.67 | na | | | | |

The maximum velocity is 24.81 and it occurs in the pipe between nodes L658 and MN41

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 6 [R/A=4]

Page 6
 Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|----------------------------|----------------|-----------|----------------|------------|-----------------------|------------|-------------------------|----------------|------------------|------------|-------|-------|
| *FLOWING SPRINKLER R/A # 4 | | | | | | | | | | | | |
| S651 to L651 | 90.5 92.417 | 5.60 | 14.88 14.88 | 1 1.049 | 2E 1T | 4.0 0.0 | 5.333 4.000 | 120 | 7.057 -0.830 | | | |
| | | | 0.0 | | | | 9.333 | 0.0752 | 0.702 | Vel = | 5.52 | |
| L651 | | | 14.88 | | | | | | 6.929 | K Factor = | 5.65 | |
| S652 to L651 | 90.5 92.417 | 5.60 | 14.82 14.82 | 1 1.049 | 1E 1T | 2.0 5.0 | 3.167 7.000 | 120 | 7.000 -0.830 | | | |
| | | | 0.0 | | | | 10.167 | 0.0747 | 0.759 | Vel = | 5.50 | |
| L651 | | | 14.82 | | | | | | 6.929 | K Factor = | 5.63 | |
| S653 to L653 | 90.5 92.417 | 5.60 | 17.23 17.23 | 1 1.049 | 1E 1T | 2.0 5.0 | 5.083 7.000 | 120 | 9.471 -0.830 | | | |
| | | | 0.0 | | | | 12.083 | 0.0988 | 1.194 | Vel = | 6.40 | |
| L653 | | | 17.23 | | | | | | 9.835 | K Factor = | 5.49 | |
| S654 to L654 | 90.5 92.417 | 5.60 | 18.82 18.82 | 1 1.049 | 1E 1T | 2.0 5.0 | 5.167 7.000 | 120 | 11.299 -0.830 | | | |
| | | | 0.0 | | | | 12.167 | 0.1163 | 1.415 | Vel = | 6.99 | |
| L654 | | | 18.82 | | | | | | 11.884 | K Factor = | 5.46 | |
| S655 to L655 | 90.5 92.417 | 5.60 | 20.54 20.54 | 1 1.049 | 1E 1T | 2.0 5.0 | 5.083 7.000 | 120 | 13.460 -0.830 | | | |
| | | | 0.0 | | | | 12.083 | 0.1367 | 1.652 | Vel = | 7.62 | |
| L655 | | | 20.54 | | | | | | 14.282 | K Factor = | 5.44 | |
| S656 to L656 | 90.5 92.417 | 5.60 | 21.57 21.57 | 1 1.049 | 2E 1T | 4.0 5.0 | 5.667 9.000 | 120 | 14.836 -0.830 | | | |
| | | | 0.0 | | | | 14.667 | 0.1497 | 2.195 | Vel = | 8.01 | |
| L656 | | | 21.57 | | | | | | 16.201 | K Factor = | 5.36 | |
| S657 to L657 | 90.5 92.417 | 5.60 | 24.30 24.3 | 1 1.049 | 1E 1T | 2.0 5.0 | 5.083 7.000 | 120 | 18.835 -0.830 | | | |
| | | | 0.0 | | | | 12.083 | 0.1866 | 2.255 | Vel = | 9.02 | |
| L657 | | | 24.30 | | | | | | 20.260 | K Factor = | 5.40 | |
| S658 to L658 | 90.5 92.417 | 5.60 | 25.28 25.28 | 1 1.049 | 1E 1T | 2.0 5.0 | 5.167 7.000 | 120 | 20.376 -0.830 | | | |
| | | | 0.0 | | | | 12.167 | 0.2007 | 2.442 | Vel = | 9.38 | |
| L658 | | | 25.28 | | | | | | 21.988 | K Factor = | 5.39 | |
| S659 to MN40 | 90.5 92.417 | 5.60 | 32.22 32.22 | 1 1.049 | 1E 1T | 2.0 5.0 | 2.333 7.000 | 120 | 33.098 -0.830 | | | |
| | | | 0.0 | | | | 9.333 | 0.3143 | 2.933 | Vel = | 11.96 | |
| MN40 | | | 32.22 | | | | | | 35.201 | K Factor = | 5.43 | |
| S660 to L660 | 90.5 92.417 | 5.60 | 29.44 29.44 | 1 1.049 | 2E 1T | 4.0 5.0 | 6.500 9.000 | 120 | 27.635 -0.830 | | | |
| | | | 0.0 | | | | 15.500 | 0.2661 | 4.124 | Vel = | 10.93 | |

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 6 [R/A=4]

Page 7
 Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|-----------------------|------------------|-----------|---------------|------------|-----------------------|--------------------|----------------------------|----------------|----------------------------|-------|------------------|-------|
| L660 | | | 0.0 29.44 | | | | | | 30.929 | | K Factor = 5.29 | |
| S661 to L660 | 90.5 92.417 | 5.60 | 29.87 | 1 | 1E 1T | 2.0 5.0 0.0 | 5.083 7.000 12.083 | 120 0.2734 | 28.456 -0.830 3.303 | | Vel = 11.09 | |
| L660 | | | 0.0 29.87 | | | | | | 30.929 | | K Factor = 5.37 | |
| S662 to MN42 | 90.500 92.417 | 5.60 | 32.78 | 1 | 1T | 5.0 0.0 0.0 | 2.000 5.000 7.000 | 120 0.3246 | 34.263 -0.830 2.272 | | Vel = 12.17 | |
| MN42 | | | 0.0 32.78 | | | | | | 35.705 | | K Factor = 5.49 | |
| S663 to MN43 | 90.500 92.417 | 5.60 | 33.99 | 1 | 1T | 5.0 0.0 0.0 | 2.000 5.000 7.000 | 120 0.3471 | 36.846 -0.830 2.430 | | Vel = 12.62 | |
| MN43 | | | 0.0 33.99 | | | | | | 38.446 | | K Factor = 5.48 | |
| S664 to MN44 | 90.500 92.417 | 5.60 | 31.53 | 1 | 3E 2T | 6.0 10.0 0.0 | 24.833 16.000 40.833 | 120 0.3021 | 31.709 -0.830 12.337 | | Vel = 11.70 | |
| MN44 | | | 0.0 31.53 | | | | | | 43.216 | | K Factor = 4.80 | |
| *BRANCH LINES R/A # 4 | | | | | | | | | | | | |
| L651 to L653 | 92.417 92.417 | | 29.69 | 1 | | 0.0 0.0 0.0 | 10.750 0.0 10.750 | 120 0.2703 | 6.929 0.0 2.906 | | Vel = 11.02 | |
| L653 to L654 | 92.417 92.417 | | 17.24 | 1 | | 0.0 0.0 0.0 | 3.250 0.0 3.250 | 120 0.6305 | 9.835 0.0 2.049 | | Vel = 17.42 | |
| L654 to L655 | 92.417 92.417 | | 18.82 | 1.25 | | 0.0 0.0 0.0 | 7.750 0.0 7.750 | 120 0.3094 | 11.884 0.0 2.398 | | Vel = 14.10 | |
| L655 to L656 | 92.417 92.417 | | 20.55 | 1.25 | | 0.0 0.0 0.0 | 3.750 0.0 3.750 | 120 0.5117 | 14.282 0.0 1.919 | | Vel = 18.51 | |
| L656 to L657 | 92.417 92.417 | | 21.57 | 1.25 | | 0.0 0.0 0.0 | 5.250 0.0 5.250 | 120 0.7731 | 16.201 0.0 4.059 | | Vel = 23.14 | |
| L657 to L658 | 92.417 92.417 | | 107.87 | 1.38 | | 0.0 0.0 0.0 | 5.250 0.0 3.250 | 120 0.5317 | 20.260 0.0 1.728 | | Vel = 20.83 | |
| L658 to MN41 | 92.417 92.417 | | 25.28 | 1.5 | 1T | 8.0 0.0 0.0 | 10.000 8.000 18.000 | 120 0.7347 | 21.988 0.0 13.224 | | Vel = 24.81 | |
| MN41 | | | 0.0 157.45 | | | | | | 35.212 | | K Factor = 26.53 | |
| L660 to MN41 | 92.417 92.417 | | 59.31 | 1.25 | 1T | 6.0 0.0 0.0 | 10.750 6.000 16.750 | 120 0.2557 | 30.929 0.0 4.283 | | Vel = 12.72 | |

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 6 [R/A=4]

Page 8
 Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|----------------------|----------------|-----------|----------|------------|-----------------------|--------|-------------------------|----------------|----------------|-------|------------|-------|
| | | | 0.0 | | | | | | | | | |
| MN41 | | | 59.31 | | | | | | 35.212 | | K Factor = | 9.99 |
| *FEED MAIN | | | | | | | | | | | | |
| MN01 | 92 | .0 | 0.0 | 2.5 | | 0.0 | 3.833 | 120 | 59.446 | | | |
| to | | | | | | 0.0 | 0.0 | | 0.0 | | | |
| MN02 | 92 | | 0.0 | 2.635 | | 0.0 | 3.833 | 0 | 0.0 | | Vel = 0 | |
| MN02 | 92 | .0 | 0.0 | 2.5 | | 0.0 | 8.167 | 120 | 59.446 | | | |
| to | | | | | | 0.0 | 0.0 | | 0.0 | | | |
| MN03 | 92 | | 0.0 | 2.635 | | 0.0 | 8.167 | 0 | 0.0 | | Vel = 0 | |
| MN03 | 92 | .0 | 0.0 | 2.5 | | 0.0 | 5.833 | 120 | 59.446 | | | |
| to | | | | | | 0.0 | 0.0 | | 0.0 | | | |
| MN04 | 92 | | 0.0 | 2.635 | | 0.0 | 5.833 | 0 | 0.0 | | Vel = 0 | |
| MN04 | 92 | .0 | 0.0 | 2.5 | | 0.0 | 6.167 | 120 | 59.446 | | | |
| to | | | | | | 0.0 | 0.0 | | 0.0 | | | |
| MN05 | 92 | | 0.0 | 2.635 | | 0.0 | 6.167 | 0 | 0.0 | | Vel = 0 | |
| MN05 | 92 | .0 | 0.0 | 2.5 | | 0.0 | 4.250 | 120 | 59.446 | | | |
| to | | | | | | 0.0 | 0.0 | | 0.0 | | | |
| MN06 | 92 | | 0.0 | 2.635 | | 0.0 | 4.250 | 0 | 0.0 | | Vel = 0 | |
| MN06 | 92 | .0 | 0.0 | 2.5 | | 0.0 | 7.750 | 120 | 59.446 | | | |
| to | | | | | | 0.0 | 0.0 | | 0.0 | | | |
| MN07 | 92 | | 0.0 | 2.635 | | 0.0 | 7.750 | 0 | 0.0 | | Vel = 0 | |
| MN07 | 92 | .0 | 0.0 | 2.5 | | 0.0 | 1.250 | 120 | 59.446 | | | |
| to | | | | | | 0.0 | 0.0 | | 0.0 | | | |
| MN08 | 92 | | 0.0 | 2.635 | | 0.0 | 1.250 | 0 | 0.0 | | Vel = 0 | |
| MN08 | 92 | .0 | 0.0 | 2.5 | | 0.0 | 10.750 | 120 | 59.446 | | | |
| to | | | | | | 0.0 | 0.0 | | 0.0 | | | |
| MN09 | 92 | | 0.0 | 2.635 | | 0.0 | 10.750 | 0 | 0.0 | | Vel = 0 | |
| MN09 | 92 | .0 | 0.0 | 2.5 | | 0.0 | 1.250 | 120 | 59.446 | | | |
| to | | | | | | 0.0 | 0.0 | | 0.0 | | | |
| MN10 | 92 | | 0.0 | 2.635 | | 0.0 | 1.250 | 0 | 0.0 | | Vel = 0 | |
| MN10 | 92 | .0 | 0.0 | 2.5 | | 0.0 | 12.000 | 120 | 59.446 | | | |
| to | | | | | | 0.0 | 0.0 | | 0.0 | | | |
| MN11 | 92 | | 0.0 | 2.635 | | 0.0 | 12.000 | 0 | 0.0 | | Vel = 0 | |
| MN11 | 92 | .0 | 0.0 | 2.5 | 2I | 16.474 | 149.750 | 120 | 59.446 | | | |
| to | | | | | 1T | 16.474 | 32.948 | | -0.577 | | | |
| MN12 | 93.333 | | 0.0 | 2.635 | | 0.0 | 182.698 | 0 | 0.0 | | Vel = 0 | |
| | | | 0.0 | | | | | | | | | |
| MN12 | | | 0.0 | | | | | | 58.869 | | K Factor = | 0 |
| MN40 | 92.417 | | 32.22 | 2.5 | | 0.0 | 3.083 | 120 | 35.201 | | | |
| to | | | | | | 0.0 | 0.0 | | 0.0 | | | |
| MN41 | 92.417 | | 32.22 | 2.635 | | 0.0 | 3.083 | 0.0036 | 0.011 | | Vel = | 1.90 |
| MN41 | 92.417 | | 216.76 | 2.5 | | 0.0 | 3.167 | 120 | 35.212 | | | |
| to | | | | | | 0.0 | 0.0 | | 0.0 | | | |
| MN42 | 92.417 | | 248.98 | 2.635 | | 0.0 | 3.167 | 0.1557 | 0.493 | | Vel = | 14.65 |
| MN42 | 92.417 | | 32.78 | 2.5 | | 0.0 | 14.000 | 120 | 35.705 | | | |
| to | | | | | | 0.0 | 0.0 | | 0.0 | | | |
| MN43 | 92.417 | | 281.76 | 2.635 | | 0.0 | 14.000 | 0.1958 | 2.741 | | Vel = | 16.58 |

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 6 [R/A=4]

Page 9
 Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|----------------------|------------------|-----------|-----------------|--------------|-----------------------|------------------------|---------------------------|----------------|----------------------------|------------------|-------|--------------------------------|
| MN43 to MN44 | 92.417 92.417 | | 33.99 315.75 | 2.5 2.635 | 1I | 8.237 0.0 | 11.500 8.237 | 120 0.2417 | 38.446 0.0 | | | |
| | | | | | | 0.0 | 19.737 | | 4.770 | Vel = 18.58 | | |
| MN44 to MN45 | 92.417 92.417 | | 31.53 347.28 | 2.5 2.635 | 1T | 16.474 0.0 | 0.917 16.474 | 120 0.2882 | 43.216 0.0 | | | |
| | | | | | | 0.0 | 17.391 | | 5.012 | Vel = 20.43 | | |
| MN45 to MN12 | 92.417 93.333 | | 0.0 347.28 | 2.5 2.635 | 3I | 24.711 0.0 | 13.583 24.711 | 120 0.2882 | 48.228 -0.397 | | | |
| | | | | | | 0.0 | 38.294 | | 11.037 | Vel = 20.43 | | |
| MN12 to MN13 | 93.333 93.333 | | 0.0 347.28 | 2.5 2.635 | 1I 1T | 8.237 16.474 | 32.833 24.711 | 120 0.2882 | 58.868 0.0 | | | |
| | | | | | | 0.0 | 57.544 | | 16.585 | Vel = 20.43 | | |
| MN13 to MN14 | 93.333 91.083 | | 0.0 347.28 | 2.5 2.635 | 2I 1T | 16.474 16.474 | 26.417 32.948 | 120 0.2882 | 75.453 0.974 | | | |
| | | | | | | 0.0 | 59.365 | | 17.111 | Vel = 20.43 | | |
| MN14 to TOR6 | 91.083 91.083 | | 0.0 347.28 | 2.5 2.635 | 2I | 16.474 0.0 | 9.667 16.474 | 120 0.2882 | 93.538 0.0 | | | |
| | | | | | | 0.0 | 26.141 | | 7.534 | Vel = 20.43 | | |
| TOR6 to BOR6 | 91.083 84 | | 0.0 347.28 | 2.5 2.635 | 1C 1B 1I | 19.22 9.61 8.237 | 7.083 37.067 44.150 | 120 0.2882 | 101.072 3.068 12.724 | | | |
| | | | | | | 0.0 | 44.150 | | 12.724 | Vel = 20.43 | | |
| BOR6 to SP36 | 84 85 | | 0.0 347.28 | 2.5 2.635 | 1T | 16.474 0.0 | 1.000 16.474 | 120 0.2882 | 116.864 -0.433 | | | |
| | | | | | | 0.0 | 17.474 | | 5.036 | Vel = 20.43 | | |
| SP36 | | | 0.0 347.28 | | | | | | 121.467 | K Factor = 31.51 | | |
| *S/P # 1 | | | | | | | | | | | | |
| HV1 to SPRF | 99.750 99.750 | .0 | 0.0 0.0 | 2.5 2.469 | 1T | 12.0 0.0 | 0.250 12.000 | 120 0 | 114.659 1.750 | | | * Fixed loss = 1.75 Vel = 0 |
| | | | | | | 0.0 | 12.250 | | 0.0 | | | |
| SPRF | | | 0.0 0.0 | | | | | | 116.409 | K Factor = 0 | | |
| HV2 to SPRF | 99.750 99.750 | .0 | 0.0 0.0 | 2.5 2.469 | 1T | 12.0 0.0 | 0.250 12.000 | 120 0 | 114.659 1.750 | | | * Fixed loss = 1.75 Vel = 0 |
| | | | | | | 0.0 | 12.250 | | 0.0 | | | |
| SPRF to SP16 | 99.750 85 | .0 | 0.0 0.0 | 6 6.065 | 4I | 40.0 0.0 | 30.000 40.000 | 120 0 | 116.409 6.388 | | | Vel = 0 |
| | | | | | | 0.0 | 70.000 | | 0.0 | | | |
| SP16 to SP15 | 85 69 | .0 | 0.0 0.0 | 6 6.065 | | 0.0 0.0 | 16.000 0.0 | 120 0 | 122.797 6.930 | | | Vel = 0 |
| | | | | | | 0.0 | 16.000 | | 0.0 | | | |
| SP15 to SP14 | 69 53 | .0 | 0.0 0.0 | 6 6.065 | | 0.0 0.0 | 16.000 0.0 | 120 0 | 129.726 6.930 | | | Vel = 0 |
| | | | | | | 0.0 | 16.000 | | 0.0 | | | |
| SP14 to SP01 | 53 45 | .0 | 0.0 0.0 | 6 6.065 | 1T | 30.0 0.0 | 8.500 30.000 | 120 0 | 136.656 3.465 | | | Vel = 0 |
| | | | | | | 0.0 | 38.500 | | 0.0 | | | |
| | | | 0.0 | | | | | | | | | |

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 6 [R/A=4]

Page 10
 Date 9-25-11


| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|----------------------|------------------|-----------|----------|------------|-----------------------|------|-------------------------|----------------|-------------------|-------|---------------------|-------|
| SP01 | | | 0.0 | | | | | | 140.121 | | K Factor = 0 | |
| SP13 to SP01 | 37 45 | .0 | 0.0 | 6 | 1T | 30.0 | 7.500 30.000 | 120 | 143.586 -3.465 | | | |
| | | | 0.0 | 6.065 | | 0.0 | 37.500 | 0 | 0.0 | | Vel = 0 | |
| SP01 | | | 0.0 | | | | | | 140.121 | | K Factor = 0 | |
| *S/P # 3 | | | | | | | | | | | | |
| HV3 to SPR3 | 101 101 | .0 | 0.0 | 2.5 | 2E 1T | 12.0 | 1.750 24.000 | 120 | 112.788 1.750 | | * Fixed loss = 1.75 | |
| | | | 0.0 | 2.469 | | 0.0 | 25.750 | 0 | 0.0 | | Vel = 0 | |
| SPR3 to SP36 | 101 85 | .0 | 0.0 | 6 | | 0.0 | 16.000 0.0 | 120 | 114.538 6.930 | | | |
| | | | 0.0 | 6.065 | | 0.0 | 16.000 | 0 | 0.0 | | Vel = 0 | |
| SP36 to SP35 | 85 69 | H50 | 397.28 | 6 | | 0.0 | 16.000 0.0 | 120 | 121.467 6.930 | | | |
| | | | 397.28 | 6.065 | | 0.0 | 16.000 | 0.0064 | 0.102 | | Vel = 4.41 | |
| SP35 to SP34 | 69 53 | H50 | 50.00 | 6 | | 0.0 | 16.000 0.0 | 120 | 128.499 6.930 | | | |
| | | | 447.28 | 6.065 | | 0.0 | 16.000 | 0.0079 | 0.127 | | Vel = 4.97 | |
| SP34 to SP33 | 53 37 | | 0.0 | 6 | | 0.0 | 16.000 0.0 | 120 | 135.556 6.930 | | | |
| | | | 447.28 | 6.065 | | 0.0 | 16.000 | 0.0079 | 0.126 | | Vel = 4.97 | |
| SP33 to SP05 | 37 29.167 | | 0.0 | 6 | 1T | 30.0 | 8.417 30.000 | 120 | 142.612 3.392 | | | |
| | | | 447.28 | 6.065 | | 0.0 | 38.417 | 0.0080 | 0.306 | | Vel = 4.97 | |
| SP05 | | | 0.0 | | | | | | 146.310 | | K Factor = 36.98 | |
| SP32 to SP05 | 21 29.167 | .0 | 0.0 | 6 | 1T | 30.0 | 7.583 30.000 | 120 | 149.847 -3.537 | | | |
| | | | 0.0 | 6.065 | | 0.0 | 37.583 | 0 | 0.0 | | Vel = 0 | |
| SP05 to SP03 | 29.167 29.167 | | 447.28 | 6 | 1I 1B 1T | 10.0 | 34.167 50.000 | 120 | 146.310 0.0 | | | |
| | | | 447.28 | 6.065 | | 30.0 | 84.167 | 0.0079 | 0.668 | | Vel = 4.97 | |
| SP03 | | | 0.0 | | | | | | 146.978 | | K Factor = 36.89 | |
| *STANDPIPE FEED | | | | | | | | | | | | |
| SP01 to SP02 | 45 27.917 | .0 | 0.0 | 6 | 1B 6I | 10.0 | 34.417 70.000 | 120 | 140.121 7.399 | | | |
| | | | 0.0 | 6.065 | | 60.0 | 104.417 | 0 | 0.0 | | Vel = 0 | |
| SP02 to SP03 | 27.917 29.167 | .0 | 0.0 | 6 | 2I | 20.0 | 235.417 20.000 | 120 | 147.519 -0.541 | | | |
| | | | 0.0 | 6.065 | | 0.0 | 255.417 | 0 | 0.0 | | Vel = 0 | |
| SP03 to SP04 | 29.167 28.083 | | 447.28 | 6 | 4I | 40.0 | 27.500 40.000 | 120 | 146.978 0.469 | | | |
| | | | 447.28 | 6.065 | | 0.0 | 67.500 | 0.0079 | 0.536 | | Vel = 4.97 | |
| SP04 to SPC1 | 28.083 12.667 | | 0.0 | 6 | 2I | 20.0 | 79.330 20.000 | 120 | 147.983 6.677 | | | |
| | | | 447.28 | 6.065 | | 0.0 | 99.330 | 0.0079 | 0.789 | | Vel = 4.97 | |

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science LVL 6 [R/A=4]

Page 11
 Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|--------------------------|------------------|-----------|---------------|------------|-----------------------|---------------------------|------------------------------|----------------|---------------------------|-------|----------------------------------|-------|
| SPC1 to SPC2 | 12.667 12.667 | | 0.0 447.28 | 6 6.065 | 1T | 30.0 0.0 | 7.833 30.000 | 120 0.0079 | 155.449 0.300 | | Vel = 4.97 | |
| SPC2 to PO | 12.667 1.833 | | 0.0 447.28 | 8 7.981 | 1I 1B 1C | 13.0 12.0 45.0 | 14.750 70.000 84.750 | 120 0.0021 | 155.749 4.692 0.177 | | Vel = 2.87 | |
| PO | | | 0.0 447.28 | | | | | | 160.618 | | K Factor = 35.29 | |
| System Demand Pressure | | | | | | 160.618 | | | | | | |
| Safety Margin | | | | | | 13.576 | | | | | | |
| Continuation Pressure | | | | | | 174.194 | | | | | | |
| Pressure @ Pump Outlet | | | | | | 174.194 | | | | | | |
| Pressure From Pump Curve | | | | | | -122.847 | | | | | | |
| Pressure @ Pump Inlet | | | | | | 51.347 | | | | | | |
| PI to POC | 1.750 6.750 | | 0.0 447.28 | 8 7.981 | 1G 1I 1T | 4.0 13.0 35.0 | 14.000 52.000 66.000 | 120 0.0021 | 51.347 -2.166 0.138 | | Vel = 2.87 | |
| POC to BF1 | 6.750 13 | | 0.0 447.28 | 8 8.27 | 2E | 56.936 0.0 | 41.000 56.936 | 140 0.0013 | 49.319 -2.707 0.130 | | Vel = 2.67 | |
| BF1 to BF2 | 13 13 | | 0.0 447.28 | 8 7.981 | 1Zic | 0.0 0.0 | 4.000 0.0 | 120 0.0020 | 46.742 5.700 0.008 | | * Fixed loss = 5.7 Vel = 2.87 | |
| BF2 to SRC | 13 13 | | 0.0 447.28 | 8 8.27 | 2E 1G 1T | 56.936 6.326 55.354 | 46.000 118.616 164.616 | 140 0.0013 | 52.450 0.0 0.217 | | Vel = 2.67 | |
| SRC | | | 0.0 447.28 | | | | | | 52.667 | | K Factor = 61.63 | |



STANDPIPE # 1 [1000 & 750]

This page intentionally left blank.



**AUTOMATIC
SPRINKLER CO.**

21605 North Central Ave. 623.580.7800
Phoenix, Arizona 85024 Fax 623.434.3154

AZ-L16-234798 CA-C16-901529
AZ-C16-234797 NV-C41-69370
UT-S370-6690455-5501 NM-MS 12-354807



Fire Protection by Computer Design

Aero Automatic Sprinkler Co.
21605 N. Central Ave.
Phoenix, Arizona 85024
623-580-7800

Job Name : Cal Poly Center for Science SP 1-1 [1000 GPM]
Building : Center for Science
Location : San Luis Obispo, Ca.
System : S/P # 1
Contract : 10034
Data File : Cal Poly CFS SP 1-1.WXF

HYDRAULIC DESIGN INFORMATION SHEET

Name - Cal Poly Center For Science Date - 9-25-2011
 Location - San Luis Obispo, Ca.
 Building - Center for Science System No. - S/P # 1
 Contractor - Aero Automatic Sprinkler Co. Contract No. - 10034
 Calculated By - Neal Larsen Drawing No. -
 Occupancy - Light / Ordinary Hazard Gr. 1

S (X)NFPA 14 Number of Standpipes ()1 ()2 ()3 (X)4 ()

Y ()Other

S ()Specific Ruling Made by Date

T

| | | | | |
|---|--|---------------------|------|-----------------|
| E | Flow at Top Most Outlet | - 500 | Gpm | System Type |
| M | Pres. at Top Most Outlet | - 100 | Psi | (X) Wet () Dry |
| | Flow For Ea. Additional Standpipe | - 500 | Gpm | |
| D | Total Additional Flow | - 1000 | Gpm | |
| E | Elevation at Highest Outlet | - 69'-0" | Feet | |
| S | Hose Valve Connection | ()1 1/2" (X)2 1/2" | | |
| I | Class Service | (X)I ()II (X)III | | |
| G | Note:At 5 th level there are three (3) standpipes available. | | | |
| N | {Standpipe # 1, 3 & 4} | | | |

| | | | |
|-------------|-------------------|--------------------|-----------------|
| Calculation | Gpm Required 1000 | Psi Required 47.18 | At SRC |
| Summary | C-Factor Used: | Overhead 120 | Underground 140 |

| | | | |
|---|--------------------------|----------------|--------------------|
| W | Water Flow Test: | Pump Data: | Tank or Reservoir: |
| A | Date of Test - 9-19-2011 | | Cap. N/A |
| T | Time of Test - 9:12 a.m. | Rated Cap. 750 | Elev. N/A |
| E | Static (Psi) - 60 [54] | @ Psi 113 | |
| R | Residual (Psi) - 55 [49] | Elev. 1'-9" | Well |
| | Flow (Gpm) - 914 | | Proof Flow Gpm N/A |
| S | Elevation - 13'-0" | | |

U


P Location: Static & Residual pressures taken from Hydrant # 63. Flow taken
 P from Hydrant # 64 along N. Poly View Drive
 L Source of Information: Fluid Resource Management {R. Ellison}
 Y Note : Flow test used in Hyd. Calculations was reduced by 10 %

Water Supply Curve (C)

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science SP 1-1 [1000 GPM]

Page 2
 Date 9-25-11

| | | |
|---|--|--|
| City Water Supply: C1 - Static Pressure : 54 C2 - Residual Pressure: 49 C2 - Residual Flow : 914 City Water Adjusted to Pump Inlet for Pf - Elev - Hose Flow A1 - Adjusted Static: 51.872 A2 - Adj Resid : 49.314 @ 790.2 A3 - Adj Resid : 40.224 @ 1382.9 | Pump Data: P1 - Pump Churn Pressure : 125.2 P2 - Pump Rated Pressure : 110.9 P2 - Pump Rated Flow : 790.2 P3 - Pump Pressure @ Max Flow : 67.9 P3 - Pump Max Flow : 1382.9 City Residual Flow @ 0 = 3307.91 City Residual Flow @ 20 = 2576.03 City Water @ 150% of Pump = 43.24 | Demand: D1 - Elevation : 24.254 D2 - System Flow : _____ D2 - System Pressure : 144.081 Hose (Adj City) : _____ Hose (Demand) : 1000 D3 - System Demand : 1000 Safety Margin : 0.911 |
|---|--|--|



Fittings Used Summary

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science SP 1-1 [1000 GPM]

Page 3
 Date 9-25-11

Fitting Legend

| Abbrev. | Name | ½ | ¾ | 1 | 1¼ | 1½ | 2 | 2½ | 3 | 3½ | 4 | 5 | 6 | 8 | 10 | 12 | 14 | 16 | 18 | 20 | 24 |
|---------|-------------------------|--|---|------|----|-----|-----|----|----|----|----|-----|----|----|----|----|----|----|----|-----|-----|
| B | Generic Butterfly Valve | 0 | 0 | 2.25 | 2 | 2.5 | 6 | 7 | 10 | 0 | 12 | 9 | 10 | 12 | 19 | 21 | 0 | 0 | 0 | 0 | 0 |
| C | Generic Check Vlv | 4 | 5 | 5 | 7 | 9 | 11 | 14 | 16 | 19 | 22 | 27 | 32 | 45 | 55 | 65 | 76 | 87 | 98 | 109 | 130 |
| E | 90' Standard Elbow | 2 | 2 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 10 | 12 | 14 | 18 | 22 | 27 | 35 | 40 | 45 | 50 | 61 |
| G | Generic Gate Valve | 0 | 0 | 0 | 1 | 0 | 1 | 1 | 1 | 1 | 2 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 10 | 11 | 13 |
| I | 90' Ell Grvd-Vic #10 | 0 | 0 | 2 | 3 | 4 | 3.5 | 6 | 5 | 8 | 7 | 8.5 | 10 | 13 | 17 | 20 | 23 | 25 | 33 | 36 | 40 |
| T | 90' Flow Thru Tee | 3 | 4 | 5 | 6 | 8 | 10 | 12 | 15 | 17 | 20 | 25 | 30 | 35 | 50 | 60 | 71 | 81 | 91 | 101 | 121 |
| Zic | Wilkens 350ADA | Fitting generates a Fixed Loss Based on Flow | | | | | | | | | | | | | | | | | | | |

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Pressure / Flow Summary - STANDARD

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science SP 1-1 [1000 GPM]

Page 4
 Date 9-25-11

| Node No. | Elevation | K-Fact | Pt Actual | Pn | Flow Actual | Density | Area | Press Req. |
|----------|-----------|--------|-----------|----|-------------|---------|------|------------|
| HV1 | 99.75 | | 91.19 | na | | | | |
| HV2 | 99.75 | | 91.19 | na | | | | |
| SPRF | 99.75 | | 92.94 | na | | | | |
| SP16 | 85.0 | | 99.33 | na | | | | |
| HV4 | 69.0 | | 100.0 | na | 250.0 | | | |
| HV5 | 53.0 | | 106.97 | na | 250.0 | | | |
| SP15 | 69.0 | | 106.26 | na | | | | |
| SP14 | 53.0 | | 113.23 | na | | | | |
| SP13 | 37.0 | | 120.53 | na | | | | |
| HV3 | 101.0 | | 88.52 | na | 250.0 | | | |
| SPR3 | 101.0 | | 95.82 | na | | | | |
| SP36 | 85.0 | | 102.8 | na | | | | |
| HV6 | 69.0 | | 108.02 | na | | | | |
| HV7 | 53.0 | | 114.99 | na | | | | |
| SP35 | 69.0 | | 109.77 | na | | | | |
| SP34 | 53.0 | | 116.74 | na | | | | |
| SP33 | 37.0 | | 123.71 | na | | | | |
| SP32 | 21.0 | | 130.75 | na | | | | |
| SP05 | 29.167 | | 127.21 | na | | | | |
| SP01 | 45.0 | | 117.07 | na | | | | |
| SP02 | 27.917 | | 125.49 | na | | | | |
| SP03 | 29.167 | | 127.44 | na | | | | |
| SP04 | 28.083 | | 129.3 | na | | | | |
| SPC1 | 12.667 | | 137.82 | na | | | | |
| SPC2 | 12.667 | | 138.61 | na | 250.0 | | | |
| PO | 1.833 | | 144.08 | na | | | | |
| PI | 1.75 | | 46.96 | na | | | | |
| POC | 6.75 | | 45.4 | na | | | | |
| BF1 | 13.0 | | 43.27 | na | | | | |
| BF2 | 13.0 | | 47.13 | na | | | | |
| SRC | 13.0 | | 48.1 | na | | | | |

The maximum velocity is 16.75 and it occurs in the pipe between nodes HV4 and SP15

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science SP 1-1 [1000 GPM]

Page 5
 Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|----------------------------------|------------------|-----------|----------|------------|-----------------------|--------------|-------------------------|----------------|----------------|-------|---------------------|-------|
| *S/P # 1 REMOTE ROOF HOSE VALVES | | | | | | | | | | | | |
| HV1 to SPRF | 99.750 99.750 | .0 | 0.0 | 2.5 | 1T | 12.0 | 0.250 | 120 | 91.188 | | | |
| | | | 0.0 | 2.469 | | 0.0 | 12.000 | | 1.750 | | * Fixed loss = 1.75 | |
| | | | 0.0 | | | 0.0 | 12.250 | 0 | 0.0 | | Vel = 0 | |
| | | | 0.0 | | | | | | 92.938 | | K Factor = 0 | |
| HV2 to SPRF | 99.750 99.750 | .0 | 0.0 | 2.5 | 1T | 12.0 | 0.250 | 120 | 91.188 | | | |
| | | | 0.0 | 2.469 | | 0.0 | 12.000 | | 1.750 | | * Fixed loss = 1.75 | |
| | | | 0.0 | | | 0.0 | 12.250 | 0 | 0.0 | | Vel = 0 | |
| | | | 0.0 | | | | | | 92.938 | | K Factor = 0 | |
| SPRF to SP16 | 99.750 85 | .0 | 0.0 | 6 | 4I | 40.0 | 30.000 | 120 | 92.938 | | | |
| | | | 0.0 | 6.065 | | 0.0 | 40.000 | | 6.388 | | | |
| | | | 0.0 | | | 0.0 | 70.000 | 0 | 0.0 | | Vel = 0 | |
| SP16 to SP15 | 85 69 | .0 | 0.0 | 6 | | 0.0 | 16.000 | 120 | 99.326 | | | |
| | | | 0.0 | 6.065 | | 0.0 | 0.0 | | 6.930 | | | |
| | | | 0.0 | | | 0.0 | 16.000 | 0 | 0.0 | | Vel = 0 | |
| | | | 0.0 | | | | | | 106.256 | | K Factor = 0 | |
| HV4 to SP15 | 69 69 | H250 | 250.00 | 2.5 | 1T 1E | 12.0 6.0 | 2.917 18.000 | 120 | 100.000 | | | |
| | | | 250.0 | 2.469 | | 0.0 | 20.917 | 0.2154 | 4.506 | | * Fixed loss = 1.75 | |
| | | | 0.0 | | | | | | | | Vel = 16.75 | |
| | | | 250.00 | | | | | | 106.256 | | K Factor = 24.25 | |
| HV5 to SP14 | 53 53 | H250 | 250.00 | 2.5 | 1T 1E | 12.0 6.0 | 2.917 18.000 | 120 | 106.973 | | | |
| | | | 250.0 | 2.469 | | 0.0 | 20.917 | 0.2154 | 4.506 | | * Fixed loss = 1.75 | |
| | | | 0.0 | | | | | | | | Vel = 16.75 | |
| | | | 250.00 | | | | | | 113.229 | | K Factor = 23.49 | |
| SP15 to SP14 | 69 53 | | 250.00 | 6 | | 0.0 | 16.000 | 120 | 106.256 | | | |
| | | | 250.0 | 6.065 | | 0.0 | 0.0 | | 6.930 | | | |
| | | | 250.0 | | | 0.0 | 16.000 | 0.0027 | 0.043 | | Vel = 2.78 | |
| SP14 to SP01 | 53 45 | | 250.00 | 6 | 1T | 30.0 | 8.500 | 120 | 113.229 | | | |
| | | | 500.0 | 6.065 | | 0.0 | 30.000 | | 3.465 | | | |
| | | | 500.0 | | | 0.0 | 38.500 | 0.0097 | 0.375 | | Vel = 5.55 | |
| | | | 0.0 | | | | | | | | | |
| | | | 500.00 | | | | | | 117.069 | | K Factor = 46.21 | |
| SP13 to SP01 | 37 45 | .0 | 0.0 | 6 | 1T | 30.0 | 7.500 | 120 | 120.534 | | | |
| | | | 0.0 | 6.065 | | 0.0 | 30.000 | | -3.465 | | | |
| | | | 0.0 | | | 0.0 | 37.500 | 0 | 0.0 | | Vel = 0 | |
| | | | 0.0 | | | | | | | | | |
| | | | 0.0 | | | | | | 117.069 | | K Factor = 0 | |
| *S/P # 3 | | | | | | | | | | | | |
| HV3 to SPR3 | 101 101 | H250 | 250.00 | 2.5 | 2E 1T | 12.0 12.0 | 1.750 24.000 | 120 | 88.525 | | | |
| | | | 250.0 | 2.469 | | 0.0 | 25.750 | 0.2154 | 5.547 | | * Fixed loss = 1.75 | |
| | | | 0.0 | | | 0.0 | 16.000 | 120 | 95.822 | | Vel = 16.75 | |
| | | | 0.0 | 6 | | 0.0 | 0.0 | | 6.930 | | | |
| SPR3 to SP36 | 101 85 | | 0.0 | 6 | | 0.0 | 0.0 | 120 | 95.822 | | | |
| | | | 250.0 | 6.065 | | 0.0 | 16.000 | 0.0027 | 0.043 | | Vel = 2.78 | |

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science SP 1-1 [1000 GPM]

Page 6
 Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|----------------------|------------------|-----------|-----------------|--------------|-----------------------|----------------------|------------------------------|----------------|----------------------------|-------|--------------------------------|-------|
| SP36 to SP35 | 85 69 | | 0.0 250.0 | 6 6.065 | | 0.0 0.0 | 16.000 0.0 | 120 0.0027 | 102.795 6.930 0.043 | | Vel = 2.78 | |
| SP35 | | | 0.0 250.00 | | | | | | 109.768 | | K Factor = 23.86 | |
| HV6 to SP35 | 69 69 | .0 | 0.0 0.0 | 2.5 2.469 | 2E 1T | 12.0 12.0 | 1.750 24.000 25.750 | 120 0 | 108.018 1.750 0.0 | | * Fixed loss = 1.75 Vel = 0 | |
| SP35 | | | 0.0 0.0 | | | | | | 109.768 | | K Factor = 0 | |
| HV7 to SP34 | 53 53 | .0 | 0.0 0.0 | 2.5 2.469 | 2E 1T | 12.0 12.0 | 1.750 24.000 25.750 | 120 0 | 114.990 1.750 0.0 | | * Fixed loss = 1.75 Vel = 0 | |
| SP34 | | | 0.0 0.0 | | | | | | 116.740 | | K Factor = 0 | |
| SP35 to SP34 | 69 53 | | 250.00 250.0 | 6 6.065 | | 0.0 0.0 | 16.000 0.0 16.000 | 120 0.0026 | 109.768 6.930 0.042 | | Vel = 2.78 | |
| SP34 to SP33 | 53 37 | | 0.0 250.0 | 6 6.065 | | 0.0 0.0 | 16.000 0.0 16.000 | 120 0.0027 | 116.740 6.930 0.043 | | Vel = 2.78 | |
| SP33 to SP05 | 37 29.167 | | 0.0 250.0 | 6 6.065 | 1T | 30.0 0.0 | 8.417 30.000 38.417 | 120 0.0027 | 123.713 3.392 0.105 | | Vel = 2.78 | |
| SP05 | | | 0.0 250.00 | | | | | | 127.210 | | K Factor = 22.17 | |
| SP32 to SP05 | 21 29.167 | .0 | 0.0 0.0 | 6 6.065 | 1T | 30.0 0.0 | 7.583 30.000 37.583 | 120 0 | 130.747 -3.537 0.0 | | Vel = 0 | |
| SP05 to SP03 | 29.167 29.167 | | 250.00 250.0 | 6 6.065 | 1I 1B 1T | 10.0 10.0 30.0 | 34.167 50.000 84.167 | 120 0.0027 | 127.210 0.0 0.228 | | Vel = 2.78 | |
| SP03 | | | 0.0 250.00 | | | | | | 127.438 | | K Factor = 22.15 | |
| *STANDPIPE FEED | | | | | | | | | | | | |
| SP01 to SP02 | 45 27.917 | | 500.00 500.0 | 6 6.065 | 6I 1B | 60.0 10.0 | 34.417 70.000 104.417 | 120 0.0098 | 117.069 7.399 1.019 | | Vel = 5.55 | |
| SP02 to SP03 | 27.917 29.167 | | 0.0 500.0 | 6 6.065 | 2I | 20.0 0.0 | 235.417 20.000 255.417 | 120 0.0098 | 125.487 -0.541 2.492 | | Vel = 5.55 | |
| SP03 to SP04 | 29.167 28.083 | | 250.00 750.0 | 6 6.065 | 4I | 40.0 0.0 | 27.500 40.000 67.500 | 120 0.0207 | 127.438 0.469 1.395 | | Vel = 8.33 | |
| SP04 to SPC1 | 28.083 12.667 | | 0.0 750.0 | 6 6.065 | 1I | 10.0 0.0 | 79.330 10.000 89.330 | 120 0.0207 | 129.302 6.677 1.845 | | Vel = 8.33 | |

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science SP 1-1 [1000 GPM]

Page 7
 Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|--------------------------|------------------|-----------|------------------|------------|-----------------------|---------------------------|------------------------------|----------------|---------------------------|-------|------------------------------------|-------|
| SPC1 to SPC2 | 12.667 12.667 | | 0.0 750.0 | 6 6.065 | 1T | 30.0 0.0 | 7.833 30.000 | 120 0.0207 | 137.824 0.782 | | Vel = 8.33 | |
| SPC2 to PO | 12.667 1.833 | H250 | 250.00 1000.0 | 8 7.981 | 1I 1B 1C | 13.0 12.0 45.0 | 14.750 70.000 84.750 | 120 0.0092 | 138.606 4.692 0.783 | | Vel = 6.41 | |
| PO | | | 0.0 1000.00 | | | | | | 144.081 | | K Factor = 83.31 | |
| System Demand Pressure | | | | | | 144.081 | | | | | | |
| Safety Margin | | | | | | 0.911 | | | | | | |
| Continuation Pressure | | | | | | 144.992 | | | | | | |
| Pressure @ Pump Outlet | | | | | | 144.992 | | | | | | |
| Pressure From Pump Curve | | | | | | -98.034 | | | | | | |
| Pressure @ Pump Inlet | | | | | | 46.958 | | | | | | |
| PI to POC | 1.750 6.750 | | 0.0 1000.0 | 8 7.981 | 1G 1I 1T | 4.0 13.0 35.0 | 14.000 52.000 66.000 | 120 0.0093 | 46.958 -2.166 0.611 | | Vel = 6.41 | |
| POC to BF1 | 6.750 13 | | 0.0 1000.0 | 8 8.27 | 2E | 56.936 0.0 | 41.000 56.936 | 140 0.0058 | 45.403 -2.707 0.572 | | Vel = 5.97 | |
| BF1 to BF2 | 13 13 | | 0.0 1000.0 | 8 7.981 | 1Zic | 0.0 0.0 | 4.000 0.0 | 120 0.0090 | 43.268 3.829 0.036 | | * Fixed loss = 3.829 Vel = 6.41 | |
| BF2 to SRC | 13 13 | | 0.0 1000.0 | 8 8.27 | 2E 1G 1T | 56.936 6.326 55.354 | 46.000 118.616 164.616 | 140 0.0058 | 47.133 0.0 0.962 | | Vel = 5.97 | |
| SRC | | | 0.0 1000.00 | | | | | | 48.095 | | K Factor = 144.19 | |



**AUTOMATIC
SPRINKLER CO.**

21605 North Central Ave. 623.580.7800
Phoenix, Arizona 85024 Fax 623.434.3154

AZ-L16-234798 CA-C16-901529
AZ-C16-234797 NV-C41-69370
UT-S370-6690455-5501 NM-MS 12-354807



Fire Protection by Computer Design

Aero Automatic Sprinkler Co.
21605 N. Central Ave.
Phoenix, Arizona 85024
623-580-7800

Job Name : Cal Poly Center for Science SP 1-2 [750 GPM]
Building : Center for Science
Location : San Luis Obispo, Ca.
System : S/P # 1
Contract : 10034
Data File : Cal Poly CFS SP 1-2.WXF

HYDRAULIC DESIGN INFORMATION SHEET

Name - Cal Poly Center For Science Date - 9-25-2011
 Location - San Luis Obispo, Ca.
 Building - Center for Science System No. - S/P # 1
 Contractor - Aero Automatic Sprinkler Co. Contract No. - 10034
 Calculated By - Neal Larsen Drawing No. -
 Occupancy - Light / Ordinary Hazard Gr. 1

S (X)NFPA 14 Number of Standpipes ()1 ()2 ()3 (X)4 ()

Y ()Other

S ()Specific Ruling Made by Date

T

| | | | | |
|---|--|---------------------|------|-----------------|
| E | Flow at Top Most Outlet | - 500 | Gpm | System Type |
| M | Pres. at Top Most Outlet | - 100 | Psi | (X) Wet () Dry |
| | Flow For Ea. Additional Standpipe | - 500 | Gpm | |
| D | Total Additional Flow | - 1000 | Gpm | |
| E | Elevation at Highest Outlet | - 99'-9" | Feet | |
| S | Hose Valve Connection | ()1 1/2" (X)2 1/2" | | |
| I | Class Service | (X)I ()II (X)III | | |
| G | Note:At Roof level there are two (2) standpipes available. | | | |
| N | {Standpipe # 1 & 3} | | | |

| | | | |
|-------------|------------------|--------------------|-----------------|
| Calculation | Gpm Required 750 | Psi Required 44.73 | At SRC |
| Summary | C-Factor Used: | Overhead 120 | Underground 140 |

| | | | |
|---|--------------------------|----------------|--------------------|
| W | Water Flow Test: | Pump Data: | Tank or Reservoir: |
| A | Date of Test - 9-19-2011 | | Cap. N/A |
| T | Time of Test - 9:12 a.m. | Rated Cap. 750 | Elev. N/A |
| E | Static (Psi) - 60 [54] | @ Psi 113 | |
| R | Residual (Psi) - 55 [49] | Elev. 1'-9" | Well |
| | Flow (Gpm) - 914 | | Proof Flow Gpm N/A |
| S | Elevation - 13'-0" | | |

U


P Location: Static & Residual pressures taken from Hydrant # 63. Flow taken
 P from Hydrant # 64 along N. Poly View Drive
 L Source of Information: Fluid Resource Management {R. Ellison}
 Y Note : Flow test used in Hyd. Calculations was reduced by 10 %

Water Supply Curve (C)

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science SP 1-2 [750 GPM]

Page 2
 Date 9-25-11

| | | |
|--|--|--|
| City Water Supply: C1 - Static Pressure : 54 C2 - Residual Pressure: 49 C2 - Residual Flow : 914 City Water Adjusted to Pump Inlet for Pf - Elev - Hose Flow A1 - Adjusted Static: 51.872 A2 - Adj Resid : 49.314 @ 790.2 A3 - Adj Resid : 40.224 @ 1382.9 | Pump Data: P1 - Pump Churn Pressure : 125.2 P2 - Pump Rated Pressure : 110.9 P2 - Pump Rated Flow : 790.2 P3 - Pump Pressure @ Max Flow : 67.9 P3 - Pump Max Flow : 1382.9 City Residual Flow @ 0 = 3307.91 City Residual Flow @ 20 = 2576.03 City Water @ 150% of Pump = 43.24 | Demand: D1 - Elevation : 37.571 D2 - System Flow : _____ D2 - System Pressure : <u>156.367</u> Hose (Adj City) : _____ Hose (Demand) : <u>750</u> D3 - System Demand : 750 Safety Margin : 5.795 |
|--|--|--|



Fittings Used Summary

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science SP 1-2 [750 GPM]

Page 3
 Date 9-25-11

Fitting Legend

| Abbrev. | Name | ½ | ¾ | 1 | 1¼ | 1½ | 2 | 2½ | 3 | 3½ | 4 | 5 | 6 | 8 | 10 | 12 | 14 | 16 | 18 | 20 | 24 |
|---------|-------------------------|--|---|------|----|-----|-----|----|----|----|----|-----|----|----|----|----|----|----|----|-----|-----|
| B | Generic Butterfly Valve | 0 | 0 | 2.25 | 2 | 2.5 | 6 | 7 | 10 | 0 | 12 | 9 | 10 | 12 | 19 | 21 | 0 | 0 | 0 | 0 | 0 |
| C | Generic Check Vlv | 4 | 5 | 5 | 7 | 9 | 11 | 14 | 16 | 19 | 22 | 27 | 32 | 45 | 55 | 65 | 76 | 87 | 98 | 109 | 130 |
| E | 90' Standard Elbow | 2 | 2 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 10 | 12 | 14 | 18 | 22 | 27 | 35 | 40 | 45 | 50 | 61 |
| G | Generic Gate Valve | 0 | 0 | 0 | 1 | 0 | 1 | 1 | 1 | 1 | 2 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 10 | 11 | 13 |
| I | 90' Ell Grvd-Vic #10 | 0 | 0 | 2 | 3 | 4 | 3.5 | 6 | 5 | 8 | 7 | 8.5 | 10 | 13 | 17 | 20 | 23 | 25 | 33 | 36 | 40 |
| T | 90' Flow Thru Tee | 3 | 4 | 5 | 6 | 8 | 10 | 12 | 15 | 17 | 20 | 25 | 30 | 35 | 50 | 60 | 71 | 81 | 91 | 101 | 121 |
| Zic | Wilkens 350ADA | Fitting generates a Fixed Loss Based on Flow | | | | | | | | | | | | | | | | | | | |

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Pressure / Flow Summary - STANDARD

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science SP 1-2 [750 GPM]

Page 4
 Date 9-25-11

| Node No. | Elevation | K-Fact | Pt Actual | Pn | Flow Actual | Density | Area | Press Req. |
|----------|-----------|--------|-----------|----|-------------|---------|------|------------|
| HV1 | 99.75 | | 100.0 | na | 250.0 | | | |
| HV2 | 99.75 | | 100.0 | na | 250.0 | | | |
| SPRF | 99.75 | | 104.39 | na | | | | |
| SP16 | 85.0 | | 111.46 | na | | | | |
| SP15 | 69.0 | | 118.55 | na | | | | |
| SP14 | 53.0 | | 125.63 | na | | | | |
| SP13 | 37.0 | | 132.94 | na | | | | |
| HV3 | 101.0 | | 100.93 | na | 250.0 | | | |
| SPR3 | 101.0 | | 108.22 | na | | | | |
| SP36 | 85.0 | | 115.2 | na | | | | |
| SP35 | 69.0 | | 122.17 | na | | | | |
| SP34 | 53.0 | | 129.14 | na | | | | |
| SP33 | 37.0 | | 136.12 | na | | | | |
| SP32 | 21.0 | | 143.15 | na | | | | |
| SP05 | 29.167 | | 139.61 | na | | | | |
| SP01 | 45.0 | | 129.47 | na | | | | |
| SP02 | 27.917 | | 137.89 | na | | | | |
| SP03 | 29.167 | | 139.84 | na | | | | |
| SP04 | 28.083 | | 141.71 | na | | | | |
| SPC1 | 12.667 | | 150.43 | na | | | | |
| SPC2 | 12.667 | | 151.22 | na | | | | |
| PO | 1.833 | | 156.37 | na | | | | |
| PI | 1.75 | | 49.6 | na | | | | |
| POC | 6.75 | | 47.8 | na | | | | |
| BF1 | 13.0 | | 45.43 | na | | | | |
| BF2 | 13.0 | | 49.97 | na | | | | |
| SRC | 13.0 | | 50.53 | na | | | | |

The maximum velocity is 16.75 and it occurs in the pipe between nodes HV1 and SPRF

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science SP 1-2 [750 GPM]

Page 5
 Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|---|------------------|-----------|-----------------|------------|-----------------------|--------------|-------------------------|----------------|-------------------|-------|------------------------------------|------------|
| *S/P # 1 REMOTE ROOF HOSE VALVES | | | | | | | | | | | | |
| HV1 to SPRF | 99.750 99.750 | H250 | 250.00 250.0 | 2.5 | 1T | 12.0 0.0 | 0.250 12.000 | 120 | 100.000 1.750 | | | |
| | | | 0.0 | | | | 12.250 | 0.2154 | 2.639 | | * Fixed loss = 1.75 Vel = 16.75 | |
| SPRF | | | 250.00 | | | | | | 104.389 | | K Factor = 24.47 | |
| HV2 to SPRF | 99.750 99.750 | H250 | 250.00 250.0 | 2.5 | 1T | 12.0 0.0 | 0.250 12.000 | 120 | 100.000 1.750 | | | |
| | | | 0.0 | | | | 12.250 | 0.2154 | 2.639 | | * Fixed loss = 1.75 Vel = 16.75 | |
| SPRF to SP16 | 99.750 85 | | 250.00 500.0 | 6 | 4I | 40.0 0.0 | 30.000 40.000 | 120 | 104.389 6.388 | | | Vel = 5.55 |
| SP16 to SP15 | 85 69 | | 0.0 500.0 | 6 | | 0.0 0.0 | 16.000 0.0 | 120 | 111.460 6.930 | | | Vel = 5.55 |
| SP15 to SP14 | 69 53 | | 0.0 500.0 | 6 | | 0.0 0.0 | 16.000 0.0 | 120 | 118.546 6.930 | | | Vel = 5.55 |
| SP14 to SP01 | 53 45 | | 0.0 500.0 | 6 | 1T | 30.0 0.0 | 8.500 30.000 | 120 | 125.632 3.465 | | | Vel = 5.55 |
| SP01 | | | 0.0 | | | | 38.500 | 0.0097 | 0.375 | | | |
| SP01 | | | 500.00 | | | | | | 129.472 | | K Factor = 43.94 | |
| SP13 to SP01 | 37 45 | .0 | 0.0 0.0 | 6 | 1T | 30.0 0.0 | 7.500 30.000 | 120 | 132.937 -3.465 | | | Vel = 0 |
| SP01 | | | 0.0 | | | | | | 129.472 | | K Factor = 0 | |
| *S/P # 3 | | | | | | | | | | | | |
| HV3 to SPR3 | 101 101 | H250 | 250.00 250.0 | 2.5 | 2E 1T | 12.0 12.0 | 1.750 24.000 | 120 | 100.928 1.750 | | | |
| | | | 0.0 | | | | 25.750 | 0.2154 | 5.547 | | * Fixed loss = 1.75 Vel = 16.75 | |
| SPR3 to SP36 | 101 85 | | 0.0 250.0 | 6 | | 0.0 0.0 | 16.000 0.0 | 120 | 108.225 6.930 | | | Vel = 2.78 |
| SP36 to SP35 | 85 69 | | 0.0 250.0 | 6 | | 0.0 0.0 | 16.000 0.0 | 120 | 115.198 6.930 | | | Vel = 2.78 |
| SP35 to SP34 | 69 53 | | 0.0 250.0 | 6 | | 0.0 0.0 | 16.000 0.0 | 120 | 122.170 6.930 | | | Vel = 2.78 |
| SP34 to SP33 | 53 37 | | 0.0 250.0 | 6 | | 0.0 0.0 | 16.000 0.0 | 120 | 129.143 6.930 | | | Vel = 2.78 |
| SP33 to SP05 | 37 29.167 | | 0.0 250.0 | 6 | 1T | 30.0 0.0 | 8.417 30.000 | 120 | 136.116 3.392 | | | Vel = 2.78 |
| SP05 | | | 0.0 | | | | 38.417 | 0.0027 | 0.105 | | | |

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science SP 1-2 [750 GPM]

Page 6
 Date 9-25-11


| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|--------------------------|------------------|-----------|---------------|------------|-----------------------|---------------------------|------------------------------|----------------|---------------------------|-------|---------------------|-------|
| SP05 | | | 0.0 250.00 | | | | | | 139.613 | | K Factor = 21.16 | |
| SP32 to SP05 | 21 29.167 | .0 | 0.0 | 6 | 1T | 30.0 0.0 | 7.583 30.000 | 120 | 143.150 -3.537 | | | |
| SP05 to SP03 | 29.167 29.167 | | 0.0 | 6.065 | | 0.0 | 37.583 | 0 | 0.0 | | Vel = 0 | |
| SP05 to SP03 | 29.167 29.167 | | 250.00 | 6 | 1I 1B 1T | 10.0 10.0 30.0 | 34.167 50.000 84.167 | 120 | 139.613 0.0 0.228 | | Vel = 2.78 | |
| SP03 | | | 0.0 250.00 | | | | | | 139.841 | | K Factor = 21.14 | |
| *STANDPIPE FEED | | | | | | | | | | | | |
| SP01 to SP02 | 45 27.917 | | 500.00 | 6 | 1B 6I | 10.0 60.0 | 34.417 70.000 | 120 | 129.472 7.399 | | | |
| SP02 to SP03 | 27.917 29.167 | | 500.0 | 6.065 | | 0.0 | 104.417 | 0.0098 | 1.019 | | Vel = 5.55 | |
| SP02 to SP03 | 27.917 29.167 | | 0.0 | 6 | 2I | 20.0 0.0 | 235.417 20.000 | 120 | 137.890 -0.541 | | | |
| SP03 to SP04 | 29.167 28.083 | | 500.0 | 6.065 | | 0.0 | 255.417 | 0.0098 | 2.492 | | Vel = 5.55 | |
| SP03 to SP04 | 29.167 28.083 | | 250.00 | 6 | 4I | 40.0 0.0 | 27.500 40.000 | 120 | 139.841 0.469 | | | |
| SP04 to SPC1 | 28.083 12.667 | | 750.0 | 6.065 | | 0.0 | 67.500 | 0.0207 | 1.395 | | Vel = 8.33 | |
| SP04 to SPC1 | 28.083 12.667 | | 0.0 | 6 | 2I | 20.0 0.0 | 79.330 20.000 | 120 | 141.705 6.677 | | | |
| SPC1 to SPC2 | 12.667 12.667 | | 750.0 | 6.065 | | 0.0 | 99.330 | 0.0206 | 2.051 | | Vel = 8.33 | |
| SPC1 to SPC2 | 12.667 12.667 | | 0.0 | 6 | 1T | 30.0 0.0 | 7.833 30.000 | 120 | 150.433 0.0 | | | |
| SPC2 to PO | 12.667 1.833 | | 750.0 | 6.065 | | 0.0 | 37.833 | 0.0207 | 0.782 | | Vel = 8.33 | |
| SPC2 to PO | 12.667 1.833 | | 0.0 | 8 | 1I 1B 1C | 13.0 12.0 45.0 | 14.750 70.000 84.750 | 120 | 151.215 4.692 0.460 | | Vel = 4.81 | |
| PO | | | 0.0 750.00 | | | | | | 156.367 | | K Factor = 59.98 | |
| System Demand Pressure | | | | | | 156.367 | | | | | | |
| Safety Margin | | | | | | 5.795 | | | | | | |
| Continuation Pressure | | | | | | 162.162 | | | | | | |
| Pressure @ Pump Outlet | | | | | | 162.162 | | | | | | |
| Pressure From Pump Curve | | | | | | -112.559 | | | | | | |
| Pressure @ Pump Inlet | | | | | | 49.603 | | | | | | |
| PI to POC | 1.750 6.750 | | 0.0 | 8 | 1G 1I 1T | 4.0 13.0 35.0 | 14.000 52.000 66.000 | 120 | 49.603 -2.166 0.359 | | Vel = 4.81 | |
| POC to BF1 | 6.750 13 | | 750.0 | 7.981 | | 0.0 | 66.000 | 0.0054 | 0.359 | | | |
| POC to BF1 | 6.750 13 | | 0.0 | 8 | 2E | 56.936 0.0 | 41.000 56.936 | 140 | 47.796 -2.707 | | | |
| BF1 to BF2 | 13 13 | | 750.0 | 8.27 | | 0.0 | 97.936 | 0.0034 | 0.336 | | Vel = 4.48 | |
| BF1 to BF2 | 13 13 | | 0.0 | 8 | 1Zic | 0.0 0.0 | 4.000 0.0 | 120 | 45.425 4.520 | | * Fixed loss = 4.52 | |
| BF2 to SRC | 13 13 | | 750.0 | 7.981 | | 0.0 | 4.000 | 0.0055 | 0.022 | | Vel = 4.81 | |
| BF2 to SRC | 13 13 | | 0.0 | 8 | 2E 1G 1T | 56.936 6.326 55.354 | 46.000 118.616 164.616 | 140 | 49.967 0.0 0.565 | | Vel = 4.48 | |

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science SP 1-2 [750 GPM]

Page 7
 Date 9-25-11

| Node1 | Elev1 | K | Qa | Nom | Fitting | | Pipe | CFact | Pt | | | |
|-------|-------|------|--------|-----|---------|-----|--------|-------|--------|-------|-------------------|-------|
| to | | | | | or | | Ftng's | | Pe | ***** | Notes | ***** |
| Node2 | Elev2 | Fact | Qt | Act | Eqv. | Ln. | Total | Pf/Ft | Pf | | | |
| | | | 0.0 | | | | | | | | | |
| SRC | | | 750.00 | | | | | | 50.532 | | K Factor = 105.51 | |



Standpipe # 4 [1000]

This page intentionally left blank.



**AUTOMATIC
SPRINKLER CO.**

21605 North Central Ave. 623.580.7800
Phoenix, Arizona 85024 Fax 623.434.3154

AZ-L16-234798 CA-C16-901529
AZ-C16-234797 NV-C41-69370
UT-S370-6690455-5501 NM-MS 12-354807



Fire Protection by Computer Design

Aero Automatic Sprinkler Co.
21605 N. Central Ave.
Phoenix, Arizona 85024
623-580-7800

Job Name : Cal Poly Center for Science SP 4 [1000 GPM]
Building : Center for Science
Location : San Luis Obispo, Ca.
System : S/P # 4
Contract : 10034
Data File : Cal Poly CFS SP 1-3.WXF

HYDRAULIC DESIGN INFORMATION SHEET

Name - Cal Poly Center For Science Date - 9-25-2011
 Location - San Luis Obispo, Ca.
 Building - Center for Science System No. - S/P # 4
 Contractor - Aero Automatic Sprinkler Co. Contract No. - 10034
 Calculated By - Neal Larsen Drawing No. -
 Occupancy - Light / Ordinary Hazard Gr. 1

S (X)NFPA 14 Number of Standpipes ()1 ()2 ()3 (X)4 ()
 Y ()Other
 S ()Specific Ruling Made by Date

T
 E Flow at Top Most Outlet - 500 Gpm System Type
 M Pres. at Top Most Outlet - 100 Psi (X) Wet () Dry
 Flow For Ea. Additional Standpipe - 500 Gpm
 D Total Additional Flow - 1000 Gpm
 E Elevation at Highest Outlet - 67'-9" Feet
 S Hose Valve Connection ()1 1/2" (X)2 1/2"
 I Class Service (X)I ()II (X)III
 G Note:At 5 th level (Roof) there are three (3) standpipes available.
 N {Standpipe # 1, 3 & 4}

Calculation Gpm Required 1000 Psi Required 45.85 At SRC
 Summary C-Factor Used: Overhead 120 Underground 140

W Water Flow Test: Pump Data: Tank or Reservoir:
 A Date of Test - 9-19-2011 Cap. N/A
 T Time of Test - 9:12 a.m. Rated Cap. 750 Elev. N/A
 E Static (Psi) - 60 [54] @ Psi 113
 R Residual (Psi) - 55 [49] Elev. 1'-9" Well
 Flow (Gpm) - 914 Proof Flow Gpm N/A
 S Elevation - 13'-0"


U
 P Location: Static & Residual pressures taken from Hydrant # 63. Flow taken
 P from Hydrant # 64 along N. Poly View Drive
 L Source of Information: Fluid Resource Management {R. Ellison}
 Y Note : Flow test used in Hyd. Calculations was reduced by 10 %.

Water Supply Curve (C)

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science SP 4 [1000 GPM]

Page 2
 Date 9-25-11

| | | |
|---|--|--|
| City Water Supply: C1 - Static Pressure : 54 C2 - Residual Pressure: 49 C2 - Residual Flow : 914 City Water Adjusted to Pump Inlet for Pf - Elev - Hose Flow A1 - Adjusted Static: 51.872 A2 - Adj Resid : 49.314 @ 790.2 A3 - Adj Resid : 40.224 @ 1382.9 | Pump Data: P1 - Pump Churn Pressure : 125.2 P2 - Pump Rated Pressure : 110.9 P2 - Pump Rated Flow : 790.2 P3 - Pump Pressure @ Max Flow : 67.9 P3 - Pump Max Flow : 1382.9 City Residual Flow @ 0 = 3307.91 City Residual Flow @ 20 = 2576.03 City Water @ 150% of Pump = 43.24 | Demand: D1 - Elevation : 23.712 D2 - System Flow : _____ D2 - System Pressure : 142.748 Hose (Adj City) : _____ Hose (Demand) : 1000 D3 - System Demand : 1000 Safety Margin : 2.244 |
|---|--|--|



Fittings Used Summary

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science SP 4 [1000 GPM]

Page 3
 Date 9-25-11

Fitting Legend

| Abbrev. | Name | ½ | ¾ | 1 | 1¼ | 1½ | 2 | 2½ | 3 | 3½ | 4 | 5 | 6 | 8 | 10 | 12 | 14 | 16 | 18 | 20 | 24 |
|---------|-------------------------|--|---|------|----|-----|-----|----|----|----|----|-----|----|----|----|----|----|----|----|-----|-----|
| B | Generic Butterfly Valve | 0 | 0 | 2.25 | 2 | 2.5 | 6 | 7 | 10 | 0 | 12 | 9 | 10 | 12 | 19 | 21 | 0 | 0 | 0 | 0 | 0 |
| C | Generic Check Vlv | 4 | 5 | 5 | 7 | 9 | 11 | 14 | 16 | 19 | 22 | 27 | 32 | 45 | 55 | 65 | 76 | 87 | 98 | 109 | 130 |
| E | 90' Standard Elbow | 2 | 2 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 10 | 12 | 14 | 18 | 22 | 27 | 35 | 40 | 45 | 50 | 61 |
| G | Generic Gate Valve | 0 | 0 | 0 | 1 | 0 | 1 | 1 | 1 | 1 | 2 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 10 | 11 | 13 |
| I | 90' Ell Grvd-Vic #10 | 0 | 0 | 2 | 3 | 4 | 3.5 | 6 | 5 | 8 | 7 | 8.5 | 10 | 13 | 17 | 20 | 23 | 25 | 33 | 36 | 40 |
| T | 90' Flow Thru Tee | 3 | 4 | 5 | 6 | 8 | 10 | 12 | 15 | 17 | 20 | 25 | 30 | 35 | 50 | 60 | 71 | 81 | 91 | 101 | 121 |
| Zic | Wilkens 350ADA | Fitting generates a Fixed Loss Based on Flow | | | | | | | | | | | | | | | | | | | |

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Pressure / Flow Summary - STANDARD

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science SP 4 [1000 GPM]

Page 4
 Date 9-25-11

| Node No. | Elevation | K-Fact | Pt Actual | Pn | Flow Actual | Density | Area | Press Req. |
|----------|-----------|--------|-----------|----|-------------|---------|------|------------|
| HV1 | 99.75 | | 93.26 | na | 250.0 | | | |
| HV2 | 99.75 | | 95.9 | na | | | | |
| SPRF | 99.75 | | 97.65 | na | | | | |
| SP16 | 85.0 | | 104.23 | na | | | | |
| SP15 | 69.0 | | 111.2 | na | | | | |
| SP14 | 53.0 | | 118.17 | na | | | | |
| SP13 | 37.0 | | 125.21 | na | | | | |
| HV3 | 99.0 | | 97.58 | na | | | | |
| SPR3 | 99.0 | | 99.33 | na | | | | |
| SP36 | 85.0 | | 105.39 | na | | | | |
| SP35 | 69.0 | | 112.32 | na | | | | |
| SP34 | 53.0 | | 119.25 | na | | | | |
| SP33 | 37.0 | | 126.18 | na | | | | |
| SP32 | 21.0 | | 133.11 | na | | | | |
| SP05 | 29.167 | | 129.57 | na | | | | |
| HV8 | 67.75 | | 100.0 | na | 250.0 | | | |
| HV9 | 67.75 | | 100.0 | na | 250.0 | | | |
| SPR4 | 67.75 | | 104.39 | na | | | | |
| SP44 | 53.0 | | 111.84 | na | | | | |
| SP43 | 37.0 | | 119.91 | na | | | | |
| SP42 | 21.0 | | 127.99 | na | | | | |
| SP41 | 5.0 | | 136.88 | na | | | | |
| HV10 | 37.0 | | 111.24 | na | 250.0 | | | |
| SP53 | 37.0 | | 118.54 | na | | | | |
| HV11 | 21.0 | | 124.04 | na | | | | |
| SP52 | 21.0 | | 125.79 | na | | | | |
| SP51 | 5.0 | | 133.28 | na | | | | |
| SPC5 | 12.5 | | 130.04 | na | | | | |
| SPC4 | 13.75 | | 133.09 | na | | | | |
| SPC3 | 12.667 | | 134.08 | na | | | | |
| SP01 | 45.0 | | 121.74 | na | | | | |
| SP02 | 27.917 | | 129.42 | na | | | | |
| SP03 | 29.167 | | 129.57 | na | | | | |
| SP04 | 28.083 | | 130.22 | na | | | | |
| SPC1 | 12.667 | | 137.17 | na | | | | |
| SPC2 | 12.667 | | 137.27 | na | | | | |
| PO | 1.833 | | 142.75 | na | | | | |
| PI | 1.75 | | 46.96 | na | | | | |
| POC | 6.75 | | 45.4 | na | | | | |
| BF1 | 13.0 | | 43.27 | na | | | | |
| BF2 | 13.0 | | 47.13 | na | | | | |
| SRC | 13.0 | | 48.09 | na | | | | |

The maximum velocity is 16.75 and it occurs in the pipe between nodes HV1 and SPRF

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science SP 4 [1000 GPM]

Page 5
 Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|----------------------------------|----------------|-----------|----------|------------|-----------------------|------|-------------------------|----------------|----------------|-------|---------------------|-------|
| *S/P # 1 REMOTE ROOF HOSE VALVES | | | | | | | | | | | | |
| HV1 | 99.750 | H250 | 250.00 | 2.5 | 1T | 12.0 | 0.250 | 120 | 93.260 | | | |
| to | | | | | | 0.0 | 12.000 | | 1.750 | | * Fixed loss = 1.75 | |
| SPRF | 99.750 | | 250.0 | 2.469 | | 0.0 | 12.250 | 0.2154 | 2.639 | | Vel = 16.75 | |
| | | | 0.0 | | | | | | | | | |
| SPRF | | | 250.00 | | | | | | 97.649 | | K Factor = 25.30 | |
| HV2 | 99.750 | .0 | 0.0 | 2.5 | 1T | 12.0 | 0.250 | 120 | 95.899 | | | |
| to | | | | | | 0.0 | 12.000 | | 1.750 | | * Fixed loss = 1.75 | |
| SPRF | 99.750 | | 0.0 | 2.469 | | 0.0 | 12.250 | 0 | 0.0 | | Vel = 0 | |
| SPRF | 99.750 | | 250.00 | 6 | 4I | 40.0 | 30.000 | 120 | 97.649 | | | |
| to | | | | | | 0.0 | 40.000 | | 6.388 | | | |
| SP16 | 85 | | 250.0 | 6.065 | | 0.0 | 70.000 | 0.0027 | 0.190 | | Vel = 2.78 | |
| SP16 | 85 | | 0.0 | 6 | | 0.0 | 16.000 | 120 | 104.227 | | | |
| to | | | | | | 0.0 | 0.0 | | 6.930 | | | |
| SP15 | 69 | | 250.0 | 6.065 | | 0.0 | 16.000 | 0.0027 | 0.043 | | Vel = 2.78 | |
| SP15 | 69 | | 0.0 | 6 | | 0.0 | 16.000 | 120 | 111.200 | | | |
| to | | | | | | 0.0 | 0.0 | | 6.930 | | | |
| SP14 | 53 | | 250.0 | 6.065 | | 0.0 | 16.000 | 0.0026 | 0.042 | | Vel = 2.78 | |
| SP14 | 53 | | 0.0 | 6 | 1T | 30.0 | 8.500 | 120 | 118.172 | | | |
| to | | | | | | 0.0 | 30.000 | | 3.465 | | | |
| SP01 | 45 | | 250.0 | 6.065 | | 0.0 | 38.500 | 0.0027 | 0.104 | | Vel = 2.78 | |
| | | | 0.0 | | | | | | | | | |
| SP01 | | | 250.00 | | | | | | 121.741 | | K Factor = 22.66 | |
| SP13 | 37 | .0 | 0.0 | 6 | 1T | 30.0 | 7.500 | 120 | 125.206 | | | |
| to | | | | | | 0.0 | 30.000 | | -3.465 | | | |
| SP01 | 45 | | 0.0 | 6.065 | | 0.0 | 37.500 | 0 | 0.0 | | Vel = 0 | |
| | | | 0.0 | | | | | | | | | |
| SP01 | | | 0.0 | | | | | | 121.741 | | K Factor = 0 | |
| *S/P # 3 | | | | | | | | | | | | |
| HV3 | 99 | .0 | 0.0 | 2.5 | 2E | 12.0 | 1.750 | 120 | 97.578 | | | |
| to | | | | | 1T | 12.0 | 24.000 | | 1.750 | | * Fixed loss = 1.75 | |
| SPR3 | 99 | | 0.0 | 2.469 | | 0.0 | 25.750 | 0 | 0.0 | | Vel = 0 | |
| SPR3 | 99 | .0 | 0.0 | 6 | | 0.0 | 16.000 | 120 | 99.328 | | | |
| to | | | | | | 0.0 | 0.0 | | 6.063 | | | |
| SP36 | 85 | | 0.0 | 6.065 | | 0.0 | 16.000 | 0 | 0.0 | | Vel = 0 | |
| SP36 | 85 | .0 | 0.0 | 6 | | 0.0 | 16.000 | 120 | 105.391 | | | |
| to | | | | | | 0.0 | 0.0 | | 6.930 | | | |
| SP35 | 69 | | 0.0 | 6.065 | | 0.0 | 16.000 | 0 | 0.0 | | Vel = 0 | |
| SP35 | 69 | .0 | 0.0 | 6 | | 0.0 | 16.000 | 120 | 112.321 | | | |
| to | | | | | | 0.0 | 0.0 | | 6.930 | | | |
| SP34 | 53 | | 0.0 | 6.065 | | 0.0 | 16.000 | 0 | 0.0 | | Vel = 0 | |
| SP34 | 53 | .0 | 0.0 | 6 | | 0.0 | 16.000 | 120 | 119.251 | | | |
| to | | | | | | 0.0 | 0.0 | | 6.930 | | | |
| SP33 | 37 | | 0.0 | 6.065 | | 0.0 | 16.000 | 0 | 0.0 | | Vel = 0 | |
| SP33 | 37 | .0 | 0.0 | 6 | 1T | 30.0 | 8.417 | 120 | 126.180 | | | |
| to | | | | | | 0.0 | 30.000 | | 3.392 | | | |
| SP05 | 29.167 | | 0.0 | 6.065 | | 0.0 | 38.417 | 0 | 0.0 | | Vel = 0 | |

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
Cal Poly Center for Science SP 4 [1000 GPM]

Page 6
Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|----------------------|------------------|-----------|-----------------|--------------|-----------------------|----------------------|----------------------------|----------------|-----------------------|-------|------------------------------------|-------|
| SP05 | | | 0.0 0.0 | | | | | | 129.572 | | K Factor = 0 | |
| SP32 to SP05 | 21 29.167 | .0 | 0.0 0.0 | 6 6.065 | 1T | 30.0 0.0 | 7.583 30.000 | 120 0 | 133.110 -3.537 | | Vel = 0 | |
| SP05 to SP03 | 29.167 29.167 | .0 | 0.0 0.0 | 6 6.065 | 1I 1B 1T | 10.0 10.0 30.0 | 34.167 50.000 84.167 | 120 0 | 129.573 0.0 0.0 | | Vel = 0 | |
| SP03 | | | 0.0 0.0 | | | | | | 129.573 | | K Factor = 0 | |
| *S/P # 4 | | | | | | | | | | | | |
| HV8 to SPR4 | 67.750 67.750 | H250 | 250.00 250.0 | 2.5 2.469 | 1T | 12.0 0.0 | 0.250 12.000 | 120 0.2154 | 100.000 1.750 | | * Fixed loss = 1.75 Vel = 16.75 | |
| SPR4 | | | 0.0 250.00 | | | | | | 104.389 | | K Factor = 24.47 | |
| HV9 to SPR4 | 67.750 67.750 | H250 | 250.00 250.0 | 2.5 2.469 | 1T | 12.0 0.0 | 0.250 12.000 | 120 0.2154 | 100.000 1.750 | | * Fixed loss = 1.75 Vel = 16.75 | |
| SPR4 to SP44 | 67.750 53 | | 250.00 500.0 | 4 4.026 | | 0.0 0.0 | 14.750 0.0 | 120 0.0718 | 104.389 6.388 | | Vel = 12.60 | |
| SP44 to SP43 | 53 37 | | 0.0 500.0 | 4 4.026 | | 0.0 0.0 | 16.000 0.0 | 120 0.0718 | 111.836 6.930 | | Vel = 12.60 | |
| SP43 to SP42 | 37 21 | | 0.0 500.0 | 4 4.026 | | 0.0 0.0 | 16.000 0.0 | 120 0.0718 | 119.914 6.930 | | Vel = 12.60 | |
| SP42 to SPC4 | 21 13.750 | | 0.0 500.0 | 4 4.026 | 1T | 20.0 0.0 | 7.250 20.000 | 120 0.0718 | 127.992 3.140 | | Vel = 12.60 | |
| SPC4 | | | 0.0 500.00 | | | | | | 133.088 | | K Factor = 43.34 | |
| SP41 to SPC4 | 5 13.750 | .0 | 0.0 0.0 | 4 4.026 | 1T | 20.0 0.0 | 8.750 20.000 | 120 0 | 136.878 -3.790 | | Vel = 0 | |
| SPC4 | | | 0.0 0.0 | | | | | | 133.088 | | K Factor = 0 | |
| *S/P # 5 | | | | | | | | | | | | |
| HV10 to SP53 | 37 37 | H250 | 250.00 250.0 | 2.5 2.469 | 2E 1T | 12.0 12.0 | 1.750 24.000 | 120 0.2154 | 111.241 1.750 | | * Fixed loss = 1.75 Vel = 16.75 | |
| SP53 to SP52 | 37 21 | | 0.0 250.0 | 4 4.026 | | 0.0 0.0 | 16.000 0.0 | 120 0.0199 | 118.538 6.930 | | Vel = 6.30 | |
| SP52 | | | 0.0 250.00 | | | | | | 125.786 | | K Factor = 22.29 | |

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science SP 4 [1000 GPM]

Page 7
 Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|--------------------------|------------------|-----------|------------------|--------------|-----------------------|----------------------|------------------------------|----------------|----------------------------|-------|--------------------------------|-------|
| HV11 to SP52 | 21 21 | .0 | 0.0 0.0 | 2.5 2.469 | 2E 1T | 12.0 12.0 0.0 | 1.750 24.000 25.750 | 120 0 | 124.036 1.750 0.0 | | * Fixed loss = 1.75 Vel = 0 | |
| SP52 to SPC5 | 21 12.500 | | 250.00 250.0 | 4 | 1T | 20.0 0.0 0.0 | 8.500 20.000 28.500 | 120 0.0199 | 125.786 3.681 0.568 | | Vel = 6.30 | |
| SPC5 | | | 0.0 250.00 | | | | | | 130.035 | | K Factor = 21.92 | |
| SP51 to SPC5 | 5 12.500 | .0 | 0.0 0.0 | 4 | 1T | 20.0 0.0 0.0 | 7.500 20.000 27.500 | 120 0 | 133.283 -3.248 0.0 | | Vel = 0 | |
| SPC5 | | | 0.0 0.0 | | | | | | 130.035 | | K Factor = 0 | |
| *STANDPIPES # 4 & 5 FEED | | | | | | | | | | | | |
| SPC5 to SPC3 | 12.500 12.667 | | 250.00 250.0 | 4 | 1B 5I 1T | 12.0 35.0 20.0 | 139.667 67.000 206.667 | 120 0.0199 | 130.035 -0.072 4.114 | | Vel = 6.30 | |
| SPC3 | | | 0.0 250.00 | | | | | | 134.077 | | K Factor = 21.59 | |
| SPC4 to SPC3 | 13.750 12.667 | | 500.00 500.0 | 6 | 3I 1B | 30.0 10.0 0.0 | 13.333 40.000 53.333 | 120 0.0098 | 133.088 0.469 0.520 | | Vel = 5.55 | |
| SPC3 to SPC2 | 12.667 12.667 | | 250.00 750.0 | 6 | 2I 1T | 20.0 30.0 0.0 | 104.667 50.000 154.667 | 120 0.0207 | 134.077 0.0 3.196 | | Vel = 8.33 | |
| SPC2 | | | 0.0 750.00 | | | | | | 137.273 | | K Factor = 64.01 | |
| *STANDPIPES # 1 & 3 FEED | | | | | | | | | | | | |
| SP01 to SP02 | 45 27.917 | | 250.00 250.0 | 6 | 6I 1B | 60.0 10.0 0.0 | 34.417 70.000 104.417 | 120 0.0027 | 121.741 7.399 0.283 | | Vel = 2.78 | |
| SP02 to SP03 | 27.917 29.167 | | 0.0 250.0 | 6 | 2I | 20.0 0.0 0.0 | 235.417 20.000 255.417 | 120 0.0027 | 129.423 -0.541 0.691 | | Vel = 2.78 | |
| SP03 to SP04 | 29.167 28.083 | | 0.0 250.0 | 6 | 4I | 40.0 0.0 0.0 | 27.500 40.000 67.500 | 120 0.0027 | 129.573 0.469 0.183 | | Vel = 2.78 | |
| SP04 to SPC1 | 28.083 12.667 | | 0.0 250.0 | 6 | 2I | 20.0 0.0 0.0 | 79.330 20.000 99.330 | 120 0.0027 | 130.225 6.677 0.268 | | Vel = 2.78 | |
| SPC1 to SPC2 | 12.667 12.667 | | 0.0 250.0 | 6 | 1T | 30.0 0.0 0.0 | 7.833 30.000 37.833 | 120 0.0027 | 137.170 0.0 0.103 | | Vel = 2.78 | |
| SPC2 to PO | 12.667 1.833 | | 750.00 1000.0 | 8 | 1I 1B 1C | 13.0 12.0 45.0 | 14.750 70.000 84.750 | 120 0.0092 | 137.273 4.692 0.783 | | Vel = 6.41 | |
| | | | 0.0 | | | | | | | | | |


Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science SP 4 [1000 GPM]

Page 8
 Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|--------------------------|----------------|-----------|----------------|------------|-----------------------|-----------------|-------------------------|----------------|------------------|-------|------------------------------------|-------|
| PO | | | 1000.00 | | | | | | 142.748 | | K Factor = 83.70 | |
| System Demand Pressure | | | | | | | 142.748 | | | | | |
| Safety Margin | | | | | | | 2.244 | | | | | |
| Continuation Pressure | | | | | | | 144.992 | | | | | |
| Pressure @ Pump Outlet | | | | | | | 144.992 | | | | | |
| Pressure From Pump Curve | | | | | | | -98.033 | | | | | |
| Pressure @ Pump Inlet | | | | | | | 46.959 | | | | | |
| PI to POC | 1.750 6.750 | | 0.0 1000.0 | 8 7.981 | 1G 1I | 4.0 13.0 | 14.000 52.000 | 120 | 46.959 -2.166 | | Vel = 6.41 | |
| POC to BF1 | 6.750 13 | | 0.0 1000.0 | 8 8.27 | 2E | 56.936 0.0 | 41.000 56.936 | 140 | 45.403 -2.707 | | Vel = 5.97 | |
| BF1 to BF2 | 13 13 | | 0.0 1000.0 | 8 7.981 | 1Zic | 0.0 0.0 | 4.000 0.0 | 120 | 43.268 3.829 | | * Fixed loss = 3.829 Vel = 6.41 | |
| BF2 to SRC | 13 13 | | 0.0 1000.0 | 8 8.27 | 2E 1G | 56.936 6.326 | 46.000 118.616 | 140 | 47.134 0.0 | | Vel = 5.97 | |
| SRC | | | 0.0 1000.00 | | | | | | 48.095 | | K Factor = 144.19 | |

This page intentionally left blank.



Standpipe # 5 [1000]

This page intentionally left blank.



**AUTOMATIC
SPRINKLER CO.**

21605 North Central Ave. 623.580.7800
Phoenix, Arizona 85024 Fax 623.434.3154

AZ-L16-234798 CA-C16-901529
AZ-C16-234797 NV-C41-69370
UT-S370-6690455-5501 NM-MS 12-354807



Fire Protection by Computer Design

Aero Automatic Sprinkler Co.
21605 N. Central Ave.
Phoenix, Arizona 85024
623-580-7800

Job Name : Cal Poly Center for Science SP 5 [1000 GPM]
Building : Center for Science
Location : San Luis Obispo, Ca.
System : S/P # 5
Contract : 10034
Data File : Cal Poly CFS SP 1-4.WXF

HYDRAULIC DESIGN INFORMATION SHEET

Name - Cal Poly Center For Science Date - 9-25-2011
 Location - San Luis Obispo, Ca.
 Building - Center for Science System No. - S/P # 5
 Contractor - Aero Automatic Sprinkler Co. Contract No. - 10034
 Calculated By - Neal Larsen Drawing No. -
 Occupancy - Light / Ordinary Hazard Gr. 1

S (X)NFPA 14 Number of Standpipes ()1 ()2 ()3 (X)4 ()

Y ()Other

S ()Specific Ruling Made by Date

T

| | | | | |
|---|--|-----------|-----------|-----------------|
| E | Flow at Top Most Outlet | - 500 | Gpm | System Type |
| M | Pres. at Top Most Outlet | - 100 | Psi | (X) Wet () Dry |
| | Flow For Ea. Additional Standpipe | - 500 | Gpm | |
| D | Total Additional Flow | - 1000 | Gpm | |
| E | Elevation at Highest Outlet | - 37'-0" | Feet | |
| S | Hose Valve Connection | ()1 1/2" | (X)2 1/2" | |
| I | Class Service | (X)I | ()II | (X)III |
| G | Note:At 3 rd. level there are four (4) standpipes available. | | | |
| N | {Standpipe # 1, 3, 4 & 5} | | | |

| | | | |
|-------------|-------------------|--------------------|-----------------|
| Calculation | Gpm Required 1000 | Psi Required 46.80 | At SRC |
| Summary | C-Factor Used: | Overhead 120 | Underground 140 |

| | | | |
|---|--------------------------|----------------|--------------------|
| W | Water Flow Test: | Pump Data: | Tank or Reservoir: |
| A | Date of Test - 9-19-2011 | | Cap. N/A |
| T | Time of Test - 9:12 a.m. | Rated Cap. 750 | Elev. N/A |
| E | Static (Psi) - 60 [54] | @ Psi 113 | |
| R | Residual (Psi) - 55 [49] | Elev. 1'-9" | Well |
| | Flow (Gpm) - 914 | | Proof Flow Gpm N/A |
| S | Elevation - 13'-0" | | |

U


P Location: Static & Residual pressures taken from Hydrant # 63. Flow taken
 P from Hydrant # 64 along N. Poly View Drive
 L Source of Information: Fluid Resource Management {R. Ellison}
 Y Note : Flow test used in Hyd. Calculations was reduced by 10 %.

Water Supply Curve (C)

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science SP 5 [1000 GPM]

Page 2
 Date 9-25-11

| | | |
|---|--|---|
| City Water Supply: C1 - Static Pressure : 54 C2 - Residual Pressure: 49 C2 - Residual Flow : 914 City Water Adjusted to Pump Inlet for Pf - Elev - Hose Flow A1 - Adjusted Static: 51.872 A2 - Adj Resid : 49.314 @ 790.2 A3 - Adj Resid : 40.224 @ 1382.9 | Pump Data: P1 - Pump Churn Pressure : 125.2 P2 - Pump Rated Pressure : 110.9 P2 - Pump Rated Flow : 790.2 P3 - Pump Pressure @ Max Flow : 67.9 P3 - Pump Max Flow : 1382.9 City Residual Flow @ 0 = 3307.91 City Residual Flow @ 20 = 2576.03 City Water @ 150% of Pump = 43.24 | Demand: D1 - Elevation : 10.394 D2 - System Flow : _____ D2 - System Pressure : <u>143.705</u> Hose (Adj City) : _____ Hose (Demand) : 1000 D3 - System Demand : 1000 Safety Margin : 1.287 |
|---|--|---|



Fittings Used Summary

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science SP 5 [1000 GPM]

Page 3
 Date 9-25-11

Fitting Legend

| Abbrev. | Name | ½ | ¾ | 1 | 1¼ | 1½ | 2 | 2½ | 3 | 3½ | 4 | 5 | 6 | 8 | 10 | 12 | 14 | 16 | 18 | 20 | 24 |
|---------|-------------------------|--|---|------|----|-----|-----|----|----|----|----|-----|----|----|----|----|----|----|----|-----|-----|
| B | Generic Butterfly Valve | 0 | 0 | 2.25 | 2 | 2.5 | 6 | 7 | 10 | 0 | 12 | 9 | 10 | 12 | 19 | 21 | 0 | 0 | 0 | 0 | 0 |
| C | Generic Check Vlv | 4 | 5 | 5 | 7 | 9 | 11 | 14 | 16 | 19 | 22 | 27 | 32 | 45 | 55 | 65 | 76 | 87 | 98 | 109 | 130 |
| E | 90' Standard Elbow | 2 | 2 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 10 | 12 | 14 | 18 | 22 | 27 | 35 | 40 | 45 | 50 | 61 |
| G | Generic Gate Valve | 0 | 0 | 0 | 1 | 0 | 1 | 1 | 1 | 1 | 2 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 10 | 11 | 13 |
| I | 90' Ell Grvd-Vic #10 | 0 | 0 | 2 | 3 | 4 | 3.5 | 6 | 5 | 8 | 7 | 8.5 | 10 | 13 | 17 | 20 | 23 | 25 | 33 | 36 | 40 |
| T | 90' Flow Thru Tee | 3 | 4 | 5 | 6 | 8 | 10 | 12 | 15 | 17 | 20 | 25 | 30 | 35 | 50 | 60 | 71 | 81 | 91 | 101 | 121 |
| Zic | Wilkens 350ADA | Fitting generates a Fixed Loss Based on Flow | | | | | | | | | | | | | | | | | | | |

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Pressure / Flow Summary - STANDARD

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science SP 5 [1000 GPM]

Page 4
 Date 9-25-11

| Node No. | Elevation | K-Fact | Pt Actual | Pn | Flow Actual | Density | Area | Press Req. |
|----------|-----------|--------|-----------|----|-------------|---------|------|------------|
| HV1 | 99.75 | | 94.22 | na | 250.0 | | | |
| HV2 | 99.75 | | 96.86 | na | | | | |
| SPRF | 99.75 | | 98.61 | na | | | | |
| SP16 | 85.0 | | 105.18 | na | | | | |
| SP15 | 69.0 | | 112.16 | na | | | | |
| SP14 | 53.0 | | 119.13 | na | | | | |
| SP13 | 37.0 | | 126.16 | na | | | | |
| HV3 | 99.0 | | 98.54 | na | | | | |
| SPR3 | 99.0 | | 100.28 | na | | | | |
| SP36 | 85.0 | | 106.35 | na | | | | |
| SP35 | 69.0 | | 113.28 | na | | | | |
| SP34 | 53.0 | | 120.21 | na | | | | |
| SP33 | 37.0 | | 127.14 | na | | | | |
| SP32 | 21.0 | | 134.07 | na | | | | |
| SP05 | 29.167 | | 130.53 | na | | | | |
| HV8 | 67.75 | | 105.17 | na | 250.0 | | | |
| HV9 | 67.75 | | 107.81 | na | | | | |
| SPR4 | 67.75 | | 109.56 | na | | | | |
| SP44 | 53.0 | | 116.24 | na | | | | |
| SP43 | 37.0 | | 123.49 | na | | | | |
| SP42 | 21.0 | | 130.74 | na | | | | |
| SP41 | 5.0 | | 138.21 | na | | | | |
| HV10 | 37.0 | | 100.0 | na | 250.0 | | | |
| SP53 | 37.0 | | 107.3 | na | | | | |
| HV11 | 21.0 | | 107.25 | na | 250.0 | | | |
| SP52 | 21.0 | | 114.54 | na | | | | |
| SP51 | 5.0 | | 123.52 | na | | | | |
| SPC5 | 12.5 | | 120.27 | na | | | | |
| SPC4 | 13.75 | | 134.42 | na | | | | |
| SPC3 | 12.667 | | 135.04 | na | | | | |
| SP01 | 45.0 | | 122.7 | na | | | | |
| SP02 | 27.917 | | 130.38 | na | | | | |
| SP03 | 29.167 | | 130.53 | na | | | | |
| SP04 | 28.083 | | 131.18 | na | | | | |
| SPC1 | 12.667 | | 138.13 | na | | | | |
| SPC2 | 12.667 | | 138.23 | na | | | | |
| PO | 1.833 | | 143.71 | na | | | | |
| PI | 1.75 | | 46.96 | na | | | | |
| POC | 6.75 | | 45.4 | na | | | | |
| BF1 | 13.0 | | 43.27 | na | | | | |
| BF2 | 13.0 | | 47.13 | na | | | | |
| SRC | 13.0 | | 48.09 | na | | | | |

The maximum velocity is 16.75 and it occurs in the pipe between nodes HV1 and SPRF

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science SP 5 [1000 GPM]

Page 5
 Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|----------------------------------|------------------|-----------|-----------------|------------|-----------------------|---------------|-------------------------|----------------|-------------------|-------|------------------------------------|-------|
| *S/P # 1 REMOTE ROOF HOSE VALVES | | | | | | | | | | | | |
| HV1 to SPRF | 99.750 99.750 | H250 | 250.00 250.0 | 2.5 | 1T | 12.0 0.0 | 0.250 12.000 | 120 | 94.217 1.750 | | * Fixed loss = 1.75 Vel = 16.75 | |
| SPRF | | | 0.0 250.00 | | | | | | 98.606 | | K Factor = 25.18 | |
| HV2 to SPRF | 99.750 99.750 | .0 | 0.0 0.0 | 2.5 | 1T | 12.0 0.0 | 0.250 12.000 | 120 | 96.856 1.750 | | * Fixed loss = 1.75 Vel = 0 | |
| SPRF | | | 250.00 | 6 | 4I | 40.0 0.0 | 30.000 40.000 | 120 | 98.606 6.388 | | | |
| SP16 to SP15 | 85 69 | | 250.0 0.0 | 6.065 | | 0.0 0.0 | 70.000 16.000 | 0.0027 | 0.190 105.184 | | Vel = 2.78 | |
| SP15 to SP14 | 69 53 | | 0.0 250.0 | 6.065 | | 0.0 0.0 | 16.000 16.000 | 0.0027 | 0.043 112.157 | | Vel = 2.78 | |
| SP14 to SP01 | 53 45 | | 0.0 250.0 | 6 | 1T | 30.0 0.0 | 8.500 30.000 | 120 | 119.130 3.465 | | Vel = 2.78 | |
| SP01 | | | 0.0 250.00 | | | | | | 122.699 | | K Factor = 22.57 | |
| SP13 to SP01 | 37 45 | .0 | 0.0 0.0 | 6 | 1T | 30.0 0.0 | 7.500 30.000 | 120 | 126.163 -3.465 | | Vel = 0 | |
| SP01 | | | 0.0 0.0 | | | | | | 122.698 | | K Factor = 0 | |
| *S/P # 3 | | | | | | | | | | | | |
| HV3 to SPR3 | 99 99 | .0 | 0.0 0.0 | 2.5 | 2E 1T | 12.0 12.0 | 1.750 24.000 | 120 | 98.535 1.750 | | * Fixed loss = 1.75 Vel = 0 | |
| SPR3 to SP36 | 99 85 | .0 | 0.0 0.0 | 6 | | 0.0 0.0 | 16.000 16.000 | 120 | 100.285 6.063 | | Vel = 0 | |
| SP36 to SP35 | 85 69 | .0 | 0.0 0.0 | 6.065 | | 0.0 0.0 | 16.000 16.000 | 0 | 0.0 106.349 | | Vel = 0 | |
| SP35 to SP34 | 69 53 | .0 | 0.0 0.0 | 6.065 | | 0.0 0.0 | 16.000 16.000 | 120 | 113.278 6.930 | | Vel = 0 | |
| SP34 to SP33 | 53 37 | .0 | 0.0 0.0 | 6 | | 0.0 0.0 | 16.000 16.000 | 120 | 120.208 6.930 | | Vel = 0 | |
| SP33 to SP05 | 37 29.167 | .0 | 0.0 0.0 | 6 | 1T | 30.0 0.0 | 8.417 30.000 | 120 | 127.137 3.392 | | Vel = 0 | |
| SP05 | | | 0.0 6.065 | | | 0.0 38.417 | | 0 | 0.0 | | Vel = 0 | |

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science SP 5 [1000 GPM]

Page 6
 Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|----------------------|------------------|-----------|-----------------|------------|-----------------------|----------------------|----------------------------|----------------|-----------------------|-------|------------------------------------|-------|
| SP05 | | | 0.0 0.0 | | | | | | 130.529 | | K Factor = 0 | |
| SP32 to SP05 | 21 29.167 | .0 | 0.0 0.0 | 6 6.065 | 1T | 30.0 0.0 | 7.583 30.000 | 120 0 | 134.067 -3.537 | | Vel = 0 | |
| SP05 to SP03 | 29.167 29.167 | .0 | 0.0 0.0 | 6 6.065 | 1I 1B 1T | 10.0 10.0 30.0 | 34.167 50.000 84.167 | 120 0 | 130.530 0.0 0.0 | | Vel = 0 | |
| SP03 | | | 0.0 0.0 | | | | | | 130.530 | | K Factor = 0 | |
| *S/P # 4 | | | | | | | | | | | | |
| HV8 to SPR4 | 67.750 67.750 | H250 | 250.00 250.0 | 2.5 | 1T | 12.0 0.0 | 0.250 12.000 | 120 | 105.172 1.750 | | * Fixed loss = 1.75 Vel = 16.75 | |
| SPR4 | | | 0.0 250.00 | 2.469 | | 0.0 | 12.250 | 0.2153 | 2.638 | | K Factor = 23.88 | |
| HV9 to SPR4 | 67.750 67.750 | .0 | 0.0 0.0 | 2.5 | 1T | 12.0 0.0 | 0.250 12.000 | 120 0 | 107.810 1.750 | | * Fixed loss = 1.75 Vel = 0 | |
| SPR4 to SP44 | 67.750 53 | | 250.00 250.0 | 4 | | 0.0 0.0 | 14.750 0.0 | 120 0.0199 | 109.560 6.388 | | Vel = 6.30 | |
| SP44 to SP43 | 53 37 | | 0.0 250.0 | 4 | | 0.0 0.0 | 16.000 16.000 | 120 0.0199 | 116.242 6.930 | | Vel = 6.30 | |
| SP43 to SP42 | 37 21 | | 0.0 250.0 | 4 | | 0.0 0.0 | 16.000 16.000 | 120 0.0199 | 123.490 6.930 | | Vel = 6.30 | |
| SP42 to SPC4 | 21 13.750 | | 0.0 250.0 | 4 | 1T | 20.0 0.0 | 7.250 20.000 | 120 | 130.739 3.140 | | Vel = 6.30 | |
| SPC4 | | | 0.0 250.00 | 4.026 | | 0.0 | 27.250 | 0.0199 | 0.542 | | K Factor = 21.56 | |
| SP41 to SPC4 | 5 13.750 | .0 | 0.0 0.0 | 4 | 1T | 20.0 0.0 | 8.750 20.000 | 120 0 | 138.211 -3.790 | | Vel = 0 | |
| SPC4 | | | 0.0 0.0 | | | | | | 134.421 | | K Factor = 0 | |
| *S/P # 5 | | | | | | | | | | | | |
| HV10 to SP53 | 37 37 | H250 | 250.00 250.0 | 2.5 | 2E 1T | 12.0 12.0 | 1.750 24.000 | 120 | 100.000 1.750 | | * Fixed loss = 1.75 Vel = 16.75 | |
| SP53 to SP52 | 37 21 | | 0.0 250.0 | 2.469 | | 0.0 0.0 | 25.750 16.000 | 0.2154 120 | 5.547 107.297 | | Vel = 6.30 | |
| SP52 | | | 0.0 250.00 | 4.026 | | 0.0 | 16.000 | 0.0199 | 0.318 | | K Factor = 23.36 | |

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science SP 5 [1000 GPM]

Page 7
 Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|--------------------------|------------------|-----------|------------------|--------------|-----------------------|----------------------|------------------------------|----------------|-----------------------------|-------|---------------------|-------|
| HV11 to SP52 | 21 21 | H250 | 250.00 250.0 | 2.5 2.469 | 2E 1T | 12.0 12.0 | 1.750 24.000 | 120 | 107.248 1.750 | | * Fixed loss = 1.75 | |
| SP52 to SPC5 | 21 12.500 | | 250.00 500.0 | 4 4.026 | 1T | 20.0 0.0 | 8.500 20.000 | 120 | 114.545 3.681 | | Vel = 16.75 | |
| SPC5 | | | 0.0 500.00 | | | | | | 120.272 | | K Factor = 45.59 | |
| SP51 to SPC5 | 5 12.500 | .0 | 0.0 0.0 | 4 4.026 | 1T | 20.0 0.0 | 7.500 20.000 | 120 | 123.520 -3.248 | | Vel = 0 | |
| SPC5 | | | 0.0 0.0 | | | | | | 120.272 | | K Factor = 0 | |
| *STANDPIPES # 4 & 5 FEED | | | | | | | | | | | | |
| SPC5 to SPC3 | 12.500 12.667 | | 500.00 500.0 | 4 4.026 | 1B 5I 1T | 12.0 35.0 20.0 | 139.667 67.000 206.667 | 120 | 120.272 -0.072 14.835 | | Vel = 12.60 | |
| SPC3 | | | 0.0 500.00 | | | | | | 135.035 | | K Factor = 43.03 | |
| SPC4 to SPC3 | 13.750 12.667 | | 250.00 250.0 | 6 6.065 | 3I 1B | 30.0 10.0 | 13.333 40.000 | 120 | 134.421 0.469 | | Vel = 2.78 | |
| SPC3 to SPC2 | 12.667 12.667 | | 500.00 750.0 | 6 6.065 | 2I 1T | 20.0 30.0 | 104.667 50.000 | 120 | 135.035 0.0 | | Vel = 8.33 | |
| SPC2 | | | 0.0 750.00 | | | | | | 138.230 | | K Factor = 63.79 | |
| *STANDPIPES # 1 & 3 FEED | | | | | | | | | | | | |
| SP01 to SP02 | 45 27.917 | | 250.00 250.0 | 6 6.065 | 6I 1B | 60.0 10.0 | 34.417 70.000 | 120 | 122.699 7.399 | | Vel = 2.78 | |
| SP02 to SP03 | 27.917 29.167 | | 0.0 250.0 | 6 6.065 | 2I | 20.0 0.0 | 235.417 20.000 | 120 | 130.380 -0.541 | | Vel = 2.78 | |
| SP03 to SP04 | 29.167 28.083 | | 0.0 250.0 | 6 6.065 | 4I | 40.0 0.0 | 27.500 40.000 | 120 | 130.530 0.469 | | Vel = 2.78 | |
| SP04 to SPC1 | 28.083 12.667 | | 0.0 250.0 | 6 6.065 | 2I | 20.0 0.0 | 79.330 20.000 | 120 | 131.182 6.677 | | Vel = 2.78 | |
| SPC1 to SPC2 | 12.667 12.667 | | 0.0 250.0 | 6 6.065 | 1T | 30.0 0.0 | 7.833 30.000 | 120 | 138.128 0.0 | | Vel = 2.78 | |
| SPC2 to PO | 12.667 1.833 | | 750.00 1000.0 | 8 7.981 | 1I 1B 1C | 13.0 12.0 45.0 | 14.750 70.000 84.750 | 120 | 138.230 4.692 0.783 | | Vel = 6.41 | |
| | | | 0.0 | | | | | | | | | |


Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science SP 5 [1000 GPM]

Page 8
 Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|--------------------------|----------------|-----------|----------------|------------|-----------------------|-----------------|-------------------------|----------------|------------------|-------|------------------------------------|-------|
| PO | | | 1000.00 | | | | | | 143.705 | | K Factor = 83.42 | |
| System Demand Pressure | | | | | | | | | 143.705 | | | |
| Safety Margin | | | | | | | | | 1.287 | | | |
| Continuation Pressure | | | | | | | | | 144.992 | | | |
| Pressure @ Pump Outlet | | | | | | | | | 144.992 | | | |
| Pressure From Pump Curve | | | | | | | | | -98.033 | | | |
| Pressure @ Pump Inlet | | | | | | | | | 46.959 | | | |
| PI to POC | 1.750 6.750 | | 0.0 1000.0 | 8 7.981 | 1G 1I | 4.0 13.0 | 14.000 52.000 | 120 | 46.959 -2.166 | | Vel = 6.41 | |
| POC to BF1 | 6.750 13 | | 0.0 1000.0 | 8 8.27 | 2E | 56.936 0.0 | 41.000 56.936 | 140 | 45.403 -2.707 | | Vel = 5.97 | |
| BF1 to BF2 | 13 13 | | 0.0 1000.0 | 8 7.981 | 1Zic | 0.0 0.0 | 4.000 0.0 | 120 | 43.268 3.829 | | * Fixed loss = 3.829 Vel = 6.41 | |
| BF2 to SRC | 13 13 | | 0.0 1000.0 | 8 8.27 | 2E 1G | 56.936 6.326 | 46.000 118.616 | 140 | 47.134 0.0 | | Vel = 5.97 | |
| SRC | | | 0.0 1000.00 | | | | | | 48.095 | | K Factor = 144.19 | |

This page intentionally left blank.



**STANDPIPE STATIC & FLOW FOR PRESSURE
REDUCING VALVE SETTING 'E'**

This page intentionally left blank.



**AUTOMATIC
SPRINKLER CO.**

21605 North Central Ave. 623.580.7800
Phoenix, Arizona 85024 Fax 623.434.3154

AZ-L16-234798 CA-C16-901529
AZ-C16-234797 NV-C41-69370
UT-S370-6690455-5501 NM-MS 12-354807



Fire Protection by Computer Design

Aero Automatic Sprinkler Co.
21605 N. Central Ave.
Phoenix, Arizona 85024
623-580-7800

Job Name : Cal Poly Center for Science SP - STATIC
Building : Center for Science
Location : San Luis Obispo, Ca.
System : S/P # 1,3,4,5
Contract : 10034
Data File : Cal Poly CFS SP 1-1-STATIC.WXF

HYDRAULIC DESIGN INFORMATION SHEET

Name - Cal Poly Center For Science Date - 9-25-2011
Location - San Luis Obispo, Ca.
Building - Center for Science System No. - S/P # 1,3,4,5
Contractor - Aero Automatic Sprinkler Co. Contract No. - 10034
Calculated By - Neal Larsen Drawing No. -
Occupancy - Light / Ordinary Hazard Gr. 1

S (X)NFPA 14 Number of Standpipes ()1 ()2 ()3 (X)4 ()
Y ()Other
S ()Specific Ruling Made by Date

T
E Flow at Top Most Outlet - 0.05 Gpm System Type
M Pres. at Top Most Outlet - N/A Psi (X) Wet () Dry
Flow For Ea. Additional Standpipe - N/A Gpm
D Total Additional Flow - 0.05 Gpm
E Elevation at Highest Outlet - 101-0 Feet
S Hose Valve Connection ()1 1/2" (X)2 1/2"
I Class Service (X)I ()II (X)III
G Note: This is a static Calculation to determine were Pressure Reducing Va.
N are required (only three (3) on 1 st. floor)

Calculation Gpm Required 0.05 Psi Required 59.99 At SRC
Summary C-Factor Used: Overhead 120 Underground 140

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - 9-19-2011 Cap. N/A
T Time of Test - 9:12 a.m. Rated Cap. 750 Elev. N/A
E Static (Psi) - 60 @ Psi 113
R Residual (Psi) - 55 Elev. 1'-9" Well
Flow (Gpm) - 914 Proof Flow Gpm N/A
S Elevation - 13'-0"


U
P Location: Static & Residual pressures taken from Hydrant # 63. Flow taken
P from Hydrant # 64 along N. Poly View Drive
L Source of Information: Fluid Resource Management {R. Ellison}
Y Note : Full Flow test was used in this Static Hyd. Calculation.

Water Supply Curve (C)

Aero Automatic Sprinkler Co.
Cal Poly Center for Science SP - STATIC

Page 2
Date 9-25-11

| | | |
|---|---|--|
| City Water Supply: C1 - Static Pressure : 60 C2 - Residual Pressure: 55 C2 - Residual Flow : 914 City Water Adjusted to Pump Inlet for Pf - Elev - Hose Flow A1 - Adjusted Static: 0 A2 - Adj Resid : 0 @ 0 A3 - Adj Resid : 0 @ 0 | Pump Data: P1 - Pump Churn Pressure : 125.2 P2 - Pump Rated Pressure : 110.9 P2 - Pump Rated Flow : 0 P3 - Pump Pressure @ Max Flow : 67.9 P3 - Pump Max Flow : 0 City Residual Flow @ 0 = 3501.77 City Residual Flow @ 20 = 2812.57 City Water @ 150% of Pump = 60.00 Pump flow terminated at adjusted curve 0 psi | Demand: D1 - Elevation : 37.571 D2 - System Flow : _____ D2 - System Pressure : <u>183.028</u> Hose (Adj City) : _____ Hose (Demand) : <u>0.05</u> D3 - System Demand : 0.05 Safety Margin : 0.008 |
|---|---|--|



Fittings Used Summary

Aero Automatic Sprinkler Co.
Cal Poly Center for Science SP - STATIC

Page 3
Date 9-25-11

Fitting Legend

| Abbrev. | Name | ½ | ¾ | 1 | 1¼ | 1½ | 2 | 2½ | 3 | 3½ | 4 | 5 | 6 | 8 | 10 | 12 | 14 | 16 | 18 | 20 | 24 |
|---------|-------------------------|--|---|------|----|-----|-----|----|----|----|----|-----|----|----|----|----|----|----|----|-----|-----|
| B | Generic Butterfly Valve | 0 | 0 | 2.25 | 2 | 2.5 | 6 | 7 | 10 | 0 | 12 | 9 | 10 | 12 | 19 | 21 | 0 | 0 | 0 | 0 | 0 |
| C | Generic Check Vlv | 4 | 5 | 5 | 7 | 9 | 11 | 14 | 16 | 19 | 22 | 27 | 32 | 45 | 55 | 65 | 76 | 87 | 98 | 109 | 130 |
| E | 90' Standard Elbow | 2 | 2 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 10 | 12 | 14 | 18 | 22 | 27 | 35 | 40 | 45 | 50 | 61 |
| G | Generic Gate Valve | 0 | 0 | 0 | 1 | 0 | 1 | 1 | 1 | 1 | 2 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 10 | 11 | 13 |
| I | 90' Ell Grvd-Vic #10 | 0 | 0 | 2 | 3 | 4 | 3.5 | 6 | 5 | 8 | 7 | 8.5 | 10 | 13 | 17 | 20 | 23 | 25 | 33 | 36 | 40 |
| T | 90' Flow Thru Tee | 3 | 4 | 5 | 6 | 8 | 10 | 12 | 15 | 17 | 20 | 25 | 30 | 35 | 50 | 60 | 71 | 81 | 91 | 101 | 121 |
| Zic | Wilkens 350ADA | Fitting generates a Fixed Loss Based on Flow | | | | | | | | | | | | | | | | | | | |

Units Summary

Diameter Units Inches
Length Units Feet
Flow Units US Gallons per Minute
Pressure Units Pounds per Square Inch

Pressure / Flow Summary - STANDARD

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science SP - STATIC

Page 4
 Date 9-25-11

| Node No. | Elevation | K-Fact | Pt Actual | Pn | Flow Actual | Density | Area | Press Req. |
|----------|-----------|--------|-----------|----|-------------|---------|------|------------|
| HV1 | 99.75 | | 138.87 | na | 0.05 | | | |
| HV2 | 99.75 | | 138.87 | na | | | | |
| SPRF | 99.75 | | 140.62 | na | | | | |
| SP16 | 85.0 | | 147.01 | na | | | | |
| SP15 | 69.0 | | 153.94 | na | | | | |
| SP14 | 53.0 | | 160.87 | na | | | | |
| SP13 | 37.0 | | 167.8 | na | | | | |
| HV3 | 99.0 | | 139.2 | na | | | | |
| SPR3 | 99.0 | | 140.94 | na | | | | |
| SP36 | 85.0 | | 147.01 | na | | | | |
| SP35 | 69.0 | | 153.94 | na | | | | |
| SP34 | 53.0 | | 160.87 | na | | | | |
| SP33 | 37.0 | | 167.8 | na | | | | |
| SP32 | 21.0 | | 174.73 | na | | | | |
| SP05 | 29.167 | | 171.19 | na | | | | |
| HV8 | 67.75 | | 152.73 | na | | | | |
| HV9 | 67.75 | | 152.73 | na | | | | |
| SPR4 | 67.75 | | 154.48 | na | | | | |
| SP44 | 53.0 | | 160.87 | na | | | | |
| SP43 | 37.0 | | 167.8 | na | | | | |
| SP42 | 21.0 | | 174.73 | na | | | | |
| SP41 | 5.0 | | 181.66 | na | | | | |
| HV10 | 37.0 | | 166.05 | na | | | | |
| SP53 | 37.0 | | 167.8 | na | | | | |
| HV11 | 21.0 | | 172.98 | na | | | | |
| SP52 | 21.0 | | 174.73 | na | | | | |
| SP51 | 5.0 | | 181.66 | na | | | | |
| SPC5 | 12.5 | | 178.41 | na | | | | |
| SPC4 | 13.75 | | 177.87 | na | | | | |
| SPC3 | 12.667 | | 178.34 | na | | | | |
| SP01 | 45.0 | | 164.33 | na | | | | |
| SP02 | 27.917 | | 171.73 | na | | | | |
| SP03 | 29.167 | | 171.19 | na | | | | |
| SP04 | 28.083 | | 171.66 | na | | | | |
| SPC1 | 12.667 | | 178.34 | na | | | | |
| SPC2 | 12.667 | | 178.34 | na | | | | |
| PO | 1.833 | | 183.03 | na | | | | |
| PI | 1.75 | | 57.87 | na | | | | |
| POC | 6.75 | | 55.71 | na | | | | |
| BF1 | 13.0 | | 53.0 | na | | | | |
| BF2 | 13.0 | | 60.0 | na | | | | |
| SRC | 13.0 | | 60.0 | na | | | | |

The maximum velocity is 0 and it occurs in the pipe between nodes and

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
Cal Poly Center for Science SP - STATIC

Page 5
Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|---|------------------|-----------|-------------|------------|-----------------------|--------------|-------------------------|----------------|-------------------|-------|---------------------|-------|
| *S/P # 1 REMOTE ROOF HOSE VALVES | | | | | | | | | | | | |
| HV1 to SPRF | 99.750 99.750 | H0.05 | 0.05 | 2.5 | 1T | 12.0 0.0 | 0.250 12.000 | 120 | 138.870 1.750 | | * Fixed loss = 1.75 | |
| | | | 0.05 | 2.469 | | 0.0 | 12.250 | 0 | 0.0 | | Vel = 0 | |
| | | | 0.0 0.05 | | | | | | 140.620 | | K Factor = 0 | |
| HV2 to SPRF | 99.750 99.750 | .0 | 0.0 | 2.5 | 1T | 12.0 0.0 | 0.250 12.000 | 120 | 138.870 1.750 | | * Fixed loss = 1.75 | |
| | | | 0.0 | 2.469 | | 0.0 | 12.250 | 0 | 0.0 | | Vel = 0 | |
| | | | 0.05 | 6 | 4I | 40.0 0.0 | 30.000 40.000 | 120 | 140.620 6.388 | | | |
| SP16 to SP15 | 85 69 | | 0.05 | 6.065 | | 0.0 | 70.000 | 0 | 0.0 | | Vel = 0 | |
| | | | 0.0 | 6 | | 0.0 | 16.000 | 120 | 147.008 6.930 | | | |
| SP15 to SP14 | 69 53 | | 0.05 | 6.065 | | 0.0 | 16.000 | 0 | 0.0 | | Vel = 0 | |
| | | | 0.0 | 6 | | 0.0 | 16.000 | 120 | 153.938 6.930 | | | |
| SP14 to SP01 | 53 45 | | 0.05 | 6.065 | 1T | 30.0 0.0 | 8.500 30.000 | 120 | 160.868 3.465 | | | |
| | | | 0.05 | 6.065 | | 0.0 | 38.500 | 0 | -0.001 | | Vel = 0 | |
| | | | 0.0 0.05 | | | | | | 164.332 | | K Factor = 0 | |
| SP13 to SP01 | 37 45 | .0 | 0.0 | 6 | 1T | 30.0 0.0 | 7.500 30.000 | 120 | 167.797 -3.465 | | | |
| | | | 0.0 | 6.065 | | 0.0 | 37.500 | 0 | 0.0 | | Vel = 0 | |
| | | | 0.0 0.0 | | | | | | 164.332 | | K Factor = 0 | |
| *S/P # 3 | | | | | | | | | | | | |
| HV3 to SPR3 | 99 99 | .0 | 0.0 | 2.5 | 2E 1T | 12.0 12.0 | 1.750 24.000 | 120 | 139.195 1.750 | | * Fixed loss = 1.75 | |
| | | | 0.0 | 2.469 | | 0.0 | 25.750 | 0 | 0.0 | | Vel = 0 | |
| | | | 0.0 | 6 | | 0.0 | 16.000 | 120 | 140.945 6.063 | | | |
| SP36 to SP35 | 85 69 | | 0.0 | 6.065 | | 0.0 | 16.000 | 0 | 0.0 | | Vel = 0 | |
| | | .0 | 0.0 | 6 | | 0.0 | 16.000 | 120 | 147.008 6.930 | | | |
| SP35 to SP34 | 69 53 | | 0.0 | 6.065 | | 0.0 | 16.000 | 0 | 0.0 | | Vel = 0 | |
| | | .0 | 0.0 | 6 | | 0.0 | 16.000 | 120 | 153.938 6.930 | | | |
| SP34 to SP33 | 53 37 | | 0.0 | 6.065 | | 0.0 | 16.000 | 0 | 0.0 | | Vel = 0 | |
| | | .0 | 0.0 | 6 | | 0.0 | 16.000 | 120 | 160.868 6.930 | | | |
| SP33 to SP05 | 37 29.167 | | 0.0 | 6.065 | 1T | 30.0 0.0 | 8.417 30.000 | 120 | 167.797 3.392 | | | |
| | | .0 | 0.0 | 6.065 | | 0.0 | 38.417 | 0 | 0.0 | | Vel = 0 | |

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science SP - STATIC

Page 6
 Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|----------------------|------------------|-----------|------------|--------------|-----------------------|----------------------|----------------------------|----------------|-----------------------|-------|--------------------------------|-------|
| SP05 | | | 0.0 0.0 | | | | | | 171.189 | | K Factor = 0 | |
| SP32 to SP05 | 21 29.167 | .0 | 0.0 0.0 | 6 6.065 | 1T | 30.0 0.0 | 7.583 30.000 | 120 0 | 174.727 -3.537 | | Vel = 0 | |
| SP05 to SP03 | 29.167 29.167 | .0 | 0.0 0.0 | 6 6.065 | 1I 1B 1T | 10.0 10.0 30.0 | 34.167 50.000 84.167 | 120 0 | 171.190 0.0 0.0 | | Vel = 0 | |
| SP03 | | | 0.0 0.0 | | | | | | 171.190 | | K Factor = 0 | |
| *S/P # 4 | | | | | | | | | | | | |
| HV8 to SPR4 | 67.750 67.750 | .0 | 0.0 0.0 | 2.5 2.469 | 1T | 12.0 0.0 | 0.250 12.000 | 120 0 | 152.729 1.750 | | * Fixed loss = 1.75 Vel = 0 | |
| SPR4 | | | 0.0 0.0 | | | | | | 154.479 | | K Factor = 0 | |
| HV9 to SPR4 | 67.750 67.750 | .0 | 0.0 0.0 | 2.5 2.469 | 1T | 12.0 0.0 | 0.250 12.000 | 120 0 | 152.729 1.750 | | * Fixed loss = 1.75 Vel = 0 | |
| SPR4 to SP44 | 67.750 53 | .0 | 0.0 0.0 | 4 4.026 | | 0.0 0.0 | 14.750 0.0 | 120 0 | 154.479 6.388 | | Vel = 0 | |
| SP44 to SP43 | 53 37 | .0 | 0.0 0.0 | 4 4.026 | | 0.0 0.0 | 16.000 16.000 | 120 0 | 160.868 6.930 | | Vel = 0 | |
| SP43 to SP42 | 37 21 | .0 | 0.0 0.0 | 4 4.026 | | 0.0 0.0 | 16.000 16.000 | 120 0 | 167.797 6.930 | | Vel = 0 | |
| SP42 to SPC4 | 21 13.750 | .0 | 0.0 0.0 | 4 4.026 | 1T | 20.0 0.0 | 7.250 20.000 | 120 0 | 174.727 3.140 | | Vel = 0 | |
| SPC4 | | | 0.0 0.0 | | | | | | 177.867 | | K Factor = 0 | |
| SP41 to SPC4 | 5 13.750 | .0 | 0.0 0.0 | 4 4.026 | 1T | 20.0 0.0 | 8.750 20.000 | 120 0 | 181.656 -3.790 | | Vel = 0 | |
| SPC4 | | | 0.0 0.0 | | | | | | 177.866 | | K Factor = 0 | |
| *S/P # 5 | | | | | | | | | | | | |
| HV10 to SP53 | 37 37 | .0 | 0.0 0.0 | 2.5 2.469 | 2E 1T | 12.0 12.0 | 1.750 24.000 | 120 0 | 166.047 1.750 | | * Fixed loss = 1.75 Vel = 0 | |
| SP53 to SP52 | 37 21 | .0 | 0.0 0.0 | 4 4.026 | | 0.0 0.0 | 16.000 16.000 | 120 0 | 167.797 6.930 | | Vel = 0 | |
| SP52 | | | 0.0 0.0 | | | | | | 174.727 | | K Factor = 0 | |

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
Cal Poly Center for Science SP - STATIC

Page 7
Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|--------------------------|------------------|-----------|----------|------------|-----------------------|----------------------|------------------------------|----------------|--------------------------|-------|--------------------------------|---------|
| HV11 to SP52 | 21 21 | .0 | 0.0 | 2.5 | 2E 1T | 12.0 12.0 | 1.750 24.000 | 120 | 172.977 1.750 | | | |
| | | | | 2.469 | | 0.0 | 25.750 | 0 | 0.0 | | * Fixed loss = 1.75 Vel = 0 | |
| SP52 to SPC5 | 21 12.500 | .0 | 0.0 | 4 | 1T | 20.0 0.0 | 8.500 20.000 | 120 | 174.727 3.681 | | | Vel = 0 |
| | | | 0.0 | 4.026 | | 0.0 | 28.500 | 0 | 0.0 | | Vel = 0 | |
| | | | 0.0 | | | | | | 178.408 | | K Factor = 0 | |
| SP51 to SPC5 | 5 12.500 | .0 | 0.0 | 4 | 1T | 20.0 0.0 | 7.500 20.000 | 120 | 181.656 -3.248 | | | Vel = 0 |
| | | | 0.0 | 4.026 | | 0.0 | 27.500 | 0 | 0.0 | | Vel = 0 | |
| | | | 0.0 | | | | | | 178.408 | | K Factor = 0 | |
| *STANDPIPES # 4 & 5 FEED | | | | | | | | | | | | |
| SPC5 to SPC3 | 12.500 12.667 | .0 | 0.0 | 4 | 1B 5I 1T | 12.0 35.0 20.0 | 139.667 67.000 206.667 | 120 | 178.408 -0.072 0.0 | | | Vel = 0 |
| | | | 0.0 | 4.026 | | | | 0 | 0.0 | | Vel = 0 | |
| | | | 0.0 | | | | | | 178.336 | | K Factor = 0 | |
| SPC4 to SPC3 | 13.750 12.667 | .0 | 0.0 | 6 | 3I 1B | 30.0 10.0 | 13.333 40.000 | 120 | 177.867 0.469 | | | Vel = 0 |
| | | | 0.0 | 6.065 | | 0.0 | 53.333 | 0 | 0.0 | | Vel = 0 | |
| SPC3 to SPC2 | 12.667 12.667 | .0 | 0.0 | 6 | 2I 1T | 20.0 30.0 | 104.667 50.000 | 120 | 178.336 0.0 | | | Vel = 0 |
| | | | 0.0 | 6.065 | | 0.0 | 154.667 | 0 | 0.0 | | Vel = 0 | |
| | | | 0.0 | | | | | | 178.336 | | K Factor = 0 | |
| *STANDPIPES # 1 & 3 FEED | | | | | | | | | | | | |
| SP01 to SP02 | 45 27.917 | | 0.05 | 6 | 6I 1B | 60.0 10.0 | 34.417 70.000 | 120 | 164.332 7.399 | | | Vel = 0 |
| | | | 0.05 | 6.065 | | 0.0 | 104.417 | 0 | 0.0 | | Vel = 0 | |
| SP02 to SP03 | 27.917 29.167 | | 0.0 | 6 | 2I | 20.0 0.0 | 235.417 20.000 | 120 | 171.731 -0.541 | | | Vel = 0 |
| | | | 0.05 | 6.065 | | 0.0 | 255.417 | 0 | 0.0 | | Vel = 0 | |
| SP03 to SP04 | 29.167 28.083 | | 0.0 | 6 | 4I | 40.0 0.0 | 27.500 40.000 | 120 | 171.190 0.469 | | | Vel = 0 |
| | | | 0.05 | 6.065 | | 0.0 | 67.500 | 0 | 0.0 | | Vel = 0 | |
| SP04 to SPC1 | 28.083 12.667 | | 0.0 | 6 | 2I | 20.0 0.0 | 79.330 20.000 | 120 | 171.659 6.677 | | | Vel = 0 |
| | | | 0.05 | 6.065 | | 0.0 | 99.330 | 0 | 0.0 | | Vel = 0 | |
| SPC1 to SPC2 | 12.667 12.667 | | 0.0 | 6 | 1T | 30.0 0.0 | 7.833 30.000 | 120 | 178.336 0.0 | | | Vel = 0 |
| | | | 0.05 | 6.065 | | 0.0 | 37.833 | 0 | 0.0 | | Vel = 0 | |
| SPC2 to PO | 12.667 1.833 | | 0.0 | 8 | 1I 1B 1C | 13.0 12.0 45.0 | 14.750 70.000 84.750 | 120 | 178.336 4.692 0.0 | | | Vel = 0 |
| | | | 0.05 | 7.981 | | | | 0 | 0.0 | | Vel = 0 | |
| | | | 0.0 | | | | | | | | | |

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science SP - STATIC

Page 8
 Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|--------------------------|----------------|-----------|-------------|------------|-----------------------|-----------------|-------------------------|----------------|------------------|-------|-----------------------------|-------|
| PO | | | 0.05 | | | | | | 183.028 | | K Factor = 0 | |
| System Demand Pressure | | | | | | | 183.028 | | | | | |
| Safety Margin | | | | | | | 0.008 | | | | | |
| Continuation Pressure | | | | | | | 183.036 | | | | | |
| Pressure @ Pump Outlet | | | | | | | 183.036 | | | | | |
| Pressure From Pump Curve | | | | | | | -125.164 | | | | | |
| Pressure @ Pump Inlet | | | | | | | 57.872 | | | | | |
| PI to POC | 1.750 6.750 | | 0.0 0.05 | 8 7.981 | 1G 1I | 4.0 13.0 | 14.000 52.000 | 120 0 | 57.872 -2.166 | | Vel = 0 | |
| POC to BF1 | 6.750 13 | | 0.0 0.05 | 8 8.27 | 2E | 56.936 0.0 | 41.000 56.936 | 140 0 | 55.706 -2.707 | | Vel = 0 | |
| BF1 to BF2 | 13 13 | | 0.0 0.05 | 8 7.981 | 1Zic | 0.0 0.0 | 4.000 0.0 | 120 0 | 53.000 7.000 | | * Fixed loss = 7 Vel = 0 | |
| BF2 to SRC | 13 13 | | 0.0 0.05 | 8 8.27 | 2E 1G | 56.936 6.326 | 46.000 118.616 | 140 0 | 60.000 0.0 | | Vel = 0 | |
| SRC | | | 0.0 0.05 | | | | | | 60.000 | | K Factor = 0.01 | |

This page intentionally left blank.



**AUTOMATIC
SPRINKLER CO.**

21605 North Central Ave. 623.580.7800
Phoenix, Arizona 85024 Fax 623.434.3154

AZ-L16-234798 CA-C16-901529
AZ-C16-234797 NV-C41-69370
UT-S370-6690455-5501 NM-MS 12-354807



Fire Protection by Computer Design

Aero Automatic Sprinkler Co.
21605 N. Central Ave.
Phoenix, Arizona 85024
623-580-7800

Job Name : Cal Poly Center for Science 1 st. flr. Riser [250 gpm]
Building : Center for Science
Location : San Luis Obispo, Ca.
System : 1 st floor
Contract : 10034
Data File : Cal Poly CFS LVL 1-250.WXF

HYDRAULIC DESIGN INFORMATION SHEET

Name - Cal Poly Center For Science Date - 9-25-2011
 Location - San Luis Obispo, Ca.
 Building - Center for Science System No. - 1 st floor
 Contractor - Aero Automatic Sprinkler Co. Contract No. - 10034
 Calculated By - Neal Larsen Drawing No. -
 Occupancy - Light / Ordinary Hazard Gr. 1

S (X)NFPA 14 Number of Standpipes ()1 ()2 ()3 (X)4 ()
 Y ()Other
 S ()Specific Ruling Made by Date

T
 E Flow at Top Most Outlet - 250 Gpm System Type
 M Pres. at Top Most Outlet - N/A Psi (X) Wet () Dry
 Flow For Ea. Additional Standpipe - N/A Gpm
 D Total Additional Flow - 250 Gpm
 E Elevation at Highest Outlet - 3'-0" Feet
 S Hose Valve Connection ()1 1/2" (X)2 1/2"
 I Class Service (X)I ()II (X)III
 G Note: This is a flow Calculation for 250 gpm @ 1 st. flr riser to determine
 N the residual pressure for setting the Pressure Reducing Va. [Setting 'E']

Calculation Gpm Required 250 Psi Required 59.54 At SRC
 Summary C-Factor Used: Overhead 120 Underground 140

W Water Flow Test: Pump Data: Tank or Reservoir:
 A Date of Test - 9-19-2011 Cap. N/A
 T Time of Test - 9:12 a.m. Rated Cap. 750 Elev. N/A
 E Static (Psi) - 60 @ Psi 113
 R Residual (Psi) - 55 Elev. 1'-9" Well
 Flow (Gpm) - 914 Proof Flow Gpm N/A
 S Elevation - 13'-0"


U
 P Location: Static & Residual pressures taken from Hydrant # 63. Flow taken
 P from Hydrant # 64 along N. Poly View Drive
 L Source of Information: Fluid Resource Management {R. Ellison}
 Y Note : Full Flow test was used in this Static Hyd. Calculation.

Water Supply Curve (C)

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science 1 st. flr. Riser [250 gpm]

Page 2
 Date 9-25-11

| | | |
|---|---|--|
| City Water Supply: C1 - Static Pressure : 60 C2 - Residual Pressure: 55 C2 - Residual Flow : 914 City Water Adjusted to Pump Inlet for Pf - Elev - Hose Flow A1 - Adjusted Static: 0 A2 - Adj Resid : 0 @ 0 A3 - Adj Resid : 0 @ 0 | Pump Data: P1 - Pump Churn Pressure : 125.2 P2 - Pump Rated Pressure : 110.9 P2 - Pump Rated Flow : 0 P3 - Pump Pressure @ Max Flow : 67.9 P3 - Pump Max Flow : 0 City Residual Flow @ 0 = 3501.77 City Residual Flow @ 20 = 2812.57 City Water @ 150% of Pump = 60.00 Pump flow terminated at adjusted curve 0 psi | Demand: D1 - Elevation : -4.331 D2 - System Flow : _____ D2 - System Pressure : <u>182.606</u> Hose (Adj City) : _____ Hose (Demand) : <u>250</u> D3 - System Demand : 250 Safety Margin : _____ |
|---|---|--|



Fittings Used Summary

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science 1 st. flr. Riser [250 gpm]

Page 3
 Date 9-25-11

Fitting Legend

| Abbrev. | Name | ½ | ¾ | 1 | 1¼ | 1½ | 2 | 2½ | 3 | 3½ | 4 | 5 | 6 | 8 | 10 | 12 | 14 | 16 | 18 | 20 | 24 |
|---------|-------------------------|--|---|------|----|-----|-----|----|----|----|----|-----|----|----|----|----|----|----|----|-----|-----|
| B | Generic Butterfly Valve | 0 | 0 | 2.25 | 2 | 2.5 | 6 | 7 | 10 | 0 | 12 | 9 | 10 | 12 | 19 | 21 | 0 | 0 | 0 | 0 | 0 |
| C | Generic Check Vlv | 4 | 5 | 5 | 7 | 9 | 11 | 14 | 16 | 19 | 22 | 27 | 32 | 45 | 55 | 65 | 76 | 87 | 98 | 109 | 130 |
| E | 90' Standard Elbow | 2 | 2 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 10 | 12 | 14 | 18 | 22 | 27 | 35 | 40 | 45 | 50 | 61 |
| G | Generic Gate Valve | 0 | 0 | 0 | 1 | 0 | 1 | 1 | 1 | 1 | 2 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 10 | 11 | 13 |
| I | 90' Ell Grvd-Vic #10 | 0 | 0 | 2 | 3 | 4 | 3.5 | 6 | 5 | 8 | 7 | 8.5 | 10 | 13 | 17 | 20 | 23 | 25 | 33 | 36 | 40 |
| T | 90' Flow Thru Tee | 3 | 4 | 5 | 6 | 8 | 10 | 12 | 15 | 17 | 20 | 25 | 30 | 35 | 50 | 60 | 71 | 81 | 91 | 101 | 121 |
| Zic | Wilkens 350ADA | Fitting generates a Fixed Loss Based on Flow | | | | | | | | | | | | | | | | | | | |

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Pressure / Flow Summary - STANDARD

Aero Automatic Sprinkler Co.
Cal Poly Center for Science 1 st. flr. Riser [250 gpm]

Page 4
Date 9-25-11

| Node No. | Elevation | K-Fact | Pt Actual | Pn | Flow Actual | Density | Area | Press Req. |
|----------|-----------|--------|-----------|----|-------------|---------|------|------------|
| BR01 | 3.0 | | 174.52 | na | 250.0 | | | |
| SPC1 | 12.667 | | 177.75 | na | | | | |
| SPC2 | 12.667 | | 177.85 | na | | | | |
| PO | 1.833 | | 182.61 | na | | | | |
| PI | 1.75 | | 57.87 | na | | | | |
| POC | 6.75 | | 55.75 | na | | | | |
| BF1 | 13.0 | | 53.09 | na | | | | |
| BF2 | 13.0 | | 59.47 | na | | | | |
| SRC | 13.0 | | 59.55 | na | | | | |

The maximum velocity is 14.71 and it occurs in the pipe between nodes BR01 and SPC1

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science 1 st. flr. Riser [250 gpm]

Page 5
 Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|--------------------------|------------------|-----------|-----------------|--------------|-----------------------|---------------------------|------------------------------|----------------|----------------------------|-------|------------------------------------|-------|
| BR01 to SPC1 | 3 12.667 | H250 | 250.00 250.0 | 2.5 2.635 | 2I 1T | 16.474 16.474 | 14.333 32.948 | 120 0.1569 | 174.519 -4.187 7.419 | | Vel = 14.71 | |
| SPC1 to SPC2 | 12.667 12.667 | | 0.0 250.0 | 6 6.065 | 1T | 30.0 0.0 | 7.917 30.000 | 120 0.0027 | 177.751 0.0 0.103 | | Vel = 2.78 | |
| SPC2 to PO | 12.667 1.833 | | 0.0 250.0 | 8 7.981 | 1I 1B 1C | 13.0 12.0 45.0 | 14.750 70.000 84.750 | 120 0.0007 | 177.854 4.692 0.060 | | Vel = 1.60 | |
| PO | | | 0.0 250.00 | | | | | | 182.606 | | K Factor = 18.50 | |
| System Demand Pressure | | | | | | 182.606 | | | | | | |
| Safety Margin | | | | | | 0.0 | | | | | | |
| Continuation Pressure | | | | | | 182.606 | | | | | | |
| Pressure @ Pump Outlet | | | | | | 182.606 | | | | | | |
| Pressure From Pump Curve | | | | | | -124.735 | | | | | | |
| Pressure @ Pump Inlet | | | | | | 57.871 | | | | | | |
| PI to POC | 1.750 6.750 | | 0.0 250.0 | 8 7.981 | 1G 1I 1T | 4.0 13.0 35.0 | 14.000 52.000 66.000 | 120 0.0007 | 57.871 -2.166 0.047 | | Vel = 1.60 | |
| POC to BF1 | 6.750 13 | | 0.0 250.0 | 8 8.27 | 2E | 56.936 0.0 | 41.000 56.936 | 140 0.0005 | 55.752 -2.707 0.045 | | Vel = 1.49 | |
| BF1 to BF2 | 13 13 | | 0.0 250.0 | 8 7.981 | 1Zic | 0.0 0.0 | 4.000 0.0 | 120 0.0008 | 53.090 6.379 0.003 | | * Fixed loss = 6.379 Vel = 1.60 | |
| BF2 to SRC | 13 13 | | 0.0 250.0 | 8 8.27 | 2E 1G 1T | 56.936 6.326 55.354 | 46.000 118.616 164.616 | 140 0.0004 | 59.472 0.0 0.074 | | Vel = 1.49 | |
| SRC | | | 0.0 250.00 | | | | | | 59.546 | | K Factor = 32.40 | |



**AUTOMATIC
SPRINKLER CO.**

21605 North Central Ave. 623.580.7800
Phoenix, Arizona 85024 Fax 623.434.3154

AZ-L16-234798 CA-C16-901529
AZ-C16-234797 NV-C41-69370
UT-S370-6690455-5501 NM-MS 12-354807



Fire Protection by Computer Design

Aero Automatic Sprinkler Co.
21605 N. Central Ave.
Phoenix, Arizona 85024
623-580-7800

Job Name : Cal Poly Center for Science 1 st. flr. Riser [328 gpm]
Building : Center for Science
Location : San Luis Obispo, Ca.
System : 1 st floor
Contract : 10034
Data File : Cal Poly CFS LVL 1-328.WXF

HYDRAULIC DESIGN INFORMATION SHEET

Name - Cal Poly Center For Science Date - 9-25-2011
 Location - San Luis Obispo, Ca.
 Building - Center for Science System No. - 1 st floor
 Contractor - Aero Automatic Sprinkler Co. Contract No. - 10034
 Calculated By - Neal Larsen Drawing No. -
 Occupancy - Light / Ordinary Hazard Gr. 1

S (X)NFPA 14 Number of Standpipes ()1 ()2 ()3 (X)4 ()
 Y ()Other
 S ()Specific Ruling Made by Date

| E | Flow at Top Most Outlet | - 328 | Gpm | | System Type |
|---|---|-----------|-----------|---------|-------------|
| M | Pres. at Top Most Outlet | - N/A | Psi | (X) Wet | () Dry |
| | Flow For Ea. Additional Standpipe | - N/A | Gpm | | |
| D | Total Additional Flow | - 328 | Gpm | | |
| E | Elevation at Highest Outlet | - 3'-0" | Feet | | |
| S | Hose Valve Connection | ()1 1/2" | (X)2 1/2" | | |
| I | Class Service | (X)I | ()II | (X)III | |
| G | Note: This is a flow Calculation for 328 gpm @ 1 st. flr riser to determine | | | | |
| N | the residual pressure for setting the Pressure Reducing Va. [Setting 'E'] | | | | |

| Calculation Summary | Gpm Required | Psi Required | At SRC |
|---------------------|----------------|--------------|-----------------|
| | 328 | 59.24 | |
| | C-Factor Used: | Overhead 120 | Underground 140 |

| Water Flow Test: | Pump Data: | Tank or Reservoir: |
|----------------------------|----------------|--------------------|
| A Date of Test - 9-19-2011 | | Cap. N/A |
| T Time of Test - 9:12 a.m. | Rated Cap. 750 | Elev. N/A |
| E Static (Psi) - 60 | @ Psi 113 | |
| R Residual (Psi) - 55 | Elev. 1'-9" | Well |
| Flow (Gpm) - 914 | | Proof Flow Gpm N/A |
| S Elevation - 13'-0" | | |


U
 P Location: Static & Residual pressures taken from Hydrant # 63. Flow taken
 P from Hydrant # 64 along N. Poly View Drive
 L Source of Information: Fluid Resource Management {R. Ellison}
 Y Note : Full Flow test was used in this Static Hyd. Calculation.

Water Supply Curve (C)

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science 1 st. flr. Riser [328 gpm]

Page 2
 Date 9-25-11

| | | |
|---|---|--|
| City Water Supply: C1 - Static Pressure : 60 C2 - Residual Pressure: 55 C2 - Residual Flow : 914 City Water Adjusted to Pump Inlet for Pf - Elev - Hose Flow A1 - Adjusted Static: 0 A2 - Adj Resid : 0 @ 0 A3 - Adj Resid : 0 @ 0 | Pump Data: P1 - Pump Churn Pressure : 125.2 P2 - Pump Rated Pressure : 110.9 P2 - Pump Rated Flow : 0 P3 - Pump Pressure @ Max Flow : 67.9 P3 - Pump Max Flow : 0 City Residual Flow @ 0 = 3501.77 City Residual Flow @ 20 = 2812.57 City Water @ 150% of Pump = 60.00 Pump flow terminated at adjusted curve 0 psi | Demand: D1 - Elevation : -4.331 D2 - System Flow : _____ D2 - System Pressure : 182.189 Hose (Adj City) : _____ Hose (Demand) : 328 D3 - System Demand : 328 Safety Margin : _____ |
|---|---|--|



Fittings Used Summary

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science 1 st. flr. Riser [328 gpm]

Page 3
 Date 9-25-11

Fitting Legend

| Abbrev. | Name | ½ | ¾ | 1 | 1¼ | 1½ | 2 | 2½ | 3 | 3½ | 4 | 5 | 6 | 8 | 10 | 12 | 14 | 16 | 18 | 20 | 24 |
|---------|-------------------------|--|---|------|----|-----|-----|----|----|----|----|-----|----|----|----|----|----|----|----|-----|-----|
| B | Generic Butterfly Valve | 0 | 0 | 2.25 | 2 | 2.5 | 6 | 7 | 10 | 0 | 12 | 9 | 10 | 12 | 19 | 21 | 0 | 0 | 0 | 0 | 0 |
| C | Generic Check Vlv | 4 | 5 | 5 | 7 | 9 | 11 | 14 | 16 | 19 | 22 | 27 | 32 | 45 | 55 | 65 | 76 | 87 | 98 | 109 | 130 |
| E | 90' Standard Elbow | 2 | 2 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 10 | 12 | 14 | 18 | 22 | 27 | 35 | 40 | 45 | 50 | 61 |
| G | Generic Gate Valve | 0 | 0 | 0 | 1 | 0 | 1 | 1 | 1 | 1 | 2 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 10 | 11 | 13 |
| I | 90' Ell Grvd-Vic #10 | 0 | 0 | 2 | 3 | 4 | 3.5 | 6 | 5 | 8 | 7 | 8.5 | 10 | 13 | 17 | 20 | 23 | 25 | 33 | 36 | 40 |
| T | 90' Flow Thru Tee | 3 | 4 | 5 | 6 | 8 | 10 | 12 | 15 | 17 | 20 | 25 | 30 | 35 | 50 | 60 | 71 | 81 | 91 | 101 | 121 |
| Zic | Wilkens 350ADA | Fitting generates a Fixed Loss Based on Flow | | | | | | | | | | | | | | | | | | | |

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Pressure / Flow Summary - STANDARD

Aero Automatic Sprinkler Co.
Cal Poly Center for Science 1 st. flr. Riser [328 gpm]

Page 4
Date 9-25-11

| Node No. | Elevation | K-Fact | Pt Actual | Pn | Flow Actual | Density | Area | Press Req. |
|----------|-----------|--------|-----------|----|-------------|---------|------|------------|
| BR01 | 3.0 | | 169.15 | na | 328.0 | | | |
| SPC1 | 12.667 | | 177.23 | na | | | | |
| SPC2 | 12.667 | | 177.4 | na | | | | |
| PO | 1.833 | | 182.19 | na | | | | |
| PI | 1.75 | | 57.73 | na | | | | |
| POC | 6.75 | | 55.65 | na | | | | |
| BF1 | 13.0 | | 53.01 | na | | | | |
| BF2 | 13.0 | | 59.13 | na | | | | |
| SRC | 13.0 | | 59.25 | na | | | | |

The maximum velocity is 19.3 and it occurs in the pipe between nodes BR01 and SPC1

Final Calculations - Hazen-Williams - 2007

Aero Automatic Sprinkler Co.
 Cal Poly Center for Science 1 st. flr. Riser [328 gpm]

Page 5
 Date 9-25-11

| Node1 to Node2 | Elev1 Elev2 | K Fact | Qa Qt | Nom Act | Fitting or Eqv. | Ln. | Pipe Ftng's Total | CFact Pf/Ft | Pt Pe Pf | ***** | Notes | ***** |
|--------------------------|------------------|-----------|-----------------|--------------|-----------------------|---------------------------|------------------------------|----------------|-----------------------------|-------|-----------------------------------|-------|
| BR01 to SPC1 | 3 12.667 | H328 | 328.00 328.0 | 2.5 2.635 | 2I 1T | 16.474 16.474 | 14.333 32.948 | 120 0.2593 | 169.154 -4.187 12.261 | | Vel = 19.30 | |
| SPC1 to SPC2 | 12.667 12.667 | | 0.0 328.0 | 6 6.065 | 1T | 30.0 0.0 | 7.917 30.000 37.917 | 120 0.0045 | 177.228 0.0 0.169 | | Vel = 3.64 | |
| SPC2 to PO | 12.667 1.833 | | 0.0 328.0 | 8 7.981 | 1I 1B 1C | 13.0 12.0 45.0 | 14.750 70.000 84.750 | 120 0.0012 | 177.397 4.692 0.100 | | Vel = 2.10 | |
| PO | | | 0.0 328.00 | | | | | | 182.189 | | K Factor = 24.30 | |
| System Demand Pressure | | | | | | 182.189 | | | | | | |
| Safety Margin | | | | | | 0.0 | | | | | | |
| Continuation Pressure | | | | | | 182.189 | | | | | | |
| Pressure @ Pump Outlet | | | | | | 182.189 | | | | | | |
| Pressure From Pump Curve | | | | | | -124.455 | | | | | | |
| Pressure @ Pump Inlet | | | | | | 57.734 | | | | | | |
| PI to POC | 1.750 6.750 | | 0.0 328.0 | 8 7.981 | 1G 1I 1T | 4.0 13.0 35.0 | 14.000 52.000 66.000 | 120 0.0012 | 57.734 -2.166 0.078 | | Vel = 2.10 | |
| POC to BF1 | 6.750 13 | | 0.0 328.0 | 8 8.27 | 2E | 56.936 0.0 | 41.000 56.936 97.936 | 140 0.0007 | 55.646 -2.707 0.073 | | Vel = 1.96 | |
| BF1 to BF2 | 13 13 | | 0.0 328.0 | 8 7.981 | 1Zic | 0.0 0.0 | 4.000 0.0 | 120 0.0012 | 53.012 6.110 0.005 | | * Fixed loss = 6.11 Vel = 2.10 | |
| BF2 to SRC | 13 13 | | 0.0 328.0 | 8 8.27 | 2E 1G 1T | 56.936 6.326 55.354 | 46.000 118.616 164.616 | 140 0.0007 | 59.127 0.0 0.122 | | Vel = 1.96 | |
| SRC | | | 0.0 328.00 | | | | | | 59.249 | | K Factor = 42.61 | |

SHOP DRAWINGS SUBMITTAL

SECTION:

DIVISION 21 – FIRE SUPPRESSION

21 0500 ; 21 1200 ; 21 1300 ; 21 3000

PROJECT:

CAL POLY CENTER FOR SCIENCE
1 GRAND AVE., BUILDING #70
SAN LUIS OBISPO, CA 93407

FOR THE:

GILBANE BUILDING COMPANY
1 GRAND AVE., BUILDING #70
SAN LUIS OBISPO, CA 93407

AS PRESENTED BY:



Aero Automatic Sprinkler Company

21605 North Central Ave.

Phoenix, AZ 85024

623-580-7800 623-434-3420 (fax)

This submittal has been reviewed by Aero Automatic Sprinkler Co. and approved with respect to the means, methods, techniques, sequences, and procedures of construction, and safety precautions and programs incidental thereto. Aero Automatic Sprinkler Co. also warrants that this submittal complies with the Contract Documents and comprises no variation to.

By: *Neal Larsen*

Date: 9-29-2011

Gilbane

Cal Poly Center for Science
Gilbane Project #: 174338010

REVIEWED

Building Name/#: Cal Poly CFS
Bid Package No: 21A
Submittal No: 003
Spec. Section: 21 05 00
Reviewed By: Scott Gurley
Date: 10/3/11

This review does not constitute nor does it assume design responsibility nor does it relieve the trade contractor/supplier from complying with the contract requirements, coordinating their work with other trade contractors and verifying field dimensions.

Gilbane

Cal Poly Center for Science
Gilbane Project #: 174338010

REVIEWED

Building Name/#: Cal Poly CFS
Bid Package No: 21A
Submittal No: 002
Spec. Section: 21 12 00
Reviewed By: Scott Gurley
Date: 10/3/11

This review does not constitute nor does it assume design responsibility nor does it relieve the trade contractor/supplier from complying with the contract requirements, coordinating their work with other trade contractors and verifying field dimensions.

Gilbane

Cal Poly Center for Science
Gilbane Project #: 174338010

REVIEWED

Building Name/#: Cal Poly CFS
Bid Package No: 21A
Submittal No: 002
Spec. Section: 21 13 00
Reviewed By: Scott Gurley
Date: 10/3/11

This review does not constitute nor does it assume design responsibility nor does it relieve the trade contractor/supplier from complying with the contract requirements, coordinating their work with other trade contractors and verifying field dimensions.

Gilbane

Cal Poly Center for Science
Gilbane Project #: 174338010


REVIEWED

Building Name/#: Cal Poly CFS
Bid Package No: 21A
Submittal No: 002
Spec. Section: 21 30 00
Reviewed By: Scott Gurley
Date: 10/3/11

This review does not constitute nor does it assume design responsibility nor does it relieve the trade contractor/supplier from complying with the contract requirements, coordinating their work with other trade contractors and verifying field dimensions.

This page intentionally left blank.

CAL POLY CENTER FOR SCIENCE CALIFORNIA POLYTECHNIC STATE UNIVERSITY SAN LUIS OBISPO, CA.



REGIONAL MAP N.T.S.



DESIGNED AND INSTALLED
BY

AERO AUTOMATIC
SPRINKLER CO.

SECTION 210000-
COMMON WORK
FIRE
SUPPRESSION
PART 1 GENERAL
1.1.3 SHOP DRAWINGS
SECTION 211200-
PIPE JOINTS
STANDPIPES
PART 1 GENERAL
1.4.3 SHOP DRAWINGS
SECTION 211300-
FIRE SUPPRESSION
SPRINKLER SYSTEMS
PART 1 GENERAL
1.4.3 SHOP DRAWINGS
SECTION 213000-
FIRE PUMP
PART 1 GENERAL
1.4.3 SHOP DRAWINGS

PROJECT DIRECTORY

OWNER CALIFORNIA STATE POLYTECHNIC UNIVERSITY
FACILITIES PLANNING & CAPITAL PROJECTS
BUILDING 70
SAN LUIS OBISPO, CA 93047
TEL- (805) 756-2581
FAX- (805) 756-7566

ARCHITECT ZIMMER GUNSUL FRASCA ARCHITECTS, LLP
515 SOUTH FLOWER ST.
SUITE 3700
LOS ANGELES, CA 90071
TEL- (213) 617-1901
FAX- (213) 617-0047

STRUCTURAL ENGINEER JOHN A. MARTIN & ASSOCIATES
950 S. GRAND AVENUE
4TH FLOOR
LOS ANGELES, CA 90015
TEL- (213) 483-6490
FAX- (213) 483-3084

MECHANICAL/PLUMBING ENGINEER RUMSEY ENGINEERS
99 LINDEN STREET
OAKLAND, CA 94607
TEL- (510) 663-2070
FAX- (510) 663-2080

ELECTRICAL ENGINEER INTEGRATED DESIGN ASSOCIATES
1084 FOXWORTHY AVENUE, SUITE 150
SAN JOSE, CA 95118
TEL- (408) 448-6300
FAX- (408) 448-6301

CIVIL ENGINEER CANNON ASSOCIATES
364 PACIFIC STREET
SAN LUIS OBISPO, CA 93041
TEL- (805) 544-7407
FAX- (805) 544-3863

LANDSCAPE ARCHITECT KATHERINE SPITZ ASSOCIATES
4212 1/2 GLENCOE AVENUE
MARINA DEL REY, CA 90292
TEL- (310) 574-4460
FAX- (310) 574-4462

LABORATORY CONSULTANT RESEARCH FACILITIES DESIGN
3965 FIFTH AVENUE, SUITE 300
SAN DIEGO, CA. 92103-3107
TEL- (619) 297-0159
FAX- (619) 294-4901

LIGHTING DESIGN DAVID NELSON AND ASSOCIATES, LLC
P.O. BOX 270254
LITTLETON, CO 80127
TEL- (720) 981-4560
FAX- (303) 484-3230

PROJECT DATA

NEW BUILDING DATA
NUMBER OF STORIES: SIX (6) STORIES
ZGF PROJECT NUMBER: L40302
TYPE CONSTRUCTION: 1B, FIRE-RESISTIVE
BUILDING OCCUPANCY: GROUP B, BUSINESS OCCUPANCY,
CONTAINING THE FOLLOWING USES:
OCCUPANCY

USE
LOBBIES/LECTURE A-3
OFFICES B
CONFERENCE ROOMS: B
(LESS THAN 50 OCCUPANTS)
LABORATORIES: B
ELECTRICAL AND TELEPHONE / DATA S-1
MECHANICAL ROOMS: S-1
STORAGE H-3
STORAGE S-2

FIRE PROTECTION: FULLY FIRE SPRINKLERED
HEIGHT: 108'
FLOOR AREA:

| FLOOR | SQ.FT |
|---------------|-----------------------|
| LEVEL ONE: | 23,148 G.S.F. |
| LEVEL TWO: | 43,458 G.S.F. |
| LEVEL THREE: | 43,209 G.S.F. |
| LEVEL FOUR: | 33,307 G.S.F. |
| LEVEL FIVE: | 25,294 G.S.F. |
| LEVEL SIX: | 19,958 G.S.F. |
| TOTAL: | 188,372 G.S.F. |

BUILDING CODES:
2007 (CBC) CALIFORNIA BUILDING CODE
2007 (FC) CALIFORNIA FIRE CODE
2007 (CMC) CALIFORNIA MECHANICAL CODE
2007 (CPC) CALIFORNIA PLUMBING CODE
2008 (NFPA 70) NATIONAL ELECTRICAL CODE
2008 (NFPA 101) LIFE SAFETY CODE
ADA STANDARDS FOR ACCESSIBLE DESIGN
ADA ACCESSIBILITY GUIDELINES FOR BUILDINGS AND FACILITIES (ADAA)
(28 CFR PART 36, APPENDIX A)
NFPA 13 - AUTOMATIC SPRINKLER SYSTEMS, 2007 EDITION.
NFPA 14 - STANDPIPE AND HOSE SYSTEMS, 2004 EDITION.
NFPA 20 - STATIONARY PUMPS FOR FIRE PROTECTION, 2003 EDITION.

FIRE PROTECTION SYMBOLS

| SYMBOL | DESCRIPTION |
|--------|------------------------------------|
| ● | RECESSED PENDENT SPRINKLER |
| ○ | HIGH TEMPERATURE PENDENT SPRINKLER |
| ○ | UPRIGHT SPRINKLER |
| ○ | EXT. COVERAGE PENDENT SPRINKLER |
| ○ | UPRIGHT SPRINKLER ON SPRIG UP |
| △ | HORZ. SIDEWALL SPRINKLER |
| ↑ | RISE OR DROP IN PIPING w/ TEE |
| ↘ | RISE OR DROP IN PIPING w/ ELBOW |
| — | PIPE HANGER LOCATIONS |
| — | PIPE HANGER LOCATION W/ STIFFNER |
| ○ | FIRE SPRINKLER RISER |
| — | INSPECTOR'S TEST CONNECTION |
| — | NEW PIPING |
| — | EXISTING PIPING |
| ○ | HYDRAULIC REFERENCE POINT |
| — | LATERAL SWAY BRACE |
| — | LONGITUDINAL SWAY BRACE |
| — | BRANCH LINE RESTRAINT (BLR) |
| + | 4 WAY SWAY BRACE |
| — | DECK TO CENTERLINE |
| — | CENTERLINE ABOVE FINISH FLOOR |
| * | DENOTES EXISTING 1" OUTLET |

SCOPE OF WORK / HAZARD ANALYSIS

PROVIDE A COMPLETE WET PIPE FIRE SPRINKLER SYSTEM FOR A NEW 6-STORY CLASSROOM/LABORATORY BUILDING WITH FIRE PUMP & CLASS 1 STANDPIPE SYSTEM. ALL SPRINKLERS TO BE QUICK RESPONSE TYPE UNLESS NOTED OTHERWISE. SPRINKLERS IN FINISHED CEILINGS TO BE RECESSED CHROME PENDENT SPRINKLERS. SPRINKLERS IN EXPOSED AREAS TO BE CHROME UPRIGHT OR PENDENT SPRINKLERS. PIPING TO BE BLACK STEEL SCHEDULE 10 AND SCHEDULE 40.

DESIGN CRITERIA:
OCCUPANCY CLASSIFICATION

| OCCUPANCY | HAZARD | MAX SPACING | DESIGN | HOSE |
|---------------------------|--------------|-------------|----------|---------|
| A-3 LOBBIES/LECTURE | LIGHT HAZARD | 225 | .10/1500 | 100/0 |
| B OFFICE/CONFERENCE RM | LIGHT HAZARD | 130 | .10/1500 | 100/0 |
| B LABORATORIES | O.H. GR. 1 | 130 | .15/1500 | 100/150 |
| S-1 STORAGE/MECH/ELECT RM | O.H. GR. 1 | 130 | .15/1500 | 100/150 |

ACTUAL FLOW TEST INFORMATION:
STATIC: 60 psi
RESIDUAL: 55 psi
FLOW: 914 gpm

REDUCED 10 PERCENT:
STATIC: 54 psi
RESIDUAL: 49 psi
FLOW: 914 gpm

TEST DATE: 8-19-2011 9:12 AM
ORIFICE SIZE: 2-1/2"
ORIFICE COEFFICIENT: 0.90


FLOW TEST PERFORMED BY FLUID RESOURCE MANAGEMENT
NOTE: FLOWING HYDRANT # 64 WITH STATIC & RESIDUAL PRESSURE FROM HYDRANT # 63

GENERAL SYSTEM NOTES:

- ALL SYSTEM PIPING SHALL BE HYDROSTATICALLY TESTED AT 200 PSI OR AT 50 PSI ABOVE THE OPERATIONAL STATIC PRESSURE OF THE SYSTEM, WHICHEVER IS GREATER FOR TWO HOURS.
- EACH VALVE SHALL HAVE A PERMANENTLY AFFIXED SIGN INDICATING ITS FUNCTION. ALL SPRINKLER SYSTEM CONTROL VALVE HANDLES TO BE LOCATED 7'-0" MAX. A.F.F.
- A STOCK OF SPARE SPRINKLERS OF EACH STYLE AND TEMPERATURE RATING, WITH A SPRINKLER WRENCH, SHALL BE LOCATED NEAR THE RISER WHERE THE TEMPERATURE TO WHICH THEY
- SPRINKLERS SHALL BE QUICK RESPONSE WITH CHROME RECESSED ESCUTCHEONS U.O.N. AND SHALL BE IN ALIGNMENT AND PARALLEL TO CEILING GRIDS. SPRINKLERS IN UNFINISHED AREAS TO BE TYCO MODEL TY-FRB QUICK RESPONSE BRASS UPRIGHT
- MAIN PIPING FOR THIS SYSTEM SHALL BE SCHEDULE 10 PIPE WITH GROOVED ENDS WITH APPLICABLE FITTINGS. BRANCH LINE CONNECTIONS TO THE MAIN SHALL BE PRE-DRILLED WITH SHOP WELDED OUTLETS. THREADED PIPING 1" TO 2" TO BE BLACK STEEL BMT SCHEDULE 40 WITH BLACK CAST IRON OR DUCTILE IRON FITTINGS. 1 1/4" AND LARGER BRANCH LINE & MAIN PIPING TO BE SCHEDULE 10 PIPE WITH GROOVED ENDS WITH GROOVED FITTINGS.
- ALL MATERIALS USED IN THE INSTALLATION OF THESE SYSTEMS SHALL BE NEW AND OF CURRENT ISSUE, AND APPROVED BY U.I. (UNDERWRITERS LAB) AND/OR FM (FACTORY MUTUAL). ALL MATERIALS SHALL BE IN CONFORMANCE WITH NFPA-13, 2007 AS WELL AS THE AUTHORITY HAVING JURISDICTION.
- SYSTEM PIPING WILL BE SUPPORTED WITH HANGERS IN ACCORDANCE WITH NFPA-13, 2007.
- SPACING AND DETAILS OF THE SUPPORT AND BRACING OF FIRE SPRINKLER PIPING SHALL COMPLY WITH THE 2007 EDITION OF NFPA 13.
- PAINTING OF THE SYSTEM PIPING AND COMPONENTS IS NOT PART OF THIS SCOPE AND, IF REQUIRED, IT SHALL BE PERFORMED BY OTHERS
- UNDERGROUND PIPING IS NOT PART OF THIS SCOPE. FIRE PROTECTION CONTRACT TO START AT FLANGE (BY OTHERS) AT 6" ABOVE FINISHED FLOOR.
- WIRING OF WATERFLOW SWITCH & CONTROL VALVE TAMPER SWITCHES BY OTHERS. ALL OTHER ALARM DEVICES TO BE PROVIDED, INSTALLED AND TESTED BY OTHERS

Sheet List Table

| Sheet Number | Sheet Title |
|--------------|----------------------------------|
| FP-1.0 | COVER SHEET |
| FP-2.0 | FIRE SPRINKLER SITE PLAN |
| FP-3.0 | FIRE PUMP PLAN |
| FP-4.0 | TEMP. STANDPIPE |
| FP-4.0 | STANDPIPE - OVERALL ISOMETRIC |
| FP-4.1 | STANDPIPE # 1 DETAILS |
| FP-4.2 | STANDPIPE # 3 DETAILS |
| FP-4.3 | STANDPIPE # 4 DETAILS |
| FP-4.4 | STANDPIPE # 5 DETAILS |
| FP-5.0 | HANGER & E.Q. DETAILS |
| FP-6.01W | FIRE SPRINKLER PLAN LEVEL 1 WEST |
| FP-6.02W | FIRE SPRINKLER PLAN LEVEL 2 WEST |
| FP-6.02E | FIRE SPRINKLER PLAN LEVEL 2 EAST |
| FP-6.03W | FIRE SPRINKLER PLAN LEVEL 3 WEST |
| FP-6.03E | FIRE SPRINKLER PLAN LEVEL 3 EAST |
| FP-6.04W | FIRE SPRINKLER PLAN LEVEL 4 WEST |
| FP-6.04E | FIRE SPRINKLER PLAN LEVEL 4 EAST |
| FP-6.05E | FIRE SPRINKLER PLAN LEVEL 5 EAST |
| FP-6.06E | FIRE SPRINKLER PLAN LEVEL 6 EAST |
| FP-7.01W | FIRE SPRINKLER RCP LEVEL 1 WEST |
| FP-7.02W | FIRE SPRINKLER RCP LEVEL 2 WEST |
| FP-7.02E | FIRE SPRINKLER RCP LEVEL 2 EAST |
| FP-7.03W | FIRE SPRINKLER RCP LEVEL 3 WEST |
| FP-7.03E | FIRE SPRINKLER RCP LEVEL 3 EAST |
| FP-7.04W | FIRE SPRINKLER RCP LEVEL 4 WEST |
| FP-7.04E | FIRE SPRINKLER RCP LEVEL 4 EAST |
| FP-7.05E | FIRE SPRINKLER RCP LEVEL 5 EAST |
| FP-7.06E | FIRE SPRINKLER RCP LEVEL 6 EAST |



VICINITY MAP
1 INCH = 50 FEET

IDENTIFICATION STAMP
DIV. OF THE STATE ARCHITECT
OFFICE OF REGULATION SERVICES
APPL 01-110181

REGISTERED PROFESSIONAL ENGINEER
GEORGE PROVENZANO
No. 12511
Exp. 12-31-11
CALIFORNIA
01/29/11

AERO AUTOMATIC SPRINKLER CO.
623.980.7900
21605 North Central Ave., Phoenix, Arizona 85024
AZ-LIB-234798 AZ-CIB-901629 AZ-CAT-98370 UT-5870-6690456-5001

CAL POLY CENTER FOR SCIENCE
CALIFORNIA POLYTECHNIC STATE UNIVERSITY
SAN LUIS OBISPO, CA.
CONTRACT WITH: **GILBANE CONSTRUCTION**
8245 GREENWICH DRIVE, SUITE 103
SAN DIEGO, CA. 92122
FORM REGISTRATION NO. 10034


PROJECT: CAL POLY CENTER FOR SCIENCE
DRAWN BY: NRL
SCALE: AS NOTED
DATE: 8-15-2011
CONTRACT: 10034
SHEET: FP-1.0

REVISIONS
NO. DATE BY DESCRIPTION
1 08/15/11 NRL SUBMITTAL TO GENERAL CONTRACTOR

ESCAPES
ESCUTCHEON
SYMBOL MFG. MODEL SIN. RESP. FINISH N.P.T. ORIFICE K TEMP. QTY.



SPRINKLER HEAD LEGEND

TOTAL SPRINKLERS THIS SHEET: QTY.



| FLOW TEST SUMMARY | |
|---|-------|
| STATIC PSI | 60 |
| RESIDUAL PSI | 55 |
| PITOT PSI | 35 |
| ORIFICE DIAMETER | 2 1/2 |
| COEFFICIENT OF DISCHARGE | 0.9 |
| GPM | 914 |
| DATE: 8-19-2011 | |
| LOCATION: N. POLY VIEW DRIVE | |
| BY WHO: FLUID RESOURCE MANAGEMENT, INC. | |
| ADJUSTED FLOW 10% REDUCTION | |
| STATIC PSI | 54 |
| RESIDUAL PSI | 49 |
| GPM | 914 |

STATIC & RESIDUAL TAKEN FROM HYD. # 63
FLOW TAKEN FROM HYD. # 64




NOTES:


- ALL MATERIAL USED AS TRENCH BACKFILL SHALL BE FREE OF DEBRIS, TRASH, OLD PAVEMENT AND ORGANIC MATERIAL, AND SHALL BE CLEARED OF ANY ROCKS AND IRREDUCIBLE MATERIAL LARGER THAN 3 INCHES.
- WHEN BACKFILL MATERIAL INCLUDES ROCKS, THE ROCKS SHALL BE PLACED IN A SUFFICIENT SOIL MATRIX TO ENSURE THAT VOIDS CAUSED BY NESTING OF THE ROCKS WILL NOT OCCUR AND THAT THE FILL CAN BE PROPERLY COMPACTED.
- SELECT BEDDING SHALL NOT CONTAIN ANY ROCKS.
- THE PAVEMENT AND LANDSCAPED AREAS SHALL BE INSTALLED PER APPROPRIATE PLANS AND SPECIFICATIONS.
- No. 12 AWG LOCATOR WIRE SHALL BE TAPED TO THE TOP OF ALL PIPES.



NOTE: UTILITY PLAN PREVIOUSLY APPROVED BY THE OFFICE OF STATE FIRE MARSHAL (FIRE and PANIC ONLY) ON NOV. 10, 2009. THESE DETAILS ARE ALL FROM THAT CIVIL PACKAGE.




| PIPE SIZE | BEARING SIZE |
|-----------|--------------|
| 12" | 15 S.F. |
| 10" | 11 S.F. |
| 8" | 7 S.F. |
| 6" | 4 S.F. |
| 4" | 2 S.F. |



| REDUCER SIZE | BEARING AREA | |
|--------------|--------------|-----------|
| | LARGE END | SMALL END |
| 12" | 8" | 9 S.F. |
| 10" | 6" | 5 S.F. |
| 8" | 6" | 4 S.F. |

NOTE: BEARING AREA SHALL BE AGAINST UNDISTURBED EARTH
ALL BOLTS AND FITTINGS SHALL BE COVERED AND TAPED WITH PLASTIC WRAP, CUMULATIVE 15 MIL. CONCRETE SHALL BE 5-SACK, 2500 PSI

| PIPE SIZE | BEARING AREA | | | |
|-----------|--------------|---------|---------|---------|
| | 11-1/4" | 22-1/2" | 45" | 90" |
| 12" | 3 S.F. | 6 S.F. | 12 S.F. | 21 S.F. |
| 10" | 2 S.F. | 4 S.F. | 8 S.F. | 15 S.F. |
| 8" | 2 S.F. | 3 S.F. | 5 S.F. | 10 S.F. |
| 6" | 1 S.F. | 2 S.F. | 3 S.F. | 4 S.F. |
| 4" | 1 S.F. | 1 S.F. | 1 S.F. | 2 S.F. |




- NOTE:
1. CONCRETE BLOCK SHOULD BE APPROX. EQUAL IN ALL DIMENSIONS.
2. ALL BOLTED FLANGED ITEMS SHALL HAVE CUMULATIVE 15 MIL PLASTIC WRAP AND TAPED COVERING BOLTS AND FITTINGS.

| CONCRETE VOLUMES | | | |
|------------------|--------|-------|-------|
| PIPE SIZE | BEND | BEND | BEND |
| 12" | 1 YD | 3 YDS | 6 YDS |
| 10" | 1 YD | 2 YDS | 4 YDS |
| 8" | 0.5 YD | 1 YD | 2 YDS |

| BEARING AREA | | | |
|--------------|---------|---------|---------|
| PIPE SIZE | 11-1/4" | 22-1/2" | 45" |
| 12" | 3 S.F. | 6 S.F. | 12 S.F. |
| 10" | 2 S.F. | 4 S.F. | 8 S.F. |
| 8" | 2 S.F. | 3 S.F. | 5 S.F. |
| 6" | 1 S.F. | 2 S.F. | 3 S.F. |
| 4" | 1 S.F. | 1 S.F. | 2 S.F. |

P DOUBLE CHECK ASSEMBLY
N.T.S.



L GATE VALVE BOX & ANCHOR
N.T.S.

IDENTIFICATION STAMP
DIV. OF THE STATE ARCHITECT
OFFICE OF REGULATION SERVICES
APPL 01-110181



| | | | |
|---|--|-----------------------------|--|
| PROJECT: CAL POLY CENTER FOR SCIENCE | | DRAWN BY: NRL | |
| CALIFORNIA POLYTECHNIC STATE UNIVERSITY | | SCALE: AS NOTED | |
| SAN LUIS OBISPO, CA | | DATE: 8-15-2011 | |
| GILBANE CONSTRUCTION | | CONTRACT: 10034 | |
| 6265 GREENWICH DRIVE, SUITE 103 | | SHEET: FP-2.0 | |
| SAN DIEGO, CA 92122 | | TOTAL SPRINKLERS THIS SHEET | |
| PROJECT NO: 9800456-5501 | | REVISIONS | |
| AUTOMATIC SPRINKLER CO. | | DATE BY DESCRIPTION | |
| 21605 North Central Ave. | | | |
| Phoenix, Arizona 85024 | | | |
| Tel: 602-997-7800 | | | |
| Fax: 602-997-0104 | | | |
| CA-CIP-401029 | | | |
| AZ-LIC-202798 | | | |
| UT-5970-6800456-5501 | | | |
| NM-MB 12-344807 | | | |

CALCULATION DESIGN INFORMATION

STANDPIPE NO.: S/P # 1
 OCCUPANCY: LIGHT / ORD. HAZ. DR. 1
 FLOW @ TOP MOST OUTLET: 500 GPM
 PRESS. @ TOP MOST OUTLET: 100 PSI
 FLOW FOR ADDITIONAL S/P: 250 GPM
 TOTAL STANDPIPE FLOW: 750 GPM
 HOSE STREAM ALLOWANCE:
 INSIDE: N/A OUTSIDE: N/A

SYSTEM DEMAND

PSI REQ. AT PUMP DISCHARGE: 156.36
 GPM REQ. AT PUMP DISCHARGE: 1000
 PSI REQ. AT SOURCE: 44.73
 GPM REQ. AT SOURCE: 750
 PSI AVAILABLE AT SOURCE: 50.52
 TOTAL PSI SAFETY FACTOR: 5.79

18"x18"x8" RECESSED FIRE HOSE VA. CABINET CROKER FIG. 1700 W/ FULL WIRED GLASS (FW)

2 1/2" FIRE HOSE VA. CROKER FIG. 5035 POLISH BRASS W/ 2 1/2"x1 1/2" ADAPTER W/ 1 1/2" CAP & CHAIN

CALCULATION DESIGN INFORMATION

STANDPIPE NO.: S/P # 1
 OCCUPANCY: LIGHT / ORD. HAZ. DR. 1
 FLOW @ TOP MOST OUTLET: 500 GPM
 PRESS. @ TOP MOST OUTLET: 100 PSI
 FLOW FOR ADDITIONAL S/P: 500 GPM
 TOTAL STANDPIPE FLOW: 1000 GPM
 HOSE STREAM ALLOWANCE:
 INSIDE: N/A OUTSIDE: N/A

SYSTEM DEMAND

PSI REQ. AT PUMP DISCHARGE: 144.08
 GPM REQ. AT PUMP DISCHARGE: 1000
 PSI REQ. AT SOURCE: 47.18
 GPM REQ. AT SOURCE: 1000
 PSI AVAILABLE AT SOURCE: 48.92
 TOTAL PSI SAFETY FACTOR: 0.91

6" GRV. BUTTERFLY VA. W/ BUILT-IN TAMPER SW (WIRING BY OTHER) [STANDPIPE ISOLATION VA.]


1 STAIR #1 - SECTION
 FP-4.1 SCALE: 1/4" = 1'-0" 1 1/2 2 3 4
 SCALE 1/4"=1'-0"

1A STAIR #1 - LEVEL 3
 FP-4.1 SCALE: 1/4" = 1'-0" 1 1/2 2 3 4
 SCALE 1/4"=1'-0"


1C STAIR #1 - LEVEL 5
 FP-4.1 SCALE: 1/4" = 1'-0" 1 1/2 2 3 4
 SCALE 1/4"=1'-0"

1B STAIR #1 - LEVEL 4
 FP-4.1 SCALE: 1/4" = 1'-0" 1 1/2 2 3 4
 SCALE 1/4"=1'-0"


1D STAIR #1 - LEVEL 6
 FP-4.1 SCALE: 1/4" = 1'-0" 1 1/2 2 3 4
 SCALE 1/4"=1'-0"




| SYMBOL | | DESC. | QTY. |
|--|----|---|------|
| SPRINKLER HEAD | ES | ESCUITCHEON | |
| SPRINKLER HEAD LEGEND | SN | RESPIR. STYLE FINISH N.O.T. ORIFICE K TEMP. | |
| <p>AUTOMATIC SPRINKLER CO. 2905 South Central Ave. Phoenix, Arizona 85024 AZ 46-224799 UT-8970-6690455-5001</p> | | | |
| <p>CAL POLY CENTER FOR SCIENCE CALIFORNIA STATE UNIVERSITY SAN LUIS OBISPO, CA</p> | | | |
| <p>GILBANE CONSTRUCTION 6345 GREENVIEW DRIVE, SUITE 103 SAN DIEGO, CA 92122</p> | | | |
| <p>STANDPIPE # 1 DETAILS</p> | | | |
| DRAWN BY: | | DATE: 8-15-2011 | |
| SCALE: 1/4"=1'-0" | | CONTRACT: 10034 | |
| PROJECT: | | SHEET: FP-4.1 | |
| TOTAL SPRINKLERS THIS SHEET | | QTY REVISIONS | |




1 SECTION- STAIR #3
FP-4.2 SCALE: 1/4" = 1'-0"




1B STAIR #3 - LEVEL 3
FP-4.2 SCALE: 1/4" = 1'-0"




1D STAIR #3 - LEVEL 5
FP-4.2 SCALE: 1/4" = 1'-0"




1A STAIR #3 - LEVEL 2
FP-4.2 SCALE: 1/4" = 1'-0"




1C STAIR #3 - LEVEL 4
FP-4.2 SCALE: 1/4" = 1'-0"



1F STAIR #3 - ROOF LEVEL
FP-4.2 SCALE: 1/4" = 1'-0"



1E STAIR #3 - LEVEL 6
FP-4.2 SCALE: 1/4" = 1'-0"



| SYMBOL | DESC. | QTY. | UNIT | TOTAL |
|-----------------------------|-------|--------|-------------|-------|
| SPRINKLER HEAD LEGEND | | | | |
| ESC. | TYPE | FINISH | TEMP. | QTY. |
| ESCALATOR | | | | |
| TOTAL SPRINKLERS THIS SHEET | | | | |
| QTY. REVISIONS | | | | |
| NO. | DATE | BY | DESCRIPTION | |
| 1 | | | | |
| 2 | | | | |
| 3 | | | | |
| 4 | | | | |
| 5 | | | | |
| 6 | | | | |
| 7 | | | | |
| 8 | | | | |
| 9 | | | | |
| 10 | | | | |
| 11 | | | | |
| 12 | | | | |
| 13 | | | | |
| 14 | | | | |
| 15 | | | | |
| 16 | | | | |
| 17 | | | | |
| 18 | | | | |
| 19 | | | | |
| 20 | | | | |
| 21 | | | | |
| 22 | | | | |
| 23 | | | | |
| 24 | | | | |
| 25 | | | | |
| 26 | | | | |
| 27 | | | | |
| 28 | | | | |
| 29 | | | | |
| 30 | | | | |
| 31 | | | | |
| 32 | | | | |
| 33 | | | | |
| 34 | | | | |
| 35 | | | | |
| 36 | | | | |
| 37 | | | | |
| 38 | | | | |
| 39 | | | | |
| 40 | | | | |
| 41 | | | | |
| 42 | | | | |
| 43 | | | | |
| 44 | | | | |
| 45 | | | | |
| 46 | | | | |
| 47 | | | | |
| 48 | | | | |
| 49 | | | | |
| 50 | | | | |
| 51 | | | | |
| 52 | | | | |
| 53 | | | | |
| 54 | | | | |
| 55 | | | | |
| 56 | | | | |
| 57 | | | | |
| 58 | | | | |
| 59 | | | | |
| 60 | | | | |
| 61 | | | | |
| 62 | | | | |
| 63 | | | | |
| 64 | | | | |
| 65 | | | | |
| 66 | | | | |
| 67 | | | | |
| 68 | | | | |
| 69 | | | | |
| 70 | | | | |
| 71 | | | | |
| 72 | | | | |
| 73 | | | | |
| 74 | | | | |
| 75 | | | | |
| 76 | | | | |
| 77 | | | | |
| 78 | | | | |
| 79 | | | | |
| 80 | | | | |
| 81 | | | | |
| 82 | | | | |
| 83 | | | | |
| 84 | | | | |
| 85 | | | | |
| 86 | | | | |
| 87 | | | | |
| 88 | | | | |
| 89 | | | | |
| 90 | | | | |
| 91 | | | | |
| 92 | | | | |
| 93 | | | | |
| 94 | | | | |
| 95 | | | | |
| 96 | | | | |
| 97 | | | | |
| 98 | | | | |
| 99 | | | | |
| 100 | | | | |

AUTOMATIC SPRINKLER CO.
AERO
 9605 North Central Ave. 650.850.7900
 Phoenix, Arizona 85024 Fax 602.640.6764
 CA-CH-901029
 AZ-LE-200798
 UT-5070-690455-5001 NNA-M9 12-30-94-07

CAL POLY CENTER FOR SCIENCE
 CALIFORNIA POLYTECHNIC STATE UNIVERSITY
 SAN LUIS OBISPO, CA

GILBANE CONSTRUCTION
 3215 GILBANE BLVD. SUITE 103
 SAN DIEGO, CA 92122
 (619) 520-9900

STAIRPIPE # 3 DETAILS


DRAWN BY: [Signature]
 SCALE: 1/4" = 1'-0"
 DATE: 8-15-2011
 CONTRACT: 10034
 SHEET: FP-4.2

CALCULATION DESIGN INFORMATION


STANDPIPE NO.: S/P # 5
 OCCUPANCY: LIGHT / ORD. HAZ. DR. 1
 FLOW @ TOP MOST OUTLET: 500 GPM
 PRESS. @ TOP MOST OUTLET: 100 PSI
 FLOW FOR ADDITIONAL SP: 500 GPM
 TOTAL STANDPIPE FLOW: 1000 GPM
 HOSE STREAM ALLOWANCE:
 INSIDE: N/A OUTSIDE: N/A

SYSTEM DEMAND


PSI REQ. AT PUMP DISCHARGE: 143.7
 GPM REQ. AT PUMP DISCHARGE: 1000
 PSI REQ. AT SOURCE: 46.80
 GPM REQ. AT SOURCE: 1000
 PSI AVAILABLE AT SOURCE: 48.08
 TOTAL PSI SAFETY FACTOR: 1.28




1 SECTION-STAIR #5
 FP-4.4 SCALE: 1/4" = 1'-0"



1A STAIR #5 - LEVEL 1
 FP-4.4 SCALE: 1/4" = 1'-0"




1B STAIR #5 - LEVEL 2
 FP-4.4 SCALE: 1/4" = 1'-0"



1C STAIR #5 - LEVEL 3
 FP-4.4 SCALE: 1/4" = 1'-0"

| SYMBOL | INFO. | MODEL | SN | RESP | STYLE | FINISH | N.P.T. | BRICE | K | TEMP. | ESC. TYPE | FINISH | TEMP. | QTY. |
|--------|-------|-------|----|------|-------|--------|--------|-------|---|-------|-----------|--------|-------|------|
| SP5 | | | | | | | | | | | ES | | | |
| SP6 | | | | | | | | | | | ES | | | |
| SP7 | | | | | | | | | | | ES | | | |
| SP8 | | | | | | | | | | | ES | | | |
| SP9 | | | | | | | | | | | ES | | | |
| SP10 | | | | | | | | | | | ES | | | |
| SP11 | | | | | | | | | | | ES | | | |
| SP12 | | | | | | | | | | | ES | | | |
| SP13 | | | | | | | | | | | ES | | | |
| SP14 | | | | | | | | | | | ES | | | |
| SP15 | | | | | | | | | | | ES | | | |
| SP16 | | | | | | | | | | | ES | | | |
| SP17 | | | | | | | | | | | ES | | | |
| SP18 | | | | | | | | | | | ES | | | |
| SP19 | | | | | | | | | | | ES | | | |
| SP20 | | | | | | | | | | | ES | | | |
| SP21 | | | | | | | | | | | ES | | | |
| SP22 | | | | | | | | | | | ES | | | |
| SP23 | | | | | | | | | | | ES | | | |
| SP24 | | | | | | | | | | | ES | | | |
| SP25 | | | | | | | | | | | ES | | | |
| SP26 | | | | | | | | | | | ES | | | |
| SP27 | | | | | | | | | | | ES | | | |
| SP28 | | | | | | | | | | | ES | | | |
| SP29 | | | | | | | | | | | ES | | | |
| SP30 | | | | | | | | | | | ES | | | |
| SP31 | | | | | | | | | | | ES | | | |
| SP32 | | | | | | | | | | | ES | | | |
| SP33 | | | | | | | | | | | ES | | | |
| SP34 | | | | | | | | | | | ES | | | |
| SP35 | | | | | | | | | | | ES | | | |
| SP36 | | | | | | | | | | | ES | | | |
| SP37 | | | | | | | | | | | ES | | | |
| SP38 | | | | | | | | | | | ES | | | |
| SP39 | | | | | | | | | | | ES | | | |
| SP40 | | | | | | | | | | | ES | | | |
| SP41 | | | | | | | | | | | ES | | | |
| SP42 | | | | | | | | | | | ES | | | |
| SP43 | | | | | | | | | | | ES | | | |
| SP44 | | | | | | | | | | | ES | | | |
| SP45 | | | | | | | | | | | ES | | | |
| SP46 | | | | | | | | | | | ES | | | |
| SP47 | | | | | | | | | | | ES | | | |
| SP48 | | | | | | | | | | | ES | | | |
| SP49 | | | | | | | | | | | ES | | | |
| SP50 | | | | | | | | | | | ES | | | |
| SP51 | | | | | | | | | | | ES | | | |
| SP52 | | | | | | | | | | | ES | | | |
| SP53 | | | | | | | | | | | ES | | | |
| SP54 | | | | | | | | | | | ES | | | |
| SP55 | | | | | | | | | | | ES | | | |
| SP56 | | | | | | | | | | | ES | | | |
| SP57 | | | | | | | | | | | ES | | | |
| SP58 | | | | | | | | | | | ES | | | |
| SP59 | | | | | | | | | | | ES | | | |
| SP60 | | | | | | | | | | | ES | | | |
| SP61 | | | | | | | | | | | ES | | | |
| SP62 | | | | | | | | | | | ES | | | |
| SP63 | | | | | | | | | | | ES | | | |
| SP64 | | | | | | | | | | | ES | | | |
| SP65 | | | | | | | | | | | ES | | | |
| SP66 | | | | | | | | | | | ES | | | |
| SP67 | | | | | | | | | | | ES | | | |
| SP68 | | | | | | | | | | | ES | | | |
| SP69 | | | | | | | | | | | ES | | | |
| SP70 | | | | | | | | | | | ES | | | |
| SP71 | | | | | | | | | | | ES | | | |
| SP72 | | | | | | | | | | | ES | | | |
| SP73 | | | | | | | | | | | ES | | | |
| SP74 | | | | | | | | | | | ES | | | |
| SP75 | | | | | | | | | | | ES | | | |
| SP76 | | | | | | | | | | | ES | | | |
| SP77 | | | | | | | | | | | ES | | | |
| SP78 | | | | | | | | | | | ES | | | |
| SP79 | | | | | | | | | | | ES | | | |
| SP80 | | | | | | | | | | | ES | | | |
| SP81 | | | | | | | | | | | ES | | | |
| SP82 | | | | | | | | | | | ES | | | |
| SP83 | | | | | | | | | | | ES | | | |
| SP84 | | | | | | | | | | | ES | | | |
| SP85 | | | | | | | | | | | ES | | | |
| SP86 | | | | | | | | | | | ES | | | |
| SP87 | | | | | | | | | | | ES | | | |
| SP88 | | | | | | | | | | | ES | | | |
| SP89 | | | | | | | | | | | ES | | | |
| SP90 | | | | | | | | | | | ES | | | |
| SP91 | | | | | | | | | | | ES | | | |
| SP92 | | | | | | | | | | | ES | | | |
| SP93 | | | | | | | | | | | ES | | | |
| SP94 | | | | | | | | | | | ES | | | |
| SP95 | | | | | | | | | | | ES | | | |
| SP96 | | | | | | | | | | | ES | | | |
| SP97 | | | | | | | | | | | ES | | | |
| SP98 | | | | | | | | | | | ES | | | |
| SP99 | | | | | | | | | | | ES | | | |
| SP100 | | | | | | | | | | | ES | | | |




AERD AUTOMATIC SPRINKLER CO.
 21005 North Central Ave.
 Phoenix, Arizona 85024
 AZ-16-234798
 UT-8970-880458-5501



682.667.7800
 Fax 624.640.0504
 CA-CR-806229
 NV-NB 92-54907

CAL POLY CENTER FOR SCIENCE
 CALIFORNIA POLYTECHNIC STATE UNIVERSITY
 SAN LUIS OBISPO, CA

GILBANE CONSTRUCTION
 1616 BEECHWICH DRIVE, SUITE 103
 SAN DIEGO, CA 92122

DATE: 8-15-2011
 SCALE: 1/4" = 1'-0"
 CONTRACT: 10034
 SHEET: FP-4.4





Tol-Brace Seismic Calculations

Project Address: Cal Poly Center for Science, 21605 N. Central Ave., Phoenix, Az. 85024
California Polytechnic State University, (623)580-7847, San Luis Obispo, Ca., Job # 10034
Aero Automatic Sprinkler Co., 21605 N. Central Ave., Phoenix, Az. 85024, (623)580-7847, CA-C16-901529
Calculations based on 2007 NFPA Pamphlet #13

| Brace Information | | Tolco Brace Components | |
|---|---------------------|---|-------------------|
| Maximum Spacing | 40' 0" (12.19 m) | Tolco Component Fig. Number | Adjusted Load |
| Maximum Brace Length | 7' 0" (2.14 m) | Fig.1001 Clamp | 1007 lbs (457 kg) |
| Bracing Material | 1" Sch.40 | Fig.980 Universal Swivel | 1382 lbs (627 kg) |
| Angle from Vertical | 30° Min. | *Calculation Based on CONCENTRIC Loading *Please Note: These calculations are for Tolco components only. Use of any other components voids these calculations and the listing of the assembly. | |
| Least Rad. of Gyration | 0.421" (11 mm) | | |
| L/R Value | 200 | | |
| Max Horizontal Load | 1227 lbs (557 kg) | Brace Identification on Plans LAT 1 Orientation of Brace Lateral | |
| Force Factor (Cp) | 0.61 | | |
| Fastener Information | | | |
| Fastener Orientation | NFPA Type A | | |
| Type | HILTI-TZ | | |
| Diameter | 1/2" | | |
| Length | 3 3/4" | | |
| Maximum Load | 1412 lbs (640 kg) | | |
| Load Information | | | |
| Braced Pipe: 6" Sch.40 Steel Pipe | | | |
| Size and Type of Pipe | Total Length | Total Calculated Load | |
| 6" Sch.40 Steel Pipe (152.4 mm) | 408 (12.2 m) | 773 lbs (351 kg) | |
| Percentage added for Fittings and Sprinklers | 15% | 116 lbs (52.62 kg) | |
| Total Adjusted Load of all pipe within Zone of Influence | | 889 lbs (403 kg) | |

Tol-Brace Seismic Calculations

Project Address: Cal Poly Center for Science, 21605 N. Central Ave., Phoenix, Az. 85024
California Polytechnic State University, (623)580-7847, San Luis Obispo, Ca., Job # 10034
Aero Automatic Sprinkler Co., 21605 N. Central Ave., Phoenix, Az. 85024, (623)580-7847, CA-C16-901529
Calculations based on 2007 NFPA Pamphlet #13

| Brace Information | | Tolco Brace Components | |
|---|---------------------|---|-------------------|
| Maximum Spacing | 45' 0" (13.72 m) | Tolco Component Fig. Number | Adjusted Load |
| Maximum Brace Length | 7' 0" (2.14 m) | Fig.4A Clamp | 1007 lbs (457 kg) |
| Bracing Material | 1" Sch.40 | Fig.980 Universal Swivel | 1382 lbs (627 kg) |
| Angle from Vertical | 30° Min. | *Calculation Based on CONCENTRIC Loading *Please Note: These calculations are for Tolco components only. Use of any other components voids these calculations and the listing of the assembly. | |
| Least Rad. of Gyration | 0.421" (11 mm) | | |
| L/R Value | 200 | | |
| Max Horizontal Load | 1227 lbs (557 kg) | Brace Identification on Plans LONG 1 Orientation of Brace Longitudinal | |
| Force Factor (Cp) | 0.61 | | |
| Fastener Information | | | |
| Fastener Orientation | NFPA Type A | | |
| Type | HILTI-TZ | | |
| Diameter | 1/2" | | |
| Length | 3 3/4" | | |
| Maximum Load | 1412 lbs (640 kg) | | |
| Load Information | | | |
| Braced Pipe: 6" Sch.40 Steel Pipe | | | |
| Size and Type of Pipe | Total Length | Total Calculated Load | |
| 6" Sch.40 Steel Pipe (152.4 mm) | 458 (13.7 m) | 870 lbs (395 kg) | |
| Percentage added for Fittings and Sprinklers | 15% | 130 lbs (58.87 kg) | |
| Total Adjusted Load of all pipe within Zone of Influence | | 1000 lbs (454 kg) | |

SPRINKLER PIPE HANGER SPACING
N.F.P.A. 13, 2007 EDITION

TABLE 9.2.1 MAXIMUM DISTANCE BETWEEN HANGERS (FT-IN.)

| NOMINAL PIPE SIZE | 3/4" | 1" | 1 1/4" | 1 1/2" | 2" | 2 1/2" | 3" & 4" | 6" | 8" |
|--------------------|------|------|--------|--------|------|--------|---------|------|------|
| STEEL PIPE | N/A | 12-0 | 12-0 | 15-0 | 15-0 | 15-0 | 15-0 | 15-0 | 15-0 |
| THREADED LIGHTWALL | N/A | 12-0 | 12-0 | 12-0 | 12-0 | | | N/A | N/A |
| COPPER TUBE | | | | | | | | | |
| CPVC | 5-6 | 6-0 | 6-6 | 7-0 | 8-0 | 9-0 | N/A | N/A | N/A |

FIGURE A-9.2.3.4 DISTANCE FROM SPRINKLER TO HANGER


12" MAX. FOR 1" DIA. (100 psi)
12" MAX. FOR 1 1/4" DIA. (100 psi)
12" MAX. FOR 1 1/2" DIA. OR LARGER

PER TABLE 9.2.1
IF GREATER THAN 12" MAX. FOR 1" DIA.
IF GREATER THAN 12" MAX. FOR 1 1/4" DIA.
IF GREATER THAN 12" FOR 1 1/2" DIA. OR LARGER

TABLE 9.1.2.1 HANGER ROD SIZE

| PIPE SIZE | DIAMETER OF ROD | PIPE SIZE | DIAMETER OF ROD |
|------------------------|-----------------|-----------|-----------------|
| UP TO AND INCLUDING 4" | 3/8" | 6" AND 8" | 1/2" |

THE CUMULATIVE HORIZONTAL LENGTH OF AN UNSUPPORTED ARMOUR TO A SPRINKLER, SPRINKLER DROP, OR SPRIG-UP SHALL NOT EXCEED 12 IN. FOR STEEL OR 6 IN. FOR COPPER TUBE. (PRESSURE EXCEEDS 100 psi)




- NOTES**
- LAT 1 TO BE USED FOR LATERAL SWAY BRACING OF SPRINKLER SYSTEM 6" MAINS. MAX SPACING 40'-0".
 - LAT 2 TO BE USED FOR LATERAL SWAY BRACING OF SPRINKLER SYSTEM 3" OR 2 1/2" MAINS WITH BRANCH LINES. MAX SPACING 35'-0".
 - LONG 1 TO BE USED FOR LONGITUDINAL SWAY BRACING OF SPRINKLER SYSTEM 6" MAINS. MAX SPACING 45'-0".
 - LONG 2 TO BE USED FOR LONGITUDINAL SWAY BRACING OF SPRINKLER SYSTEM 3" OR 2 1/2" MAINS. MAX SPACING 80'-0".

SEISMIC CRITERIA

SEISMIC DESIGN CATEGORY: D
SEISMIC IMP. FACTOR: 1.0
SITE SOIL PROFILE TYPE: B
SPECTRAL RESPONSE ACCELERATIONS:
S_s = 1.26*
S₁ = 0.481*

SEISMIC COEFFICIENT: Cp = 0.61**

*S_s & S₁ VALUES TAKEN FROM STRUCTURAL DRAWING S 1.01 - DATED 10-23-2009
** VALUE INTERPOLATED FROM TABLE 9.3.5.6.2 OF N.F.P.A.



WEIGHT OF WATER FILLED PIPE [LB./FT.]

| | NOMINAL SIZE | 1" | 1 1/4" | 1 1/2" | 2" | 2 1/2" | 3" | 4" | 6" | 8" | |
|--------------------------|--------------|------|----------|----------|----------|--------|------|-------|-------|-------|-------|
| THREADED OR GROOVED PIPE | SCHEDULE 40 | I.D. | 2.05 | 2.93 | 3.61 | 5.13 | 7.89 | 10.82 | 16.40 | 31.69 | 47.70 |
| GROOVED PIPE | SCHEDULE 10 | I.D. | NOT USED | NOT USED | NOT USED | 4.22 | 5.89 | 7.94 | 11.78 | 23.03 | 40.08 |

Tol-Brace Seismic Calculations

Project Address: Cal Poly Center for Science, 21605 N. Central Ave., Phoenix, Az. 85024
California Polytechnic State University, (623)580-7847, San Luis Obispo, Ca., Job # 10034
Aero Automatic Sprinkler Co., 21605 N. Central Ave., Phoenix, Az. 85024, (623)580-7847, CA-C16-901529
Calculations based on 2007 NFPA Pamphlet #13

| Brace Information | | Tolco Brace Components | |
|---|---------------------|---|-------------------|
| Maximum Spacing | 35' 0" (10.67 m) | Tolco Component Fig. Number | Adjusted Load |
| Maximum Brace Length | 7' 0" (2.14 m) | Fig.1001 Clamp | 1007 lbs (457 kg) |
| Bracing Material | 1" Sch.40 | Fig.980 Universal Swivel | 1382 lbs (627 kg) |
| Angle from Vertical | 30° Min. | *Calculation Based on CONCENTRIC Loading *Please Note: These calculations are for Tolco components only. Use of any other components voids these calculations and the listing of the assembly. | |
| Least Rad. of Gyration | 0.421" (11 mm) | | |
| L/R Value | 200 | | |
| Max Horizontal Load | 1227 lbs (557 kg) | Brace Identification on Plans LAT 2 Orientation of Brace Lateral | |
| Force Factor (Cp) | 0.61 | | |
| Fastener Information | | | |
| Fastener Orientation | NFPA Type A | | |
| Type | HILTI-TZ | | |
| Diameter | 1/2" | | |
| Length | 3 3/4" | | |
| Maximum Load | 1412 lbs (640 kg) | | |
| Load Information | | | |
| Braced Pipe: 3" Sch.10 Steel Pipe | | | |
| Size and Type of Pipe | Total Length | Total Calculated Load | |
| 3" Sch.10 Steel Pipe (76.2 mm) | 358 (10.7 m) | 170 lbs (77 kg) | |
| 1.5" Sch.40 Steel Pipe (38.1 mm) | 108 (3 m) | 22 lbs (10 kg) | |
| 1.25" Sch.40 Steel Pipe (31.75 mm) | 318 (9.4 m) | 55 lbs (25 kg) | |
| 1" Sch.40 Steel Pipe (25.4 mm) | 1408 (42.7 m) | 175 lbs (79 kg) | |
| Percentage added for Fittings and Sprinklers | 15% | 63 lbs (28.56 kg) | |
| Total Adjusted Load of all pipe within Zone of Influence | | 485 lbs (220 kg) | |

Tol-Brace Seismic Calculations

Project Address: Cal Poly Center for Science, 21605 N. Central Ave., Phoenix, Az. 85024
California Polytechnic State University, (623)580-7847, San Luis Obispo, Ca., Job # 10034
Aero Automatic Sprinkler Co., 21605 N. Central Ave., Phoenix, Az. 85024, (623)580-7847, CA-C16-901529
Calculations based on 2007 NFPA Pamphlet #13

| Brace Information | | Tolco Brace Components | |
|---|---------------------|---|-------------------|
| Maximum Spacing | 80' 0" (24.38 m) | Tolco Component Fig. Number | Adjusted Load |
| Maximum Brace Length | 7' 0" (2.14 m) | Fig.4L Clamp | 1007 lbs (457 kg) |
| Bracing Material | 1" Sch.40 | Fig.980 Universal Swivel | 1382 lbs (627 kg) |
| Angle from Vertical | 30° Min. | *Calculation Based on CONCENTRIC Loading *Please Note: These calculations are for Tolco components only. Use of any other components voids these calculations and the listing of the assembly. | |
| Least Rad. of Gyration | 0.421" (11 mm) | | |
| L/R Value | 200 | | |
| Max Horizontal Load | 1227 lbs (557 kg) | Brace Identification on Plans LONG 2 Orientation of Brace Longitudinal | |
| Force Factor (Cp) | 0.61 | | |
| Fastener Information | | | |
| Fastener Orientation | NFPA Type A | | |
| Type | HILTI-TZ | | |
| Diameter | 1/2" | | |
| Length | 3 3/4" | | |
| Maximum Load | 1412 lbs (640 kg) | | |
| Load Information | | | |
| Braced Pipe: 3" Sch.10 Steel Pipe | | | |
| Size and Type of Pipe | Total Length | Total Calculated Load | |
| 3" Sch.10 Steel Pipe (76.2 mm) | 808 (24.4 m) | 387 lbs (176 kg) | |
| Percentage added for Fittings and Sprinklers | 15% | 58 lbs (26.31 kg) | |
| Total Adjusted Load of all pipe within Zone of Influence | | 445 lbs (202 kg) | |

ESQUICHEON
SYN. MFC. MODEL
SPRINKLER HEAD LEGEND
SYN. RESP. STYLE FINISH N.P.T. ORIFICE
K TEMP
ESC. TYPE FINISH TEMP. QTY.
DATE BY DESCRIPTION
SUBMITTAL TO GENERAL CONTRACTOR
N/A N/A 2011

TOTAL SPRINKLERS THIS SHEET: 11

NORTH

AERO AUTOMATIC SPRINKLER CO.
21605 North Central Ave., Phoenix, Arizona 85024
663-980-7800 Fax: 623-630-8104
AZ-LP-204798 CA-C16-901529
UT-8970-680455-5501 N/A-M8 12-30-07

CAL POLY CENTER FOR SCIENCE
CALIFORNIA POLYTECHNIC STATE UNIVERSITY
SAN LUIS OBISPO, CA

GILBANE CONSTRUCTION
526 GIBBERNICH DRIVE, SUITE 103
SAN DIEGO, CA 92108
TEL: 619-591-8888 FAX: 619-591-8889

HANGER & E.O. DETAILS

ISSUED BY: NRL
SCALE: AS NOTED
DATE: 8-15-2011
CONTRACT: 10034
SHEET: FP-5.0

IDENTIFICATION STAMP OF THE STATE ARCHITECT OFFICE OF REGULATION SERVICES
APPL 01-110181

REGISTERED PROFESSIONAL ENGINEER
EXPIRES 12/31/15
FP 602
09/29/11

CALCULATION DESIGN INFORMATION

AREA: 1-2
 OCCUPANCY: LECTURE
 HAZARD: LIGHT HAZARD
 DENSITY: 0.10 GPM / SQ.FT.
 AREA OF OPERATION: 1575 SQ. FT.
 AREA PER HEAD: 163 SQ.FT. (MAX.)
 HOSE STREAM ALLOWANCE:
 INSIDE: 100 OUTSIDE:

SYSTEM DEMAND

PSI REQ. AT BASE OF RISER: 162.2
 GPM REQ. AT BASE OF RISER: 328.4
 PSI REQ. AT SOURCE: 45.59
 GPM REQ. AT SOURCE: 428.4
 PSI AVAILABLE AT SOURCE: 52.76
 TOTAL PSI SAFETY FACTOR: 7.17

NOTE: ALL HANGER RODS 6" OR LESS ACT AS LATERAL E.O. BRACING & BRANCH LINE RESTRAINT (BLR)



UPRIGHT SPRINKLERS TO BE WITHIN 1' TO 22" DEFLECTOR DISTANCE.
 ALL CEILING HEIGHTS TO BE 10'-6" (U.N.O.)

CALCULATION DESIGN INFORMATION


AREA: 1-1
 OCCUPANCY: LECTURE
 HAZARD: LIGHT HAZARD
 DENSITY: 0.10 GPM / SQ.FT.
 AREA OF OPERATION: 1520 SQ. FT.
 AREA PER HEAD: 168 SQ.FT. (MAX.)
 HOSE STREAM ALLOWANCE:
 INSIDE: 100 OUTSIDE:

SYSTEM DEMAND

PSI REQ. AT BASE OF RISER: 126.6
 GPM REQ. AT BASE OF RISER: 250.6
 PSI REQ. AT SOURCE: 7.27
 GPM REQ. AT SOURCE: 350.6
 PSI AVAILABLE AT SOURCE: 53.15
 TOTAL PSI SAFETY FACTOR: 43.68




FIRE SPRINKLER PLAN LEVEL I WEST





KEY PLAN

| <p>PROJECT: CAL POLY CENTER FOR SCIENCE SAN LUIS OBISPO, CA</p> <p>OWNER: GILBANE CONSTRUCTION 6245 GREENWICH DRIVE, SUITE 105 SAN DIEGO, CA 92122</p> <p>DESIGNED BY: [Signature] 09/29/11</p> | | <p>DATE: 8-15-2011 CONTRACT: 10034 SHEET: FP-6.01W</p> | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
|---|------|---|-------------|-----|------|----|-------------|---|--|--|--|---|--|--|--|---|--|--|--|---|--|--|--|---|--|--|--|---|--|--|--|---|--|--|--|---|--|--|--|---|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|----|--|--|--|-----|--|--|--|
| <p>SCALE: 1/8"=1'-0"</p> | | <p>REGISTERED PROFESSIONAL ENGINEER GEORGE PROVENIEN No. 692 Exp. 12-31-11 STATE OF CALIFORNIA</p> | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| <p>PROJECT: AUTOMATIC SPRINKLER CO. 622 800 7800 Phoenix, Arizona 85024 AZ-CE-284798 UT-9070-6980458-5501</p> | | <p>UT-9070-6980458-5501</p> | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| <p>SCALE: N.T.S.</p> | | <p>REVISIONS</p> <table border="1"> <tr> <th>NO.</th> <th>DATE</th> <th>BY</th> <th>DESCRIPTION</th> </tr> <tr> <td>1</td> <td></td> <td></td> <td></td> </tr> <tr> <td>2</td> <td></td> <td></td> <td></td> </tr> <tr> <td>3</td> <td></td> <td></td> <td></td> </tr> <tr> <td>4</td> <td></td> <td></td> <td></td> </tr> <tr> <td>5</td> <td></td> <td></td> <td></td> </tr> <tr> <td>6</td> <td></td> <td></td> <td></td> </tr> <tr> <td>7</td> <td></td> <td></td> <td></td> </tr> <tr> <td>8</td> <td></td> <td></td> <td></td> </tr> <tr> <td>9</td> <td></td> <td></td> <td></td> </tr> <tr> <td>10</td> <td></td> <td></td> <td></td> </tr> <tr> <td>11</td> <td></td> <td></td> <td></td> </tr> <tr> <td>12</td> <td></td> <td></td> <td></td> </tr> <tr> <td>13</td> <td></td> <td></td> <td></td> </tr> <tr> <td>14</td> <td></td> <td></td> <td></td> </tr> <tr> <td>15</td> <td></td> <td></td> <td></td> </tr> <tr> <td>16</td> <td></td> <td></td> <td></td> </tr> <tr> <td>17</td> <td></td> <td></td> <td></td> </tr> <tr> <td>18</td> <td></td> <td></td> <td></td> </tr> <tr> <td>19</td> <td></td> <td></td> <td></td> </tr> <tr> <td>20</td> <td></td> <td></td> <td></td> </tr> <tr> <td>21</td> <td></td> <td></td> <td></td> </tr> <tr> <td>22</td> <td></td> <td></td> <td></td> </tr> <tr> <td>23</td> <td></td> <td></td> <td></td> </tr> <tr> <td>24</td> <td></td> <td></td> <td></td> </tr> <tr> <td>25</td> <td></td> <td></td> <td></td> </tr> <tr> <td>26</td> <td></td> <td></td> <td></td> </tr> <tr> <td>27</td> <td></td> <td></td> <td></td> </tr> <tr> <td>28</td> <td></td> <td></td> <td></td> </tr> <tr> <td>29</td> <td></td> <td></td> <td></td> </tr> <tr> <td>30</td> <td></td> <td></td> <td></td> </tr> <tr> <td>31</td> <td></td> <td></td> <td></td> </tr> <tr> <td>32</td> <td></td> <td></td> <td></td> </tr> <tr> <td>33</td> <td></td> <td></td> <td></td> </tr> <tr> <td>34</td> <td></td> <td></td> <td></td> </tr> <tr> <td>35</td> <td></td> <td></td> <td></td> </tr> <tr> <td>36</td> <td></td> <td></td> <td></td> </tr> <tr> <td>37</td> <td></td> <td></td> <td></td> </tr> <tr> <td>38</td> <td></td> <td></td> <td></td> </tr> <tr> <td>39</td> <td></td> <td></td> <td></td> </tr> <tr> <td>40</td> <td></td> <td></td> <td></td> </tr> <tr> <td>41</td> <td></td> <td></td> <td></td> </tr> <tr> <td>42</td> <td></td> <td></td> <td></td> </tr> <tr> <td>43</td> <td></td> <td></td> <td></td> </tr> <tr> <td>44</td> <td></td> <td></td> <td></td> </tr> <tr> <td>45</td> <td></td> <td></td> <td></td> </tr> <tr> <td>46</td> <td></td> <td></td> <td></td> </tr> <tr> <td>47</td> <td></td> <td></td> <td></td> </tr> <tr> <td>48</td> <td></td> <td></td> <td></td> </tr> <tr> <td>49</td> <td></td> <td></td> <td></td> </tr> <tr> <td>50</td> <td></td> <td></td> <td></td> </tr> <tr> <td>51</td> <td></td> <td></td> <td></td> </tr> <tr> <td>52</td> <td></td> <td></td> <td></td> </tr> <tr> <td>53</td> <td></td> <td></td> <td></td> </tr> <tr> <td>54</td> <td></td> <td></td> <td></td> </tr> <tr> <td>55</td> <td></td> <td></td> <td></td> </tr> <tr> <td>56</td> <td></td> <td></td> <td></td> </tr> <tr> <td>57</td> <td></td> <td></td> <td></td> </tr> <tr> <td>58</td> <td></td> <td></td> <td></td> </tr> <tr> <td>59</td> <td></td> <td></td> <td></td> </tr> <tr> <td>60</td> <td></td> <td></td> <td></td> </tr> <tr> <td>61</td> <td></td> <td></td> <td></td> </tr> <tr> <td>62</td> <td></td> <td></td> <td></td> </tr> <tr> <td>63</td> <td></td> <td></td> <td></td> </tr> <tr> <td>64</td> <td></td> <td></td> <td></td> </tr> <tr> <td>65</td> <td></td> <td></td> <td></td> </tr> <tr> <td>66</td> <td></td> <td></td> <td></td> </tr> <tr> <td>67</td> <td></td> <td></td> <td></td> </tr> <tr> <td>68</td> <td></td> <td></td> <td></td> </tr> <tr> <td>69</td> <td></td> <td></td> <td></td> </tr> <tr> <td>70</td> <td></td> <td></td> <td></td> </tr> <tr> <td>71</td> <td></td> <td></td> <td></td> </tr> <tr> <td>72</td> <td></td> <td></td> <td></td> </tr> <tr> <td>73</td> <td></td> <td></td> <td></td> </tr> <tr> <td>74</td> <td></td> <td></td> <td></td> </tr> <tr> <td>75</td> <td></td> <td></td> <td></td> </tr> <tr> <td>76</td> <td></td> <td></td> <td></td> </tr> <tr> <td>77</td> <td></td> <td></td> <td></td> </tr> <tr> <td>78</td> <td></td> <td></td> <td></td> </tr> <tr> <td>79</td> <td></td> <td></td> <td></td> </tr> <tr> <td>80</td> <td></td> <td></td> <td></td> </tr> <tr> <td>81</td> <td></td> <td></td> <td></td> </tr> <tr> <td>82</td> <td></td> <td></td> <td></td> </tr> <tr> <td>83</td> <td></td> <td></td> <td></td> </tr> <tr> <td>84</td> <td></td> <td></td> <td></td> </tr> <tr> <td>85</td> <td></td> <td></td> <td></td> </tr> <tr> <td>86</td> <td></td> <td></td> <td></td> </tr> <tr> <td>87</td> <td></td> <td></td> <td></td> </tr> <tr> <td>88</td> <td></td> <td></td> <td></td> </tr> <tr> <td>89</td> <td></td> <td></td> <td></td> </tr> <tr> <td>90</td> <td></td> <td></td> <td></td> </tr> <tr> <td>91</td> <td></td> <td></td> <td></td> </tr> <tr> <td>92</td> <td></td> <td></td> <td></td> </tr> <tr> <td>93</td> <td></td> <td></td> <td></td> </tr> <tr> <td>94</td> <td></td> <td></td> <td></td> </tr> <tr> <td>95</td> <td></td> <td></td> <td></td> </tr> <tr> <td>96</td> <td></td> <td></td> <td></td> </tr> <tr> <td>97</td> <td></td> <td></td> <td></td> </tr> <tr> <td>98</td> <td></td> <td></td> <td></td> </tr> <tr> <td>99</td> <td></td> <td></td> <td></td> </tr> <tr> <td>100</td> <td></td> <td></td> <td></td> </tr> </table> | | NO. | DATE | BY | DESCRIPTION | 1 | | | | 2 | | | | 3 | | | | 4 | | | | 5 | | | | 6 | | | | 7 | | | | 8 | | | | 9 | | | | 10 | | | | 11 | | | | 12 | | | | 13 | | | | 14 | | | | 15 | | | | 16 | | | | 17 | | | | 18 | | | | 19 | | | | 20 | | | | 21 | | | | 22 | | | | 23 | | | | 24 | | | | 25 | | | | 26 | | | | 27 | | | | 28 | | | | 29 | | | | 30 | | | | 31 | | | | 32 | | | | 33 | | | | 34 | | | | 35 | | | | 36 | | | | 37 | | | | 38 | | | | 39 | | | | 40 | | | | 41 | | | | 42 | | | | 43 | | | | 44 | | | | 45 | | | | 46 | | | | 47 | | | | 48 | | | | 49 | | | | 50 | | | | 51 | | | | 52 | | | | 53 | | | | 54 | | | | 55 | | | | 56 | | | | 57 | | | | 58 | | | | 59 | | | | 60 | | | | 61 | | | | 62 | | | | 63 | | | | 64 | | | | 65 | | | | 66 | | | | 67 | | | | 68 | | | | 69 | | | | 70 | | | | 71 | | | | 72 | | | | 73 | | | | 74 | | | | 75 | | | | 76 | | | | 77 | | | | 78 | | | | 79 | | | | 80 | | | | 81 | | | | 82 | | | | 83 | | | | 84 | | | | 85 | | | | 86 | | | | 87 | | | | 88 | | | | 89 | | | | 90 | | | | 91 | | | | 92 | | | | 93 | | | | 94 | | | | 95 | | | | 96 | | | | 97 | | | | 98 | | | | 99 | | | | 100 | | | |
| NO. | DATE | BY | DESCRIPTION | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 1 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 2 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 3 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 4 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 5 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 6 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 7 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 8 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 9 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 10 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 13 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 14 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 15 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 16 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 17 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 18 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 19 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 20 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 21 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 22 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 23 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 24 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 25 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 26 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 27 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 28 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 29 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 30 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 31 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 32 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 33 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 34 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 35 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 36 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 37 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 38 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 39 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 40 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 41 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 42 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 43 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 44 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 45 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 46 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 47 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 48 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 49 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 50 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 51 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 52 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 53 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 54 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 55 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 56 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 57 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 58 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 59 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 60 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 61 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 62 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 63 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 64 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 65 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 66 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 67 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 68 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 69 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 70 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 71 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 72 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 73 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 74 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 75 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 76 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 77 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 78 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 79 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 80 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 81 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 82 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 83 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 84 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 85 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 86 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 87 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 88 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 89 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 90 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 91 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 92 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 93 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 94 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 95 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 96 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 97 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 98 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 99 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 100 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |




FIRE SPRINKLER PLAN LEVEL 2 EAST



UPRIGHT SPRINKLERS TO BE WITHIN 1\"/>

KEY PLAN


| | |
|---|--|
| | |
| AUTOMATIC CO. SPRINKLER CO. 623 463 7800 950 North Central Ave. Phoenix, Arizona 85024 CA - 415-901-0229 AZ - 602-944-7898 UT - 801-970-6994/699-5501 NM - 505-828-3487 | |
| CAL POLY CENTER FOR SCIENCE SAN LUIS OBISPO, CA | GILBANE CONSTRUCTION 2515 GILBANE CENTER SUITE 105 SAN DIEGO, CA 92122 SAN DIEGO, CA |
| PROJECT: CAL POLY CENTER FOR SCIENCE DRAWN BY: NRL SCALE: 1/8"=1'-0" DATE: 8-15-2011 CONTRACT: 10034 SHEET: FP-6.02E | FIRE SPRINKLER PLAN LEVEL 2 EAST TOTAL SPRINKLERS THIS SHEET: 188 REVISIONS REVISIONS: (Table with columns for description and date) 1. 01/29/11 |




| CALCULATION DESIGN INFORMATION | |
|--------------------------------|-----------------------|
| AREA: | 3-1" |
| OCCUPANCY: | LAB |
| HAZARD: | ORDINARY HAZARD GR. 1 |
| DENSITY: | 0.15 GPM / SQ.FT. |
| AREA OF OPERATION: | 987 SQ.FT. |
| AREA PER HEAD: | 130 SQ.FT. (MAX.) |
| HOSE STREAM ALLOWANCE: | |
| INSIDE: | 100 |
| OUTSIDE: | 150 |
| SYSTEM DEMAND | |
| PSI REQ. AT BASE OF RISER: | 102.61 |
| GPM REQ. AT BASE OF RISER: | 252.75 |
| PSI REQ. AT SOURCE: | -0.88 |
| GPM REQ. AT SOURCE: | 502.75 |
| PSI AVAILABLE AT SOURCE: | 52.35 |
| TOTAL PSI SAFETY FACTOR: | 53.23 |

REMOTE AREA REDUCED BY 39.25% (CH=10'-6")
[112 SQ.FT. MIN.]


UPRIGHT SPRINKLERS TO BE WITHIN 1' TO 22" DEFLECTOR DISTANCE.
ALL CEILING HEIGHTS TO BE 10'-6" (U.N.O.)





FIRE SPRINKLER PLAN LEVEL 3 WEST




| | |
|--|--|
| | |
| AUTOMATIC SPRINKLER CO. 21005 North Central Ave. Phoenix, Arizona 85024 AZ Lic 232798 UT-8970-8890458-5501 | |
| CAL POLY CENTER FOR SCIENCE SAN LUIS OBISPO, CA GILBANE CONSTRUCTION 6265 GREENWICH DRIVE, SUITE 100 SAN DIEGO, CA 92122 FIRE SPRINKLER PLAN LEVEL 3 WEST | |
| PROJECT: CAL POLY CENTER FOR SCIENCE SHEET: FP-6.03W DATE: 8-15-2011 CONTRACT: 10034 | DESIGNER: NTL SCALE: 1/8"=1'-0" DATE: 8-15-2011 CONTRACT: 10034 |
| ESCUTCHEON QTY: 204 ESC TYPE: FENSLI N/A RECESSED CHRM N/A X TEMP: 155 Y TEMP: 172 Z TEMP: 200 CHRM 1/2": 58 DFR CHRM 1/2": 200 | |
| TOTAL SPRINKLERS THIS SHEET: 208 REVISIONS | |



KEY PLAN




UPRIGHT SPRINKLERS TO BE WITHIN 1' TO 22" DEFLECTOR DISTANCE.
ALL CEILING HEIGHTS TO BE 10'-6" (U.N.O.)



FIRE SPRINKLER PLAN LEVEL 4 WEST


KEY PLAN




| | | |
|--|--|---|
| PROJECT: CAL POLY CENTER FOR SCIENCE SAN LUIS OBISPO, CA OWNER: GILBANE CONSTRUCTION 1455 RESEARCH SUITE 103 SAN DIEGO, CA 92122 DATE: 8-15-2011 CONTRACT: 10034 SHEET: FP-6.04W | | REVISIONS: 1. DATE BY DESCRIPTION 2. REVISIONS |
| SPRINKLER HEAD LEGEND: SWL MFG. MODEL TYCO TY-FRB TY3131 OR TY3231 FINISH STYLE PEND UPR BRASS 1/2" 1/2" 1/2" ESC. TYPE RECESSED CHRM N/A K TEMP 5.6 5.6 5.6 FINISH TEMP N/A QTY. 118 | | ESCUICHEON: TOTAL SPRINKLERS THIS SHEET 121 |

AERD AUTOMATIC SPRINKLER CO.
 2905 North Central Ave
 Phoenix, Arizona 85024
 AZ Lic 292798
 UT-9370-6960455-5501



2 NORTH




UPRIGHT SPRINKLERS TO BE WITHIN 1' TO 22" DEFLECTOR DISTANCE.
 ALL CEILING HEIGHTS TO BE 10'-6" (U.N.O.)




FIRE SPRINKLER PLAN LEVEL 4 EAST




| | | | |
|--|--|---|--|
| PROJECT: CAL POLY CENTER FOR SCIENCE 21605 North Central Ave. Phoenix, Arizona 85024 AZ Lic 232798 UT-8970-898045-5501 | | CONTRACTOR: GILBANE CONSTRUCTION 565 GREENWICH DRIVE, SUITE 103 SAN DIEGO, CA 92122 CA-CIP-80029 NH-MS 92-54907 | |
| DRAWN BY: NRL SCALE: 1/8"=1'-0" DATE: 8-15-2011 CONTRACT: 10034 SHEET: FP-6.04E | REGISTERED PROFESSIONAL ENGINEER GEORGE PROVENIER No. 1251-1 09/16/10 | | |
| AUTOMATIC SPRINKLER CO. 21605 North Central Ave. Phoenix, Arizona 85024 UT-8970-898045-5501 | | NORTH | |
| ESCUTCHEON ESC TYPE FINISH TEMP QTY RECESSED CHRM N/A 180 PEND CHRM N/A 5 | | TOTAL SPRINKLERS THIS SHEET: 194 REVISIONS | |



UPRIGHT SPRINKLERS TO BE WITHIN 1" TO 22" DEFLECTOR DISTANCE.
 ALL CEILING HEIGHTS TO BE 10'-6" (U.N.C.)



FIRE SPRINKLER PLAN LEVEL 5 EAST




| | |
|---|---|
| | |
| AUTOMATIC SPRINKLER CO. 2905 North Central Ave. Phoenix, Arizona 85024 AZ Lic. # 24757 AZ-COP-284759 UT-8370-680468-6501 602.950.7800 Fax: 602.484.3164 www.automaticsprinkler.com | |
| CAL POLY CENTER FOR SCIENCE CALIFORNIA POLYTECHNIC STATE UNIVERSITY SAN LUIS OBISPO, CA. | |
| GILBANE CONSTRUCTION 7245 GREENWICH DRIVE, SUITE 105 SAN DIEGO, CA. 92122 PH: 619.594.9299 | |
| REGISTERED PROFESSIONAL ENGINEER GEORGE PROVEDENSKI No. 6922 Exp. 12-31-14 State of California | |
| DRAWN BY: NRL SCALE: 1/8"=1'-0" DATE: 6-15-2011 CONTRACT: 10034 | SHEET: FP-6.05E TOTAL SPRINKLERS THIS SHEET: 194 REVISIONS: |

| CALCULATION DESIGN INFORMATION | |
|--------------------------------|-------------------|
| AREA: | 6-4 |
| OCCUPANCY: | OFFICE / LOBBY |
| HAZARD: | LIGHT HAZARD |
| DENSITY: | 0.10 GPM / SQ.FT. |
| AREA OF OPERATION: | 1567 SQ. FT. |
| AREA PER HEAD: | 210 SQ.FT. (MAX.) |
| HOSE STREAM ALLOWANCE: | |
| INSIDE: | 100 |
| OUTSIDE: | |
| SYSTEM DEMAND | |
| PSI REQ. AT BASE OF RISER: | 116.86 |
| GPM REQ. AT BASE OF RISER: | 347.3 |
| PSI REQ. AT SOURCE: | 59.09 |
| GPM REQ. AT SOURCE: | 447.3 |
| PSI AVAILABLE AT SOURCE: | 52.66 |
| TOTAL PSI SAFETY FACTOR: | 13.57 |


| CALCULATION DESIGN INFORMATION | |
|--------------------------------|-----------------------|
| AREA: | 6-3 |
| OCCUPANCY: | LAB |
| HAZARD: | ORDINARY HAZARD GR. 1 |
| DENSITY: | 0.15 GPM / SQ.FT. |
| AREA OF OPERATION: | 920 SQ.FT. |
| AREA PER HEAD: | 130 SQ.FT. (MAX.) |
| HOSE STREAM ALLOWANCE: | |
| INSIDE: | 100 |
| OUTSIDE: | 150 |
| SYSTEM DEMAND | |
| PSI REQ. AT BASE OF RISER: | 108.4 |
| GPM REQ. AT BASE OF RISER: | 273.4 |
| PSI REQ. AT SOURCE: | 26.71 |
| GPM REQ. AT SOURCE: | 523.4 |
| PSI AVAILABLE AT SOURCE: | 52.11 |
| TOTAL PSI SAFETY FACTOR: | 25.4 |

| CALCULATION DESIGN INFORMATION | |
|--------------------------------|-----------------------|
| AREA: | 6-1 |
| OCCUPANCY: | LAB |
| HAZARD: | ORDINARY HAZARD GR. 1 |
| DENSITY: | 0.15 GPM / SQ.FT. |
| AREA OF OPERATION: | 940 SQ.FT. |
| AREA PER HEAD: | 130 SQ.FT. (MAX.) |
| HOSE STREAM ALLOWANCE: | |
| INSIDE: | 100 |
| OUTSIDE: | 150 |
| SYSTEM DEMAND | |
| PSI REQ. AT BASE OF RISER: | 95.47 |
| GPM REQ. AT BASE OF RISER: | 233.15 |
| PSI REQ. AT SOURCE: | 12.35 |
| GPM REQ. AT SOURCE: | 483.15 |
| PSI AVAILABLE AT SOURCE: | 53.35 |
| TOTAL PSI SAFETY FACTOR: | 40.1 |


| CALCULATION DESIGN INFORMATION | |
|--------------------------------|-------------------|
| AREA: | 6-2 |
| OCCUPANCY: | CORRIDOR |
| HAZARD: | LIGHT HAZARD |
| DENSITY: | 0.10 GPM / SQ.FT. |
| AREA OF OPERATION: | 5 HEADS CORR. |
| AREA PER HEAD: | 225 SQ.FT. (MAX.) |
| HOSE STREAM ALLOWANCE: | |
| INSIDE: | 100 |
| OUTSIDE: | |
| SYSTEM DEMAND | |
| PSI REQ. AT BASE OF RISER: | 34.5 |
| GPM REQ. AT BASE OF RISER: | 113.1 |
| PSI REQ. AT SOURCE: | 51.52 |
| GPM REQ. AT SOURCE: | 213.09 |
| PSI AVAILABLE AT SOURCE: | 53.58 |
| TOTAL PSI SAFETY FACTOR: | 105.1 |



UPRIGHT SPRINKLERS TO BE WITHIN 1' TO 22' DEFLECTOR DISTANCE.
ALL CEILING HEIGHTS TO BE 10'-6" (U.N.O.)



FIRE SPRINKLER PLAN LEVEL 6 EAST





KEY PLAN

| | |
|--|------------|
| | |
| AUTOMATIC SPRINKLER CO. 2805 North Central Ave. Phoenix, Arizona 85024 AZ-LIC-292798 UT-8970-6980456-5501 | |
| GILBANE CONSTRUCTION PROJECT ENGINEER: SUITE 105 SAN DIEGO, CA 92122 | |
| CAL POLY CENTER FOR SCIENCE CALIFORNIA POLYTECHNIC STATE UNIVERSITY SAN LUIS OBISPO, CA | |
| DRAWN BY: | 1/8"=1'-0" |
| DATE: | 8-15-2011 |
| CONTRACT: | 10034 |
| SHEET: | FP-6.06E |
| REGISTERED PROFESSIONAL ENGINEER STATE OF CALIFORNIA No. 51113 Exp. 12/31/13 | |
| TOTAL SPRINKLERS THIS SHEET: 213 REVISIONS | |




FIRE SPRINKLER RCP LEVEL 2 WEST




UPRIGHT SPRINKLERS TO BE WITHIN 1' TO 22" DEFLECTOR DISTANCE.
ALL CEILING HEIGHTS TO BE 10'-6" (U.N.O.)


| <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="2">SPRINKLER HEAD LEGEND</th> <th colspan="2">ESCUTCHEON</th> </tr> <tr> <th>SYMBOL</th> <th>DESCRIPTION</th> <th>ESC. TYPE</th> <th>FINISH</th> </tr> <tr> <td>●</td> <td>TYCO TY-FRB</td> <td>RECESSED</td> <td>CHRM</td> </tr> <tr> <td>○</td> <td>TYCO TY-FRB</td> <td>UPR</td> <td>CHRM</td> </tr> </table> | | | | | | | | SPRINKLER HEAD LEGEND | | ESCUTCHEON | | SYMBOL | DESCRIPTION | ESC. TYPE | FINISH | ● | TYCO TY-FRB | RECESSED | CHRM | ○ | TYCO TY-FRB | UPR | CHRM |
|--|---|------------|-------------|--|--|--|-----|---|---|-----------------|-----------------|-----------------|-------------|-----------|-------------|---|-------------|----------|------|---|-------------|-----|------|
| SPRINKLER HEAD LEGEND | | ESCUTCHEON | | | | | | | | | | | | | | | | | | | | | |
| SYMBOL | DESCRIPTION | ESC. TYPE | FINISH | | | | | | | | | | | | | | | | | | | | |
| ● | TYCO TY-FRB | RECESSED | CHRM | | | | | | | | | | | | | | | | | | | | |
| ○ | TYCO TY-FRB | UPR | CHRM | | | | | | | | | | | | | | | | | | | | |
| <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th>SYMBOL</th> <th>DESCRIPTION</th> <th>QTY</th> </tr> <tr> <td>●</td> <td>TYCO TY-FRB</td> <td>166</td> </tr> <tr> <td>○</td> <td>TYCO TY-FRB</td> <td>2</td> </tr> </table> | | | | | | | | SYMBOL | DESCRIPTION | QTY | ● | TYCO TY-FRB | 166 | ○ | TYCO TY-FRB | 2 | | | | | | | |
| SYMBOL | DESCRIPTION | QTY | | | | | | | | | | | | | | | | | | | | | |
| ● | TYCO TY-FRB | 166 | | | | | | | | | | | | | | | | | | | | | |
| ○ | TYCO TY-FRB | 2 | | | | | | | | | | | | | | | | | | | | | |
| <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th>NO.</th> <th>DATE</th> <th>BY</th> <th>DESCRIPTION</th> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </table> | | | | | | | | NO. | DATE | BY | DESCRIPTION | | | | | | | | | | | | |
| NO. | DATE | BY | DESCRIPTION | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | |
| TOTAL SPRINKLERS THIS SHEET | | | | | | | 168 | | | | | | | | | | | | | | | | |
| <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%; text-align: center;"> AUTOMATIC SPRINKLER CO. 1700 North Central Ave. Phoenix, Arizona 85024 AZ - 602-979-9279 UT - 801-937-6904/55-5501 </td> <td style="width: 50%; text-align: center;"> 623-665-7800 Fax: 623-484-8364 CA - 916-400-9259 SAN DIEGO, CA - 619-444-7800 NH - 603-893-4807 </td> </tr> </table> | | | | | | | | AUTOMATIC SPRINKLER CO. 1700 North Central Ave. Phoenix, Arizona 85024 AZ - 602-979-9279 UT - 801-937-6904/55-5501 | 623-665-7800 Fax: 623-484-8364 CA - 916-400-9259 SAN DIEGO, CA - 619-444-7800 NH - 603-893-4807 | | | | | | | | | | | | | | |
| AUTOMATIC SPRINKLER CO. 1700 North Central Ave. Phoenix, Arizona 85024 AZ - 602-979-9279 UT - 801-937-6904/55-5501 | 623-665-7800 Fax: 623-484-8364 CA - 916-400-9259 SAN DIEGO, CA - 619-444-7800 NH - 603-893-4807 | | | | | | | | | | | | | | | | | | | | | | |
| <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%; text-align: center;"> CAL POLY CENTER FOR SCIENCE SAN LUIS OBISPO, CA </td> <td style="width: 50%; text-align: center;"> GILBANE CONSTRUCTION RESEARCH SUITE 103 SAN DIEGO, CA 92122 </td> </tr> </table> | | | | | | | | CAL POLY CENTER FOR SCIENCE SAN LUIS OBISPO, CA | GILBANE CONSTRUCTION RESEARCH SUITE 103 SAN DIEGO, CA 92122 | | | | | | | | | | | | | | |
| CAL POLY CENTER FOR SCIENCE SAN LUIS OBISPO, CA | GILBANE CONSTRUCTION RESEARCH SUITE 103 SAN DIEGO, CA 92122 | | | | | | | | | | | | | | | | | | | | | | |
| <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">DRAWN BY: NRL</td> <td style="width: 50%;">SCALE: 1/8"=1'-0"</td> </tr> <tr> <td>DATE: 8-15-2011</td> <td>CONTRACT: 10034</td> </tr> <tr> <td colspan="2" style="text-align: center;">SHEET: FP-7.02W</td> </tr> </table> | | | | | | | | DRAWN BY: NRL | SCALE: 1/8"=1'-0" | DATE: 8-15-2011 | CONTRACT: 10034 | SHEET: FP-7.02W | | | | | | | | | | | |
| DRAWN BY: NRL | SCALE: 1/8"=1'-0" | | | | | | | | | | | | | | | | | | | | | | |
| DATE: 8-15-2011 | CONTRACT: 10034 | | | | | | | | | | | | | | | | | | | | | | |
| SHEET: FP-7.02W | | | | | | | | | | | | | | | | | | | | | | | |





KEY PLAN




UPRIGHT SPRINKLERS TO BE WITHIN 1" TO 22" DEFLECTOR DISTANCE.
 ALL CEILING HEIGHTS TO BE 10'-6" (U.N.O.)




FIRE SPRINKLER RCP LEVEL 2 EAST




| | |
|---|---|
| | |
| AUTOMATIC SPRINKLER CO. 2905 W. North Street Phoenix, Arizona 85024 AZ Lic. 234729 UT-9376-680465-5501 | |
| CAL POLY CENTER FOR SCIENCE SAN LUIS OBISPO, CA | |
| GILBANE CONSTRUCTION 655 GREENWICH SQUARE, SUITE 103 SAN DIEGO, CA 92108 | |
| FIRE SPRINKLER RCP LEVEL 2 EAST | |
| DRAWN BY: NRL SCALE: 1/8"=1'-0" DATE: 8-15-2011 CONTRACT: 10034 SHEET: FP-7.02E | PROJECT: CAL POLY CENTER FOR SCIENCE SHEET NO: 12-51-17 DATE: 8-15-2011 CONTRACT: 10034 SHEET: FP-7.02E |
| ESCUTCHEON ESC. TYPE FINISH TEMP. QTY. RECESSED CHRM N/A 186 2 | |
| SPRINKLER HEAD LEGEND SIN RESP STYLE FINISH N.P.T. ORifice K TEMP. FINISH TEMP. QTY. TY-FRB TY-FRB 1/2" 5.6 155 1/2" 5.6 155 186 TY-FRB TY-FRB 1/2" 5.6 200 1/2" 5.6 200 2 | |
| TOTAL SPRINKLERS THIS SHEET 188 REVISIONS | |




UPRIGHT SPRINKLERS TO BE WITHIN 1' TO 22" DEFLECTOR DISTANCE.
 ALL CEILING HEIGHTS TO BE 10'-6" (U.N.O.)




FIRE SPRINKLER RCP LEVEL 3 WEST




KEY PLAN




| | | | |
|---|------|----------------------------------|---------------------------------|
| PROJECT: CAL POLY CENTER FOR SCIENCE SAN LUIS OBISPO, CA | | DRAWN BY: NRL | |
| CONTRACT WITH: GILBANE CONSTRUCTION 6265 GREENWICH DRIVE, SUITE 103 SAN DIEGO, CA 92122 | | DATE: 8-15-2011 | |
| SHEET: FIRE SPRINKLER RCP LEVEL 3 WEST | | CONTRACT: 10034 | |
| PROJECT NO: FP-7.03W | | SCALE: 1/8"=1'-0" | |
| DATE: 8-15-2011 | | SHEET: 204 | |
| CONTRACT: 10034 | | TOTAL SPRINKLERS THIS SHEET: 208 | |
| SHEET: FP-7.03W | | REVISIONS | |
| NO. | DATE | BY | DESCRIPTION |
| 1 | | | SUBMITTAL TO GENERAL CONTRACTOR |
| 2 | | | |
| 3 | | | |
| 4 | | | |
| 5 | | | |
| 6 | | | |
| 7 | | | |
| 8 | | | |
| 9 | | | |
| 10 | | | |
| 11 | | | |
| 12 | | | |
| 13 | | | |
| 14 | | | |
| 15 | | | |
| 16 | | | |
| 17 | | | |
| 18 | | | |
| 19 | | | |
| 20 | | | |
| 21 | | | |
| 22 | | | |
| 23 | | | |
| 24 | | | |
| 25 | | | |
| 26 | | | |
| 27 | | | |
| 28 | | | |
| 29 | | | |
| 30 | | | |
| 31 | | | |
| 32 | | | |
| 33 | | | |
| 34 | | | |
| 35 | | | |
| 36 | | | |
| 37 | | | |
| 38 | | | |
| 39 | | | |
| 40 | | | |
| 41 | | | |
| 42 | | | |
| 43 | | | |
| 44 | | | |
| 45 | | | |
| 46 | | | |
| 47 | | | |
| 48 | | | |
| 49 | | | |
| 50 | | | |
| 51 | | | |
| 52 | | | |
| 53 | | | |
| 54 | | | |
| 55 | | | |
| 56 | | | |
| 57 | | | |
| 58 | | | |
| 59 | | | |
| 60 | | | |
| 61 | | | |
| 62 | | | |
| 63 | | | |
| 64 | | | |
| 65 | | | |
| 66 | | | |
| 67 | | | |
| 68 | | | |
| 69 | | | |
| 70 | | | |
| 71 | | | |
| 72 | | | |
| 73 | | | |
| 74 | | | |
| 75 | | | |
| 76 | | | |
| 77 | | | |
| 78 | | | |
| 79 | | | |
| 80 | | | |
| 81 | | | |
| 82 | | | |
| 83 | | | |
| 84 | | | |
| 85 | | | |
| 86 | | | |
| 87 | | | |
| 88 | | | |
| 89 | | | |
| 90 | | | |
| 91 | | | |
| 92 | | | |
| 93 | | | |
| 94 | | | |
| 95 | | | |
| 96 | | | |
| 97 | | | |
| 98 | | | |
| 99 | | | |
| 100 | | | |




UPRIGHT SPRINKLERS TO BE WITHIN 1" TO 22" DEFLECTOR DISTANCE.
 ALL CEILING HEIGHTS TO BE 10'-6" (U.N.O.)




FIRE SPRINKLER RCP LEVEL 3 EAST



| | |
|---|------------|
| | |
| AUTOMATIC SPRINKLER CO. 2700 North Central Ave. 858 665 7800 Phoenix, Arizona 85024 Fla. 623 464 3854 AZ Lic- 292798 CA- 016 40029 UT- 8970-6980459-5501 NM- 92-344807 | |
| CAL POLY CENTER FOR SCIENCE SAN LUIS OBISPO, CA. | |
| GILBANE CONSTRUCTION RESEARCH BLDG. SUITE 105 SAN DIEGO, CA. 92122 | |
| PROJECT: FIRE SPRINKLER RCP LEVEL 3 EAST | |
| DRAWN BY: | NRJ |
| SCALE: | 1/8"=1'-0" |
| DATE: | 8-15-2011 |
| CONTRACT: | 10034 |
| SHEET: | FP-7.03E |
| REGISTERED PROFESSIONAL ENGINEER CALIFORNIA LICENSE NO. 693 EXPIRES 12/31/11 | |
| TOTAL SPRINKLERS THIS SHEET: 226 REVISIONS | |




UPRIGHT SPRINKLERS TO BE WITHIN 1' TO 22" DEFLECTOR DISTANCE.
ALL CEILING HEIGHTS TO BE 10'-6" (U.N.O.)





FIRE SPRINKLER RCP LEVEL 4 WEST



KEY PLAN




| | | | | | | | |
|---|--------|---------------------------|------------|------------------------------------|------|--|--|
| PROJECT: CAL POLY CENTER FOR SCIENCE SAN LUIS OBISPO, CA. 9505 North Central Ave. Phoenix, Arizona 85024 AZ-Lic-204798 UT-8070-6690455-5501 NM-NR 12-354807 | | DATE: 8-15-2011 | | CONTRACT: 10034 | | SHEET: FP-7.04W | |
| SCALE: 1/8"=1'-0" | | DRAWN BY: NRL | | REVISIONS: 121 REVISIONS | | TOTAL SPRINKLERS THIS SHEET: 121 | |
| SYMBOL | MODEL | TEMP | ESCH. TYPE | FINISH | TEMP | QTY | DESCRIPTION |
| ● | TY-FRB | 155 | RECESSED | CHRM | N/A | 118 | RECESSED PENDENT SPRINKLER (CHROME/CHROME) |
| ⊙ | TY-FRB | 200 | UPR | CHRM | 1/2" | 3 | UPRIGHT SPRINKLER (CHROME/CHROME) |




FIRE SPRINKLER RCP LEVEL 4 EAST



| | |
|--|---|
| | |
| AUTOMATIC SPRINKLER CO. 2905 North Central Ave. Phoenix, Arizona 85024 AZ - 602-997-9797 UT - 807-669-0455-5601 FAX - 602-997-9804 FAX - 807-669-0455-5601 IN AZ LICENSE # 12-354807 | |
| CAL PLY CENTER FOR SCIENCE SAN LUIS OBISPO, CA | GILBANE CONSTRUCTION CALIFORNIA REGISTERED CONTRACTOR SAN DIEGO, CA 92122 (IN AZ LICENSE # 12-354807) |
| PROJECT: FIRE SPRINKLER RCP LEVEL 4 EAST | DRAWN BY: NRL |
| SCALE: 1/8"=1'-0" | DATE: 8-15-2011 |
| CONTRACT: 10034 | SHEET: FP-7.04E |
| REVISIONS | |
| NO. DATE BY DESCRIPTION | REVISIONS THIS SHEET |
| 1 8-15-11 NRL TOTAL SPRINKLERS TO BE INSTALLED 189 | 194 |
| 2 8-15-11 NRL RECESSED CHRM N/A 5 | |
| 3 8-15-11 NRL UPRR CHRM 1/2" 200 | |
| 4 8-15-11 NRL FINISH N.P.T. OFFICE 5.6 | |
| 5 8-15-11 NRL ESCUTCHEON 189 | |






UPRIGHT SPRINKLERS TO BE WITHIN 1' TO 22" DEFLECTOR DISTANCE.
 ALL CEILING HEIGHTS TO BE 10'-6" (U.N.O.)




PENDENT SPRINKLER HEAD
 SCALE: N.T.S.


FIRE SPRINKLER RCP LEVEL 5 EAST



| | | | |
|--|----------|---|--------------------|
| PROJECT: CAL POLY CENTER FOR SCIENCE CALIFORNIA POLYTECHNIC STATE UNIVERSITY SAN LUIS OBISPO, CA | | CONTRACTOR: GILBANE CONSTRUCTION 846 BEECHWICH DRIVE, SUITE 103 SAN DIEGO, CA 92122 PHONE: 619-444-1111 FAX: 619-444-1111 | |
| DESIGNER: NREL 1500 CENTRE DRIVE, SUITE 300 DENVER, CO 80202 PHONE: 303-733-1400 FAX: 303-733-1401 | | DATE: 8-15-2011 | |
| SCALE: 1/8"=1'-0" | | CONTRACT: 10034 | |
| SHEET: FP-7.05E | | TOTAL SPRINKLERS THIS SHEET: 194 | |
| REVISIONS: | | | |
| NO. | DATE | BY | DESCRIPTION |
| 1 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 2 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 3 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 4 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 5 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 6 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 7 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 8 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 9 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 10 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 11 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 12 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 13 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 14 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 15 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 16 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 17 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 18 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 19 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 20 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 21 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 22 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 23 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 24 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 25 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 26 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 27 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 28 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 29 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 30 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 31 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 32 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 33 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 34 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 35 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 36 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 37 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 38 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 39 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 40 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 41 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 42 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 43 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 44 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 45 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 46 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 47 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 48 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 49 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 50 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 51 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 52 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 53 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 54 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 55 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 56 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 57 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 58 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 59 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 60 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 61 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 62 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 63 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 64 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 65 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 66 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 67 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 68 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 69 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 70 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 71 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 72 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 73 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 74 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 75 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 76 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 77 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 78 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 79 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 80 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 81 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 82 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 83 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 84 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 85 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 86 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 87 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 88 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 89 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 90 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 91 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 92 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 93 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 94 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 95 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 96 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 97 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 98 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 99 | 08/15/11 | NREL | ISSUED FOR PERMITS |
| 100 | 08/15/11 | NREL | ISSUED FOR PERMITS |




UPRIGHT SPRINKLERS TO BE WITHIN 1' TO 22" DEFLECTOR DISTANCE.
 ALL CEILING HEIGHTS TO BE 10'-6" (U.N.O.)



FIRE SPRINKLER RCP LEVEL 6 EAST

2 1 0 4 8
 SCALE 1/8"=1'-0"




| <p>NORTH</p> | | | | | | | | | | | | | | | | |
|---|--------|------------|--------|--------|-------|----------|------|--------|------|-----|-----|-----|--------|-----|-----|----|
| <p>AERD AUTOMATIC SPRINKLER CO. 21605 North Central Ave. Phoenix, Arizona 85024 602-980-7900 Fax 602-424-3154 AZ-LB-234798 CA-CB-90629 AZ-CB-68970 NY-CB-11111 UT-6070-668465-5501 NH-WB-15-00007</p> | | | | | | | | | | | | | | | | |
| <p>CAL POLY CENTER FOR SCIENCE CALIFORNIA POLYTECHNIC STATE UNIVERSITY SAN LUIS OBISPO, CA.</p> <p>GILBANE CONSTRUCTION 2285 GREENWICH DRIVE, SUITE 103 SAN DIEGO, CA 92122 FIRE SPRINKLER RCP LEVEL 6 EAST</p> | | | | | | | | | | | | | | | | |
| <p>PROJECT: CAL POLY CENTER FOR SCIENCE DRAWN BY: [Blank] SCALE: 1/8"=1'-0" DATE: 8-15-2011 CONTRACT: 10034 SHEET: FP-7.06E</p> | | | | | | | | | | | | | | | | |
| <p>REGISTERED PROFESSIONAL ENGINEER GEORGE PROVENZANO No. 6922 Exp. 12-31-11 09/20/11</p> | | | | | | | | | | | | | | | | |
| <p>ESCUICHEON</p> <table border="1"> <thead> <tr> <th>ESCA. TYPE</th> <th>FINISH</th> <th>TEMP.</th> <th>QTY.</th> </tr> </thead> <tbody> <tr> <td>RECESSED</td> <td>CHRM</td> <td>N/A</td> <td>183</td> </tr> <tr> <td>N/A</td> <td>N/A</td> <td>N/A</td> <td>20</td> </tr> </tbody> </table> | | ESCA. TYPE | FINISH | TEMP. | QTY. | RECESSED | CHRM | N/A | 183 | N/A | N/A | N/A | 20 | | | |
| ESCA. TYPE | FINISH | TEMP. | QTY. | | | | | | | | | | | | | |
| RECESSED | CHRM | N/A | 183 | | | | | | | | | | | | | |
| N/A | N/A | N/A | 20 | | | | | | | | | | | | | |
| <p>SPRINKLER HEAD LEGEND</p> <table border="1"> <thead> <tr> <th>SYMBOL</th> <th>MODEL</th> <th>FINISH</th> <th>TEMP.</th> <th>QTY.</th> </tr> </thead> <tbody> <tr> <td>●</td> <td>T1-FRB</td> <td>CHRM</td> <td>155</td> <td>183</td> </tr> <tr> <td>○</td> <td>T1-FRB</td> <td>UPR</td> <td>200</td> <td>20</td> </tr> </tbody> </table> | | SYMBOL | MODEL | FINISH | TEMP. | QTY. | ● | T1-FRB | CHRM | 155 | 183 | ○ | T1-FRB | UPR | 200 | 20 |
| SYMBOL | MODEL | FINISH | TEMP. | QTY. | | | | | | | | | | | | |
| ● | T1-FRB | CHRM | 155 | 183 | | | | | | | | | | | | |
| ○ | T1-FRB | UPR | 200 | 20 | | | | | | | | | | | | |
| <p>TOTAL SPRINKLERS THIS SHEET: 213</p> | | | | | | | | | | | | | | | | |

GENERAL NOTES

- NOTIFICATION DEVICES CANNOT BE T-TAPPED. ADDRESSABLE (IDC) DEVICES CAN BE T-TAPPED. ALL FIRE ALARM CABLING SHALL BE RUN FROM DEVICE TO DEVICE, WITH NO SPLICES. ANY REQUIRED TERMINATIONS MUST BE MADE IN APPROVED BOX.
- ALL INTERIOR INITIATING DEVICES, NOTIFICATION DEVICES, AND MODULES REQUIRE 4" SQUARE SPECIAL DEEP BACK BOXES U.O.N.
- PANEL BACK BOXES AND OTHER LISTED BACK BOXES SHALL BE PROVIDED TO THE EC BY DBI. ALL CONTROL PANELS, POWER SUPPLIES, AND BATTERY BOXES SHALL UTILIZE ONLY FACTORY KNOCKOUTS NEAR THE TOP OF THE CAN TO ALLOW PLACEMENT OF BATTERIES.
- ALL FIRE ALARM CONDUIT TO BE 3/4" EMT MINIMUM U.O.N. FIRE ALARM CONDUIT SHALL BE SEPARATE FROM CONDUIT SYSTEM FOR SECURITY ALARM CABLING AND OTHER SYSTEMS.
- WALL MOUNT AUDIO/VISUAL DEVICES SHALL BE MOUNTED 80" AFF TO BOTTOM OF THE STROBE LENS.
- MANUAL PULL STATIONS SHALL BE MOUNTED 48" AFF TO CENTERLINE OF BOX. MPS SHALL BE DOUBLE ACTION AND KEYED THE SAME AS THE FACP.
- DEDICATED 120 VAC CIRCUIT WITH LOCKOUT @ BREAKER TO BE PROVIDED BY OTHERS AT LOCATION OF PANELS AND POWER SUPPLIES.
- KNOX BOX, PIV, SUPERVISORY SWITCHES, FLOW SWITCHES, SOLENOIDS, AND SPRINKLER BELLS SHALL BE PROVIDED BY OTHERS.
- SMOKE DETECTORS SHALL NOT BE PLACED WITHIN 3' OF ANY SUPPLY AIR REGISTER OR WHERE THE AIR MOVEMENT EXCEEDS THE MANUFACTURER'S LISTING.
- FIRE FIGHTER TELEPHONE RISER IS CLASS A, STYLE Z
- VOLTAGE DROP CALCULATIONS FOR NOTIFICATION DEVICES ARE BASED ON THE LAYOUT SHOWN. DEVIATION FROM THESE PLANS COULD RESULT IN ADDITIONAL CONDUIT WORK, REENGINEERING, UPSIZED CABLE AND/OR ADDITIONAL POWER REQUIREMENTS.
- PAINT ALL FIRE ALARM JUNCTION BOXES AND COVERS RED IN UNFINISHED AREAS (IE ABOVE CEILINGS, MECHANICAL ROOMS ETC.) IN FINISHED AREAS CONDUIT AND JUNCTION BOXES CAN BE PAINTED TO MATCH THE ROOM FINISH, THE INSIDE COVER IF THE JUNCTION BOX MUST BE IDENTIFIED AS "FIRE ALARM" AND THE CONDUIT MUST HAVE PAINTED RED BANDS 3/4" WIDE AT 10' CENTERS AND AT EACH SIDE OF A FLOOR, WALL, OR CEILING PENETRATION.
- UPON COMPLETION OF INSTALLATION OF THE FIRE ALARM SYSTEM A SATISFACTORY TEST OF THE ENTIRE SYSTEM SHALL BE MADE IN THE PRESENCE OF THE AUTHORITY HAVING JURISDICTION (AHJ).
- ALL NOTIFICATION DEVICES SHALL BE SYNCHRONIZED.
- A STAMPED SET OF APPROVED FIRE ALARM PLANS SHALL BE AT THE JOBSITE AND USED FOR INSTALLATION.
- SIGNALING LINE CIRCUIT IS CLASS B, STYLE 4
- NOTIFICATION APPLIANCE CIRCUIT IS CLASS B, STYLE Y
- ALL SMOKE DETECTORS SHALL BE INSTALLED AT LEAST 1'-0" FROM FLUORESCENT LIGHT FIXTURES TO AVOID UNWANTED ALARMS AND SHALL BE INSTALLED IN AREAS THAT DO NOT EXCEED THE MANUFACTURER'S OPERATING TEMPERATURE RANGE BETWEEN 32°F AND 120°F.

CENTER FOR SCIENCE AND MATHEMATICS CALIFORNIA STATE POLYTECHNIC UNIVERSITY SAN LUIS OBISPO, CALIFORNIA 93407 FIRE ALARM & EMERGENCY COMMUNICATION SYSTEM

SITE PLAN



CENTER FOR SCIENCE

PROJECT DESCRIPTION

- OCCUPANCY TYPE: A, B, AND H3
- SYSTEM TYPE: CLASS B, ADDRESSABLE, MANUAL
- METHOD OF COMMUNICATION: TELEPHONE
- SCOPE OF WORK: FIRE ALARM & VOICE EVACUATION SYSTEMS

SEQUENCE OF OPERATIONS MATRIX

| EVENT | ACTION | | | | | | | | | | | | |
|--|--------|---|---|---|---|---|---|---|---|----|----|----|----|
| | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 |
| FIRE ALARM CONTROL UNIT | | | | | | | | | | | | | |
| PANEL SUPERVISORY CONDITION (TEST BYPASS) ON ACM-24 AT | X | | X | X | | | | | | | | | X |
| PANEL TROUBLE CONDITION (AC POWER FAIL, LOW BATTERY, OPEN CIRCUIT, GROUND FAULT, ETC.) | X | X | X | X | | | | | | | | | X |
| MANUAL PULL STATION ACTIVATION | | X | X | X | X | | | | | | | | |
| SPOT SMOKE DETECTOR ACTIVATION | | X | X | X | X | | | | | | | | |
| DUET SMOKE DETECTOR ACTIVATION | | X | X | X | X | | | | | | | | |
| AIR HANDLING UNIT DUCT SMOKE DETECTOR ACTIVATION | | X | X | X | X | | | | | | | | |
| SPRINKLER TAMPER SWITCH | | X | X | X | | | | | | | | | |
| SPRINKLER WATER FLOW ACTIVATION | | X | X | X | | | | | | | | | |
| FIRE PUMP RUNNINGS | | X | X | X | | | | | | | | | |
| FIRE PUMP LOSS OF PHASE | | X | X | X | | | | | | | | | |
| FIRE PUMP PHASE REVERSAL | | X | X | X | | | | | | | | | |
| HEAT DETECTOR ACTIVATION (ELEVATOR EQUIPMENT) | | X | X | X | X | | | | | | | | |
| ELEVATOR LOBBY (SMOKE) / ELEVATOR HOISTWAYS | | X | X | X | X | | | | | | | | |
| SHUNT TRIP POWER SUPERVISION | | X | X | X | | | | | | | | | |
| GENERAL ALARM (ANYWHERE WITHIN THE BUILDING) | | X | X | X | X | | | | | | | | |
| ATRILUM SMOKE CONTROL SYSTEM ALARM | | X | X | X | | | | | | | | | |
| BEAM SMOKE DETECTOR WITHIN ATRIUM | | X | X | X | | | | | | | | | |
| PULL STATION WITHIN ATRIUM | | X | X | X | | | | | | | | | |
| SPRINKLER WATER FLOW WITHIN ATRIUM | | X | X | X | | | | | | | | | |

SYMBOL LEGEND

| COUNT | FIRE ALARM SYMBOLS | MODEL # | CSFM LISTING # |
|-------|---|----------|--------------------------------|
| 31 | [F] MANUAL PULL STATION | NBG-12LX | 7150-0028:0199 |
| 73 | [F] STROBE ONLY | SW | 7320-1653:201 |
| 165 | [F] SPEAKER/STROBE | SPWS | 7320-1653:201 |
| 6 | [F] SPEAKER ONLY | SPW | 7320-1653:201 |
| 7 | [F] WP SPEAKER - WEATHER PROOF | SPWK | 7320-1653:201 |
| 0 | [H] HEAT DETECTOR | FST-851 | 7270-0028:196 |
| 18 | [S] SMOKE DETECTOR | FSP-851 | 7272-0028:206 |
| 64 | [S] _D SMOKE DETECTOR - DUCT | DNR | 3242-1653:209 |
| 23 | [S] _{BT} BEAM SMOKE DETECTOR - TRANSMITTER | OSE-SPW | 7260-1728:0121 |
| 15 | [S] _{BR} BEAM SMOKE DETECTOR- RECEIVER | OSI-90 | 7260-1728:0121 |
| 1 | [FACP] FIRE ALARM CONTROL PANEL | NFS2-640 | 7165-0028:0243 |
| 5 | [RNPS] REMOTE NOTIFICATION POWER SUPPLY | ACPS-610 | 7315-0028:248 |
| 4 | [FATC] FIRE ALARM TERMINAL CABINET | N/A | N/A |
| 32 | [EOLR] END OF LINE RESISTOR | N/A | N/A |
| 2 | [RA] REMOTE ANNUNCIATOR | FDU-80 | 7120-0028:209 |
| 8 | [MD] MAGNETIC DOOR HOLDER | N/A | BY OTHERS |
| 21 | [AM] ADDRESSABLE MODULE | FMM-1 | 7300-0028:0219 |
| 12 | [RM] RELAY MODULE | FRM-1 | 7300-0028:219 |
| 16 | [WFS] WATER FLOW SWITCH | N/A | BY OTHERS |
| 10 | [VTS] VALVE TAMPER SWITCH | N/A | BY OTHERS |
| 21 | [FDM] DUAL MONITOR MODULE | FDM-1 | 7300-0028:0219 |
| 64 | [FDRM] DUAL RELAY / MONITOR MODULE | FDRM-1 | 7300-0028:0219 |
| 12 | [FJ] FIRE FIGHTER'S PHONE JACKS | FTM-1 | 7300-1652:0182 |
| 4 | [DAA2] DIGITAL AUDIO AMPLIFIERS | DAA2 | 7170-0028:223 7170-0028:224 |
| 1 | [XP6-R] SIX RELAY CONTROL MODULE | XP6-R | 7300-0028:0219 |
| 1 | [XP10-M] TEN-INPUT MONITOR MODULE | XP10-M | 7300-0028:0219 |

WIRING LEGEND

| LABEL | GAUGE | USE | TYPE (OR EQUIVALENT) |
|-------|-------|-------------------------|----------------------|
| A | 16/2 | UTP SLC | WEST PENN D990 |
| B | 16/2 | TSP SPEAKER | WEST PENN D991 |
| C | 14 | NAC VISUAL | THHN |
| D | 14 | 24 VDC | THHN |
| E | 16/4 | TS ANNUNCIATOR | WEST PENN 993 |
| F | 14/2 | TSP FIRE FIGHTERS PHONE | WEST PENN D995 |

DRAWING INDEX

- | | | |
|----|--------------------|----------|
| 1 | COVER SHEET | FA 0.0 |
| 2 | RISER DIAGRAM | FA 1.0 |
| 3 | FIRST FLOOR WEST | FA 3.01W |
| 4 | SECOND FLOOR EAST | FA 3.02E |
| 5 | SECOND FLOOR WEST | FA 3.02W |
| 6 | THIRD FLOOR EAST | FA 3.03E |
| 7 | THIRD FLOOR WEST | FA 3.03W |
| 8 | FOURTH FLOOR EAST | FA 3.04E |
| 9 | FOURTH FLOOR WEST | FA 3.04W |
| 10 | FIFTH FLOOR EAST | FA 3.05E |
| 11 | FIFTH FLOOR WEST | FA 3.05W |
| 12 | SIXTH FLOOR EAST | FA 3.06E |
| 13 | SEVENTH FLOOR EAST | FA 3.07E |
| 14 | CALCULATIONS | FA 4.0 |
| 15 | DETAILS | FA 5.0 |

CODE REGULATIONS

| APPLICABLE CODES | CALIFORNIA CODE REGULATIONS |
|---|-----------------------------|
| 2007 BUILDING STANDARDS ADMINISTRATIVE CODE | TITLE 24 PART 1 |
| 2007 CALIFORNIA BUILDING CODE (CBC) | TITLE 24 PART 2 |
| 2007 CALIFORNIA ELECTRICAL CODE (CEC) | TITLE 24 PART 3 |
| 2007 CALIFORNIA MECHANICAL CODE (CMC) | TITLE 24 PART 4 |
| 2007 CALIFORNIA PLUMBING CODE (CPC) | TITLE 24 PART 5 |
| 2007 CALIFORNIA ENERGY CODE | TITLE 24 PART 6 |
| 2007 CALIFORNIA ELEVATOR SAFETY CONSTRUCTION CODE | TITLE 24 PART 7 |
| 2007 CALIFORNIA HISTORICAL BUILDING CODE | TITLE 24 PART 8 |
| 2007 CALIFORNIA FIRE CODE (FC) | TITLE 24 PART 9 |
| 2007 CALIFORNIA REFERENCED STANDARDS CODE | TITLE 24 PART 12 |
| 2007 AUTOMATIC SPRINKLER SYSTEMS | NFPA 13 |
| 2007 STATIONARY PUMPS | NFPA 20 |
| 2007 NATIONAL FIRE ALARM CODES (CALIFORNIA AMENDED) | NFPA 72 |
| 2007 STANDARD FOR INSTALLATION OF AIR-CONDITIONING | NFPA90A |
| 2007 STANDARD FOR INSTALLATION OF WARM AIR HEATING | NFPA 90B |
| 2006 STANDARD FOR SMOKE-CONTROL SYSTEMS UTILIZING BARRIERS AND PRESSURE DIFFERENCES | NFPA 92A |
| 2005 STANDARD FOR SMOKE MANAGEMENT SYSTEMS IN MALLS, ATRIA, AND LARGE SPACES | NFPA 92B |

Deep Blue Integration
 Consulting - Design - Installation
 Service - Monitoring
 Deep Blue Integration, Inc
 3442 Empress Drive Suite C
 San Luis Obispo, CA 93401
 C-10, C-16 #943465 ACO#8864
 Toll Free: 888-830-0031
 805-791-2037
 www.deepblueintegration.com

| DATE | DESCRIPTION | APPR. |
|-----------|-------------|-------|
| 6/14/2011 | | |
| 5/19/2012 | | |
| 8/20/2012 | | |
| 1/15/2013 | | |
| 4/2/2013 | | |
| 8/23/2013 | | |

| | |
|--|---------------------------------------|
| DESIGNED BY: Curtis Streecher | DATE: 08/23/2013 |
| DRAWN BY: Derek Richardson | SCALE: |
| CHECKED BY: CURTIS STREECHER, SET NICET IV #102872 | DRAWING CODE: FA-ALL DRAWINGS CPFS |
| PROJECT ENGINEER: Integral Design Associates, INC. | |

**CENTER FOR SCIENCE AND MATHEMATICS
CALIFORNIA STATE POLYTECHNIC UNIVERSITY
SAN LUIS OBISPO, CA**

CSFM #18-40-03-001

AS-BUILT
SET COVER SHEET

SYMBOL LEGEND

| COUNT | FIRE ALARM SYMBOLS | MODEL # | CSFM LISTING # |
|-------|--------------------|-----------------------------------|-------------------------------------|
| 31 | [Symbol] | MANUAL PULL STATION | NBG-12LX 7150-0028:0199 |
| 73 | [Symbol] | STROBE ONLY | SW 7320-1653:201 |
| 165 | [Symbol] | SPEAKER/STROBE | SPWS 7320-1653:201 |
| 6 | [Symbol] | SPEAKER ONLY | SPW 7320-1653:201 |
| 7 | [Symbol] | SPEAKER - WEATHER PROOF | SPWK 7320-1653:201 |
| 0 | [Symbol] | HEAT DETECTOR | FST-851 7270-0028:196 |
| 18 | [Symbol] | SMOKE DETECTOR | FSP-851 7272-0028:206 |
| 64 | [Symbol] | SMOKE DETECTOR - DUCT | DNR 3242-1653:209 |
| 23 | [Symbol] | BEAM SMOKE DETECTOR - TRANSMITTER | OSE-SPW 7260-1728:0121 |
| 15 | [Symbol] | BEAM SMOKE DETECTOR-RECEIVER | OSI-90 7260-1728:0121 |
| 1 | [Symbol] | FIRE ALARM CONTROL PANEL | NFS2-640 7165-0028:0243 |
| 5 | [Symbol] | REMOTE NOTIFICATION POWER SUPPLY | ACPS-610 7315-0028:248 |
| 4 | [Symbol] | FIRE ALARM TERMINAL CABINET | N/A N/A |
| 32 | [Symbol] | END OF LINE RESISTOR | N/A N/A |
| 2 | [Symbol] | REMOTE ANNUNCIATOR | FDU-80 7120-0028:209 |
| 8 | [Symbol] | MAGNETIC DOOR HOLDER | N/A BY OTHERS |
| 21 | [Symbol] | ADDRESSABLE MODULE | FMM-1 7300-0028:0219 |
| 12 | [Symbol] | RELAY MODULE | FRM-1 7300-0028:219 |
| 16 | [Symbol] | WATER FLOW SWITCH | N/A BY OTHERS |
| 10 | [Symbol] | VALVE TAMPER SWITCH | N/A BY OTHERS |
| 21 | [Symbol] | DUAL MONITOR MODULE | FDM-1 7300-0028:0219 |
| 64 | [Symbol] | DUAL RELAY / MONITOR MODULE | FDRM-1 7300-0028:0219 |
| 12 | [Symbol] | FIRE FIGHTERS PHONE JACKS | FTM-1 7300-1652:0182 |
| 4 | [Symbol] | DIGITAL AUDIO AMPLIFIERS | DAA2 7170-0028:223 7170-0028:224 |
| 1 | [Symbol] | SIX RELAY CONTROL MODULE | XP6-R 7300-0028:0219 |
| 1 | [Symbol] | TEN-INPUT MONITOR MODULE | XP10-M 7300-0028:0219 |

GENERAL NOTES:

- The Notification Appliance Circuits vary between 14 AWG and 12 AWG, see voltage drops for correct sizing.
- All smoke detectors shall be placed at least 1'-0" from fluorescent light fixtures to avoid unwanted alarms and in areas that will not exceed manufacturer's specified operating temperature 32°F to 120°F.

SHEET NOTES:

- The fire alarm control panel shall be connected to a separate dedicated branch circuit, maximum 20 amperes. This circuit shall be labeled at the main power distribution panel as FIRE ALARM. Fire alarm control panel primary power wiring shall be 12 AWG. The control panel cabinet shall be grounded securely to either a cold water pipe or grounding rod.
 - The riser going between floors will be in 2" conduit or larger.
 - 6.10.1.16* All circuits necessary for the operation of two-way telephone communication systems shall be installed using one of the following methods:
 - A 2-hour fire rated circuit integrity (CI) cable
 - A 2-hour fire rated cable system (electrical circuit protective system)
 - A 2-hour fire rated enclosure
 - Performance alternatives approved by the authority having jurisdiction
 - Buildings fully protected by an automatic sprinkler system installed in accordance with NFPA 13. Standard for the Installation of Sprinkler Systems, with the wiring or cables installed in metal raceways and in accordance with Article 760 of NFPA 70
- 6.10.1.16 One or more of the following means might be considered acceptable to provide a level of survivability consistent with the intent of this requirement:
- Routing two-way telephone circuits separately
 - Using short-circuit fault tolerant circuits


Deep Blue Integration
 Consulting - Design - Installation
 Service - Monitoring
 Deep Blue Integration, Inc
 3442 Empress Drive Suite C
 San Luis Obispo, CA 93401
 C-10, C-16 #943465 ACO#6884
 Toll Free: 888-6000-DBI FAX:
 805-791-2037
 www.deepblueintegration.com

Revisions

| NO. | DATE | DESCRIPTION | BY | APP. |
|-----|------------|---|----|------|
| 1 | 8/24/2013 | REVIEW COMMENTS | | |
| 2 | 8/27/2013 | CRP # 982.1 & FT 99 | | |
| 3 | 8/20/2012 | SFM REVIEW COMMENTS | | |
| 4 | 11/29/2013 | CRS 93.2 | | |
| 5 | 8/22/2013 | FA & SMOKE CONTROL SFM COMMENTS AS-BUILT DRAWINGS | | |

| | | | |
|---------------------------------|--------------------------------|--|--|
| DESIGNED BY: Curtis Streeter | DATE: 08/23/2013 | SCALE: | DRAWING CODE: FA-ALL DRAWINGS CPDPS |
| DRAWN BY: Dean Richardson | CHECKED BY: Curtis Streeter | PROJECT ENGINEER: Integral Design Associates Inc. | |

CENTER FOR SCIENCE AND MATHEMATICS
CALIFORNIA STATE POLYTECHNIC UNIVERSITY
 SAN LUIS OBISPO, CA
 CSFM #18-10-03-0001




WIRING LEGEND

| LABEL | GAUGE | USE | TYPE (OR EQUIVALENT) |
|-------|-------|-------------------------|----------------------|
| A | 16/2 | UTP SLC | WEST PENN D990 |
| B | 16/2 | TSP SPEAKER | WEST PENN D991 |
| C | 14 | NAC VISUAL | THHN |
| D | 14 | 24 VDC | THHN |
| E | 16/4 | TS ANNUNCIATOR | WEST PENN 993 |
| F | 14/2 | TSP FIRE FIGHTERS PHONE | WEST PENN D995 |

DRAWING INDEX

| NO. | DESCRIPTION | FA NO. |
|-----|--------------------|----------|
| 1 | COVER SHEET | FA 0.0 |
| 2 | RISER DIAGRAM | FA 1.0 |
| 3 | FIRST FLOOR WEST | FA 3.01W |
| 4 | SECOND FLOOR EAST | FA 3.02E |
| 5 | SECOND FLOOR WEST | FA 3.02W |
| 6 | THIRD FLOOR EAST | FA 3.03E |
| 7 | THIRD FLOOR WEST | FA 3.03W |
| 8 | FOURTH FLOOR EAST | FA 3.04E |
| 9 | FOURTH FLOOR WEST | FA 3.04W |
| 10 | FIFTH FLOOR EAST | FA 3.05E |
| 11 | FIFTH FLOOR WEST | FA 3.05W |
| 12 | SIXTH FLOOR EAST | FA 3.06E |
| 13 | SEVENTH FLOOR EAST | FA 3.07E |
| 14 | CALCULATIONS | FA 4.0 |
| 15 | DETAILS | FA 5.0 |

FIRE ALARM RISER DIAGRAMS



FIRE ALARM FIRST FLOOR WEST
 SCALE 1/8" = 1'0"

SYMBOL LEGEND

| COUNT | FIRE ALARM SYMBOLS | MODEL # | CSFM LISTING # |
|-------|--------------------|----------|--------------------------------|
| 31 | | NBG-12LX | 7150-0028-0199 |
| 73 | | SW | 7320-1653-201 |
| 165 | | SPWS | 7320-1653-201 |
| 6 | | SPW | 7320-1653-201 |
| 7 | | SPWK | 7320-1653-201 |
| 0 | | FST-951 | 7272-0028-196 |
| 18 | | FSP-851 | 7272-0028-206 |
| 64 | | DNR | 3242-1853-209 |
| 29 | | OSE-SPW | 7260-1728-0121 |
| 15 | | OSI-90 | 7260-1728-0121 |
| 1 | | NFS2-640 | 7165-0028-0243 |
| 5 | | ACPS-610 | 7315-0028-248 |
| 4 | | N/A | N/A |
| 32 | | N/A | N/A |
| 2 | | FDU-80 | 7120-0028-209 |
| 8 | | N/A | BY OTHERS |
| 21 | | FMM-1 | 7300-0028-019 |
| 12 | | FRM-1 | 7300-0028-219 |
| 16 | | N/A | BY OTHERS |
| 10 | | N/A | BY OTHERS |
| 21 | | FDM-1 | 7300-0028-0219 |
| 64 | | FDRM-1 | 7300-0028-0219 |
| 12 | | FTM-1 | 7300-1652-0182 |
| 4 | | DAA2 | 7170-0028-223 7170-0028-224 |
| 1 | | XP6-R | 7300-0028-0219 |
| 1 | | XP10-M | 7300-0028-0219 |

WIRING LEGEND

| LABEL | GAUGE | USE | TYPE (OR EQUIVALENT) |
|-------|----------|---------------------|----------------------|
| A | 16/2 UTP | SLC | WEST PENN D990 |
| B | 16/2 TSP | SPEAKER | WEST PENN D991 |
| C | 14 | NAC VISUAL | THHN |
| D | 14 | 24 VDC | THHN |
| E | 16/4 TS | ANNUNCIATOR | WEST PENN 993 |
| F | 14/2 TSP | FIRE FIGHTERS PHONE | WEST PENN D995 |

DRAWING INDEX

| | | |
|----|--------------------|----------|
| 1 | COVER SHEET | FA 0.0 |
| 2 | RISER DIAGRAM | FA 1.0 |
| 3 | FIRST FLOOR WEST | FA 3.01W |
| 4 | SECOND FLOOR EAST | FA 3.02E |
| 5 | SECOND FLOOR WEST | FA 3.02W |
| 6 | THIRD FLOOR EAST | FA 3.03E |
| 7 | THIRD FLOOR WEST | FA 3.03W |
| 8 | FOURTH FLOOR EAST | FA 3.04E |
| 9 | FOURTH FLOOR WEST | FA 3.04W |
| 10 | FIFTH FLOOR EAST | FA 3.05E |
| 11 | FIFTH FLOOR WEST | FA 3.05W |
| 12 | SIXTH FLOOR EAST | FA 3.06E |
| 13 | SEVENTH FLOOR EAST | FA 3.07E |
| 14 | CALCULATIONS | FA 4.0 |
| 15 | DETAILS | FA 5.0 |

REVISIONS

| NO. | DATE | DESCRIPTION | BY | APPR. |
|-----|-----------|-------------|----|-------|
| 1 | 6/14/2011 | | | |
| 2 | 5/19/2012 | | | |
| 3 | 8/20/2012 | | | |
| 4 | 1/15/2013 | | | |
| 5 | 4/9/2013 | | | |
| 6 | 8/23/2013 | | | |

REVIEW COMMENTS

| NO. | DATE | DESCRIPTION |
|-----|-----------|---------------------------------|
| 1 | 8/23/2013 | FA & SMOKE CONTROL SFT COMMENTS |
| 2 | 8/23/2013 | AS-BUILT DRAWINGS |

| | | | |
|---|---------------------|--------|---------------------------------------|
| DESIGNED BY: Curtis Streever | DATE: 08/23/2013 | SCALE: | DRAWING CODE: FA ALL DRAWINGS CPFS |
| DRAWN BY: Derek Richardson | | | |
| CHECKED BY: CURTIS STREEVER, SET NICETV #102672 | | | |
| PROJECT ENGINEER: Ingral Design Associates, INC. | | | |

CENTER FOR SCIENCE AND MATHEMATICS
CALIFORNIA STATE POLYTECHNIC UNIVERSITY
 SAN LUIS OBISPO, CA
 CSFM #18-40-03-0001



FIRE ALARM SECOND FLOOR WEST
 SCALE 1/8" = 1'0"

| SYMBOL LEGEND | | | |
|---------------|--------------------|----------|--------------------------------|
| COUNT | FIRE ALARM SYMBOLS | MODEL # | CSPM LISTING # |
| 01 | [Symbol] | MSG-12LX | 7150-0028:0199 |
| 73 | [Symbol] | SW | 7320-1653:201 |
| 165 | [Symbol] | SPWS | 7320-1653:201 |
| 6 | [Symbol] | SPW | 7320-1653:201 |
| 7 | [Symbol] | SPWK | 7320-1653:201 |
| 0 | [Symbol] | FST-851 | 7270-0028:196 |
| 18 | [Symbol] | FSP-851 | 7272-0028:206 |
| 64 | [Symbol] | DNR | 3242-1653:209 |
| 23 | [Symbol] | OSE-SPW | 7260-1726:0121 |
| 15 | [Symbol] | OSI-90 | 7260-1726:0121 |
| 1 | [Symbol] | NFS2-640 | 7165-0028:0243 |
| 5 | [Symbol] | ACPS-610 | 7315-0028:248 |
| 4 | [Symbol] | N/A | N/A |
| 32 | [Symbol] | N/A | N/A |
| 2 | [Symbol] | FDU-80 | 7120-0028:209 |
| 8 | [Symbol] | N/A | BY OTHERS |
| 21 | [Symbol] | FMM-1 | 7300-0028:0219 |
| 12 | [Symbol] | FRM-1 | 7300-0028:219 |
| 16 | [Symbol] | N/A | BY OTHERS |
| 10 | [Symbol] | N/A | BY OTHERS |
| 21 | [Symbol] | FDM-1 | 7300-0028:0219 |
| 64 | [Symbol] | FDPM-1 | 7300-0028:0219 |
| 12 | [Symbol] | FTM-1 | 7300-1652:0182 |
| 4 | [Symbol] | DAR2 | 7170-0028:223 7170-0028:224 |
| 1 | [Symbol] | XPB-R | 7300-0028:0219 |
| 1 | [Symbol] | XP10-M | 7300-0028:0219 |


| WIRING LEGEND | | | |
|---------------|----------|---------------------|----------------------|
| LABEL | GAUGE | USE | TYPE (OR EQUIVALENT) |
| A | 16/2 UTP | SLC | WEST PENN D990 |
| B | 16/2 TSP | SPEAKER | WEST PENN D991 |
| C | 14 | NAC VISUAL | THHN |
| D | 14 | 24 VDC | THHN |
| E | 16/4 TS | ANNUNCIATOR | WEST PENN 993 |
| F | 14/2 TP | FIRE FIGHTERS PHONE | WEST PENN D995 |

| DRAWING INDEX | | |
|---------------|--------------------|----------|
| 1 | COVER SHEET | FA 0.0 |
| 2 | RISER DIAGRAM | FA 1.0 |
| 3 | FIRST FLOOR WEST | FA 3.01W |
| 4 | SECOND FLOOR EAST | FA 3.02E |
| 5 | SECOND FLOOR WEST | FA 3.02W |
| 6 | THIRD FLOOR EAST | FA 3.03E |
| 7 | THIRD FLOOR WEST | FA 3.03W |
| 8 | FOURTH FLOOR EAST | FA 3.04E |
| 9 | FOURTH FLOOR WEST | FA 3.04W |
| 10 | FIFTH FLOOR EAST | FA 3.05E |
| 11 | FIFTH FLOOR WEST | FA 3.05W |
| 12 | SIXTH FLOOR EAST | FA 3.06E |
| 13 | SEVENTH FLOOR EAST | FA 3.07E |
| 14 | CALCULATIONS | FA 4.0 |
| 15 | DETAILS | FA 5.0 |

| REVISIONS | REVIEW COMMENTS | DATE | APPR. |
|-----------|-------------------------------|-----------|-------|
| 1 | CRB # 883.1 & F 89 | 5/12/2012 | |
| 2 | SFM REVIEW COMMENTS | 8/20/2012 | |
| 3 | CRB 83.2 | 1/15/2013 | |
| 4 | FA SMOKE CONTROL SFM COMMENTS | 4/23/2013 | |
| 5 | AS-BUILT DRAWINGS | 8/23/2013 | |

| | | |
|---------------------------------|------------------|----------------------|
| DESIGNED BY: | DATE: | 09/23/2013 |
| Curtis Steiner | DRAWN BY: | |
| | Derek Richardson | |
| CHECKED BY: | SCALE: | |
| CURTIS STEINER, SET | DRAWING CODE: | FA ALL DRAWINGS CPFS |
| INCE TY #162672 | | |
| PROJECT ENGINEER: | | |
| Integral Design Associates INC. | | |

CENTER FOR SCIENCE AND MATHEMATICS
CALIFORNIA STATE POLYTECHNIC UNIVERSITY
 SAN LUIS OBISPO, CA
 CSPM #18-40-03-0001



FIRE ALARM SECOND FLOOR EAST ↑
 SCALE 1/8" = 1'0"

SHEET NOTES

- 1 PROVIDE FIRE ALARM BEAM DETECTORS TRANSMITTER AND RECEIVER. INTERLOCK WITH SMOKE EVACUATION SYSTEM SUCH THAT WHEN BEAM DETECTOR IS ACTIVATED, SMOKE EVACUATION SYSTEM IS ACTIVATED. REFER TO DETAIL 4 & 5/FA5.0.
- 2 ACTIVATION OF A MANUAL PULL STATION, BEAM DETECTOR OR SPRINKLER WATER FLOW WITHIN THE ATRIUM SHALL ACTIVATE ATRIUM SMOKE EVACUATION SYSTEM. SMOKE EVACUATION SYSTEM SHALL FUNCTION AS DIRECTED BY MECHANICAL DOCUMENTS. REFER TO DETAIL 9/M5.05 FOR ADDITIONAL INFORMATION.
- 3 ACTIVATION OF AN ALARM ANYWHERE WITHIN THE BUILDING SHALL SHUT DOWN ALL AIR HANDLING UNITS.
- 4 ACTIVATION OF THE ATRIUM SMOKE CONTROL SYSTEM SHALL OPEN ALL ATRIUM DOORS WITH MOTORIZED DOOR OPERATORS.

SYMBOL LEGEND

| COUNT | FIRE ALARM SYMBOLS | MODEL # | CSFM LISTING # |
|-------|---------------------------------------|----------|--------------------------------|
| 31 | MANUAL PULL STATION | NBG-12LX | 7150-0028:0199 |
| 73 | STROBE ONLY | SW | 7320-1653:201 |
| 166 | SPEAKER/STROBE | SPWS | 7320-1653:201 |
| 6 | SPEAKER ONLY | SPW | 7320-1653:201 |
| 7 | SPEAKER - WEATHER PROOF | SPWK | 7320-1653:201 |
| 0 | HEAT DETECTOR | FST-851 | 7270-0028:196 |
| 18 | SMOKE DETECTOR | FSP-651 | 7272-0028:206 |
| 64 | SMOKE DETECTOR - DUCT | DNR | 3242-1653:209 |
| 23 | BEAM SMOKE DETECTOR - TRANSMITTER | OSE-SPW | 7280-1728:0121 |
| 15 | BEAM SMOKE DETECTOR - RECEIVER | OSR-90 | 7280-1728:0121 |
| 1 | FACP FIRE ALARM CONTROL PANEL | NFS2-640 | 7185-0028:0243 |
| 5 | RNPS REMOTE NOTIFICATION POWER SUPPLY | ACPS-610 | 7315-0028:240 |
| 4 | FATC FIRE ALARM TERMINAL CABINET | N/A | N/A |
| 32 | END OF LINE RESISTOR | N/A | N/A |
| 2 | RAA REMOTE ANNUNCIATOR | FDU-80 | 7120-0028:209 |
| 8 | MH MAGNETIC DOOR HOLDER | N/A | BY OTHERS |
| 21 | AM ADDRESSABLE MODULE | FMA-1 | 7300-0028:0219 |
| 12 | RM RELAY MODULE | FRM-1 | 7300-0028:219 |
| 16 | WFS WATER FLOW SWITCH | N/A | BY OTHERS |
| 10 | VTS VALVE TAMPER SWITCH | N/A | BY OTHERS |
| 21 | DMR DUAL MONITOR MODULE | FDM-1 | 7300-0028:0219 |
| 64 | FDRM DUAL RELAY / MONITOR MODULE | FDRM-1 | 7300-0028:0219 |
| 12 | FFJ FIRE FIGHTERS PHONE JACKS | FTM-1 | 7300-1652:0182 |
| 4 | DAAR DIGITAL AUDIO AMPLIFIERS | DAAR | 7170-0028:223 7170-0028:224 |
| 1 | XPR SIX RELAY CONTROL MODULE | XP6-R | 7300-0028:0219 |
| 1 | XPI TEN-INPUT MONITOR MODULE | XP10-M | 7300-0028:0219 |

WIRING LEGEND

| LABEL | GAUGE | USE | TYPE (OR EQUIVALENT) |
|-------|----------|---------------------|----------------------|
| A | 16/2 | UTP | WEST PENN D990 |
| B | 16/2 | TSP | WEST PENN D991 |
| C | 14 | NAC VISUAL | THHN |
| D | 14 | 24 VDC | THHN |
| E | 16/4 TS | ANNUNCIATOR | WEST PENN 993 |
| F | 14/2 TSP | FIRE FIGHTERS PHONE | WEST PENN D995 |

DRAWING INDEX


| | | |
|----|--------------------|----------|
| 1 | COVER SHEET | FA 0.0 |
| 2 | RISER DIAGRAM | FA 1.0 |
| 3 | FIRST FLOOR WEST | FA 3.01W |
| 4 | SECOND FLOOR EAST | FA 3.02E |
| 5 | SECOND FLOOR WEST | FA 3.02W |
| 6 | THIRD FLOOR EAST | FA 3.03E |
| 7 | THIRD FLOOR WEST | FA 3.03W |
| 8 | FOURTH FLOOR EAST | FA 3.04E |
| 9 | FOURTH FLOOR WEST | FA 3.04W |
| 10 | FIFTH FLOOR EAST | FA 3.05E |
| 11 | FIFTH FLOOR WEST | FA 3.05W |
| 12 | SIXTH FLOOR EAST | FA 3.06E |
| 13 | SEVENTH FLOOR EAST | FA 3.07E |
| 14 | CALCULATIONS | FA 4.0 |
| 15 | DETAILS | FA 5.0 |

Revisions

| NO. | DATE | DESCRIPTION |
|-----|-----------|---------------------------------------|
| 1 | 8/14/2011 | REVIEW COMMENTS |
| 2 | 8/14/2011 | REVIEW COMMENTS |
| 3 | 8/20/2012 | CFB 10561.1 F1 B9 SFM REVIEW COMMENTS |
| 4 | 1/15/2013 | CFB 83.2 |
| 5 | 4/30/2013 | FA & SMOKE CONTROL SFM COMMENTS |
| 6 | 8/23/2013 | AS-BUILT DRAWINGS |

| | |
|---|---------------------------------------|
| DESIGNED BY: Curtis Streeter | DATE: 08/23/2013 |
| DRAWN BY: Derek Richardson | SCALE: |
| CHECKED BY: CURTIS STREETER, SET NICET IV #102872 | DRAWING CODE: FA ALL DRAWINGS CPFS |
| PROJECT ENGINEER: Integral Design Associates, INC. | |

CENTER FOR SCIENCE AND MATHEMATICS
CALIFORNIA STATE POLYTECHNIC UNIVERSITY
 SAN LUIS OBISPO, CA
 CSFM #18-40-03-0001



FIRE ALARM THIRD FLOOR WEST
 SCALE 1/8" = 1'0"

| COUNT | FIRE ALARM SYMBOLS | MODEL # | CSEFM LISTING # |
|-------|--------------------|-----------------------------------|-------------------------------------|
| 29 | [MPS] | MANUAL PULL STATION | NBG-12LX 7150-0028-0199 |
| 73 | [S] | STROBE ONLY | SW 7320-1653-201 |
| 153 | [SPWS] | SPEAKER/STROBE | SPWS 7320-1653-201 |
| 6 | [SPW] | SPEAKER ONLY | SPW 7320-1653-201 |
| 7 | [SPWK] | SPEAKER - WEATHER PROOF | SPWK 7320-1653-201 |
| 0 | [HST] | HEAT DETECTOR | FST-851 7270-0028-196 |
| 18 | [SD] | SMOKE DETECTOR | FSP-851 7270-0028-206 |
| 64 | [DNR] | SMOKE DETECTOR - DUCT | DNR 3042-1653-209 |
| 23 | [OSI-SPW] | BEAM SMOKE DETECTOR - TRANSMITTER | OSE-SPW 7260-1728-0121 |
| 15 | [OSI-R] | BEAM SMOKE DETECTOR - RECEIVER | OSI-R 7260-1728-0121 |
| 1 | [FACP] | FIRE ALARM CONTROL PANEL | NFS2-640 7165-0028-0243 |
| 5 | [RNPS] | REMOTE NOTIFICATION POWER SUPPLY | ACPS-610 7315-0028-248 |
| 5 | [FATC] | FIRE ALARM TERMINAL CABINET | N/A N/A |
| 32 | [EOLR] | END OF LINE RESISTOR | N/A N/A |
| 2 | [RA] | REMOTE ANNUNCIATOR | FDU-80 7120-0028-209 |
| 8 | [MD] | MAGNETIC DOOR HOLDER | N/A BY OTHERS |
| 19 | [AM] | ADDRESSABLE MODULE | FMM-1 7300-0028-0219 |
| 9 | [RM] | RELAY MODULE | FRM-1 7300-0028-219 |
| 16 | [WFS] | WATER FLOW SWITCH | N/A BY OTHERS |
| 22 | [VTS] | VALVE TAMPER SWITCH | N/A BY OTHERS |
| 21 | [FDM] | DUAL MONITOR MODULE | FDM-1 7300-0028-0219 |
| 64 | [FDRM] | DUAL RELAY / MONITOR MODULE | FDRM-1 7300-0028-0219 |
| 12 | [FJ] | FIRE FIGHTERS PHONE JACKS | FTM-1 7300-1652-0182 |
| 4 | [DAA2] | DIGITAL AUDIO AMPLIFIERS | DAA2 7170-0028-223 7170-0028-224 |
| 1 | [XPR-R] | SIX RELAY CONTROL MODULE | XPR-R 7300-0028-0219 |
| 1 | [XPI-M] | TEN-INPUT MONITOR MODULE | XPI-M 7300-0028-0219 |

| LABEL | GAUGE | USE | TYPE (OR EQUIVALENT) |
|-------|----------|---------------------|----------------------|
| A | 16/2 UTP | SLC | WEST PENN D990 |
| B | 16/2 TSP | SPEAKER | WEST PENN D991 |
| C | 14 | NAC VISUAL | THHN |
| D | 14 | 24 VDC | THHN |
| E | 16/4 TS | ANNUNCIATOR | WEST PENN 993 |
| F | 14/2 TSP | FIRE FIGHTERS PHONE | WEST PENN D995 |

| DRAWING INDEX | | |
|---------------|--------------------|----------|
| 1 | COVER SHEET | FA 0.0 |
| 2 | RISER DIAGRAM | FA 1.0 |
| 3 | FIRST FLOOR WEST | FA 3.01W |
| 4 | SECOND FLOOR EAST | FA 3.02E |
| 5 | SECOND FLOOR WEST | FA 3.02W |
| 6 | THIRD FLOOR EAST | FA 3.03E |
| 7 | THIRD FLOOR WEST | FA 3.03W |
| 8 | FOURTH FLOOR EAST | FA 3.04E |
| 9 | FOURTH FLOOR WEST | FA 3.04W |
| 10 | FIFTH FLOOR EAST | FA 3.05E |
| 11 | FIFTH FLOOR WEST | FA 3.05W |
| 12 | SIXTH FLOOR EAST | FA 3.06E |
| 13 | SEVENTH FLOOR EAST | FA 3.07E |
| 14 | CALCULATIONS | FA 4.0 |
| 15 | DETAILS | FA 5.0 |

Deep Blue Integration
 Consulting - Design - Installation
 Service - Monitoring
 Deep Blue Integration, Inc.
 3442 Empress Drive Suite C
 San Luis Obispo, CA 93401
 C-10, C-16 #943465 ACO#68864
 Toll Free: 888-600-0081 FAX:
 805-781-2037
 www.deepblueintegration.com

| REVISIONS | DATE | DESCRIPTION | APPROVED |
|-----------|-----------|---------------------------------|----------|
| 6/14/2011 | 5/18/2012 | | |
| 5/18/2012 | 4/11/2012 | | |
| 8/20/2012 | 8/20/2012 | SPM REVIEW COMMENTS | |
| 1/15/2013 | 1/15/2013 | CRB #32 | |
| 4/2/2013 | 4/2/2013 | FA & SMOKE CONTROL SPM COMMENTS | |
| 8/23/2013 | 8/23/2013 | AS-BUILT DRAWINGS | |

| | | | |
|---|---------------------|--------|--|
| DESIGNED BY: Curtis Steiner | DATE: 08/23/2013 | SCALE: | DRAWING CODE: FA ALL DRAWINGS CRPFS |
| DRAWN BY: David Richardson | | | |
| CHECKED BY: CURTIS STEINER, SET NCE/TH #16627 | | | |
| PROJECT ENGINEER: Integral Design Associates, INC. | | | |


CENTER FOR SCIENCE AND MATHEMATICS
 CALIFORNIA STATE POLYTECHNIC UNIVERSITY
 SAN LUIS OBISPO, CA
 CSEFM #18-40-03-0001

| REVISIONS | REVIEW COMMENTS | DATE | APPR. |
|-----------|---------------------------------|-----------|-------|
| 1 | CRB #08.1 & F1 89 | 8/14/2011 | |
| 2 | SPM REVIEW COMMENTS | 5/18/2012 | |
| 3 | CRB #3.2 | 4/17/2012 | |
| 4 | FA & SMOKE CONTROL SPM COMMENTS | 8/20/2012 | |
| 5 | AS-BUILT DRAWINGS | 1/15/2013 | |
| 6 | | 4/9/2013 | |
| 7 | | 8/23/2013 | |

| | | | |
|---------------------------------|---------------------|--------|---------------------------------------|
| DESIGNED BY: Curtis Streever | DATE: 08/22/2013 | SCALE: | DRAWING CODE: FA ALL DRAWINGS CPFS |
|---------------------------------|---------------------|--------|---------------------------------------|

| | | |
|-------------------------------|---|--|
| DRAWN BY: Derek Richardson | CHECKED BY: SAFETY REVIEWER, SET DATE: 11/14/2013 | PROJECT ENGINEER: Integral Design Associates INC. |
|-------------------------------|---|--|

**CENTER FOR SCIENCE AND MATHEMATICS
 CALIFORNIA STATE POLYTECHNIC UNIVERSITY**
 SAN LUIS OBISPO, CA
 CSFM #18-40-03-0001



FIRE ALARM THIRD FLOOR EAST
 SCALE 1/8" = 1'0"


SHEET NOTES

- 1 PROVIDE FIRE ALARM BEAM DETECTORS TRANSMITTER AND RECEIVER. INTERLOCK WITH SMOKE EVACUATION SYSTEM SUCH THAT WHEN BEAM DETECTOR IS ACTIVATED, SMOKE EVACUATION SYSTEM IS ACTIVATED. REFER TO DETAIL 4 & 5/FA5.0.
- 2 ACTIVATION OF A MANUAL PULL STATION, BEAM DETECTOR OR SPRINKLER WATER FLOW WITHIN THE ATRIUM SHALL ACTIVATE ATRIUM SMOKE EVACUATION SYSTEM. SMOKE EVACUATION SYSTEM SHALL FUNCTION AS DIRECTED BY MECHANICAL DOCUMENTS. REFER TO DETAIL 9/M5.05 FOR ADDITIONAL INFORMATION.
- 3 ACTIVATION OF AN ALARM ANYWHERE WITHIN THE BUILDING SHALL SHUT DOWN ALL AIR HANDLING UNITS.
- 4 ACTIVATION OF THE ATRIUM SMOKE CONTROL SYSTEM SHALL OPEN ALL ATRIUM DOORS WITH MOTORIZED DOOR OPERATORS.

| SYMBOL LEGEND | | MODEL # | CSFM LISTING # |
|---------------|-----------------------------------|----------|--------------------------------|
| 31 | MANUAL PULL STATION | NBG-12LX | 7150-0028-0199 |
| 73 | STROBE ONLY | SW | 7320-1653-201 |
| 165 | SPEAKER/STROBE | SPWS | 7320-1653-201 |
| 6 | SPEAKER ONLY | SPW | 7320-1653-201 |
| 7 | SPEAKER - WEATHER PROOF | SPWK | 7320-1653-201 |
| 0 | HEAT DETECTOR | FST-851 | 7270-0028-196 |
| 18 | SMOKE DETECTOR | FSP-851 | 7272-0028-206 |
| 64 | SMOKE DETECTOR - DUCT | DNR | 3242-1653-209 |
| 23 | BEAM SMOKE DETECTOR - TRANSMITTER | OSE-SPW | 7260-1728-0121 |
| 15 | BEAM SMOKE DETECTOR - RECEIVER | OSI-90 | 7260-1728-0121 |
| 1 | FIRE ALARM CONTROL PANEL | NFS2-640 | 7165-0028-0243 |
| 5 | REMOTE NOTIFICATION POWER SUPPLY | ACPS-610 | 7315-0028-248 |
| 4 | FIRE ALARM TERMINAL CABINET | N/A | N/A |
| 32 | END OF LINE RESISTOR | N/A | N/A |
| 2 | REMOTE ANNUNCIATOR | FOL-80 | 7120-0028-209 |
| 8 | MAGNETIC DOOR HOLDER | N/A | BY OTHERS |
| 21 | ADDRESSABLE MODULE | FMM-1 | 7300-0028-0219 |
| 12 | RELAY MODULE | FRM-1 | 7300-0028-219 |
| 16 | WATER FLOW SWITCH | N/A | BY OTHERS |
| 10 | VALVE TAMPER SWITCH | N/A | BY OTHERS |
| 21 | DUAL MONITOR MODULE | FDM-1 | 7300-0028-0219 |
| 64 | DUAL RELAY / MONITOR MODULE | FRDM-1 | 7300-0028-0219 |
| 12 | FIRE FIGHTERS PHONE JACKS | FTM-1 | 7300-1652-0182 |
| 4 | DIGITAL AUDIO AMPLIFIERS | DAAZ | 7170-0028-223 7170-0028-224 |
| 1 | SIX RELAY CONTROL MODULE | XP6-R | 7300-0028-0219 |
| 1 | TEN-INPUT MONITOR MODULE | XP10-M | 7300-0028-0219 |

| WIRING LEGEND | | | |
|---------------|----------|---------------------|----------------------|
| LABEL | GAUGE | USE | TYPE (OR EQUIVALENT) |
| A | 16/2 UTP | SLC | WEST PENN D990 |
| B | 16/2 TSP | SPEAKER | WEST PENN D991 |
| C | 14 | NAC VISUAL | THHN |
| D | 14 | 24 VDC | THHN |
| E | 16/4 TS | ANNUNCIATOR | WEST PENN 993 |
| F | 14/2 TSP | FIRE FIGHTERS PHONE | WEST PENN D995 |

| DRAWING INDEX | | |
|---------------|--------------------|----------|
| 1 | COVER SHEET | FA 0.0 |
| 2 | RISER DIAGRAM | FA 1.0 |
| 3 | FIRST FLOOR WEST | FA 3.01W |
| 4 | SECOND FLOOR EAST | FA 3.02E |
| 5 | SECOND FLOOR WEST | FA 3.02W |
| 6 | THIRD FLOOR EAST | FA 3.03E |
| 7 | THIRD FLOOR WEST | FA 3.03W |
| 8 | FOURTH FLOOR EAST | FA 3.04E |
| 9 | FOURTH FLOOR WEST | FA 3.04W |
| 10 | FIFTH FLOOR EAST | FA 3.05E |
| 11 | FIFTH FLOOR WEST | FA 3.05W |
| 12 | SIXTH FLOOR EAST | FA 3.06E |
| 13 | SEVENTH FLOOR EAST | FA 3.07E |
| 14 | CALCULATIONS | FA 4.0 |
| 15 | DETAILS | FA 5.0 |



FIRE ALARM FOURTH FLOOR WEST
 SCALE 1/8" = 1'0"

| COUNT | FIRE ALARM SYMBOLS | MODEL # | CSFM LISTING # |
|-------|-----------------------------------|----------|--------------------------------|
| 31 | MANUAL PULL STATION | NBS-12LX | 7150-0028:0199 |
| 73 | STROBE ONLY | SW | 7320-1653:201 |
| 165 | SPEAKER/STROBE | SPWS | 7320-1653:201 |
| 6 | SPEAKER ONLY | SPW | 7320-1653:201 |
| 7 | SPEAKER - WEATHER PROOF | SPWK | 7320-1653:201 |
| 0 | HEAT DETECTOR | FST-851 | 7270-0028:196 |
| 18 | SMOKE DETECTOR | FSP-851 | 7272-0028:206 |
| 64 | SMOKE DETECTOR - DUCT | DNR | 3242-1653:209 |
| 23 | BEAM SMOKE DETECTOR - TRANSMITTER | OSE-SPW | 7280-1728:0121 |
| 15 | BEAM SMOKE DETECTOR - RECEIVER | OSI-90 | 7280-1728:0121 |
| 1 | FIRE ALARM CONTROL PANEL | NFS2-640 | 7165-0028:0243 |
| 5 | REMOTE NOTIFICATION POWER SUPPLY | ACPS-610 | 7315-0028:248 |
| 4 | FIRE ALARM TERMINAL CABINET | N/A | N/A |
| 32 | END OF LINE RESISTOR | N/A | N/A |
| 2 | REMOTE ANNUNCIATOR | FDU-80 | 7120-0028:209 |
| 8 | MAGNETIC DOOR HOLDER | N/A | BY OTHERS |
| 21 | ADDRESSABLE MODULE | FRM-1 | 7300-0028:0219 |
| 12 | RELAY MODULE | FRM-1 | 7300-0028:219 |
| 16 | WATER FLOW SWITCH | N/A | BY OTHERS |
| 10 | VALVE TAMPER SWITCH | N/A | BY OTHERS |
| 21 | DUAL MONITOR MODULE | FDM-1 | 7300-0028:0219 |
| 64 | DUAL RELAY / MONITOR MODULE | FDRM-1 | 7300-0028:0219 |
| 12 | FIRE FIGHTERS PHONE JACKS | FTM-1 | 7300-1652:0182 |
| 4 | DIGITAL AUDIO AMPLIFIERS | DA2 | 7170-0028:223 7170-0028:224 |
| 1 | SIX RELAY CONTROL MODULE | XP6-R | 7300-0028:0219 |
| 1 | TEN-INPUT MONITOR MODULE | XP10-M | 7300-0028:0219 |

| LABEL | GAUGE | USE | TYPE (OR EQUIVALENT) |
|-------|----------|---------------------|----------------------|
| A | 16/2 UTP | SLC | WEST PENN D990 |
| B | 16/2 TSP | SPEAKER | WEST PENN D991 |
| C | 14 | NAC VISUAL | THHN |
| D | 14 | 24 VDC | THHN |
| E | 16/4 TS | ANNUNCIATOR | WEST PENN 993 |
| F | 14/2 TSP | FIRE FIGHTERS PHONE | WEST PENN D995 |

| DRAWING INDEX | | |
|---------------|--------------------|----------|
| 1 | COVER SHEET | FA 0.0 |
| 2 | RISER DIAGRAM | FA 1.0 |
| 3 | FIRST FLOOR WEST | FA 3.01W |
| 4 | SECOND FLOOR EAST | FA 3.02E |
| 5 | SECOND FLOOR WEST | FA 3.02W |
| 6 | THIRD FLOOR EAST | FA 3.03E |
| 7 | THIRD FLOOR WEST | FA 3.03W |
| 8 | FOURTH FLOOR EAST | FA 3.04E |
| 9 | FOURTH FLOOR WEST | FA 3.04W |
| 10 | FIFTH FLOOR EAST | FA 3.05E |
| 11 | FIFTH FLOOR WEST | FA 3.05W |
| 12 | SIXTH FLOOR EAST | FA 3.06E |
| 13 | SEVENTH FLOOR EAST | FA 3.07E |
| 14 | CALCULATIONS | FA 4.0 |
| 15 | DETAILS | FA 5.0 |


Deep Blue Integration
 Consulting - Design - Installation
 Service - Monitoring
 Deep Blue Integration, Inc.
 3442 Empress Drive Suite C
 San Luis Obispo, CA 93401
 C-10, C-16 #943465 ACO#6864
 Toll Free: 888-800-0081 FAX:
 805-791-9237
 www.deepblueintegration.com

| REVISIONS | DATE | DESCRIPTION |
|---------------------------------|-----------|-------------|
| REVIEW COMMENTS | | |
| CB # 1051 & F1 P9 | 8/14/2011 | |
| SFM REVIEW COMMENTS | 4/11/2012 | |
| CB # 82 | 8/20/2012 | |
| FA & SMOKE CONTROL SFM COMMENTS | 1/15/2013 | |
| AS-BUILT DRAWINGS | 4/9/2013 | |
| | 8/23/2013 | |

| | | | | |
|--|---------------------|--|--------|---------------------------------------|
| DESIGNED BY: Curtis Steetzer | DATE: 08/23/2013 | DRAWN BY: Derek Richardson | SCALE: | DRAWING CODE: FA-ALL DRAWINGS CPFS |
| CHECKED BY: CURTIS STEETZER, SET NICET IV #10272 | | PROJECT ENGINEER: Integral Design Associates INC. | | |

CENTER FOR SCIENCE AND MATHEMATICS
CALIFORNIA STATE POLYTECHNIC UNIVERSITY
 SAN LUIS OBISPO, CA
 CSFM #18-40-03-001

SHEET ID
FA 3.04W
 SHEET 6 OF 15



FIRE ALARM FOURTH FLOOR EAST
 SCALE 1/8" = 1'0"

SHEET NOTES

- 1 PROVIDE FIRE ALARM BEAM DETECTORS TRANSMITTER AND RECEIVER. INTERLOCK WITH SMOKE EVACUATION SYSTEM SUCH THAT WHEN BEAM DETECTOR IS ACTIVATED, SMOKE EVACUATION SYSTEM IS ACTIVATED. REFER TO DETAIL 4 & 5/FA.0.
- 2 ACTIVATION OF A MANUAL PULL STATION, BEAM DETECTOR OR SPRINKLER WATER FLOW WITHIN THE ATRIUM SHALL ACTIVATE ATRIUM SMOKE EVACUATION SYSTEM. SMOKE EVACUATION SYSTEM SHALL FUNCTION AS DIRECTED BY MECHANICAL DOCUMENTS. REFER TO DETAIL 9/M5.05 FOR ADDITIONAL INFORMATION.
- 3 ACTIVATION OF AN ALARM ANYWHERE WITHIN THE BUILDING SHALL SHUT DOWN ALL AIR HANDLING UNITS.
- 4 ACTIVATION OF THE ATRIUM SMOKE CONTROL SYSTEM SHALL OPEN ALL ATRIUM DOORS WITH MOTORIZED DOOR OPERATORS.

| SYMBOL LEGEND | | | |
|---------------|-----------------------------------|----------|--------------------------------|
| COUNT | FIRE ALARM SYMBOLS | MODEL # | CSFM LISTING # |
| 31 | MANUAL PULL STATION | NBG-12LX | 7150-0028-0199 |
| 73 | STROBE ONLY | SW | 7320-1653-201 |
| 165 | SPEAKER/STROBE | SPWS | 7320-1653-201 |
| 6 | SPEAKER ONLY | SPW | 7320-1653-201 |
| 7 | SPEAKER - WEATHER PROOF | SPWK | 7320-1653-201 |
| 0 | HEAT DETECTOR | FST-851 | 7270-0028-196 |
| 18 | SMOKE DETECTOR | FSP-851 | 7272-0028-206 |
| 64 | SMOKE DETECTOR - DUCT | DNR | 8242-1653-209 |
| 23 | BEAM SMOKE DETECTOR - TRANSMITTER | OSE-SPW | 7280-1728-0121 |
| 15 | BEAM SMOKE DETECTOR - RECEIVER | OSI-90 | 7280-1728-0121 |
| 1 | FIRE ALARM CONTROL PANEL | NFS2-640 | 7165-0028-0343 |
| 5 | REMOTE NOTIFICATION POWER SUPPLY | ACPS-610 | 7315-0028-248 |
| 4 | FIRE ALARM TERMINAL CABINET | N/A | N/A |
| 32 | END OF LINE RESISTOR | N/A | N/A |
| 2 | REMOTE ANNUNCIATOR | FDU-80 | 7120-0028-209 |
| 8 | MAGNETIC DOOR HOLDER | N/A | BY OTHERS |
| 21 | ADDRESSABLE MODULE | FMM-1 | 7300-0028-0219 |
| 12 | RELAY MODULE | FRM-1 | 7300-0028-219 |
| 16 | WATER FLOW SWITCH | N/A | BY OTHERS |
| 16 | VALVE TAMPER SWITCH | N/A | BY OTHERS |
| 21 | DUAL MONITOR MODULE | FDM-1 | 7300-0028-0219 |
| 64 | DUAL RELAY / MONITOR MODULE | FDRM-1 | 7300-0028-0219 |
| 12 | FIRE FIGHTERS PHONE JACKS | FTM-1 | 7300-1652-0182 |
| 4 | DIGITAL AUDIO AMPLIFIERS | DA2 | 7170-0028-223 7170-0028-224 |
| 1 | SIX RELAY CONTROL MODULE | XP6-R | 7300-0028-0219 |
| 1 | TEN-INPUT MONITOR MODULE | XP10-M | 7300-0028-0219 |

| WIRING LEGEND | | | |
|---------------|----------|---------------------|----------------------|
| LABEL | GAUGE | USE | TYPE (OR EQUIVALENT) |
| A | 16/2 UTP | SLC | WEST PENN D990 |
| B | 16/2 TSP | SPEAKER | WEST PENN D991 |
| C | 14 | NAC VISUAL | THHN |
| D | 14 | 24 VDC | THHN |
| E | 16/4 TS | ANNUNCIATOR | WEST PENN 993 |
| F | 14/2 TSP | FIRE FIGHTERS PHONE | WEST PENN D995 |

| DRAWING INDEX | | |
|---------------|--------------------|----------|
| 1 | COVER SHEET | FA 0.0 |
| 2 | RISER DIAGRAM | FA 1.0 |
| 3 | FIRST FLOOR WEST | FA 3.01W |
| 4 | SECOND FLOOR EAST | FA 3.02E |
| 5 | SECOND FLOOR WEST | FA 3.02W |
| 6 | THIRD FLOOR EAST | FA 3.03E |
| 7 | THIRD FLOOR WEST | FA 3.03W |
| 8 | FOURTH FLOOR EAST | FA 3.04E |
| 9 | FOURTH FLOOR WEST | FA 3.04W |
| 10 | FIFTH FLOOR EAST | FA 3.05E |
| 11 | FIFTH FLOOR WEST | FA 3.05W |
| 12 | SIXTH FLOOR EAST | FA 3.06E |
| 13 | SEVENTH FLOOR EAST | FA 3.07E |
| 14 | CALCULATIONS | FA 4.0 |
| 15 | DETAILS | FA 5.0 |

| REVISIONS | DATE | DESCRIPTION | SYMBOL | APPR. |
|---------------------------------|-----------|-------------|--------|-------|
| REVIEW COMMENTS | 6/14/2011 | | | |
| CRB # 063.1 & 19 | 5/18/2012 | | | |
| SPM REVIEW COMMENTS | 4/11/2012 | | | |
| CRB # 83.2 | 8/20/2012 | | | |
| FA & SMOKE CONTROL SPM COMMENTS | 1/15/2013 | | | |
| AS-BUILT DRAWINGS | 4/20/2013 | | | |
| | 8/23/2013 | | | |

| | | | | | | |
|---------------------------------|---------------------|-------------------------------|--------------------|----------------------------------|--|--|
| DESIGNED BY: Curtis Streever | DATE: 08/23/2013 | DRAWN BY: Derek Richardson | SCALE: AS SHOWN | CHECKED BY: DANIEL RICHARDSON | DRAWING CODE: FA ALL DRAWINGS CPD/CFS | PROJECT ENGINEER: Integral Design Associates INC. |
|---------------------------------|---------------------|-------------------------------|--------------------|----------------------------------|--|--|

CENTER FOR SCIENCE AND MATHEMATICS
CALIFORNIA STATE POLYTECHNIC UNIVERSITY
 SAN LUIS OBISPO, CA
 CSFM #18-40-03-0001

GENERAL NOTES


- NOTIFICATION DEVICES CANNOT BE T-TAPPED. ADDRESSABLE (IDC) DEVICES CAN BE T-TAPPED. ALL FIRE ALARM CABLING SHALL BE RUN FROM DEVICE TO DEVICE, WITH NO SPLICES. ANY REQUIRED TERMINATIONS MUST BE MADE IN APPROVED BOX.
- ALL INTERIOR INITIATING DEVICES, NOTIFICATION DEVICES, AND MODULES REQUIRE 4" SQUARE SPECIAL DEEP BACK BOXES U.O.N.
- PANEL BACK BOXES AND OTHER LISTED BACK BOXES SHALL BE PROVIDED TO THE EC BY DBI. ALL CONTROL PANELS, POWER SUPPLIES, AND BATTERY BOXES SHALL UTILIZE ONLY FACTORY KNOCKOUTS NEAR THE TOP OF THE CAN TO ALLOW PLACEMENT OF BATTERIES.
- ALL FIRE ALARM CONDUIT TO BE 3/4" EMT MINIMUM U.O.N. FIRE ALARM CONDUIT SHALL BE SEPARATE FROM CONDUIT SYSTEM FOR SECURITY ALARM CABLING AND OTHER SYSTEMS.
- WALL MOUNT AUDIO/VISUAL DEVICES SHALL BE MOUNTED 80" AFF TO BOTTOM OF THE STROBE LENS.
- MANUAL PULL STATIONS SHALL BE MOUNTED 48" AFF TO CENTERLINE OF BOX. MPS SHALL BE DOUBLE ACTION AND KEYED THE SAME AS THE FACP.
- DEDICATED 120 VAC CIRCUIT WITH LOCKOUT @ BREAKER TO BE PROVIDED BY OTHERS AT LOCATION OF PANELS AND POWER SUPPLIES.
- KNOX BOX, PIV, SUPERVISORY SWITCHES, FLOW SWITCHES, SOLENOIDS, AND SPRINKLER BELLS SHALL BE PROVIDED BY OTHERS.
- SMOKE DETECTORS SHALL NOT BE PLACED WITHIN 3' OF ANY SUPPLY AIR REGISTER OR WHERE THE AIR MOVEMENT EXCEEDS THE MANUFACTURER'S LISTING.
- FIRE FIGHTER TELEPHONE RISER IS CLASS A, STYLE Z
- VOLTAGE DROP CALCULATIONS FOR NOTIFICATION DEVICES ARE BASED ON THE LAYOUT SHOWN. DEVIATION FROM THESE PLANS COULD RESULT IN ADDITIONAL CONDUIT WORK, REENGINEERING, UPSIZED CABLE AND/OR ADDITIONAL POWER REQUIREMENTS.
- PAINT ALL FIRE ALARM JUNCTION BOXES AND COVERS RED IN UNFINISHED AREAS (IE ABOVE CEILINGS, MECHANICAL ROOMS ETC.) IN FINISHED AREAS CONDUIT AND JUNCTION BOXES CAN BE PAINTED TO MATCH THE ROOM FINISH, THE INSIDE COVER IF THE JUNCTION BOX MUST BE IDENTIFIED AS "FIRE ALARM" AND THE CONDUIT MUST HAVE PAINTED RED BANDS 3/4" WIDE AT 10' CENTERS AND AT EACH SIDE OF A FLOOR, WALL, OR CEILING PENETRATION.
- UPON COMPLETION OF INSTALLATION OF THE FIRE ALARM SYSTEM A SATISFACTORY TEST OF THE ENTIRE SYSTEM SHALL BE MADE IN THE PRESENCE OF THE AUTHORITY HAVING JURISDICTION (AHJ).
- ALL NOTIFICATION DEVICES SHALL BE SYNCHRONIZED.
- A STAMPED SET OF APPROVED FIRE ALARM PLANS SHALL BE AT THE JOBSITE AND USED FOR INSTALLATION.
- SIGNALING LINE CIRCUIT IS CLASS B, STYLE 4
- NOTIFICATION APPLIANCE CIRCUIT IS CLASS B, STYLE Y
- ALL SMOKE DETECTORS SHALL BE INSTALLED AT LEAST 1'-0" FROM FLUORESCENT LIGHT FIXTURES TO AVOID UNWANTED ALARMS AND SHALL BE INSTALLED IN AREAS THAT DO NOT EXCEED THE MANUFACTURER'S OPERATING TEMPERATURE RANGE BETWEEN 32°F AND 120°F.

CODE REGULATIONS

| CALIFORNIA CODE REGULATIONS | |
|---|------------------|
| APPLICABLE CODES | TITLE 24 PART 1 |
| 2007 BUILDING STANDARDS ADMINISTRATIVE CODE | TITLE 24 PART 2 |
| 2007 CALIFORNIA BUILDING CODE (CBC) | TITLE 24 PART 3 |
| 2007 CALIFORNIA ELECTRICAL CODE (CEC) | TITLE 24 PART 4 |
| 2007 CALIFORNIA MECHANICAL CODE (CMC) | TITLE 24 PART 5 |
| 2007 CALIFORNIA PLUMBING CODE (CPC) | TITLE 24 PART 6 |
| 2007 CALIFORNIA ENERGY CODE | TITLE 24 PART 7 |
| 2007 CALIFORNIA ELEVATOR SAFETY CONSTRUCTION CODE | TITLE 24 PART 8 |
| 2007 CALIFORNIA HISTORICAL BUILDING CODE | TITLE 24 PART 9 |
| 2007 CALIFORNIA FIRE CODE (FC) | TITLE 24 PART 12 |
| 2007 CALIFORNIA REFERENCED STANDARDS CODE | |
| APPLICABLE STANDARDS & GUIDELINES | NFPA 13 |
| 2007 AUTOMATIC SPRINKLER SYSTEMS | NFPA 20 |
| 2007 STATIONARY PUMPS | NFPA 72 |
| 2007 NATIONAL FIRE ALARM CODES (CALIFORNIA AMENDED) | NFPA 90A |
| 2007 STANDARD FOR INSTALLATION OF AIR-CONDITIONING | NFPA 90B |
| 2007 STANDARD FOR INSTALLATION OF WARM AIR HEATING | NFPA 92A |
| 2006 STANDARD FOR SMOKE-CONTROL SYSTEMS UTILIZING BARRIERS AND PRESSURE DIFFERENCES | NFPA 92B |
| 2005 STANDARD FOR SMOKE MANAGEMENT SYSTEMS IN MALLS, ATRIA, AND LARGE SPACES | |

CENTER FOR SCIENCE AND MATHEMATICS CALIFORNIA STATE POLYTECHNIC UNIVERSITY SAN LUIS OBISPO, CALIFORNIA 93407 FIRE ALARM & EMERGENCY COMMUNICATION SYSTEM

SITE PLAN



CENTER FOR SCIENCE

PROJECT DESCRIPTION

- OCCUPANCY TYPE: A, B, AND H3
- SYSTEM TYPE: CLASS B, ADDRESSABLE, MANUAL
- METHOD OF COMMUNICATION: TELEPHONE
- SCOPE OF WORK: FIRE ALARM & VOICE EVACUATION SYSTEMS

SEQUENCE OF OPERATIONS MATRIX

| EVENT | ACTION | | | | | | | | | | | | |
|--|--------|---|---|---|---|---|---|---|---|----|----|----|----|
| | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 |
| FIRE ALARM CONTROL UNIT | | | | | | | | | | | | | |
| PANEL SUPERVISORY CONDITION (TEST BYPASS) ON ACM-24 AT | X | | X | X | | | | | | | | | |
| PANEL TROUBLE CONDITION (AC POWER FAIL, LOW BATTERY, OPEN CIRCUIT, GROUND FAULT, ETC.) | X | X | X | X | | | | | | | | | |
| PANEL ALARM CONDITION | X | X | X | X | X | | | | | | | | |
| MANUAL PULL STATION ACTIVATION | X | X | X | X | X | X | | | | | | | |
| SPOT SMOKE DETECTOR ACTIVATION | X | X | X | X | X | X | X | | | | | | |
| DUCT SMOKE DETECTOR ACTIVATION | X | X | X | X | X | X | X | X | | | | | |
| AIR HANDLING UNIT SMOKE DETECTOR ACTIVATION | X | X | X | X | X | X | X | X | X | | | | |
| SPRINKLER TAMPER SWITCH | X | X | X | X | X | X | X | X | X | | | | |
| SPRINKLER WATER FLOW ACTIVATION | X | X | X | X | X | X | X | X | X | | | | |
| FIRE PUMP RUNNINGS | X | X | X | X | X | X | X | X | X | | | | |
| FIRE PUMP LOSS OF PHASE | X | X | X | X | X | X | X | X | X | | | | |
| FIRE PUMP PHASE REVERSAL | X | X | X | X | X | X | X | X | X | | | | |
| HEAT DETECTOR ACTIVATION (ELEVATOR EQUIPMENT) | X | X | X | X | X | X | X | X | X | | | | |
| ELEVATOR LOBBY (SMOKE) / ELEVATOR HORIZONTALS | X | X | X | X | X | X | X | X | X | | | | |
| SHUNT TRIP POWER SUPERVISION | X | X | X | X | X | X | X | X | X | | | | |
| GENERAL ALARM (ANYWHERE WITHIN THE BUILDING) | X | X | X | X | X | X | X | X | X | X | | | |
| ATRILUM SMOKE CONTROL SYSTEM ALARM | X | X | X | X | X | X | X | X | X | X | X | | |
| BEAM SMOKE DETECTOR WITHIN ATRIUM | X | X | X | X | X | X | X | X | X | X | X | X | |
| PULL STATION WITHIN ATRIUM | X | X | X | X | X | X | X | X | X | X | X | X | X |
| SPRINKLER WATER FLOW WITHIN ATRIUM | X | X | X | X | X | X | X | X | X | X | X | X | X |

SYMBOL LEGEND

| COUNT | FIRE ALARM SYMBOLS | MODEL # | CSFM LISTING # |
|-------|---|----------|--------------------------------|
| 31 | [F] MANUAL PULL STATION | NBG-12LX | 7150-0028:0199 |
| 73 | [F] STROBE ONLY | SW | 7320-1653:201 |
| 165 | [F] SPEAKER/STROBE | SPWS | 7320-1653:201 |
| 6 | [F] SPEAKER ONLY | SPW | 7320-1653:201 |
| 7 | [WP] [F] SPEAKER - WEATHER PROOF | SPWK | 7320-1653:201 |
| 0 | [H] HEAT DETECTOR | FST-851 | 7270-0028:196 |
| 18 | [S] SMOKE DETECTOR | FSP-851 | 7272-0028:206 |
| 64 | [S] _D SMOKE DETECTOR - DUCT | DNR | 3242-1653:209 |
| 23 | [S] _{BT} BEAM SMOKE DETECTOR - TRANSMITTER | OSE-SPW | 7260-1728:0121 |
| 15 | [S] _{BR} BEAM SMOKE DETECTOR - RECEIVER | OSI-90 | 7260-1728:0121 |
| 1 | [FACP] FIRE ALARM CONTROL PANEL | NFS2-640 | 7165-0028:0243 |
| 5 | [RNPS] REMOTE NOTIFICATION POWER SUPPLY | ACPS-610 | 7315-0028:248 |
| 4 | [FATC] FIRE ALARM TERMINAL CABINET | N/A | N/A |
| 32 | [EOL] END OF LINE RESISTOR | N/A | N/A |
| 2 | [RA] REMOTE ANNUNCIATOR | FDU-80 | 7120-0028:209 |
| 8 | [MD] MAGNETIC DOOR HOLDER | N/A | BY OTHERS |
| 21 | [AM] ADDRESSABLE MODULE | FMM-1 | 7300-0028:0219 |
| 12 | [RM] RELAY MODULE | FRM-1 | 7300-0028:219 |
| 16 | [WFS] WATER FLOW SWITCH | N/A | BY OTHERS |
| 10 | [VTS] VALVE TAMPER SWITCH | N/A | BY OTHERS |
| 21 | [FDM] DUAL MONITOR MODULE | FDM-1 | 7300-0028:0219 |
| 64 | [FDRM] DUAL RELAY / MONITOR MODULE | FDRM-1 | 7300-0028:0219 |
| 12 | [FJ] FIRE FIGHTER'S PHONE JACKS | FTM-1 | 7300-1652:0182 |
| 4 | [DAA2] DIGITAL AUDIO AMPLIFIERS | DAA2 | 7170-0028:223 7170-0028:224 |
| 1 | [XP6-R] SIX RELAY CONTROL MODULE | XP6-R | 7300-0028:0219 |
| 1 | [XP10-M] TEN-INPUT MONITOR MODULE | XP10-M | 7300-0028:0219 |

WIRING LEGEND

| LABEL | GAUGE | USE | TYPE (OR EQUIVALENT) |
|-------|-------|-------------------------|----------------------|
| A | 16/2 | UTP SLC | WEST PENN D990 |
| B | 16/2 | TSP SPEAKER | WEST PENN D991 |
| C | 14 | NAC VISUAL | THHN |
| D | 14 | 24 VDC | THHN |
| E | 16/4 | TS ANNUNCIATOR | WEST PENN 993 |
| F | 14/2 | TSP FIRE FIGHTERS PHONE | WEST PENN D995 |

DRAWING INDEX

| | | |
|----|--------------------|----------|
| 1 | COVER SHEET | FA 0.0 |
| 2 | RISER DIAGRAM | FA 1.0 |
| 3 | FIRST FLOOR WEST | FA 3.01W |
| 4 | SECOND FLOOR EAST | FA 3.02E |
| 5 | SECOND FLOOR WEST | FA 3.02W |
| 6 | THIRD FLOOR EAST | FA 3.03E |
| 7 | THIRD FLOOR WEST | FA 3.03W |
| 8 | FOURTH FLOOR EAST | FA 3.04E |
| 9 | FOURTH FLOOR WEST | FA 3.04W |
| 10 | FIFTH FLOOR EAST | FA 3.05E |
| 11 | FIFTH FLOOR WEST | FA 3.05W |
| 12 | SIXTH FLOOR EAST | FA 3.06E |
| 13 | SEVENTH FLOOR EAST | FA 3.07E |
| 14 | CALCULATIONS | FA 4.0 |
| 15 | DETAILS | FA 5.0 |

AS-BUILT SET COVER SHEET

Deep Blue Integration
Consulting - Design - Installation
Service - Monitoring
Deep Blue Integration, Inc
3442 Empress Drive Suite C
San Luis Obispo, CA 93401
C-10, C-16 #943465 ACO#8864
Toll Free: 888-830-0391 FAX:
805-791-2037
www.deepblueintegration.com

| DATE | DESCRIPTION | BY | DATE |
|-----------|---------------------------------|----|------|
| 6/14/2011 | REVISIONS | | |
| 4/19/2012 | REVIEW COMMENTS | | |
| 8/20/2012 | CRB # 093.1 & FI 99 | | |
| 8/20/2012 | SPM REVIEW COMMENTS | | |
| 1/15/2013 | CRB 832 | | |
| 4/2/2013 | FA & SMOKE CONTROL SPM COMMENTS | | |
| 8/23/2013 | AS-BUILT DRAWINGS | | |

DESIGNED BY: **Chris Shearer**
DRAWN BY: **Derek Richardson**
CHECKED BY: **CURTIS STREETER, SET**
NICET # 1102872
PROJECT ENGINEER: **Integral Design Associates, INC.**
DATE: 08/23/2013
SCALE:
DRAWING CODE: FA-ALL DRAWINGS CPFS

**CENTER FOR SCIENCE AND MATHEMATICS
CALIFORNIA STATE POLYTECHNIC UNIVERSITY
SAN LUIS OBISPO, CA**
CSFM #18-40-03-001

SHEET ID
FA-0
SHEET 1 OF 15

SYMBOL LEGEND

| COUNT | FIRE ALARM SYMBOLS | MODEL # | CSFM LISTING # |
|-------|--------------------|-----------------------------------|-------------------------------------|
| 31 | [Symbol] | MANUAL PULL STATION | NBG-12LX 7150-0028:0199 |
| 73 | [Symbol] | STROBE ONLY | SW 7320-1653:201 |
| 165 | [Symbol] | SPEAKER/STROBE | SPWS 7320-1653:201 |
| 6 | [Symbol] | SPEAKER ONLY | SPW 7320-1653:201 |
| 7 | [Symbol] | SPEAKER - WEATHER PROOF | SPWK 7320-1653:201 |
| 0 | [Symbol] | HEAT DETECTOR | FST-851 7270-0028:196 |
| 18 | [Symbol] | SMOKE DETECTOR | FSP-851 7272-0028:206 |
| 64 | [Symbol] | SMOKE DETECTOR - DUCT | DNR 3242-1653:209 |
| 23 | [Symbol] | BEAM SMOKE DETECTOR - TRANSMITTER | OSE-SPW 7260-1728:0121 |
| 15 | [Symbol] | BEAM SMOKE DETECTOR - RECEIVER | OSI-90 7260-1728:0121 |
| 1 | [Symbol] | FIRE ALARM CONTROL PANEL | NFS2-640 7165-0028:0243 |
| 5 | [Symbol] | REMOTE NOTIFICATION POWER SUPPLY | ACPS-610 7315-0028:248 |
| 4 | [Symbol] | FIRE ALARM TERMINAL CABINET | N/A N/A |
| 32 | [Symbol] | END OF LINE RESISTOR | N/A N/A |
| 2 | [Symbol] | REMOTE ANNUNCIATOR | FDU-80 7120-0028:209 |
| 8 | [Symbol] | MAGNETIC DOOR HOLDER | N/A BY OTHERS |
| 21 | [Symbol] | ADDRESSABLE MODULE | FMM-1 7300-0028:0219 |
| 12 | [Symbol] | RELAY MODULE | FRM-1 7300-0028:219 |
| 16 | [Symbol] | WATER FLOW SWITCH | N/A BY OTHERS |
| 10 | [Symbol] | VALVE TAMPER SWITCH | N/A BY OTHERS |
| 21 | [Symbol] | DUAL MONITOR MODULE | FDM-1 7300-0028:0219 |
| 64 | [Symbol] | DUAL RELAY / MONITOR MODULE | FDRM-1 7300-0028:0219 |
| 12 | [Symbol] | FIRE FIGHTERS PHONE JACKS | FTM-1 7300-1652:0182 |
| 4 | [Symbol] | DIGITAL AUDIO AMPLIFIERS | DAA2 7170-0028:223 7170-0028:224 |
| 1 | [Symbol] | SIX RELAY CONTROL MODULE | XP6-R 7300-0028:0219 |
| 1 | [Symbol] | TEN-INPUT MONITOR MODULE | XP10-M 7300-0028:0219 |

GENERAL NOTES:

- The Notification Appliance Circuits vary between 14 AWG and 12 AWG, see voltage drops for correct sizing.
- All smoke detectors shall be placed at least 1'-0" from fluorescent light fixtures to avoid unwanted alarms and in areas that will not exceed manufacturer's specified operating temperature 32°F to 120°F.

SHEET NOTES:

- The fire alarm control panel shall be connected to a separate dedicated branch circuit, maximum 20 amperes. This circuit shall be labeled at the main power distribution panel as FIRE ALARM. Fire alarm control panel primary power wiring shall be 12 AWG. The control panel cabinet shall be grounded securely to either a cold water pipe or grounding rod.
 - The riser going between floors will be in 2" conduit or larger.
 - 6.10.1.16* All circuits necessary for the operation of two-way telephone communication systems shall be installed using one of the following methods:
 - A 2-hour fire rated circuit integrity (CI) cable
 - A 2-hour fire rated cable system (electrical circuit protective system)
 - A 2-hour fire rated enclosure
 - Performance alternatives approved by the authority having jurisdiction
 - Buildings fully protected by an automatic sprinkler system installed in accordance with NFPA 13. Standard for the Installation of Sprinkler Systems, with the wiring or cables installed in metal raceways and in accordance with Article 760 of NFPA 70
- 6.10.1.16 One or more of the following means might be considered acceptable to provide a level of survivability consistent with the intent of this requirement:
- Routing two-way telephone circuits separately
 - Using short-circuit fault tolerant circuits


Deep Blue Integration
 Consulting - Design - Installation
 Service - Monitoring
 Deep Blue Integration, Inc
 3442 Empress Drive Suite C
 San Luis Obispo, CA 93401
 C-10, C-16 #943465 ACO#6884
 Toll Free: 888-6000-DBI FAX:
 805-791-2037
 www.deepblueintegration.com

Revisions

| NO. | DATE | DESCRIPTION |
|-----|------------|---|
| 1 | 8/24/2013 | REVIEW COMMENTS |
| 2 | 8/27/2013 | CRP # 982.1 & FT 99 |
| 3 | 8/20/2012 | SFM REVIEW COMMENTS |
| 4 | 11/29/2013 | CRS 93.2 |
| 5 | 8/23/2013 | FA & SMOKE CONTROL SFM COMMENTS AS-BUILT DRAWINGS |

DESIGNED BY: Curtis Streeter
 DRAWN BY: Derek Richardson
 CHECKED BY: CURTIS STREETER, SET
 NCET IV #10272
 PROJECT ENGINEER: Integral Design Associates, Inc.
 DATE: 08/23/2013
 SCALE:
 DRAWING CODE: FA-ALL DRAWINGS CPDFS

CENTER FOR SCIENCE AND MATHEMATICS
CALIFORNIA STATE POLYTECHNIC UNIVERSITY
 SAN LUIS OBISPO, CA
 CSFM #18-10-03-0001



WIRING LEGEND


| LABEL | GAUGE | USE | TYPE (OR EQUIVALENT) |
|-------|-------|-------------------------|----------------------|
| A | 16/2 | UTP SLC | WEST PENN D990 |
| B | 16/2 | TSP SPEAKER | WEST PENN D991 |
| C | 14 | NAC VISUAL | THHN |
| D | 14 | 24 VDC | THHN |
| E | 16/4 | TS ANNUNCIATOR | WEST PENN 993 |
| F | 14/2 | TSP FIRE FIGHTERS PHONE | WEST PENN D995 |

DRAWING INDEX

| NO. | TITLE | FA NO. |
|-----|--------------------|----------|
| 1 | COVER SHEET | FA 0.0 |
| 2 | RISE R DIAGRAM | FA 1.0 |
| 3 | FIRST FLOOR WEST | FA 3.01W |
| 4 | SECOND FLOOR EAST | FA 3.02E |
| 5 | SECOND FLOOR WEST | FA 3.02W |
| 6 | THIRD FLOOR EAST | FA 3.03E |
| 7 | THIRD FLOOR WEST | FA 3.03W |
| 8 | FOURTH FLOOR EAST | FA 3.04E |
| 9 | FOURTH FLOOR WEST | FA 3.04W |
| 10 | FIFTH FLOOR EAST | FA 3.05E |
| 11 | FIFTH FLOOR WEST | FA 3.05W |
| 12 | SIXTH FLOOR EAST | FA 3.06E |
| 13 | SEVENTH FLOOR EAST | FA 3.07E |
| 14 | CALCULATIONS | FA 4.0 |
| 15 | DETAILS | FA 5.0 |

FIRE ALARM RISER DIAGRAMS

SHEET #18-10-03-0001
FA 1.0
 SHEET 2 OF 15



FIRE ALARM FIRST FLOOR WEST
 SCALE 1/8" = 1'0"

SYMBOL LEGEND

| COUNT | FIRE ALARM SYMBOLS | MODEL # | CSFM LISTING # |
|-------|-----------------------------------|----------|--------------------------------|
| 31 | MANUAL PULL STATION | NBG-12LX | 7150-0028-0199 |
| 73 | STROBE ONLY | SW | 7320-1653-201 |
| 165 | SPEAKER/STROBE | SPWS | 7320-1653-201 |
| 6 | SPEAKER ONLY | SPW | 7320-1653-201 |
| 7 | SPEAKER - WEATHER PROOF | SPWK | 7320-1653-201 |
| 0 | HEAT DETECTOR | FST-951 | 7272-0028-196 |
| 18 | SMOKE DETECTOR | FSP-851 | 7272-0028-206 |
| 64 | SMOKE DETECTOR - DUCT | DNR | 3242-1853-209 |
| 29 | BEAM SMOKE DETECTOR - TRANSMITTER | OSE-SPW | 7260-1728-0121 |
| 15 | BEAM SMOKE DETECTOR - RECEIVER | OSI-90 | 7260-1728-0121 |
| 1 | FIRE ALARM CONTROL PANEL | NFS2-640 | 7165-0028-0243 |
| 5 | REMOTE NOTIFICATION POWER SUPPLY | ACPS-610 | 7315-0028-248 |
| 4 | FIRE ALARM TERMINAL CABINET | N/A | N/A |
| 32 | END OF LINE RESISTOR | N/A | N/A |
| 2 | REMOTE ANNUNCIATOR | FDU-80 | 7120-0028-209 |
| 8 | MAGNETIC DOOR HOLDER | N/A | BY OTHERS |
| 21 | ADDRESSABLE MODULE | FMM-1 | 7300-0028-0219 |
| 12 | RELAY MODULE | FRM-1 | 7300-0028-219 |
| 16 | WATER FLOW SWITCH | N/A | BY OTHERS |
| 10 | VALVE TAMPER SWITCH | N/A | BY OTHERS |
| 21 | DUAL MONITOR MODULE | FDM-1 | 7300-0028-0219 |
| 64 | DUAL RELAY / MONITOR MODULE | FDRM-1 | 7300-0028-0219 |
| 12 | FIRE FIGHTERS PHONE JACKS | FTM-1 | 7300-1652-0182 |
| 4 | DIGITAL AUDIO AMPLIFIERS | DAA2 | 7170-0028-223 7170-0028-224 |
| 1 | SIX RELAY CONTROL MODULE | XP6-R | 7300-0028-0219 |
| 1 | TEN-INPUT MONITOR MODULE | XP10-M | 7300-0028-0219 |

WIRING LEGEND

| LABEL | GAUGE | USE | TYPE (OR EQUIVALENT) |
|-------|----------|---------------------|----------------------|
| A | 16/2 UTP | SLC | WEST PENN D990 |
| B | 16/2 TSP | SPEAKER | WEST PENN D991 |
| C | 14 | NAC VISUAL | THHN |
| D | 14 | 24 VDC | THHN |
| E | 16/4 TS | ANNUNCIATOR | WEST PENN 993 |
| F | 14/2 TSP | FIRE FIGHTERS PHONE | WEST PENN D995 |

DRAWING INDEX

| | | |
|----|--------------------|----------|
| 1 | COVER SHEET | FA 0.0 |
| 2 | RISER DIAGRAM | FA 1.0 |
| 3 | FIRST FLOOR WEST | FA 3.01W |
| 4 | SECOND FLOOR EAST | FA 3.02E |
| 5 | SECOND FLOOR WEST | FA 3.02W |
| 6 | THIRD FLOOR EAST | FA 3.03E |
| 7 | THIRD FLOOR WEST | FA 3.03W |
| 8 | FOURTH FLOOR EAST | FA 3.04E |
| 9 | FOURTH FLOOR WEST | FA 3.04W |
| 10 | FIFTH FLOOR EAST | FA 3.05E |
| 11 | FIFTH FLOOR WEST | FA 3.05W |
| 12 | SIXTH FLOOR EAST | FA 3.06E |
| 13 | SEVENTH FLOOR EAST | FA 3.07E |
| 14 | CALCULATIONS | FA 4.0 |
| 15 | DETAILS | FA 5.0 |

REVISIONS

| NO. | DATE | DESCRIPTION | BY | APPR. |
|-----|-----------|-------------|----|-------|
| 1 | 6/14/2011 | | | |
| 2 | 5/19/2012 | | | |
| 3 | 8/20/2012 | | | |
| 4 | 1/15/2013 | | | |
| 5 | 4/9/2013 | | | |
| 6 | 8/23/2013 | | | |

REVIEW COMMENTS

| NO. | DATE | DESCRIPTION |
|-----|-----------|---------------------------------|
| 1 | 8/23/2013 | FA & SMOKE CONTROL SFT COMMENTS |
| 2 | 8/23/2013 | AS-BUILT DRAWINGS |

| | | | |
|---|---------------------|--------|---------------------------------------|
| DESIGNED BY: Curtis Streever | DATE: 08/23/2013 | SCALE: | DRAWING CODE: FA ALL DRAWINGS CPFS |
| DRAWN BY: Derek Richardson | | | |
| CHECKED BY: CURTIS STREEVER, SET NICETV #102672 | | | |
| PROJECT ENGINEER: Ingral Design Associates, INC. | | | |

CENTER FOR SCIENCE AND MATHEMATICS
CALIFORNIA STATE POLYTECHNIC UNIVERSITY
 SAN LUIS OBISPO, CA
 CSFM #18-40-03-0001



FIRE ALARM SECOND FLOOR WEST ↑
 SCALE 1/8" = 1'0"

| SYMBOL LEGEND | | | |
|---------------|-----------------------------------|-----------|--------------------------------|
| COUNT | FIRE ALARM SYMBOLS | MODEL # | CSPM LISTING # |
| 01 | MANUAL PULL STATION | NBSG-12LX | 7150-0028:0199 |
| 73 | STROBE ONLY | SW | 7320-1653:201 |
| 165 | SPEAKER/STROBE | SPWS | 7320-1653:201 |
| 6 | SPEAKER ONLY | SPW | 7320-1653:201 |
| 7 | SPEAKER - WEATHER PROOF | SPWK | 7320-1653:201 |
| 0 | HEAT DETECTOR | FST-851 | 7270-0028:196 |
| 18 | SMOKE DETECTOR | FSP-851 | 7272-0028:206 |
| 64 | SMOKE DETECTOR - DUCT | DNR | 3242-1653:209 |
| 23 | BEAM SMOKE DETECTOR - TRANSMITTER | OSE-SPW | 7260-1728:0121 |
| 15 | BEAM SMOKE DETECTOR - RECEIVER | OSR-90 | 7260-1728:0121 |
| 1 | FIRE ALARM CONTROL PANEL | NFS2-640 | 7165-0028:0243 |
| 5 | REMOTE NOTIFICATION POWER SUPPLY | ACPS-610 | 7315-0028:248 |
| 4 | FIRE ALARM TERMINAL CABINET | N/A | N/A |
| 32 | END OF LINE RESISTOR | N/A | N/A |
| 2 | REMOTE ANNUNCIATOR | FDU-80 | 7120-0028:209 |
| 8 | MAGNETIC DOOR HOLDER | N/A | BY OTHERS |
| 21 | ADDRESSABLE MODULE | FMM-1 | 7300-0028:0219 |
| 12 | RELAY MODULE | FRM-1 | 7300-0028:219 |
| 16 | WATER FLOW SWITCH | N/A | BY OTHERS |
| 10 | VALVE TAMPER SWITCH | N/A | BY OTHERS |
| 21 | DUAL MONITOR MODULE | FDM-1 | 7300-0028:0219 |
| 64 | DUAL RELAY / MONITOR MODULE | FRDM-1 | 7300-0028:0219 |
| 12 | FIRE FIGHTERS PHONE JACKS | FTM-1 | 7300-1652:0182 |
| 4 | DIGITAL AUDIO AMPLIFIERS | DAA2 | 7170-0028:223 7170-0028:224 |
| 1 | SIX RELAY CONTROL MODULE | XP6-R | 7300-0028:0219 |
| 1 | TEN-INPUT MONITOR MODULE | XP10-M | 7300-0028:0219 |


| WIRING LEGEND | | | |
|---------------|----------|---------------------|----------------------|
| LABEL | GAUGE | USE | TYPE (OR EQUIVALENT) |
| A | 16/2 UTP | SLC | WEST PENN D990 |
| B | 16/2 TSP | SPEAKER | WEST PENN D991 |
| C | 14 | NAC VISUAL | THHN |
| D | 14 | 24 VDC | THHN |
| E | 16/4 TS | ANNUNCIATOR | WEST PENN 993 |
| F | 14/2 TP | FIRE FIGHTERS PHONE | WEST PENN D995 |

| DRAWING INDEX | | |
|---------------|--------------------|----------|
| 1 | COVER SHEET | FA 0.0 |
| 2 | RISER DIAGRAM | FA 1.0 |
| 3 | FIRST FLOOR WEST | FA 3.01W |
| 4 | SECOND FLOOR EAST | FA 3.02E |
| 5 | SECOND FLOOR WEST | FA 3.02W |
| 6 | THIRD FLOOR EAST | FA 3.03E |
| 7 | THIRD FLOOR WEST | FA 3.03W |
| 8 | FOURTH FLOOR EAST | FA 3.04E |
| 9 | FOURTH FLOOR WEST | FA 3.04W |
| 10 | FIFTH FLOOR EAST | FA 3.05E |
| 11 | FIFTH FLOOR WEST | FA 3.05W |
| 12 | SIXTH FLOOR EAST | FA 3.06E |
| 13 | SEVENTH FLOOR EAST | FA 3.07E |
| 14 | CALCULATIONS | FA 4.0 |
| 15 | DETAILS | FA 5.0 |

| REVISIONS | REVIEW COMMENTS | DATE | APPR. |
|-----------|-------------------------------|-----------|-------|
| 1 | CRB # 883.1 & F 89 | 5/12/2012 | |
| 2 | SFM REVIEW COMMENTS | 8/20/2012 | |
| 3 | CRB 83.2 | 1/15/2013 | |
| 4 | FA SMOKE CONTROL SFM COMMENTS | 4/23/2013 | |
| 5 | AS-BUILT DRAWINGS | 8/23/2013 | |

| | | |
|---------------------|-------------------|---------------------------------|
| DESIGNED BY: | DATE: | 09/23/2013 |
| Curtis Steiner | SCALE: | |
| DRAWN BY: | DRAWING CODE: | FA ALL DRAWINGS CPFS |
| Derek Richardson | | |
| CHECKED BY: | PROJECT ENGINEER: | Integral Design Associates INC. |
| CURTIS STEINER, SET | | |
| INCE TY #162672 | | |

CENTER FOR SCIENCE AND MATHEMATICS
CALIFORNIA STATE POLYTECHNIC UNIVERSITY
 SAN LUIS OBISPO, CA
 CSPM #18-40-03-0001



FIRE ALARM SECOND FLOOR EAST ↑
 SCALE 1/8" = 1'0"

SHEET NOTES

- 1 PROVIDE FIRE ALARM BEAM DETECTORS TRANSMITTER AND RECEIVER. INTERLOCK WITH SMOKE EVACUATION SYSTEM SUCH THAT WHEN BEAM DETECTOR IS ACTIVATED, SMOKE EVACUATION SYSTEM IS ACTIVATED. REFER TO DETAIL 4 & 5/FA5.0.
- 2 ACTIVATION OF A MANUAL PULL STATION, BEAM DETECTOR OR SPRINKLER WATER FLOW WITHIN THE ATRIUM SHALL ACTIVATE ATRIUM SMOKE EVACUATION SYSTEM. SMOKE EVACUATION SYSTEM SHALL FUNCTION AS DIRECTED BY MECHANICAL DOCUMENTS. REFER TO DETAIL 9/M5.05 FOR ADDITIONAL INFORMATION.
- 3 ACTIVATION OF AN ALARM ANYWHERE WITHIN THE BUILDING SHALL SHUT DOWN ALL AIR HANDLING UNITS.
- 4 ACTIVATION OF THE ATRIUM SMOKE CONTROL SYSTEM SHALL OPEN ALL ATRIUM DOORS WITH MOTORIZED DOOR OPERATORS.

SYMBOL LEGEND

| COUNT | FIRE ALARM SYMBOLS | MODEL # | CSFM LISTING # |
|-------|---------------------------------------|----------|--------------------------------|
| 31 | MANUAL PULL STATION | NBG-12LX | 7150-0028:0199 |
| 73 | STROBE ONLY | SW | 7320-1653:201 |
| 166 | SPEAKER/STROBE | SPWS | 7320-1653:201 |
| 6 | SPEAKER ONLY | SPW | 7320-1653:201 |
| 7 | SPEAKER - WEATHER PROOF | SPWK | 7320-1653:201 |
| 0 | HEAT DETECTOR | FST-851 | 7270-0028:196 |
| 18 | SMOKE DETECTOR | FSP-651 | 7272-0028:206 |
| 64 | SMOKE DETECTOR - DUCT | DNR | 3242-1653:209 |
| 23 | BEAM SMOKE DETECTOR - TRANSMITTER | OSE-SPW | 7280-1728:0121 |
| 15 | BEAM SMOKE DETECTOR - RECEIVER | OSR-90 | 7280-1728:0121 |
| 1 | FACP FIRE ALARM CONTROL PANEL | NFS2-640 | 7185-0028:0243 |
| 5 | RNPS REMOTE NOTIFICATION POWER SUPPLY | ACPS-610 | 7315-0028:240 |
| 4 | FATC FIRE ALARM TERMINAL CABINET | N/A | N/A |
| 32 | END OF LINE RESISTOR | N/A | N/A |
| 2 | RAA REMOTE ANNUNCIATOR | FDU-80 | 7120-0028:209 |
| 8 | MDH MAGNETIC DOOR HOLDER | N/A | BY OTHERS |
| 21 | AM ADDRESSABLE MODULE | FMA-1 | 7300-0028:0219 |
| 12 | RM RELAY MODULE | FRM-1 | 7300-0028:219 |
| 16 | WFS WATER FLOW SWITCH | N/A | BY OTHERS |
| 10 | VTS VALVE TAMPER SWITCH | N/A | BY OTHERS |
| 21 | DMR DUAL MONITOR MODULE | FDM-1 | 7300-0028:0219 |
| 64 | FDRM DUAL RELAY / MONITOR MODULE | FDRM-1 | 7300-0028:0219 |
| 12 | FFJ FIRE FIGHTERS PHONE JACKS | FTM-1 | 7300-1652:0102 |
| 4 | DAAR DIGITAL AUDIO AMPLIFIERS | DAAR | 7170-0028:223 7170-0028:224 |
| 1 | XPR SIX RELAY CONTROL MODULE | XP6-R | 7300-0028:0219 |
| 1 | XPI TEN-INPUT MONITOR MODULE | XP10-M | 7300-0028:0219 |

WIRING LEGEND

| LABEL | GAUGE | USE | TYPE (OR EQUIVALENT) |
|-------|----------|---------------------|----------------------|
| A | 16/2 UTP | SLC | WEST PENN D990 |
| B | 16/2 TSP | SPEAKER | WEST PENN D991 |
| C | 14 | NAC VISUAL | THHN |
| D | 14 | 24 VDC | THHN |
| E | 16/4 TS | ANNUNCIATOR | WEST PENN 993 |
| F | 14/2 TSP | FIRE FIGHTERS PHONE | WEST PENN D995 |

DRAWING INDEX


| | | |
|----|--------------------|----------|
| 1 | COVER SHEET | FA 0.0 |
| 2 | RISER DIAGRAM | FA 1.0 |
| 3 | FIRST FLOOR WEST | FA 3.01W |
| 4 | SECOND FLOOR EAST | FA 3.02E |
| 5 | SECOND FLOOR WEST | FA 3.02W |
| 6 | THIRD FLOOR EAST | FA 3.03E |
| 7 | THIRD FLOOR WEST | FA 3.03W |
| 8 | FOURTH FLOOR EAST | FA 3.04E |
| 9 | FOURTH FLOOR WEST | FA 3.04W |
| 10 | FIFTH FLOOR EAST | FA 3.05E |
| 11 | FIFTH FLOOR WEST | FA 3.05W |
| 12 | SIXTH FLOOR EAST | FA 3.06E |
| 13 | SEVENTH FLOOR EAST | FA 3.07E |
| 14 | CALCULATIONS | FA 4.0 |
| 15 | DETAILS | FA 5.0 |

Revisions

| NO. | DATE | DESCRIPTION |
|-----|-----------|---------------------------------------|
| 1 | 8/14/2011 | REVIEW COMMENTS |
| 2 | 8/14/2011 | REVIEW COMMENTS |
| 3 | 8/20/2012 | CFB 10561.1 F1 B9 SFM REVIEW COMMENTS |
| 4 | 1/15/2013 | CFB 82.2 |
| 5 | 4/30/2013 | FA & SMOKE CONTROL SFM COMMENTS |
| 6 | 8/23/2013 | AS-BUILT DRAWINGS |

| | |
|--|---------------------------------------|
| DESIGNED BY: Curtis Steiner | DATE: 08/23/2013 |
| DRAWN BY: Derek Richardson | SCALE: |
| CHECKED BY: CURTIS STEINER, SET NICET IV #102872 | DRAWING CODE: FA ALL DRAWINGS CPFS |
| PROJECT ENGINEER: Integral Design Associates, INC. | |

CENTER FOR SCIENCE AND MATHEMATICS
CALIFORNIA STATE POLYTECHNIC UNIVERSITY
 SAN LUIS OBISPO, CA
 CSFM #18-40-03-0001



FIRE ALARM THIRD FLOOR WEST
 SCALE 1/8" = 1'0"

| QUANTITY | FIRE ALARM SYMBOLS | MODEL # | CSEFM LISTING # |
|----------|--------------------|----------|--------------------------------|
| 29 | [MPS] | NBG-12LX | 7150-0028-0199 |
| 73 | [S] | SW | 7320-1653-201 |
| 153 | [SP] | SPWS | 7320-1653-201 |
| 6 | [SP] | SPW | 7320-1653-201 |
| 7 | [WP] | SPWK | 7320-1653-201 |
| 0 | [H] | FST-851 | 7270-0028-196 |
| 18 | [S] | FSP-851 | 7270-0028-206 |
| 64 | [S] | DNR | 3042-1653-209 |
| 23 | [S] | OSE-SPW | 7260-1728-0121 |
| 15 | [S] | OSI-90 | 7260-1728-0121 |
| 1 | [FACP] | NFS2-640 | 7165-0028-0243 |
| 5 | [RNPS] | ACPS-610 | 7315-0028-248 |
| 5 | [FATC] | N/A | N/A |
| 32 | [E] | N/A | N/A |
| 2 | [RA] | FDU-80 | 7120-0028-209 |
| 8 | [MD] | N/A | BY OTHERS |
| 19 | [AM] | FRM-1 | 7300-0028-0219 |
| 9 | [RM] | FRM-1 | 7300-0028-219 |
| 16 | [WFS] | N/A | BY OTHERS |
| 22 | [VTS] | N/A | BY OTHERS |
| 21 | [FDM] | FRM-1 | 7300-0028-0219 |
| 64 | [FDRM] | FDRM-1 | 7300-0028-0219 |
| 12 | [FJ] | FTM-1 | 7300-1652-0182 |
| 4 | [DAA2] | DAA2 | 7170-0028-223 7170-0028-224 |
| 1 | [XPR-R] | XPR-R | 7300-0028-0219 |
| 1 | [XPI-M] | XPI-M | 7300-0028-0219 |

| LABEL | GAUGE | USE | TYPE (OR EQUIVALENT) |
|-------|----------|---------------------|----------------------|
| A | 16/2 UTP | SLC | WEST PENN D990 |
| B | 16/2 TSP | SPEAKER | WEST PENN D991 |
| C | 14 | NAC VISUAL | THHN |
| D | 14 | 24 VDC | THHN |
| E | 16/4 TS | ANNUNCIATOR | WEST PENN 993 |
| F | 14/2 TSP | FIRE FIGHTERS PHONE | WEST PENN D995 |

| DRAWING INDEX | | |
|---------------|--------------------|----------|
| 1 | COVER SHEET | FA 0.0 |
| 2 | RISER DIAGRAM | FA 1.0 |
| 3 | FIRST FLOOR WEST | FA 3.01W |
| 4 | SECOND FLOOR EAST | FA 3.02E |
| 5 | SECOND FLOOR WEST | FA 3.02W |
| 6 | THIRD FLOOR EAST | FA 3.03E |
| 7 | THIRD FLOOR WEST | FA 3.03W |
| 8 | FOURTH FLOOR EAST | FA 3.04E |
| 9 | FOURTH FLOOR WEST | FA 3.04W |
| 10 | FIFTH FLOOR EAST | FA 3.05E |
| 11 | FIFTH FLOOR WEST | FA 3.05W |
| 12 | SIXTH FLOOR EAST | FA 3.06E |
| 13 | SEVENTH FLOOR EAST | FA 3.07E |
| 14 | CALCULATIONS | FA 4.0 |
| 15 | DETAILS | FA 5.0 |

Deep Blue Integration
 Consulting - Design - Installation
 Service - Monitoring
 Deep Blue Integration, Inc.
 3442 Empress Drive Suite C
 San Luis Obispo, CA 93401
 C-10, C-16 #943465 ACO#68864
 Toll Free: 888-600-0081 FAX:
 805-781-4203
 www.deepblueintegration.com

| REVISIONS | DATE | DESCRIPTION |
|-----------|-----------|---------------------------------|
| 1 | 8/14/2011 | REVIEW COMMENTS |
| 2 | 5/18/2012 | CRB # 1081 & F1 99 |
| 3 | 4/11/2012 | SFM REVIEW COMMENTS |
| 4 | 8/20/2012 | CRB # 932 |
| 5 | 1/15/2013 | FA & SMOKE CONTROL SFM COMMENTS |
| 6 | 4/2/2013 | AS-BUILT DRAWINGS |
| 7 | 8/23/2013 | |

DESIGNED BY: Curt Steiner
 DRAWN BY: Derek Richardson
 CHECKED BY: CURTIS SYLVESTER, SET
 NCE/TH #16627
 PROJECT ENGINEER: Integral Design Associates, Inc.

DATE: 08/23/2013
 SCALE:
 DRAWING CODE: FA ALL DRAWINGS CRPFS

CENTER FOR SCIENCE AND MATHEMATICS
 CALIFORNIA STATE POLYTECHNIC UNIVERSITY
 SAN LUIS OBISPO, CA
 CSEFM #18-40-03-0001


SHEET ID
FA 3.03W
 SHEET 6 OF 15

| REVISIONS | REVIEW COMMENTS | DATE | APPR. |
|-----------|---------------------------------|-----------|-------|
| 1 | CRB #08.1 & F1 89 | 6/14/2011 | |
| 2 | SPM REVIEW COMMENTS | 5/18/2012 | |
| 3 | CRB #3.2 | 4/17/2012 | |
| 4 | FA & SMOKE CONTROL SPM COMMENTS | 8/20/2012 | |
| 5 | AS-BUILT DRAWINGS | 1/15/2013 | |
| 6 | | 4/9/2013 | |
| 7 | | 8/23/2013 | |

| | | | |
|---|---------------------|--------|---------------------------------------|
| DESIGNED BY: Curtis Streever | DATE: 08/22/2013 | SCALE: | DRAWING CODE: FA ALL DRAWINGS CPFS |
| DRAWN BY: Derek Richardson | | | |
| CHECKED BY: SAFETY REVIEWER, SET DATE: 11/14/2013 | | | |
| PROJECT ENGINEER: Integral Design Associates INC. | | | |

| | | | |
|---|---------------------|--------|---------------------------------------|
| DESIGNED BY: Curtis Streever | DATE: 08/22/2013 | SCALE: | DRAWING CODE: FA ALL DRAWINGS CPFS |
| DRAWN BY: Derek Richardson | | | |
| CHECKED BY: SAFETY REVIEWER, SET DATE: 11/14/2013 | | | |
| PROJECT ENGINEER: Integral Design Associates INC. | | | |

**CENTER FOR SCIENCE AND MATHEMATICS
 CALIFORNIA STATE POLYTECHNIC UNIVERSITY**
 SAN LUIS OBISPO, CA
 CSFM #18-40-03-0001



FIRE ALARM THIRD FLOOR EAST
 SCALE 1/8" = 1'0"


SHEET NOTES

- 1 PROVIDE FIRE ALARM BEAM DETECTORS TRANSMITTER AND RECEIVER. INTERLOCK WITH SMOKE EVACUATION SYSTEM SUCH THAT WHEN BEAM DETECTOR IS ACTIVATED, SMOKE EVACUATION SYSTEM IS ACTIVATED. REFER TO DETAIL 4 & 5/FA5.0.
- 2 ACTIVATION OF A MANUAL PULL STATION, BEAM DETECTOR OR SPRINKLER WATER FLOW WITHIN THE ATRIUM SHALL ACTIVATE ATRIUM SMOKE EVACUATION SYSTEM. SMOKE EVACUATION SYSTEM SHALL FUNCTION AS DIRECTED BY MECHANICAL DOCUMENTS. REFER TO DETAIL 9/M5.05 FOR ADDITIONAL INFORMATION.
- 3 ACTIVATION OF AN ALARM ANYWHERE WITHIN THE BUILDING SHALL SHUT DOWN ALL AIR HANDLING UNITS.
- 4 ACTIVATION OF THE ATRIUM SMOKE CONTROL SYSTEM SHALL OPEN ALL ATRIUM DOORS WITH MOTORIZED DOOR OPERATORS.

| SYMBOL LEGEND | | | |
|---------------|-----------------------------------|----------|--------------------------------|
| COUNT | FIRE ALARM SYMBOLS | MODEL # | CSFM LISTING # |
| 31 | MANUAL PULL STATION | NBG-12LX | 7150-0028-0199 |
| 73 | STROBE ONLY | SW | 7320-1653-201 |
| 165 | SPEAKER/STROBE | SPWS | 7320-1653-201 |
| 6 | SPEAKER ONLY | SPW | 7320-1653-201 |
| 7 | SPEAKER - WEATHER PROOF | SPWK | 7320-1653-201 |
| 0 | HEAT DETECTOR | FST-851 | 7270-0028-196 |
| 18 | SMOKE DETECTOR | FSP-851 | 7272-0028-206 |
| 64 | SMOKE DETECTOR - DUCT | DNR | 3242-1653-209 |
| 23 | BEAM SMOKE DETECTOR - TRANSMITTER | OSE-SPW | 7260-1728-0121 |
| 15 | BEAM SMOKE DETECTOR - RECEIVER | OSI-90 | 7260-1728-0121 |
| 1 | FIRE ALARM CONTROL PANEL | NFS2-640 | 7165-0028-0243 |
| 5 | REMOTE NOTIFICATION POWER SUPPLY | ACPS-610 | 7315-0028-248 |
| 4 | FIRE ALARM TERMINAL CABINET | N/A | N/A |
| 32 | END OF LINE RESISTOR | N/A | N/A |
| 2 | REMOTE ANNUNCIATOR | FOL-80 | 7120-0028-209 |
| 8 | MAGNETIC DOOR HOLDER | N/A | BY OTHERS |
| 21 | ADDRESSABLE MODULE | FMM-1 | 7300-0028-0219 |
| 12 | RELAY MODULE | FRM-1 | 7300-0028-219 |
| 16 | WATER FLOW SWITCH | N/A | BY OTHERS |
| 10 | VALVE TAMPER SWITCH | N/A | BY OTHERS |
| 21 | DUAL MONITOR MODULE | FDM-1 | 7300-0028-0219 |
| 64 | DUAL RELAY / MONITOR MODULE | FRDM-1 | 7300-0028-0219 |
| 12 | FIRE FIGHTERS PHONE JACKS | FTM-1 | 7300-1652-0182 |
| 4 | DIGITAL AUDIO AMPLIFIERS | DA2 | 7170-0028-223 7170-0028-224 |
| 1 | SIX RELAY CONTROL MODULE | XP6-R | 7300-0028-0219 |
| 1 | TEN-INPUT MONITOR MODULE | XP10-M | 7300-0028-0219 |

| WIRING LEGEND | | | |
|---------------|----------|---------------------|----------------------|
| LABEL | GAUGE | USE | TYPE (OR EQUIVALENT) |
| A | 16/2 UTP | SLC | WEST PENN D990 |
| B | 16/2 TSP | SPEAKER | WEST PENN D991 |
| C | 14 | NAC VISUAL | THHN |
| D | 14 | 24 VDC | THHN |
| E | 16/4 TS | ANNUNCIATOR | WEST PENN 993 |
| F | 14/2 TSP | FIRE FIGHTERS PHONE | WEST PENN D995 |

| DRAWING INDEX | | |
|---------------|--------------------|----------|
| 1 | COVER SHEET | FA 0.0 |
| 2 | RISER DIAGRAM | FA 1.0 |
| 3 | FIRST FLOOR WEST | FA 3.01W |
| 4 | SECOND FLOOR EAST | FA 3.02E |
| 5 | SECOND FLOOR WEST | FA 3.02W |
| 6 | THIRD FLOOR EAST | FA 3.03E |
| 7 | THIRD FLOOR WEST | FA 3.03W |
| 8 | FOURTH FLOOR EAST | FA 3.04E |
| 9 | FOURTH FLOOR WEST | FA 3.04W |
| 10 | FIFTH FLOOR EAST | FA 3.05E |
| 11 | FIFTH FLOOR WEST | FA 3.05W |
| 12 | SIXTH FLOOR EAST | FA 3.06E |
| 13 | SEVENTH FLOOR EAST | FA 3.07E |
| 14 | CALCULATIONS | FA 4.0 |
| 15 | DETAILS | FA 5.0 |



FIRE ALARM FOURTH FLOOR WEST
 SCALE 1/8" = 1'0"

| COUNT | FIRE ALARM SYMBOLS | MODEL # | CSFM LISTING # |
|-------|-----------------------------------|----------|--------------------------------|
| 31 | MANUAL PULL STATION | NBS-12LK | 7150-0028:0199 |
| 73 | STROBE ONLY | SW | 7320-1653:201 |
| 165 | SPEAKER/STROBE | SPWS | 7320-1653:201 |
| 6 | SPEAKER ONLY | SPW | 7320-1653:201 |
| 7 | SPEAKER - WEATHER PROOF | SPWK | 7320-1653:201 |
| 0 | HEAT DETECTOR | FST-851 | 7270-0028:196 |
| 18 | SMOKE DETECTOR | FSP-851 | 7272-0028:206 |
| 64 | SMOKE DETECTOR - DUCT | DNR | 3242-1653:209 |
| 23 | BEAM SMOKE DETECTOR - TRANSMITTER | OSE-SPW | 7280-1728:0121 |
| 15 | BEAM SMOKE DETECTOR - RECEIVER | OSI-90 | 7280-1728:0121 |
| 1 | FIRE ALARM CONTROL PANEL | NFS2-640 | 7165-0028:0243 |
| 5 | REMOTE NOTIFICATION POWER SUPPLY | ACPS-610 | 7315-0028:248 |
| 4 | FIRE ALARM TERMINAL CABINET | N/A | N/A |
| 32 | END OF LINE RESISTOR | N/A | N/A |
| 2 | REMOTE ANNUNCIATOR | FDU-80 | 7120-0028:209 |
| 8 | MAGNETIC DOOR HOLDER | N/A | BY OTHERS |
| 21 | ADDRESSABLE MODULE | FRM-1 | 7300-0028:0219 |
| 12 | RELAY MODULE | FRM-1 | 7300-0028:219 |
| 16 | WATER FLOW SWITCH | N/A | BY OTHERS |
| 10 | VALVE TAMPER SWITCH | N/A | BY OTHERS |
| 21 | DUAL MONITOR MODULE | FDM-1 | 7300-0028:0219 |
| 64 | DUAL RELAY / MONITOR MODULE | FDRM-1 | 7300-0028:0219 |
| 12 | FIRE FIGHTERS PHONE JACKS | FTM-1 | 7300-1652:0182 |
| 4 | DIGITAL AUDIO AMPLIFIERS | DA2 | 7170-0028:223 7170-0028:224 |
| 1 | SIX RELAY CONTROL MODULE | XP6-R | 7300-0028:0219 |
| 1 | TEN-INPUT MONITOR MODULE | XP10-M | 7300-0028:0219 |

| LABEL | GAUGE | USE | TYPE (OR EQUIVALENT) |
|-------|----------|---------------------|----------------------|
| A | 16/2 UTP | SLC | WEST PENN D990 |
| B | 16/2 TSP | SPEAKER | WEST PENN D991 |
| C | 14 | NAC VISUAL | THHN |
| D | 14 | 24 VDC | THHN |
| E | 16/4 TS | ANNUNCIATOR | WEST PENN 993 |
| F | 14/2 TSP | FIRE FIGHTERS PHONE | WEST PENN D995 |

| DRAWING INDEX | | |
|---------------|--------------------|----------|
| 1 | COVER SHEET | FA 0.0 |
| 2 | RISER DIAGRAM | FA 1.0 |
| 3 | FIRST FLOOR WEST | FA 3.01W |
| 4 | SECOND FLOOR EAST | FA 3.02E |
| 5 | SECOND FLOOR WEST | FA 3.02W |
| 6 | THIRD FLOOR EAST | FA 3.03E |
| 7 | THIRD FLOOR WEST | FA 3.03W |
| 8 | FOURTH FLOOR EAST | FA 3.04E |
| 9 | FOURTH FLOOR WEST | FA 3.04W |
| 10 | FIFTH FLOOR EAST | FA 3.05E |
| 11 | FIFTH FLOOR WEST | FA 3.05W |
| 12 | SIXTH FLOOR EAST | FA 3.06E |
| 13 | SEVENTH FLOOR EAST | FA 3.07E |
| 14 | CALCULATIONS | FA 4.0 |
| 15 | DETAILS | FA 5.0 |


Deep Blue Integration
 Consulting - Design - Installation
 Service - Monitoring
 Deep Blue Integration, Inc.
 3442 Empress Drive Suite C
 San Luis Obispo, CA 93401
 C-10, C-16 #943465 ACO#6864
 Toll Free: 888-800-0081 FAX:
 805-791-9237
 www.deepblueintegration.com

| REVISIONS | DATE | DESCRIPTION |
|---------------------------------|-----------|-------------|
| REVIEW COMMENTS | | |
| CB # 1051 & F1 P9 | 8/14/2011 | |
| SFM REVIEW COMMENTS | 4/11/2012 | |
| CB # 82 | 8/20/2012 | |
| FA & SMOKE CONTROL SFM COMMENTS | 1/15/2013 | |
| AS-BUILT DRAWINGS | 4/9/2013 | |
| | 8/23/2013 | |

| | | | | |
|--|---------------------|--|--------|---------------------------------------|
| DESIGNED BY: Curtis Streever | DATE: 08/23/2013 | DRAWN BY: Derek Richardson | SCALE: | DRAWING CODE: FA-ALL DRAWINGS CPFS |
| CHECKED BY: CURTIS STREEVER, SET NICET IV #10272 | | PROJECT ENGINEER: Integral Design Associates INC. | | |

CENTER FOR SCIENCE AND MATHEMATICS
CALIFORNIA STATE POLYTECHNIC UNIVERSITY
 SAN LUIS OBISPO, CA
 CSFM #18-40-03-001

SHEET ID
FA 3.04W
 SHEET 6 OF 15



FIRE ALARM FOURTH FLOOR EAST
 SCALE 1/8" = 1'0"

SHEET NOTES

- 1 PROVIDE FIRE ALARM BEAM DETECTORS TRANSMITTER AND RECEIVER. INTERLOCK WITH SMOKE EVACUATION SYSTEM SUCH THAT WHEN BEAM DETECTOR IS ACTIVATED, SMOKE EVACUATION SYSTEM IS ACTIVATED. REFER TO DETAIL 4 & 5/FA.0.
- 2 ACTIVATION OF A MANUAL PULL STATION, BEAM DETECTOR OR SPRINKLER WATER FLOW WITHIN THE ATRIUM SHALL ACTIVATE ATRIUM SMOKE EVACUATION SYSTEM. SMOKE EVACUATION SYSTEM SHALL FUNCTION AS DIRECTED BY MECHANICAL DOCUMENTS. REFER TO DETAIL 9/M5.05 FOR ADDITIONAL INFORMATION.
- 3 ACTIVATION OF AN ALARM ANYWHERE WITHIN THE BUILDING SHALL SHUT DOWN ALL AIR HANDLING UNITS.
- 4 ACTIVATION OF THE ATRIUM SMOKE CONTROL SYSTEM SHALL OPEN ALL ATRIUM DOORS WITH MOTORIZED DOOR OPERATORS.

| SYMBOL LEGEND | | | |
|---------------|-----------------------------------|----------|--------------------------------|
| COUNT | FIRE ALARM SYMBOLS | MODEL # | CSFM LISTING # |
| 31 | MANUAL PULL STATION | NBG-12LX | 7150-0028-0199 |
| 73 | STROBE ONLY | SW | 7320-1653-201 |
| 165 | SPEAKER/STROBE | SPWS | 7320-1653-201 |
| 6 | SPEAKER ONLY | SPW | 7320-1653-201 |
| 7 | SPEAKER - WEATHER PROOF | SPWK | 7320-1653-201 |
| 0 | HEAT DETECTOR | FST-851 | 7270-0028-196 |
| 18 | SMOKE DETECTOR | FSP-851 | 7272-0028-206 |
| 64 | SMOKE DETECTOR - DUCT | DNR | 8242-1653-209 |
| 23 | BEAM SMOKE DETECTOR - TRANSMITTER | OSE-SPW | 7280-1728-0121 |
| 15 | BEAM SMOKE DETECTOR - RECEIVER | OSI-90 | 7280-1728-0121 |
| 1 | FIRE ALARM CONTROL PANEL | NFS2-640 | 7165-0028-0243 |
| 5 | REMOTE NOTIFICATION POWER SUPPLY | ACPS-610 | 7315-0028-248 |
| 4 | FIRE ALARM TERMINAL CABINET | N/A | N/A |
| 32 | END OF LINE RESISTOR | N/A | N/A |
| 2 | REMOTE ANNUNCIATOR | FDU-80 | 7120-0028-209 |
| 8 | MAGNETIC DOOR HOLDER | N/A | BY OTHERS |
| 21 | ADDRESSABLE MODULE | FMM-1 | 7300-0028-0219 |
| 12 | RELAY MODULE | FRM-1 | 7300-0028-219 |
| 16 | WATER FLOW SWITCH | N/A | BY OTHERS |
| 16 | VALVE TAMPER SWITCH | N/A | BY OTHERS |
| 21 | DUAL MONITOR MODULE | FDM-1 | 7300-0028-0219 |
| 64 | DUAL RELAY / MONITOR MODULE | FDRM-1 | 7300-0028-0219 |
| 12 | FIRE FIGHTERS PHONE JACKS | FTM-1 | 7300-1652-0182 |
| 4 | DIGITAL AUDIO AMPLIFIERS | DA2 | 7170-0028-223 7170-0028-224 |
| 1 | SIX RELAY CONTROL MODULE | XP6-R | 7300-0028-0219 |
| 1 | TEN-INPUT MONITOR MODULE | XP10-M | 7300-0028-0219 |


| WIRING LEGEND | | | |
|---------------|----------|---------------------|----------------------|
| LABEL | GAUGE | USE | TYPE (OR EQUIVALENT) |
| A | 16/2 UTP | SLC | WEST PENN D990 |
| B | 16/2 TSP | SPEAKER | WEST PENN D991 |
| C | 14 | NAC VISUAL | THHN |
| D | 14 | 24 VDC | THHN |
| E | 16/4 TS | ANNUNCIATOR | WEST PENN 993 |
| F | 14/2 TSP | FIRE FIGHTERS PHONE | WEST PENN D995 |

| DRAWING INDEX | | |
|---------------|--------------------|----------|
| 1 | COVER SHEET | FA 0.0 |
| 2 | RISER DIAGRAM | FA 1.0 |
| 3 | FIRST FLOOR WEST | FA 3.01W |
| 4 | SECOND FLOOR EAST | FA 3.02E |
| 5 | SECOND FLOOR WEST | FA 3.02W |
| 6 | THIRD FLOOR EAST | FA 3.03E |
| 7 | THIRD FLOOR WEST | FA 3.03W |
| 8 | FOURTH FLOOR EAST | FA 3.04E |
| 9 | FOURTH FLOOR WEST | FA 3.04W |
| 10 | FIFTH FLOOR EAST | FA 3.05E |
| 11 | FIFTH FLOOR WEST | FA 3.05W |
| 12 | SIXTH FLOOR EAST | FA 3.06E |
| 13 | SEVENTH FLOOR EAST | FA 3.07E |
| 14 | CALCULATIONS | FA 4.0 |
| 15 | DETAILS | FA 5.0 |

| REVISIONS | DATE | DESCRIPTION | SYMBOL | APPR. |
|---------------------------------|-----------|-------------|--------|-------|
| REVIEW COMMENTS | 6/14/2011 | | | |
| CRB # 063.1 & 19 | 5/18/2012 | | | |
| SPM REVIEW COMMENTS | 4/11/2012 | | | |
| CRB # 83.2 | 8/20/2012 | | | |
| FA & SMOKE CONTROL SPM COMMENTS | 1/15/2013 | | | |
| AS-BUILT DRAWINGS | 4/20/2013 | | | |
| | 8/23/2013 | | | |

| | | | | | | |
|---------------------------------|---------------------|-------------------------------|--------------------|----------------------------------|--|--|
| DESIGNED BY: Curtis Streever | DATE: 08/23/2013 | DRAWN BY: Derek Richardson | SCALE: AS SHOWN | CHECKED BY: DANIEL RICHARDSON | DRAWING CODE: FA ALL DRAWINGS CPD/CFS | PROJECT ENGINEER: Integral Design Associates INC. |
|---------------------------------|---------------------|-------------------------------|--------------------|----------------------------------|--|--|

CENTER FOR SCIENCE AND MATHEMATICS
CALIFORNIA STATE POLYTECHNIC UNIVERSITY
 SAN LUIS OBISPO, CA
 CSFM #18-40-03-0001



FIRE ALARM FIFTH FLOOR EAST
 SCALE 1/8" = 1'-0"

SHEET NOTES

- 1 PROVIDE FIRE ALARM BEAM DETECTORS TRANSMITTER AND RECEIVER. INTERLOCK WITH SMOKE EVACUATION SYSTEM SUCH THAT WHEN BEAM DETECTOR IS ACTIVATED, SMOKE EVACUATION SYSTEM IS ACTIVATED. REFER TO DETAIL 4 & 5/FA5.0.
- 2 ACTIVATION OF A MANUAL PULL STATION, BEAM DETECTOR OR SPRINKLER WATER FLOW WITHIN THE ATRIUM SHALL ACTIVATE ATRIUM SMOKE EVACUATION SYSTEM. SMOKE EVACUATION SYSTEM SHALL FUNCTION AS DIRECTED BY MECHANICAL DOCUMENTS. REFER TO DETAIL 9/M5.05 FOR ADDITIONAL INFORMATION.
- 3 ACTIVATION OF AN ALARM ANYWHERE WITHIN THE BUILDING SHALL SHUT DOWN ALL AIR HANDLING UNITS.
- 4 ACTIVATION OF THE ATRIUM SMOKE CONTROL SYSTEM SHALL OPEN ALL ATRIUM DOORS WITH MOTORIZED DOOR OPERATORS.

SYMBOL LEGEND

| COUNT | FIRE ALARM SYMBOLS | MODEL # | CSFM LISTING # |
|-------|-------------------------------------|--------------------------------|----------------|
| 31 | [MPS] | MBG-12LX | 7150-0028:0199 |
| 73 | [STROBE] | SW | 7320-1653:201 |
| 165 | [SPEAKER] | SPWS | 7320-1653:201 |
| 6 | [SPEAKER ONLY] | SPW | 7320-1653:201 |
| 7 | [SPEAKER - WEATHER PROOF] | SPWK | 7320-1653:201 |
| 0 | [HEAT DETECTOR] | FST-851 | 7270-0028:196 |
| 18 | [SMOKE DETECTOR] | FSP-851 | 7272-0028:206 |
| 64 | [SMOKE DETECTOR - DUCT] | DNR | 3242-1653:209 |
| 23 | [BEAM SMOKE DETECTOR - TRANSMITTER] | OSE-SPW | 7280-1728:0121 |
| 15 | [BEAM SMOKE DETECTOR - RECEIVER] | OSI-90 | 7280-1728:0121 |
| 1 | [FACP] | NFS-640 | 7185-0028:0240 |
| 5 | [RNPS] | ACPS-610 | 7315-0028:248 |
| 4 | [FATC] | N/A | N/A |
| 22 | [END OF LINE RESISTOR] | N/A | N/A |
| 2 | [RA] | FDU-80 | 7120-0028:209 |
| 8 | [MD] | N/A | BY OTHERS |
| 21 | [AM] | FMM-1 | 7300-0028:0219 |
| 12 | [RM] | FRM-1 | 7300-0028:219 |
| 16 | [WFS] | N/A | BY OTHERS |
| 10 | [VTS] | N/A | BY OTHERS |
| 21 | [FDM] | FDM-1 | 7300-0028:0219 |
| 64 | [FDRM] | FDRM-1 | 7300-0028:0219 |
| 12 | [FJ] | FTM-1 | 7300-1652:0182 |
| 4 | [DAA2] | 7170-0028:223 7170-0028:224 | |
| 1 | [XPR-R] | XP6-R | 7300-0028:0219 |
| 1 | [XPR-M] | XP10-M | 7300-0028:0219 |

WIRING LEGEND

| LABEL | GAUGE | USE | TYPE (OR EQUIVALENT) |
|-------|----------|---------------------|----------------------|
| A | 16/2 UTP | SLC | WEST PENN D990 |
| B | 16/2 TSP | SPEAKER | WEST PENN D991 |
| C | 14 | NAC VISUAL | THHN |
| D | 14 | 24 VDC | THHN |
| E | 16/4 TS | ANNUNCIATOR | WEST PENN 993 |
| F | 14/2 TSP | FIRE FIGHTERS PHONE | WEST PENN D995 |

DRAWING INDEX


| | | |
|----|--------------------|----------|
| 1 | COVER SHEET | FA 0.0 |
| 2 | RISER DIAGRAM | FA 1.0 |
| 3 | FIRST FLOOR WEST | FA 3.01W |
| 4 | SECOND FLOOR EAST | FA 3.02E |
| 5 | SECOND FLOOR WEST | FA 3.02W |
| 6 | THIRD FLOOR EAST | FA 3.03E |
| 7 | THIRD FLOOR WEST | FA 3.03W |
| 8 | FOURTH FLOOR EAST | FA 3.04E |
| 9 | FOURTH FLOOR WEST | FA 3.04W |
| 10 | FIFTH FLOOR EAST | FA 3.05E |
| 11 | FIFTH FLOOR WEST | FA 3.05W |
| 12 | SIXTH FLOOR EAST | FA 3.06E |
| 13 | SEVENTH FLOOR EAST | FA 3.07E |
| 14 | CALCULATIONS | FA 4.0 |
| 15 | DETAILS | FA 5.0 |

Revisions

| NO. | REVISION COMMENTS | DATE | APPR. |
|-----|---------------------------------|-----------|-------|
| 1 | REVIEW COMMENTS | 8/14/2011 | |
| 2 | CFB #0821 & F1 B9 | 5/18/2012 | |
| 3 | SPM REVIEW COMMENTS | 4/11/2012 | |
| 4 | CFB #9.2 | 8/20/2012 | |
| 5 | FA & SMOKE CONTROL SPM COMMENTS | 1/15/2013 | |
| 6 | AS-BUILT DRAWINGS | 4/3/2013 | |
| | | 8/23/2013 | |

| | | | |
|--|---------------------------------------|---|--------------------|
| DESIGNED BY: Curtis Streever | DATE: 08/23/2013 | DRAWN BY: Derek Richardson | SCALE: AS SHOWN |
| CHECKED BY: CURTIS STREEVER, SET NICETTY #102872 | DRAWING CODE: FA ALL DRAWINGS CPFS | PROJECT ENGINEER: Integral Design Associates, Inc. | |

CENTER FOR SCIENCE AND MATHEMATICS
CALIFORNIA STATE POLYTECHNIC UNIVERSITY
 SAN LUIS OBISPO, CA
 CSFM #18-40-03-0001



FIRE ALARM FIFTH FLOOR EAST
 SCALE 1/8" = 1'-0"

SHEET NOTES

- 1 PROVIDE FIRE ALARM BEAM DETECTORS TRANSMITTER AND RECEIVER. INTERLOCK WITH SMOKE EVACUATION SYSTEM SUCH THAT WHEN BEAM DETECTOR IS ACTIVATED, SMOKE EVACUATION SYSTEM IS ACTIVATED. REFER TO DETAIL 4 & 5/FA.0.
- 2 ACTIVATION OF A MANUAL PULL STATION, BEAM DETECTOR OR SPRINKLER WATER FLOW WITHIN THE ATRIUM SHALL ACTIVATE ATRIUM SMOKE EVACUATION SYSTEM. SMOKE EVACUATION SYSTEM SHALL FUNCTION AS DIRECTED BY MECHANICAL DOCUMENTS. REFER TO DETAIL 9/M5.05 FOR ADDITIONAL INFORMATION.
- 3 ACTIVATION OF AN ALARM ANYWHERE WITHIN THE BUILDING SHALL SHUT DOWN ALL AIR HANDLING UNITS.
- 4 ACTIVATION OF THE ATRIUM SMOKE CONTROL SYSTEM SHALL OPEN ALL ATRIUM DOORS WITH MOTORIZED DOOR OPERATORS.

SYMBOL LEGEND

| COUNT | FIRE ALARM SYMBOLS | MODEL # | CSFM LISTING # |
|-------|---------------------------------------|--------------------------------|----------------|
| 31 | MANUAL PULL STATION | NBSG-12LX | 7150-0028-0199 |
| 73 | STROBE ONLY | SW | 7320-1653-201 |
| 165 | SPEAKER/STROBE | SPWS | 7320-1653-201 |
| 6 | SPEAKER ONLY | SPW | 7320-1653-201 |
| 7 | SPEAKER - WEATHER PROOF | SPWK | 7320-1653-201 |
| 0 | HEAT DETECTOR | FST-851 | 7270-0028-106 |
| 18 | SMOKE DETECTOR | FSP-851 | 7272-0028-206 |
| 64 | SMOKE DETECTOR - DUCT | DNR | 3242-1653-209 |
| 23 | BEAM SMOKE DETECTOR - TRANSMITTER | OSE-SPW | 7260-1728-0121 |
| 15 | BEAM SMOKE DETECTOR - RECEIVER | OSI-90 | 7260-1728-0121 |
| 1 | FACP FIRE ALARM CONTROL PANEL | NFS2-640 | 7165-0028-0243 |
| 5 | RNPS REMOTE NOTIFICATION POWER SUPPLY | ACPS-610 | 7315-0028-248 |
| 4 | FATC FIRE ALARM TERMINAL CABINET | N/A | N/A |
| 32 | END OF LINE RESISTOR | N/A | N/A |
| 2 | RA REMOTE ANNUNCIATOR | FDU-80 | 7120-0028-209 |
| 8 | MD MAGNETIC DOOR HOLDER | N/A | BY OTHERS |
| 21 | AM ADDRESSABLE MODULE | FRM-1 | 7300-0028-0219 |
| 12 | RM RELAY MODULE | FRM-1 | 7300-0028-219 |
| 16 | WFS WATER FLOW SWITCH | N/A | BY OTHERS |
| 10 | VTS VALVE TAMPER SWITCH | N/A | BY OTHERS |
| 21 | EDM DUAL MONITOR MODULE | FDM-1 | 7300-0028-0219 |
| 64 | FDRM DUAL RELAY / MONITOR MODULE | FDRM-1 | 7300-0028-0219 |
| 12 | FJ FIRE FIGHTERS PHONE JACKS | FTM-1 | 7300-1652-0182 |
| 4 | DAA DIGITAL AUDIO AMPLIFIERS | 7170-0028-223 7170-0028-224 | |
| 1 | XP6-R SIX RELAY CONTROL MODULE | XP6-R | 7300-0028-0219 |
| 1 | XP10-M TEN INPUT MONITOR MODULE | XP10-M | 7300-0028-0219 |

WIRING LEGEND

| LABEL | GAUGE | USE | TYPE (OR EQUIVALENT) |
|-------|----------|---------------------|----------------------|
| A | 16/2 UTP | SLC | WEST PENN D990 |
| B | 16/2 TSP | SPEAKER | WEST PENN D991 |
| C | 14 | NAC VISUAL | THHN |
| D | 14 | 24 VDC | THHN |
| E | 16/4 TS | ANNUNCIATOR | WEST PENN 993 |
| F | 14/2 TSP | FIRE FIGHTERS PHONE | WEST PENN D995 |

DRAWING INDEX


| | | |
|----|--------------------|----------|
| 1 | COVER SHEET | FA 0.0 |
| 2 | RISER DIAGRAM | FA 1.0 |
| 3 | FIRST FLOOR WEST | FA 3.01W |
| 4 | SECOND FLOOR EAST | FA 3.02E |
| 5 | SECOND FLOOR WEST | FA 3.02W |
| 6 | THIRD FLOOR EAST | FA 3.03E |
| 7 | THIRD FLOOR WEST | FA 3.03W |
| 8 | FOURTH FLOOR EAST | FA 3.04E |
| 9 | FOURTH FLOOR WEST | FA 3.04W |
| 10 | FIFTH FLOOR EAST | FA 3.05E |
| 11 | FIFTH FLOOR WEST | FA 3.05W |
| 12 | SIXTH FLOOR EAST | FA 3.06E |
| 13 | SEVENTH FLOOR EAST | FA 3.07E |
| 14 | CALCULATIONS | FA 4.0 |
| 15 | DETAILS | FA 5.0 |

Revisions

| NO. | REVISION COMMENTS | DATE | SYMBOL | DESCRIPTION | APPR. |
|-----|---------------------------------|-----------|--------|-------------|-------|
| 1 | REVIEW COMMENTS | 6/14/2011 | | | |
| 2 | CFB #0951 & F1 B9 | 4/15/2012 | | | |
| 3 | SFM REVIEW COMMENTS | 8/20/2012 | | | |
| 4 | CFB #2 | 1/15/2013 | | | |
| 5 | FA & SMOKE CONTROL SFM COMMENTS | 4/3/2013 | | | |
| 6 | AS-BUILT DRAWINGS | 8/22/2013 | | | |

| | | | |
|--|---------------------|--------|---|
| DESIGNED BY: Curtis Steiner | DATE: 08/23/2013 | SCALE: | DRAWING CODE: FALL DRAWINGS CPFS |
| DRAWN BY: Derek Richardson | | | PROJECT ENGINEER: Integral Design Associates, INC. |
| CHECKED BY: CURTIS STEINER, SET NICET IV #102872 | | | |

CENTER FOR SCIENCE AND MATHEMATICS
CALIFORNIA STATE POLYTECHNIC UNIVERSITY
 SAN LUIS OBISPO, CA
 CSFM #18-40-03-0001



FIRE ALARM SIXTH FLOOR EAST ↑
 SCALE 1/8" = 1'0"

SHEET NOTES

- 1 PROVIDE FIRE ALARM BEAM DETECTORS TRANSMITTER AND RECEIVER. INTERLOCK WITH SMOKE EVACUATION SYSTEM SUCH THAT WHEN BEAM DETECTOR IS ACTIVATED, SMOKE EVACUATION SYSTEM IS ACTIVATED. REFER TO DETAIL 4 & 5/FA5.0.
- 2 ACTIVATION OF A MANUAL PULL STATION, BEAM DETECTOR OR SPRINKLER WATER FLOW WITHIN THE ATRIUM SHALL ACTIVATE ATRIUM SMOKE EVACUATION SYSTEM. SMOKE EVACUATION SYSTEM SHALL FUNCTION AS DIRECTED BY MECHANICAL DOCUMENTS. REFER TO DETAIL 9/M5.05 FOR ADDITIONAL INFORMATION.
- 3 ACTIVATION OF AN ALARM ANYWHERE WITHIN THE BUILDING SHALL SHUT DOWN ALL AIR HANDLING UNITS.
- 4 ACTIVATION OF THE ATRIUM SMOKE CONTROL SYSTEM SHALL OPEN ALL ATRIUM DOORS WITH MOTORIZED DOOR OPERATORS.

SYMBOL LEGEND

| COUNT | FIRE ALARM SYMBOLS | MODEL # | CSFM LISTING # |
|-------|---------------------------------------|----------|--------------------------------|
| 31 | MANUAL PULL STATION | NBG-12LX | 7150-0028-0199 |
| 73 | STROBE ONLY | SW | 7320-1653-201 |
| 165 | SPEAKER/STROBE | SPWS | 7320-1653-201 |
| 6 | SPEAKER ONLY | SPW | 7320-1653-201 |
| 7 | SPEAKER - WEATHER PROOF | SPWK | 7320-1653-201 |
| 9 | HEAT DETECTOR | FST-851 | 7270-0028-196 |
| 18 | SMOKE DETECTOR | FSP-851 | 7272-0028-206 |
| 84 | SMOKE DETECTOR - DUCT | DNR | 3242-1653-206 |
| 29 | BT BEAM SMOKE DETECTOR - TRANSMITTER | OSE-SPW | 7260-1728-0121 |
| 15 | BR BEAM SMOKE DETECTOR - RECEIVER | OSI-90 | 7260-1728-0121 |
| 1 | FACP FIRE ALARM CONTROL PANEL | NFS2-640 | 7165-0028-0243 |
| 5 | RNPS REMOTE NOTIFICATION POWER SUPPLY | ACPS-610 | 7315-0028-248 |
| 4 | FATC FIRE ALARM TERMINAL CABINET | N/A | N/A |
| 32 | END OF LINE RESISTOR | N/A | N/A |
| 2 | RA REMOTE ANNUNCIATOR | FDU-80 | 7120-0028-209 |
| 8 | MD MAGNETIC DOOR HOLDER | N/A | BY OTHERS |
| 21 | AM ADDRESSABLE MODULE | FMM-1 | 7300-0028-0219 |
| 12 | RM RELAY MODULE | FRM-1 | 7300-0028-219 |
| 16 | WFS WATER FLOW SWITCH | N/A | BY OTHERS |
| 10 | VTS VALVE TAMPER SWITCH | N/A | BY OTHERS |
| 21 | FDM DUAL MONITOR MODULE | FDM-1 | 7300-0028-0219 |
| 64 | FDRM DUAL RELAY / MONITOR MODULE | FDRM-1 | 7300-0028-0219 |
| 12 | FJ FIRE FIGHTERS PHONE JACKS | FTM-1 | 7300-1652-0182 |
| 4 | DAAD DIGITAL AUDIO AMPLIFIERS | DAAD | 7170-0028-223 7170-0028-224 |
| 1 | XP6R SIX RELAY CONTROL MODULE | XP6-R | 7300-0028-0219 |
| 1 | XP10M TEN-INPUT MONITOR MODULE | XP10-M | 7300-0028-0219 |

WIRING LEGEND

| LABEL | GAUGE | USE | TYPE (OR EQUIVALENT) |
|-------|----------|---------------------|----------------------|
| A | 16/2 UTP | SLC | WEST PENN D990 |
| B | 16/2 TSP | SPEAKER | WEST PENN D991 |
| C | 14 | NAC VISUAL | THHN |
| D | 14 | 24 VDC | THHN |
| E | 16/4 TS | ANNUNCIATOR | WEST PENN 993 |
| F | 14/2 TSP | FIRE FIGHTERS PHONE | WEST PENN D995 |

DRAWING INDEX


| | | |
|----|--------------------|----------|
| 1 | COVER SHEET | FA 0.0 |
| 2 | RISER DIAGRAM | FA 1.0 |
| 3 | FIRST FLOOR WEST | FA 3.01W |
| 4 | SECOND FLOOR EAST | FA 3.02E |
| 5 | SECOND FLOOR WEST | FA 3.02W |
| 6 | THIRD FLOOR EAST | FA 3.03E |
| 7 | THIRD FLOOR WEST | FA 3.03W |
| 8 | FOURTH FLOOR EAST | FA 3.04E |
| 9 | FOURTH FLOOR WEST | FA 3.04W |
| 10 | FIFTH FLOOR EAST | FA 3.05E |
| 11 | FIFTH FLOOR WEST | FA 3.05W |
| 12 | SIXTH FLOOR EAST | FA 3.06E |
| 13 | SEVENTH FLOOR EAST | FA 3.07E |
| 14 | CALCULATIONS | FA 4.0 |
| 15 | DETAILS | FA 5.0 |

Revisions

| NO. | REVISION COMMENTS | DATE | APPR. |
|-----|---------------------------------|------------|-------|
| 1 | REVIEW COMMENTS | | |
| 2 | CRB # 093.1 & F1 99 | 8/11/2013 | |
| 3 | SFM REVIEW COMMENTS | 8/20/2013 | |
| 4 | CRB # 2.3 | 11/15/2013 | |
| 5 | FA & SMOKE CONTROL SFM COMMENTS | 4/2/2013 | |
| 6 | AS-BUILT DRAWINGS | 8/23/2013 | |

| | |
|---|--|
| DESIGNED BY: Curtis Streeter | DATE: 08/23/2013 |
| DRAWN BY: Derek Richardson | SCALE: AS SHOWN |
| CHECKED BY: CURTIS STREETER, SET NICET IV #102672 | DRAWING CODE: FA ALL DRAWINGS CP/CS |
| PROJECT ENGINEER: Integral Design Associates INC. | |

CENTER FOR SCIENCE AND MATHEMATICS
CALIFORNIA STATE POLYTECHNIC UNIVERSITY
 SAN LUIS OBISPO, CA
 CSFM #18-40-05-0001



FIRE ALARM SEVENTH FLOOR EAST 
 SCALE 1/8" = 1'0"

SYMBOL LEGEND

| COUNT | FIRE ALARM SYMBOLS | MODEL # | CSFM LISTING # |
|-------|-----------------------------------|----------|--------------------------------|
| 31 | MANUAL PULL STATION | NBG-12LX | 7150-0028-0199 |
| 73 | STROBE ONLY | SW | 7320-1653-201 |
| 185 | SPEAKER/STROBE | SPWS | 7320-1653-201 |
| 6 | SPEAKER ONLY | SPW | 7320-1653-201 |
| 7 | SPEAKER - WEATHER PROOF | SPWK | 7320-1653-201 |
| 0 | HEAT DETECTOR | FST-851 | 7270-0028-196 |
| 18 | SMOKE DETECTOR | FSP-851 | 7272-0028-206 |
| 64 | SMOKE DETECTOR - DUCT | DNR | 3242-1653-209 |
| 25 | BEAM SMOKE DETECTOR - TRANSMITTER | OSE-SPW | 7260-1728-0121 |
| 15 | BEAM SMOKE DETECTOR - RECEIVER | OSI-90 | 7260-1728-0121 |
| 1 | FIRE ALARM CONTROL PANEL | NFS2-640 | 7165-0028-0243 |
| 5 | REMOTE NOTIFICATION POWER SUPPLY | ACPS-610 | 7315-0028-248 |
| 4 | FIRE ALARM TERMINAL CABINET | N/A | N/A |
| 32 | END OF LINE RESISTOR | N/A | N/A |
| 2 | REMOTE ANNUNCIATOR | FDU-80 | 7120-0028-209 |
| 8 | MAGNETIC DOOR HOLDER | N/A | BY OTHERS |
| 21 | ADDRESSABLE MODULE | FMM-1 | 7300-0028-0219 |
| 12 | RELAY MODULE | FRM-1 | 7300-0028-219 |
| 16 | WATER FLOW SWITCH | N/A | BY OTHERS |
| 10 | VALVE TAMPER SWITCH | N/A | BY OTHERS |
| 21 | DUAL MONITOR MODULE | FDM-1 | 7300-0028-0219 |
| 64 | DUAL RELAY / MONITOR MODULE | FDRM-1 | 7300-0028-0219 |
| 12 | FIRE FIGHTERS PHONE JACKS | FTM-1 | 7300-1652-0182 |
| 4 | DIGITAL AUDIO AMPLIFIERS | DAA2 | 7170-0028-223 7170-0028-224 |
| 1 | SIX RELAY CONTROL MODULE | XP6-R | 7300-0028-0219 |
| 1 | TEN-INPUT MONITOR MODULE | XP10-M | 7300-0028-0219 |

WIRING LEGEND

| LABEL | GAUGE | USE | TYPE (OR EQUIVALENT) |
|-------|----------|---------------------|----------------------|
| A | 16/2 UTP | SLC | WEST PENN D990 |
| B | 16/2 TSP | SPEAKER | WEST PENN D991 |
| O | 14 | NAC VISUAL | THHN |
| D | 14 | 24 VDC | THHN |
| T | 16/4 TS | ANNUNCIATOR | WEST PENN 993 |
| F | 14/2 TSP | FIRE FIGHTERS PHONE | WEST PENN D995 |

DRAWING INDEX

| | | |
|----|--------------------|----------|
| 1 | COVER SHEET | FA 0.0 |
| 2 | RISER DIAGRAM | FA 1.0 |
| 3 | FIRST FLOOR WEST | FA 3.01W |
| 4 | SECOND FLOOR EAST | FA 3.02E |
| 5 | SECOND FLOOR WEST | FA 3.02W |
| 6 | THIRD FLOOR EAST | FA 3.03E |
| 7 | THIRD FLOOR WEST | FA 3.03W |
| 8 | FOURTH FLOOR EAST | FA 3.04E |
| 9 | FOURTH FLOOR WEST | FA 3.04W |
| 10 | FIFTH FLOOR EAST | FA 3.05E |
| 11 | FIFTH FLOOR WEST | FA 3.05W |
| 12 | SIXTH FLOOR EAST | FA 3.06E |
| 13 | SEVENTH FLOOR EAST | FA 3.07E |
| 14 | CALCULATIONS | FA 4.0 |
| 15 | DETAILS | FA 5.0 |

Deep Blue Integration
 Consulting - Design - Installation
 Service - Monitoring
 Deep Blue Integration, Inc.
 3442 Empress Drive Suite C
 San Luis Obispo, CA 93401
 C-10, C-16 #943465 ACO#6864
 Toll Free: 888-800-0401 FAX:
 805-791-2037
 www.deepblueintegration.com

Revisions

| REVISION COMMENTS | DATE | APPR. |
|-------------------|------|-------|
| 6/14/2011 | | |
| 5/18/2012 | | |
| 4/11/2012 | | |
| 8/20/2012 | | |
| 8/20/2012 | | |
| 8/20/2012 | | |
| 1/15/2013 | | |
| 4/22/13 | | |
| 8/23/2013 | | |

DESIGNED BY: **Chris Steiner**
 DRAWN BY: **Devin Richardson**
 CHECKED BY: **CURTIS STREETER, SET**
 NICEET #102872
 PROJECT ENGINEER: **Integral Design Associates, INC.**
 DATE: 08/23/2013
 SCALE:
 DRAWING CODE: FA ALL DRAWINGS CPFS

CENTER FOR SCIENCE AND MATHEMATICS
CALIFORNIA STATE POLYTECHNIC UNIVERSITY
 SAN LUIS OBISPO, CA
 CSFM #18-40-03-0001

SHEET ID
FA 3.07E
 SHEET 13 OF 15

Revisions

| DATE | DESCRIPTION |
|-----------|-------------|
| 5/14/2011 | APPL |
| 4/11/2012 | APPL |
| 8/20/2012 | APPL |
| 1/15/2013 | APPL |
| 4/29/2013 | APPL |
| 8/23/2013 | APPL |

REVIEW COMMENTS


CRB # 0931 & F1 99
 SFM REVIEW COMMENTS
 CRB 82
 FA SMOKE CONTROL SFM COMMENTS
 AS-BUILT DRAWINGS

DESIGNED BY: Curtis Streeter
 DRAWN BY: Deek Richardson
 CHECKED BY: CURTIS STREETER, SET
 NICK IT # 102972
 PROJECT ENGINEER: Integrat Design Associates INC.
 DRAWING CODE: FA ALL DRAWINGS CPCS
 DATE: 08/23/2013
 SCALE:

**CENTER FOR SCIENCE AND MATHEMATICS
 CALIFORNIA STATE POLYTECHNIC UNIVERSITY
 SAN LUIS OBISPO, CA**

CSFM #18-40-03-001

DAA2 AMPLIFIER DIAGRAM























SPEAKER CALCULATIONS

Fire Alarm Control Panel Battery Calculation

| ITEM | DESCRIPTION | STANDBY CURRENT PER UNIT | QTY | TOTAL STANDBY CURRENT | ALARM CURRENT PER UNIT | QTY | TOTAL ALARM CURRENT |
|------|----------------------------------|--------------------------|-----|-----------------------|------------------------|-----|---------------------|
| 1 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 2 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 3 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 4 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 5 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 6 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 7 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 8 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 9 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 10 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 11 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 12 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 13 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 14 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 15 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 16 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 17 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 18 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 19 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 20 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 21 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 22 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 23 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 24 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 25 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 26 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 27 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 28 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 29 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 30 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 31 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 32 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 33 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 34 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 35 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 36 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 37 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 38 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 39 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 40 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 41 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 42 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 43 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 44 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 45 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 46 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 47 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 48 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 49 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 50 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 51 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 52 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 53 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 54 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 55 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 56 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 57 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 58 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 59 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 60 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 61 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 62 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 63 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 64 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 65 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 66 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 67 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 68 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 69 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 70 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 71 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 72 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 73 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 74 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 75 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 76 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 77 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 78 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 79 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 80 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 81 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 82 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 83 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 84 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 85 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 86 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 87 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 88 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 89 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 90 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 91 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 92 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 93 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 94 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 95 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 96 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 97 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 98 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 99 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 100 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |

Fire Alarm Control Panel Battery Calculation

| ITEM | DESCRIPTION | STANDBY CURRENT PER UNIT | QTY | TOTAL STANDBY CURRENT | ALARM CURRENT PER UNIT | QTY | TOTAL ALARM CURRENT |
|------|----------------------------------|--------------------------|-----|-----------------------|------------------------|-----|---------------------|
| 1 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 2 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 3 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 4 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 5 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 6 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 7 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 8 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 9 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 10 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 11 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 12 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 13 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 14 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 15 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 16 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 17 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 18 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 19 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 20 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 21 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 22 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |
| 23 | 12V 7Ah Sealed Lead Acid Battery | 0.050 | 1 | 0.050 | 0.050 | 1 | 0.050 |



DETAILS

Revisions

| REVISION COMMENTS | DATE | SYMBOL | DESCRIPTION |
|-------------------|------|--------|-------------|
| 6/14/2011 | | | |
| 8/1/2011 | | | |
| 8/20/2012 | | | |
| 1/15/2013 | | | |
| 4/23/2013 | | | |
| 8/23/2013 | | | |

| | |
|---|--|
| DESIGNED BY: Chris Sweeney | DATE: 06/23/2013 |
| DRAWN BY: Derek Richardson | SCALE: |
| CHECKED BY: CURTIS STREETER, SET NICET IV #102672 | DRAWING CODE: FA-ALL DRAWINGS CP/CS |

| |
|--|
| PROJECT ENGINEER: Integrat Design Associates INC. |
|--|

CENTER FOR SCIENCE AND MATHEMATICS
CALIFORNIA STATE POLYTECHNIC UNIVERSITY
 SAN LUIS OBISPO, CA

CSFM #18-05-0001

Appendix F

Smoke extraction calculations

$$Z = 27.5 \text{ m}$$

$$\dot{Q} = 1500 \text{ kW}$$

Zukoski

$$T_p = 5 * \left(\frac{\sqrt{T_\infty} \dot{Q}}{\sqrt{g} c_p \rho_\infty} \right)^{2/3} z^{-5/3} + T_\infty = 305.1 \text{ K}$$

$$\rho_p = \frac{\rho_\infty T_\infty}{T_p} = 1.196 \frac{\text{kg}}{\text{m}^3}$$

$$\dot{m}_p = 0.21 \left(\frac{\rho_\infty^2 g}{c_p T_\infty} \right)^{1/3} \dot{Q}^{1/3} z^{5/3} = 220.6 \frac{\text{kg}}{\text{s}}$$

$$\dot{V}_p = \frac{\dot{m}_p}{\rho_p} = \frac{220.6}{1.196} = 184.4 \frac{\text{m}^3}{\text{s}}$$

Heskestad

$$\dot{Q}_c = 0.7 * \dot{Q}$$

$$z_0 = 0.083 \dot{Q}^{2/5} - 1.02D = 0.53 \text{ m}$$

$$T_p = 9.1 * \left(\frac{\sqrt{T_\infty} \dot{Q}_c}{\sqrt{g} c_p \rho_\infty} \right)^{2/3} (z - z_0)^{-5/3} + T_\infty = 308.5 \text{ K}$$

$$\rho_p = \frac{\rho_\infty T_\infty}{T_p} = 1.183 \frac{\text{kg}}{\text{m}^3}$$

$$\dot{m}_p = 0.071 \dot{Q}_c^{1/3} (z - z_0)^{5/3} + 0.00192 \dot{Q}_c = 177.1 \frac{\text{kg}}{\text{s}}$$

$$\dot{V}_p = \frac{\dot{m}_p}{\rho_p} = \frac{177.1}{1.183} = 149.7 \frac{\text{m}^3}{\text{s}}$$

McCaffrey

$$T_p = 22.3 * \left(\frac{\dot{Q}^{2/5}}{z} \right)^{5/3} + T_\infty = 309.9 \text{ K}$$

$$\rho_p = \frac{\rho_\infty T_\infty}{T_p} = 1.178 \frac{\text{kg}}{\text{m}^3}$$

$$\dot{m}_p = 0.21 \left(\frac{\rho_\infty^2 g}{c_p T_\infty} \right)^{1/3} \dot{Q}^{1/3} z^{5/3} = 220.6 \frac{\text{kg}}{\text{s}}$$

$$\dot{V}_p = \frac{\dot{m}_p}{\rho_p} = \frac{220.6}{1.178} = 187.3 \frac{\text{m}^3}{\text{s}}$$