

Dynamic Study and PI Control of Milk Cooling Process

Rudy Agustriyanto^{a,*}, Endang Srihari Mochni^a

^a Department of Chemical Engineering, University of Surabaya, Jl. Raya Kalirungkut, Surabaya, 60293, Indonesia

Corresponding author: *rudy.agustriyanto@staff.ubaya.ac.id

Abstract—The background of this research is to understand the operation process, which is the main goal of developing the process model. This model is often used for operator training, process design, safety system analysis, or control system design. The dynamic model of the milk cooling process from 36°C to 4°C using chilled water available at 2°C was performed. Chilled water was maintained at a constant temperature by using a refrigerant unit. The process being investigated was a Packo brand milk cooling tank belonging to KUD SAE Pujon (Malang - Indonesia). A fundamental heat balance method was used to derive the model, leading to a first-order transfer function process. For a 2-hr cooling process, the gain and time constant values are 1.00 and 42.3548 mins, respectively. Heat balance was then extended to continuous processes so that its transfer function could also be obtained. This study simulated and investigated the behavior of batch and continuous processes. Process Identification via input-output data was also introduced for continuous process. The process model obtained from the system identification toolbox was very useful in control, such as for determining tuning parameters via the Ziegler-Nichol method for Proportional-Integral control. However, a small delay was required to be introduced to the system as the first order process without time Ziegler Nichol method cannot be implemented. Further research may include other system identification methods, such as ARX, ARMAX, Output-Error, Box Jenkins etc., or implementing advanced process control for milk cooling.

Keywords— Dynamic study; milk cooling; simulation; process control.

Manuscript received 24 Sep. 2021; revised 25 Jan. 2022; accepted 15 Feb. 2022. Date of publication 31 Oct. 2022.
IJASEIT is licensed under a Creative Commons Attribution-Share Alike 4.0 International License.



I. INTRODUCTION

Milk is a white liquid food rich in nutrients mammalian milk glands produce. This is the main source of nutrition for baby mammals, including humans, before they can digest other types of food [1]. Early lactation milk contains colostrum [2], which carries maternal antibodies to its young and can reduce the risk of many diseases [3]. It contains many other nutrients, including protein and lactose [4], [5]. Consumption of inter-species milk is common, particularly among humans, who consume other mammalian milk [6]. Milk is a good medium for the growth of microorganisms [7], especially pathogenic bacteria such as *Staphylococcus aureus*, *Escherichia coli*, and *Salmonella sp* [8], [9]. Microorganisms in raw milk can thrive if stored at room temperature [10], [11]. These microorganisms will be dangerous if consumed, so raw milk that has been milked must be stored at a certain temperature [12]. It aims to inhibit the growth of microorganisms that can reduce the quality of fresh milk.

Methods of milk collection differ across countries, and there is no single, universally applicable scheme. Milk is highly perishable due to bacterial activity, and therefore, it

must be collected and cooled soon to avoid damage due to deterioration and to maintain the standard. Since milk production is often remote from markets and treatment facilities, in Indonesia, the milk cooling center at *Koperasi Unit Desa* (KUD) provides the facilities to maintain quality through cooling and hygienic storage before further transportation to the milk factory [13].

The chilling of raw fresh milk to below 4 °C as soon as possible after milking and within two to four hours at the most - is recognized as the best way of maintaining standard and reducing milk damage. Therefore, it was done in Cooperatives (*Koperasi Unit Desa*) as a batch cooling process and this process is performed twice a day (in the morning and afternoon). However, in a milk factory, milk cooling is usually done in a continuous process. This cooler needs to be installed with a controller to ensure the temperature of the milk comes out 4 °C [14].

The main problem that often occurs in dairy factories is the operator's lack of understanding of the process, which creates difficulties in controlling the process or in designing appropriate equipment when needed. Therefore, this paper aims to present the dynamic model of the batch and steady-

state milk cooling process. The model in Laplace transform is important for controlling the process, and understanding the process operation is a major overall objective for developing a dynamic process model. This model is often used for operator training, process design, safety system analysis or design, or control system design.

Milk cooling is one of the largest consumers of electricity [15]–[17]; therefore, milk production is an exhaustive energy process. Milk cooling can be done in two steps: precooling using water and refrigerant cooling to 4°C. Cooling costs at a Milk Cooling Center can be decreased by precooling fresh warm milk using water from the main supply, surface, well, or groundwater. Precooling reduces the refrigeration burden and hence reduces energy needs and costs. When the temperature difference between the water and the fresh raw milk is significant, refrigeration costs can be reduced by up to 64 percent [13]. However, in tropical countries like Indonesia, we normally skip the first step since the water temperature and fresh raw milk are about the same. The energy required for milk cooling depends mainly on the efficiency of the cooling equipment and the temperature difference in milk between the initial and end of the process [15].

Chilled water can be used to cool the milk in the bulk tank cautiously. Water can be chilled using a chiller or ice bank equipment, which usually consists of an insulated water tank with an evaporator and a holding vessel. The water is chilled to approximately 2°C, and the milk is cooled to 4°C. Another method of chilling water is circulation through an ice bank. Ice builds up around the copper tubes in cylindrical formation. Water is circulated in a closed loop through the bulk tank and back to the ice bank [15]. When milk is stored above 30°C, it can spoil after 4 h, depending on its total bacteria count. Storing at 20°C, 10°C and 4°C can partially inhibit bacterial growth for the first 8, 16, and 24 h after milking, respectively [18].

Murphy et al. [15] studied feed forward and feedback controller for milk cooling system for two steps cooling (precooling and refrigerant cooling) and tuned using Ziegler Nichols ultimate gain method [19]. However, no information for the plant models was provided. Coughanowr and LeBlanc [19] presented a fundamental method for the obtain mercury thermometer's first-order transfer function. This paper adopted the method for derivation of batch milk cooling transfer function, which is similar in nature.

Investigations of waste heat recovery from bulk milk coolers [20] have also been conducted. Heat dissipated into the atmosphere through the condenser was recovered to improve the plant's energy efficiency. The waste heat can be utilized to heat the water which was used to clean the milk processing equipment. Another modeling work that focuses on an ice bank for milk cooling after milking has also been performed [21]. Agustriyanto et al. [22], [23] provided a transfer function model for continuous milk cooling, while this paper also derived a batch cooling system. Operators in dairy factories often do not understand the process that occurs, so they cannot control or design the equipment according to their needs. This is a major problem in dairy factories.

The models addressed in this paper were based on fundamental theories or laws, such as the conservation of energy [24]. Simulink was also used to simulate the model. Simulink is a block diagram environment for multi-domain

simulation and Model-Based Design. It supports system-level design, simulation, automatic code generation, and continuous test and verification of embedded systems. Simulink provides a graphical editor, customizable block libraries, and solvers for modelling and simulating dynamic systems. It is integrated with MATLAB, enabling us to incorporate MATLAB algorithms into models and export simulation results to MATLAB for further analysis. Therefore, it is easier for us to generate and analyze the data.

II. MATERIALS AND METHOD

This section describes the method for mathematical modeling of batch and continuous milk cooling process and Proportional Integral (PI) control of continuous milk cooling because this study was a simulation. However, Pujon Malang's survey was conducted to collect equipment data at KUD SAE.

A. Mathematical Method for Batch Process

The system being studied was the milk cooling facilities belonging to KUD SAE Pujon, as shown in Figure 1. It is a rectangular milk cooling tank with a half-cylinder tank contained therein. A rectangular tank is a place for cooling water, while a half-cylinder tank is a container for milk. The scheme of the milk cooling tank is shown in Figure 2. Table 1 shows batch and parameter data for simulation.

The tank capacity (V) is 2500 L. Therefore, the mass of milk in the tank can be calculated since the milk density is known. The volume of chilled water is unknown, but its temperature is kept constant at 2°C (T_1) by using refrigerant.



Fig. 1 Packo milk cooling tank (courtesy of Koperasi SAE Pujon).

If we set the cooling time equal to 2 hours, then the total heat that must be released from milk to cooling water can be calculated as follows:

$$Q = m \cdot C_p \cdot \Delta T \quad (1)$$

$$Q = 2567.5 \times 3.93 \times (36 - 4)$$

$$Q = 322,888.8 \text{ kJ}/2h$$

$$Q = 2690.74 \text{ kJ}/h$$




Fig. 2 Stirred milk cooling tank system seen for the side (courtesy of koperasi sae pujon)

TABLE I
BATCH AND PARAMETER DATA

Symbol	Description	Values	Units
V	Tank volume	2500	L
T_i	Temperature of inlet milk	36	°C
T_o	Temperature of milk inside the tank	4	°C
T_1	Temperature of chilled water	2	°C
C_p	Heat capacity of milk	3.93	kJ/kg.K
ρ	Density of milk	1027	kg/m ³
m	Mass of milk in the tank	2567.5	kg
U	Overall heat transfer coefficient	274.4613	kJ/min.m ² .°C
A	Surface area of milk cooling tank	0.8680	m ²
Q	Heat released from milk to cooling water	2690.74	kJ/min

Heat transfer area (A) is the area of half cylinder can be calculated mathematically, where:

$$r = 0.3485 \text{ m and } t = 1.238 \text{ m,}$$

$$A = \frac{1}{2} \pi r(r + t) = 0.8680 \text{ m}^2 \quad (2)$$

Log mean temperature different (LMTD) for parallel flow then can be calculated [25], [26], [27], [28] :

$$\Delta T_{LMTD} = \frac{\Delta T_2 - \Delta T_1}{\ln\left(\frac{\Delta T_2}{\Delta T_1}\right)} \quad (3)$$

$$\Delta T_{LMTD} = \frac{(36-2)-(4-2)}{\ln\left(\frac{36-2}{4-2}\right)} = 11.2946$$

Since:

$$Q = U \cdot A \cdot \Delta T_{LMTD} \quad (4)$$

Then:

$$U = 274.4613 \frac{\text{kJ}}{\text{min}} \cdot \text{m}^2 \cdot \text{°C} \quad (5)$$

Batch milk cooling process can be modelled based on energy balance as follows[19]:

Unsteady state energy balance:

$$Q_{in} - Q_{out} = \text{Accumulation} \quad (6)$$

When $Q_{in} = 0$, then:

$$0 = U \cdot A \cdot \Delta T = \frac{dQ}{dt}$$

$$-U \cdot A \cdot (T_o - T_1) = m \cdot C_p \cdot \frac{dT_o}{dt}$$

$$U \cdot A \cdot (T_1 - T_o) = m \cdot C_p \cdot \frac{dT_o}{dt} \quad (7)$$

Steady state energy balance:

$$U \cdot A \cdot (T_{1s} - T_{os}) = 0 \quad (8)$$

Equation (7)-(8):

$$U \cdot A \cdot (T_1 - T_{1s}) - (T_o - T_{os}) = m \cdot C_p \cdot \frac{dT_o}{dt} \quad (9)$$

Taking Laplace Transform of both sides in Equation (9):

$$UA(T_1(s) - T_o(s)) = mC_p(sT_o(s) - T_o(0)) \quad (10)$$

When $T_o(0)=0$, then:

$$UA(T_1(s) - T_o(s)) = mC_p s T_o(s)$$

$$\frac{T_o(s)}{T_1(s)} = \frac{1}{\frac{mC_p s}{UA} + 1} \quad (11)$$

The resulting Equation (11) is a first order process transfer function [22] [29]with:

$$\text{Gain} = K_p = 1 \quad (12)$$

$$\text{Time constant} = \tau_p = \frac{mC_p}{UA} \quad (13)$$

Hence:

$$\frac{T_o(s)}{T_1(s)} = \frac{1}{42.3548s+1} \quad (14)$$

B. Mathematical Method for Continuous Process

The same tank was then operated continuously. It was assumed that the volume of milk or the mass of milk in the tank was constant so that the mass balance could be neglected. Table 2 shows the parameters at steady state conditions used in the mathematical model equation.

TABLE II
STEADY STATE CONTINUOUS DATA

Symbol	Description	Values	Units
ws	Flow rate of inlet milk	85.6	kg/min
m	Mass of milk inside the tank	2567.5	kg
$T_{o,s}$	Temperature of outlet milk	4	°C
$T_{i,s}$	Temperature of inlet milk	36	°C
Q	Heat released (from milk to chilled water)	83397.05	kJ/min

Standard procedure could be applied to the continuous system to derive Laplace Transfer Function [22], [23]. The results are as follows:

$$T_o(s) = \frac{T_i(s)}{\left(\frac{m}{w_s} s + 1\right)} - \frac{\frac{Q(s)}{w_s C_p}}{\left(\frac{m}{w_s} s + 1\right)} - \frac{(T_{o,s} - T_{i,s}) \cdot W(s)}{\left(\frac{m}{w_s} s + 1\right)} \quad (15)$$

or:

$$T_o(s) = \frac{1}{(\tau \cdot s + 1)} T_i(s) - \frac{K_1}{(\tau \cdot s + 1)} Q(s) - \frac{K_2}{(\tau \cdot s + 1)} W(s) \quad (16)$$

where:

$$K_1 = \frac{1}{w_s \cdot c_p}$$

$$K_2 = \frac{(T_{o,s} - T_{i,s})}{w_s}$$

$$\tau = \frac{m}{w_s}$$

Therefore:

$$T_o(s) = \frac{1}{(30 \cdot s + 1)} T_i(s) - \frac{0,002973}{(30 \cdot s + 1)} Q(s) + \frac{0,37390}{(30 \cdot s + 1)} W(s) \quad (17)$$

C. Proportional-Integral Control of Continuous Milk Cooling

The system and block diagram for closed loop systems are shown in Figures 3 and 4. For simplicity, the Ziegler-Nichol tuning method would be used. Ziegler Nichol formula for Proportional-Integral controller are as follows [19], [30], [31], [32].

$$K_c = 0.45 K_u \quad (18)$$

$$\tau_I = P_u / 1.2 \quad (19)$$




Fig. 3 Continuous milk cooling system controlled by PI controller




Fig. 4 Block diagram of continuous milk cooling system with PI controller [33]

The ultimate period, P_u , is defined as the period of sustained cycling that would occur if a proportional controller with gain K_u were used. K_u and P_u were easily determined from the Bode diagram [34], [35] ω_{co} is cross-over frequency [36].

$$P_u = \frac{2\pi}{\omega_{co}} \quad (20)$$

III. RESULTS AND DISCUSSION

A. Dynamic Study of Batch Process

The milk cooling process in Cooperatives (Koperasi Unit Desa) is generally carried out as a batch process. The batch process only depends on time. When the milk temperature has reached the expected, then the milk is released. Assuming that the overall heat transfer coefficient (U) is constant, the result of the mathematical model is shown in Equation 14.

From the mathematical model of the batch system above, the simulation results are shown in Figure 5. Based on Figure 5, it can be seen that the batch system only affects cooling time. The milk temperature comes in at 36°C and the temperature reaches 4°C with a cooling time of 120 minutes.




Fig. 5 Milk temperature profile

Since the gain is 1 while the time constant is 42.3548 minutes, the process will reach 2°C at about more than 4 times the time constant [21]. The time constant is the time required for the first-order process to reach 63.2% to the new steady state value when a step disturbance is given to the input variable [19], [37].

Now, suppose that cooling water temperature varies as shown in Figure 6. The milk temperature profile in the tank can be investigated and shown in Figure 7. Various results for different cooling water temperatures can also be obtained easily using Simulink.




Fig. 6 Temperature profile of inlet chilled water




Fig. 7 Temperature profile of milk inside the tank

B. Dynamic Study of Continuous Process

The mathematical model in Equation 17 was simulated in Simulink to obtain the input-output data. The input and output results were then identified using the System Identification Toolbox (SIT) in Matlab. Suppose we did not derive Equation (17), but using the input-output data collected directly from the plant (or, in this study, simulated using Equation 17), we still can identify the system transfer function [38].

The transfer function obtained via System Identification Toolbox are as follows:

$$T_o(s) = \frac{0.978}{(29.011s + 1)} T_i(s) - \frac{0,002868}{(28.524s + 1)} Q(s) + \frac{0,3627}{(28.742s + 1)} W(s) \quad (18)$$

It can be seen that Equations (18) and (17) are comparable and not much different. Matlab System Identification Toolbox also provides other methods such as Output-Error, ARX, Box-Jenkins etc [39], [40], [41], [42]. Figure 8, 9, and 10 show simulation results for the original model (Equation 17) and the model identified from System Identification Toolbox – SIT (Equation 18). Those perturbations were given for T_i , Q , and W , respectively.




Fig. 8 Comparison of output between original model and SIT with T_i perturbation




Fig. 9 Comparison of output between original model and SIT with Q perturbation




Fig. 10 Comparison of output between the original model and SIT with W perturbation

C. Proportional-Integral Control of Continuous Process

Proportional Integral controller settings using the Ziegler-Nichol tuning method are shown in Table 3. Here we assumed several values of time delay since the process itself is a first-order process without time delay, and Cross-over frequency cannot be determined for a first-order process without time delay. Therefore, a small value of time delay should be added to the process so that we can have cross-over frequency, ultimate gain and ultimate period.

The Bode Diagram was used in this method to calculate K_i and τ_i . The following is an example of a calculation assuming Time Delay = 1 min.

$$\frac{T_o(s)}{Q(s)} = -\frac{0,002868}{(28.524s+1)} e^{-s} \quad (19)$$

From the Bode diagram (Figure 11), the cross-over frequency value was 3.283 rad/time, and the magnitude was 0.00003061 abs, so that the ultimate gain (K_u) and ultimate period (P_u) could be determined:

$$K_u = 32669,0624$$

$$P_u = 1,9129$$




Fig. 11 Bode diagram

Figure 12,13,14 shows the output profile (T_o) and its set point for using the assumption of time delay from 1, 2, and 3 mins, respectively. It can be seen that the higher the time delay assumption, the greater the error will be.

TABLE III
PI CONTROLLER SETTING BASED ON THE ZIEGLER-NICHOL METHOD

Time Delay (min)	K_c	τ_I
1	-14701	1.59
2	-8929	2.62
3	-7047	3.32
4	-5291	4.43
5	-4253	5.51




Fig. 12 Output profile and setpoint for 1 min time delay




Fig. 13 Output profile and setpoint for 2 min time delay




Fig. 14 Output profile and setpoint for 3 min time delay

Figure 15 and 16 show profile of output for regulatory problem (disturbance rejection) for controller setting using 4- and 5-mins assumption. Again, it can be seen that the smaller the time delay assumption the better.




Fig. 15 Output profile (T_o) and its setpoint for 4 min time delay with changes in temperature of inlet milk (T_i)




Fig. 16 Output profile (T_o) and its setpoint for 5 min time delay with changes in temperature of inlet milk (T_i)

IV. CONCLUSION

The dynamic model of the batch milk cooling process has been derived and simulated using Simulink. The overall heat transfer coefficient (U) was assumed constant and could be calculated as the batch process finished in 2 hours. The milk temperature profile shows reasonable dynamics during the process. The dynamic model of continuous milk cooling has also been presented. Suppose we did not derive Equation (17), but we can still identify the system transfer function g the input-output data collected directly from the plant (or, in this study, simulated using Equation 17). Several methods for system identification are provided in MATLAB. These include transfer function models, state space models, polynomial models (i.e., ARX, ARMAX, Output-Error, Box Jenkins) etc. Those models can be converted to Laplace Transfer Function easily. The system identification can be applied for the continuous system and the batch milk cooling process. The mathematical model is particularly useful for control purposes. Here we demonstrated Proportional-Integral control of the continuous milk cooling process, i.e., using the Ziegler-Nichol tuning method for determining controller parameters. Also, we introduced a small-time delay to the system to simplify the tuning process. Other tuning methods are also available such as Tyreus-Luybean,

Hagglund-Astrom, Ciancone, Direct Synthesis etc. [43], [44], [45]. Further research may include system identification for different sizes of equipment or different type of cooling processes, and advanced control strategies for the milk cooling process.

ACKNOWLEDGMENT

The authors are grateful to the Chemical Engineering Department, University of Surabaya, and Koperasi Unit Desa (KUD) SAE Pujon Malang.

REFERENCES

- [1] P. D. Edwards *et al.*, "Maternal effects in mammals: Broadening our understanding of offspring programming," *Frontiers in Neuroendocrinology*, vol. 62, p. 100924, Jul. 2021, doi: 10.1016/J.YFRNE.2021.100924.
- [2] A. Valdecabres and N. Silva-del-Río, "First-milking colostrum mineral concentrations and yields: Comparison to second milking and associations with serum mineral concentrations, parity, and yield in multiparous Jersey cows," *Journal of Dairy Science*, Jan. 2022, doi: 10.3168/JDS.2021-21069.
- [3] T. F. O'Callaghan *et al.*, "The bovine colostrum and milk metabolome at the onset of lactation as determined by ¹H-NMR," *International Dairy Journal*, vol. 113, p. 104881, Feb. 2021, doi: 10.1016/J.IDAIRYJ.2020.104881.
- [4] P. D. Edwards *et al.*, "Maternal effects in mammals: Broadening our understanding of offspring programming," *Frontiers in Neuroendocrinology*, vol. 62, p. 100924, Jul. 2021, doi: 10.1016/J.YFRNE.2021.100924.
- [5] R. Jongeneel and A. R. Gonzalez-Martinez, "The role of market drivers in explaining the EU milk supply after the milk quota abolition," *Economic Analysis and Policy*, Dec. 2021, doi: 10.1016/J.EAP.2021.11.020.
- [6] A. O. da Camara, L. G. Rodrigues, T. da S. Ferreira, and O. M. G. de Moraes, "Sodium found in processed cow milk and estimated intake by infants," *Jornal de Pediatria*, vol. 97, no. 6, pp. 665–669, Nov. 2021, doi: 10.1016/J.JPED.2021.02.003.
- [7] N. N. Nasralla *et al.*, "Compositional characteristics of dairy products and their potential nondairy applications after shelf-life," *Current Research in Food Science*, vol. 5, pp. 150–156, Jan. 2022, doi: 10.1016/J.CRFS.2021.12.017.
- [8] D. Lindsay, R. Robertson, R. Fraser, S. Engstrom, and K. Jordan, "Heat induced inactivation of microorganisms in milk and dairy products," *International Dairy Journal*, vol. 121, p. 105096, Oct. 2021, doi: 10.1016/J.IDAIRYJ.2021.105096.
- [9] X. Yang *et al.*, "The complex community structures and seasonal variations of psychrotrophic bacteria in raw milk in Heilongjiang Province, China," *LWT*, vol. 134, p. 110218, Dec. 2020, doi: 10.1016/J.LWT.2020.110218.
- [10] J. B. Ndahetuye *et al.*, "MILK Symposium review: Microbiological quality and safety of milk from farm to milk collection centers in Rwanda," *Journal of Dairy Science*, vol. 103, no. 11, pp. 9730–9739, Nov. 2020, doi: 10.3168/JDS.2020-18302.
- [11] D. Annie Rose Nirmala, S. Ramaswamy, K. Logesh, and S. Joe Patrick Gnanaraj, "Empirical study on risk mitigation for dairy supply chain management of Aavin Co-operative Milk Producers' Union Ltd.," *Materials Today: Proceedings*, vol. 49, pp. 3657–3660, Jan. 2022, doi: 10.1016/J.MATPR.2021.09.243.
- [12] K. A. Zacharski, N. Burke, C. C. Adley, P. Hogan, A. Ryan, and M. Southern, "Milk reception in a time-efficient manner: A case from the dairy processing plant," *Food Control*, vol. 124, p. 107939, Jun. 2021, doi: 10.1016/J.FOODCONT.2021.107939.
- [13] F. Moffat, S. Khanal, A. Bennet, T. B. Thapa, and S. M. George, *Technical and Investment Guidelines for Milk Cooling Centers*. Rome: Food and Agriculture Organization of the United Nations, 2016.
- [14] R. Al-Shannaq, A. Auckailli, and M. Farid, "Cooling of milk on dairy farms: an application of a novel ice encapsulated storage system in New Zealand," *Food Engineering Innovations Across the Food Supply Chain*, pp. 207–228, Jan. 2022, doi: 10.1016/B978-0-12-821292-9.00006-6.
- [15] M. D. Murphy, J. Upton, and M. J. O'Mahony, "Rapid milk cooling control with varying water and energy consumption," *Biosystems Engineering*, vol. 116, pp. 15–22, 2013.
- [16] P. Shine, J. Upton, P. Sefeedpari, and M. D. Murphy, "Energy consumption on dairy farms: A review of monitoring, prediction modelling, and analyses," *Energies*, vol. 13, no. 5. MDPI AG, Mar. 01, 2020, doi: 10.3390/en13051288.
- [17] P. Shine, T. Scully, J. Upton, L. Shalloo, and M. D. Murphy, "Electricity & direct water consumption on Irish pasture based dairy farms: A statistical analysis," *Applied Energy*, vol. 210, pp. 529–537, Jan. 2018, doi: 10.1016/j.apenergy.2017.07.029.
- [18] J. Upton, M. Murphy, P. French, and P. Dillon, "Dairy farm energy consumption," 2010.
- [19] D. R. Coughanowr and S. E. LeBlanc, *Process Systems Analysis and Control*, 3rd ed. McGraw-Hill, 2009.
- [20] S. N. Sapali, S. M. Pise, A. T. Pise, and D. V. Ghewade, "Investigations of waste heat recovery from bulk milk cooler," *Case Studies in Thermal Engineering*, vol. 4, pp. 136–143, 2014.
- [21] R. A. Jordan, L. A. B. Cortez, V. Silveira Jr, M. E. R. M. Cavalcantimata, and F. D. de Oliveira, "Modeling and testing of an ice bank for milk cooling after milking," *Journal of the Brazilian Association of Agricultural Engineering*, vol. 38, no. 4, pp. 510–517, 2018.
- [22] R. Agustriyanto, A. Febriyanto, and P. S. Widiawati, "Perbandingan kinerja penetelan Hagglund-Astorn dan Tyreus Luyben pada sistem kendali pendinginan susu," *Jurnal Rekayasa Proses*, vol. 12, no. 2, pp. 10–18, 2018.
- [23] R. Agustriyanto, "Regulatory performance of two different tuning methods for milk cooling control system," *IOP Conf. Series: Materials Science and Engineering*, vol. 703, 2019.
- [24] X. Dong, Y. Yu, Z. Zhang, and X. Huang, "Mathematical analysis of heat balance model for the bubble growth in the subcooled boiling flow," *Case Studies in Thermal Engineering*, vol. 28, p. 101630, Dec. 2021, doi: 10.1016/J.CSITE.2021.101630.
- [25] D. Vinoth Kumar, S. Vijayaraghavan, and P. Thakur, "Analytical and experimental investigation on heat transfer and flow parameters of Multichannel louvered fin cross flow heat exchanger using iterative LMTD and ϵ -NTU method," *Materials Today: Proceedings*, Nov. 2021, doi: 10.1016/J.MATPR.2021.11.045.
- [26] X. Cui, K. J. Chua, M. R. Islam, and W. M. Yang, "Fundamental formulation of a modified LMTD method to study indirect evaporative heat exchangers," *Energy Conversion and Management*, vol. 88, pp. 372–381, Dec. 2014, doi: 10.1016/J.ENCONMAN.2014.08.056.
- [27] K. L. Wong, M. T. Ke, and S. S. Ku, "The log mean heat transfer rate method of heat exchanger considering the influence of heat radiation," *Energy Conversion and Management*, vol. 50, no. 11, pp. 2693–2698, Nov. 2009, doi: 10.1016/J.ENCONMAN.2009.05.024.
- [28] M. Mistry and R. Misener, "Optimising heat exchanger network synthesis using convexity properties of the logarithmic mean temperature difference," *Computers & Chemical Engineering*, vol. 94, pp. 1–17, Nov. 2016, doi: 10.1016/J.COMPCHEMENG.2016.07.001.
- [29] H. Fatoorehchi and R. Rach, "A method for inverting the Laplace transforms of two classes of rational transfer functions in control engineering," *Alexandria Engineering Journal*, vol. 59, no. 6, pp. 4879–4887, Dec. 2020, doi: 10.1016/J.AEJ.2020.08.052.
- [30] J. Fišer and P. Zitek, "PID Controller Tuning via Dominant Pole Placement in Comparison with Ziegler-Nichols Tuning," *IFAC-PapersOnLine*, vol. 52, no. 18, pp. 43–48, Jan. 2019, doi: 10.1016/J.IFACOL.2019.12.204.
- [31] K. H. Tseng, M. Y. Chung, C. Y. Chang, C. L. Hsieh, and Y. K. Tseng, "Parameter optimization of nanosilver colloid prepared by electrical spark discharge method using Ziegler-Nichols method," *Journal of Physics and Chemistry of Solids*, vol. 148, p. 109650, Jan. 2021, doi: 10.1016/J.JPCS.2020.109650.
- [32] M. Nikolaou, "Ziegler and Nichols meet Kermack and McKendrick: Parsimony in dynamic models for epidemiology," *Computers & Chemical Engineering*, vol. 157, p. 107615, Jan. 2022, doi: 10.1016/J.COMPCHEMENG.2021.107615.
- [33] Y. Chen, H. Yan, Y. Luo, and H. Yang, "A proportional–integral (PI) law based variable speed technology for temperature control in indirect evaporative cooling system," *Applied Energy*, vol. 251, p. 113390, Oct. 2019, doi: 10.1016/J.APENERGY.2019.113390.
- [34] B. Şenol, U. Demiroğlu, and R. Matušů, "Fractional order proportional derivative control for time delay plant of the second order: The frequency frame," *Journal of the Franklin Institute*, vol. 357, no. 12, pp. 7944–7961, Aug. 2020, doi: 10.1016/J.JFRANKLIN.2020.06.016.
- [35] A. Atangana and A. Akgül, "Can transfer function and Bode diagram be obtained from Sumudu transform," *Alexandria Engineering Journal*, vol. 59, no. 4, pp. 1971–1984, Aug. 2020, doi: 10.1016/J.AEJ.2019.12.028.

- [36] P. P. Arya and S. Chakrabarty, "A Modified IMC Structure to Independently Select Phase Margin and Gain Cross-over Frequency Criteria," *IFAC-PapersOnLine*, vol. 51, no. 1, pp. 267–272, Jan. 2018, doi: 10.1016/J.IFACOL.2018.05.066.
- [37] P. Neyezhnikov and I. Zakharov, "Determination of the time constant of measuring transducers," *Measurement: Sensors*, vol. 18, p. 100278, Dec. 2021, doi: 10.1016/J.MEASEN.2021.100278.
- [38] G. Picci, W. Cao, and A. Lindquist, "Modeling and Identification of Low Rank Vector Processes," *IFAC-PapersOnLine*, vol. 54, no. 7, pp. 631–636, Jan. 2021, doi: 10.1016/J.IFACOL.2021.08.431.
- [39] B. Roffel and B. Betlem, *Process Dynamics and Control: Modeling for Control and Prediction*. West Sussex: John Wiley & Sons Ltd, 2006.
- [40] L. Cheng, A. Cigada, Z. Lang, E. Zappa, and Y. Zhu, "An output-only ARX model-based sensor fusion framework on structural dynamic measurements using distributed optical fiber sensors and fiber Bragg grating sensors," *Mechanical Systems and Signal Processing*, vol. 152, p. 107439, May 2021, doi: 10.1016/J.YMSSP.2020.107439.
- [41] L. Li, H. Zhang, X. Ren, and J. Zhang, "A novel recursive learning identification scheme for Box–Jenkins model based on error data," *Applied Mathematical Modelling*, vol. 90, pp. 200–216, Feb. 2021, doi: 10.1016/J.APM.2020.08.076.
- [42] Y. Cao, Z. Wang, S. Hu, and W. Wang, "Modeling of weld penetration control system in GMAW-P using NARMAX methods," *Journal of Manufacturing Processes*, vol. 65, pp. 512–524, May 2021, doi: 10.1016/J.JMAPRO.2021.03.039.
- [43] Shahrokhi, Mohammad, Zomorodi, and Alireza, "Comparison of PID controller tuning methods," Tehran, 2018.
- [44] T. Anitha and G. Gopu, "Controlled mechanical ventilation for enhanced measurement in pressure and flow sensors," *Measurement: Sensors*, vol. 16, p. 100054, Aug. 2021, doi: 10.1016/J.MEASEN.2021.100054.
- [45] A. Basu, S. Mohanty, and R. Sharma, "Introduction of fractional elements for improvising the performance of PID controller for heating furnace using AMIGO tuning technique," *Perspectives in Science*, vol. 8, pp. 323–326, Sep. 2016, doi: 10.1016/J.PISC.2016.04.065.

International Journal on Advanced Science Engineering Information Technology

Available online at
<http://ijaseit.insightsociety.org>

Advanced Science Image processing Image retrieval microprocessor
Back Projection fuzzy Engineering alumina Gait analysis Biometric
Mobile Agent Interpolation Soft Tissue hydrothermal stability Outlier filter
Sampling Theorem Magnetic field porous structure acidity Wireless
Parsimony Database Server Robot Operation Image extraction
Graphical User Interface Virus Compressive Strength Life Cycle Cost
Current shaping Phylogenetic Analysis Sensor Networks Energy Saving
Metamorphic Virus neural network Predictive Tools Energy Optimization
parallel port Obfuscation Techniques Admixture Router Image matching
Power factor Boost regulator catalyst Construction Delay Support Vector Machine Regression Analysis
breast phantom Effects of Delay Current harmonics Surveillance
Information Technology soybean



Wednesday, 26 October 2022

ISSN: 2088-5334

International Journal on Advanced Science Engineering Information Technology

[HOME](#) [ARCHIVES](#)

Editorial Team

Editor in Chief :

Rahmat Hidayat, (Scopus ID: 57191265401) Politeknik Negeri Padang, INDONESIA

Associate Editors :

Taufik, (Scopus ID: 23670809800), California Polytechnic State University, USA
 Haitham Alali, (Scopus ID: 49963007000), Amman Arab University, JORDAN
 Wan Mohtar Wan Yusoff, (Scopus ID: 15019967700), Univ. Kebangsaan Malaysia, MALAYSIA
 Halimah Badioze Zaman, (Scopus ID: 25825801600), Univ. Kebangsaan Malaysia, MALAYSIA
 Son Radu, (Scopus ID: 7005251005), Universiti Putra Malaysia, Malaysia, MALAYSIA
 Mohd Razi Ismail, (Scopus ID: 25957691400), Universiti Putra Malaysia, MALAYSIA
 Takashi Oku, (Scopus ID: 56275094900), Prefectural University of Hiroshima, JAPAN
 Kohei Nakano, (Scopus ID: 7402011766), Gifu University, JAPAN
 Nurul Huda, (Scopus ID: 6701695514), Universiti Malaysia Sabah, MALAYSIA
 Yandra Arkeman, (Scopus ID: 55946558300), Bogor Agriculture University, INDONESIA
 Sate Sampattagul, (Scopus ID: 7801640861), Chiangmai University, THAILAND
 Peeyush Soni, (Scopus ID: 9248907800), Asian Institute of Technology, THAILAND
 Yolanda Lechon Perez, (Scopus ID: 6602826000), Ciemat, Madrid, SPAIN
 Gabriele Arcidiacono (Scopus ID: 56656284600), G. Marconi University, ITALY
 Alessandra Pieroni (Scopus ID: 25929524500), Marconi International University, Florida - USA
 Alessandro Simonetta (Scopus ID: 55344403700), University of Rome Tor Vergata, ITALY
 Rita Muhamad Awang, (Scopus ID: 55957782400), Universiti Putra Malaysia, MALAYSIA
 Anton S Prabuwo, (Scopus ID: 18134309800), King Abdulaziz Univ, SAUDI ARABIA
 P Mangala C S De Silva, (Scopus ID: 7006461145), University of Ruhuna, SRI LANKA
 Bich Huy Nguyen, (Scopus ID: 36191086100), Nong Lam University, VIETNAM
 Paul Kristiansen, (Scopus ID: 23097563600), University of New England, AUSTRALIA
 Amitava Basu, (Scopus ID: 21833738300), Bidhan Chandra Krishi Vidyalyaya, INDIA
 Shahrul Azman Mohd Noah, (Scopus ID: 35087633200), Universiti Kebangsaan Malaysia, MALAYSIA
 Luca Di Nunzio (Scopus ID: 57195199010), University of Rome Tor Vergata, ITALY
 Rocco Fazzolari (Scopus ID: 36469997900), University of Rome Tor Vergata, ITALY
 Ruben Paul Borg (Scopus ID: 55246483600), L-Università ta' Malta, Msida, Malta
 Van Viet Pham (Scopus ID: 57200413784), Ho Chi Minh City University of Transport, VIETNAM

Editors :

Nurhamidah, (Scopus ID: 57191636504), Andalas University, INDONESIA
 Ario Betha Juansiferro, (Scopus ID: 57189369470), Kobe University, JAPAN
 Zairi Ismael Rizman, (Scopus ID: 36959761800), Universiti Teknologi MARA (UiTM) (Terengganu) MALAYSIA
 Shahreen Kasim, (Scopus ID: 36155431900), Universiti Tun Hussein Onn - MALAYSIA
 Chi-Hua Chen, (Scopus ID: 35799698800), National Chiao Tung University, TAIWAN
 Abrar Ismardi, (Scopus ID: 26633102900), Telkom University - INDONESIA

IJASEIT

[About](#)

[Editorial Board](#)

[Guide for Authors](#)

[Journal Contact](#)

[Online Submission](#)

[Peer Review Policy](#)


[Publication Ethics](#)

[Browse Authors](#)

[NEW Update : IJASEIT in Scopus](#)

[NEW Update : IJASEIT in Scimago JR](#)

Scopus CiteScore



Scimago Journal Rank



Template of Journal IJASEIT

Support Contact

WAG : +62-82171-822448
E-mail : ijaseit@insightsociety.org

The Map Authors

Vol. 12 (2022) No. 5

Articles in Press (articles that have been accepted for publication but which have not been formally published and not yet have the complete volume, issue, page information, and DOI) that include errors, or are discovered to be accidental duplicates of other published article(s), or are determined to violate our journal publishing ethics guidelines in the view of the editors.

Articles

Morphological in situ Characterization of Mortiño (*Vaccinium floribundum* Kunth) in the Andes of Ecuador

Wilson Vásquez-Castillo, Kerly Ayala, Marcelo Almeida, Alejandro F. Barrientos-Priego, Pablo Moncayo-Moncayo, Álvaro Monteros-Altamirano

pages: 1714-1720 [Full text](#) DOI:10.18517/ijaseit.12.5.15157

Leaf Characterizations of IRR 400 Series, BPM 24, and RRIC 100 Rubber (*Hevea brasiliensis* Muell. Arg.) Clone Using Leafgram Method

Syarifah Aini Pasaribu, Mohammad Basyuni, Edison Purba, Yaya Hasanah

pages: 1721-1727 [Full text](#) DOI:10.18517/ijaseit.12.5.15512

Evaluation of Antibacterial Activity, Total Phenolic and Flavonoid Contents of Extracts of Endophytic Fungi Associated with *Tinospora crispa* (L.) Hook. f. & Thomson

Ahmad Fathoni, Sumi Hudiyo, Emil Budianto, Antonius Herry Cahyana, Muhammad Ilyas, Andria Agusta

pages: 1728-1735 [Full text](#) DOI:10.18517/ijaseit.12.5.14816

Potential Use of Cross-flow Microfiltration System in Separation of Functional Compound from Fermented Beetroot (*Beta vulgaris* L.) as Natural Oxidation Prevention

Agustine Susilowati, - Aspiyanto, Yati Maryati, Hakiki Melanie

pages: 1736-1743 [Full text](#) DOI:10.18517/ijaseit.12.5.13750

Mangroves and the Sustainability of Longtail Shad Fish (*Tenualosa macroura*) in Riau Province Water, Indonesia

Vivin Seygita, - Sulistiono, Cecep Kusmana, Gatot Yulianto

pages: 1744-1755 [Full text](#) DOI:10.18517/ijaseit.12.5.17421

Double Production of Shallot (*Allium cepa* L var. *aggregatum*) based on Climate, Water, and Soil Management in Sandy Land

- Sutardi, Joko Pramono, Sugeng Widodo, Tri Martini, Annisa Dhiener Alifia, Yayan Apriyana, Popi Rejekiningrum, Nanik Setyowati, Hano Hanafi

pages: 1756-1767 [Full text](#) DOI:10.18517/ijaseit.12.5.14698

The Behavior of Shallot Farmer Using Pesticides in Lembah Gumanti District, Solok Regency, Indonesia

- Elfianto, Rahmat Syahni, - Asmawi, - Ifdal

pages: 1768-1774 [Full text](#) DOI:10.18517/ijaseit.12.5.17161

Protein Isolate of Jack Bean Tempeh (*Canavalia ensiformis*) by Spray Drying Method with Variation of Inlet Temperature

Vira Putri Yarlina, Muhamad Rizki Ramdani, - Zaida, Nandi Sukri, Mohammad Djali, Robi Andoyo, Mohd Nizam Lani

pages: 1775-1780 [Full text](#) DOI:10.18517/ijaseit.12.5.16228

The Development of Polymeric Composite Membrane Containing Plant Waste Derived Activated Carbon and TiO₂ for Raw Petroleum Refinery Wastewater Treatment

- Marhaini, Sri Martini, Khairil Insani, Endang Supraptiah

pages: 1781-1787 [Full text](#) DOI:10.18517/ijaseit.12.5.14508

Discriminating Geographical Origin of Cashew Nuts Based on the Combination of Multi-elements and Chemical Component Analysis

Rahmat Setiyono, Anggoro C. Sukartiko, Wahyu Supartono

pages: 1788-1796 [Full text](#) DOI:10.18517/ijaseit.12.5.14099

Rhizopora apiculata (Blume) Density, NDVI, and Utilization by Fishermen Community in Muara Angke Wildlife Reserve, Penjaringan District, Jakarta, Indonesia

Noverita Dian Takarina, Agung Suwanto, Raldi H Koestoer, Evi Frimawaty

pages: 1797-1804 [Full text](#) DOI:10.18517/ijaseit.12.5.15575

Yield and Quality Extract of *Clitoria ternatea* Accessions with Different Drying Methods

- Kusumiyati, Nita Yuniati, Yusuf Eka Maulana, Agung Karuniawan

pages: 1805-1811 [Full text](#) DOI:10.18517/ijaseit.12.5.14552

Performance of Soybean Genotypes in the Acidic Dryland and Wetland

IJASEIT

About

Editorial Board

Guide for Authors

Journal Contact

Online Submission

Peer Review Policy


Publication Ethics

Browse Authors

NEW Update : IJASEIT in Scopus

NEW Update : IJASEIT in Scimago JR

Scopus CiteScore



Scimago Journal Rank



Template of Journal IJASEIT

Support Contact

WAG : +62-82171-822448

E-mail : ijaseit@insightsociety.org

The Map Authors

M. Muchlish Adie, Yuliantoro Baliadi, Eriyanto Yusnawan, Andy Wijanarko, Ayda Krisnawati
pages: 1812-1817 [Full text](#) DOI:10.18517/ijaseit.12.5.12720

Characteristics of Carbonate Facies and Depositional Environment of Tapak Formation in the Ajibarang Area, Central Java, Indonesia

Published by INSIGHT - Indonesian Society for Knowledge and Human Development
- Praptisih, Purna Sulastya Putra, Septrio HASEIT, ISSN: 2088-5334 | e-ISSN : 2460-6952 | DOI : 10.18517
pages: 1818-1823 [Full text](#) DOI:10.18517/ijaseit.12.5.13290

Performance and Prospects of Mobile Rice Mill Unit

[01169372](#) [View My Stats](#)
Agus Haryanto, Septa Prasetya Adi, Siti Suharyatun, Febryan Kusuma Wisnu, Mareli Telaumbanua
pages: 1824-1835 [Full text](#) DOI:10.18517/ijaseit.12.5.15099

Dynamic Study and PI Control of Milk Cooling Process

Rudy Agustriyanto, Endang Srihari Mochni
pages: 1836-1843 [Full text](#) DOI:10.18517/ijaseit.12.5.16332

Ionic Liquids Based Cocktails as a Composite Redox Electrolyte for Natural Dye-Sensitized Solar Cells

Ahmad Mudzakhir, Asep Bayu Dani Nandiyanto, Heli Siti Halimatul Munawaroh, Karina Mulya Rizky, Danar Wulan, Lavita Kaova Lazyedara, Sedy Arfan Saputra
pages: 1844-1856 [Full text](#) DOI:10.18517/ijaseit.12.5.17044

Modelling Fuel Cut Off Controller on CNG Engines Using Fuzzy Logic: A Prototype

Suroto Munahar, Muji Setiyo, Madihah Mohd Saudi, Azuan Ahmad, Dori Yuvenda
pages: 1857-1865 [Full text](#) DOI:10.18517/ijaseit.12.5.18494

A Revisit of the Energy-Economy-Environment Nexus with Multi-Regression

Novena Damar Asri, Purnomo Yugiartoro
pages: 1866-1874 [Full text](#) DOI:10.18517/ijaseit.12.5.15907

The Modified Structural Quasi Score Estimator for Poisson Regression Parameters with Covariate Measurement Error

Fevi Novkaniza, Khairil Anwar Notodiputro, I Wayan Mangku, Kusman Sadik
pages: 1875-1881 [Full text](#) DOI:10.18517/ijaseit.12.5.12163

Soft Set Parametric-based Data Clustering for Building Data Set

Iwan Tri Riyadi Yanto, Ahmad Azhari, Rohmat Saedudin, Sely Novita Sari, Mustafa Mat Deris, Norhalina Senan
pages: 1882-1886 [Full text](#) DOI:10.18517/ijaseit.12.5.16010

Heart Disease Prediction Using Genetic Algorithm with Machine Learning Classifiers

Basant Abdel Menem Metwally, Nagham Elsayed Mekky, Ibrahim Mahmoud Elhenawy
pages: 1887-1894 [Full text](#) DOI:10.18517/ijaseit.12.5.16015

Adoption of Visual Programming Environments in Programming Learning

Qais Batha, Noraidah Sahari, Nazatul Aini, Noorazeen Mohd
pages: DOI:10.18517/ijaseit.12.5.15500

Behavior of Earthquake Damage Steel Structures in Fire

Riza Suwondo, Lee Cunningham, Martin Gillie, Colin Bailey
pages: DOI:10.18517/ijaseit.12.5.11882

Intelligent Course Recommender Chatbot Using Natural Language Processing

Tan Chia Wei, Mohd Hanafi Ahmad Hijazi, Suraya Alias, Ag Asri Ag Ibrahim, Mohd Fairuz Iskandar Othman
pages: DOI:10.18517/ijaseit.12.5.14798

Horizontal and Vertical Geometric Accuracy of Agisoft Photoscan and Pix4D Mapper Softwares at Kebun Raya Universitas Mulawarman in Samarinda, East Kalimantan, Indonesia

Sri Endayani, Ronggo Sadono, Ambar Kusumandari, - Hartono, M. Baiquni
pages: DOI:10.18517/ijaseit.12.5.16362

Ethnomathematics Study: Learning Geometry in the Mosque Ornaments

Tia Purniati, - Turmudi, Dadang Juandi, Didi Suhaedi
pages: DOI:10.18517/ijaseit.12.5.17063

Study of Caffeine as an Anticorrosion for API 5LX52 steel in Geothermal Environment Simulation

Agus Solehudin, Enda Permana, Haipan Salam, Iwa Kuntadi, Atiek Rostika Noviyanti
pages: DOI:10.18517/ijaseit.12.5.17067

Investigating the Security Threats on Using M-Payment Applications in Saudi Arabia: Exploratory Study

Raed Alotaibi, Abdulrahman Alghamdi
pages: DOI:10.18517/ijaseit.12.5.16242


Exploring the Substitution Effect of Ride-Sourcing in Commuting and Transport Stations Trips: Learning from Evidence in Bandung City, Indonesia

Andean Maulana, Muhamad Rizki, Oka Purwanti, Muhammad Farda
pages: DOI:10.18517/ijaseit.12.5.15976


Designing Hybrid CNN-SVM Model for COVID-19 Classification Based on X-ray Images Using LGBM Feature Selection

Sri Hartini, Zuherman Rustam, Rahmat Hidayat
pages: DOI:10.18517/ijaseit.12.5.16875

The Evolution of Cyberattack Motives



Keywords Cloud



Published by



Member of



Sirapat Boonkrong, Kaewrattana Prompunjai, Suwitchayagon Watcharawongbodee, Supisara Chueachantuek
pages: [DOI:10.18517/ijaseit.12.5.16431](https://doi.org/10.18517/ijaseit.12.5.16431)

also developed by scimago:



SCIMAGO INSTITUTIONS RANKINGS

SJR

Scimago Journal & Country Rank

Enter Journal Title, ISSN or Publisher Name

[Home](#)[Journal Rankings](#)[Country Rankings](#)[Viz Tools](#)[Help](#)[About Us](#)

International Journal on Advanced Science, Engineering and Information Technology

COUNTRY

SUBJECT AREA AND CATEGORY

PUBLISHER

H-INDEX

[Indonesia](#)Universities and research
institutions in Indonesia[Agricultural and Biological
Sciences](#)[Agricultural and Biological
Sciences \(miscellaneous\)](#)[Computer Science](#)[Computer Science
\(miscellaneous\)](#)[Engineering](#)[Engineering
\(miscellaneous\)](#)**25**

PUBLICATION TYPE

ISSN

COVERAGE

INFORMATION

Journals


20885334, 24606952


2015-2021

[Homepage](#)[How to publish in this journal](#)ijaseit@insightsociety.org

SCOPE

International Journal on Advanced Science, Engineering and Information Technology (IJASEIT) is an international peer-reviewed journal dedicated to interchange for the results of high quality research in all aspect of science, engineering and information technology. The journal publishes state-of-art papers in fundamental theory, experiments and simulation, as well as applications, with a systematic proposed method, sufficient review on previous works, expanded discussion and concise conclusion. As our commitment to the advancement of science and technology, the IJASEIT follows the open access policy that allows the published articles freely available online without any subscription. The journal scopes include (but not limited to) the followings: -Science: Bioscience & Biotechnology. Chemistry & Food Technology, Environmental, Health Science, Mathematics & Statistics, Applied Physics -Engineering: Architecture, Chemical & Process, Civil & structural, Electrical, Electronic & Systems, Geological & Mining Engineering, Mechanical & Materials -Information Science & Technology: Artificial Intelligence, Computer Science, E-Learning & Multimedia, Information System, Internet & Mobile Computing

 [Join the conversation about this journal](#)

 [Quartiles](#)








FIND SIMILAR JOURNALS 

1
**International Journal of
Advanced Computer Science**
GBR

2
**Journal of Theoretical and
Applied Information**
PAK

3
**Journal of Engineering and
Applied Sciences**
PAK

4
**Pertanika Journal of Science
and Technology**
MYS



International Journal on Advanced Science...

Q3 Agricultural and Biological Sciences (miscellaneous) best quartile

SJR 2021
0.25

powered by scimagojr.com

← Show this widget in your own website

Just copy the code below and paste within your html code:

```
<a href="https://www.scimi
```

SCImago Graphica

Explore, visually communicate and make sense of data with our [new data visualization tool](#).

Source details

International Journal on Advanced Science, Engineering and Information Technology

Scopus coverage years: from 2015 to Present

Publisher: INSIGHT - Indonesian Society for Knowledge and Human Development

ISSN: 2088-5334 E-ISSN: 2460-6952

Subject area: Agricultural and Biological Sciences: General Agricultural and Biological Sciences Engineering: General Engineering
Computer Science: General Computer Science

Source type: Journal

CiteScore 2021
1.8

SJR 2021
0.251

SNIP 2021
0.589

[View all documents >](#) [Set document alert](#) [Save to source list](#) [Source Homepage](#)

[CiteScore](#) [CiteScore rank & trend](#) [Scopus content coverage](#)

CiteScore 2021 ▼

1.8 = $\frac{2,447 \text{ Citations 2018 - 2021}}{1,360 \text{ Documents 2018 - 2021}}$

Calculated on 05 May, 2022

CiteScoreTracker 2022 ⓘ

1.3 = $\frac{1,567 \text{ Citations to date}}{1,210 \text{ Documents to date}}$

Last updated on 05 October, 2022 • Updated monthly

CiteScore rank 2021 ⓘ

Category	Rank	Percentile
Agricultural and Biological Sciences		
General Agricultural and Biological Sciences	#87/211	59th
Engineering		
General Engineering	#146/300	51st
Computer Science		
General Computer Science	#128/231	44th

[View CiteScore methodology >](#) [CiteScore FAQ >](#) [Add CiteScore to your site ↗](#)

About Scopus

[What is Scopus](#)

[Content coverage](#)

[Scopus blog](#)

[Scopus API](#)

[Privacy matters](#)

Language

[日本語版を表示する](#)

[查看简体中文版本](#)

[查看繁體中文版本](#)

[Просмотр версии на русском языке](#)

Customer Service

[Help](#)

[Tutorials](#)

[Contact us](#)

ELSEVIER

[Terms and conditions](#) ↗ [Privacy policy](#) ↗

Copyright © Elsevier B.V. ↗. All rights reserved. Scopus® is a registered trademark of Elsevier B.V.

We use cookies to help provide and enhance our service and tailor content. By continuing, you agree to the use of cookies ↗.

