



LUND UNIVERSITY

SARS-CoV-2 in size-fractionated aerosols from hospital corridors and relations to the indoor environment

Thuresson, Sara; Fraenkel, Carl-Johan; Medstrand, Patrik; Alsved, Malin; Löndahl, Jakob

2022

Document Version:

Publisher's PDF, also known as Version of record

[Link to publication](#)

Citation for published version (APA):

Thuresson, S., Fraenkel, C.-J., Medstrand, P., Alsved, M., & Löndahl, J. (2022). *SARS-CoV-2 in size-fractionated aerosols from hospital corridors and relations to the indoor environment*. 1-1. Abstract from NOSA symposium 2022. https://www.nosa-aerosol.org/wordpress/wp-content/uploads/2022/03/NOSA2022_AbstractBook_v020322.pdf

Total number of authors:

5

Creative Commons License:

Unspecified

General rights

Unless other specific re-use rights are stated the following general rights apply:

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain
- You may freely distribute the URL identifying the publication in the public portal

Read more about Creative commons licenses: <https://creativecommons.org/licenses/>

Take down policy

If you believe that this document breaches copyright please contact us providing details, and we will remove access to the work immediately and investigate your claim.

LUND UNIVERSITY

PO Box 117
221 00 Lund
+46 46-222 00 00

SARS-CoV-2 in size-fractionated aerosols from hospital corridors and relations to the indoor environment

S. Thuresson¹, C-J. Fraenkel^{2,3}, P. Medstrand⁴, M. Alsved¹, J. Löndahl¹

¹ Division of Ergonomics and Aerosol Technology, Department of Design Sciences, Lund University

² Department of Infection Control, Region Skåne, Lund, Sweden

³ Division of Infection Medicine, Department of Clinical Sciences, Lund University

⁴ Department of Translational Medicine, Lund University

Although most hospital wards treating patients with infectious diseases have isolation rooms with airlocks and regulated pressure systems, there is a risk that virus might be present in the air of corridors. In the corridors, less personal protective measures are in place than in patient rooms, posing a risk of infection for the hospital staff. Airborne virus might also be emitted by pre- or asymptomatic staff.

The aim of the current study was to evaluate the presence of airborne virus, specifically SARS-CoV-2, in infection ward corridors, and the size distribution of the virus-containing aerosols. Associations between virus presence and relative humidity and/or temperature in the facilities was also investigated.

Aerosol particles were collected in hospital corridors from March 2020 to April 2021 at infectious disease wards in Southern Sweden. Collection was performed using an 8-stage cascade impactor (Next Generation Impactor, Copley Scientific, UK) operating at a flowrate of 60 L min⁻¹ for 12 hours a day, 7 days a week. The impactor plates were exchanged every 7 days. After collection, each impactor stage was swabbed with a wetted nylon swab (Copan Scientific) and stored in universal transport media in -80 °C until analysis with real time reverse transcription polymerase chain reaction (RT-qPCR) for detection of SARS-CoV-2 RNA. The size fractions collected were: >8.1 µm, 4.5–8.1 µm, 2.9–4.5 µm, 1.7–2.9 µm, 0.9–1.7 µm, 0.6–0.9 µm, 0.3–0.6 µm, and 0.1–0.3 µm.

Indoor temperature, relative humidity and CO₂ concentration was recorded with a CL-11 or CP-11 multiple parameter meter (Rotronic, Germany). Recording was done 24 hours a day, 7 days a week, during the entire sampling period.

So far, only a small fraction of the collected samples (48 of 816) have been analysed by RT-qPCR. The majority of these are negative for SARS-CoV-2. Temperature measurements showed a mean corridor temperature of 23.4°C (SD: 0.38). Relative humidity varied between 6 and 67 % (mean: 28.4, SD: 10.6).

Results are expected to increase our understanding about virus presence in hospital corridors, and what aerosol particle sizes that contain SARS-CoV-2. Size information is important for understanding the particle origin, transmission patterns indoors, and where these particles deposit in the respiratory system when inhaled. Possible relations to temperature and relative humidity could improve mitigation strategies related to controlling the indoor environment.