

Online Research @ Cardiff

This is an Open Access document downloaded from ORCA, Cardiff University's institutional repository: <https://orca.cardiff.ac.uk/id/eprint/159330/>

This is the author's version of a work that was submitted to / accepted for publication.

Citation for final published version:

Yakout, Ahmed H., AboRas, Kareem M., Kotb, Hossam, Alharbi, Mohammed, Shouran, Mokhtar ORCID: <https://orcid.org/0000-0002-9904-434X> and Abdul Samad, Bdereddin ORCID: <https://orcid.org/0000-0002-9140-5024> 2023. A novel ultra local based-fuzzy PIDF controller for frequency regulation of a hybrid microgrid system with high renewable energy penetration and storage devices. Processes 11 (4) , 1093. 10.3390/pr11041093 file

Publishers page: <https://doi.org/10.3390/pr11041093>
<<https://doi.org/10.3390/pr11041093>>

Please note:

Changes made as a result of publishing processes such as copy-editing, formatting and page numbers may not be reflected in this version. For the definitive version of this publication, please refer to the published source. You are advised to consult the publisher's version if you wish to cite this paper.

This version is being made available in accordance with publisher policies.

See

<http://orca.cf.ac.uk/policies.html> for usage policies. Copyright and moral rights for publications made available in ORCA are retained by the copyright holders.



Article

A Novel Ultra Local Based-Fuzzy PIDF Controller for Frequency Regulation of a Hybrid Microgrid System with High Renewable Energy Penetration and Storage Devices

Ahmed H. Yakout ¹, Kareem M. AboRas ² , Hossam Kotb ² , Mohammed Alharbi ³ , Mokhtar Shouran ⁴ 
and Bdereddin Abdul Samad ^{4,*} 

¹ Department of Electrical Engineering, Faculty of Engineering, Ain Shams University, Cairo 11517, Egypt

² Department of Electrical Power and Machines, Faculty of Engineering, Alexandria University, Alexandria 21544, Egypt

³ Department of Electrical Engineering, College of Engineering, King Saud University, Riyadh 11421, Saudi Arabia

⁴ Magnetics and Materials Research Group, School of Engineering, Cardiff University, Cardiff CF24 3AA, UK

* Correspondence: abdulsamadbf@cardiff.ac.uk

Abstract: A new ultra-local control (ULC) model and two marine predator algorithm (MPA)-based controllers; MPA-based proportional-integral-derivative with filter (PIDF) and MPA-based Fuzzy PIDF (FPIDF) controllers; are combined to enhance the frequency response of a hybrid microgrid system. The input scaling factors, boundaries of membership functions, and gains of the FPIDF controller are all optimized using the MPA. In order to further enhance the frequency response, the alpha parameter of the proposed ULC model is optimized using MPA. The performance of the proposed controller is evaluated in the microgrid system with different renewable energy sources and energy storage devices. Furthermore, a comparison of the proposed MPA-based ULC-PIDF and ULC-FPIDF controllers against the previously designed controllers is presented. Moreover, a variety of scenarios are studied to determine the proposed controller's sensitivity and robustness to changes in wind speed, step loads, solar irradiance, and system parameter changes. The results of time-domain simulations performed in MATLAB/SIMULINK are shown. Finally, the results demonstrate that under all examined conditions, the new ULC-based controllers tend to further enhance the hybrid microgrid system's frequency time response.

Keywords: ultra-local control; fuzzy control; PID; load frequency control; marine predator algorithm; renewable energy



Citation: Yakout, A.H.; AboRas, K.M.; Kotb, H.; Alharbi, M.; Shouran, M.; Abdul Samad, B. A Novel Ultra Local Based-Fuzzy PIDF Controller for Frequency Regulation of a Hybrid Microgrid System with High Renewable Energy Penetration and Storage Devices. *Processes* **2023**, *11*, 1093. <https://doi.org/10.3390/pr11041093>

Academic Editors: Kian Jon Chua and Bipro R. Dhar

Received: 13 February 2023

Revised: 22 March 2023

Accepted: 26 March 2023

Published: 4 April 2023



Copyright: © 2023 by the authors. Licensee MDPI, Basel, Switzerland. This article is an open access article distributed under the terms and conditions of the Creative Commons Attribution (CC BY) license (<https://creativecommons.org/licenses/by/4.0/>).

1. Introduction

1.1. Background and Motivation

Due to the recent rise in load demand, new electricity liberalization policy, and rapid depletion of fossil resources, the electric power system has undergone several changes. The microgrid notion has also been developed as a result of environmental concerns and industrial growth, and renewable energy sources (RES) have been included into modern power systems [1]. The microgrid is a small system that includes distributed energy resources, commercial and residential loads, and storage devices, as well as centralized and decentralized controllers [2]. Frequency instability in the microgrid system can be caused by unpredictable renewable energy sources, weak power converter inertia, and abrupt changes in load disturbance. Therefore, appropriate control methods are required to guarantee the microgrid's power quality [3].

1.2. Literature Review

In previous literature, several studies on load frequency control (LFC) examining methods of various controls for effective power system operation have been presented. The

classical controllers are usually mentioned as integer order controllers. Because of their simplicity, these controllers are used in a lot of LFC publications. In addition, a variety of optimization techniques have been proposed to tune the parameters of proportional-integral-derivative (PID) control, such as the technique of whale optimization [4], the enhanced genetic algorithm technique [5], the optimization of particle swarm [6], the optimization of the lightning attachment procedure [7], the technique of marine predator [8], the optimizer of social spider [9], and the technique of cuckoo search [10]. In [11], the parameters of PID are set using the stability boundary position. The generation control of a combined cycle petrol turbine and thermal power system was automated by the authors of [12] using conventional P, PI, and PID controllers.

Moreover, it has been proposed that a PID adjusted using the quasi-oppositional chaotic selfish-herd approach can govern three hybrid microgrids comprising unequal wind systems, photovoltaic (PV) systems, and stored energy systems [13]. Moreover, as shown in [14], the authors introduced a modified PID controller that combines a linear quadratic gaussian technique with it. This modified PID controller has a strong combined impact that can stabilize frequency in hybrid microgrid systems. In [15], the PID controller was altered by the addition of a derivative parameter (PIDD), and it was used as a frequency controller of a two-area power system considering thermal-reheat type systems. This optimization process was implemented using the teaching and learning-based optimization method.

Moreover, the integral order controllers have been designed with a higher degree of freedom to increase their flexibility and efficiency. The researchers in [16] suggest employing second-order degree of freedom-PID (2DOF-PID) and third-order degree of freedom-PID (3DOF-PID) controllers tuned using the grey wolf optimization approach as load frequency controllers for a multi-unit hydro-thermal connected system. Additionally, the 3DOF-PID controller, which was discussed in [17], has been tuned as an LFC for four interconnected area systems using the multi-verse optimization technique. The beginning phase of the uncontrolled load frequency controller operating condition was aided by these tactics. Moreover, it was found that power systems with high RES penetration might cause issues with reliability, deviation in frequency, instability in voltage, and low power quality. Regrettably, conventional PID struggles to deal with renewable energy resource fluctuation [18].

1.2.1. LFC with Conventional Control

In addition to the primary three parameters, the fractional order controllers offer an additional two degrees of freedom compared to the conventional PID controller [19]. By doing this, the controller's efficiency, adaptability, and resilience are increased in comparison to the traditional PID controller. Fractional calculus serves as the foundation for these controllers [20]. In addition, using the genetic technique, particle swarm optimization, and grasshopper optimization technique has improved the result of automatic generation regulation in multi-area systems by using the fractional order-PID (FOPID) controller [21,22]. It has been confirmed in [23] that an automated voltage regulator (AVR) system operated by a FOPID controller utilizing the multi-objective chaotic approach is stable and resilient. By using a bacterial foraging optimizer to optimize the controller parameters, Datta et al. [24] used FOPID for simulating LFC to control an interconnected system with a hybrid wind turbine-based plant. The Egyptian national power grid frequency, which has been integrated with wind and photovoltaic energy sources, has been controlled using a non-linear FOPID controller [25], with the benefit of combining non-linear FOPID and PID controllers. A modified FOPID-LFC was also implemented for a system that is interconnected to RESs and electric automobiles. An artificial ecosystem optimizer was used by the controller [26]. Furthermore, compared to the PID, the tilt integral derivative (TID) is superior in that it requires less tuning, has a lower effect on the response when the parameters of the system change, and has a higher ratio of disturbance rejection. A multi-area system's load frequency was controlled using a TID compensator and a variety of optimization techniques, including the technique of differential evolution [27] and the

method of performance index [28]. Moreover, the differential evolution (DE) optimization method has been suggested for a modified TID controller with a filter (TIDF) [27].

As classical controllers, the FO controllers may have more degrees of freedom to enhance their stability and robustness. The 2DOF-TIDF controller has been proposed as a load frequency controller [29] and was tested against the traditional FO controllers proving to be more effective. Recently, researchers have developed a 3DOF-FOPID controller, and its response has been compared to the 1DOF-FOPID and 2DOF-FOPID controllers [29].

The LFC problem has recently seen the introduction of smart controllers, such as adaptive neuro-fuzzy inference systems, model predictive control, fuzzy logic control (FLC), and artificial neural networks. According to [30,31], the model predictive control has been used to stabilize a system made up of wind turbines. The model predictive control has been used in [32] as a LFC for three-area power systems, and its effectiveness has been proven by comparing it to the classical PID. In addition, as stated previously [33], a multi-verse optimizer has been used to tune the model predictive control for a sizable, interconnected power system. According to [34], Ismail et al. tested the model predictive control (MPC) robustness using four-area interconnected electric vehicles and power systems.

1.2.2. LFC with Advanced Control

The load frequency regulation of a system made up of many RES has also been implemented using an adaptive neuro-fuzzy inference system (ANFIS) employing the Ant Lion approach [35]. The ANFIS was suggested by researchers in [36] as a way to preserve the frequency stability of hybrid multi-generational power systems in six domains. Moreover, in [37] ANFIS was trained using the PID controller settings of the NSGA-II method. Moreover, the ANFIS has been suggested as an LFC in [38], where it has been modified for frequency stabilization of two-area linked power systems using an artificial cooperative search method. Furthermore, the ANN controller has been used in integrated PV plant systems [39]. The particle swarm optimization-based ANN technique has been taken into consideration in [40] to adjust the PID controller's parameters in a microgrid system.

Extensive research is now being done on combining FLC with fractional-order controllers or classical PID controllers. In order to control a steam engine for the first time, Mamdani employed FLC in 1974. For improved outcomes, the FLC provides greater accuracy. Therefore, optimizing the membership functions for each of the outputs and inputs could improve the system's overall performance [41,42]. The disadvantage of FLC is that there are no predefined standards for any application. The researcher's system knowledge and expertise will determine this.

Two techniques were employed to enhance an integrated FLC-PID controller: the sine-cosine algorithm [43] and the marine predators algorithm [44]. In [45,46], a controller of fuzzy-FOPID was constructed utilizing the differential evolution technique. The LFC of hybrid power systems is now regulated by one extra fuzzy PID [47]. The performance of the proposed controller was improved by genetically optimizing the input and output parameters of the controller. Based on the mine blasting process, the authors of [48] suggested a novel Fuzzy-PID controller architecture for reheating thermal systems with multi-area load frequency regulation. The system considered the governor dead zone effect and the nonlinear limitations of the turbine generation rate. The Tribe-DE optimization technique was presented by the authors of [49] as a fuzzy self-tuning PID controller capable of load frequency regulation under external disturbances and parametric existence uncertainty.

Furthermore, a relatively new controller known as an intelligent or adaptive PI or PID controller has been used in controlling the water level in tanks. This controller uses ultra-local control, a model-free predictive control, with the conventional PI and PID controllers making them robust and intelligent [50,51]. This type of control has also been used in [52] as a current controller for a three-phase voltage source pulse width modulation (PWM) rectifier. A new sensor that uses machine learning-based ULC for chemotherapeutic control and adjustment has recently been built and is described in [53]. The results show

enhanced performance [50–53]. Hence, the authors of this paper decided to use the ultra-local control scheme and investigate its availability to enhance the performance of load frequency controllers.

1.3. Contributions and Paper Organization

The novelty of this paper can be summarized as follows:

- A new combination of parallel ultra-local control (ULC) with classical PIDF and intelligent Fuzzy PIDF controllers has been proposed to solve the LFC problem.
- The gains of the PIDF controller, the primary parameter of the ULC, as well as the input scaling factors and gains of the fuzzy PIDF controller are optimized using the MPA, a recent optimizer.
- Improving the proposed controller's effectiveness by utilizing MPA to optimize the fuzzy controller's membership function bounds.
- Evaluating the suggested controller's resilience and efficacy in a hybrid microgrid under various scenarios, including the use of renewable energy sources and storage technologies.

This paper is organized as follows as well: The mathematical model of the components of the case study system is shown in Section 2. Section 3 explains the marine predator algorithm technique, while Section 4 goes into great depth on the examined controller's structure. The results of several simulations are discussed in Section 5. The study's result is presented in the finding part, Section 6.

2. System Structure

The recommended case study is a hybrid microgrid system made up of two locations connected by a tie-line, as shown in Figure 1. A load, a superconducting magnetic energy storage (SMES) device, a wind energy source, and a diesel engine with a valve actuator are all shown in Area 1.




Figure 1. The hybrid microgrid system's block diagram.

A battery energy storage (BES) device, a PV energy source, a valve, a load, and a diesel generator are all present in Area 2. Each area additionally uses the suggested ULC-Fuzzy PIDF controller to regulate system frequency and preserve system stability under a range of operating circumstances, including changes in solar irradiation, variable load disturbances, variations in wind speed, and adjustments to system parameters. In the suggested model, it is anticipated that each PV system, diesel generator, and wind turbine system will provide roughly 25% of the microgrid's total load. Additionally, it is believed that each area's storage has a capacity equal to the amount of linked renewable energy. As shown in Table 1 [48], every element of the microgrid is presented as a linear, first-order transfer function model.

Table 1. Values for model parameters [43].

Systems	Transfer Function	Parameters
Diesel generator	$\frac{K_{DG}}{T_{DG} \cdot s + 1}$	$K_{DG1} = K_{DG2} = 1$ $T_{DG1} = T_{DG2} = 0.5$
Valve actuator	$\frac{K_V}{T_V \cdot s + 1}$	$K_{V1} = K_{V2} = 1$ $T_{V1} = T_{V2} = 0.05$
Wind turbine	$\frac{K_{WT}}{T_{WT} \cdot s + 1}$	$K_{WT} = 1$ $T_{WT} = 1.5$
SMES	$\frac{K_{SMES}}{T_{SMES} \cdot s + 1}$	$K_{SMES} = 0.98$ $T_{SMES} = 0.03$
PV	$\frac{K_{PV}}{T_{PV} \cdot s + 1}$	$K_{PV} = 1$ $T_{PV} = 0.03$
BES	$\frac{K_{BES}}{T_{BES} \cdot s + 1}$	$K_{BES} = 1.8$ $T_{BES} = 0$
Area swing	$\frac{K_{AS}}{T_{AS} \cdot s + 1}$	$K_{AS1} = K_{AS2} = 1$ $T_{AS1} = T_{AS2} = 3$
Synchronizing coefficient	$\frac{K_{12}}{s}$	$K_{12} = 1.4\pi$
Speed droops	R_1, R_2	$R_1 = R_2 = 0.05$
Frequency bias coefficients	B_1, B_2	$B_1 = B_2 = 21$

3. MPA Optimization Algorithm

MPA has the advantages of a simple algorithm design, with relatively good accuracy and stable results across several runs. Its benefit is that the population's first solution is generated and the population variety is increased by chaotic mapping's good traversal and randomization. Nevertheless, due to the lack of population variety in the late stages of optimization, MPA might quickly enter a local optimum. The MPA optimization process is divided into 3 stages and takes into account ratios of various velocities while modeling the prey and predator whole life cycle. The MPA approach's main phases may be described as follows:

Initialization: Recommended variable random positions, the prey matrix during initialization, and the elite matrix are generated, where elite matrix repeats vector position with optimum fitness function.

Phase 1: This stage is distinguished by a ratio of high-velocity $v \geq 10$ for great exploration capabilities [33]:

While $Iter < \frac{1}{3}Iter_{max}$

$$\vec{S}_i = \vec{R}_B \otimes \left(\vec{Elite}_i - \left(\vec{R}_B \otimes \vec{Prey}_i \right) \right) \quad i = 1, 2, \dots, n \quad (1)$$

$$\vec{Prey}_i = \vec{Prey}_i + \left(0.5\vec{R} \otimes \vec{S}_i \right) \quad (2)$$

where \vec{S}_i the magnitude of the predator's steps, \vec{R}_B is a random number vector based on the normal distribution of Brownian motion, \vec{R} is a number at random between [0, 1], and n is the ratio of search agents to the population.

Phase 2: The unit velocity ratio identifies this stage (i.e., $v \approx 1$) [33] as follows:

While $\frac{1}{3}Iter_{max} < Iter < \frac{2}{3}Iter_{max}$

$$\vec{S}_i = \vec{R}_L \otimes \left(\vec{Elite}_i - \left(\vec{R}_L \otimes \vec{Prey}_i \right) \right) \quad i = 1, 2, \dots, n/2 \quad (3)$$

$$\vec{Prey}_i = \vec{Prey}_i + \left(0.5\vec{R} \otimes \vec{S}_i \right) \quad (4)$$

where R_L is a vector of random integers based on the normal distribution of the Levy motion. But, according to the Brownian technique, Equations (5) and (6) are used to update the second half of the population as follows:

$$\vec{S}_i = \vec{R}_B \otimes \left(\left(\vec{R}_B \otimes \vec{Elite}_i \right) - \vec{Prey}_i \right) \quad i = n/2, \dots, n \quad (5)$$

$$\vec{Prey}_i = \vec{Elite}_i + \left(0.5X_f \otimes \vec{S}_i \right) \quad (6)$$

Equation (7) can be used to determine X_f , a factor that controls the predator's stride length:

$$X_f = [1 - (Iter / Iter_{max})]^{(2 \times Iter / Iter_{max})} \quad (7)$$

Stage 3: A feature of this phase is the low-velocity ratio. ($v = 0.1$) as follows:

While $Iter > \frac{2}{3}Iter_{max}$

$$\vec{S}_i = \vec{R}_L \otimes \left(\left(\vec{R}_L \otimes \vec{Elite}_i \right) - \vec{Prey}_i \right) \quad i = 1, 2, \dots, n \quad (8)$$

$$\vec{Prey}_i = \vec{Elite}_i + \left(0.5X_f \otimes \vec{S}_i \right) \quad (9)$$

Finalizing: The elite matrix refreshes the top solutions following each iteration, and the ultimate solution is discovered following the last iteration. Figure 2 depicts the essential phases of the MPA optimization process. Also, the suggested ULC-based controllers (i.e., adaptive or intelligent controllers) and the issue formulation will be described in the next part.




Figure 2. Flowchart of the MPA optimization method.

4. Formulation of the Problem and the Proposed Controller Structure

As previously mentioned, the load frequency problem discussed in this paper will use ultra-local control (ULC) based controller structure to improve the microgrid performance. Ultra-local control is a model-free predictive control, where the system model is not detailed and is instead approximated with a differential Equation (10) meant to capture the system dynamics

$$y(t)^v = F(t) + \alpha * u(t) \quad (10)$$

where $y(t)$ is the system output (ACE_1 , and ACE_2) in our problem, $u(t)$ is the system input (generator's reference power settings), v is the differential equation order (taken to be 1 as a small sampling time is considered), $F(t)$ is a time-varying function that includes all of the system's structural information as well as the many potential disruptions, and finally, α is a non-physical constant that is chosen (MPA optimized in our case) to match the RHS and LHS of Equation (10). Moreover, F is calculated in our study using Heun's discrete equation (with a small sampling time of 0.01 s) as in (11) [52].

$$F = \frac{-3}{n_f^3 t_s} \sum_{k=1}^{n_f} (F_1 + F_2) \quad (11)$$

where, n_f is the sequence length (unity in our study), t_s is the sampling time, k is an integer sample counter, F_1 and F_2 are functions of the system output and input and are given as:

$$F_1 = [n_f - 2(k - 1)] * y(k - 1) + [n_f - 2k] * y(k) \quad (12)$$

$$F_2 = [\alpha * (k - 1) * t_s * \{n_f - (k - 1)\}] * u(k - 1) + [\alpha * k * t_s * (n_f - k)] * u(k) \quad (13)$$

Furthermore, for ultra-local based controllers (also known as intelligent or adaptive controllers), the ultra-local model predictive block is applied as shown in Figure 3. Hence, the new system input $u(t)$ becomes as follows:

$$u(t) = \frac{-F + dy/dt + \theta(e)}{\alpha} \quad (14)$$

where dy/dt is the output rate of change and is set to zero in our case, $\theta(e)$ is the original controller function which is once taken as PIDF controller and once as a Fuzzy PIDF controller (see Figure 4) whose rules are shown in Table 2 and whose scaling factors, gains, and membership function are MPA optimized. Figure 5 depicts the whole model of the ULC-fuzzy PIDF-based MPA. In order to keep things simple, Figures 6–8 depict the five triangle membership functions that were employed in this work for FLC inputs and outputs [43]. They are also known as zero (Z), small positive (SP), small negative (SN), and large positive (LP) (SN). The membership functions of the error input (E) are between $[-1, 1]$ and $[-0.2, 0.2]$, respectively, according to Figure 6. The error change (CE) input membership functions with a triangular Z membership basis between $[-0.35, 0.35]$ are shown in Figure 7. Figure 8 depicts the output control signal’s membership functions (u).




Figure 3. Ultra-local based controller structure.




Figure 4. The MPA-based fuzzy PIDF Controller’s structure.

Table 2. The rule set of the fuzzy logic controller.

E	CE				
	LN	SN	Z	SP	LP
LP	Z	SP	SP	LP	LP
SP	SN	Z	SP	SP	LP
Z	SN	SN	Z	SP	SP
SN	LN	SN	SN	Z	SP
LN	LN	LN	SN	SN	Z




Figure 5. The MPA optimizer’s ULC-fuzzy PID controller block diagram.




Figure 6. Ideal triangular input error membership functions.




Figure 7. Optimal error-change input triangular membership functions.




Figure 8. Optimal output control signal triangular membership functions.

The fuzzy logic controller (FLC) implementation process is detailed below [2,43]:

- (1) Fuzzification: In this stage, the FLC transforms the error (E) and change of error (CE) variables into five language variables (LP, LN, Z, SP, SN).
- (2) Rule base formation: The FLC uses Mamdani fuzzy inference (FIS) to build fuzzy rules based on the linguistic variables obtained through the fuzzification process, as illustrated in Table 2. The experience of the creator determines the FLC's rule foundation. To get the best possible reaction, each system has its own set of rules.
- (3) Defuzzification. The defuzzification process uses linguistic variables, which are the system's outputs, as inputs. Also, when using a bisector defuzzification method, the defuzzification procedure turns these variables into crisp variables [2,43].

First, we have implemented the procedures and equations of the MPA optimization algorithm (Equations (1)–(9)) using an m-file in MATLAB. Then, we have modeled the two-area microgrid system using MATLAB/Simulink including the ULC-fuzzy PIDF controller with its unknown model parameters (k_1 , k_2 , k_p , k_i , k_d , N , α). Finally, the MPA optimization algorithm (m-file) can be linked to the system control model (Simulink) shown in Figure 5 using the 'sim' command in MATLAB to get the optimal parameters of the controller.

By decreasing the fitness function (FF), one may achieve the ULC-fuzzy PIDF controller's optimal gains [2,43]:

$$FF = \int_0^{t_{sim}} (|\Delta F_1| + |\Delta F_2| + |\Delta P_{tie-line}|) dt \quad (15)$$

where ΔF_1 is F_1 represents the frequency deviation in region 1 and F_2 represents the frequency deviation in area 2 and $\Delta P_{tie-line}$ is the variance in tie-line power. Moreover, the suggested MPA is used to tune the controller settings under the following restrictions [43]:

$$\begin{cases} k_{p,min} \leq k_p \leq k_{p,max} \\ k_{i,min} \leq k_i \leq k_{i,max} \\ k_{d,min} \leq k_d \leq k_{d,max} \\ N_{min} \leq N \leq N_{max} \\ k_{1,min} \leq k_1 \leq k_{1,max} \\ k_{2,min} \leq k_2 \leq k_{2,max} \\ \alpha_{,min} \leq \alpha \leq \alpha_{,max} \end{cases} \quad (16)$$

5. Stability Analysis

One of the most crucial needs for any closed-loop system is stability, which is why it is examined in this part for the suggested controller. The Lyapunov approach [54], which is based on looking for a positive definite function of the state with a negative temporal

derivative, is one of the most well-known techniques for stability analysis. A time-invariant state space model can be used to represent any multivariable system as shown below [54]:

$$\dot{x}(t) = Ax(t) + Bu(t) \quad (17)$$

$$y(t) = Cx(t) + Du(t) \quad (18)$$

where $x(t)$ is the state vector, $\dot{x}(t)$ is the derivative of the state vector, $u(t)$ represents the input to the system, and $y(t)$ is the system output. The constant matrices of the system are A , B , C , and D . The system is considered stable by the Lyapunov approach if all eigenvalues of the symmetric positive definite matrix (P) are positive and the derivative of the Lyapunov function $V(x)$ is negative [54]. In addition, the Lyapunov function and its derivative can be represented using Equations (19) and (20), respectively:

$$V(x) = x^T Px \quad (19)$$

$$\frac{dV(x)}{dt} = \dot{x}^T Px + x^T p\dot{x} = x^T (A^T P + PA) x < 0 \quad (20)$$

Using the suggested controller, it was discovered that there were a lot of states in the hybrid two-area case study system. Yet, the Lyapunov theory has been used to demonstrate the closed-loop system's stability. Also, according to the Lyapunov approach, the P matrix's eigenvalues are all positive, which is a sign that the system is stable.

6. Results and Discussion

To demonstrate the efficacy of the suggested ULC-fuzzy PIDF controller, the simulation results for the microgrid under various uncertainties are shown in this section. In the first scenario, when the microgrid is subjected to a 5% step load disturbance in area 1, the performance of several MPA-based controllers, including the PIDF, ULC-PIDF, fuzzy PIDF, and ULC-fuzzy PIDF controllers, is compared (the design value). The stability and performance of the proposed MPA-based ULC-fuzzy PIDF controller are then evaluated under:

1. Different small and large step load perturbations (SLP).
2. Microgrid parameters variations.
3. A continuous random load variation.
4. Integration of different RES fluctuations.

6.1. Scenario (I): Effect of Step Load Perturbation

In this case, Area 1 is subjected to a 5% step load disturbance without taking RES variation into account for controller design considerations. The alpha constants of the proposed MPA-based ULC-PIDF and ULC-fuzzy PIDF controllers are optimized using the MPA method with a population size of 15 each iteration and a total of 30 iterations, and then compared to the previously discussed MPA-based PIDF and fuzzy PIDF. The convergence curves of the MPA optimizer are shown in Figure 9, indicating fast convergence with lower fitness function (FF) values. Additionally, Table 3 lists the ideal FF values and ideal design parameters for various controllers. It can be seen that, especially for the ULC-fuzzy PIDF combination, adding the ultra-local controller to the previous controllers can produce better FF values than the conventionally designed controllers. The optimum FF value can be improved with the ULC-fuzzy PIDF by approximately 71.42% compared to the conventional MPA-based fuzzy PIDF controller. In addition, the ULC-optimal PIDF's FF value is enhanced by around 75.3% when compared to the traditional PIDF controller. As a result, utilizing the suggested controller, where the ULC is applied to the MPA-based FPIDF and PIDF, the system's responsiveness was much enhanced.




Figure 9. Convergence curves of the MPA algorithm for (a) ULC-PIDF and (b) ULC-fuzzy PIDF controllers.

Table 3. Optimal performance and gains of various controllers in terms of fitness.

Controller	Optimal FF	Area 1							Area 2						
		k_{p1}	k_{i1}	k_{d1}	N_1	k_1	k_2	α	k_{p2}	k_{i2}	k_{d2}	N_2	k_3	k_4	α
PIDF [43]	0.81×10^{-3}	17.87	18.11	10.17	198	–	–	–	19.98	19.98	11.61	199	–	–	–
ULC-PIDF	0.20×10^{-3}	17.87	18.11	10.17	198	–	–	5.84	19.98	19.98	11.61	199	–	–	5.84
fuzzy PIDF [43]	0.07×10^{-3}	8.61	5.48	9.66	123	1.95	0.61	–	5.71	7.11	8.24	195	1.54	1.64	–
ULC-fuzzy PIDF	0.02×10^{-3}	8.61	5.48	9.66	123	1.95	0.61	29.97	5.71	7.11	8.24	195	1.54	1.64	29.97

The transient responses of the frequency deviations in Areas 1 and Area 2 (F_1 and F_2) as well as the tie-line power deviation (P_{tie}) under 5% SLP are shown in Figure 10 utilizing a variety of optimized controllers. It is therefore reasonable to claim that the MPA-based ULC-fuzzy PIDF controller is superior to conventional controllers at maintaining stability and boosting the performance of the microgrid. The standard MPA-based PIDF controller, as seen in Figure 10, has the lowest response, according to MO and MU.

The maximum overshoot (MO), maximum undershoot (MU), and settling time (T_s) for F_1 , F_2 , and P_{tie} , respectively, are shown in Table 4 as the system dynamic results for 5% SLP. The lowest values of maximum overshoot, maximum undershoot, and settling time are given by the proposed MPA-based ULC-fuzzy PIDF controller, followed by the conventional MPA-based fuzzy controller and the ULC-PIDF. However, the MPA-based classical PIDF controller obtains the maximum value of maximum overshoot, maximum undershoot, and settling time. The suggested ULC-fuzzy PIDF controller generally enhanced the maximum undershoot, maximum overshoot, and settling time values of the

system responses by around 98.8%, 98.45%, and 61.1%, respectively, as compared to the standard PIDF controller.

Table 4. Transient expectations for 5% SLP utilizing various controllers.

Controller	ΔF_1 (Hz)			ΔF_2 (Hz)			ΔP_{tie} (p.u.)		
	MUS (Hz) $\times 10^{-5}$	MOS (Hz) $\times 10^{-5}$	T_s (s)	MUS (Hz) $\times 10^{-6}$	MOS (Hz)	T_s (s)	MUS (p.u.) $\times 10^{-4}$	MOS (p.u.)	T_s (s)
PIDF [43]	-4.66	0.84	18	-9.28	0	18	-1.94	0	18
ULC-PIDF	-1.126	0.227	12	-2.33	0		-0.489	0	12
fuzzy PIDF [43]	-0.228	0.053	10	-0.73	0	10	-0.154	0	10
ULC-fuzzy PIDF	-0.054	0.013	7	-0.18	0	7	-0.038	0	7






Figure 10. Transient response for 5% SLP using different controllers: (a) ΔF_1 , (b) ΔF_2 , and (c) ΔP_{tie} .

Moreover, the designed MPA-based ULC-fuzzy PIDF controller stability robustness is tested at smaller and larger values of step load perturbations where step values are changed between 1% and 20%. Results presented in Figures 11 and 12 prove such stability robustness of the proposed controller at small and large load perturbations, respectively. Additionally, Table 5 gives values for the frequency time response, undershoot, and overshoot at the SLPs under consideration.







Figure 11. Transient response for small SLP based on ULC-fuzzy PIDF controller: (a) ΔF_1 , (b) ΔF_2 and (c) ΔP_{tie} .



(a)



(b)



(c)

Figure 12. Transient response for large SLP based on ULC-fuzzy PIDF controller: (a) ΔF_1 , (b) ΔF_2 and (c) ΔP_{tie} .

Table 5. Transient specifications based on ULC-fuzzy PIDF controller for different SLP.

SLP%	ΔF_1 (Hz)		ΔF_2 (Hz)		ΔP_{tie} (p.u.)	
	MUS (Hz) $\times 10^{-6}$	MOS (Hz) $\times 10^{-6}$	MUS (Hz) $\times 10^{-7}$	MOS (Hz)	MUS (p.u.) $\times 10^{-5}$	MOS (p.u.)
1	-0.11	0.03	-0.36	0	-0.08	0
3	-0.32	0.08	-1.08	0	-0.23	0
5 (Design value)	-0.54	0.13	-1.80	0	-0.38	0
7	-0.75	0.18	-2.52	0	-0.53	0
9	-0.97	0.23	-3.24	0	-0.68	0
10	-1.073	0.26	-3.60	0	-0.76	0
15	-1.61	0.39	-5.40	0	-1.14	0
20	-2.15	0.51	-7.21	0	-1.52	0

6.2. Scenario (II): Sensitivity Analysis of System Parameters Change

The sensitivity analysis of the system's performance to a change in system parameters is presented in this scenario. This study aims to evaluate the proposed MPA-based ULC-fuzzy PIDF controller's performance and stability. In this scenario, the T_{d1} , K_{SMES} , B_1 , and B_2 parameters all undergo a 25% change. Table 6 provides a summary of the study findings. As can be seen, when the aforementioned parameters change, ΔF_1 , ΔF_2 , and ΔP_{tie} 's dynamic responses are marginally impacted. In addition, the values of maximum undershoot and maximum overshoot remain low, as proposed in typical operations. The settling time is not specified because it is constant across all cases. Similar to this, altering other system variables essentially has no impact on the system under the study's dynamic performance. As a result, the suggested ULC-fuzzy PIDF controller is strong and effective at preserving system performance and stability when system parameters change.

Table 6. Transient specifications based on ULC-fuzzy PIDF controller for system parameters variation.

System Parameter	Percentage of Change	ΔF_1 (Hz)		ΔF_2 (Hz)		ΔP_{tie} (p.u.)	
		MUS (Hz) $\times 10^{-6}$	MOS (Hz) $\times 10^{-6}$	MUS (Hz) $\times 10^{-7}$	MOS (Hz) $\times 10^{-7}$	MUS (p.u.) $\times 10^{-5}$	MOS (p.u.) $\times 10^{-5}$
T_{d1}	-25%	-0.527	0.1269	-1.791	0	-0.3761	0
	+25%	-0.5507	0.1303	-1.815	0	-0.3812	0
K_{SMES}	-25%	-0.6088	0.1461	-2.051	0	-0.4308	0
	+25%	-0.478	0.1144	-1.603	0	-0.3366	0
B_1	-25%	-0.6818	0.1783	-2.215	0	-0.4652	0
	+25%	-0.4419	0.0974	-1.516	0	-0.3183	0
B_2	-25%	-0.5385	0.11	-2.216	0	-0.3490	0
	+25%	-0.5346	0.1408	-1.516	0	-0.3979	0

6.3. Scenario (III): Effect of Random Load Variation

In this case, as shown in Figure 13, uncertain random load variation is applied to the power system. The load randomly alternates between 0 p.u. and 0.2 p.u. every 20 s. In order to confirm the performance robustness of the suggested method, this scenario compares the proposed MPA-based ULC-fuzzy PIDF to MPA-based fuzzy PIDF, ULC-PIDF, and PIDF, as shown in Figure 14.







Figure 13. Profile of the random load.



(a)



(b)



(c)

Figure 14. Transient response using different controllers under random load variation: (a) ΔF_1 , (b) ΔF_2 , and (c) ΔP_{tie} .

6.4. Scenario (IV): RES Fluctuation Effect

This case targets to test the efficacy of the proposed ULC-fuzzy PIDF controller when subjected to real variable wind power in Area 1 (From the Zafarana Location, east of Egypt) and real variable PV power in Area 2 (From the Aswan Location, south of Egypt) simultaneously, as illustrated in Figures 15 and 16. Similar to the earlier cases, the ULC-fuzzy PIDF and ULC-PIDF both exhibit improved performance when compared to a conventional fuzzy PIDF and a conventional PIDF, respectively, as demonstrated in Figure 17.




Figure 15. Profile of Wind power.




Figure 16. Profile of PV power.




Figure 17. Dynamic response using different controllers through RES fluctuation: (a) ΔF_1 , (b) ΔF_2 , and (c) ΔP_{tie} .

7. Conclusions

This study has successfully presented a new MPA-ultra-local control-based fuzzy PIDF controller to enhance the frequency response of a two-area linked hybrid microgrid. The hybrid system combines traditional diesel generation with renewable energy sources such

as wind and solar PV. Additionally, SMES & BES storage devices are each connected to an area. The marine predator algorithm (MPA), a recent metaheuristic optimization algorithm, was used to extract the best parameters for the suggested controller. The robustness, faster convergence, and higher accuracy of the MPA algorithm are benefits. Additionally, various uncertainties have been used to test the proposed controller's performance robustness, including a range of SLP values, random load variation, fluctuations in wind speed, and changes in solar irradiance. Results show that the MPA ULC- fuzzy PIDF controller greatly outperformed the traditional PID controller in terms of fitness function based on the ISE value 40 times. Additionally, for all scenarios, the MPA-based ULC-fuzzy PIDF controller outperformed the individual PIDF, ULC-PIDF, and fuzzy PIDF controllers in terms of frequency response and tie-line power deviation. A high degree of accuracy was also attained by the MPA-based ULC-fuzzy PIDF controller when some system parameters were altered by 25%. Additionally, the proposed controller performs better when exposed to variations in wind and PV power. In future work, the studied controller might be investigated with non-linear systems.

Author Contributions: Conceptualization, A.H.Y. and H.K.; methodology, A.H.Y., K.M.A., H.K., M.A., M.S. and B.A.S. All authors have read and agreed to the published version of the manuscript.

Funding: This research received no external funding.

Data Availability Statement: The data sources employed for analysis are presented in the text.

Acknowledgments: This work was supported by the Researchers Supporting Project number (RSP2023R467), King Saud University, Riyadh, Saudi Arabia.

Conflicts of Interest: The authors declare no conflict of interest.

References

1. AboRas, K.M.; Ragab, M.; Shouran, M.; Alghamdi, S.; Kotb, H. Voltage and Frequency Regulation in Smart Grids via a Unique Fuzzy PIDF2 Controller Optimized by Gradient-Based Optimization Algorithm. *Energy Rep.* **2023**, *9*, 1201–1235. [[CrossRef](#)]
2. Ali, M.; Kotb, H.; Kareem AboRas, M.; Nabil Abbasy, H. Frequency Regulation of Hybrid Multi-Area Power System Using Wild Horse Optimizer Based New Combined Fuzzy Fractional-Order PI and TID Controllers. *Alex. Eng. J.* **2022**, *61*, 12187–12210. [[CrossRef](#)]
3. Ali, M.; Kotb, H.; Aboras, K.M.; Abbasy, N.H. Design of Cascaded PI-Fractional Order PID Controller for Improving the Frequency Response of Hybrid Microgrid System Using Gorilla Troops Optimizer. *IEEE Access* **2021**, *9*, 150715–150732. [[CrossRef](#)]
4. Hasanien, H.M. Whale Optimisation Algorithm for Automatic Generation Control of Interconnected Modern Power Systems Including Renewable Energy Sources. *IET Gener. Transm. Distrib.* **2018**, *12*, 607–614. [[CrossRef](#)]
5. Raja, S.K.; Badathala, V.P.; Ss, K. LFC Problem by Using Improved Genetic Algorithm Tuning PID Controller. *Int. J. Pure Appl. Math.* **2018**, *120*, 7899–7908.
6. Rao, R.N.; Reddy, P.R.K. PSO Based Tuning of PID Controller for a Load Frequency Control in Two Area Power System. *Int. J. Eng. Res. Appl. (IJERA)* **2015**, *1*, 1499–1505.
7. Saleh, B. Design of PID Controller with Grid Connected Hybrid Renewable Energy System Using Optimization Algorithms. *J. Electr. Eng. Technol.* **2021**, 1–15. [[CrossRef](#)]
8. Sobhy, M.A.; Abdelaziz, A.Y.; Hasanien, H.M.; Ezzat, M. Marine Predators Algorithm for Load Frequency Control of Modern Interconnected Power Systems Including Renewable Energy Sources and Energy Storage Units. *Ain Shams Eng. J.* **2021**, *12*, 3843–3857. [[CrossRef](#)]
9. El-Fergany, A.A.; El-Hameed, M.A. Efficient Frequency Controllers for Autonomous Two-Area Hybrid Microgrid System Using Social-Spider Optimiser. *IET Gener. Transm. Distrib.* **2017**, *11*, 637–648. [[CrossRef](#)]
10. Mehta, P.; Bhatt, P.; Pandya, V. Optimized Coordinated Control of Frequency and Voltage for Distributed Generating System Using Cuckoo Search Algorithm. *Ain Shams Eng. J.* **2018**, *9*, 1855–1864. [[CrossRef](#)]
11. Sharma, J.; Hote, Y.V.; Prasad, R. PID Controller Design for Interval Load Frequency Control System with Communication Time Delay. *Control. Eng. Pract.* **2019**, *89*, 154–168. [[CrossRef](#)]
12. Saha, D.; Saikia, L.C. Automatic Generation Control of an Interconnected CCGT-Thermal System Using Stochastic Fractal Search Optimized Classical Controllers. *Int. Trans. Electr. Energy Syst.* **2018**, *28*, e2533. [[CrossRef](#)]
13. Barik, A.K.; Das, D.C. Integrated Resource Planning in Sustainable Energy-Based Distributed Microgrids. *Sustain. Energy Technol. Assessments* **2021**, *48*, 101622. [[CrossRef](#)]
14. Khamies, M.; Magdy, G.; Hussein, M.E.; Banakhr, F.A.; Kamel, S. An Efficient Control Strategy for Enhancing Frequency Stability of Multi-Area Power System Considering High Wind Energy Penetration. *IEEE Access* **2020**, *8*, 140062–140078. [[CrossRef](#)]

15. Sahu, R.K.; Gorripotu, T.S.; Panda, S. Automatic Generation Control of Multi-Area Power Systems with Diverse Energy Sources Using Teaching Learning Based Optimization Algorithm. *Eng. Sci. Technol. Int. J.* **2016**, *19*, 113–134. [[CrossRef](#)]
16. Patel, N.C.; Debnath, M.K.; Bagarty, D.P.; Das, P. GWO Tuned Multi Degree of Freedom PID Controller for Load Frequency Control. *Int. J. Eng. Technol.* **2018**, *7*, 548–552. [[CrossRef](#)]
17. Mudi, J.; Shiva, C.K.; Mukherjee, V. Multi-Verse Optimization Algorithm for LFC of Power System with Imposed Non-Linearities Using Three-Degree-of-Freedom PID Controller. *Iran. J. Sci. Technol.* **2019**, *43*, 837–856.
18. Gheisarnejad, M. An Effective Hybrid Harmony Search and Cuckoo Optimization Algorithm Based Fuzzy PID Controller for Load Frequency Control. *Appl. Soft Comput.* **2018**, *65*, 121–138. [[CrossRef](#)]
19. Bayati, N.; Dadkhah, A.; Vahidi, B.; Sadeghi, S.H.H. Fopid Design for Load-Frequency Control Using Genetic Algorithm. *Sci. Int.* **2015**, *27*, 3089–3094.
20. Pan, I.; Das, S. Fractional Order AGC for Distributed Energy Resources Using Robust Optimization. *IEEE Trans. Smart Grid* **2016**, *7*, 2175–2186. [[CrossRef](#)]
21. Tabak, A. Fractional Order Frequency Proportional-Integral-Derivative Control of Microgrid Consisting of Renewable Energy Sources Based on Multi-Objective Grasshopper Optimization Algorithm. *Trans. Inst. Meas. Control.* **2022**, *44*, 378–392. [[CrossRef](#)]
22. Pan, I.; Das, S. Frequency Domain Design of Fractional Order PID Controller for AVR System Using Chaotic Multi-Objective Optimization. *Int. J. Electr. Power Energy Syst.* **2013**, *51*, 106–118. [[CrossRef](#)]
23. Datta, A.; Koley, I.; Panda, G.K.; Atoche, A.C.; Castillo, J.V. Dynamic Power-Frequency Control in a Hybrid Wind-PV Plant Interlinked with AC Power System. *J. Electr. Eng. Technol.* **2021**, *16*, 1469–1479. [[CrossRef](#)]
24. Taher, S.A.; Hajiakbari Fini, M.; Falahati Aliabadi, S. Fractional Order PID Controller Design for LFC in Electric Power Systems Using Imperialist Competitive Algorithm. *Ain Shams Eng. J.* **2014**, *5*, 121–135. [[CrossRef](#)]
25. Fayek, H.H.; Kotsampopoulos, P. Central Tunicate Swarm NFOPID-Based Load Frequency Control of the Egyptian Power System Considering New Uncontrolled Wind and Photovoltaic Farms. *Energies* **2021**, *14*, 3604. [[CrossRef](#)]
26. Ahmed, E.M.; Mohamed, E.A.; Elmelegi, A.; Aly, M.; Elbaksawi, O. Optimum Modified Fractional Order Controller for Future Electric Vehicles and Renewable Energy-Based Interconnected Power Systems. *IEEE Access* **2021**, *9*, 29993–30010. [[CrossRef](#)]
27. Kumar Sahu, R.; Panda, S.; Biswal, A.; Chandra Sekhar, G.T. Design and Analysis of Tilt Integral Derivative Controller with Filter for Load Frequency Control of Multi-Area Interconnected Power Systems. *ISA Trans.* **2016**, *61*, 251–264. [[CrossRef](#)]
28. Topno, P.N.; Chanana, S. Load Frequency Control of a Two-Area Multi-Source Power System Using a Tilt Integral Derivative Controller. *J. Vib. Control.* **2018**, *24*, 110–125. [[CrossRef](#)]
29. Chintu, J.M.R.; Sahu, R.K.; Panda, S. Design and Analysis of Two Degree of Freedom Tilt Integral Derivative Controller with Filter for Frequency Control and Real Time Validation. *J. Electr. Eng.* **2020**, *71*, 388–396. [[CrossRef](#)]
30. Shouran, M.; Anayi, F.; Packianather, M.; Habil, M. Load Frequency Control Based on the Bees Algorithm for the Great Britain Power System. *Designs* **2021**, *5*, 50. [[CrossRef](#)]
31. Zhang, C.; Wang, S.; Zhao, Q. Distributed Economic MPC for LFC of Multi-Area Power System with Wind Power Plants in Power Market Environment. *Int. J. Electr. Power Energy Syst.* **2021**, *126*, 106548. [[CrossRef](#)]
32. Singh, A.; Sharma, V.; Dahiya, P.; Sharma, R.N. Model Predictive Based Load Frequency Control of Interconnected Power Systems. *Recent Adv. Electr. Electron. Eng. (Former. Recent Pat. Electr. Electron. Eng.)* **2018**, *11*, 322–333. [[CrossRef](#)]
33. Ali, H.H.; Kassem, A.M.; Al-Dhaifallah, M.; Fathy, A. Multi-Verse Optimizer for Model Predictive Load Frequency Control of Hybrid Multi-Interconnected Plants Comprising Renewable Energy. *IEEE Access* **2020**, *8*, 114623–114642. [[CrossRef](#)]
34. Ismail, M.M.; Bendary, A.F. Load Frequency Control for Multi Area Smart Grid Based on Advanced Control Techniques. *Alex. Eng. J.* **2018**, *57*, 4021–4032. [[CrossRef](#)]
35. Fathy, A.; Kassem, A.M. Antlion Optimizer-ANFIS Load Frequency Control for Multi-Interconnected Plants Comprising Photovoltaic and Wind Turbine. *ISA Trans.* **2019**, *87*, 282–296. [[CrossRef](#)] [[PubMed](#)]
36. Prakash, S.; Sinha, S.K. Automatic Load Frequency Control of Six Areas' Hybrid Multi-Generation Power Systems Using Neuro-Fuzzy Intelligent Controller. *IETE J. Res.* **2018**, *64*, 471–481. [[CrossRef](#)]
37. Aryanpour, H.; Shayeghi, H.; Nooshyar, M.; Esmaeili, M. Design of New Controller for Load Frequency Control of Isolated Microgrid Considering System Uncertainties. *Int. J. Power Energy Convers.* **2018**, *9*, 285. [[CrossRef](#)]
38. Selvaraju, R.K.; Somaskandan, G. ACS Algorithm Tuned ANFIS-Based Controller for LFC in Deregulated Environment. *J. Appl. Res. Technol.* **2017**, *15*, 152–166. [[CrossRef](#)]
39. Patowary, M.; Panda, G.; Naidu, B.R.; Deka, B.C. ANN-based Adaptive Current Controller for On-grid DG System to Meet Frequency Deviation and Transient Load Challenges with Hardware Implementation. *IET Renew. Power Gener.* **2018**, *12*, 61–71. [[CrossRef](#)]
40. Shouran, M.; Anayi, F.; Packianather, M. The Bees Algorithm Tuned Sliding Mode Control for Load Frequency Control in Two-Area Power System. *Energies* **2021**, *14*, 5701. [[CrossRef](#)]
41. Dombi, J.; Hussain, A. A New Approach to Fuzzy Control Using the Distending Function. *J. Process Control.* **2020**, *86*, 16–29. [[CrossRef](#)]
42. Valdez, F.; Castillo, O.; Peraza, C. Fuzzy Logic in Dynamic Parameter Adaptation of Harmony Search Optimization for Benchmark Functions and Fuzzy Controllers. *Int. J. Fuzzy Syst.* **2020**, *22*, 1198–1211. [[CrossRef](#)]
43. Yakout, A.H.; Kotb, H.; Hasaniien, H.M.; AboRas, K.M. Optimal Fuzzy PIDF Load Frequency Controller for Hybrid Microgrid System Using Marine Predator Algorithm. *IEEE Access* **2021**, *9*, 54220–54232. [[CrossRef](#)]

44. Rajesh, K.; Dash, S. Load Frequency Control of Autonomous Power System Using Adaptive Fuzzy Based PID Controller Optimized on Improved Sine Cosine Algorithm. *J. Ambient. Intell. Humaniz. Comput.* **2019**, *10*, 2361–2373. [[CrossRef](#)]
45. Mishra, D.; Sahu, P.C.; Prusty, R.C.; Panda, S. Fuzzy Adaptive Fractional Order-PID Controller for Frequency Control of an Islanded Microgrid under Stochastic Wind/Solar Uncertainties. *Int. J. Ambient. Energy* **2021**, 1–17. [[CrossRef](#)]
46. Osinski, C.; Leandro, G.V.; da Costa Oliveira, G.H. A New Hybrid Load Frequency Control Strategy Combining Fuzzy Sets and Differential Evolution. *J. Control Autom. Electr. Syst.* **2021**, *32*, 1627–1638. [[CrossRef](#)]
47. Ahmadi, S.; Talami, S.H.; Sahnesaraie, M.A.; Dini, F.; Tahernejadjozam, B.; Ashgevari, Y. FUZZY Aided PID Controller Is Optimized by GA Algorithm for Load Frequency Control of Multi-Source Power Systems. In Proceedings of the 2020 IEEE 18th World Symposium on Applied Machine Intelligence and Informatics (SAMII), Herlany, Slovakia, 23–25 January 2020.
48. Fathy, A.; Kassem, A.M.; Abdelaziz, A.Y. Optimal Design of Fuzzy PID Controller for Deregulated LFC of Multi-Area Power System via Mine Blast Algorithm. *Neural Comput. Appl.* **2020**, *32*, 4531–4551. [[CrossRef](#)]
49. Yakout, A.H.; Attia, M.A.; Kotb, H. Marine Predator Algorithm Based Cascaded PID Load Frequency Controller for Electric Power Systems with Wave Energy Conversion Systems. *Alex. Eng. J.* **2021**, *60*, 4213–4222. [[CrossRef](#)]
50. Thabet, H.; Ayadi, M.; Rotella, F. Experimental Comparison of New Adaptive PI Controllers Based on the Ultra-Local Model Parameter Identification. *Int. J. Control Autom. Syst.* **2016**, *14*, 1520–1527. [[CrossRef](#)]
51. Thabet, H.; Ayadi, M.; Rotella, F. Design of Adaptive PID Controllers Based on Adaptive Smith Predictor for Ultra-Local Model Control. *Int. J. Autom. Control* **2017**, *11*, 222. [[CrossRef](#)]
52. Zhang, Y.; Liu, X.; Liu, J.; Rodriguez, J.; Garcia, C. Model-Free Predictive Current Control of Power Converters Based on Ultra-Local Model. In Proceedings of the 2020 IEEE International Conference on Industrial Technology (ICIT), Buenos Aires, Argentina, 26–28 February 2020.
53. Faraji, B.; Gheisarnejad, M.; Rouhollahi, K.; Esfahani, Z.; Khooban, M.H. Machine Learning Approach Based on Ultra-Local Model Control for Treating Cancer Pain. *IEEE Sens. J.* **2021**, *21*, 8245–8252. [[CrossRef](#)]
54. Ding, F.; Zhang, X.; Xu, L. The Innovation Algorithms for Multivariable State-space Models. *Int. J. Adapt. Control Signal Process.* **2019**, *33*, 1601–1618. [[CrossRef](#)]

Disclaimer/Publisher’s Note: The statements, opinions and data contained in all publications are solely those of the individual author(s) and contributor(s) and not of MDPI and/or the editor(s). MDPI and/or the editor(s) disclaim responsibility for any injury to people or property resulting from any ideas, methods, instructions or products referred to in the content.