

Assessing the requirements from 'BB101' 2006 and 2018 for a naturally ventilated preparatory schools in the UK

Yingchun Ji, Will Swan, Richard Fitton and Terrence Fernando

School of the Built Environment, University of Salford, Salford, M5 4WT, United Kingdom

Telephone: 0044 161 2954841 / Email: y.ji@salford.ac.uk

Abstract

In the UK, BB101 is the guidance document for ventilation design of school buildings. There are significant changes proposed in the new version of BB101. The aim of this paper is to examine the requirements of thermal comfort and CO₂ based indoor air quality using both versions on a typical naturally ventilated preparatory school design using dynamic thermal simulations. The findings indicate that the new set of requirements on this school building designs (both thermal and CO₂ concentration) are much more difficult to meet than the requirements from the old version. One of the new thermal comfort criteria may be too difficult to achieve in practice, as the target value was exceeded for all the rooms of the examined design, using both Test Reference Year and Design Summer Year weather data. The ventilation provision for the school design is believed to be adequate. With appropriate ventilation control strategies, the design is able to meet the revised CO₂ concentration criteria. Further examinations of the new criteria of from the new guidance document are needed to make sure the chosen criteria are fit for purpose. The use of future projected Design Summer Year weather data (2020) also adds extra challenges for school building design the preparatory school building to meet the newly proposed adaptive thermal comfort criteria.

Key words: Building Bulletin 101, thermal comfort, CO₂ concentration, Weather data, Overheating

Practical Applications:

The research presents a very first assessment of a preparatory school building design using the newly proposed BB101 guidance document. It will assist further exploration on the appropriateness of the new assessment criteria and the use of Design Summer Year weather data in order to explore the implications of the new BB101 guidelines for designers. The method adopted in the research can also be used for other building types to assess overheating in buildings when adaptive comfort criteria are recommended.

1. Introduction

Effective ventilation in buildings is essential in providing an acceptable indoor environment for occupants. Indoor CO₂ concentration, which is directly associated with the effectiveness of ventilation, has been given particular emphasis in school buildings. Various studies have shown that the school learning environment has a significant influence on the cognitive performance of pupils.^{1,2,3} In the UK, Building Bulletin 101 (entitled 'Ventilation of School Buildings')

provides a design framework for school buildings.⁴ Ventilation requirements from different strategies such as natural, mechanical and hybrid were outlined in this document. Public schools in the UK are often naturally ventilated.⁵ The use of natural ventilation has the benefits of using no extra energy and, potentially, providing better indoor air quality, however, the control of natural ventilation, driven by thermal stack effects or wind forces, is difficult, and can often result cold draughts and higher energy use in heating season.⁶ Mechanical ventilation has the benefits of better control of the supply of fresh air, but misses the opportunity of using natural ventilation, which is perfectly viable in the warm season. The latest update on Building Bulletin 101 (2018) aims to provide more practical guidelines in tackling energy consumption and controllability in a holistic approach for school buildings.⁷

The consultation of the latest update to BB101 started on the 6th of September 2016 and the final draft was made available in January 2017. The latest release of the guidance document was in early August 2018 on the www.gov.uk website. The new BB101 is entitled 'Guidelines for ventilation, thermal comfort and indoor air quality in schools'. Recommendations on CO₂ concentration based indoor air quality and thermal comfort in the new BB101 are significantly different with the BB101 (2006). Table 1 shows the summary of these changes.

Insert Table 1 here

As shown in the table, the new BB101 has much tighter requirements for indoor CO₂ concentrations. Daily average CO₂ concentration are reduced from 1500ppm to 1000ppm, and for the maximum allowed CO₂ concentration, the figure has been reduced from 5000ppm to 1500/2000ppm, with a newly introduced 20 minute limit. Unlike the previous version, which had a universal requirement for CO₂ concentration, the new version introduces a clear difference for maximum allowed CO₂ concentration when using specific ventilation strategies. In the case of the hybrid mode, however, the number is used for compliance purpose depends the system's operation, i.e. whether in natural ventilation mode or mechanical ventilation mode.

From a thermal comfort perspective, the changes are significant. BB101 (2006) used a single fixed temperature criterion to judge overheating occurrences (number of hours above 28°C), while the new BB101 (2018) proposes an adaptive thermal comfort approach, where the indoor comfort temperatures are influenced by the outdoor running mean temperature. Relevant calculations are shown below, while more details may be found in TM52 and other standards and guidance documents.^{8,9,10}

$$T_{comf} = 0.33Max(10, T_{rm}) + 18.8 \quad (1)$$

$$T_{max} = T_{comf} + sar \quad (2)$$

where T_{max} is the indoor comfort maximum temperature limit determined by the comfort temperature T_{comf} and sar (suggested acceptable range). In the above guidance documents, sar was suggested to have four different categories (I to IV) depending on the expectations of the indoor environment. For a high level of expectation (Cat. I) $sar = \pm 2^\circ\text{C}$, normal expectation

(Cat. II) $sar = \pm 3$ °C, moderate level of expectation (Cat. III) $sar = \pm 4$ °C, and low expectation (Cat. IV) $sar > 4$ °C. In the case of new build school buildings, **Cat. II** is applied for spaces where teaching and learning, drama, dance and exams are held. For refurbishment projects Cat. III or IV is applied for these spaces. T_{rm} is an exponentially weighted running mean of the daily mean (T_{ed}) outdoor air temperature, T_{rm} is defined as

$$T_{rm} = (1 - \alpha)T_{ed-1} + \alpha T_{rm-1} \quad (3)$$

where, T_{ed-1} and T_{rm-1} are the daily mean and running mean temperature for the previous day. T_{rm} is decreasingly affected by any particular daily mean temperature as time passes, the rate at which the effect of any particular daily mean temperature dies away depending on α (a constant between 0 and 1). The recommended value for α is 0.8.⁸

In Table 1, the Hours of Exceedance (H_e) are counted based on the temperature difference ΔT between the indoor operative temperature T_{op} and the comfort maximum temperature limit T_{max} ($\Delta T = T_{op} - T_{max}$). This adaptive overheating occurrence requirement is 'the number of hours (H_e) during which ΔT is greater than or equal to one degree (K) during the period 1st May to 30th September for the defined hours inclusive shall not be more than 40 hours'. ΔT is rounded to the nearest degree (i.e. for ΔT between 0.5 and 1.5 the value used is 1°C, for 1.5 to 2.5 the value used is 2°C and so on).

The daily weighted exceedance (W_e) is the 'daily accumulated number of hours over' for that particular day: the sum of all the rounded ΔT . The third criterion limits the maximum indoor operative temperature (T_{upp}) i.e., T_{upp} should not be 4°C higher than the comfort maximum temperature limit T_{max} of a particular category.

School ventilation design has always been assessed by the Test Reference Year weather data. In the newly proposed BB101, Design Summer Year (DSY) weather was suggested to be used when examining the likely thermal comfort of schools. In the UK, both TRYs and DSYs are licensed by the Chartered Institution of Building Service Engineers (CIBSE). A DSY by definition should be always warmer than its associated TRY weather, as the latter represents a typical (or averaged) weather condition and the former represents a near extreme summer.¹⁵ However, the methodology (ranking the average dry bulb temperature from April to September and choosing the mid-year of the upper quartile to represent the near extreme) adopted in CIBSE Guide J¹¹ experienced issues in predicting indoor warmth where, for some locations, TRY is warmer than its corresponding DSY for some building designs.^{12,13} Recent research and the latest CIBSE weather data release attempted to mitigate the above issue.^{14,15} When using the CIBSE weather data to model various building settings, it is clear that the indoor condition is not only influenced by the weather data, but also the building design itself. As a consequence, outdoor warmth defined by the given weather data does not necessarily translate into the predicted indoor warmth consistently.^{16,17} Nevertheless, for the CIBSE latest release of the weather data, the quadratic nature of the chosen metric (called 'weight cooling degree hour' - WCDH) is broadly consistent with the relationship between the fraction of people uncomfortable and the departure from the comfort temperature.¹⁵ There were recent updates in both DSYs and TRYs discussing the details on how these weather files were generated.^{18,19}

1
2
3
4 The baseline weather data for these updated DSYs and TRYs are more up to date (1984 to 2013)
5 and CIBSE encourages academics and industry professionals to use these files for building
6 simulation purposes. It is fair to say the uptake of these data has not been extensive so far.
7 One of the reasons may be that the building compliance calculations are still required to use
8 the early release of the TRYs for consistency. There are some examples of the use of the new
9 CIBSE weather data in evaluating overheating for open plan offices in London²⁰, and assessing
10 the impact of these weather data on residential building designs²¹, however, for school
11 building designs these data have not been examined.

12
13
14
15 The UK's Building Schools for the Future (BSF) programme aimed to rebuild and renew 3500
16 secondary schools in England, with an initially anticipated budget of £45b.²² This was the
17 largest single capital investment programme in 50 years in improving learning and teaching
18 environment. Although the programme was scrapped due to cost efficiency related issues²³,
19 the link between effective teaching and learning and the environment in which it takes place
20 appears to be well established.³ It is, therefore, important to ensure that a better indoor
21 environment is achieved for new school designs, as well as in the retrofit of existing school
22 buildings.

23
24
25
26 Significant changes have been made to the requirements of both CO₂ concentrations and
27 thermal comfort of school buildings between the BB101 2006 version and the BB101 2018
28 version. In addition, the updated weather files from CIBSE in 2016 have yet to be substantially
29 explored in assessing school buildings. The research question raised in this paper is: what
30 impact do these changes have on the evaluation of school building designs in terms of
31 ventilation, thermal comfort and CO₂ concentration? Using the latest weather files this
32 research takes the first opportunity to examine the potential impact of the new BB101 (2018)
33 requirements on an existing school design in contrast with its previous version's requirements.

34 35 36 37 **2. Methodology**

38 39 40 2.1 The school model

41
42 An existing naturally ventilated school was used in this research. The 4 storey preparatory
43 school was designed and built in late 2008 on an existing site in London. The entrance hall is
44 the narrow part of the building sandwiched between existing buildings (Fig 1). The teaching
45 and learning spaces within the building include 8 classrooms, 1 computer room and 1 music
46 room. The windows of these spaces are all facing east. The west side of the entrance hall is
47 adjacent a major road. The built up noise level on the west side prevented the idea of opening
48 windows, therefore roof terminals were used for ventilation. Natural ventilation is achieved
49 through ventilation louvres, openable windows, roof terminals and stacks. A dynamic thermal
50 model was used to assess the design BB101 2006 criteria and the design achieved a pass prior
51 construction. This research will examine how the design performs under the newly proposed
52 criteria compared with the former criteria. The construction details are shown in Table 2. The
53 fabric U-values are well above the current building regulation requirements in the UK. In the
54 Part L – conservation of fuel and power, the external wall U-value requirement is 0.35W/m²K.²⁴

1
2
3
4 The fabric U-values of this school design are close to the requirements from the voluntary
5 Fabric Energy Efficiency Standard²⁵ and the Passivhaus standard.²⁶
6

7
8 Insert Figure 1 here
9

10 Insert Table 2 here
11

12 The detailed layout of the school is shown in Fig 2. Teaching and learning spaces on the ground
13 floor include classrooms G.02, & G.22 and a music room G.20; the first floor has classrooms
14 F1.18, F1.19 & F1.20 and a computer room F1.17; two class rooms are on the second floor:
15 F2.07 & F2.09; and there is one class room T3.09 on the third floor (G, F, S & T stand Ground,
16 First, Second & Third Floor). Ventilation for these spaces is arranged individually, meaning
17 there is no cross ventilation between these rooms or any other adjacent rooms. Every room
18 has either its own designated stacks or roof terminals serving as 'exhaust'. The ventilation
19 louvres and openable windows would, in theory, serve as 'inlets' in summer operation.
20 Reverse air flow may happen, but the airflow only happens within a particular space, rather
21 than causing cross contamination with other spaces. These 10 spaces, with various inlet/outlet
22 areas, volumes, layouts, internal gains, stack heights and different types of roof terminals, will
23 be used to carry out the compliance check against the requirements from BB101. These
24 individually ventilated spaces are able to provide sufficient data for the proposed assessment
25 of this research.
26
27
28
29

30
31 Insert Figure 2 here
32

33 2.2 Modelling assumptions 34

35 The likely performance of the school building was assessed using the Integrated Environment
36 Solutions (IES) Virtual Environment, which is a well-established tool for analysing the dynamic
37 responses of a building based on the hourly input of weather data.²⁷ The detailed internal heat
38 gains are shown in Table 3. All rooms include an overhead projector with a gain of 250 watts,
39 while room F1.17 also includes 23 laptops (60 watts each). Lighting is assumed 10W/m² and
40 the occupancy time is 09:00 to 15:30 Monday to Friday (assumptions on heat gains are based
41 on recommendations from CIBSE Guide A.¹⁰ Maximum occupancy and all available gains in
42 Table 3 are included to represent the worst case scenario. In reality, the overhead projectors
43 may not be in use all the time during week days, artificial lighting may be compensated by
44 natural daylight, and heat gains from laptops will depend on the intensity of usage. However,
45 the worst case scenario is required when carrying out compliance calculation. The average
46 gains in these teaching and learning spaces are around 50 to 60W/m² except room F1.17,
47 where a higher gain is due to the use of computers. Natural ventilation (through low level
48 louvres or openable windows and high level stacks or roof terminals) for the design is expected
49 to overcome the potential overheating in summer as there is no provision of mechanical
50 ventilation for these teaching and learning spaces.
51
52
53
54
55

56 Insert Table 3 here
57
58
59
60

Ventilation was modelled using a network airflow model, which predicts hourly ventilation rates based on prevailing driving forces of wind and buoyancy (caused by the temperature difference between inside and outside). Building ventilation is achieved by the louvres, vertical stacks with transfer grills, roof air extract terminals/louvres and openable windows. Their free areas and discharge coefficients were assumed based on their characteristics or product specifications, details of which are shown in Appendix A.

In order to mimic the likely behaviour of occupants, simple control logics were used such that the opening of the louvres and windows was determined by either the internal temperature or CO₂ concentration, during the occupied period. The degree of opening for the inlet windows and louvres was varied from fully closed to fully open as the internal air temperature rose from 20 °C to 24 °C or the CO₂ concentration rose from 800ppm to 2000ppm (*ref*: Table 1). During the summer period, May to September inclusive, no heating was modelled, the inlet louvres are kept open at night, as well as during weekends to achieve night cooling. Night cooling is very important in regulating the indoor thermal environment for the following day, in particular, with heavyweight construction, where large thermal mass can be used as a thermal storage to help regulate the day and night temperature variations in the indoor environment.^{6,28} This research focuses on the likely summer overheating, winter conditions, therefore, are not considered.

2.3 Weather data used

The most recent release of weather data from CIBSE was in 2016. Both Test Reference Years (TRYs) and Design Summer Years data (DSYs) were made available for 14 locations across the country: Belfast, Birmingham, Cardiff, Edinburgh, Glasgow, Leeds, London, Manchester, Newcastle, Norwich, Nottingham, Plymouth, Southampton, and Swindon. For average weather years (TRYs) the recent 2016 release is broadly consistent with the former release in 2006 as the method used for selecting individual months for TRYs are similar. Relatively large variations were observed for some locations such as Norwich, Southampton and Swindon, but these were largely attributed to the change of observation locations.¹⁸ The new metric used to select near extreme weather years for the DSYs in the 2016 release was ‘weight cooling degree hours (WCDH)’, defined as:

$$WCDH = \sum_{i=1}^N (T_{dbt}^i - T_{comf}^i)^2 |T_{dbt}^i > T_{comf}^i| \quad (4)$$

where T_{comf}^i is from Eq (1) with i represents individual hours, T_{dbt}^i is the dry bulb temperature at hour i , representing the indoor operative temperature under the conceptual building assumption¹⁵, and N is the total hours from April to September inclusive (4392 hours).

The London probabilistic DSYs were selected using the WCDHs by calculating their return periods. Three pDSYs are produced to represent different types of warm events, i.e. for London Heathrow, pDSY-1 (1989) represents a *moderately warm summer*; pDSY-2 (2003) has a *more intense single warm spell*; and pDSY-3 (1976) has a *long period of persistent warmth*. Higher WCDH leads to a longer return period, which indicates more severe summer warmth. For locations other than London, the same analogy was adopted, but the return periods were assessed using WCDH and two new metrics modified from the WCDH: Static WCDH &

Threshold WCDH.¹⁹ By definition the WCDH metric assumes that the outdoor weather dry bulb temperature equals the indoor operative temperature. The metric not only accounts for overheating occurrences, but also gives emphasis to overheating severity. Table 4 shows the WCDHs calculated for both TRYs and DSYs from the 2016 release and the previous 2006 release. Across all the 14 locations, London weather is the warmest judging by the WCDH metric. The evaluation of the school building is therefore carried out using London's weather data. The new BB101 proposed to use the future projected weather data of pDSY-1 (2020) (using the most appropriate one for the assessment location) for compliance calculation. In this research, the current pDSY-1, pDSY-2, & pDSY-3 were also used for the chosen location to conduct the analysis. These pDSYs are the actual years in history chosen to present different characteristics of warm weather, these data are from instrumental records, considered to be more realistic than their mathematical transformed future projected data.^{15,18}

Insert Table 4 here

3. Results

3.1 Thermal responses of the school against BB101 2006 criteria

Table 5 shows the thermal responses of the ten functional rooms within the naturally ventilated school building. The criteria used in table 5 are from the BB101 2006 version. In this version the Test Reference Years (TRYs) were required to assess school building designs. The data presented in the table using Design Summer Year (DSYs) weather are for cross comparison purposes. For the 'number of hours over 28°C' criterion, all the functional spaces of the school design meet the requirement by a relatively large margin when using the TRY weathers. Even with the near extreme weather conditions (the pDSYs) majority of the spaces are well within the target requirement (less than 120 hours). For some of the pDSYs, the music room G20, classroom G22 & computer room F117 failed to meet this criterion (bold numbers in Table 5 – Criteria 1). For Criteria 3 – the 'average internal/external temperature difference' – most of the spaces meet the $\leq 5^{\circ}\text{C}$ target requirement. The computer room F117 consistently fails this criterion with one of the TRYs (TRY16), due to its high internal heat gains (Table 3). Classroom S209 is the second worst against Criteria 2, followed by classroom F118. For the Criteria 3, all the rooms failed to meet this criterion when DSYs were used. Even with TRYs, five out of the ten evaluated spaces exceeded the target requirement. The judgement on a school design is based on the principle that – *'the school will not suffer from overheating if two out of these three criteria are met'*. With the given design, data in Table 5 illustrate that a full pass is achieved when using TRY 2006, while for all the other weather data evaluated including TRY 2016, there are always some spaces that fail to meet the standard requirement.

It is worth noting that the 'average internal/external temperature difference (Criteria 2)' in Table 5 is the average of the whole occupancy time from May to September. BB101 2006 does not clearly define whether the average is for the internal/external temperature difference during the whole occupancy time or the maximum 'daily' average internal/external temperature difference. If it were for the whole summer time, from May to September, this criterion could not capture the overheating severity at a daily level. For example, collectively, the average internal/external temperature difference meets the targets, but this criterion would not guarantee there are days when the internal/external temperature difference could be significantly higher than the given target, causing discomfort for occupants. If the criterion were for the maximum 'daily' average difference between internal and external temperature, it could potentially be misleading for overheating assessments in school designs. Figure 3

1
2
3
4 shows the internal (blue line) and external (red line) temperatures for a typical cooler day and
5 a typical warmer day, using room F117 as an example. It is evident that a higher 'daily' average
6 internal/external temperature difference can be found on a cooler day (11.10°C on the 4th of
7 May) rather than a warmer day (6.38°C on the 12th of August), when overheating is likely to
8 happen. This implies that the maximum 'daily' average internal/external temperature
9 difference could happen during a particular cooler day when overheating is unlikely to happen
10 (as in Figure 3 left, the maximum temperature is less than 22°C), which clearly contradicts the
11 purpose of the criterion in assessing overheating. For cooler days, the outdoor daily average
12 dry-bulb temperature during occupancy is low (8.73°C), but the average indoor air
13 temperature during occupancy is relatively high (19.83°C) due to the internal gains (ref: Table
14 3), solar gains and overall low thermal transmittances of construction materials used (ref:
15 Table 2). As shown in Figure 3, the ventilation rate during occupancy between the two days is
16 quite different, with low ventilation in the cooler day and higher ventilation in the warmer day.
17 This is due to the impact of the ventilation control strategy on internal air temperature as
18 explained in section 2.2. The low ventilation in a cooler day is also a key reason for a high
19 average internal/external temperature difference.
20
21
22

23 Insert Figure 3 here

24
25 Insert Table 5 here
26
27

28 3.2 Thermal responses of the school against BB101 2018 criteria

29 As shown in Table 6, the same modelling outputs were examined against the new adaptive
30 thermal comfort based criteria from the newly proposed BB101 2018. Bold numbers in the
31 table indicate that the target values are not met. For the 'Hours of Exceedance' criterion using
32 current Design Summer Year weathers (pDSYs) and pDSY-1 2020, all the evaluated rooms
33 failed to meet this criterion for weather locations such as Gatwick pDSY-3, Heathrow pDSY-2,
34 pDSY-3, and the London Weather Centre pDSY-3. For the pDSY-1 at the three locations in
35 London, there are 5 or 6 rooms where their 'hours of exceedance' are below the target value.
36 For pDSY-1 2020, 4 rooms at Gatwick, 1 room at Heathrow and 3 rooms at London weather
37 centre are below 40 hours. This may indicate that with pDSY-1 (and its immediate projections),
38 which is a 'moderately warm summer', there is scope to work towards achieving a pass for all
39 the spaces with this criterion. However, it would be much tougher to achieve a pass for pDSY-2,
40 which has a more intense single warm spell, & pDSY-3, which has a long period of persistent
41 warmth, among all three locations in London. It would be much easier to meet this criterion if
42 Test Reference Year weathers were used. For both TRY 2006 and TRY 2016, only one or two
43 rooms failed to meet the 40 hours target.
44
45
46

47 For Criteria 2 in table 6 – daily weighted exceedance, all the rooms with all the weather data
48 overwhelmingly failed to meet this criterion by a much larger margin. Broadly, W_e results from
49 pDSYs are far larger than those from the TRYs (please note: the London TRYs are Heathrow
50 based) which is expected by their definitions. This criterion is to assess the overheating
51 severity on a daily basis. Examining both TRYs and pDSYs weather data over the summer
52 period from May to September inclusive, it is clear all the weather data have warm spells
53 where the outdoor temperatures are high. These warm spells, moderate or severe, will result a
54 higher daily weighted exceedance. This will make passing this criterion extremely difficult. The
55 pDSY-2 weather data by definition have 'a more intense single warm spell'. An intense warm
56 spell could potentially lead to a higher W_e as W_e is calculated on a daily basis. This is certainly
57 the case for Heathrow and the London Weather Centre, as all the calculated W_e values from
58
59
60

the two locations for pDSY-2 are higher than the W_e values calculated from their corresponding pDSY-1 and pDSY-3. However, this trend is less obvious at Gatwick as only 3 rooms (F118, 119, 120) follow the trend by a relatively small margin. All the other rooms, either its pDSY-1, or pDSY-3, or both result higher W_e values. The resulted W_e values for pDSY-1 2020 – the future projection of pDSY-1 are consistently higher than its corresponding pDSY-1 and, in many cases, even higher than pDSY-2 and pDSY-3, due to the emphasis of warm spells when future weather data were generated.

The third criterion is an alternative way of assessing overheating severity. It assesses the temperature difference (ΔT) between the maximum operative temperature T_{upp} and the maximum allowed comfort temperature T_{max} . Apart from the pDSY-1 weather data of London Weather Centre and Heathrow, which has 3 rooms and 1 room where ΔT is at 4K, higher ΔT values were resulted by all the other pDSYs weathers for all the rooms, including the pDSY-1 2020. Collectively higher ΔT values were predicted for all the rooms when using the pDSY-2 weather from the three locations compared with their corresponding pDSY-1 & pDSY-3 at these locations. This again emphasizes the influence of the single intense warm spell on the overheating severity for any given time when maximum ΔT is resulted across the whole summer. The temperature difference ΔT (as well as the daily weighted exceedance W_e) values will inevitably be influenced by the ‘intensity’ of the particular warm spell within pDSY-2 weathers.

Out of these three criteria, if ‘any two of them exceeded the target values, the building design would be deemed to be overheating’. With the suggested use of CIBSE Design Summer Year weather data (pDSY-1 2020) in BB101 2018, the design examined in this paper indeed causes overheating, which is clearly evidenced in Table 6. The requirement from Criteria 2 is very hard to meet. Meeting the other two criteria can be possible for some spaces, such as rooms G02 & F119, with moderately warm weather pDSY-1 at London Weather Centre, and room S309 for pDSY-1 at both London Heathrow and Weather Centre. However, the whole building design as is, overwhelmingly fails for pDSY-1 2020 and all the other examined pDSYs. For the two TRYs examined, small margins need to be managed (such as room G20, G22, F117 & F118) before the design can pass the overheating assessment. For the three examined locations in London, the Weather Centre represents inner urban climate, Gatwick represents rural climate, and Heathrow represents intermediate urban and suburban locations. Broadly speaking, weather data from the London Weather Centre does seem to be warmer. This is expected due to inner urban heat island effects.²⁰

Insert Table 6 here

3.3 CO₂ concentration against both versions of BB101 criteria

Table 7 shows the CO₂ concentration data against the requirements from the old and newly proposed BB101. For the ‘Maximum CO₂ concentration’, the new target of ≤ 2000 ppm is much stricter than the previous target of ≤ 5000 ppm. With the given school design and the examined TRYs and pDSYs, this criterion can be met without much further effort on the design. Only one room (G 02) fails to meet this with some of the examined weather data. For the ‘maximum daily average CO₂ concentration’ it is obviously a different story. The majority of the examined rooms failed to meet the newly proposed requirement in BB101 2018 (≤ 1000 ppm). It is worth noting that if the criterion of ≤ 1500 ppm from BB101 2006 were used, all the rooms would

1
2
3
4 have passed. The newly proposed requirements on CO₂ concentration are indeed much more
5 stringent than the previous version and a typical school design could fail easily.
6

7
8 The school design used in this research is a typical natural ventilation design. It does provide
9 adequate provision to bring down CO₂ concentration through ventilation. As illustrated in
10 Figure 4 (choosing the same dates as in Figure 3), the ventilation rate on the warmer day (12th
11 August) can be as high as 500l/s during occupancy. With only 24 occupants in total (room F117,
12 1 adult and 23 pupils, see table 3), the ventilation rate per person is more than 20l/s/p, the
13 resulted CO₂ concentration is less than 650ppm. However, for the cooler day (4th of May) the
14 ventilation rate is less than 200l/s, the average CO₂ concentration is over 1000ppm. The lower
15 ventilation on the cooler day is due to the ventilation control by referencing internal air
16 temperature and CO₂ concentration (*The degree of opening for the inlet windows and louvres*
17 *was varied from fully closed to fully open as the internal air temperature rose from 20 °C to 24*
18 *°C or the CO₂ concentration rose from 800ppm to 2000ppm, see section 2.2). This strategy was*
19 *set to meet the BB101 2006 requirement. If the control for CO₂ concentration were, for*
20 *example, 600ppm to 1000ppm, the inlet windows and louvres would have been fully opened*
21 *on the 4th of May (Figure 4, left). With the high internal/external temperature difference,*
22 *higher ventilation could be achieved (this affirms the provision of ventilation is adequate*
23 *enough when necessary). However, the indoor air temperature could be brought down to, or*
24 *much lower than, the comfort temperature threshold (22.1°C, ref: Eq (1) when the running*
25 *mean T_{rm} is less than 10°C). Therefore, a delicate balance between CO₂ concentration and*
26 *thermal comfort needs to be managed through more appropriate natural ventilation control*
27 *strategies.*
28
29

30
31 Insert Figure 4 here
32

33 Insert Table 7 here
34

35 **4. Discussion**

36
37 Apart from the radical changes in CO₂ concentration requirements and the use of adaptive
38 thermal comfort over fixed temperature criteria to judge overheating, the new BB101 also
39 emphasizes the significance of the indoor air quality (IAQ) from other pollutants. It considers a
40 wide range of potential pollutants from both the indoor and outdoor environment. Relevant
41 national and international standards are referenced and explicit requirements are given on
42 controlling the permitted level of these pollutants. The old version BB101 also discussed IAQ
43 by referencing various pollutants but the given requirements were not as detailed as the new
44 BB101. One thing in common from both old and new BB101 is that there are no
45 recommendations on how pollutants based compliance calculations should be made when
46 required. Specialized air pollutants modelling tools and the dynamic thermal simulation tools
47 (such as the one used in this research) may be used together to provide a more holistic
48 assessment for new school building designs under the new guidance document.
49
50
51
52
53

54 The primary focus of this research is to evaluate the impact from the newly proposed BB101
55 on the overheating assessment of an existing school building design. It is not about proposing
56 interventions to achieve the relevant target criteria. The chosen school design is a typical
57 natural ventilation design. The overheating assessment of the design can achieve a pass using
58
59
60

1
2
3
4 the requirements from BB101 2006. However, the design will fail using the newly proposed
5 criteria from BB101 2018. As discussed in section 3.3, the indoor CO₂ concentrations will not
6 be an issue, if the appropriate control strategies are used with the given design. For thermal
7 comfort criteria, more effort would be needed if the design is to achieve a pass under the new
8 BB101 requirements.
9
10

11 4.1 Overheating occurrence criteria

12
13 Criteria 1 from both versions of BB101 account for overheating occurrence: how many hours
14 (times) the indoor temperature is over the threshold during occupancy. For the 2006 version,
15 the indoor air temperature is assessed against a fixed temperature threshold of 28°C; while for
16 the newly proposed version, the indoor operative temperature is assessed against adaptive
17 thermal comfort temperature, which varies with outdoor weather dry bulb temperature. In
18 summer time, the indoor operative temperature tends to be slightly higher than the indoor air
19 temperature due to the relatively high mean radiant temperature (at low indoor air movement
20 condition, the operative temperature is the average of the air temperature and the mean
21 radiant temperature). The difference is rarely more than 0.5°C in summer time for free running
22 conditions (no heating/cooling). When calculating the hours of exceedance (H_e), the
23 temperature difference was rounded to the nearest degree (see section 1), so the slight
24 difference between the indoor air temperature and the operative temperature becomes
25 irrelevant. The data for Criteria 1 from Tables 5 & 6 are plotted in Figure 5 to examine whether
26 there is a correlation between the two overheating occurrence criteria. As shown in Figure 5,
27 the data do seem to be well correlated. Previous research on the two similar criteria has also
28 shown correlations between variations of designs against the same weather data.²⁸ The
29 current data were from 10 individual rooms and 12 different weather data; the resulting
30 overheating occurrences between the two criteria are correlated more strictly due to how H_e
31 is calculated. In terms of the likelihood of achieving a pass for the two overheating occurrence
32 criteria, it is obvious that the new criterion from BB101 2018 using Design Summer Year (pDSYs)
33 weather data is much more difficult to achieve (with more points beyond the target 40 degree
34 hours compared with the number of points beyond the 120 hours over 28°C).
35
36
37
38
39
40
41
42

43 Insert Figure 5 here

44 4.2 Overheating severity criteria

45
46 The second criterion (daily weighted exceedance) in Table 6 assesses overheating severity by
47 counting the sum of the all the rounded ΔT . The maximum daily weighted exceedance W_e will
48 naturally happen on the peak day, which means this criterion is in line with the Criteria 3
49 (maximum internal air temperature – the peak day) in Table 5. Figure 6 illustrates the peak
50 date (29th June) for room F117 using London Heathrow pDSY-3 (Heathrow 1976). The peak
51 indoor operative temperature is 37.49°C (peak air temperature 37.45°C as in Table 5 Criteria 3)
52 at 2:30pm, while the peak outdoor dry bulb temperature is 33.8°C at 4:00pm. The cloud cover
53 increased after 1:00pm which leads to reduced solar radiation gain for the room. The reduced
54 solar gain was the reason why the peak indoor operative temperature happens before the
55 peak outdoor dry bulb temperature. The maximum CO₂ concentration on this hottest day is
56
57
58
59
60

1
2
3
4 less than 650ppm which means the ventilation is adequate during occupancy. Using equations
5 1 to 3, the daily mean, running mean and indoor comfort maximum temperature limit T_{max}
6 can be calculated at 24.15°C, 24.28°C & 29.81°C respectively (T_{max} is dashed line on the graph).
7 The operative temperatures above the dashed line during occupancy can be added up to
8 calculate W_e . For this case, W_e equal 40 degree hours. The upper limit temperature (T_{upp}) is
9 also an overheating severity criterion. On this peak date, $\Delta T = T_{upp} - T_{max} = 37.49^\circ\text{C} - 29.81^\circ\text{C} =$
10 7.68°C which will be rounded up to 8°C as in Table 6 (Criteria 3).
11
12
13

14 Due to the nature how T_{max} is calculated, T_{max} will always equal or be above 25.1°C . Using
15 T_{max} as a baseline to calculate daily weighted exceedance avoids the possibility that a higher
16 W_e is found on a cooler day, which could happen when calculating maximum 'daily'
17 internal/external temperature difference, as discussed in section 3.1. Therefore, W_e is truly
18 reflecting the maximum extent of overheating on a particular date.
19
20
21

22 Criteria 3, in Table 5, is very difficult to achieve, especially for those pDSY weathers (for cross
23 comparison purposes only, they are not meant to be used in BB101 2006 version). While
24 Criteria 3, in Table 6, is relatively less difficult to achieve. Although this criterion also assesses
25 the maximum indoor operative temperature which is similarly with the maximum indoor air
26 temperature, the difference is that Criteria 3 in Table 6 assesses the temperature difference ΔT
27 rather than the absolute figure of the maximum temperature. Using the adaptive comfort
28 approach, T_{max} varies with outdoor daily running mean temperatures, which makes the target
29 ΔT relatively easier to achieve.
30
31
32

33 Insert Figure 6 here
34

35 4.3 Limitations and future work

36

37 BB101 compliance calculations have always been carried out using dynamic thermal simulation
38 tools in the past, primarily focused on thermal comfort criteria and CO_2 concentration
39 requirements. Such calculations are inevitably influenced by various model assumptions, such
40 as approximations on building facades, operational schedules and the use of weather data.
41 There is increasing research evidence showing the discrepancies between predicted and in-use
42 performance – the so called 'performance gap'.^{29,30} It would be beneficial that such
43 evaluations can be validated by field measurements to improve the confidence of the
44 modelling outputs. However, field measurements are rare and often not comprehensive
45 enough for detailed validation purposes. The validation of the modelling outputs of this
46 research were not possible due to the lack of monitoring data of the existing building. This
47 represents an opportunity to extend this work in the future.
48
49
50
51

52 The new BB101 is not only introducing tighter requirements on thermal comfort and CO_2
53 concentration, but are also putting great emphasis on the IAQ related pollutant control.
54 Explicit requirements are given against various pollutants, which may cause adverse impacts
55 on occupants. It is evident from this research that designs that comply with the BB101 2006
56 criteria, as might be expected, do not necessarily meeting the criteria of the new BB101 2018.
57 For the natural ventilation design of school buildings, systematic assessments are needed to
58
59
60

1
2
3
4 examine the new criteria, and interventions (such as shading, high thermal mass structure,
5 phase change materials, appropriate control on night purging, etc) may well be needed in
6 order to make sure the relevant criteria are met. It is likely that natural ventilation on its own
7 may not be able to maintain the level of comfort needed; mixed mode or demand controlled
8 mechanical ventilation may be needed as a consequence from the tighter requirements of the
9 new BB101. For a more holistic assessment of the new guidance document, the indoor air
10 quality of new designs also needs to be evaluated, which may involve the use of specialized
11 pollutant modelling tools.
12
13
14

15 **5. Conclusions**

16
17 This work sets out to evaluate the new BB101 requirements on school building designs against
18 the requirements from its early version. Both overheating and CO₂ concentrations were
19 examined on an existing naturally ventilated school design. 10 classrooms with various internal
20 heat gains levels were included for the analysis. The used weather data are from London,
21 where overheating in classrooms is more likely to happen in the UK. The 12 weather data from
22 the latest CIBSE release include the Test Reference Years from Heathrow, and Design Summer
23 Years from Gatwick, Heathrow, London Weather Centre and their corresponding projected
24 weather in 2020. Both sets of requirements from BB101 2006 and 2018 were assessed using
25 the school design and there are 120 data outputs in total for each criterion. The data
26 presented in this research clearly indicates that meeting the new requirements from BB101
27 2018 are more difficult than those of the BB101 2006 for natural ventilation school designs.
28 The school model can achieve a pass when using the requirements from BB101 2006 with the
29 relevant Test Reference Year weather. However, in many respects, the design fails to meet the
30 requirements from BB101 2018 when the current and future projected Design Summer Year
31 weather data were used.
32
33
34
35
36

37 The adaptive thermal comfort based criteria from BB101 2018 include the 'Hours of
38 Exceedance – H_e ', 'daily weighted exceedance – W_e ' and ' ΔT ' (represents the difference
39 between the maximum operative temperature T_{upp} and the corresponding maximum allowed
40 comfort temperature T_{max}). For H_e , there are only a few rooms, when using pDSY-1 (a
41 moderate warm summer) in London, that can meet the 40 degree hours target. By comparison,
42 when counting the number of hours over 28°C using Test Reference Year weathers – the
43 requirement from BB101 2006, all the rooms examined are well below the target 120 hours.
44 From the overheating occurrence perspective, the new requirement is more difficult to meet
45 when compared with the earlier requirement.
46
47
48
49

50 For W_e , the results show that there is no likelihood that this criterion can be met for the school
51 design examined. W_e in Table 6 shows the school design exceeded its target value for all the
52 rooms with all the weather data examined (120 data), often by a large margin. This is due to
53 the nature of how W_e is calculated. Even using TRY weather data, the minimum W_e calculated
54 are 10 degree hours which are still much larger than the target 6 degree hours. This raises the
55 question on the practicality of using this criterion to assess overheating in schools. One can
56 safely assume if a design were able to meet this criterion, the other two criteria should have
57
58
59
60

1
2
3
4 been well met automatically. The criterion 'average internal/external temperature difference'
5 from BB101 2006 is also deemed unrealistic in assessing overheating. When the 'average
6 difference' is for the whole summer, it is much easier to achieve but it fails to capture the
7 likelihood of overheating at daily level. If a maximum 'daily' difference between average
8 internal and external temperature were examined, the criterion could be misleading as a
9 cooler day can result a larger daily internal/external temperature difference, but overheating is
10 unlikely to happen.
11
12
13

14 For ΔT criterion, although it assesses the maximum indoor operative temperature - T_{upp} , ΔT is
15 not only determined by T_{upp} but also T_{max} , which varies with the running mean outdoor
16 temperature. For this reason, the ΔT criterion is relatively more achievable when compared
17 with the 'maximum internal temperature' criterion from BB101 2006, which are well
18 evidenced by Criteria 3 in Table 5 & Table 6.
19
20

21 The CO₂ concentration related IAQ criteria do not seem to add much difficulty for school
22 natural ventilation design, although the requirements are stricter in the new version of BB101.
23 Higher CO₂ concentration tends to occur on cooler days, where the ventilation is restricted due
24 to low indoor temperature. This could be easily rectified by providing more appropriate
25 ventilation control strategies, as the given design provides enough provision for ventilation
26 when needed.
27
28
29

30 The new BB101 was published in August 2018. The discussions from this research could be
31 useful in understanding the assessment criteria for school building designs. If assessment
32 criteria were unrealistically strict, few school designs could meet those using naturally
33 ventilated approaches. There is the potential that the industry may stay away from natural
34 ventilation design on this basis. This will undermine the efforts in promoting natural ventilation
35 to achieve energy conservation and better indoor air quality. However, if the requirements are
36 too easy to achieve, naturally ventilated schools will be built, but they will fail to maintain
37 thermal comfort for occupants in practice. This research represents an initial investigation into
38 the proposed guidance document. However, more effort is needed to evaluate these criteria in
39 terms of how practical they are in guiding the future school designs. Clearly from this research,
40 one of the new adaptive thermal comfort criteria – daily weighted exceedance W_e can be
41 arguable as it may be too difficult to achieve due to the nature of how it is calculated. It is also
42 evident that a design is more likely to meet the standard requirements using 'a moderate
43 warm summer' and its projected 2020 counterpart than its corresponding two pDSYs which
44 have either 'a single intense warm spell' or 'a long persistent warmth'.
45
46
47
48
49
50
51

52 **Appendix A**

53
54 Insert Table A1 here

55 **References**

56
57
58
59
60

- 1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
-
- ¹ Coley D, Greeves R & Saxby B. The effect of low ventilation rates on the cognitive function of a primary school class. *International Journal of Ventilation*, 2007, 6(2), pp. 107 – 112.
- ² Bako-Biro Z et al. Ventilation rates in schools and pupils' performance. *Building and Environment*, 2012, Volume 48, pp. 215-223.
- ³ Barrett P, Davies F, Zhang Y & Barrett L. The impact of classroom design on pupils' learning: Final results of a holistic, multi-level analysis. *Building and Environment*, 2015, Volume 89, pp. 118-133
- ⁴ BB101 2006. *Ventilation of School buildings*, 2006, ISBN 011-2711642. s.l.:s.n.
- ⁵ Jenkins D P, Peacock A D & Banfill P. Will future low-carbon schools in the UK have an overheating problem. *Building and Environment*, 2009, Volume 44, pp. 490-501.
- ⁶ Ji Y, Lomas K J & Cook M J. Hybrid ventilation for low energy building design in south China. *Building and Environment*, 2009, Volume 44, pp. 2245-2255.
- ⁷ BB101, 2018. Guidelines on ventilation, thermal comfort and indoor air quality in schools. Version 1, August 2018, Education & Skill Funding Agency, <https://www.gov.uk/government/publications> [Accessed September 2018]
- ⁸ BS EN 15251 2007. *Indoor environmental input parameters for design and assessment of energy performance of buildings addressing indoor air quality, thermal environment, lighting and acoustics*. 2007, s.l.:BSI, EN.
- ⁹ CIBSE TM52, 2013. *The limits of thermal comfort: avoiding overheating in European buildings*. London: The Chartered Institution of Building Services Engineers.
- ¹⁰ CIBSE Guide A 2015. *Environmental design*. London: Chartered Institution of Building Services Engineers
- ¹¹ CIBSE Guide J 2002. *Weather, solar and illuminance data*. London: The Chartered Institution of Building Services and Engineers.
- ¹² Smith S & Hanby V. Methodologies for the generation of design summer years for building energy simulation using UKCP09 probabilistic climate projections. *Building Services Engineer Research & Technology*, 2012, Volume 33, pp. 9-17.
- ¹³ Jetsch M, Levermore G & Parkinson J. Limitations of the CIBSE design summer year approach for delivering representative near-extreme summer weather conditions. *Building Serv. Eng. Res. Technol.*, 2013, Volume 35, pp. 155-169.
- ¹⁴ Jentsch M, Eames M. & Levermore J. Generating near-extreme Summer Reference Years for building performance simulation. *Building Serv. Eng. Res. Technol.*, 2015, Volume 36, pp. 701-727.
- ¹⁵ CIBSE TM49 2014. *Design Summer Years for London*. London: The Chartered Institution of Building Services Engineers.
- ¹⁶ Ji Y, Zhang Y, Korolija I & Fitcher J.. Design summer year weather - outdoor warmth ranking metrics and their numerical verification. 2016, *Building Serv. Eng. Res. Technol.*, 37(6), pp. 639-663.
- ¹⁷ Ji Y, Korolija I & Zhang Y. Thermal responses of single zone offices on existing near-extreme summer weather data. *Building Simulation*, 2017, 11(1), pp. 15-35.
- ¹⁸ Eames M, Ramallo-Gonzalez A & Wood M. An update of the UK's test reference year: The implications of a revised climate on building design. *Building Serv. Eng. Res. Technol.*, 2016, 37(3), pp. 316-333.
- ¹⁹ Eames, M. An update of the UK's design summer years: Probabilistic design summer years for enhanced overheating risk analysis in building design. *Building Serv. Eng. Res. Technol.*, 2016, 37(5), pp. 503-522.
- ²⁰ Virk G, Mylona A, Mavrogianni A & Davies M. Using the new CIBSE design summer years to assess overheating in London: Effect of the urban heat island on design. *Building Serv. Eng. Res. Technol.*, 2015, 36(2), pp. 115-128.
- ²¹ Amoako-Attah J & B-Jahromi A. The impact of Different Weather Files on Lond Detached Residential Building Performance. *Sustainability*, 2016, 8(1194), pp. 1-18.
- ²² Mahony P, Hextall I & Richardson M. 'Building Schools for the Future': Reflections on a new social architecture. *Journal of Education Policy*, 2011, 26(3), pp. 341-360.
- ²³ Mahony P & Hextall I. 'Building Schools for the Future': 'transformation' for social justice or expensive blunder?. *British Educational Research Journal*, 2012, 39(5), pp. 853-871.
- ²⁴ Part L 2010. *Conservation of fuel and power*. s.l.:HM Government.
- ²⁵ Zero Carbon Hub 2009. *Defining a Fabric Energy Efficiency Standard for Zero Carbon Homes*. London: Zero Carbon Hub.
- ²⁶ Passivhaus 2010. *Passivhaus primer: Designer's guide - A guide for the design team and local authorities*. s.l.:Building Research Establishment.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60

²⁷ IESVE 2017. *Integrated Environmental Solutions Virtual Environment*. Available at: www.iesve.com [Accessed November 2017].

²⁸ Lomas K & Ji Y. Resilience of naturally ventilated buildings to climate change: advanced natural ventilation and hospital wards. *Energy and Buildings*, 2009, Volume 41, pp. 629-653

²⁹ Menezes AC, Cripps A, Bouchlaghem D & Buswell R. (2012). Predicted vs. actual energy performance of non-domestic buildings: Using post-occupancy evaluation data to reduce the performance gap. *Applied Energy* 97 (2012) p. 355-364

³⁰ Marshall A., Fitton R., Swan W., Farmer D., Johnston D., Benjaber M., Ji Y. 2017. Domestic building fabric performance: Closing the gap between the in situ measured and modelled performance, *Energy and Buildings*, Volume 150, Pages 307-317, ISSN 0378-7788, <https://doi.org/10.1016/j.enbuild.2017.06.028>

For Peer Review

Table 1 The key differences in IAQ and thermal comfort between the old BB101 and new BB101 for school teaching and learning spaces

	BB101 (2006)	BB101 (2016 2018)	
Ventilation requirement (l/s/p – litre per second per person)	Natural, Mechanical or Hybrid ventilation	Mechanical	Natural
	<ul style="list-style-type: none"> ▪ minimum: 3l/s/p ▪ Minimum daily average: 5l/s/p ▪ System capacity - ability to provide minimum 8l/s/p during occupancy 	8 to 9l/s/p	5l/s/p
CO ₂ concentration	<ul style="list-style-type: none"> ▪ Average during occupancy ≤1500ppm ▪ Maximum ≤5000ppm ▪ Ability to adjust the concentration to 1000ppm. 	<ul style="list-style-type: none"> ▪ Average: ≤1000ppm ▪ Maximum: ≤1500ppm for more than 20 minutes 	<ul style="list-style-type: none"> ▪ Average: ≤1000ppm ▪ Maximum: ≤2000ppm for more than 20 minutes
Thermal comfort criteria – (two out of three criteria need to be met).	<ul style="list-style-type: none"> ▪ Number of hours the air temperature over 28°C ≤120 ▪ Average internal to external temperature difference ≤5°C ▪ Maximum internal air temperature ≤32°C 	<ul style="list-style-type: none"> ▪ Hours of Exceedance (H_e) ≤ 40 ▪ Daily Weighted Exceedance (W_e) ≤ 6 ▪ Upper Limit Temperature (T_{upp} – represents the maximum indoor operative temperature), with condition $\Delta T = T_{upp} - T_{max} \leq 4K$ 	
Weather file	Test Reference Year	Design Summer Year	
Occupancy	9:00 to 15:30 / 1 st May to 31 st Sept	9:00 to 16:00 / 1 st May to 31 st Sept	

Table 2 Construction details and the overall thermal transmittance: U-values

Construction Type	Construction Detail (outside to inside)	U-value (W/m ² K)
External Glazing	6mm glazed panel + 16mm Argon filled gap + 6mm glazed panel	1.09
Zinc Roof	Lightweight metallic cladding 3mm + Plywood (Lightweight) 45mm + Glass Fibre Quilt 200mm + Weatherboard 90mm + EPS Slab 25mm + Gypsum Plasterboard 25mm	0.14
Sarnafil Roof	Lightweight Metallic Cladding 3mm + Dense EPS Slab Insulation 200mm + Cast Concrete (Dense) 200mm + Cavity 200mm + Acoustic Tile HF-ES 10mm	0.12
Internal wall	Fiberboard – Tile & Lay-in Panels + (Gypsum/Plaster Board + Glass-Fibre Quilt Plywood (Lightweight) + Glass-Fibre Quilt + Gypsum/Plaster Board) + Fiberboard – Tile & Lay-in Panels	0.29
External Wall	Plywood Sheathing 36mm + Glass-Fibre Quilt 250mm + Plywood (Lightweight) 18mm + Gypsum Plastering 30mm	0.15
Ground Exposed Floor	London Clay 750mm + Cast Concrete (Dense) 200mm + Screed 10mm + Dense EPS Slab insulation 40mm + EPS Slab 30mm + Fibreboard 20mm + Rubber Tiles 6mm	0.27
Intermediate Floors	Cast Concrete (dense) 200mm + Screed 10mm + EPS Slab 30mm + Fibreboard 20mm + Rubber tiles 6mm	0.62

Table 3 Internal heat gains and occupancy (G, F, S & T mean Ground, First, Second & Third Floor, data were taken from design specifications)

Room	Internal heat gains			FA (m ²)	Total Gain		Occupancy Time
	During occupancy	equipment	Lighting		(W)	(W/m ²)	
G.02	1 Adult + 19 Pupils	250W	10W/m ²	35.6	2120.6	59.5	09:00 to 15:30 Mon To Fri
G.20	1 Adult + 22 Pupils			43.7	2425.9	55.5	
G.22	1 Adult + 19 Pupils			40.3	2166.0	53.8	
F1.17	1 Adult + 23 Pupils	23 (laptops) x 60W + 250W		45.5	3899.3	85.7	
F1.18	1 Adult + 20 Pupils	250W		38.7	2227.6	57.5	
F1.19	1 Adult + 27 Pupils			52.0	2883.8	55.5	
F1.20	1 Adult + 20 Pupils			39.2	2232.8	56.9	
S2.07	1 Adult + 18 Pupils			34.6	2036.2	58.8	
S2.09	1 Adult + 18 Pupils			33.2	2022.8	61.0	
T3.09	1 Adult + 18 Pupils			34.1	2030.1	59.5	

Table 4 The weight cooling degree hours (WCDH) metric for both TRYs and DSYs (the candidate years selected for DSYs are in bracket for both releases)

Locations	WCDHs (selected year)						
	2016 release					2006 release	
	TRY	pDSY-1(2020)	pDSY-1	pDSY-2	pDSY-3	TRY	DSY
Belfast	0	51	28 (2003)	135 (2006)	97 (1995)	0	37 (1999)
Birmingham	340	1120	765 (1989*)	1890 (2006)	1966 (1995)	534	768 (1989*)
Cardiff	144	262	156 (2013)	511 (1995)	966 (1976)	49	44 (1988)
Edinburgh	0	162	109 (1989)	299 (1975)	110 (2006)	48	48 (1997)
Glasgow	12	232	150 (2003)	357 (1975)	346 (1976)	2	42 (1997)
Leeds	314	727	486 (1989)	1356 (1990)	1336 (1995*)	173	1341 (1995*)
London - Gatwick	-	1899	1201 (1989)	2984 (2003)	3547 (1976)	-	-
London - Heathrow	629	2785	1808(1989*)	3146 (2003)	3972 (1976)	886	1816 (1989*)
London – WC	-	1777	1105 (1989)	3133 (2003)	2920 (1976)	-	-
Manchester	146	481	282 (1997)	970 (1990)	1326 (1995)	392	315 (1999)
Newcastle	85	248	176 (1996)	514 (1990)	185 (2006)	135	10 (1999)
Norwich	836	1069	670 (1997)	1332 (1990)	2330 (1976)	361	135 (2004)
Nottingham	482	1295	963 (1996)	1432 (1990)	1951 (1976)	152	158 (2002)
Plymouth	24	162	94 (1984)	267 (1990*)	529 (1976)	2	259 (1990*)
Southampton	187	1053	645 (1989)	1170 (2003)	2061 (1995)	258	58 (1982)
Swindon	239	1125	780 (2013)	1683 (2003)	2320 (1995)	230	248 (1999)

*These individual years appear in both releases. Their WCDHs should, in theory, be exactly the same. Close examinations on these weather years indicate that the dry bulb temperatures have been shifted an hour between the two releases for some reason, which led to the slight differences of WCDHs.

Table 5 Indoor comfort examination using criteria from BB101 2006

Rooms	Criteria 1 - Number of Hours over 28C (Target is ≤120 hours)										
	London TRYs		Gatwick DSYs			Heathrow DSYs			Weather Centre DSYs		
	TRY06	TRY16	pDSY-1	pDSY-2	pDSY-3	pDSY-1	pDSY-2	pDSY-3	pDSY-1	pDSY-2	pDSY-3
G 02	15	15	30	46	72	41	65	83	37	66	76
G 20	77	52	110	102	135	142	158	182	147	175	175
G 22	57	34	74	82	103	110	132	154	118	142	147
F 117	47	39	98	123	130	137	149	168	123	152	142
F 118	32	23	42	70	98	70	92	112	62	96	109
F 119	16	15	31	48	76	43	65	85	37	67	81
F 120	15	13	28	44	73	39	63	83	29	64	79
S 207	21	18	38	60	87	64	83	104	62	89	94
S 209	28	20	44	65	95	68	95	113	65	94	109
T 309	14	16	31	55	82	57	72	95	51	74	87
Rooms	Criteria 2 – Average internal/external temperature difference (target is ≤5°C)										
	London TRYs		Gatwick DSYs			Heathrow DSYs			Weather Centre DSYs		
	TRY06	TRY16	pDSY-1	pDSY-2	pDSY-3	pDSY-1	pDSY-2	pDSY-3	pDSY-1	pDSY-2	pDSY-3
G 02	3.36	3.84	3.48	3.01	3.29	3.74	3.62	3.65	3.92	3.96	3.79
G 20	3.45	3.74	3.39	2.85	3.07	3.83	3.63	3.70	4.06	4.12	3.88
G 22	3.16	3.45	2.99	2.41	2.71	3.42	3.24	3.32	3.65	3.72	3.51
F 117	4.71	5.85	5.73	5.59	5.57	6.07	5.69	5.79	5.75	5.99	5.47
F 118	4.66	4.96	4.97	4.31	4.76	5.18	4.87	5.05	5.24	5.13	5.12
F 119	3.51	3.81	3.66	3.17	3.45	3.89	3.58	3.74	3.89	3.89	3.74
F 120	3.08	3.39	3.18	2.70	2.95	3.44	3.16	3.29	3.48	3.49	3.32
S 207	4.48	4.95	4.68	4.31	4.51	4.94	4.74	4.84	4.99	5.12	4.71
S 209	4.85	5.20	5.13	4.64	5.04	5.32	5.14	5.32	5.36	5.41	5.35
T 309	4.29	4.66	4.51	4.16	4.27	4.81	4.35	4.54	4.59	4.73	4.30
Rooms	Criteria 3 – Maximum internal temperature: target is ≤32°C										
	London TRYs		Gatwick DSYs			Heathrow DSYs			Weather Centre DSYs		
	TRY06	TRY16	pDSY-1	pDSY-2	pDSY-3	pDSY-1	pDSY-2	pDSY-3	pDSY-1	pDSY-2	pDSY-3
G 02	31.71	31.24	33.71	35.57	34.09	33.58	36.74	34.76	33.33	37.66	34.84
G 20	34.29	34.64	36.75	36.87	36.94	36.64	39.57	37.81	36.6	40.58	38.01
G 22	33.72	33.90	35.83	35.79	36.13	35.74	38.66	37.00	35.70	39.67	37.20
F 117	32.69	33.79	36.00	38.24	36.87	35.94	39.01	37.45	35.46	40.10	37.36
F 118	32.88	32.93	35.14	37.17	35.69	35.19	38.42	36.59	34.61	39.35	36.54
F 119	31.86	31.38	34.03	36.24	34.29	33.86	37.05	35.12	33.57	37.92	35.14
F 120	31.62	31.14	33.64	35.61	33.99	33.51	36.62	34.78	33.29	37.51	34.81
S 207	31.85	31.75	33.94	36.14	34.69	33.88	37.09	35.50	33.54	38.04	35.57
S 209	32.25	32.06	34.33	36.55	35.14	34.27	37.55	36.06	34.01	38.38	36.20
T 309	31.49	31.21	33.43	35.81	34.14	33.48	36.62	34.74	33.08	37.63	34.99

Table 6 Indoor comfort examination using criteria from BB101 ~~2016~~2018

Rooms	Criteria 1 – Hours of Exceedance (H_e) \leq 40 hours													
	London TRYS		Gatwick DSYS				Heathrow DSYS				Weather Centre DSYS			
	TRY06	TRY16	2020	-1	-2	-3	2020	-1	-2	-3	2020	-1	-2	-3
G 02	10	9	33	24	35	55	41	30	47	56	36	22	42	47
G 20	63	42	129	96	84	113	149	119	118	135	149	114	127	125
G 22	45	30	90	54	63	81	114	79	96	98	113	80	98	96
F 117	39	33	130	89	107	118	154	116	120	125	137	93	118	108
F 118	33	18	65	42	71	80	84	51	74	84	68	47	69	76
F 119	12	10	35	26	38	59	44	33	49	59	39	25	45	55
F 120	10	9	30	20	32	54	38	23	44	54	33	20	38	48
S 207	15	13	41	32	49	64	60	40	57	69	54	32	60	63
S 209	21	17	55	36	57	79	78	47	69	81	63	42	68	74
T 309	10	11	38	26	41	60	50	33	50	62	44	22	47	52
Rooms	Criteria 2 – Daily weighted exceedance (W_e) \leq 6 degree hours													
	London TRYS		Gatwick DSYS				Heathrow DSYS				Weather Centre DSYS			
	TRY06	TRY16	2020	-1	-2	-3	2020	-1	-2	-3	2020	-1	-2	-3
G 02	14	11	25	19	22	23	22	19	31	19	21	16	36	21
G 20	23	25	38	34	27	34	35	32	43	34	35	31	50	38
G 22	22	19	33	28	22	29	32	26	37	30	29	27	44	32
F 117	20	25	39	34	39	42	38	32	49	40	35	30	51	41
F 118	21	19	35	29	34	33	32	25	42	28	30	25	45	32
F 119	14	11	26	22	27	24	25	19	31	21	22	18	36	23
F 120	14	10	24	19	23	22	20	18	31	19	21	16	32	21
S 207	14	13	26	22	27	28	25	20	36	27	23	18	38	28
S 209	18	17	29	24	29	31	27	22	40	28	26	22	41	32
T 309	12	11	23	19	24	24	23	18	33	21	20	16	35	23
Rooms	Criteria 3 – Upper limit temperature (T_{upp}), with condition $\Delta T = T_{upp} - T_{max} \leq 4K$													
	London TRYS		Gatwick DSYS				Heathrow DSYS				Weather Centre DSYS			
	TRY06	TRY16	2020	-1	-2	-3	2020	-1	-2	-3	2020	-1	-2	-3
G 02	4	3	6	5	6	5	5	5	7	5	5	4	8	5
G 20	6	6	9	8	8	8	8	8	10	8	8	8	11	8
G 22	6	5	8	7	7	7	8	7	9	7	7	7	10	7
F 117	5	5	8	7	9	8	8	7	9	8	7	7	10	8
F 118	5	5	8	7	8	7	7	6	9	7	7	6	10	7
F 119	4	3	6	6	7	5	6	5	7	6	5	5	8	6
F 120	4	3	6	5	6	5	5	5	7	5	5	4	7	5
S 207	4	3	6	5	7	6	6	5	7	6	5	5	8	6
S 209	4	4	6	6	7	6	6	5	8	7	6	5	8	7
T 309	3	3	5	5	6	5	5	4	7	5	5	4	7	5

Table 7 Indoor CO₂ concentration examination using criteria from BB101 2006 & ~~2016~~2018.

Rooms	Maximum CO ₂ concentration: Target ≤ 5000ppm (BB101 2006); ≤2000ppm (BB101 2018)													
	London TRYS		Gatwick DSYS				Heathrow DSYS				Weather Centre DSYS			
	TRY06	TRY16	2020	-1	-2	-3	2020	-1	-2	-3	2020	-1	-2	-3
G 02	2627	1851	2021	2012	2144	2170	1837	1839	2021	2753	1916	1913	1886	1914
G 20	1745	1389	1528	1573	1886	1687	1337	1393	1423	1347	1340	1343	1343	1351
G 22	1708	1331	1740	1711	1773	1730	1322	1310	1362	1284	1260	1274	1280	1286
F 117	1115	1145	1001	1070	1294	1126	952	958	1137	1081	898	993	1074	1068
F 118	1853	1845	1537	1936	1980	1888	1219	1522	1625	1543	1244	1549	1545	1504
F 119	1475	1539	1503	1513	1645	1506	1471	1470	1520	1476	1450	1448	1501	1472
F 120	1399	1423	1422	1423	1562	1423	1371	1369	1413	1402	1346	1350	1397	1392
S 207	1863	2738	1139	1633	2453	1937	1061	1239	1777	1552	1050	1119	1171	1646
S 209	1927	2228	1097	1565	2335	2168	1005	1091	1582	1223	991	1075	1103	1216
T 309	1840	2224	1161	1614	2120	1758	1031	1077	1786	1925	1032	1189	1387	1756
Rooms	Maximum daily average CO ₂ : Target ≤ 1500ppm (BB101 2006); ≤1000ppm (BB101 2018)													
	London TRYS		Gatwick DSYS				Heathrow DSYS				Weather Centre DSYS			
	TRY06	TRY16	2020	-1	-2	-3	2020	-1	-2	-3	2020	-1	-2	-3
G 02	1454	1393	1250	1371	1399	1481	1096	1210	1256	1230	1152	1283	1160	1221
G 20	1179	1137	1282	1283	1445	1287	1116	1126	1154	1130	1109	1117	1136	1118
G 22	1109	1086	1292	1302	1386	1262	1069	1077	1106	1086	1067	1073	1088	1073
F 117	866	989	766	812	944	901	724	773	826	853	745	805	799	839
F 118	1112	1218	987	1092	1176	1077	859	971	986	1014	857	990	910	1022
F 119	1181	1225	1069	1157	1180	1221	995	1073	1081	1101	979	1067	1028	1134
F 120	1161	1158	1134	1194	1234	1179	1047	1103	1106	1116	1022	1096	1067	1108
S 207	1156	1283	939	1065	1389	1216	905	976	1084	1030	867	928	929	1079
S 209	1114	1273	927	1051	1344	1128	852	908	967	964	835	901	916	956
T 309	1169	1515	919	1035	1280	1346	866	919	1037	1186	806	872	933	1228

Appendix A

Table A1. List of ventilation openings and their characteristics (Cd is the discharge coefficients)

Room	Opening Type	Free Area (m ²)	Cd	Opening Period
G02	1 No. Louvre (inlet)	0.112	0.4	09:00 to 15:30, Mon To Fri ^{*2}
	1 No. Transfer Louvre	0.192	0.55	00:00 to 24:00, Mon to Sun
	1 No. Airstract ^{*1} (Roof terminal)	0.368	0.61	00:00 to 24:00, Mon to Sun
	3 No. Openable windows ^{*4}	4.3	0.61	09:00 to 15:30, Mon To Fri ^{*3}
G20	8 No. Louvre (inlet)	0.136 by 8	0.4	09:00 to 15:30, Mon To Fri ^{*2}
	1 No. Transfer Louvre	0.201	0.55	00:00 to 24:00, Mon to Sun
	2 No. Louvre (exhaust)	0.274 by 2	0.4	00:00 to 24:00, Mon to Sun
	0 No. Openable windows ^{*4}	-	0.61	09:00 to 15:30, Mon To Fri ^{*3}
G22	8 No. Louvre (inlet)	0.136 by 8	0.4	09:00 to 15:30, Mon To Fri ^{*2}
	1 No. Transfer Louvre	0.201	0.55	00:00 to 24:00, Mon to Sun
	2 No. Louvre (exhaust)	0.274 by 2	0.4	00:00 to 24:00, Mon to Sun
	0 No. Openable windows ^{*4}	-	0.61	09:00 to 15:30, Mon To Fri ^{*3}
F117	1 No. Louvre (inlet)	0.112	0.4	09:00 to 15:30, Mon To Fri ^{*2}
	1 No. Transfer Louvre	0.201	0.55	00:00 to 24:00, Mon to Sun
	1 No. Airstract ^{*1} (Roof terminal)	0.368	0.4	00:00 to 24:00, Mon to Sun
	4 No. Openable windows ^{*4}	3.08	0.61	09:00 to 15:30, Mon To Fri ^{*3}
F118	1 No. Louvre (inlet)	0.112	0.4	09:00 to 15:30, Mon To Fri ^{*2}
	1 No. Transfer Louvre	0.201	0.55	00:00 to 24:00, Mon to Sun
	2 No. Louvre (exhaust)	0.238 by 2	0.4	00:00 to 24:00, Mon to Sun
	4 No. Openable windows ^{*4}	3.89	0.61	09:00 to 15:30, Mon To Fri ^{*3}
F119	1 No. Louvre (inlet)	0.112	0.4	09:00 to 15:30, Mon To Fri ^{*2}
	1 No. Transfer Louvre	0.201	0.55	00:00 to 24:00, Mon to Sun
	2 No. Louvre (exhaust)	0.238 by 2	0.4	00:00 to 24:00, Mon to Sun
	6 No. Openable windows ^{*4}	5.73	0.61	09:00 to 15:30, Mon To Fri ^{*3}
F120	1 No. Louvre (inlet)	0.112	0.4	09:00 to 15:30, Mon To Fri ^{*2}
	1 No. Transfer Louvre	0.201	0.55	00:00 to 24:00, Mon to Sun
	2 No. Louvre (exhaust)	0.238 by 2	0.4	00:00 to 24:00, Mon to Sun
	4 No. Openable windows ^{*4}	3.89	0.61	09:00 to 15:30, Mon To Fri ^{*3}
S207	1 No. Louvre (inlet)	0.112	0.4	09:00 to 15:30, Mon To Fri ^{*2}
	1 No. Transfer Louvre	0.219	0.55	00:00 to 24:00, Mon to Sun
	1 No. Airstract ^{*1} (Roof terminal)	0.368	0.4	00:00 to 24:00, Mon to Sun
	4 No. Openable windows ^{*4}	3.08	0.61	09:00 to 15:30, Mon To Fri ^{*3}
S209	1 No. Louvre (inlet)	0.112	0.4	09:00 to 15:30, Mon To Fri ^{*2}
	1 No. Transfer Louvre	0.219	0.55	00:00 to 24:00, Mon to Sun
	2 No. Louvre (exhaust)	0.256 by 2	0.4	00:00 to 24:00, Mon to Sun
	4 No. Openable windows ^{*4}	3.14	0.61	09:00 to 15:30, Mon To Fri ^{*3}
T309	1 No. Louvre (inlet)	0.112	0.4	09:00 to 15:30, Mon To Fri ^{*2}
	1 No. Transfer Louvre	0.293	0.55	00:00 to 24:00, Mon to Sun
	1 No. Airstract (Roof terminal)	0.384	0.61	00:00 to 24:00, Mon to Sun
	4 No. Openable windows ^{*4}	2.75	0.61	09:00 to 15:30, Mon To Fri ^{*3}

^{*1} The 1 No. 1250x575 Airstract was shared by Rooms G02, F117 & S207.

^{*2} Aircool Louvre opening controlled between 09:00 and 15:30 Monday to Friday and closed at all other times during the winter period, October to April. Opening varies from fully closed to fully open as the CO₂ concentration rises from 800ppm to 2000ppm. Open at night and at weekends during the summer period, May to September, for night cooling

^{*3} Window opening controlled between 09:00 and 15:30 Monday to Friday and closed at all other times during the summer period, May to September inclusive. Opening varies from fully closed to fully open as the temperature rises from 20 °C to 24 °C or the CO₂ concentration rises from 800ppm to 2000ppm

^{*4} The number counted here is the openable windows, they are either 'tilt and turn' windows or 'bottom-hinged' windows. In IES model, the free areas of these windows are the maximum openable areas for these windows. It has been assumed that these areas are achievable in practice.

Figure List:

Fig 1 Plan view of the school with surrounding buildings (left), axonometric view of the school (right).

Fig 2 Floor plan views (second and third floors, the narrow extruded parts were cut off)

Figure 3 Internal variables/External dry bulb temperature for a cooler day (left) and a warmer day (right) for room F117 using the TRY 2016 weather data.

Figure 4 CO₂ concentration, ventilation, and internal/external temperatures for a cooler day (left) and a warmer day (right) for room F117 using the TRY 2016 weather data

Figure 5 Predictions on Hours of Exceedance H_e and the number of hours over 28°C for the 10 rooms with 11 weather data.

Figure 6 Indoor (operative temperature, CO₂, solar gain) and outdoor (dry bulb temperature, cloud cover) parameters on the peak date for room F117 with Heathrow pDSY-3 weather data.

For Peer Review




Fig 1 Plan view of the school with surrounding buildings (left), axonometric view of the school (right).




Fig 2 Floor plan views (second and third floors, the narrow extruded parts were cut off)




Figure 3 Internal variables/External dry bulb temperature for a cooler day (left) and a warmer day (right) for room F117 using the TRY 2016 weather data.




Figure 4 CO₂ concentration, ventilation, and internal/external temperatures for a cooler day (left) and a warmer day (right) for room F117 using the TRY 2016 weather data




Figure 5 Predictions on Hours of Exceedance H_e and the number of hours over 28°C for the 10 rooms with 11 weather data.




Figure 6 Indoor (operative temperature, CO2, solar gain) and outdoor (dry bulb temperature, cloud cover) parameters on the peak date for room F117 with Heathrow pDSY-3 weather data.