

Research Article

Digital Control of a Continuous Stirred Tank Reactor

M. P. Di Ciccio, M. Bottini, and P. Pepe

*Department of Electrical and Information Engineering, University of L'Aquila,
67040 Poggio di Roio (AQ), Italy*

Correspondence should be addressed to P. Pepe, pierdomenico.pepe@univaq.it

Received 4 August 2010; Revised 24 January 2011; Accepted 18 February 2011

Academic Editor: Maria do Rosário de Pinho

Copyright © 2011 M. P. Di Ciccio et al. This is an open access article distributed under the Creative Commons Attribution License, which permits unrestricted use, distribution, and reproduction in any medium, provided the original work is properly cited.

We project a novel digital control law for continuous stirred tank reactors, based on sampled measures of temperatures and reactant concentration, as it happens in practice. The methodology of relative degree preservation under sampling is used. It is proved that a suitably approximated sampled system, obtained by Taylor series expansion and truncation, in closed loop with the projected control law, is asymptotically stable, provided that a condition on the sampling period is verified. Such condition allows for values of the sampling period larger than necessary in practical implementation with usual technology. Many simulations show the high performance of the proposed digital control law.

1. Introduction

The control of the operation of chemical reactors has attracted the attention of researchers for a long time. The underlying motivation relies on the fact that industrial chemical reactors are frequently operated at unstable operating conditions, which often corresponds to optimal process performance [1–19]. Polymerization processes [5] and bioreactors fermentors [18] are important examples of large-scale chemical reactors operated at unstable conditions. As well known, the measures of the reactant concentration cannot be achieved on continuous time. In practice, these measures are available at certain time intervals. It is therefore very important to project control laws which are piecewise constant and are updated at each measures update. That is, for practical use, a digital control law has to be projected. Applications of nonlinear digital control theory to some chemical reactors can be found in [20, 21]. In [11] a discrete-time controller is obtained by linear approximations successively executed at each sampling time, and an application to a continuous stirred tank reactor is shown.

In this paper we deal with a novel digital controller design for a continuous stirred tank reactor, where an irreversible, exothermic, liquid-phase reaction $A \rightarrow B$ evolves. The controlled output is the reactor temperature. The jacket temperature dynamics is considered. The control law is actuated by means of a pneumatic valve which regulates the cooling water flow rate. This actuation process is easier to implement than the ones based on the use of the inlet reactor concentration or of the jacket temperature as manipulated inputs. The model consists of three nonlinear ordinary differential equations. We develop a digital control law by means of a suitably approximated sampled model, obtained by Taylor series expansions (see [21, 22]). The preservation of relative degree methodology shown in [22] is here used. For the underlying continuous time model, the relative degree is not full. The relative degree is preserved for the approximated sampled model by introducing a dummy output. Then a feedback control law is projected, by which the approximated sampled system becomes asymptotically stable. Many performed computer simulations show the high performance of the proposed digital controller. Saturation effects have been taken into account in simulations. The convergence of the state variables to the arbitrarily chosen operating point is always obtained with the many considered system initial conditions (even start-up initial conditions).

2. The Model of the CSTR

Here we study a CSTR with jacket cooling in which a first-order irreversible exothermic reaction takes place [23]: $A \rightarrow B$ (Figure 1).

The liquids in the reactor and in the jacket are assumed perfectly mixed, that is, with no radial, axial, or angular gradients in properties (temperature, concentrations). This allows to consider reactor and jacket temperatures and reactant concentrations as space invariant variables. If physical properties are assumed constant (densities and heat capacities), the reactor volume is constant and the jacket volume is constant, the mathematical model of the CSTR is given by the following set of nonlinear functional differential equations:

$$\begin{aligned}\dot{x}_1(t) &= \frac{F(Ca_0 - x_1(t))}{V_r} - x_1(t)K_0e^{-E/Rx_2(t)}, \\ \dot{x}_2(t) &= \frac{F(T_0 - x_2(t))}{V_r} - \lambda x_1(t)K_0e^{-E/Rx_2(t)}\rho^{-1}C_p^{-1} - \frac{UA_j(x_2(t) - x_3(t))}{V_r\rho C_p}, \\ \dot{x}_3(t) &= \frac{u(t)(T_{\text{cin}} - x_3(t))}{V_j} + \frac{UA_j(x_2(t) - x_3(t))}{V_j\rho_j C_j},\end{aligned}\quad (2.1)$$

where $x_1 = Ca$ = reactant concentration (kmol/m³), $x_2 = T_R$ = reactor temperature (K), $x_3 = T_J$ = jacket temperature (K), u = flow rate of coolant (control input) (m³/s), K_0 = pre-exponential factor (s⁻¹), E = activation energy (J/kmol), R = universal gas constant, 8314 Jkmol⁻¹K⁻¹, F = flow rate of feed and product (m³/s), ρ = density of product stream (kg/m³), Ca_0 = concentration of reactant A in feed (kmol/m³), V_R = volumetric holdup of liquid in reactor (m³), T_0 = temperature of feed (K), C_p = heat capacity of product (Jkg⁻¹K⁻¹), λ = heat of reaction (J/kmol), U = overall heat transfer coefficient (WK⁻¹m⁻²), A_j = jacket heat transfer area (m²), ρ_j = density of coolant (kg/m³), C_j = heat capacity of coolant (Jkg⁻¹K⁻¹), and T_{cin} = supply temperature of cooling medium (K).




Figure 1: Schematic reactor type CSTR.

Let $\varkappa \in [0, 1]$ be the reaction conversion

$$\varkappa = \frac{Ca_0 - Ca}{Ca_0}. \quad (2.2)$$

Let \varkappa_{eq} be the chosen operating point reaction conversion. By (2.2) it follows that the operating point concentration of reactant in the reactor Ca_{eq} is given by

$$Ca_{eq} = Ca_0(1 - \varkappa_{eq}). \quad (2.3)$$

From equations in (2.1), setting zero the left-hand side, it follows that the operating point reactor temperature (T_{Req}), the operating point jacket temperature (T_{jeq}), the necessary coolant water flow rate (u_{eq}) for the chosen operating point are given by

$$\begin{aligned} T_{Req} &= -E \left(\ln \left(-\frac{F(-Ca_0 + Ca_{eq})}{Ca_{eq}K_0V_r} \right) \right)^{-1} R^{-1}, \\ T_{jeq} &= \frac{\lambda Ca_0 F \varkappa_{eq}}{UA_j} - \frac{F \rho C_p T_0}{UA_j} - E \left(\ln \left(\frac{F \varkappa_{eq}}{(1 - \varkappa_{eq})K_0V_r} \right) \right)^{-1} R^{-1} \\ &\quad - F \rho C_p E \left(\ln \left(\frac{F \varkappa_{eq}}{(1 - \varkappa_{eq})K_0V_r} \right) \right)^{-1} R^{-1} U^{-1} A_j^{-1}, \\ u_{eq} &= UA_j E \rho_j^{-1} C_j^{-1} (T_{cin} - T_{jeq})^{-1} \left(\ln \left(\frac{F \varkappa_{eq}}{(1 - \varkappa_{eq})K_0V_r} \right) \right)^{-1} R^{-1} \\ &\quad + \frac{UA_j T_{jeq}}{\rho_j C_j (T_{cin} - T_{jeq})}. \end{aligned} \quad (2.4)$$

3. Sampled System and Digital Control Law

The system (2.1) is in the form

$$\dot{x}(t) = f(x(t)) + g(x(t)) \cdot u(t), \quad (3.1)$$

where the functions f , g can be easily defined by (2.1) as

$$f(x(t)) = \begin{bmatrix} f_1(x(t)) \\ f_2(x(t)) \\ f_3(x(t)) \end{bmatrix} = \begin{bmatrix} \frac{F(Ca_0 - x_1(t))}{V_r} - x_1(t)K_0e^{-E/Rx_2(t)} \\ \frac{F(T_0 - x_2(t))}{V_r} - \lambda x_1(t)K_0e^{-E/Rx_2(t)}\rho^{-1}C_p^{-1} - \frac{UA_j(x_2(t) - x_3(t))}{V_r\rho C_p} \\ \frac{UA_j(x_2(t) - x_3(t))}{V_j\rho_j C_j} \end{bmatrix},$$

$$g(x(t)) = \begin{bmatrix} g_1(x(t)) \\ g_2(x(t)) \\ g_3(x(t)) \end{bmatrix} = \begin{bmatrix} 0 \\ 0 \\ \frac{T_{cin} - x_3(t)}{V_j} \end{bmatrix}. \quad (3.2)$$

In order to rewrite (3.1) in normal form, as required in [22], let us now consider the following variables:

$$\xi(t) = \begin{bmatrix} \xi_1(t) \\ \xi_2(t) \\ \xi_3(t) \end{bmatrix} = \begin{bmatrix} x_2(t) - T_{Req} \\ f_2(x(t)) \\ x_1(t) - Ca_{eq} \end{bmatrix} = \phi(x(t)), \quad (3.3)$$

from which the easy inverse relation holds

$$x(t) = \Phi^{-1}(\xi(t)) = \begin{bmatrix} \xi_3(t) + Ca_{eq} \\ \xi_1(t) + T_{Req} \\ -\frac{F\rho C_p}{UA_j}(T_0 - \xi_1(t) - T_{Req}) \\ +\frac{\lambda V_r(\xi_3(t) + Ca_{eq})K_0e^{-E/R(\xi_1(t)+T_{Req})}}{UA_j} + \frac{\xi_2(t)V_r\rho C_p}{UA_j} + \xi_1(t) + T_{Req} \end{bmatrix}. \quad (3.4)$$

Let the control input be equal to

$$u(t) = u_{eq} + v(t). \quad (3.5)$$

Let the controlled output be

$$y(t) = h(\xi(t)) = \xi_1(t). \quad (3.6)$$

We want to control to zero this output, which corresponds to drive the reactor temperature to the reactor temperature operating point T_{Req} .

We can write the system equations by using the new variables $\xi(t)$ as follows:

$$\dot{\xi}(t) = p_1(\xi(t)) + p_2(\xi(t))v(t), \quad (3.7)$$

where p_1, p_2 are given by

$$p_1(\xi(t)) = \begin{bmatrix} p_{11}(\xi(t)) \\ p_{21}(\xi(t)) \\ p_{31}(\xi(t)) \end{bmatrix},$$

$$p_{11}(\xi(t)) = \xi_2(t),$$

$$\begin{aligned} p_{21}(\xi(t)) = & -\lambda K_0 F C a_0 V_r^{-1} \rho^{-1} C_p^{-1} \left(e^{E/R(\xi_1(t)+T_{Req})} \right)^{-1} - \frac{u_{eq} U A_j \xi_1(t)}{V_j V_r \rho C_p} + \frac{u_{eq} F T_0}{V_j V_r} \\ & + \lambda \xi_3(t) K_0 F V_r^{-1} \rho^{-1} C_p^{-1} \left(e^{E/R(\xi_1(t)+T_{Req})} \right)^{-1} - \frac{u_{eq} U A_j T_{Req}}{V_j V_r \rho C_p} - \frac{u_{eq} F \xi_1(t)}{V_j V_r} \\ & + \lambda K_0 C a_{eq} F V_r^{-1} \rho^{-1} C_p^{-1} \left(e^{E/R(\xi_1(t)+T_{Req})} \right)^{-1} - \frac{u_{eq} \xi_2(t)}{V_j} + \frac{u_{eq} U A_j T_{cin}}{V_j V_r \rho C_p} \\ & + \lambda K_0^2 \xi_3(t) \left(e^{E/R(\xi_1(t)+T_{Req})} \right)^{-2} \rho^{-1} C_p^{-1} - \frac{u_{eq} F T_{Req}}{V_j V_r} - \frac{U A_j \xi_2(t)}{V_j \rho_j C_j} \\ & + \lambda K_0^2 C a_{eq} \left(e^{E/R(\xi_1(t)+T_{Req})} \right)^{-2} \rho^{-1} C_p^{-1} - \frac{\xi_2(t) F}{V_r} \\ & - \xi_2(t) \lambda K_0 E \xi_3(t) \rho^{-1} C_p^{-1} R^{-1} \left(\xi_1(t) + T_{Req} \right)^{-2} \left(e^{E/R(\xi_1(t)+T_{Req})} \right)^{-1} \\ & - \xi_2(t) \lambda K_0 E C a_{eq} \rho^{-1} C_p^{-1} R^{-1} \left(\xi_1(t) + T_{Req} \right)^{-2} \left(e^{E/R(\xi_1(t)+T_{Req})} \right)^{-1} \\ & - \frac{U A_j \xi_2(t)}{V_r \rho C_p} + \frac{U A_j F T_0}{V_j \rho_j C_j V_r} - \frac{U A_j F \xi_1(t)}{V_j \rho_j C_j V_r} - \frac{U A_j F T_{Req}}{V_j \rho_j C_j V_r} \\ & - U A_j \lambda K_0 \xi_3(t) V_j^{-1} \rho_j^{-1} C_j^{-1} \rho^{-1} C_p^{-1} \left(e^{E/R(\xi_1(t)+T_{Req})} \right)^{-1} \\ & - U A_j \lambda K_0 C a_{eq} V_j^{-1} \rho_j^{-1} C_j^{-1} \rho^{-1} C_p^{-1} \left(e^{E/R(\xi_1(t)+T_{Req})} \right)^{-1} \end{aligned}$$

$$\begin{aligned}
& -u_{\text{eq}}\lambda K_0 \xi_3(t) V_j^{-1} \rho^{-1} C_p^{-1} \left(e^{E/R(\xi_1(t)+T_{\text{Req}})} \right)^{-1} \\
& -u_{\text{eq}}\lambda K_0 C a_{\text{eq}} V_j^{-1} \rho^{-1} C_p^{-1} \left(e^{E/R(\xi_1(t)+T_{\text{Req}})} \right)^{-1}, \\
p_{31}(\xi(t)) &= \frac{F(Ca_0 - \xi_3(t) - Ca_{\text{eq}})}{V_r} - (\xi_3(t) + Ca_{\text{eq}}) K_0 e^{-E/R(\xi_1(t)+T_{\text{Req}})}, \\
p_2(\xi(t)) &= \begin{bmatrix} p_{12}(\xi(t)) \\ p_{22}(\xi(t)) \\ p_{32}(\xi(t)) \end{bmatrix}, \\
p_{12}(\xi(t)) &= 0, \\
p_{22}(\xi(t)) &= \frac{T_{\text{cin}} U A_j}{V_j V_r \rho C_p} + \frac{F T_0}{V_j V_r} - \frac{F \xi_1(t)}{V_j V_r} - \frac{F T_{\text{Req}}}{V_j V_r} - \frac{U A_j \xi_1(t)}{V_j V_r \rho C_p} - \frac{T_{\text{Req}} U A_j}{V_j V_r \rho C_p} - \frac{\xi_2(t)}{V_j} \\
& - \lambda K_0 \xi_3(t) V_j^{-1} \rho^{-1} C_p^{-1} \left(e^{E/R(\xi_1(t)+T_{\text{Req}})} \right)^{-1} \\
& - \lambda K_0 C a_{\text{eq}} V_j^{-1} \rho^{-1} C_p^{-1} \left(e^{E/R(\xi_1(t)+T_{\text{Req}})} \right)^{-1}, \\
p_{32}(\xi(t)) &= 0.
\end{aligned} \tag{3.8}$$

Since $\xi = 0$ corresponds to $x = \begin{bmatrix} C a_{\text{eq}} \\ T_{\text{Req}} \\ T_{\text{Jeq}} \end{bmatrix}$, it follows that $p_1(0) = 0$. The introduction of the new variables allows to obtain the CSTR equations in normal form [22], and the origin is an equilibrium point. Therefore, the stability of the origin for the system described by (3.7) is equivalent to the stability of the chosen operating point for the system described by (2.1). Let us now sample and approximate, by Taylor series expansion and truncation, the system (3.7) as follows: setting $v(t) = v(k\delta) = v_k$, $k\delta \leq t < (k+1)\delta$, $k = 0, 1, 2, \dots$,

$$\begin{aligned}
\begin{bmatrix} \tilde{\xi}_1 \\ \tilde{\xi}_2 \end{bmatrix}((k+1)\delta) &= \begin{bmatrix} 1 & \delta \\ 0 & 1 \end{bmatrix} \begin{bmatrix} \tilde{\xi}_1 \\ \tilde{\xi}_2 \end{bmatrix}(k\delta) + \begin{bmatrix} \delta^2 \\ \delta \end{bmatrix} R_0(k\delta), \\
\tilde{\xi}_3((k+1)\delta) &= \tilde{\xi}_3(k\delta) + \delta p_{31}(\tilde{\xi}(k\delta)) + \frac{\delta^2}{2} q(\tilde{\xi}(k\delta)),
\end{aligned} \tag{3.9}$$

where $\tilde{\xi}(k\delta)$ is the approximation of $\xi(k\delta)$; R_0 is given by (Lie derivatives are used),

$$\begin{aligned}
R_0(k\delta) &= l_{p_1}^2 h(\tilde{\xi}(k\delta)) + l_{p_2} l_{p_1} h(\tilde{\xi}(k\delta)) v(k\delta); \\
l_{p_1}^2 h(\tilde{\xi}(k\delta)) &= \frac{\partial l_{p_1}^1 h(\tilde{\xi}(k\delta))}{\partial(\tilde{\xi}(k\delta))} p_1(\tilde{\xi}(k\delta)); \quad l_{p_1}^1 h(\tilde{\xi}(k\delta)) = \frac{\partial h(\tilde{\xi}(k\delta))}{\partial(\tilde{\xi}(k\delta))} p_1(\tilde{\xi}(k\delta)); \\
l_{p_2} l_{p_1} h(\tilde{\xi}(k\delta)) &= \frac{\partial l_{p_1} h(\tilde{\xi}(k\delta))}{\partial(\tilde{\xi}(k\delta))} p_2(\tilde{\xi}(k\delta));
\end{aligned} \tag{3.10}$$

$q(\tilde{\xi}(k\delta))$ is given by

$$\begin{aligned}
q(\tilde{\xi}(k\delta)) &= \frac{\partial p_{31}(\tilde{\xi}(k\delta))}{\partial \tilde{\xi}(k\delta)} p_1(\tilde{\xi}(k\delta)), \\
q(\tilde{\xi}(k\delta)) &= -K_0 E \tilde{\xi}_2(k\delta) \tilde{\xi}_3 R^{-1} (\tilde{\xi}_1(k\delta) + T_{\text{Req}})^{-2} \left(e^{E/R(\tilde{\xi}_1(k\delta) + T_{\text{Req}})} \right)^{-1} \\
&\quad - K_0 E \tilde{\xi}_2(k\delta) C a_{\text{eq}} R^{-1} (\tilde{\xi}_1(k\delta) + T_{\text{Req}})^{-2} \left(e^{E/R(\tilde{\xi}_1(k\delta) + T_{\text{Req}})} \right)^{-1} \\
&\quad - \frac{F^2 C a_0}{V_r^2} + \frac{F^2 \tilde{\xi}_3}{V_r^2} + \frac{F^2 C a_{\text{eq}}}{V_r^2} + 2 F K_0 \tilde{\xi}_3 V_r^{-1} \left(e^{E/R(\tilde{\xi}_1(k\delta) + T_{\text{Req}})} \right)^{-1} \\
&\quad + 2 F K_0 C a_{\text{eq}} V_r^{-1} \left(e^{E/R(\tilde{\xi}_1(k\delta) + T_{\text{Req}})} \right)^{-1} + K_0^2 C a_{\text{eq}} \left(e^{E/R(\tilde{\xi}_1(k\delta) + T_{\text{Req}})} \right)^{-2} \\
&\quad - F K_0 C a_0 V_r^{-1} \left(e^{E/R(\tilde{\xi}_1(k\delta) + T_{\text{Req}})} \right)^{-1} + \tilde{\xi}_3(k\delta) K_0^2 \left(e^{E/R(\tilde{\xi}_1(k\delta) + T_{\text{Req}})} \right)^{-2}.
\end{aligned} \tag{3.11}$$

The approximated sampled system (3.9) is obtained by exploiting the normal form of (3.7) (see [22]) and by neglecting, in the Taylor series expansion, the terms which are $0(\delta^3)$ in the expression of $\xi_1((k+1)\delta)$ and in the expression of $\xi_3((k+1)\delta)$, and the terms which are $0(\delta^2)$ in the expression of $\xi_2((k+1)\delta)$ (see terms $N_{r,\delta}^2$ in [22, Proposition 3.2]). Notice that, since $(\partial p_{31}(\tilde{\xi}(k\delta))/\partial \tilde{\xi}(k\delta)) p_2(\tilde{\xi}(k\delta)) = 0$, the inclusion of a term which is $0(\delta^2)$ in the approximation of $\xi_3((k+1)\delta)$ does not cause a new presence (besides the one in R_0) of the control input v_k . As well, neglecting terms which are $0(\delta^2)$ in the expression of $\xi_2((k+1)\delta)$ avoids to have further terms (besides R_0) which involve the control input. This fact is instrumental for building the digital control law here proposed, as will be shown below.

The approximated sampled system (3.9) admits relative degree equal to 1, thus not preserving the relative degree equal to 2 of the original continuous time system (2.1) with respect to the output $x_2(t)$ (reactor temperature). Thus, a digital input/output linearizing feedback control law built up on the basis of the given output (3.6) yields a further internal dynamics. In order to preserve the relative degree, let us introduce the dummy output as proposed in [22],

$$y_\delta(k\delta) = \begin{bmatrix} 1 & -\frac{\delta}{2} \end{bmatrix} \begin{bmatrix} \tilde{\xi}_1(k\delta) \\ \tilde{\xi}_2(k\delta) \end{bmatrix}, \tag{3.12}$$

and let us define the variables

$$\chi(k) = \begin{bmatrix} \chi_1(k) \\ \chi_2(k) \\ \chi_3(k) \end{bmatrix} = \begin{bmatrix} y_\delta(k\delta) \\ y_\delta((k+1)\delta) \\ \tilde{\xi}_3(k\delta) \end{bmatrix} = M \tilde{\xi}(k\delta), \tag{3.13}$$

where the nonsingular matrix M is given by

$$M = \begin{bmatrix} 1 & -\frac{\delta}{2} & 0 \\ 1 & \frac{\delta}{2} & 0 \\ 0 & 0 & 1 \end{bmatrix}. \quad (3.14)$$

Let M_1 be the upleft submatrix of M

$$M_1 = \begin{bmatrix} 1 & -\frac{\delta}{2} \\ 1 & \frac{\delta}{2} \end{bmatrix}. \quad (3.15)$$

We obtain, from (3.9),

$$\begin{bmatrix} \chi_1(k+1) \\ \chi_2(k+1) \end{bmatrix} = M_1 \begin{bmatrix} 1 & \delta \\ 0 & 1 \end{bmatrix} M_1^{-1} \begin{bmatrix} \chi_1(k) \\ \chi_2(k) \end{bmatrix} + M_1 \begin{bmatrix} \frac{\delta^2}{2} \\ \delta \end{bmatrix} R_0(k\delta), \quad (3.16)$$

$$\chi_3(k+1) = \chi_3(k) + \delta p_{31} (M^{-1} \chi(k)) + \frac{\delta^2}{2} q (M^{-1} \chi(k)),$$

where R_0 , rewritten with the variables χ , becomes

$$R_0(k\delta) = l_{p_1}^2 h(M^{-1} \chi(k)) + l_{p_2} l_{p_1} h(M^{-1} \chi(k)) v_k. \quad (3.17)$$

Theorem 3.1. *Let*

$$\Gamma = [\Gamma_1 \ \Gamma_2] \in \mathbb{R}^{1 \times 2} \quad (3.18)$$

be chosen such that the matrix $\begin{bmatrix} 0 & 1 \\ \Gamma_1 & \Gamma_2 \end{bmatrix}$ has eigenvalues inside the open complex unitary circle. Let the sampling period $\delta > 0$ satisfy the following inequality:

$$\delta < \delta_{\max} = \frac{2}{(F/V_r) + K_0 e^{-E/RT_{\text{req}}}}. \quad (3.19)$$

Then, the following discrete time feedback control law

$$v_k = \frac{-l_{p_1}^2 h(M^{-1} \chi(k))}{l_{p_2} l_{p_1} h(M^{-1} \chi(k))} + \frac{[1 \ -2] \begin{bmatrix} \chi_1(k) \\ \chi_2(k) \end{bmatrix} + \Gamma \begin{bmatrix} \chi_1(k) \\ \chi_2(k) \end{bmatrix}}{\delta^2 l_{p_2} l_{p_1} h(M^{-1} \chi(k))} \quad (3.20)$$

is such that the trivial solution of the closed-loop system (3.16)–(3.20) is asymptotically stable. Moreover, the eigenvalues of the Jacobian (evaluated at 0) of the right-hand function describing the closed-loop system (3.16)–(3.20) are given by the eigenvalues of the matrix $\begin{bmatrix} 0 & 1 \\ \Gamma_1 & \Gamma_2 \end{bmatrix}$ and by the eigenvalue

$$1 - \delta \left(\frac{F}{V_r} + K_0 e^{-E/RT_{\text{req}}} \right) + \frac{\delta^2}{2} \left(\frac{F}{V_r} + K_0 e^{-E/RT_{\text{req}}} \right)^2, \quad (3.21)$$

which takes its minimum, equal to 1/2, at $\delta = \delta_{(1/2)} = 1 / ((F/V_r) + K_0 e^{-E/RT_{\text{req}}})$.

Proof. By the form of the matrix M_1 , the following equation holds for χ_1 and for χ_2 , in (3.16)

$$\begin{bmatrix} \chi_1(k+1) \\ \chi_2(k+1) \end{bmatrix} = \begin{bmatrix} 0 & 1 \\ -1 & 2 \end{bmatrix} \begin{bmatrix} \chi_1(k) \\ \chi_2(k) \end{bmatrix} + \begin{bmatrix} 0 \\ \delta^2 \end{bmatrix} R_0(k\delta). \quad (3.22)$$

Notice that, by construction, such subsystem (and thus the overall system (3.16)) admits relative degree equal to 2, in a neighborhood of the origin, with respect to the dummy output $\chi_1(k)$. Indeed, taking into account of the form of $R_0(k\delta)$, we have

$$\begin{aligned} \chi_1(k+1) &= \chi_2(k+1), \\ \chi_1(k+2) &= \chi_2(k+1) = [-1 \ 2] \chi(k) \\ &\quad + \delta^2 \left(l_{p_1}^2 h(M^{-1} \chi(k)) + l_{p_2} l_{p_1} h(M^{-1} \chi(k)) v(k\delta) \right), \end{aligned} \quad (3.23)$$

and the term multiplying $v(k\delta)$ is nonzero in a neighborhood of the origin, since $l_{p_2} l_{p_1} h(M^{-1} \chi(k))$ is smooth in a neighborhood of the origin and $l_{p_2} l_{p_1} h(0) \neq 0$. Therefore, taking again into account the form of R_0 , the proposed discrete-time feedback control law yields the following equations for the closed-loop-system (3.16), (3.20)

$$\begin{aligned} \begin{bmatrix} \chi_1(k+1) \\ \chi_2(k+1) \end{bmatrix} &= \begin{bmatrix} 0 & 1 \\ \Gamma_1 & \Gamma_2 \end{bmatrix} \begin{bmatrix} \chi_1(k) \\ \chi_2(k) \end{bmatrix}, \\ \chi_3(k+1) &= \chi_3(k) + \delta p_{31} (M^{-1} \chi(k)) + \frac{\delta^2}{2} q(M^{-1} \chi(k)). \end{aligned} \quad (3.24)$$

In order to show the asymptotic stability of the nonlinear system (3.24), it is sufficient to show that the linear system obtained by linearizing (3.24) is asymptotically stable. The Jacobian, at zero, of the function in the right-hand side of (3.24) is given, taking into account of p_{31} and of q , by

$$J = \begin{bmatrix} 0 & 1 & 0 \\ \Gamma_1 & \Gamma_2 & 0 \\ \alpha & \beta & \gamma \end{bmatrix}, \quad (3.25)$$

where

$$\gamma = 1 - \delta \left(\frac{F}{V_r} + K_0 e^{-E/RT_{\text{Req}}} \right) + \frac{\delta^2}{2} \left(\frac{F}{V_r} + K_0 e^{-E/RT_{\text{Req}}} \right)^2 \quad (3.26)$$

and α, β are suitable reals. Given the triangular structure of the Jacobian J , the eigenvalues are given by the eigenvalues of the matrix $\begin{bmatrix} 0 & 1 \\ \Gamma_1 & \Gamma_2 \end{bmatrix}$ and by γ . The eigenvalues of the matrix $\begin{bmatrix} 0 & 1 \\ \Gamma_1 & \Gamma_2 \end{bmatrix}$ are inside the open unitary circle. The eigenvalue γ is always positive (for positive sampling period), and is inside the open unitary circle if the inequality (3.19) is satisfied. Moreover, by using the derivative of γ with respect to δ , we obtain that γ takes the minimum value, 0.5, at $\delta_{(1/2)}$. \square

Now, going back to initial variables x , by means of the (approximated) relation $\chi(k) \approx M\phi^{-1}(x(k\delta))$, the digital feedback control law here proposed is given, for $k\delta \leq t < (k+1)\delta$, $k = 0, 1, 2, \dots$, by

$$\begin{aligned} u(t) = & 4V_j\lambda K_0 F C a_0 (T_{\text{cin}} - x_3(k\delta))^{-1} U^{-1} A_j^{-1} \left(e^{E/Rx_2(k\delta)} \right)^{-1} + 2 \frac{V_j V_r \rho C_p T_{\text{Req}} \Gamma_1}{\delta^2 (T_{\text{cin}} - x_3(k\delta)) U A_j} \\ & - 2 \frac{V_j F x_2(k\delta)}{(T_{\text{cin}} - x_3(k\delta)) V_r} + \frac{V_j \rho C_p F^2 T_0}{(T_{\text{cin}} - x_3(k\delta)) U A_j V_r} - 2 \frac{V_j V_r \rho C_p x_2(k\delta)}{\delta^2 (T_{\text{cin}} - x_3(k\delta)) U A_j} \\ & + 2 \frac{V_j x_2(k\delta)}{\delta (T_{\text{cin}} - x_3(k\delta))} - 2V_j \lambda K_0 F x_1(k\delta) (T_{\text{cin}} - x_3(k\delta))^{-1} U^{-1} A_j^{-1} \left(e^{E/Rx_2(k\delta)} \right)^{-1} \\ & - V_r V_j \lambda K_0^2 x_1(k\delta) (T_{\text{cin}} - x_3(k\delta))^{-1} U^{-1} A_j^{-1} \left(e^{E/Rx_2(k\delta)} \right)^{-2} \\ & + V_j F T_0 \lambda x_1(k\delta) K_0 E (T_{\text{cin}} - x_3(k\delta))^{-1} U^{-1} A_j^{-1} R^{-1} x_2(k\delta)^{-2} \left(e^{E/Rx_2(k\delta)} \right)^{-1} \\ & - V_j \lambda K_0 F x_1(k\delta) E (T_{\text{cin}} - x_3(k\delta))^{-1} U^{-1} A_j^{-1} x_2(k\delta)^{-1} R^{-1} \left(e^{E/Rx_2(k\delta)} \right)^{-1} \\ & - V_r V_j \lambda^2 x_1(k\delta)^2 K_0^2 E (T_{\text{cin}} - x_3(k\delta))^{-1} U^{-1} A_j^{-1} \rho^{-1} C_p^{-1} \left(e^{E/Rx_2(k\delta)} \right)^{-2} \frac{1}{R x_2(k\delta)} \\ & - V_j \lambda x_1(k\delta) K_0 (T_{\text{cin}} - x_3(k\delta))^{-1} \rho^{-1} C_p^{-1} \left(e^{E/Rx_2(k\delta)} \right)^{-1} - 2 \frac{V_j V_r \rho C_p \Gamma_1 x_2(k\delta)}{\delta^2 (T_{\text{cin}} - x_3(k\delta)) U A_j} \\ & - V_j \lambda x_1(k\delta) K_0 E (T_{\text{cin}} - x_3(k\delta))^{-1} \rho^{-1} C_p^{-1} x_2(k\delta)^{-1} R^{-1} \left(e^{E/Rx_2(k\delta)} \right)^{-1} \\ & - \frac{V_j U A_j x_2(k\delta)}{(T_{\text{cin}} - x_3(k\delta)) V_r \rho C_p} + \frac{V_j x_3(k\delta) F}{(T_{\text{cin}} - x_3(k\delta)) V_r} \\ & + \frac{V_j F T_0}{(T_{\text{cin}} - x_3(k\delta)) V_r} - \frac{V_j \rho C_p F^2 x_2(k\delta)}{(T_{\text{cin}} - x_3(k\delta)) U A_j V_r} \\ & + V_j x_3(k\delta) \lambda x_1(k\delta) K_0 E (T_{\text{cin}} - x_3(k\delta))^{-1} \rho^{-1} C_p^{-1} R^{-1} x_2(k\delta)^{-2} \left(e^{E/Rx_2(k\delta)} \right)^{-1} \end{aligned}$$

$$\begin{aligned}
& + \frac{V_j U A_j x_3(k\delta)}{(T_{\text{cin}} - x_3(k\delta)) V_r \rho C_p} - \frac{U A_j x_2(k\delta)}{(T_{\text{cin}} - x_3(k\delta)) \rho_j C_j} + \frac{U A_j x_3(k\delta)}{(T_{\text{cin}} - x_3(k\delta)) \rho_j C_j} \\
& - 2 \frac{V_j x_3(k\delta)}{\delta(T_{\text{cin}} - x_3(k\delta))} + 2 \frac{V_j V_r \rho C_p T_{R_{\text{eq}}}}{\delta^2(T_{\text{cin}} - x_3(k\delta)) U A_j} \\
& - 2 \frac{V_j \rho C_p F T_0}{\delta(T_{\text{cin}} - x_3(k\delta)) U A_j} + 2 \frac{V_j \rho C_p F x_2(k\delta)}{\delta(T_{\text{cin}} - x_3(k\delta)) U A_j} \\
& + 2 V_r V_j \lambda x_1(k\delta) K_0 \delta^{-1} (T_{\text{cin}} - x_3(k\delta))^{-1} U^{-1} A_j^{-1} \left(e^{E/Rx_2(k\delta)} \right)^{-1}.
\end{aligned} \tag{3.27}$$

The digital control law (3.27) is applied to the CSTR system, described by the differential equations (2.1), by means of a zero-order hold device. Such control law can be easily implemented on a microprocessor. It is a static feedback control law, that is, no dynamics are involved. The control law has to be computed at every sampling period which is very much larger than the computation time (many minutes versus some seconds at maximum). The great advantage of this digital control law is also given by the fact that only sampled-data measures, provided by a suitable device, are necessary. Take into account that, in practice, continuous time measures are difficult to obtain, or even impossible. The feedback control law here presented is therefore easily realizable. The closed-loop system (2.1), (3.27) (with the zero-order hold) is simulated in the following section.

4. Simulation Results

Simulations, using MatLab (The MathWorks, Inc.) Software Package, have been carried out to verify the effectiveness of the proposed method. The values of the model parameters used in simulation are given in Table 1 (taken from [23]). In all the carried out simulations, a minimum and a maximum value for the input u , specifically the volumetric flow rate of the refrigerant, is imposed, to take into account of the actuator saturation. It is considered:

$$F_{J \min} \leq u(t) \leq F_{J \max} \tag{4.1}$$

with the following acceptable physical values for a control valve

$$\begin{aligned}
F_{J \min} &= 0.002 \text{ m}^3/\text{s} = 7.2 \text{ m}^3/\text{h}, \\
F_{J \max} &= 0.08 \text{ m}^3/\text{s} = 288 \text{ m}^3/\text{h}.
\end{aligned} \tag{4.2}$$

With these parameters, δ_{\max} in condition (3.19) is equal to 0.57 h, which corresponds to about 34 min. The value of $\delta_{(1/2)}$ is equal to about 0.28 h which corresponds to about 16 min.

Table 1: Reactor and controller parameters values.

$K_0 = 7.47 \times 10^{10} \text{ h}^{-1}$	$Ca_0 = 8.01 \text{ kmol} \cdot \text{m}^{-3}$
$E = 69.71 \times 10^6 \text{ J} \cdot \text{kmol}^{-1}$	$F = 15.76 \text{ m}^3 \cdot \text{h}^{-1}$
$\rho = 801 \text{ kg} \cdot \text{m}^{-3}$	$T_{\text{cin}} = 294 \text{ K}$
$R = 8314 \text{ J} \cdot \text{kmol}^{-1} \cdot \text{K}^{-1}$	$T_0 = 294 \text{ K}$
$\rho_j = 1000 \text{ kg} \cdot \text{m}^{-3}$	$A_j = 45.2 \text{ m}^2$
$C_p = 3137 \text{ J} \cdot \text{kg}^{-1} \cdot \text{K}^{-1}$	$V_r = 30.3 \text{ m}^3$
$C_j = 4183 \text{ J} \cdot \text{kg}^{-1} \cdot \text{K}^{-1}$	$V_j = 9 \text{ m}^3$
$\lambda = -69.71 \times 10^6 \text{ J} \cdot \text{kmol}^{-1}$	$\Gamma_1 = -6 \cdot 10^{-6}$
$U = 3.0636 \times 10^6 \text{ J} \cdot \text{h}^{-1} \cdot \text{m}^{-2} \cdot \text{K}^{-1}$	$\Gamma_2 = -5 \cdot 10^{-3}$

Table 2: Process parameters of Simulation 1.

Reactor operating point	Initial state
$x_{\text{eq}} = 85\%$	$\begin{cases} C_a(t=0) = C_{a_0} \\ T_R(t=0) = T_0 \\ T_J(t=0) = T_{\text{cin}} \end{cases}$
$\delta = 0.1 \text{ h} = 6 \text{ min}$	
$Ca_{\text{eq}} = 1.2015 \text{ kmol} \cdot \text{m}^{-3}$	
$T_{R_{\text{eq}}} = 350 \text{ K}$	
$T_{J_{\text{eq}}} = 312 \text{ K}$	
$u_{\text{eq}} = 69.86 \text{ m}^3 \cdot \text{h}^{-1}$	
Parameters mismatch: absent	

We performed several sets of simulation runs and all showed the high performance of the digital control law here proposed. We choose the reactor conversion $x_{\text{eq}} = 0.85$, to which the following unstable operating point corresponds: $Ca_{\text{eq}} = 1.2015 \text{ kmol/m}^3$, $T_{R_{\text{eq}}} = 350 \text{ K}$, $T_{J_{\text{eq}}} = 312 \text{ K}$, $u_{\text{eq}} = 69.86 \text{ m}^3/\text{h}$. In the simulations here presented, the process is initially assumed to be at the start up, that is $x_1(0) = Ca_0$ (concentration of reactant in feed) = 8.01 kmol/m^3 , $x_2(0) = T_0$ (temperature of feed) = 294 K , $x_3(0) = T_{\text{cin}}$ (supply temperature of cooling medium) = 294 K . This means that the reactor is very far from the operating point.

In Simulation 1 (see Table 2, Figure 2) we consider the reactor at nominal parameters values (see Table 1), without any uncertainty. Figure 2 shows the evolution of the reactant concentration, of the reactor temperature, of the jacket temperature, and of the piecewise constant control signal, respectively, with sampling period equal to 10^{-1} h (6 min).

As can be seen, all the state variables converge to the operating point ones in a very good fashion, without dangerous oscillations. The reactor temperature settling time is estimated from plots to be about 6 h, the steady-state error is equal to 0.

In Simulation 2 (see Table 3, Figure 3) we consider again the reactor at nominal parameters values (see Table 1), without any parameters mismatch, and a sampling period equal to 0.25 h (15 min) is considered. The same desirable convergence to the operating point is achieved, with a reactor temperature settling time of about 8 h. Again no dangerous oscillations appear and the reactor temperature is driven in a very good fashion to the operating point, with steady-state error equal to 0.

In Simulations 3, 4 (see Table 4, Figure 4, and Table 5, Figure 5, resp.) we consider the reactor whose parameters are uncertain, with sampling time again equal to 0.1 h and 0.25 h ,




Figure 2: Results of Simulation 1.

Table 3: Process parameters of Simulation 2.

Reactor operating point	Initial state
$\chi_{eq} = 85\%$	$\begin{cases} C_a(t = 0) = C_{a_0} \\ T_R(t = 0) = T_0 \\ T_J(t = 0) = T_{cin} \end{cases}$
$\delta = 0.25 \text{ h} = 15 \text{ min}$	
$C_{a_{eq}} = 1.2015 \text{ kmol} \cdot \text{m}^{-3}$	
$T_{R_{eq}} = 350 \text{ K}$	
$T_{J_{eq}} = 312 \text{ K}$	
$u_{eq} = 69.86 \text{ m}^3 \cdot \text{h}^{-1}$	
Parameters mismatch: absent	

respectively. We apply the controller obtained using the nominal values of the parameters (see Table 1), to a reactor whose parameter values are different with respect to the nominal ones as reported in Table 5. In this case we observe a reactor temperature steady-state error of about 5 K. Take into account that the parameters mismatch has been deliberately chosen very critical, in order to show the robustness of the proposed controller.

The performed simulations show the high performance of the proposed controller, as evidenced, in the case the reactor parameters are exactly known, by zero steady state error, no dangerous oscillations, good settling time. When parameters mismatch occurs, the proposed controller yields a very good behavior for the reactor, evidenced by small steady-state errors, no dangerous oscillations, and good settling time. We stress the fact that the




Figure 3: Results of Simulation 2.

Table 4: Process parameters of Simulation 3.

Reactor operating point	Initial state
$\chi_{\text{eq}} = 85\%$ $\delta = 0.1 \text{ h} = 6 \text{ min}$ $C_{a\text{eq}} = 1.2015 \text{ kmol} \cdot \text{m}^{-3}$ $T_{R\text{eq}} = 350 \text{ K}$ $T_{J\text{eq}} = 312 \text{ K}$ $u_{\text{eq}} = 69.86 \text{ m}^3 \cdot \text{h}^{-1}$	$\begin{cases} C_a(t=0) = C_{a_0} \\ T_R(t=0) = T_0 \\ T_J(t=0) = T_{\text{cin}} \end{cases}$
Parameters mismatch:	$F = F/1.3, T_0 = T_0 \cdot 1.05;$ $C_{a_0} = C_{a_0}/1.1, T_{\text{cin}} = T_{\text{cin}} \cdot 1.03$ $U = 0.8 \cdot U$

proposed controller allows for sampled-data measures of the state variables, which is very useful in practical applications.

5. Conclusion

In this paper we have presented a digital control law for a continuous stirred tank reactor, constructed on the basis of an approximated sampled model and of the preservation of the

Table 5: Process parameters of Simulation 4.

Reactor operating point	Initial state
$\chi_{eq} = 85\%$ $\delta = 0.25 \text{ h} = 15 \text{ min}$ $C_{a_{eq}} = 1.2015 \text{ kmol} \cdot \text{m}^{-3}$ $T_{R_{eq}} = 350 \text{ K}$ $T_{J_{eq}} = 312 \text{ K}$ $u_{eq} = 69.86 \text{ m}^3 \cdot \text{h}^{-1}$	$\begin{cases} C_a(t=0) = C_{a_0} \\ T_R(t=0) = T_0 \\ T_J(t=0) = T_{cin} \end{cases}$
Parameters mismatch:	$F = F/1.3, T_0 = T_0 \cdot 1.05,$ $C_{a_0} = C_{a_0}/1.1, T_{cin} = T_{cin} \cdot 1.03,$ $U = 0.8 \cdot U$




Figure 4: Results of Simulation 3.

relative degree methodology. The proposed feedback control law is easy to implement and simulations show high performance. A condition on the sampling period is found, by which the asymptotic stability of the closed-loop approximated sampled system is proved. Such condition is verified by sampling periods belonging to feasible sets, allowing for values larger than necessary in practical implementation. Future work will concern the construction of a discrete-time observer, in order to avoid reactant concentration measures, which are difficult




Figure 5: Results of Simulation 4.

to do and expensive (see [24–27]). Another topic which will be investigated is the problem arising by the recycle time-delay (see [21, 28–31]), on the basis of the results in [32].

Acknowledgments

This paper is supported by the University of L'Aquila Atheneum RIA Project and by the Center of Excellence for Research DEWS, L'Aquila, Italy.

References

- [1] K. Adebekun, "Output feedback control of a stirred tank reactor," *Computers and Chemical Engineering*, vol. 20, no. 8, pp. 1017–1021, 1996.
- [2] R. Aguilar, R. Martínez-Guerra, and A. Poznyak, "PI observers for uncertainty estimation in continuous chemical reactors," in *Proceedings of the IEEE International Conference on Control Applications (CCA '01)*, pp. 1037–1041, México City, Mexico, September 2001.
- [3] J. Alvarez-Ramirez and A. Morales, "PI control of continuously stirred tank reactors: stability and performance," *Chemical Engineering Science*, vol. 55, no. 22, pp. 5497–5507, 2000.
- [4] A. K. Jana, "Nonlinear state estimation and generic model control of a continuous stirred tank reactor," *International Journal of Chemical Reactor Engineering*, vol. 5, article A42, 2007.
- [5] N. Assala, F. Viel, and J. P. Gauthier, "Stabilization of polymerization CSTR under input constraints," *Computers and Chemical Engineering*, vol. 21, no. 5, pp. 501–509, 1996.

- [6] J. S. Chang and K. Y. Chen, "An integrated strategy for early detection of hazardous states in chemical reactors," *Chemical Engineering Journal*, vol. 98, no. 3, pp. 199–211, 2004.
- [7] C.-T. Chen and S.-T. Peng, "A sliding mode control scheme for non-minimum phase non-linear uncertain input-delay chemical processes," *Journal of Process Control*, vol. 16, no. 1, pp. 37–51, 2006.
- [8] B. Daaou, A. Mansouri, M. Bouhamida, and M. Chenafa, "A robust nonlinear observer for state variables estimation in multi-input multi-output chemical reactors," *International Journal of Chemical Reactor Engineering*, vol. 6, article A86, 2008.
- [9] D. Fissore, "Robust control in presence of parametric uncertainties: observer-based feedback controller design," *Chemical Engineering Science*, vol. 63, no. 7, pp. 1890–1900, 2008.
- [10] A. M. Gibon-Fargeot, F. Celle-Couenne, and H. Hammouri, "Cascade estimation design for CSTR models," *Computers and Chemical Engineering*, vol. 24, no. 11, pp. 2355–2366, 2000.
- [11] Y. Hashimoto, K. Matsumoto, T. Matsuo, T. Hamaguchi, A. Yoneya, and Y. Togari, "Anti-saturation discrete-time nonlinear controllers and observers," *Computers and Chemical Engineering*, vol. 24, no. 2-7, pp. 815–821, 2000.
- [12] N. M. Iyer and A. E. Farrell, "Indirect schemes for adaptive linearizing control of a continuous stirred tank reactor," in *Proceedings of the 26th Southeastern Symposium on System Theory*, pp. 623–627, March 1994.
- [13] K. A. Kosanovich, M. J. Piovoso, V. Rokhlenko, and A. Guez, "Nonlinear adaptive control with parameter estimation of a CSTR," *Journal of Process Control*, vol. 5, no. 3, pp. 137–148, 1995.
- [14] C. Kravaris, P. Daoutidis, and R. A. Wright, "Output feedback control of nonminimum-phase nonlinear processes," *Chemical Engineering Science*, vol. 49, no. 13, pp. 2107–2122, 1994.
- [15] F. Pierri, F. Caccavale, M. Iamarino, and V. Tufano, "A controller-observer scheme for adaptive control of chemical batch reactors," in *Proceedings of the American Control Conference*, pp. 5524–5529, Minneapolis, Minn, USA, June 2006.
- [16] J. Prakash and R. Senthil, "Design of observer based nonlinear model predictive controller for a continuous stirred tank reactor," *Journal of Process Control*, vol. 18, no. 5, pp. 504–514, 2008.
- [17] R. Senthil, K. Janarthanan, and J. Prakash, "Nonlinear state estimation using fuzzy Kalman filter," *Industrial and Engineering Chemistry Research*, vol. 45, no. 25, pp. 8678–8688, 2006.
- [18] M. Soroush, "Nonlinear state-observer design with application to reactors," *Chemical Engineering Science*, vol. 52, no. 3, pp. 387–404, 1997.
- [19] R. A. Wright and C. Kravaris, "Two-degree-of-freedom output feedback controllers for discrete-time nonlinear systems," *Chemical Engineering Science*, vol. 61, no. 14, pp. 4676–4688, 2006.
- [20] J. P. García-Sandoval, V. González-Álvarez, B. Castillo-Toledo, and C. Pelayo-Ortiz, "Robust discrete control of nonlinear processes: application to chemical reactors," *Computers and Chemical Engineering*, vol. 32, no. 12, pp. 3246–3253, 2008.
- [21] Y. H. Choi, Y. C. Kim, and K. T. Chong, "Output feedback controller design for input time-delayed nonlinear system," *Journal of Mechanical Science and Technology*, vol. 21, no. 12, pp. 2059–2065, 2007.
- [22] J. P. Barbot, S. Monaco, and D. Normand-Cyrot, "A sampled normal form for feedback linearization," *Mathematics of Control, Signals, and Systems*, vol. 9, no. 2, pp. 162–188, 1996.
- [23] W. L. Luyben, *Chemical Reactor Design*, John Wiley & Sons, New York, NY, USA, 2007.
- [24] C. Antoniadis and P. D. Christofides, "Feedback control of nonlinear differential difference equation systems," *Chemical Engineering Science*, vol. 54, no. 23, pp. 5677–5709, 1999.
- [25] S. I. Biagiola and J. L. Figueroa, "A high gain nonlinear observer: application to the control of an unstable nonlinear process," *Computers and Chemical Engineering*, vol. 28, no. 9, pp. 1881–1898, 2004.
- [26] S. Salehi and M. Shahrokhi, "Two observer-based nonlinear control approaches for temperature control of a class of continuous stirred tank reactors," *Chemical Engineering Science*, vol. 63, no. 2, pp. 395–403, 2008.
- [27] M. P. Di Ciccio, M. Bottini, P. Pepe, and P. U. Foscolo, "Observer-based control of a continuous stirred tank reactor with recycle time delay," in *Proceedings of the 14th IFAC Conference on Methods and Models in Automation and Robotics*, Miedzydroje, Poland, 2009.
- [28] B. Lehman, I. Widjaya, and K. Shujaaee, "Vibrational control of chemical reactions in a CSTR with delayed recycle stream," *Journal of Mathematical Analysis and Applications*, vol. 193, no. 1, pp. 28–59, 1995.
- [29] W. Wu, "Finite difference-based output feedback control for a class of nonlinear systems with sampling time-delay," *Journal of Process Control*, vol. 19, no. 5, pp. 906–913, 2009.

- [30] W. Wu, "Systematic design of nonlinear controllers for a nonisothermal CSTR with delay in the recycle stream," *Journal of the Chinese Institute of Chemical Engineers*, vol. 30, no. 1, pp. 11–21, 1999.
- [31] P. Pepe, "A robust state feedback control law for a continuous stirred tank reactor with recycle," in *Topics in Time Delay Systems*, vol. 388 of *Lecture Notes in Control and Inform. Sci.*, pp. 281–291, Springer, Berlin, Germany, 2009.
- [32] P. Pepe, "Preservation of the full relative degree for a class of delay systems under sampling," *Journal of Dynamic Systems, Measurement and Control*, vol. 125, no. 2, pp. 267–270, 2003.



Hindawi

Submit your manuscripts at
<http://www.hindawi.com>

