

Adaptive voltage regulation of an inverter-based power distribution network with a class of droop controllers

Citation for published version (APA):

Chong, M. S., & Sandberg, H. (2020). Adaptive voltage regulation of an inverter-based power distribution network with a class of droop controllers. *IFAC-PapersOnLine*, 53(2), 12416-12421.
<https://doi.org/10.1016/j.ifacol.2020.12.1301>

Document license:

CC BY-NC-ND

DOI:

[10.1016/j.ifacol.2020.12.1301](https://doi.org/10.1016/j.ifacol.2020.12.1301)

Document status and date:

Published: 01/01/2020

Document Version:

Publisher's PDF, also known as Version of Record (includes final page, issue and volume numbers)

Please check the document version of this publication:

- A submitted manuscript is the version of the article upon submission and before peer-review. There can be important differences between the submitted version and the official published version of record. People interested in the research are advised to contact the author for the final version of the publication, or visit the DOI to the publisher's website.
- The final author version and the galley proof are versions of the publication after peer review.
- The final published version features the final layout of the paper including the volume, issue and page numbers.

[Link to publication](#)

General rights

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain
- You may freely distribute the URL identifying the publication in the public portal.

If the publication is distributed under the terms of Article 25fa of the Dutch Copyright Act, indicated by the "Taverne" license above, please follow below link for the End User Agreement:

www.tue.nl/taverne

Take down policy

If you believe that this document breaches copyright please contact us at:

openaccess@tue.nl

providing details and we will investigate your claim.

Adaptive voltage regulation of an inverter-based power distribution network with a class of droop controllers^{*}

Michelle S. Chong^{*} Henrik Sandberg^{**}

^{*} *Department of Mechanical Engineering, Eindhoven University of Technology, the Netherlands. m.s.t.chong@tue.nl*

^{**} *Division of Decision and Control Systems, KTH Royal Institute of Technology, Sweden. hsan@kth.se*

Abstract: The voltage received by each customer connected to a power distribution line with local controllers (inverters) is regulated to be within a desired margin through a class of slope-restricted controllers, known conventionally as *droop* controllers. We adapt the design of the droop controllers according to the known bounds of the net power consumption of each customer in each observation time window. A sufficient condition for voltage regulation is provided for each time window, which guides the design of the droop controllers, depending on the properties of the distribution line (line impedances) and the upper bound of all the customers' power consumption during each time window. The resulting adaptive scheme is verified on a benchmark model of a European low-voltage network by the CIGRE task force.

Copyright © 2020 The Authors. This is an open access article under the CC BY-NC-ND license (<http://creativecommons.org/licenses/by-nc-nd/4.0>)

Keywords: power distribution; power-system control; nonlinear control.

1. INTRODUCTION

The proliferation of harnessing renewable energy sources such as solar and wind at the customer end has been motivated by meeting environmental sustainability goals in lieu of being financially viable. This is actuated via connecting alternating current/direct current (AC/DC) inverters which are co-located with the customer to the power distribution network, see Lopes et al. (2007). As a result, the customer departs from the traditional role of being merely a consumer, as the customer can now have a dual role of also being a producer. Consequently, fluctuations outside of the safety margin in the voltage received by the customer can occur, especially when there are many customers. Therefore, this calls for a systematic design of the local inverters (controllers) to guarantee that the voltages at the customer end are within a safety margin specified by the operator.

This paper concentrates on regulating the voltage level of each customer connected to a power distribution network in a line configuration, which is achieved by adapting the controller design based on each customer's projected power consumption. In this setup, power is delivered to each customer with the substation at the head of the line, and the customers connect to line sequentially, as shown in Figure 1. A nominal voltage \bar{v} is communicated by the substation to each inverter, which injects reactive power by employing the so-called droop controllers, which has been used for voltage regulation in Andr n et al. (2015); Turitsyn et al. (2010); Simpson-Porco et al. (2017); Farivar et al. (2013); Jahangiri and Aliprantis (2013); Han et al.

(2017); Zhu and Liu (2016); Liu et al. (2008); Schiffer et al. (2014); Jafarian et al. (2018), to name a few.

In our previous papers, Chong et al. (2019b) and Chong et al. (2019a), we showed that voltage regulation can be guaranteed with a class of slope-restricted droop controllers, which differs from the conventional droop controllers used in the literature listed earlier, in two ways: (i) the input to the controller is the difference of the *squared* received and nominal voltages, and (ii) a class of droop functions satisfying a slope restriction property is identified, which expands beyond the piecewise continuous saturation function used in the literature. Further, a sufficient condition for voltage regulation uses only the upper bound of all the customers' net power consumption, which has the additional benefit of preserving privacy. A drawback of our previous results is a sufficient condition that is overly conservative, resulting in a higher than needed generation of reactive power by the controllers. In this paper, we consider finite observation time windows, where the upper bounds of the customers' power consumption is known beforehand. This allows us to adapt the design of our class of droop controllers, while still guaranteeing that all the customer's voltage are within a desired margin of the nominal voltage. This adaptive scheme is tested on a benchmark model of the residential feeder of a European low-voltage distribution line, and shown in simulations that less reactive power needs to be generated by the controllers. Additionally, more active power can be injected into the line, which increases the revenue of each customer.

The remainder of the paper is structured as follows. We first introduce the notations used, followed by Section 2 where we present a model of a power distribution line

^{*} This work is supported in part by the Swedish Research Council (grant 2016-0861), the Swedish Energy Agency (project LarGo!), and the Swedish Civil Contingencies Agency (project CERCES).

with inverters. The voltage regulation objective is then stated in Section 3, which is achieved via local injection of reactive power into the distribution network by the inverters. In Section 4, we present a scheme that adapts each local controllers' droop characteristics according to the a priori known bounds on the net active power and consumed reactive power during an observation window. We then verify this adaptive scheme on a benchmark model in Section 5 and show in simulations that the adaptive scheme performs better than the non-adaptive scheme according to two performance metrics. Section 6 concludes the paper with discussions for future work.

Notation Let $\mathbb{R} = (-\infty, \infty)$, $\mathbb{R}_{\geq 0} = [0, \infty)$, $\mathbb{R}_{> 0} = (0, \infty)$, $\mathbb{N} = \{0, 1, \dots\}$. Let the set of complex numbers be denoted by \mathbb{C} . We denote the set of integers $\{i, i+1, i+2, \dots, i+k\}$ as $\mathbb{N}_{[i, i+k]}$. Let (u, v) where $u \in \mathbb{R}^{n_u}$ and $v \in \mathbb{R}^{n_v}$ denote the vector $(u^T, v^T)^T$. The identity matrix of dimension n is denoted by \mathbb{I}_n and a matrix of dimension m by n with all elements 1 is denoted by $\mathbf{1}_{m \times n}$. A diagonal matrix with elements d_i , $i \in \mathbb{N}_{[1, n]}$ is denoted by $\text{diag}(d_1, d_2, \dots, d_n)$. Given a symmetric matrix P , its maximum (minimum) eigenvalue is denoted by $\lambda_{\max}(P)$ ($\lambda_{\min}(P)$). The infinity norm of a vector $x \in \mathbb{R}^n$, is denoted $|x| := \max_{i \in \mathbb{N}_{[1, n]}} |x_i|$ and for a matrix $A \in \mathbb{R}^{n \times n}$, $|A| := \max_{i \in \mathbb{N}_{[1, n]}} \sum_{j \in \mathbb{N}_{[1, n]}} |a_{ij}|$, where a_{ij} is the row i -th and column j -th element of matrix A .

2. MODEL OF A POWER DISTRIBUTION LINE WITH INVERTERS

We consider a model of a distribution grid infrastructure with N customers feeding into a low-voltage (LV) grid in a line configuration, as shown in Figure 1. Each customer $i \in \mathbb{N}_{[1, N]}$ has a renewable energy source such as a photovoltaic cell, modelled as a controllable voltage source (Simpson-Porco et al., 2017). Each renewable energy source is equipped with an inverter¹ which is able to generate reactive power $q_{g,i}$ while generating near maximum active power $\rho_{g,i}$.

For each customer $i \in \mathbb{N}_{[1, N]}$, the received voltage level is v_i and the voltage level at the point of connection with the distribution line is v'_i , with a corresponding line impedance $Z'_i = R'_i + jX'_i$ in between customer i and the connection point on the distribution line, where $R'_i \in \mathbb{R}_{\geq 0}$ is the resistance and $X'_i \in \mathbb{R}_{\geq 0}$ is the reactance. In between each connection point, the corresponding line impedance is $Z_i = R_i + jX_i$, where $R_i \in \mathbb{R}_{\geq 0}$ is the resistance and $X_i \in \mathbb{R}_{\geq 0}$ is the reactance. Each customer has a load which can consume reactive $q_{c,i}$ and active powers $\rho_{c,i}$, independently of the generated reactive $q_{g,i}$ and active powers $\rho_{g,i}$.

Under the assumption that the power losses in the distribution lines are negligible, we use the linearized DistFlow model in Baran and Wu (1989) for describing the power

¹ This is enforced by curtailing the generated active power $\rho_{g,i}$ based on the generated reactive power $q_{g,i}$ and the power rating of the inverter, known as the apparent power \bar{s}_i , according to $\rho_{g,i} \leq \sqrt{\bar{s}_i^2 - q_{g,i}^2}$




Fig. 1. Infrastructure of the low-voltage distribution grid.

flow in a line configuration². Additionally, we also model the point-to-point voltages of the connection point at the distribution line v'_i and the customer's end v_i in the last equation of (1). The relationship between the power flow and point-to-point voltage of key nodes of interest $i \in \mathbb{N}_{[0, N]}$, in Figure 1 is

$$\begin{aligned} P_{i+1} &= P_i + \rho_{i+1}, \\ Q_{i+1} &= Q_i + q_{i+1}, \\ v'_{i+1} &= v_i{}^2 - 2\beta_i(P_i, Q_i), \\ v_i{}^2 &= v_{i-1}{}^2 - 2\beta'_{i-1}(\rho_i, q_i), \end{aligned} \quad (1)$$

where P_i and Q_i are the respective total active and reactive powers flowing from customer i to customer $i+1$; $\rho_i := \rho_{g,i} - \rho_{c,i}$ and $q_i := q_{g,i} - q_{c,i}$ are the net injection of the respective active and reactive power into the distribution line from customer i ; $\beta_i(r, s) := R_i r + X_i s$ and $\beta'_i(r, s) := R'_i r + X'_i s$ with $\beta'_{-1}(r, s) = 0$ for all $r, s \in \mathbb{R}$.

Our modelling assumptions are stated in Assumption 1 below.

Assumption 1. (Modelling assumptions). For each customer $i \in \mathbb{N}_{[1, N]}$:

- (i) The reactive power $q_{c,i}$ consumed by each customer i is bounded and the bound Δ_c is known, i.e. $|q_{c,i}(t)| \leq \Delta_c$, for all $t \geq 0$.
- (ii) The net injected active power ρ_i is bounded and the bound Δ_ρ is known, i.e. $|\rho_i(t)| \leq \Delta_\rho$, for all $t \geq 0$.
- (iii) The node voltages at the receiving end v_i for each customer i is locally measurable.
- (iv) The nominal voltage reference \bar{v} is communicated to each customer i .

² The nonlinear terms in the DistFlow model by Baran and Wu (1989) capture the power losses in the distribution lines, which we assume are negligible.

3. PROBLEM FORMULATION

We aim to regulate the customers' received voltage levels v_i for $i \in \mathbb{N}_{[1,N]}$, such that it lies within a safe operating range of the reference voltage communicated to each customer, $\bar{v} \in \mathbb{R}$, i.e. for a given $\delta \geq 0$,

$$\bar{v} - \delta \leq v_i(t) \leq \bar{v} + \delta, \quad \forall t \geq 0. \quad (2)$$

This is achieved by only managing the flow of the reactive powers Q_i in the distribution grid. To this end, controllers Σ_i (actuated by the inverters) are designed for each customer, which is also known in the literature such as in Andr en et al. (2015), as droop control. In Chong et al. (2019a), we showed that a class of slope-restricted droop controllers can be designed to achieve the voltage regulation objective (2), for the power distribution model considered in this paper.

In this paper, we consider the case where we update the droop controllers Σ_i at discrete time instants t_k , $k \in \mathbb{N}$, due to new information about the bounds on the power consumption (Δ_c and Δ_ρ respectively. Cf. Assumption 1). Without loss of generality, we consider $t_0 = 0$ and assume that the observation time window $[t_k, t_{k+1})$ is sufficiently large such that no Zeno phenomenon may occur. Further, the bounds are known a priori for each observation window $[t_k, t_{k+1})$. For example, power consumption in a commercial district peaks during business hours and declines after hours. The motivation behind this setup is to adapt our controllers to the known bounds on the power consumption for certain time epochs. We denote these bounds on the consumed reactive and active powers during the observation window $[t_k, t_{k+1})$ as $\Delta_{c,k}$ and $\Delta_{\rho,k}$, respectively. We then update the droop function $K_{i,k}$ accordingly, in the droop controllers Σ_i defined as follows

$$\Sigma_i : \dot{q}_{g,i} = -\frac{1}{\tau_i} q_{g,i} + \frac{1}{\tau_i} K_{i,k}(\bar{v}^2 - v_i^2), \quad \forall t \in [t_k, t_{k+1}), \quad (3)$$

where $\tau_i \in \mathbb{R}_{>0}$ is the time-constant of the inverter's response and the droop function $K_{i,k}(w)$ is a static mapping from the difference of the squared voltages w to the set-point for the reactive power, updated at t_k . The droop function $K_{i,k}$ satisfies the slope-restriction and saturation property (4) as assumed in Chong et al. (2019a), which we state in the following assumption.

Assumption 2. During each observation window $t \in [t_k, t_{k+1})$, $k \in \mathbb{N}$, the droop function $K_{i,k}$, $i \in \mathbb{N}_{[1,N]}$ in (3) satisfies

$$0 \leq \frac{K_{i,k}(v) - K_{i,k}(w)}{v - w} \leq d_{i,k}, \quad \forall v, w \in \mathbb{R}, v \neq w, \quad (4)$$

and $|K_{i,k}(v)| \leq \bar{K}_{i,k}$, for all $v \in \mathbb{R}$, where $d_{i,k} \geq 0$ and $\bar{K}_{i,k} \geq 0$. \square

The parameter $d_{i,k}$ is a design parameter chosen according to the condition in Section 4.

At each update time t_k , we reset the state of all the controllers (3) to zero³ as follows

$$q_{g,i}(t_k^+) = 0. \quad (5)$$

Under this setup, we aim to meet the voltage regulation objective (2).

³ This choice was made to simplify the re-design of the droop function $K_{i,k}$ according to condition (10) in Theorem 3.

4. ADAPTIVE SCHEME FOR VOLTAGE REGULATION

To assist in formulating our main result, we rewrite the distribution model (1) and droop controllers (3) in new coordinates, with $y_i = \bar{v}^2 - v_i^2$, $\eta_i := v_{i-1}^2 - v_i^2$ for $i \in \mathbb{N}_{[1,N]}$ and $y_0 := \bar{v}^2 - v_0^2$. The resulting system for $i \in \mathbb{N}_{[1,N]}$ is

$$\begin{aligned} \dot{q}_{g,i} &= -\frac{1}{\tau_i} q_{g,i} + \frac{1}{\tau_i} K_{i,k}(y_i), & t \in [t_k, t_{k+1}), \\ q_{g,i}(t_k^+) &= 0, \\ y_i &= \eta_i + y_{i-1}, \\ \eta_i &= v_{i-1}^2 - v_i^2 + v_i^2 - v_i^2, \\ &= 2\beta_{i-1}(P_{i-1}, Q_{i-1}) + 2\beta'_{i-2}(\rho_{i-1}, q_{i-1}) \\ &\quad - 2\beta'_{i-1}(\rho_i, q_i), \end{aligned} \quad (6)$$

where we recall that $\beta_i(r, s) = R_i r + X_i s$, $\beta'_i(r, s) = R'_i r + X'_i s$ and $\beta'_{-1}(r, s) = 0$ for all $r, s \in \mathbb{R}$.

Our voltage regulation objective (2) can then be restated in the new coordinates as:

$$|\bar{v}^2 - v_i(t)^2| = |y_i(t)| \leq \epsilon, \quad \forall i \in \mathbb{N}_{[1,N]}, \forall t \geq 0, \quad (7)$$

where $\epsilon := -\delta^2 + 2\bar{v}\delta$. Note that the satisfaction of (7) implies that objective (2) holds. Henceforth, we will state our main result such that that the equivalent objective (7) is satisfied.

Before doing so, we write the system (6) in the compact form below, by applying (Chong et al., 2019a, Proposition 4). Let $q_g := (q_{g,1}, q_{g,2}, \dots, q_{g,N})$, $q_c := (q_{c,1}, q_{c,2}, \dots, q_{c,N})$, $\rho := (\rho_1, \rho_2, \dots, \rho_N)$ and $y := (y_1, y_2, \dots, y_N)$. The model (6) in compact form is written as follows

$$\begin{aligned} \dot{q}_g &= A(\tau)q_g - A(\tau)K_k(y), & t \in [t_k, t_{k+1}), \\ q_g(t_k^+) &= 0, \\ y &= Hq_g + \phi(\rho, q_c) + y_0 \mathbf{1}_{N \times 1}, \end{aligned} \quad (8)$$

where

- $A(\tau) = \text{diag}\left(-\frac{1}{\tau_1}, -\frac{1}{\tau_2}, \dots, -\frac{1}{\tau_N}\right)$,
- $K_k(y) = (K_{1,k}(y_1), K_{2,k}(y_2), \dots, K_{N,k}(y_N))$,
-

$$H = -2 \begin{pmatrix} X_0 & X_0 & \dots & X_0 \\ \star & (X_0 + X_1) & \dots & (X_0 + X_1) \\ \vdots & \ddots & \ddots & \vdots \\ \star & \dots & \star & \sum_{i \in \mathbb{N}_{[0, N-1]}} X_i \end{pmatrix} - 2\text{diag}(X'_0, \dots, X'_{N-1}),$$

where \star denotes a block component of a symmetric matrix,

- $\phi(\rho, q_c) = \left(\phi_0, \dots, \sum_{i \in \mathbb{N}_{[0, j-1]}} \phi_i + \sum_{i \in \mathbb{N}_{[0, j-2]}} 2\beta'_i(\rho_{i+1}, q_{c, i+1}) \right)$,
- $\dots, \sum_{i \in \mathbb{N}_{[0, N-1]}} \phi_i + \sum_{i \in \mathbb{N}_{[0, N-2]}} 2\beta'_i(\rho_{i+1}, q_{c, i+1}) \Big)$,

where

$$\begin{aligned} \phi_i(\rho, q_c) &:= 2X_i \left(\sum_{j \in \mathbb{N}_{[i+1, N]}} q_{c, j} \right) - 2R_i \left(\sum_{j \in \mathbb{N}_{[i+1, N]}} \rho_j \right) \\ &\quad - 2\beta'_i(\rho_{i+1}, q_{c, i+1}). \end{aligned}$$

Let $\{t_k\}_{k \in \mathbb{N}}$ where $t_{k+1} - t_k \geq T > 0$, $\{\Delta_{c,k}\}_{k \in \mathbb{N}}$ and $\{\Delta_{\rho,k}\}_{k \in \mathbb{N}}$ be a sequence of update time instants, a se-

quence of a priori known bounds on the consumed reactive power and net injected active power, respectively. We are now ready to state our main result, where the proof can be found in a full version of this paper [Chong and Sandberg (2020)].

Theorem 3. Consider the distribution model (1) and droop controllers (3) with N customers under Assumption 1 and 2. For any $\epsilon \geq 0$, if there exist $\Delta_{\phi,k} = \Delta_{\phi,k}(\Delta_{\rho,k}, \Delta_{c,k}) > 0$ and $\epsilon_y > 0$ for all $k \in \mathbb{N}$, such that

$$\epsilon \geq \Delta_{\phi,k} + \epsilon_y, \quad (9)$$

then there exist $d_k \geq 0$, $\bar{K}_k \geq 0$, $\tau_{\max} > 0$ and $\tau_{\min} > 0$ satisfying

$$d_k \leq \frac{(\epsilon - \Delta_{\phi,k} - \epsilon_y) \exp(-t_k/\tau_{\max})}{\frac{\tau_{\max}}{\tau_{\min}} |H| (\Delta_{\phi,k} + \epsilon_y) + \left(\frac{\tau_{\max}}{\tau_{\min}}\right)^2 |H|^2 \bar{K}_k}, \quad (10)$$

where

- $d_k := \max_{i \in \mathbb{N}_{[1,N]}} d_{i,k}$,
- $\tau_{\max} := \max_{i \in \mathbb{N}_{[1,N]}} \tau_i$ and $\tau_{\min} := \min_{i \in \mathbb{N}_{[1,N]}} \tau_i$,
- $\bar{K}_k := \max_{i \in \mathbb{N}_{[1,N]}} \bar{K}_{i,k}$,
-

$$\Delta_{\phi,k} := N(N+1) (\bar{R} \Delta_{\rho,k} + \bar{X} \Delta_{c,k}) + 2(2N-1) (\bar{R}' \Delta_{\rho,k} + \bar{X}' \Delta_{c,k}),$$

where

$$\begin{aligned} \cdot \bar{R} &:= \max_{i \in \mathbb{N}_{[1,N-1]}} R_i, \bar{R}' := \max_{i \in \mathbb{N}_{[0,N-2]}} R'_i, \\ \cdot \bar{X} &:= \max_{i \in \mathbb{N}_{[1,N-1]}} X_i, \bar{X}' := \max_{i \in \mathbb{N}_{[0,N-2]}} X'_i, \end{aligned}$$

- $|\bar{v}^2 - v'_0(t)^2| \leq \epsilon_y$, for all $t \geq 0$,

such that the received voltage v_i of each customer i meets the voltage regulation objective (7). \square

The sufficient condition (10) in Theorem 3 provides a guideline for adapting the droop controller (3) according to the a priori known bounds $\Delta_{c,k}$, $\Delta_{\rho,k}$ on the power consumption during each observation window $[t_k, t_{k+1})$, $k \in \mathbb{N}$. The design parameter d_k in (10) guides the design of the droop function $K_{i,k}$ in each of the droop controllers (3). For instance, a piecewise saturation function commonly considered in the literature such as Andr en et al. (2015) takes the form below

$$K_{i,k}(w) := \begin{cases} -\bar{Q}_{i,k}, & w \leq w_{\min,i,k}, \\ -\left(1 - \frac{w - w_{\min,i,k}}{w_{m,i,k} - w_{\min,i,k}}\right) \bar{Q}_{i,k}, & w \in (w_{\min,i,k}, w_{m,i,k}], \\ 0, & w \in (w_{m,i,k}, w_{n,i,k}], \\ \left(\frac{w - w_{n,i,k}}{w_{\max,i,k} - w_{n,i,k}}\right) \bar{Q}_{i,k}, & w \in (w_{n,i,k}, w_{\max,i,k}], \\ \bar{Q}_{i,k}, & w > w_{\max,i,k}, \end{cases} \quad (11)$$

where $w_{\min,i,k} \leq w_{m,i,k} \leq 0 \leq w_{n,i,k} \leq w_{\max,i,k}$ are design parameters, $\bar{Q}_{i,k} \in \mathbb{R}_{\geq 0}$ is the saturation limit of the i -th inverter satisfying $\bar{Q}_{i,k} = \bar{s}_i$, where $\bar{s}_i \in \mathbb{R}$ is the maximum apparent power of the i -th inverter. This droop function (11) satisfies Assumption 2 with $\bar{K}_{i,k} = \bar{Q}_{i,k}$ and

$$d_{i,k} := \min \left\{ \frac{\bar{Q}_{i,k}}{w_{\max,i,k} - w_{n,i,k}}, \frac{\bar{Q}_{i,k}}{w_{m,i,k} - w_{\min,i,k}} \right\}. \quad (12)$$

5. CASE STUDY ON A BENCHMARK MODEL

We validate our results on a benchmark model of $N = 5$ customers in the residential feeder of the European low voltage CIGRE distribution grid (Strunz et al., 2009, Fig. 7.7), shown in Figure 2. The topology of the benchmark model can be mapped to our model shown in Figure 1 according to Table 1. The model parameters as found in (Strunz et al., 2009, Table 7.26) are summarised in Table 2. The reference voltage \bar{v} communicated to each customer is $\bar{v} = 230$ V and the nominal voltage at the substation is $v'_0(t) = \bar{v} + 5 \sin(t)$ V to model harmonic perturbations.




Fig. 2. Residential feeder of the European low voltage CIGRE benchmark grid. Arrows in **black** represent loads and the arrows in **green** represent inverters.

Table 1. Mapping of nodes from the benchmark topology to our topology

Node label	
Benchmark topology (Strunz et al., 2009, Fig. 7.7) in Figure 2	Our topology in Figure 1
R1	v'_0
R3	v'_1
R11	v_1
R4	v'_2
R15	v_2
R6	v'_3
R16	v_3
R9	v'_4
R17	v_4
R10	v'_5
R18	v_5

Table 2. Parameters as found in (Strunz et al., 2009, Table 7.26)

i	1	2	3	4	5
R_{i-1} [Ω]	0.00343	0.00172	0.00343	0.00515	0.00172
X_{i-1} [Ω]	0.04711	0.02356	0.04711	0.07067	0.02356
R'_{i-1} [Ω]	0.00147	0.00662	0.00147	0.00147	0.00147
X'_{i-1} [Ω]	0.02157	0.09707	0.02157	0.02157	0.02157
Apparent power of each inverter \bar{s}_i , [VA]	4200	6500	4700	5300	3600

Our simulation study considers the observation instants $t_0 = 0$ s, $t_1 = 100$ s, $t_2 = 200$ s and $t_3 = 300$ s, where the a priori known upper bounds on the net active power and the consumed reactive power has changed in between the observation instants as shown in Table 3 and as seen in Figure 3. All the inverters (3) have a time constant of $\tau_i = 100$, for $i \in \mathbb{N}_{[1,N]}$. By applying Theorem 3, we choose the design parameter d_k according to (10) which then guides the design of the droop functions $K_{i,k}$ in (11) by choice of the droop characteristics $w_{\min,i,k}$, $w_{m,i,k}$,

$w_{n,i,k}$ and $w_{\max,i,k}$. Here, the saturation value $\bar{K}_{i,k}$ is set to the apparent power \bar{s}_i of each inverter, $\bar{K}_{i,k} = \bar{s}_i$, for all $k \in \mathbb{N}$ (c.f. Table 2 for values of \bar{s}_i). Hence, by the physical capabilities of the inverter, the injected active power is limited to $\rho_{g,i} \leq \sqrt{\bar{s}_i^2 - q_{g,i}^2}$. Figure 4 shows that the resulting adaptive scheme achieves the voltage regulation objective (2).




Fig. 3. Reactive $q_{c,i}$ and active $\rho_{c,i}$ powers consumed by each customer i .

Table 3. Simulation scenario and the application of (10) in Theorem 3

Observation window $[t_k, t_{k+1})$	$k = 0$	$k = 1$	$k = 2$
Upper bound on the net injected active power for all customers, $\Delta_{\rho,k}$	460	1300	750
Upper bound on the consumed reactive power for all customers, $\Delta_{c,k}$	360	1200	960
d_k obtained from (10) in Theorem 3	0.1418	0.0181	0.0099
Parameters of the droop function $K_{i,k}$, $i \in \mathbb{N}_{[1,5]}$ in (11) according to d_k :			
$[w_{\max,i,k}]$	$\begin{bmatrix} 29613 \\ 45830 \\ 33138 \\ 37369 \\ 25383 \end{bmatrix}$	$\begin{bmatrix} 232320 \\ 359540 \\ 259980 \\ 293160 \\ 199130 \end{bmatrix}$	$\begin{bmatrix} 423930 \\ 656080 \\ 474390 \\ 534950 \\ 363360 \end{bmatrix}$
$w_{\min,i,k} = -w_{\max,i,k}$			
$w_{m,i,k} = w_{n,i,k}$	0	0	0

For comparison, we consider the case where we do not adapt the droop controller (3) in accordance to the known bounds $\Delta_{c,k}$ and $\Delta_{\rho,k}$ for each observation window. Instead, only an initial design based on the largest known bound for the entire observation window $[t_0, t_3)$ for the droop controller (3) is used, i.e. we design the droop function $K_{i,k}$ for all $i \in \mathbb{N}_{[1,N]}$, $k \in \mathbb{N}_{[0,3]}$ based on the maximal known bounds $\Delta_c = \max_{k \in \mathbb{N}_{[0,2]}} \Delta_{c,k} = 1200$, $\Delta_\rho = \max_{k \in \mathbb{N}_{[0,2]}} \Delta_{\rho,k} = 1300$, resulting




Fig. 4. Adaptive droop controllers: Vertical red lines indicate the observation instants t_k , $k \in \mathbb{N}_{[0,2]}$. Legend: Customer 1 (blue), 2 (red), 3 (orange), 4 (purple), 5 (green). (Top) Solid lines indicate the output of the droop controllers $q_{g,i}$. (Middle) The active power $\rho_{g,i}$ injected into the distribution line by each customer i . (Bottom) Solid lines indicate the voltages of each customer v_i are within 10 % of the nominal voltage \bar{v} for all $t \geq 0$. Dashed lines indicate $(1 \pm p)\bar{v}$, where $p = 0.1$.

in $d_{i,k} = 0.3251$ and consequently, $w_{m,i,k} = w_{n,i,k} = 0$, $[w_{\max,i,k}] = [12918, 19992, 14456, 16301, 11073]$, and $w_{\min,i,k} = -w_{\max,i,k}$ for $i \in \mathbb{N}_{[1,5]}$ and $k \in \mathbb{N}_{[0,3]}$. Figure 5 shows that the voltage regulation objective (7) is achieved.

We use the performance metrics $\mathcal{P}_q := \int_0^{t_3} |q_g(s)| ds$ and $\mathcal{P}_\rho := \int_0^{t_3} |\rho_g(s)| ds$ to compare the adaptive vs. non-adaptive droop controllers. The metric \mathcal{P}_q is motivated by achieving the voltage regulation objective with less reactive power generated by the inverter. The metric \mathcal{P}_ρ is used to monitor profit as increasing the injection of active power into the distribution network increases the generation of revenue. For the simulation scenario described, the adaptive scheme outperforms the non-adaptive scheme in the aforementioned performance metrics with $\mathcal{P}_q = 2.9456$ [kJ], $\mathcal{P}_\rho = 1.6182$ [MJ] (adaptive) and $\mathcal{P}_q = 30.833$ [kJ], $\mathcal{P}_\rho = 1.2404$ [MJ] (non-adaptive).

6. CONCLUSIONS AND FUTURE WORK

We have presented a scheme that adapts to the known bounds of the load's net power consumption with guar-




Fig. 5. Non-adaptive droop controllers: Vertical red lines indicate the observation instants t_k , $k \in \mathbb{N}_{[0,2]}$. Legend: Customer 1 (blue), 2 (red), 3 (orange), 4 (purple), 5 (green). (Top) Solid lines indicate the output of the droop controllers $q_{g,i}$. (Middle) The active power $\rho_{g,i}$ injected into the distribution line by each customer i . (Bottom) Solid lines indicate the voltages of each customer v_i are within 10 % of the nominal voltage \bar{v} for all $t \geq 0$. Dashed lines indicate $(1 \pm p)\bar{v}$, where $p = 0.1$.

antees on each customers' voltage being within a desired safety margin through local inverters injecting reactive power into the distribution network. Future work will take into account the unmodelled dynamics in the power distribution line.

7. ACKNOWLEDGEMENT

We are thankful to Catalin Gavriluta and David Umsonst for the discussions leading to this work and for reproducing Figure 2 from Strunz et al. (2009).

REFERENCES

Andr n, F., Bletterie, B., Kadam, S., Kotsampopoulos, P., and Bucher, C. (2015). On the stability of local voltage control in distribution networks with a high penetration of inverter-based generation. *IEEE Transactions on Industrial Electronics*, 62(4), 2519–2529.

Baran, M. and Wu, F. (1989). Network reconfiguration in distribution systems for loss reduction and load balancing. *IEEE Transactions on Power delivery*, 4(2), 1401–1407.

Chong, M., Umsonst, D., and Sandberg, H. (2019a). Local voltage control of an inverter-based power distribution network with a class of slope-restricted droop controllers. In *Proceedings of the 8th IFAC Workshop on Distributed Estimation and Control in Networked Systems*.

Chong, M., Umsonst, D., and Sandberg, H. (2019b). Voltage regulation of a power distribution network in a radial configuration with a class of sector-bounded droop controllers. In *Proceedings of the 2019 IEEE Conference on Decision and Control*.

Chong, M.S. and Sandberg, H. (2020). Adaptive voltage regulation of an inverter-based power distribution network with a class of droop controllers. arXiv:2005.04060 [math.OC].

Farivar, M., Chen, L., and Low, S. (2013). Equilibrium and dynamics of local voltage control in distribution systems. In *52nd IEEE Conference on Decision and Control*, 4329–4334. IEEE.

Han, R., Meng, L., Ferrari-Trecate, G., Coelho, E., Vasquez, J., and Guerrero, J. (2017). Containment and consensus-based distributed coordination control to achieve bounded voltage and precise reactive power sharing in islanded ac microgrids. *IEEE Transactions on Industry Applications*, 53(6), 5187–5199.

Jafarian, M., Sandberg, H., and Johansson, K. (2018). The interconnection of quadratic droop voltage controllers is a Lotka-Volterra system: implications for stability analysis. *IEEE Control Systems Letters*, 2(2), 218–223.

Jahangiri, P. and Aliprantis, D. (2013). Distributed Volt/VAR control by PV inverters. *IEEE Transactions on Power Systems*, 28(3), 3429–3439.

Liu, Y., Bebic, J., Kroposki, B., De Bedout, J., and Ren, W. (2008). Distribution system voltage performance analysis for high-penetration photovoltaics. In *IEEE Energy 2030 Conference*, 1–8. IEEE.

Lopes, J., Hatziargyriou, N., Mutale, J., Djapic, P., and Jenkins, N. (2007). Integrating distributed generation into electric power systems: A review of drivers, challenges and opportunities. *Electric power systems research*, 77(9), 1189–1203.

Schiffer, J., Ortega, R., Astolfi, A., Raisch, J., and Sezi, T. (2014). Conditions for stability of droop-controlled inverter-based microgrids. *Automatica*, 50(10), 2457–2469.

Simpson-Porco, J., D rfler, F., and Bullo, F. (2017). Voltage stabilization in microgrids via quadratic droop control. *IEEE Transactions on Automatic Control*, 62(3), 1239–1253.

Strunz, K., Hatziargyriou, N., Andrieu, C., et al. (2009). Benchmark systems for network integration of renewable and distributed energy resources. *CIGRE Task Force C, 6(04-02)*, 78.

Turitsyn, K.,  ulc, P., Backhaus, S., and Chertkov, M. (2010). Distributed control of reactive power flow in a radial distribution circuit with high photovoltaic penetration. In *IEEE Power and Energy Society General Meeting*, 1–6. IEEE.

Zhu, H. and Liu, H. (2016). Fast local voltage control under limited reactive power: Optimality and stability analysis. *IEEE Transactions on Power Systems*, 31(5), 3794–3803.